

Appendices

Appendices

Table of Contents

Appendix 1	Member List of the Study Team	2
Appendix 2	Survey Schedule	4
Appendix 3	List of Party Concerned in the Recipient Country	6
Appendix 4	Minutes of Discussion	8
Appendix 5	Other Relevant Data.....	22
Appendix 5- 1	Investment Program for PPWSA from 1993-2004.....	22
Appendix 5- 2	Present Conditions of Phum Prek Water Treatment Plant.....	24
Appendix 5- 3	Results of Population Projection and Water Demand Estimation	28
Appendix 5- 4	Water Quality Monitoring Date.....	32
Appendix 5- 5	Analysis of Distributed Water Volume, Leakage and Daily Maximum Coefficient	38
Appendix 5- 6	Boring Date (Survey Locations).....	45
Appendix 5- 7	Planned Facilities and Equipment	57
Appendix 5- 8	Operation and Maintenance Costs of Electricity and Chemicals	62
Appendix 5- 9	Permission of Installation of Raw Water Mains.....	65
Appendix 5- 10	Permission of Installation of Raw Water Mains (Telecommunication building site).....	69
Appendix 5- 11	Registration of Landfill Land of Phum Prek Water Treatment Plant.....	72

Appendix 1 Member List of the Study Team

1-1 Basic Design Survey

- (1) Ms. Keiko YAMAMOTO, Leader
Senior Technical Advisor,
Japan International Cooperation Agency (JICA)
- (2) Ms. Makiko WATANABE, Project Coordinator
First Project Management Division, Grant Aid Management Department,
Japan International Cooperation Agency (JICA)
- (3) Mr. Hidetoshi HAGA, Project Manager / Operation and Management Planning
TOKYO ENGINEERING CONSULTANTS CO., LTD.
- (4) Mr. Hiroataka SATO, Water Treatment Planning
TOKYO ENGINEERING CONSULTANTS CO., LTD.
- (5) Mr. Takayuki TANGE, Facility Planning
TOKYO ENGINEERING CONSULTANTS CO., LTD.
- (6) Mr. Junichi WATANABE, Socio-Economic Survey
NIHON SUIDO CONSULTANTS CO., LTD.
- (7) Mr. Hisamitsu TANAKA, Cost Estimation
TOKYO ENGINEERING CONSULTANTS CO., LTD.
- (8) Mr. Takuro NUKAZAWA, Facility Planning (CAD), Cost Estimation
TOKYO ENGINEERING CONSULTANTS CO., LTD.

1-2 Explanation and Discussion for the Draft Basic Design Report

- (1) Ms. Keiko YAMAMOTO, Leader
Senior Technical Advisor,
Japan International Cooperation Agency (JICA)
- (2) Ms. Makiko WATANABE, Project Coordinator
First Project Management Division, Grant Aid Management Department,
Japan International Cooperation Agency (JICA)
- (3) Mr. Hidetoshi HAGA, Project Manager / Operation and Management Planning
TOKYO ENGINEERING CONSULTANTS CO., LTD.

(4) Mr. Hirotaka SATO, Water Treatment Planning
TOKYO ENGINEERING CONSULTANTS CO., LTD.

(5) Mr. Takayuki TANGE, Facility Planning
TOKYO ENGINEERING CONSULTANTS CO., LTD.

Appendix 2 Survey Schedule

2-1 Basic Design Survey

No.	Date	JICA Officers	Project Manager/ Operation and Management Planning	Water Treatment Planning	Facility Planning	Socio-Economy Survey	Cost estimation / Procurement Planning	
1	6/10	Sat			Narita to Bangkok			
2	11	Sun			Arrive to Phnom Penh, Preparation for soil testing			
3	12	Mon			Courtesy call to and discussion with PPWSA,			
4	13	Tue			Preparation for soil testing			
5	14	Wed			Preparation for geographic survey			
6	15	Thu			Preparation for geographic survey			
7	16	Fri			Preparation for geographic survey			
8	17	Sat			Preparation for geographic survey			
9	18	Sun	Narita to Bangkok					
10	19	Mon	Arrive to Phnom Penh, Courtesy call on Embassy of Japan and JICA Cambodia Office, Discussion with PPWSA (Explanation of Inception Report)					
11	20	Tue	Site survey (Phum Prek, Chrouy Chang War, Chamcar Morn treatment plant, 7th January/Toul Kork district)					
12	21	Wed	Discussion with PPWSA, Courtesy call on ADB and World Bank Meeting with Mr. Ueda (JICA expert)					
13	22	Thu	Discussion with PPWSA (Discussion on M/M)					
14	23	Fri	Discussion with PPWSA (Discussion on M/M) Signing of the M/M					
15	24	Sat	Additional site survey/discussion (if necessary)					
16	25	Sun	Internal meeting					
17	26	Mon	Report to Embassy of Japan and JICA Office Leave Phnom Penh					
18	27	Tue	Arrive to Narita	Internal discussion on components of the project and the survey Formulation of survey contents and schedule				
19	28	Wed	Confirmation of contents of the project and the survey	Site investigation and data collection of water source	Preparation for soil testing and route and plan survey	Data collection on socio-economy		
20	29	Thu	Site investigation for surveys	Site investigation and data collection of water source	Site investigation for surveys	Data collection on socio-economy		
21	30	Fri	Contract with surveyor	Analysis of evaluation of water sources	Contract with surveyor	Data collection on socio-economy		
22	7/1	Sat	Data and report review	Data and report review	Data and report review	Data and report review		
23	2	Sun						
24	3	Mon	Investigation and date collection of existing facility	Investigation and date collection of existing facility	Investigation and date collection of existing facility	Data collection of water supply condition, Environmental survey		
25	4	Tue	Investigation and date collection of existing facility	Investigation and date collection of existing facility	Investigation and date collection of existing facility	Data collection of water supply condition		
26	5	Wed	Investigation and date collection of existing facility	Investigation and date collection of existing facility	Investigation and date collection of existing facility	Data collection of water supply condition		
27	6	Thu	Analysis and evaluation of existing facility	Analysis and evaluation of existing facility	Analysis and evaluation of existing facility	Water demand estimation		
28	7	Fri	Analysis and evaluation of existing facility	Analysis and evaluation of existing facility	Analysis and evaluation of existing facility	Water demand estimation		
29	8	Sat	Data and report review	Data and report review	Data and report review	Water demand estimation		
30	9	Sun						
31	10	Mon	Data collection of management and O&M	Additional investigation and date collection	Additional investigation and date collection	Environmental survey		
32	11	Tue	Investigation of management and O&M	Additional investigation and date collection	Investigation of power supply	Water demand estimation,	Narita to Bangkok	

							Environmental survey	
33	12	Wed		Data collection of management and O&M	Water demand estimation, Environmental survey	Investigation of power supply	Water demand estimation, Environmental survey	Arrival to Phnom Penh Formulation of survey contents and schedule
34	13	Thu		Data collection of management and O&M	Analysis for expansion capacity	Analysis for expansion capacity	Report writing on socio-economy and water demand estimation	Data collection of procurement and cost estimate
35	14	Fri		discussion on socio-economy and water demand estimation	discussion on socio-economy and water demand estimation	Analysis for expansion	discussion on socio-economy and water demand estimation	Data collection of procurement and cost estimate
36	15	Sat		Data and report review	Data and report review	Data and report review	Handing over data and survey results	Data review
37	16	Sun					Leave Phnom Penh	
38	17	Mon		Data collection of O&M	Planning of WTP	Designing of WTP	Arrival to Narita	Data collection of procurement and cost estimate
39	18	Tue		Data collection of O&M	Planning of WTP	Designing of WTP		Data collection of procurement and cost estimate
40	19	Wed		Data collection of O&M	Planning of WTP	Designing of WTP		Data collection of procurement and cost estimate
41	20	Thu		Analysis and evaluation of management and O&M	Analysis of distribution networks	Summary of soil testing and surveys		Data collection of procurement and cost estimate
42	21	Fri		Analysis and evaluation of management O&M	Analysis of distribution networks	Summary of soil testing and surveys		Survey of construction
43	22	Sat		Data and report review	Data and report review	Data and report review		Data and report review
44	23	Sun						
45	24	Mon		Summary of facility planning and designing	Summary of facility planning and designing	Summary of facility planning and designing		Survey of construction
46	25	Tue		Discussion on technical cooperation	Analysis of project benefits	Discussion on technical cooperation		Preliminary estimation of the project cost
47	26	Wed		Confirmation of the works to be conducted by the Cambodian side	Analysis of project benefits	Confirmation of the works to be conducted by the Cambodian side		Preliminary estimation of the project cost
48	27	Thu		Internal meeting and report writing	Internal meeting and report writing	Internal meeting and report writing		Internal meeting and report writing
49	28	Fri		Reporting survey results to PPWSA	Reporting survey results to PPWSA	Reporting survey results to PPWSA		Reporting survey results to PPWSA
50	29	Sat		Report writing	Report writing	Report writing		Report writing
51	30	Sun						
52	31	Mon		Report to Embassy of Japan and JICA Office, Leave Phnom Penh	Report to Embassy of Japan and JICA Office, Leave Phnom Penh	Report to Embassy of Japan and JICA Office, Leave Phnom Penh		Report to Embassy of Japan and JICA Office, Leave Phnom Penh
53	8/1	Tue		Arrival to Narita	Arrival to Narita	Arrival to Narita		Arrival to Narita

2-2 Explanation and Discussion for the Draft Basic Design Report

No.	Date	Moving	Contents
1	10/1(Sun)	Leave Japan and arrive Bangkok	Stay Bangkok
2	2(Mon)	Leave Bangkok and arrive Phnom Penh	Courtesy Call on the Embassy of Japan JICA Cambodia Office and PPWSA and submission of the draft report
3	3(Tue)		Explanation and discussion of the draft report
4	4(Wed)		Additional site survey Courtesy call of the Council for the Development of Cambodia(CD) Discussion of the draft report
5	5(Thu)		Discussion of the draft report and M/D
6	6(Fri)		Signing of M/D Report to the Embassy of Japan and JIA Cambodia Office
7	7(Sat)	JICA members leave Phnom Penh	Collection of additional data on cost estimation
8	8(Sun)		Analysis of the data
9	9(Mon)	Consultant members leave Phnom Penh and arrive Bangkok	Collection of additional data on cost estimation Report to PPWSA
10	10(Tue)	Consultant members leave Bangkok and arrive Japan	Arrive in Japan

Appendix 3 List of Party Concerned in the Recipient Country

◆ Phnom Penh Water Supply Authority (PPWSA)

Mr. EK SONG CHAN	General Director
Mr. Long Naro	Director of Technical and Project Department
Mr. Ma Noravin	Hydraulic and design engineer, Technical and Project Dept.
Mr. Tan Bounneth	Vice Chief, Phum Prek Water Treatment Plant
Mr. Sun Sokhe	Water and Wastewater engineer
Mr. Chia Shim	Dept of Sanitation
Mr. Sim Kheng Lin	Director of Commercial Dept.
Mr.	
Mr. Tetsuya Ueda	Short-term professional
Ms. Atsuko Kobashikawa	JOCV (Water quality management)
Ms. Amporn Kakanlaung	Third Country JICA Expert (Bangkok Metropolitan Water Supply Authority in Thailand)

◆ Municipality of Phnom Penh

Mr. Chea Sophara	Governor
Mr. Mann Chhceurn	Chie Cabinet
Mr. Tauch Lavinoran	Assistant to H.E. Sengtong, Vice Governor of Phnom Penh Municipality
Mr. Ouch Vann	Director, Waste Water Cleaning
Mr. Chhorng Vautha	Chief of planning of Section of drainage and Sewage
Dr. Chhouv Kongphally	Chief of Health Promotion, Dept. of Health
Ms. Mom Sandap	Director, Dept. of Planning
Mr. Ean Narin	Project Manager, Project Management Unit

◆ Ministry of Planning

Mr. San Sy Than	Director, National Institute of Statistics
San Sy Than	Director National Institute of
Mr. Son Seng Huot	Director

◆ Ministry of Post and Telecommunication

Mr. Ly Sam An	Director of International Telecom Department
---------------	--

Minutes of Discussions
on
the Basic Design Study on the Project for Expansion of
Phum Prek Water Treatment Plant
in
The Kingdom of Cambodia

In response to a request from the Royal Government of Cambodia, the Government of Japan decided to conduct a Basic Design Study on the Project for Expansion of Phum Prek Water Treatment Plant (hereinafter referred to as "the Project"), and entrusted the study to Japan International Cooperation Agency (hereinafter referred to as 'JICA').

JICA sent to Cambodia the Basic Design Study Team (hereinafter referred to as 'the Team'), which is headed by Ms. Keiko Yamamoto, Senior Technical Adviser, JICA, and is scheduled to stay in the country from the 19th June to the 31st July, 2000.



The Team held a series of discussions with the concerned officials of the Royal Government of Cambodia and conducted a field survey at the study area.

In the course of discussions and field survey, both parties confirmed the main items described on the attached sheets. The Team will proceed to further work and prepare the Basic Design Study Report.

Phnom Penh, 23rd June, 2000



Ms. Keiko Yamamoto
Leader
Basic Design Study Team
Japan International Cooperation Agency



Sonn Chan
General Director
Phnom Penh Water Supply Authority

ATTACHMENT

1. Objective of the Project

The objective of the Project is to improve the health and living standard of the people in Phnom Penh City by improving the water supply condition through expansion of Phum Prek Water Treatment Plant.

2. Project site

The site of the Project is Phum Prek Water Treatment Plant, as shown in Annex-1.

3. Responsible and Implementing Organization

Responsible organization and the implementing organization is Phnom Penh Water Supply Authority (PPWSA). The organization chart is shown in Annex-2.

4. Items requested by PPWSA

After discussions with the Team, the items described in Annex-3 were finally requested by Cambodian side. However, both sides agreed that the final components of the Project will be determined by Japanese side after further studies in Japan.

5. Japan's Grant Aid Scheme

5-1. Cambodian side understood the system and characteristics of Japan's Grant Aid Scheme explained by the Team, as described in Annex-4.

5-2. Cambodian side will take necessary measures, as described in Annex-5, for smooth implementation of the Project, as a condition for the Japanese Grant Aid to be implemented.

6. Schedule of the Study

6-1. The consultants will proceed to further studies in Cambodia until the 31st July, 2000.

6-2. JICA will prepare the draft report in English and dispatch a mission to Cambodia in order to explain its contents in or around October, 2000.

6-3. In case the contents of the report is accepted in principle by PPWSA, JICA will complete the final report and send it to PPWSA in or around January, 2001.

1/2 2

7. Other relevant issues

7-1. Cambodian side promised to submit the land use permission for conveyance pipeline and the land use right for the reclaimed land for distribution water reservoir from the Municipality of Phnom Penh by 31st July, 2000.


7-2. Both sides agreed to set the target year of the Project at the year 2005, and review the future water demand until the year 2015 in accordance with the action plan developed by PPWSA.

7-3. Cambodian side promised that PPWSA will allocate enough budget and staff with appropriate technical skills to ensure proper and effective operation and maintenance of the facilities and equipment provided under the Project.

7-4. With concern to the quality of water from existing treatment facility, PPWSA requested an assistance of a Japanese expert regarding the water treatment process.

h e

Annex-1 Site of the Project



h r

Annex-3 List of requested items

1. Expansion of the facilities

- (1) Water treatment facility for 50,000m³/day
 - Receiving chamber
 - Rapid mixing chamber
 - Flocculation basin
 - Sedimentation basin
 - Rapid sand gravity filter
- (2) Chemical dosing system for 150,000m³/day
 - Chemical house including storage and laboratory with necessary equipment
 - Chemical dosing facilities
- (3) Distribution water reservoir for 10,000m³/day
- (4) Distribution pump (1 unit)
- (5) Conveyance pipeline of dia. 1200mm * 1.5km
- (6) Raw water intake pumps (2 units)
- (7) Electrical instruments

2. Rehabilitation of the existing facilities

- (1) Distribution pumps (3 units)
- (2) Raw water intake pumps (3 units)

Handwritten initials

Annex-4 Japan's Grant Aid Scheme

1. Grant Aid Procedures

- a. Japan's Grant Aid Program is executed through the following procedures.
- Application (A request made by the recipient country)
 - Study (Basic Design Study conducted by JICA)
 - Appraisal & Approval (Appraisal by the Government of Japan and Approval by the Cabinet of Japan)
 - Determination of Implementation (Exchange of Notes between the Governments of Japan and the recipient country)

b. Firstly, the application or request for a Grant Aid project submitted by a recipient country is examined by the Government of Japan (the Ministry of Foreign Affairs) to determine whether or not it is eligible for Grant Aid. If the request is deemed appropriate, the Government of Japan assigns JICA (Japan International Cooperation Agency) to conduct a study on the request.

Secondly, JICA conducts the study (Basic Design Study) using (a) Japanese consulting firm(s).

Thirdly, the Government of Japan appraises the project to see whether or not it is suitable for Japan's Grant Aid Scheme, based on the Basic Design Study Report prepared by JICA, and the results are then submitted to the Cabinet for an approval.

Fourthly, the project, once approved by the Cabinet, becomes official with the Exchange of Notes signed by the Governments of Japan and recipient country.

Finally, for the implementation of the project, JICA will assist the recipient country in such matters as preparing tenders, contract and so on.

H R

2. Basic Design Study

a. Contents of the study

The aim of the Basic Design Study (hereafter referred to as "the Study") conducted by JICA on a requested project (hereafter referred to as "the Project") is to provide a basic document necessary for the appraisal of the Project by the Government of Japan. The contents of the Study are as follows :

- a) Confirmation of the background, objectives, and benefits of the Project and also institutional capacity of agencies concerned of the recipient country necessary for the Project's implementation.
- b) Evaluation of the appropriateness of the Project to be implemented under the Grant Aid Scheme from a technical, social and economic point of view.
- c) Confirmation of items agreed on by both parties concerning the basic concept of the Project.
- d) Preparation of a basic design of the Project.
- e) Estimation of costs of the Project.

The contents of the original request are not necessarily approved in their initial form as the contents of the Grant Aid project. The Basic Design of the Project is confirmed considering the guidelines of the Japan's Grant Aid Scheme.

The Government of Japan requests the Government of the recipient country to take whether measures are necessary to ensure its self-reliance in the implementation of the Project. Such measures must be guaranteed even though they may fall outside of the jurisdiction of the organization in the recipient country actually implementing the Project. Therefore, the implementation of the Project is confirmed by all relevant organizations of the recipient country through the Minutes of Discussions.

13 2

b. Selection of Consultants

For smooth implementation of the Study, JICA uses (a) registered consultant firm(s). JICA select (a) firm(s) based on proposals submitted by interested firms. The firm(s) selected carry(ies) out a Basic Design Study and write(s) a report, based upon terms of reference set by JICA.

The consultant firm(s) used for the Study is(are) recommended by JICA to the recipient country to also work on the Project's implementation after the Exchange of Notes, in order to maintain technical consistency.

3. Japan's Grant Aid Scheme

a. Grant Aid

The Grant Aid Scheme provides a recipient country with non-reimbursable funds to procure the facilities, equipment and services (engineering services and transportation of the products, etc.) for economic and social development of the country under principles in accordance with the relevant laws and regulations of Japan. Grant Aid is not supplied through the donation of materials as such.

b. Exchange of Notes (E/N)

Japan's Grant Aid is extended in accordance with the Notes exchanged by the two Governments concerned, in which the objectives of the Project, period of execution, conditions and amount of the Grant Aid, etc., are confirmed.

c. Period

"The period of the Grant Aid" means the one fiscal year which the Cabinet approves the Project for. Within the fiscal year, all procedures such as exchanging of the Notes, concluding contracts with (a) consultant firm(s) and (a) contractor(s) and final payment to them must be completed.

However, in case of delays in delivery, installation or construction due to unforeseen factors such as weather, the period of the Grant Aid can be further extended for a maximum of one fiscal year at most by mutual

13 R

agreement between the two Governments.

d. Purchase of the Products and or Services

Under the Grant Aid, in principle, Japanese products and services including transport or those of the recipient country are to be purchased.

When the two Governments deem it necessary, the Grant Aid may be used for the purchase of the products or services of a third country.

However, the prime contractors, namely, consulting, constructing and procurement firms, are limited to "Japanese nationals". (The term "Japanese nationals" means persons of Japanese nationality or Japanese corporations controlled by persons of Japanese nationality.)

e. Necessity of "Verification"

The Government of recipient country or its designated authority will conclude contracts denominated in Japanese yen with Japanese nationals. Those contracts shall be verified by the Government of Japan. This "Verification" is deemed necessary to secure accountability to Japanese taxpayers.

f. Undertakings required of the Government of the Recipient Country
(As described in ANNEX 5)

g. Proper Use

The recipient country is required to maintain and use the facilities constructed and the equipment purchased under the Grant Aid properly and effectively and to assign staff necessary for this operation and maintenance as well as to bear all the expenses other than those covered by the Grant Aid.

h. Re-export

The products purchased under the Grant Aid should not be re-exported from the recipient country.

h r

i. Banking Arrangements (B/A)

a) The Government of the recipient country or its designated authority should open an account in the name of the Government of the recipient country in an authorized foreign exchange bank in Japan (hereinafter referred to as "the Bank"). The Government of Japan will execute the Grant Aid by making payments in Japanese yen to cover the obligations incurred by the Government of the recipient country or its designated authority under the Verified Contracts.

b) The payments will be made when payment requests are presented by the Bank to the Government of Japan under an authorization to pay issued by the Government of the recipient country or its designated authority.

h *r*

Annex-5 Necessary Measures to be taken by the Cambodian side

The following necessary measures should be taken by the Cambodian side on condition that the Grant Aid by the Government of Japan is extended to the Project:

1. To provide data and information necessary for the Project.
2. To secure and provide cleared and leveled land for the Project and secure the authority to build facilities prior to the commencement of the construction, especially the land for a new distribution water reservoir.
3. To remove existing facilities such as the existing chemical storage.
4. To use and maintain properly and effectively all the equipment purchased and facilities constructed under the Grant.
5. To bear commissions to the Japanese bank for its banking services based upon the Banking Arrangement, namely the advising commission of the "Authorization to Pay" and payment commission.
6. To ensure prompt unloading, tax exemption, customs clearance at the port of disembarkation and prompt internal transportation therein of the materials and equipment for the Project purchased under the Grant Aid.
7. To exempt Japanese juridical and physical nationals engaged in the Project from customs duties, internal taxes and other fiscal levies which may be imposed in Cambodia with respect to the supply of the products and services under the verified contracts.
8. To accord Japanese nationals whose services may be required in connection with the supply of the products and the services under the verified contract such facilities as may be necessary for their entry into Cambodia and stay therein for the performance of their work in accordance with the relevant laws and regulations of Cambodia.
9. To provide necessary permissions, licenses and other authorizations for implementing the Project, if necessary.
10. To bear all the expenses, other than those to be borne by the Japan's Grant Aid within the scope of the Project.

SR


**Minutes of Discussions
of
Basic Design Study on the Project for Expansion of Phum Prek Water
Treatment Plant
in
The Kingdom of Cambodia
(Explanation on Draft Report)**

In June 2000, the Japan International Cooperation Agency (hereinafter referred to as JICA) dispatched a Basic Design Study Team on the Project for Expansion of Phum Prek Water Treatment Plant (hereinafter referred to as the Project), and through discussion, field survey, and technical examination of the results in Japan, JICA prepared a draft report of the Study.

In order to explain and consult with the concerned officials of the Royal Government of Cambodia on the components of the draft report, JICA sent to Cambodia the Draft Report Explanation Team (hereinafter referred to as 'the Team'), headed by Ms. Keiko Yamamoto, Senior Technical Adviser, JICA, from 2nd October to 9th October, 2000.

As a result of discussions, both parties confirmed the main items described on the attached sheets.

Phnom Penh, 6th October, 2000


Ms. Keiko Yamamoto
Leader
Draft Report Explanation Team
Japan International Cooperation Agency



H.E. Soan Chan
General Director
Phnom Penh Water Supply Authority

ATTACHMENT

1. Components of the Draft Basic Design Report

The Cambodian side agreed and accepted in principle the components of the draft report explained by the Team.

2. Japan's Grant Aid System

The Cambodian side understood the Japan's Grant Aid System as explained by the Team and described in Annex-4 of the Minutes of Discussions signed by both parties on 23rd June, 2000.

3. Schedule of the Study

JICA will complete the final report in accordance with the confirmed item and send it to the Cambodian side in or around January 2001.

4. Other Relevant Issues

4-1 Both sides agreed that PPWSA will take necessary measures described in the draft report for smooth implementation of the Project. PPWSA promised to complete the following undertakings by the end of August 2001, prior to the commencement of the construction.

- Acquisition of necessary permissions for expansion of water treatment plant.
- Provision of construction site for air vessels and expanded water treatment facilities.
- Removal of pipe materials located at the construction site for the new reservoir.
- Removal the existing chemical storage located at the construction site for the new water treatment plant.
- Leveling the land for the construction of water treatment plant and reservoir.

4-2 Both sides agreed that PPWSA will secure enough budget for the above mentioned necessary undertakings.

4-3 Both sides agreed that PPWSA will take necessary measures such as utilization of other water treatment plants and explanation to the local community to minimize the influence of the reduction or cut-off of water supply during the construction.

4-4 Both sides agreed that PPWSA will ensure a good coordination with the Project during its construction stage to secure the daily operation of the water treatment plant and smooth implementation of the construction.

4-5 Both sides reconfirmed that PPWSA will allocate enough budget and staff with appropriate technical skills to ensure proper and effective operation and maintenance of the facilities and equipment provided under the Project.

4-6 Both sides agreed that PPWSA will continue to endeavor in strengthening the water quality control, extending the distribution pipeline, educating the local community and improving the water charge collection in order to maximize the effect of the Project.

h

h

Appendix 5 Other Relevant Data

Appendix 5-1 Investment Program for PPWSA from 1993-2004

Name of project	term of project	Name of facility or district	budget		name of donor	kind of cooperation
			total	Cambodia input %		
Improvement of Distribution Network	1992-1993	Replacement of Water Distribution System in Sras Chak Sub-district, Don Penh District	\$ 1,630,000.00	10	French Protocol	Grant Aid
Improvement of Water Supply Facilities in Phnom Penh	1993-1994	Rehabilitation of Filter System in Phum Prek Water Treatment Plant	\$ 3,260,000.00	0	French Protocol	Grant Aid
Technical Assistance for the Rehabilitation of Water Utilities of Phnom Penh and Sihanoukville	1993-1995	Strengthen the Managerial and Operational Capacities of the Water Utilities of the cities of Phnom Penh and Sihanoukville by Expert	\$ 4,110,900.00	0	UNDP/ World Bank	Grant Aid
Improvement of Water Supply Facilities in Phnom Penh	1995-1996	Extension of 10,000m ³ /day in Chamcar Morn Water Treatment Plant	\$ 5,300,000.00	0	French Protocol	Grant Aid
Improvement of Distribution Network	1995-1996	Replacement of Water Distribution System in Don Penh District	\$ 4,906,650.00	10	World Bank and French Protocol	Loan and Grant Aid
Improvement of Water Supply Facilities in Phnom Penh	1996-1997	Rehabilitation of Existing Chamcar Morn Water Treatment Plant 10,000 m ³ /day	\$ 1,705,000.00	30	French Protocol	Grant Aid
Phnom Penh Water Supply and Drainage Project. Part A- Water Supply ADB Loan No.1468-CAM(SF)	1997-1999	Replacement of Water Distribution System in Chamcar Morn District	\$ 2,269,800.00	20	Asian Development Bank	Loan
Phnom Penh Water Supply and Drainage Project. Part A- Water Supply ADB Loan No.1468-CAM(SF)	1997-1999	Supply of Institutional Supporting Equipment (Vehicles and Machinery for Pipelaying Teams)& Office Equipment (Computer, Printer and etc.)	\$ 442,415.00	0	Asian Development Bank	Loan

Name of project	term of project	Name of facility or district	budget	name of donor	kind of cooperation
Phnom Penh Water Supply and Drainage Project. Part A- Water Supply ADB Loan No.1468-CAM(SF)	1997-2001	Design and Supervision of Water Transmission Pipeline in the City of Phnom Penh (600 mm to 1600 mm, 15 Km)	\$ 1,065,951.00	Asian Development Bank	Loan
Phnom Penh Water Supply and Drainage Project. Part A- Water Supply ADB Loan No.1468-CAM(SF)	1999-2001	Supply, Delivery and Installation of Water Transmission Pipelines in the City of Phnom Penh (600 mm to 1600 mm, 15 Km)	\$12,200,000.00	Asian Development Bank	Loan
Cambodia Urban Water Supply Project, IDA Credit No. 3041 KH	1998-2001	Replacement of Water Distribution System in Toul Kork District	\$ 2,819,925.00	World Bank	Loan
Cambodia Urban Water Supply Project, IDA Credit No. 3041 KH	1998-2001	Construction Supervision Consultant for the Rehabilitation and Extension of Chruoy Chang War Water Treatment Plant	\$ 1,179,730.00	World Bank	Loan
Cambodia Urban Water Supply Project, IDA Credit No. 3041 KH	1998-2001	Rehabilitation and Extension of the Chruoy Chang War Water Treatment Plant 65 000 m3/day	\$11,100,000.00	World Bank	Loan
Cambodia Urban Water Supply Project, IDA Credit No. 3041 KH	1998-2002	Technical Assistance to Improve of Operational (Water Loss Control Expert, Training Expert) and Financial (Accounting Software Expert) Performance	\$ 1,064,900.00	World Bank	Loan
Cambodia Urban Water Supply Project, IDA Credit No. 3041 KH	1998-2002	Supply of Leakage Detection, Training Equipment, Computer for Accounting System Equipment	\$ 626,400.00	World Bank	Loan
Cambodia Urban Water Supply Project, IDA Credit No. 3041 KH	1998-2002	Pilot Program for financing domestic connections to the poor family as revolving Fund	\$ 260,000.00	World Bank	Loan
Cambodia Urban Water Supply Project, IDA Credit No. 3041 KH	1998-2002	Training to the PPWSA	\$ 380,000.00	World Bank	Loan
Cambodia Urban Water Supply Project, IDA Credit No. 3041 KH	2000-2001	Replacement of Additional Distribution System in Phnom Penh City	\$ 1,300,000.00	World Bank	Loan
Cambodia Urban Water Supply Project, IDA Credit No. 3041 KH	2001-2003	Extension of Distribution System to Su-urban Area	\$ 4,700,000.00	World Bank	Loan

Source: PPWSA

Appendix 5-2 Present Conditions of Phum Prek Water Treatment Plant

Existing Facility		Present Conditions and Necessary Improvement Measures of Phum Prek WTP	The Year Constructed or Installed
Intake Facility in the Sap River	Intake Tower	RC Lower structure ; Dia. 4.95 m × H 11.60 m Upper structure ; W 10.0m × L 11.0m × H 8.7 m	1966
	Intake Gate	H 1.0m × W 1.0m 4 gates (including 2 upper gates for the rainy season and 2 lower gates for the dry season) Operating apparatus Lod end bearing 50 mm (13.42 m - 2 lods, 7.16 m - 2 lods) Remarks: The gates can work and be used but the operating apparatus and lod end bearings are malfunction. They need to replace.	1966
	Intake Pump	Vertical mixed flow pump 3 sets (including one reserve) Diameter ; 500 mm Discharge rate ; 2,200 m ³ /hr Total head ; 21.0 m Motor output ; 50 Hz, 3,000 V, 18.5 kw Material of impeller ; Bronze Accessory ; 700 mm check valve Remarks: Existing pumps were installed in 1989 and 11 years have already elapsed. The impeller in the pump is made of bronze and its service life is about 15 years. It will be required to replace within 4~5 years.	1989
	Overhead traveling Crane	Hoisting load ; 6.0 ton H steel ; 440 × 300 mm Travelling motion ; 10.0 m Traverse motion ; 8.0 m Span ; 10.0 m Hoisting height ; 5.0 m Remarks: The motor for the traverse-moving trolley of the crane has broken down and the trolley is incapable of traverse motion. The gear for the trolley which has worn out. There is a distinct possibility that the gear may slip and drop the pump when it is being raised or lowered. Repairs to the trolley are required.	
	Access Bridge	Steel truss bridge Span ; L 42 m × W 4.0m Main pipe girder ; 900 mm × 2 pipes	1966
	Air Vessel (Anti-Water Hammer Facility)	Volume ; 15 m ³ / tank × 2 tank Pressure ; 5.0 kg/cm ² Remarks: The pressure tank (air vessel) is installed on the shore of the river adjacent to the access bridge of the intake tower. Since this tank is partially embedded in the ground, water enters the tank chamber at high water levels during floods. Consequently, the bottom part of the steel pressure tank has corroded, and its performance as a pressure vessel has deteriorated.	1966
	Air Valve	; 65 mm (注) Air Valve is malfunction.	1966

Existing Facility		Present Conditions and Necessary Improvement Measures of Phum Prek WTP	The Year Constructed or Installed
Raw Water Mains	Raw Water Mains	Cast iron pipes ; 700 mm × 2 pipes L1 = 1,270 m × 1 pipe, L2 = 1,214 m × 1 pipe Remarks: Part of the L1 pipe was installed in 1958 and the remaining part and L2 pipe were installed in 1966. The inner of the both pipes are deteriorated by rust and adhered sand silt. Furthermore, sand is settled at the bottom. The value of flow coefficient (C) is 70 ~ 80, which indicates that the pipes are much worsen condition.	1958 1966
Water Treatment Facility	Receiving Well	RC 1 basin W 4.50 m × L 5.75 m × Water depth 4.74 m V = 123 m ³ Sludge valve ; 100 mm 1 set Overflow weir ; L = 4.0 m 1 set	1966
	Rapid Mixing Well	RC 2 basins W 2.80 m × L 2.95 m × Water depth 2.23 m V = 18.5 m ³ / basin Inlet gate ; W 1.0 m × H 1.0 m, 2 sets Chemical feeding equipment ; 1 tank Remarks: Retention time for rapid mixing is not enough and thus mixing of chemicals are not adequate. Flush mixer ; 320 × 348 rpm × 4 kw × 380 V Outlet gate ; W 1.0 m × H 1.0 m 2 sets Top valve ; 80, 2 sets	1966
	Flocculation Basin	RC 6 basin W 11.10 m × L 5.53 m × Average depth of water 3.29 m V = 202 m ³ Inlet gate ; 300 inside screw type 12 sets Flocculater ; 4.50 m × H 2.5 m × 25 / 37 rpm × 1.3 / 2.0 kw × 380 V 12 sets Remarks: Retention time is not enough and thus floc growth and formation is not enough and inadequate.	1966
	Chemical Sedimentation Basin	RC 6 basins W 11.10 m × L 53.20 m × Ave. depth of water 2.45 m V = 1,467 m ³ - Drainage for wastewater and sludge Top valve ; 200 mm, 18 sets Inlet equipment ; Spilt roll 6 sets - Collecting well Top valve ; 100 mm 6 sets Valve for cleaning ; Angle valve 60 mm 28 sets Pump for cleaning ; 80 mm × Q = 30 m ³ /hr × H 61.55 m × 17.6 kw × 380 V Remarks: Inlet wooden structure is corroded and the structure is inadequate to make tabulation in the basin. As a result, appropriate sedimentation of the floc formed is not occurred.	1966

Existing Facility		Present Conditions and Necessary Improvement Measures of Phum Prek WTP	The Year Constructed or Installed
Water Distribution Facility	Water Reservoir	No.1 Reservoir ; RC 1 basin W 50.0 m × L 50.0 m × Effective depth of water 4.0 m = 10,000 m ³	1959
		No.2 Reservoir ; RC 2 basins W 31.4 m × L 39.4 m × Effective depth of water 4.06 m = 5,000 m ³	1995
	Pump Room	RC building 2 rooms No.1 pump room W 8.25 m × L 19.45 m × H 6.0 m	1966
		No.2 pump room W 8.25 m × L 20.00 m × H 6.0 m	1995
	Distribution Pump	DP-1, 2 & 3 (KBU) 3 sets 500/ 400 × Q 2,100 m ³ /hr × H 42.0 m × 325 kw × 3,000 V	1966
		DP-4 (Ebara) 1 set 500/ 400 × Q 2,100 m ³ /hr × H 42.0 m × 325 kw × 3,000 V DP-5 & 6 (Kubota) 2 sets 350/ 200 × Q 1,050 m ³ /hr × H 42.0 m × 180 kw × 3000 V	1995 1994, 95
	Transmission Pump	TP-1 & 2 (Kubota) 2 sets 350/ 200 × Q 1,050 m ³ /hr × H 42.0 m × 180 kw × 3000 V	1994, 95
Vacuum pump for distribution/transmission pump	2 sets, Vacuum pump		
Overhead traveling Crane	No.1 crane 1 set Hoisting load ; 3 ton traveling motion ; 19.0 m Traverse motion ; 5.0 m Span ; 6.25 m Hoisting height ; 5.0 m	1966	
	No.2 crane 1 set Hoisting load ; 4 ton traveling motion ; 19.0 m Traverse motion ; 5.0 m Span ; 6.25 m Hoisting height ; 5.0 m	1994	
Electrical and Control Facility	Electrical and Control Facility Complete sets of necessary facilities for the machine, etc. adopted above.		

Source : JICA B/D Study Team, July 2000

Water Demand Analysis (Water Demand at the End of the Year)		1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	
Year	2000	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	
Connection increase rate	10,000	12,000	16,000 per year																	
Conditions																				
Actual average household size (pers) of Phnom Penh (Census 1998)																				
Population and water demand in Phnom Penh																				
Actual domestic connection ratio of total connections in 1999																				
5.7 persons																				
85 %																				
Total (Urban and Suburban)																				
Population																				
Total Population	(pers)	936,767	987,229	1,040,043	1,095,291	1,153,076	1,213,501	1,276,676	1,342,726	1,411,797	1,484,034	1,559,613	1,638,721	1,721,574	1,808,106	1,899,467	1,995,117	2,095,627	2,201,401	
PPWSA piped supply	(pers)	234,234	263,632	332,267	390,426	477,638	564,650	652,056	739,270	826,476	913,685	1,000,686	1,088,107	1,175,317	1,262,630	1,349,737	1,436,946	1,524,160	1,611,368	
Others including WS	(pers)	702,533	703,397	707,756	704,865	675,438	648,851	624,621	603,498	585,321	570,349	558,927	550,614	546,257	545,476	549,750	558,171	571,467	590,033	
PPWSA piped supply service ratio	(%)	25	29	32	36	41	47	51	55	59	62	64	66	66	70	71	72	73	73	
Number of connections at the end of year																				
Total connections	(Nos.)	48,714	59,345	69,345	80,345	99,345	116,345	134,345	152,345	170,345	188,345	206,345	224,345	242,345	260,345	278,345	296,345	314,345	332,345	
Total connection increase	(Nos.)	9,631	10,000	10,000	12,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	18,000	
Domestic connections	(Nos.)	41,093	49,796	59,296	69,496	89,796	99,096	114,396	129,696	144,996	160,296	175,596	190,896	206,196	221,496	236,796	252,096	267,396	282,696	
Domestic connection increase	(Nos.)	8,703	8,703	8,500	10,200	15,300	15,300	15,300	15,300	15,300	15,300	15,300	15,300	15,300	15,300	15,300	15,300	15,300	15,300	
Accounted-for water																				
Per capita Demand	(l/c/d)	133	133	132	132	130	129	129	128	126	124	123	122	121	120	119	118	116	117	
Commercial & Industrial Demand	(m3/d)	28,262	34,340	43,762	51,453	62,136	72,912	83,618	94,639	104,224	113,619	123,021	132,429	141,844	151,268	160,694	170,126	179,558	188,915	
Administration Demand	(m3/d)	12,819	15,106	19,222	22,591	27,221	31,896	36,640	41,443	46,404	49,371	53,340	57,313	61,289	65,270	69,253	73,239	77,228	81,221	
Whole-seller Demand	(m3/d)	5,077	6,595	3,692	4,329	5,128	5,946	6,791	7,659	8,188	8,719	9,251	9,785	10,320	10,857	11,394	11,933	12,474	13,016	
Total Demand	(m3/d)	1,473	1,139	946	759	570	380	190	0	0	0	0	0	0	0	0	0	0	0	
Per capita AFW 1	(l/c/d)	47,951	57,180	67,635	79,132	95,057	111,134	127,439	143,940	157,816	171,709	185,612	199,527	213,453	227,393	241,341	255,300	269,270	283,252	
Per capita AFW 2	(l/c/d)	205	201	204	203	199	197	195	195	191	188	185	182	182	180	179	176	177	176	
Accounted-for water Ratio	(%)	44	55	65	72	82	92	100	107	112	116	119	122	124	126	127	128	128	129	
Water Demand																				
Daily Average water demand	(m3/d)	107,206	102,425	104,054	114,684	130,215	146,229	159,299	179,626	197,270	214,636	232,015	249,409	266,817	284,241	301,677	319,125	336,586	354,055	
Per capita Average water demand	(l/c/d)	469	361	313	284	273	259	244	243	235	235	232	229	227	225	224	222	221	220	
Daily Maximum water demand	(m3/d)	111,494	116,765	135,270	149,088	169,260	190,098	207,088	233,604	256,451	279,027	301,620	324,232	346,862	369,513	392,180	414,863	437,564	460,285	
Per capita Maximum water demand	(l/c/d)	478	411	407	382	364	337	318	316	310	305	301	298	295	293	291	289	287	286	
Peak factor (Daily-Max demand / Daily-Average dem		1.04	1.14	1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30	
Water Production Capacity (m3/day)																				
Year	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015		
Phum Prek WTP	100,000	100,000	100,000	100,000	100,000	100,000	100,000	150,000	150,000	150,000	150,000	150,000	150,000	150,000	150,000	150,000	150,000	150,000	150,000	
Chhagr Non WTP	20,000	20,000	20,000	20,000	20,000	20,000	20,000	20,000	20,000	20,000	20,000	20,000	20,000	20,000	20,000	20,000	20,000	20,000	20,000	
Chhuoy Changwar				65,000	65,000	65,000	65,000	65,000	65,000	65,000	65,000	65,000	65,000	65,000	65,000	65,000	65,000	65,000	65,000	
Chhri																				
Notes:																				
1) Per capita AFW is calculated by dividing AFW into PPWSA piped water supply population																				
2) Per capita AFW is calculated by dividing AFW into total population																				

Water Demand Analysis (Water Demand at the End of the Year)																				
Case - A	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015				
Connection increase rate	10,000	12,000	16,000	per year																
Conditions																				
Actual average household size (pers) of Phnom Penh (Census: 1989)																				
Actual domestic connection ratio of total connections in 1989																				
Actual water demand ratio of each category to domestic in 1989																				
Domestic demand	100.0																			
Commercial & Industrial	41.5																			
Administration	10.8																			
Wholesale	2.1																			
Total	100.0																			
Average Ratio of 7th January and Chantear Mon in 1989																				
Domestic demand	64.7																			
Commercial & Industrial	26.9																			
Administration	7.0																			
Wholesale	1.4																			
Total	100.0																			
Population and Water Demand Forecast in Phnom Penh																				
Suburban	Year	1988	1989	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	
Population																				
Total Population	(pers)	421,092	452,835	486,591	522,430	560,501	600,912	649,792	698,293	737,540	788,727	843,031	900,651	961,810	1,026,751	1,095,747	1,169,097	1,247,134	1,330,229	
PPVWSA piped supply	(pers)	2,434	2,502	2,502	2,699	28,466	51,500	70,436	86,825	152,219	218,378	284,316	360,037	415,553	480,875	545,997	610,926	675,667	740,196	
Others including WS	(pers)	418,658	450,333	484,079	519,831	532,035	549,412	579,357	611,468	585,321	570,349	563,715	550,614	546,257	545,876	549,750	558,171	571,467	590,033	
PPVWSA piped supply service ratio	(%)	0.6	0.6	0.5	0.5	5.1	8.6	10.9	12.5	20.6	27.7	33.7	39.9	43.2	46.8	49.8	52.3	54.2	55.6	
Number of connections at the end of year																				
Total connections	(Nos.)	566	576	576	596	5,935	10,689	14,597	17,774	31,477	45,132	58,742	72,307	85,929	99,311	112,752	126,154	139,516	152,835	
Total connection increase	(Nos.)	10	10	0	20	5,339	4,754	3,908	3,176	13,704	13,665	13,639	19,595	13,522	13,482	13,441	13,401	13,362	13,319	
Domestic connections	(Nos.)	427	439	439	456	4,994	9,095	12,357	15,057	26,705	38,312	49,980	61,410	72,904	84,364	95,789	107,180	118,536	129,859	
Domestic connection increase	(Nos.)	12	12	0	17	4,538	4,041	3,322	2,700	11,646	11,607	11,566	11,530	11,494	11,460	11,425	11,391	11,358	11,321	
Accounted - for water																				
Domestic	(l/c/d)	145	163	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	
Per capita Demand	(m3/d)	352	408	250	260	2,847	5,150	7,044	8,593	15,222	21,838	28,432	35,004	41,555	48,098	54,600	61,099	67,567	74,020	
Commercial & Industrial Demand	(m3/d)	147	204	104	108	1,192	2,137	2,923	3,552	6,317	9,063	11,799	14,527	17,245	19,957	22,669	25,384	28,040	30,718	
Administration Demand	(m3/d)	92	79	11	12	128	231	316	365	692	979	1,274	1,569	1,862	2,155	2,447	2,736	3,028	3,319	
Wholesale Demand	(m3/d)	189	155	129	103	78	52	26	0	0	0	0	0	0	0	0	0	0	0	
Total Demand	(m3/d)	760	846	494	483	4,235	7,570	10,309	12,530	22,221	31,880	41,505	51,100	60,662	70,200	79,705	89,185	98,635	108,056	
Per capita AFW 1	(l/c/d)	320	338	197	185	149	147	146	146	146	146	146	146	146	146	146	146	146	146	
Per capita AFW 2	(l/c/d)	2	2	1	1	8	13	16	16	30	40	49	57	65	69	73	76	79	81	
Accounted - for water Ratio	(%)	65	69	73	75	80	80	80	80	80	80	80	80	80	80	80	80	80	80	
Water Demand																				
Daily Average water demand	(m3/d)	760	846	494	483	4,235	7,570	10,309	12,530	22,221	31,880	41,505	51,100	60,662	70,200	79,705	89,185	98,635	108,056	
Per capita Average water demand	(l/c/d)	304	349	204	193	163	182	182	182	182	182	182	182	182	182	182	182	182	182	182
Daily maximum water demand	(m3/d)	988	910	7,541	12,949	16,752	20,352	23,737	27,122	30,507	33,892	37,277	40,662	44,047	47,432	50,817	54,202	57,587	60,972	64,357
Per capita maximum water demand	(l/c/d)	395	350	285	251	238	237	237	237	237	237	237	237	237	237	237	237	237	237	237
Peak factor (Daily-Max demand / Daily-Average demand)		1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30	1.30

Notes: 1) Per capita AFW is calculated by dividing AFW into PPVWSA piped water supply population
2) Per capita AFW is calculated by dividing AFW into total population

Appendix 5- 4 Water Quality Monitoring Date

Table 1 Monthly average of raw water characteristics in 1999

No.	Parameter	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ave.
1	Temp. (°C)	27.3	28.4	29.9	30.4	30.2	28.9	29.3	28.7	29.2	29.9	28.7	25.2	28.8
2	Colour (Pt/Co)	41	233	252	224	438	245	335	240	241	173	95	110	219
3	Cond. (µs)	90	84	77	78	82	113	113	90	126	106	80	67	92
4	TDS (mg/L)	45	42	39	39	41	57	57	45	63	53	40	34	46
5	SS (mg/L)	37	63	27	100	54	246	109	408	280	47	48	66	124
6	Turbidity (NTU)	30	45	35	99	100	216	148	360	250	49	50	74	121
7	pH-value	7.12	7.09	6.84	7.01	7.04	6.85	7.10	6.85	7.82	7.15	6.80	6.79	7.04
8	CO ₂ (mg/L)	6	12	23	45	30	10	12	18	10	17	21	20	19
9	Alkalinity (mgCaCO ₃ /L)	40	36	28	32	36	42	40	38	60	54	41	54	42
10	Total Hardness (mg/L)	35	32	32	24	32	40	44	34	54	50	22	21	35
11	Caicium (mgCaCO ₃ /L)	31	20	20	22	28	36	36	28	38	42	21	16	28
12	Magnesium (mg/L)	4	12	12	2	4	4	8	6	16	8	1	5	7
13	Potassium (mg/L)	-	-	-	-	-	-	-	-	-	-	-	-	-
14	Alminum (mg/L)	0.008	0.007	0.004	-	0.008	0.011	0.023	0.008	0.023	0.004	0.000	0.002	0.009
15	Iron (mg/L)	0.26	0.48	0.51	0.45	1.56	1.62	1.34	0.89	0.35	0.46	0.29	0.55	0.73
16	Manganese (mg/L)	0.1	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.1	0.0
17	Sulfate (mg/L)	0	0	0	0	1	8	8	2	8	0	0	0	2
18	Nitrate (mg/L)	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
19	Nitrite (mg/L)	0.011	0.012	0.105	0.017	0.009	0.004	0.002	0.000	0.010	0.002	0.002	0.001	0.015
20	N-Ammonium (mg/L)	2.37	0.49	-	-	-	-	-	-	-	-	-	-	1.43
21	Phosphate (mg/L)	0.01	0.14	0.64	0.30	0.00	0.49	0.16	0.16	0.06	0.22	0.17	0.01	0.20
22	Chloride (mg/L)	5.5	27.5	36.0	41.5	12.4	-	-	-	4.0	3.8	28.0	4.3	18.1
23	Fluoride (mg/L)	0.11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.21	0.00	0.03
24	Sulfide (mg/L)	0.013	0.034	0.037	0.022	0.050	0.055	0.050	0.051	0.033	0.002	0.014	0.028	0.032
25	Cyanide (mg/L)	-	-	-	-	-	-	-	-	-	-	-	-	-
26	Chromium (mg/L)	0.08	0.08	0.07	0.10	0.08	0.09	0.00	0.17	0.13	0.10	0.15	0.15	0.10
27	Copper (mg/L)	0.01	0.01	0.00	0.01	0.03	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.01
28	Zinc (mg/L)	0.00	0.01	0.00	0.00	0.01	0.00	0.00	0.01	0.10	0.01	0.00	0.00	0.01
29	COD (mg/L)	-	-	-	-	-	-	-	-	-	-	-	-	-
30	Total Coliform (cfu/100mL)	12000	7000	5800	22000	7200	31800	13000	8600	18000	1600	2000	2800	10983.3
31	Fecal Coliform (cfu/100mL)	800	12500	8400	11400	6600	13600	11800	5400	17400	2600	6200	2200	8241.67

Source: PPWSA Water quality monitoring laboratory

Table 2 Monthly average of treated water characteristics in 1999

No.	Parameter	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Ave.
1	Temp. (°C)	27.8	28.7	30.3	31.0	30.7	29.3	29.4	28.6	28.9	29.6	28.8	25.7	29.1
2	Colour (Pt/Co)	17	13	13	11	7	7	4	0	19	2	18	2	9
3	Cond. (μs)	95	90	77	85	96	129	125	104	134	114	85	70	100
4	TDS (mg/L)	48	45	39	43	48	64	62	52	67	57	42	35	50
5	SS (mg/L)	3	3	2	1	2	1	1	2	2	0	0	0	1
6	Turbidity (NTU)	1.5	1.6	1.2	1.5	6.0	1.2	1.2	1.4	1.2	0.4	0.9	0.5	1.6
7	pH-value	6.80	6.88	6.43	6.71	6.66	6.44	6.94	6.60	7.50	6.74	6.64	6.70	6.75
8	CO ₂ (mg/L)	25	40	47	48	65	50	20	43	67	5	40	30	40
9	Alkalinity (mgCaCO ₃ /L)	28	28	20	24	24	30	30	24	60	60	40	30	33
10	Total Hardness (mg/L)	22	24	20	23	28	36	40	30	54	52	21	21	31
11	Caicium (mgCaCO ₃ /L)	12	20	16	16	20	30	34	24	38	40	20	16	24
12	Magnesium (mg/L)	10	4	4	7	8	6	6	6	16	12	1	5	7
13	Potassium (mg/L)	-	-	-	-	-	-	-	-	-	-	-	-	-
14	Alminum (mg/L)	0.029	0.034	0.012	-	0.012	0.002	0.014	0.005	0.010	0.008	0.001	0.003	0.012
15	Iron (mg/L)	5.50	0.10	0.05	0.03	0.27	0.03	0.05	0.02	0.09	0.04	0.05	0.03	0.52
16	Manganese (mg/L)	0.0	0.1	0.0	0.1	0.2	0.1	0.0	0.0	0.0	0.0	0.1	0.1	0.1
17	Sulfate (mg/L)	11	10	15	19	2	24	18	22	28	17	13	11	16
18	Nitrate (mg/L)	0.7	1.0	1.2	2.8	1.8	0.8	1.0	0.9	1.5	0.9	0.6	0.6	1.2
19	Nitrite (mg/L)	0.002	0.002	0.001	0.002	0.002	0.001	0.002	0.002	0.003	0.003	0.002	0.002	0.002
20	N-Ammonium (mg/L)	0.06	0.00	-	-	-	-	-	-	-	-	-	-	0.03
21	Phosphate (mg/L)	0.31	0.02	0.08	0.20	0.03	0.07	0.67	0.04	0.01	0.09	0.01	0.03	0.13
22	Chloride (mg/L)	8.0	43.5	40.5	46.0	10.4	-	-	-	5.0	4.9	45.0	4.5	23.1
23	Fluoride (mg/L)	0.18	0.00	0.13	0.00	0.00	0.00	0.00	0.18	0.32	0.07	0.24	0.13	0.10
24	Sulfide (mg/L)	0.001	0.001	0.011	0.000	0.006	0.004	0.006	0.004	0.000	0.004	0.001	0.004	0.004
25	Cyanide (mg/L)	-	-	-	-	-	-	-	-	-	-	-	-	-
26	Chromium (mg/L)	0.08	0.07	0.08	0.13	0.12	0.10	0.12	0.14	0.16	0.13	0.16	0.19	0.12
27	Copper (mg/L)	0.01	0.00	0.00	0.00	0.00	0.01	0.00	0.01	0.01	0.02	0.01	0.03	0.01
28	Zinc (mg/L)	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.02	0.01	0.01	0.00	0.01
29	COD (mg/L)	-	-	-	-	-	-	-	-	-	-	-	-	-
30	Total Coliform (cfu/100mL)	0	0	0	0	0	0	0	0	0	0	0	0	0
31	Fecal Coliform (cfu/100mL)	0	0	0	0	0	0	0	0	0	0	0	0	0

Source: PPWSA Water Quality Monitoring Laboratory

Table 3 Typical Water Quality Data of Each Process of Phum Prek Water Treatment Plant at the Beginning of the Dry Season in 1999

Time	Water Quality Item	Raw water	Rapid mixing	Flocculation basin	Sedimentation basin	After filtration	Tap water in the Plant
07:30	Temperature	28.2	27.8	27.8	27.3	28.7	27.8
	pH	6.85			6.80	6.57	6.58
	Turbidity (NTU)	21	18	16	10	2.3	1.8
	Free-Chlorine						0.16
	Total Chlorine						0.64
	TDS	35	36	36	36	32	37
	Electric Conductivity	75	73	73	73	74	74
	SS	15			9		3
10:30	Temperature	28.5	28.4	28.4	28.5	28.7	28.7
	pH						
	Turbidity (NTU)	17	18	17	10	1.4	1.3
	Free-Chlorine						
	Total Chlorine						
14:30	Temperature	28.8	28.8	28.6	28.9	29.0	29.6
	pH	6.67			6.57	6.54	6.51
	Turbidity (NTU)	19	18	19	9	1.2	1.4
	Free-Chlorine						0.11
	Total Chlorine						0.68
	TDS	35	36	36	36	37	36
	Electric Conductivity	70	72	73	73	74	73
	SS	19			9		3

Coagulant feeding rate : 10 mg/l

Source: PPWSA Water Quality Monitoring Laboratory

Table 4 Typical Water Quality Data of Each Process of Phum Prek Water Treatment Plant at the end of the Dry Season in 1999

Time	Water Quality Item	Raw water	Rapid mixing	Flocculation basin	Sedimentation basin	After filtration	Tap water in the Plant
07:30	Temperature	28.5	28.2	28.1	28.1	28.7	29.0
	pH	6.95			6.53	6.40	6.48
	Turbidity (NTU)	60	50	50	4	0.4	1.7
	Free-Chlorine						0.30
	Total Chlorine						0.50
	TDS	30	32	33	33	33	33
	Electric Conductivity	60	65	66	66	66	67
	SS	72			13		1
10:30	Temperature	28.6	28.6	28.4	28.4	28.4	29.2
	pH						
	Turbidity (NTU)	50	50	42	5	0.6	1.3
	Free-Chlorine						
	Total Chlorine						
14:30	Temperature	29.2	29.3	29.4	29.3	28.7	29.4
	pH	6.94			6.73	6.50	6.49
	Turbidity (NTU)	55	60	64	9.5	1.8	1.4
	Free-Chlorine						0.60
	Total Chlorine						0.70
	TDS	31	33	33	34	34	34
	Electric Conductivity	61	67	67	67	68	67
	SS	66			10		1

Coagulant feeding rate : 20 mg/l

Source: PPWSA Water Quality Monitoring Laboratory

Table 5 Typical Water Quality Data of Each Process of Phum Prek Water Treatment Plant at the end of the Rainy Season in 1999

Time	Water Quality Item	Raw water	Rapid mixing	Flocculation basin	Sedimentation basin	After filtration	Tap water in the Plant
07:30	Temperature	27	27.1	27.1	26.9	27	27.1
	pH	6.88			6.76	6.70	6.65
	Turbidity (NTU)	385	432	456	10	2	1.3
	Free-Chlorine						0.80
	Total Chlorine						0.90
	TDS	45	46	53	51	51	50
	Electric Conductivity	89	93	106	101	102	100
	SS	488			7		1
10:30	Temperature	28.2	28.1	28.0	27.9	27.6	27.6
	pH						
	Turbidity (NTU)	462	426	396	22	6	5.6
	Free-Chlorine						
	Total Chlorine						
14:30	Temperature	27.2	27.3	27.2	27.2	27.4	27.2
	pH	6.80			6.54	6.51	6.54
	Turbidity (NTU)	396	369	405	12	1.6	3.1
	Free-Chlorine						1.4
	Total Chlorine						1.45
	TDS	46	53	53	53	54	52
	Electric Conductivity	93	106	106	106	107	104
	SS	412			13		8

Coagulant feeding rate : 35 mg/l

Source: PPWSA Water Quality Monitoring Laboratory

Table 6 Tap Water Quality in Phnom Penh City

No.	Location	Temp. ()	pH	Turbid. (NTU)	Conduct. (µ S/cm)	Total Chlorine (mg/l)	Free Chlorine (mg/l)	Total Bacteria	E. Coli
1	No.1792	29.3	6.9	3	120.6	1.04	0.93	-	0
2	No.31	29.4	6.4	4	116	1.19	1.03	0	0
3	No.25	29.4	6.4	2	115	0.98	0.97	-	0
4	No.477	30.2	6.5	3	117	0.90	0.77	-	0
5	No.35	30.2	6.8	1	117.7	0.62	0.75	-	0
6	No.52	30.8	6.8	1	118	0.79	0.72	-	0

Measured date: June 29 2000

Source: PPWSA Water Quality Monitoring Laboratory

Table 7 Tap Water Quality in Phnom Penh City

No	Location	DAtc	Temp ()	pH	Turbid. (NTU)	Conduct. (μ S/cm)	Total Chlorine (mg/l)	Free Chlorine (mg/l)
1	No.5 St. 75	00 5/16	30	7.2	0.9	175	0.61	0.49
2	No.2248, St. 93	00 5/16	30	6.9	1.0	174	0.48	0.38
3	No. 265, St. 1	00 5/16	30	6.9	1.0	159	0.23	0.14
4	No. 120, St.3	00 5/16	30	7.0	1.7	172	0.42	0.26
5	No. 8, St. 242	00 5/16	31	6.9	1.0	172	0.36	0.26
6	No. 274, St. 93	00 5/16	30	6.8	1.1	173	0.04	0.04
7	Fish	00 5/16	29.5	6.9	1.8	174	0.76	0.60
8	No. 103C, St. 67	00 5/16	29.5	6.9	0.9	176	0.88	0.80
9	No. 97 St. Sihanuk	00 5/14	30.2	7.2	1.4	179	0.51	0.35
10	No. 198 St. Norodom	00 5/14	30.7	7.2	4.4	181	0.75	0.6
11	No. 447 St. 271	00 5/14	29.4	7.5	0.9	181	0.15	0.1
12	No. 25 St. 490		31.4	7.1	2.7	178	0.73	0.66
13	No. 90B St. 432		31.7	7.1	5.1	178	0.6	0.51
14	No. 158 St. 173		31.6	7.0	4.0	179	0.48	0.35
15	No. 40 St. 368		31.8	6.9	3.1	180	0.14	0.05
16	No. 202 St. 143		31.6	6.9	1.1	179	0.16	0.05
17	No. 13B St. 47	99 5/31	29.9	6.9	12.8	130.4	0.36	0.24
18	No.18 St. 5	99 5/31	29.6	6.8	12	124.4	0.46	0.39
19	No.203 St. 19	99 5/31	29.7	6.9	11.8	121.7	0.36	0.29
20	No.28 E0 St. Paster	99 5/31	29.8	7.0	19	124.7	0.04	0.02
21	No. 473 St.1	99 5/31	30.4	6.9	19	126	0.13	0.06
22	No.33D St.134	99 5/31	30.0	6.8	10	124.4	0.63	0.31
23	No.40 St.213	99 5/31	30.8	6.8	11	126	0.33	0.2
24	No.482 E0+E1 St.230	99 5/31	28.9	7.1	14	136.5	0.06	0.06
25	No.329 St.112	99 5/31	30.6	6.8	12	126	0.09	0.06
26	No.1792 St.5	99 6/29	29.3	6.9	3	120.6	1.04	0.93
27	No.31 St. Srisanud	99 6/29	29.4	6.4	4	116	1.19	1.04
28	No.36 St.136	99 6/29	29.4	6.4	2	115	0.98	0.97
29	No.477 St.51(?)	99 6/29	30.2	6.5	3	117	0.9	0.77
30	No.35 St.51	99 6/29	30.2	6.8	1	117.7	0.62	0.75
31	No.12 St.289	99 6/7	30	7.0	4.12	149	0.55	0.40
32	No.03 St.562	99 6/7	30.4	6.9	5.27	148	0.13	0.05
33	No.51 St.287	99 6/7	30.5	6.9	3.14	148	0.48	0.24
34	No.99 St.315	99 6/7	30	6.66	3.4	147	0.05	0.02
35	No.4 St.265	99 6/7	31.8	6.8	3.17	147	0.39	0.1
36	No.235A St.138	99 6/7	31.2	6.8	3.23	146	0.76	0.68
37	No.25E0 St.Paster	99 6/7	30.7	6.9	3.5	147.4	0.05	0.02
38	No.18 St.5	99 6/7	30.4	6.65	2.2	146	0.94	0.89
39	No.488 St.	99 6/7	31.0	6.8	3.36	146	0.92	0.8
40	No.6A St.27	99 6/7	31	6.64	1.2	148	0.11	0.16

Source: PPSA Water Quality Monitoring Laboratory

Appendix 5- 5 Analysis of Distributed Water Volume, Leakage and Daily Maximum Coefficient

(m ³ /hour)									
District name Zone No.	7th January 1	7th January 2	7th January 3	7th January 4	7th January 5	7th January 6	7th January 7	7th January 8	7th January TOTAL
Hour/Date	02/15/00	02/15/00	02/28/00	02/29/00	03/01/00	02/17/00	02/15/00	02/02/00	
00:00-01:00	6.5	2.9	16.1	4.7	68.1	17.20	6.56	6.01	128.07
01:00-02:00	12.0	25.9	36.4	19.3	20.7	16.40	6.64	3.80	141.14
02:00-03:00	21.9	4.8	14.1	20.4	42.9	15.60	6.87	15.27	141.84
03:00-04:00	12.1	21.5	30.5	40.1	43.7	26.60	20.73	20.28	215.51
04:00-05:00	36.7	31.2	39.9	50.5	76.7	31.30	21.63	14.35	302.28
05:00-06:00	48.2	25.9	99.3	99.6	139.2	72.10	30.58	33.60	548.48
06:00-07:00	62.5	31.5	113.8	137.3	128.0	76.70	50.63	32.64	633.07
07:00-08:00	49.0	44.5	97.8	112.2	130.3	77.30	58.09	40.61	609.80
08:00-09:00	57.3	29.9	124.6	157.4	123.3	77.50	45.43	37.95	653.38
09:00-10:00	67.3	31.1	88.9	140.2	125.7	74.60	41.69	42.84	612.33
10:00-11:00	59.2	24.0	123.7	113.3	129.3	66.80	45.51	38.01	599.82
11:00-12:00	69.8	28.9	110.9	113.2	97.0	67.60	45.29	24.85	557.54
12:00-13:00	60.4	37.5	102.1	118.0	94.3	74.60	42.28	40.67	569.85
13:00-14:00	56.2	30.9	119.0	101.4	89.5	73.90	33.31	39.76	543.97
14:00-15:00	55.2	28.4	93.1	136.2	89.8	64.90	53.73	30.86	552.19
15:00-16:00	51.4	29.3	101.3	128.9	108.7	61.50	44.15	33.47	558.72
16:00-17:00	41.4	33.4	106.8	132.2	130.2	61.60	44.68	28.63	578.91
17:00-18:00	51.7	28.4	79.0	97.7	125.4	71.20	48.10	37.38	538.88
18:00-19:00	62.6	29.0	73.9	100.0	123.3	74.60	51.37	31.89	546.66
19:00-20:00	47.6	29.3	91.6	106.5	122.9	65.50	45.89	3.59	512.88
20:00-21:00	43.4	30.9	111.7	56.7	64.8	40.80	38.44	10.75	397.49
21:00-22:00	14.6	21.7	42.4	0.5	44.4	40.10	25.12	19.78	208.60
22:00-23:00	27.5	4.9	26.3	72.3	42.6	19.80	8.08	4.49	205.97
23:00-24:00	16.6	25.1	20.9	44.9	30.0	18.60	6.73	5.25	168.08
Max	69.80	44.50	124.60	157.40	139.20	77.50	58.09	42.84	653.38
Average	42.96	26.29	77.67	87.65	91.28	53.62	34.23	24.86	438.56
Total distribution	1031.10	630.90	1864.10	2103.50	2190.80	1286.80	821.53	596.73	10525.46
Hourly maximum dist./average dist. (Peak)	1.62	1.69	1.60	1.80	1.52	1.45	1.70	1.72	1.49
Hourly dist. - Average Daily dist.									
00:00-01:00	(36.46)	(23.39)	(61.57)	(82.95)	(23.18)	(36.42)	(27.67)	(18.85)	(310.49)
01:00-02:00	(30.96)	(0.39)	(41.27)	(68.35)	(70.58)	(37.22)	(27.59)	(21.06)	(297.42)
02:00-03:00	(21.06)	(21.49)	(63.57)	(67.25)	(48.38)	(38.02)	(27.36)	(9.59)	(296.72)
03:00-04:00	(30.86)	(4.79)	(47.17)	(47.55)	(47.58)	(27.02)	(13.50)	(4.58)	(223.05)
04:00-05:00	(6.26)	4.91	(37.77)	(37.15)	(14.58)	(22.32)	(12.60)	(10.51)	(136.28)
05:00-06:00	5.24	(0.39)	21.63	11.95	47.92	18.48	(3.65)	8.74	109.92
06:00-07:00	19.54	5.21	36.13	49.65	36.72	23.08	16.40	7.78	194.51
07:00-08:00	6.04	18.21	20.13	24.55	39.02	23.68	23.86	15.75	171.24
08:00-09:00	14.34	3.61	46.93	69.75	32.02	23.88	11.20	13.09	214.82
09:00-10:00	24.34	4.81	11.23	52.55	34.42	20.98	7.46	17.98	173.77
10:00-11:00	16.24	(2.29)	46.03	25.65	38.02	13.18	11.28	13.15	161.26
11:00-12:00	26.84	2.61	33.23	25.55	5.72	13.98	11.06	(0.01)	118.98
12:00-13:00	17.44	11.21	24.43	30.35	3.02	20.98	8.05	15.81	131.29
13:00-14:00	13.24	4.61	41.33	13.75	(1.78)	20.28	(0.92)	14.90	105.41
14:00-15:00	12.24	2.11	15.43	48.55	(1.48)	11.28	19.50	6.00	113.63
15:00-16:00	8.44	3.01	23.63	41.25	17.42	7.88	9.92	8.61	120.16
16:00-17:00	(1.56)	7.11	29.13	44.55	38.92	7.98	10.45	3.77	140.35
17:00-18:00	8.74	2.11	1.33	10.05	34.12	17.58	13.87	12.52	100.32
18:00-19:00	19.64	2.71	(3.77)	12.35	32.02	20.98	17.14	7.03	108.10
19:00-20:00	4.64	3.01	13.93	18.85	31.62	11.88	11.66	(21.27)	74.32
20:00-21:00	0.44	4.61	34.03	(30.95)	(26.48)	(12.82)	4.21	(14.11)	(41.07)
21:00-22:00	(28.36)	(4.59)	(35.27)	(87.15)	(46.88)	(13.52)	(9.11)	(5.08)	(229.96)
22:00-23:00	(15.46)	(21.39)	(51.37)	(15.35)	(48.68)	(33.82)	(26.15)	(20.37)	(232.59)
23:00-24:00	(26.36)	(1.19)	(56.77)	(42.75)	(61.28)	(35.02)	(27.50)	(19.61)	(270.48)
Necessary reservoir volume (m ³)	197.36	79.89	398.54	479.41	390.92	256.15	176.05	145.08	2038.07
Necessary volume /average hourly dist. Volume (hour)	4.59	3.04	5.13	5.47	4.28	4.78	5.14	5.84	4.65

(m³/hour)

District name Zone No.	Chamcar Morn 1	Chamcar Morn 3	Chamcar Morn 4	Chamcar Morn 7	Chamcar Morn 8	Chamcar Morn 10	Chamcar Morn 11	Chamcar Morn 12	CHAMCAR MORN TOTAL
Hour/Date	05/18/00	03/27/00	04/07/00	06/15/00	04/03/00	03/27/00	05/02/00	05/03/00	
00:00-01:00	28.88	16.6	24.60	20.6	9.25	19.60	7.40	2.23	129.16
01:00-02:00	29.99	42.8	43.60	17.8	11.27	20.80	7.20	2.82	176.28
02:00-03:00	37.70	32.1	28.60	25.4	30.86	22.10	4.00	2.73	183.49
03:00-04:00	35.20	42.6	40.10	15.8	32.94	26.60	15.50	3.71	212.45
04:00-05:00	63.21	85.8	38.00	35.2	23.59	41.40	9.50	5.70	302.40
05:00-06:00	74.10	90.9	37.70	42.0	33.02	56.70	18.90	6.78	360.10
06:00-07:00	77.50	118.8	38.70	74.8	27.26	52.40	23.40	6.87	419.73
07:00-08:00	79.65	120.7	51.90	64.2	32.05	61.90	31.00	9.75	451.15
08:00-09:00	80.05	106.3	51.00	78.6	42.00	59.20	28.40	12.19	457.74
09:00-10:00	72.01	104.1	37.70	61.8	46.90	63.60	24.00	15.96	426.07
10:00-11:00	72.21	92.6	63.20	64.3	55.47	60.00	33.10	10.58	451.46
11:00-12:00	68.26	113.7	44.70	57.8	50.05	50.20	13.60	13.73	412.04
12:00-13:00	69.63	99.4	51.10	56.1	33.87	44.10	37.20	12.19	403.59
13:00-14:00	70.05	99.0	49.20	39.9	27.01	67.10	16.50	11.66	380.42
14:00-15:00	67.37	108.5	37.10	52.6	31.68	46.00	28.90	12.23	384.38
15:00-16:00	73.61	107.5	48.90	34.6	35.26	73.60	15.80	13.79	403.06
16:00-17:00	69.08	108.3	50.00	50.4	43.38	47.50	22.90	10.97	402.53
17:00-18:00	70.61	103.6	59.70	58.9	31.26	55.40	33.00	14.39	426.86
18:00-19:00	65.20	110.8	44.84	43.7	40.10	55.10	15.10	10.12	384.96
19:00-20:00	43.00	112.7	54.86	36.9	32.08	56.50	23.10	9.56	368.70
20:00-21:00	43.49	83.4	37.40	48.1	28.51	44.20	16.70	4.14	305.94
21:00-22:00	34.90	67.7	58.40	42.1	27.54	52.60	19.20	5.56	308.00
22:00-23:00	33.70	21.8	32.20	26.1	20.01	16.60	14.20	2.04	166.65
23:00-24:00	32.52	39.3	32.00	6.9	18.54	7.00	10.40	3.46	150.12
Max	80.05	120.70	63.20	78.60	55.47	73.60	37.20	15.96	457.74
Average	58.00	84.54	43.98	43.94	31.83	45.84	19.54	8.47	336.14
Total distribution	1391.92	2029.00	1055.50	1054.60	763.90	1100.20	469.00	203.16	8067.28
Hourly maximum dist./average dist. (Peak)	1.38	1.43	1.44	1.79	1.74	1.61	1.90	1.89	1.36

00:00-01:00	(29.12)	(67.94)	(19.38)	(23.34)	(22.58)	(26.24)	(12.14)	(6.24)	(206.98)
01:00-02:00	(28.01)	(41.74)	(0.38)	(26.14)	(20.56)	(25.04)	(12.34)	(5.65)	(159.86)
02:00-03:00	(20.30)	(52.44)	(15.38)	(18.54)	(0.97)	(23.74)	(15.54)	(5.74)	(152.65)
03:00-04:00	(22.80)	(41.94)	(3.88)	(28.14)	1.11	(19.24)	(4.04)	(4.76)	(123.69)
04:00-05:00	5.21	1.26	(5.98)	(8.74)	(8.24)	(4.44)	(10.04)	(2.77)	(33.74)
05:00-06:00	16.10	6.36	(6.28)	(1.94)	1.19	10.86	(0.64)	(1.69)	23.96
06:00-07:00	19.50	34.26	(5.28)	30.86	(4.57)	6.56	3.86	(1.60)	83.59
07:00-08:00	21.65	36.16	7.92	20.26	0.22	16.06	11.46	1.29	115.01
08:00-09:00	22.05	21.76	7.02	34.66	10.17	13.36	8.86	3.73	121.60
09:00-10:00	14.01	19.56	(6.28)	17.86	15.07	17.76	4.46	7.50	89.93
10:00-11:00	14.21	8.06	19.22	20.36	23.64	14.16	13.56	2.12	115.32
11:00-12:00	10.26	29.16	0.72	13.86	18.22	4.36	(5.94)	5.27	75.90
12:00-13:00	11.63	14.86	7.12	12.16	2.04	(1.74)	17.66	3.73	67.45
13:00-14:00	12.05	14.46	5.22	(4.04)	(4.82)	21.26	(3.04)	3.20	44.28
14:00-15:00	9.37	23.96	(6.88)	8.66	(0.15)	0.16	9.36	3.77	48.24
15:00-16:00	15.61	22.96	4.92	(9.34)	3.43	27.76	(3.74)	5.33	66.92
16:00-17:00	11.08	23.76	6.02	6.46	11.55	1.66	3.36	2.51	66.39
17:00-18:00	12.61	19.06	15.72	14.96	(0.57)	9.56	13.46	5.93	90.72
18:00-19:00	7.20	26.26	0.86	(0.24)	8.27	9.26	(4.44)	1.66	48.82
19:00-20:00	(15.00)	28.16	10.88	(7.04)	0.25	10.66	3.56	1.10	32.56
20:00-21:00	(14.51)	(1.14)	(6.58)	4.16	(3.32)	(1.64)	(2.84)	(4.33)	(30.20)
21:00-22:00	(23.10)	(16.84)	14.42	(1.84)	(4.29)	6.76	(0.34)	(2.91)	(28.14)
22:00-23:00	(24.30)	(62.74)	(11.78)	(17.84)	(11.82)	(29.24)	(5.34)	(6.43)	(169.49)
23:00-24:00	(25.48)	(45.24)	(11.98)	(37.04)	(13.29)	(38.84)	(9.14)	(5.01)	(186.02)
Necessary reservoir volume (m ³)	202.59	330.03	100.05	184.24	95.17	170.18	89.58	47.08	1090.74
Necessary volume /average hourly dist. Volume (hour)	3.49	3.90	2.27	4.19	2.99	3.71	4.58	5.56	3.24






(m ³ /hour)									
District name	Tuol Kork	TUOL KORK	09h	Daun Penh	Daun Penh	Daun Penh	Daun Penh	DAUN PENH	DAUN PENH
Zone No.	2	TOTAL	5A	1	* 7B	12	14	TOTAL	TOTAL
Hour/Date	06/26/00		02/14/00	05/18/00	09/14/99	01/17/00	10/28/99	(without 14)	
00:00-01:00	9.2	9.2	14.49	57.94	77.9	2.19	112	264.52	152.52
01:00-02:00	9.1	9.1	8.01	49.18	118.0	2.10	62	239.29	177.29
02:00-03:00	8.8	8.8	14.98	53.74	121.4	2.98	43	236.10	193.10
03:00-04:00	19.9	19.9	20.08	66.57	120.9	3.14	60	270.69	210.69
04:00-05:00	28.4	28.4	31.82	72.75	247.0	3.06	117	471.63	354.63
05:00-06:00	39.7	39.7	57.07	151.23	241.0	8.29	142	599.59	457.59
06:00-07:00	54.5	54.5	72.89	142.55	248.3	8.18	154	625.92	471.92
07:00-08:00	50.7	50.7	80.66	166.06	243.7	11.65	170	672.07	502.07
08:00-09:00	33.9	33.9	62.82	168.42	249.0	10.08	150	640.32	490.32
09:00-10:00	67.1	67.1	81.04	175.57	254.3	9.92	142	662.83	520.83
10:00-11:00	83.9	83.9	58.10	148.37	231.7	10.36	170	618.53	448.53
11:00-12:00	65.8	65.8	78.97	155.31	222.0	9.79	140	606.07	466.07
12:00-13:00	48.0	48.0	73.19	162.39	243.9	11.07	150	640.55	490.55
13:00-14:00	49.1	49.1	70.81	152.46	230.1	6.89	138	599.26	460.26
14:00-15:00	46.7	46.7	78.89	135.93	214.7	4.12	150	583.64	433.64
15:00-16:00	49.9	49.9	66.20	142.41	224.8	5.57	148	586.98	438.98
16:00-17:00	51.9	51.9	79.40	149.09	222.8	4.92	120	576.21	456.21
17:00-18:00	49.9	49.9	71.42	152.44	227.1	4.76	30	485.72	455.72
18:00-19:00	49.9	49.9	75.91	145.19	224.6	5.69	21	472.39	451.39
19:00-20:00	50.1	50.1	75.57	122.80	223.9	6.21	189	617.48	428.48
20:00-21:00	36.5	36.5	83.50	71.77	247.7	5.17	118	526.14	408.14
21:00-22:00	45.5	45.5	27.92	88.06	120.5	2.97	126	365.45	239.45
22:00-23:00	15.4	15.4	23.72	53.00	111.3	2.71	137	327.73	190.73
23:00-24:00	13.5	13.5	17.56	43.17	131.0	2.44	104	298.17	194.17
Max	83.90	83.90	83.50	175.57	254.30	11.65	189.00	672.07	520.83
Average	40.73	40.73	55.21	117.77	199.90	6.01	120.54	499.43	378.89
Total distribution	977.40	977.40	1325.02	2826.40	4797.60	144.26	2893.00	11986.28	9093.28
Hourly maximum dist./average dist. (Peak dist.)	2.06	2.06	1.51	1.49	1.27	1.94	1.57	1.35	1.37



00:00-01:00	(31.53)	(31.53)	(40.72)	(59.83)	(122.00)	(3.82)	(8.54)	(234.91)	(226.37)
01:00-02:00	(31.63)	(31.63)	(47.20)	(68.59)	(81.90)	(3.91)	(58.54)	(260.14)	(201.60)
02:00-03:00	(31.93)	(31.93)	(40.23)	(64.03)	(78.50)	(3.03)	(77.54)	(263.33)	(185.79)
03:00-04:00	(20.83)	(20.83)	(35.13)	(51.20)	(79.00)	(2.87)	(60.54)	(228.74)	(168.20)
04:00-05:00	(12.33)	(12.33)	(23.39)	(45.02)	47.10	(2.95)	(3.54)	(27.80)	(24.26)
05:00-06:00	(1.03)	(1.03)	1.86	33.46	41.10	2.28	21.46	100.16	78.70
06:00-07:00	13.78	13.78	17.68	24.78	48.40	2.17	33.46	126.49	93.03
07:00-08:00	9.98	9.98	25.45	48.29	43.80	5.64	49.46	172.64	123.18
08:00-09:00	(6.83)	(6.83)	7.61	50.65	49.10	4.07	29.46	140.89	111.43
09:00-10:00	26.38	26.38	25.83	57.80	54.40	3.91	21.46	163.40	141.94
10:00-11:00	43.18	43.18	2.89	30.60	31.80	4.35	49.46	119.10	69.64
11:00-12:00	25.08	25.08	23.76	37.54	22.10	3.78	19.46	106.64	87.18
12:00-13:00	7.28	7.28	17.98	44.62	44.00	5.06	29.46	141.12	111.66
13:00-14:00	8.38	8.38	15.60	34.69	30.20	0.88	17.46	98.83	81.37
14:00-15:00	5.98	5.98	23.68	18.16	14.80	(1.89)	29.46	84.21	54.75
15:00-16:00	9.18	9.18	10.99	24.64	24.90	(0.44)	27.46	87.55	60.09
16:00-17:00	11.18	11.18	24.19	31.32	22.90	(1.09)	(0.54)	76.78	77.32
17:00-18:00	9.18	9.18	16.21	34.67	27.20	(1.25)	(90.54)	(13.71)	76.83
18:00-19:00	9.18	9.18	20.70	27.42	24.70	(0.32)	(99.54)	(27.04)	72.50
19:00-20:00	9.38	9.38	20.36	5.03	24.00	0.20	68.46	118.05	49.59
20:00-21:00	(4.23)	(4.23)	28.29	(46.00)	47.80	(0.84)	(2.54)	26.71	29.25
21:00-22:00	4.78	4.78	(27.29)	(29.71)	(79.40)	(3.04)	5.46	(133.98)	(139.44)
22:00-23:00	(25.33)	(25.33)	(31.49)	(64.77)	(88.60)	(3.30)	16.46	(171.70)	(188.16)
23:00-24:00	(27.23)	(27.23)	(37.65)	(74.60)	(68.90)	(3.57)	(16.54)	(201.26)	(184.72)
Necessary reservoir volume (m3)	192.85	192.85	283.09	503.72	598.30	32.33	418.42	1535.88	1318.51
Necessary volume /average hourly dist. Volume (hour)	4.74	4.74	5.13	4.28	2.99	5.38	3.47	3.08	3.48

(m³/hour)

District name	GRAND TOTAL	GRAND TOTAL
Zone No.		(without14)
Hour/Date		
00:00-01:00	530.95	418.95
01:00-02:00	565.81	503.81
02:00-03:00	570.23	527.23
03:00-04:00	718.55	658.55
04:00-05:00	1104.71	987.71
05:00-06:00	1547.87	1405.87
06:00-07:00	1733.22	1579.22
07:00-08:00	1783.72	1613.72
08:00-09:00	1785.34	1635.34
09:00-10:00	1768.33	1626.33
10:00-11:00	1753.71	1583.71
11:00-12:00	1641.45	1501.45
12:00-13:00	1661.99	1511.99
13:00-14:00	1571.75	1433.75
14:00-15:00	1566.91	1416.91
15:00-16:00	1598.66	1450.66
16:00-17:00	1609.55	1489.55
17:00-18:00	1501.36	1471.36
18:00-19:00	1453.91	1432.91
19:00-20:00	1549.16	1360.16
20:00-21:00	1266.07	1148.07
21:00-22:00	927.55	801.55
22:00-23:00	715.75	578.75
23:00-24:00	629.87	525.87
Max	1785.34	1635.34
Average	1314.85	1194.31
Total distribution	31556.42	28663.42
Hourly maximum dist./average dist. (Peak	1.36	1.37

00:00-01:00	(783.90)	(775.36)
01:00-02:00	(749.04)	(690.50)
02:00-03:00	(744.62)	(667.08)
03:00-04:00	(596.30)	(535.76)
04:00-05:00	(210.14)	(206.60)
05:00-06:00	233.02	211.56
06:00-07:00	418.37	384.91
07:00-08:00	468.87	419.41
08:00-09:00	470.49	441.03
09:00-10:00	453.48	432.02
10:00-11:00	438.86	389.40
11:00-12:00	326.60	307.14
12:00-13:00	347.14	317.68
13:00-14:00	256.90	239.44
14:00-15:00	252.06	222.60
15:00-16:00	283.81	256.35
16:00-17:00	294.70	295.24
17:00-18:00	186.51	277.05
18:00-19:00	139.06	238.60
19:00-20:00	234.31	165.85
20:00-21:00	(48.78)	(46.24)
21:00-22:00	(387.30)	(392.76)
22:00-23:00	(599.10)	(615.56)
23:00-24:00	(684.98)	(668.44)
Necessary reservoir volume (m ³)	4804.17	4598.29
Necessary volume /average hourly dist. Volume (hour)	3.65	3.85





Estimation of Unaccounted-For Water (UFW)

District	Zone	Zone meter reading (Total amount of distributed water in the zone) m ³ /3days	Customer's meter reading (Total amount of consumed in the zone) m ³ /3days	UFW or Leakage amount m ³ /3days	% of UFW or Leakage %	The month in which it is measured
Don Penh	Zone 1	8,479	6,549	1,930	23	Nov. 1999
	Zone 5A	4,260	3,746	514	12	Oct. 1999
	Zone 5B	1,892	1,598	294	16	Sept. 1999
	Zone 6	3,316	2,726	590	18	Jan. 2000
	Zone 7A	3,358	2,635	723	22	Aug. 1999
	Zone 12	373	287	86	23	Feb. 2000
	Zone 14	8,268	7,623	645	8	Mar. 2000
	Zone 15	1,985	1,628	357	18	Dec. 1999
	total/ave.	31,931	26,792	5,139	16	
7th January	Zone 1	3,118	2,829	289	9	Feb. 2000
	Zone 2	1,907	1,761	146	8	Feb. 2000
	Zone 7	2,813	2,477	336	12	Feb. 2000
	Zone 8	1,997	1,690	307	15	Feb. 2000
	Zone 10	2,656	2,474	182	7	Mar. 2000
	total/ave.	12,491	11,231	1,260	10	
tota/ave.		44,422	38,023	6,399	14	

Source : PPWSA

Results of Boring Survey

RESEARCH AND DESIGN ENTERPRISE SOIL TESTING LABORATORY		FIELD BORING LOG BOREHOLE No..R-1		SHEET 1			
STANDARD PENETRATION TEST							
Project: W.T.P		Date started..13/06/2000		Location:Phum prek W.T.P, khan toul kork, Phnom Penh Kingdom of Cambodia.			
Owner :		Date finished 13/06/2000		Size 120mm ,Elevation: + 11.645			
Contractor :		Method :Rotary Auger		On 13/06/2000 Time...07h30 am			
sub contractor :		Depth to water flow : 4.50m.		On 13/06/2000 Time. 10 h30 am			
sub contractor :		Depth to water level: 2.70m.					
DEPTH and TYPE OF SAMPLE			DESCRIPTION OF STRATA	DEPTH and THICK.	LEGEND of SOIL	S P T (N) BLOWS/300MM	RECOVERY RATIO (MM)
(M)	(M)	D U No					
0			1/ Made ground(brown silt, clay, sand, crushed stone, crushed brick and plastic bag, encountered from ground surface to 1.00m depth.	0.00			
1							
2		D	1 Dark-grey, brown silt, clay, silt and sand encountered from 1.00 to 4.00m depth.	(4.00)		1.50 to 1.95m = 1, 2, 4, N-6	200/450
3							
4		D		4.00		3.00 to 3.45m = 1, 1, 2, N-3	300/450
5							
6		U	2/ Medium brown silty lean CLAY(CL).	(3.00)		5.00m to 5.45m = 1, 3, 2, N-5	300/450
7		D				6.00m to 6.45m = 2, 3, 5, N-8	300/450
8							
9		U	3/ Stiff red, grey fat CLAY(CH).	(1.00)		7.50m to 7.95m = 2, 4, 6, N-10	300/450
10							
11		D	4/ Medium dense yellow and grey very clayey fine to medium SAND(CS), with gravel.	(3.00)		9.00m to 9.45m = 3, 5, 10, N-15	320/450
12							
13		D	5/ Dense grey and yellow very clayey fine to medium SAND(CS), with gravel.	(2.00)		10.50m to 10.95m 6, 10, 11, N-21	300/450
14							
15		D	6/ Dense yellow and very clayey medium to coarse SAND(CS), with gravel.	(3.00)		12.00m to 12.45m 9, 20, 22, N-42	450/450
						13.50m to 13.95m 10, 20, 20, N-40	330/450
consistency		RELATIVE DENSITY		TYPE OF SAMPLE		TYPE OF FIELD TEST	
SPT(N),Blows/300mm		SPT(N),Blows/300mm		D-disturbed sample		SPT Standard penetration test	
Very soft 0 to 2		Very loose 0 to 4		U-Undisturbed sample		VT Shear vane test	
Soft 2 to 4		Loose 4 to 10				PT pocket penetrometer test	
Medium 4 to 8		Medium 10 to 30				q _u =Kgf/cm ²	
Stiff 8 to 15		Dense 30 to 50				K Permeability	
Very stiff 15 to 30		Very dense Over 50				Figure 2	
Hard 30 to 50							

RESEARCH AND DESIGN ENTERPRISE SOIL TESTING LABORATORY		FIELD BORING LOG BOREHOLE No..R-1			SHEET 2			
STANDARD PENETRATION TEST								
Project: W.T.P		Date started..13/06/2000		Location:Phum prek W.T.P, khan toul kork, Phnom Penh Kingdom of Cambodia.				
Owner :		Date finished 13/06/2000		Size 120mm ,Elevation: + 11.615				
Contractor :		Method :Rotary Auger		On 13/06/2000		Time:..07h30 am		
sub contractor :		Depth to water flow : 4.50m.		On 13/06/2000		Time. 10 h30 am		
DEPTH and TYPE OF SAMPLE		DESCRIPTION OF STRATA			DEPTH and THICK.	LEGEND of SOIL	S P T (N) BLOWS/300MM	RECOVERY RATIO (MM)
(M)	(M)	D	U	No				
15		D		13	6/ Dense yellow and very clayey medium to coarse SAND(CS), with gravel.		15.00m to 15.45 = 9, 13, 20, N-33	450/450
16					7/ Very dense yellow and grey very clayey medium to coarse SAND(CS), with gravel.			
17		D		14	End of borehole No R-1 at 17.00m depth.		16.50m to 16.95m 25, 25,15,N>50	250/400
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
consistency		RELATIVE DENSITY		TYPE OF SAMPLE		TYPE OF FIELD TEST		
SPT(N),Blows/300mm		SPT(N),Blows/300mm		D-disturbed sample		SPT Standard penetration test		
Very soft 0 to 2		Very loose 0 to 4		U-Undisturbed sample		VT Shear vane test		
Soft 2 to 4		Loose 4 to 10				PT pocket penetrometer test		
Medium 4 to 8		Medium 10 to 30				q _v =Kgf/cm ²		
Stiff 8 to 15		Dense 30 to 50				K Permeability		
Very stiff 15 to 30		Very dense Over 50				Figure 2a		
Hard 30 to 50								









RESEARCH AND DESIGN ENTERPRISE SOIL TESTING LABORATORY				FIELD BORING LOG BOREHOLE No..R-2				SHEET 1		
STANDARD PENETRATION TEST										
Project: W.T.P		Date started..12/06/2000			Location:Phum prek W.T.P, khan toul kork, Phnom Penh Kingdom of Cambodia.					
Owner :		Date finished 12/06/2000			Size 120mm ,Elevation: + 11.250					
Contractor :		Method :Rotary Auger			On 12/06/2000 Time...10h0am					
sub contractor :		Depth to water flow : 4.50m.			On 12/06/2000 Time. 15 h15pm					
sub contractor :		Depth to water level: 2.50m.								
DEPTH and TYPE OF SAMPLE				DESCRIPTION OF STRATA	DEPTH and THICK.	LEGEND of SOIL	SPT (N) BLOWS/300MM	RECOVERY RATIO (MM)		
(M)	(M)	D	U						No	
0	-				1/ Made ground (Brown silt, clay, sand, crushed stone and crushed brick, encountered from surface to 2.00m depth.	0.00				
1	-									
2	-		D	1	Dark-grey, black clay, silt, sand and peat, encountered from 2.00m to 4.50m depth.	(4.50)		1.50 to 1.95m = 1, 1, 2, N-3		200/450
3	-		D	2				3.00 to 3.45m = 0, 0, 0, N<1		250/450
4	-					4.50				
5	-		D	3	2/ Stiff trace sandy fat CLAY(CH).	5.00		4.50m to 4.95m = 2, 3, 7, N-10		250/450
6	-		D	4	3/ Very soft dark-grey clay, silt, sand and peat.	(1.50)		5.50m to 5.95m = 1, 1, 1, N-2		300/450
7	-		D	5	4/ Stiff yellow and grey fine sandy lean CLAY (CL).	(1.00)				
8	-		U	6	5/ Medium dense yellow F-M SAND, gravel.	8.00				
9	-		D	7	6/ Very dense yellow F-M SAND, gravel.	8.50		7.90m to 8.35m = 6, 8, 43, N-51		400/450
10	-		D	8	7/ Medium dense grey, yellow fine to medium SAND(CS), with gravel.	(1.00)		9.00m to 9.45m = 5, 10, 10, N-20		400/450
11	-		D	9	8/ Medium dense grey and yellow very clayey medium to coarse SAND(CS), with gravel.	(1.50)		10.50m to 10.95m 8, 13, 15, N-28		350/450
12	-									
13	-		D	10	9/ Very stiff grey and yellow fine to medium sandy lean CLAY(CL).	(3.00)		12.00m to 12.45m 11, 14, 15, N-29		370/450
14	-		D	11		14.00		13.50m to 13.95m 9, 13, 14, N-27		350/450
15	-				10/ Dense yellow and grey very clayey medium to coarse SAND(CS), gravel.					
consistency		RELATIVE DENSITY		TYPE OF SAMPLE		TYPE OF FIELD TEST				
SPT(N),Blows/300mm		SPT(N),Blows/300mm		D-disturbed sample		SPT Standard penetration test				
Very soft 0 to 2		Very loose 0 to 4		U-Undisturbed sample		VT Shear vane test				
Soft 2 to 4		Loose 4 to 10				PT pocket penetrometer test				
Medium 4 to 8		Medium dense 10 to 30				q _u =Kgf/cm ²				
Stiff 8 to 15		Dense 30 to 50				K Permeability				
Very stiff 15 to 30		Very dense Over 50				Figure 3				
Hard 30 to 50										

RESEARCH AND DESIGN ENTERPRISE SOIL TESTING LABORATORY				FIELD BORING LOG BOREHOLE No..R-2 STANDARD PENETRATION TEST				SHEET 2		
Project: W.T.P		Date started..12/06/2000		Location:Phum prek W.T.P, khan toul kork, Phnom Penh Kingdom of Cambodia.						
Owner :		Date finished 12/06/2000		Method :Rotary Auger		Size 120mm ,Elevation: + 11.250				
Contractor :		Depth to water flow : 4.50m.		On 12/06/2000		Time...10h0am				
sub contractor :		Depth to water level: 2.50m.		On 12/06/2000		Time. 15 h15pm				
DEPTH and TYPE OF SAMPLE				DESCRIPTION OF STRATA	DEPTH and THICK.	LEGEND of SOIL	S P T (N) BLOWS/300MM	RECOVERY RATIO (MM)		
(M)	(M)	D	U							No
15	-		D	12	10/ Dense yellow and grey very clayey medium to coarse SAND(CS), gravel.		15.00m to 15.45m = 25, 20, 21, N-41	450/450		
16	-						16.50			
17	-		D	13	11/ Hard grey mottled yellow fine to medium sandy lean CLAY(CL).		(1.00)	16.50m to 16.95m 10, 20, 19, N-39	300/450	
18	-						17.50			
19	-		D	14	12/ Dense yellow very clayey medium to coarse SAND(CS), with gravel.	(2.50)	18.00m to 18.45m 10, 19, 19, N-38	320/450		
20	-		U	15						
20	-		D	16			19.50m to 19.95m 25, 22, 22, N-44	330/450		
21	-				End of borehole No R-2 at 20.00m depth.					
22	-									
23	-									
24	-									
25	-									
26	-									
27	-									
28	-									
29	-									
30	-									
consistency		RELATIVE DENSITY		TYPE OF SAMPLE		TYPE OF FIELD TEST				
SPT(N),Blows/300mm		SPT(N),Blows/300mm		D-disturbed sample		SPT Standard penetration test				
Very soft 0 to 2		Very loose 0 to 4		U-Undisturbed sample		VT Shear vane test				
Soft 2 to 4		Loose 4 to 10				PT pocket penetrometer test				
Medium 4 to 8		Medium dense 10 to 30				q _u =Kgf/cm ²				
Stiff 8 to 15		Dense 30 to 50				K Permeability				
Very stiff 15 to 30		Very dense Over 50								
Hard 30 to 50										

Figure 3a

STANDARD PENETRATION TEST

Project: W.T. P	Date started..13/06/2000	Location:Phum prek W.T.P, khan toul kork, Phnom Penh Kingdom of Cambodia.
Owner :	Date finished 13/06/2000	Size 120mm ,Elevation.: + 11.575
Contractor :	Method :Rotary Auger	On 13/06/2000 Time...11h00Am
sub contractor :	Depth to water flow : 6.00m.	On 13/06/2000 Time. 18 h00 Pm
	Depth to water level: 2.60m.	

DEPTH and TYPE OF SAMPLE					DESCRIPTION OF STRATA	DEPTH and THICK.	LEGEND of SOIL	S P T (N) BLOWS/300MM	RECOVERY RATIO (MM)
(M)	(M)	D	U	No					
0	-				1/ Made ground(Reddish-brown sand, clay, silt and gravel(laterite), encountered from ground surface to 0.30m and crushed stone encountered from 0.30m to 0.50m depth.	0.00		1.50 to 1.95m = 1, 2, 3, N-5	350/450
1	-				Medium brown silt, clay and sand from 0.5m to..	(2.50)			
2	-	D		1	2/ Stiff brown mottled grey fat CLAY(CH).	2.50		3.00 to 3.45m = 1, 2, 2, N-4	350/450
3	-		U	2		3.00			
4	-	D		3		4.50		4.50m to 4.95m = 2, 4, 6, N-10	270/450
5	-		U	4		5.50			
6	-	D		5	3/ Soft dark-grey clay, silt, sand and peat.	(1.00)		6.00m to 6.45m = 1, 1, 2, N-3	400/450
7	-			6	6.50				
8	-	D		7	4/ Medium dense yellow, grey very silty fine medium SAND(MS). with gravel.	(4.50)		7.50m to 7.95m = 4, 9, 11, N-20	300/450
9	-			8		9.00			
10	-	D		9		10.00		9.00m to 9.45m = 8, 18, 12, N-30	320/450
11	-		U	10		11.50			
12	-	D		11	5/ Medium dense grey, yellow very clayey fine to medium SAND(CS).	(1.50)		10.50m to 10.95m 6, 10, 13, N-23	300/450
13	-			12	12.00				
14	-	D		13	6/ Dense greenish-grey very clayey medium to coarse SAND(CS), with gravel.	(4.50)		12.00m to 12.45m 10, 17, 24, N-41	350/450
15	-			14		13.50			
		D		15	END OF BOREHOLE No R-3 at 15.00m.	15.00		13.50m to 13.95m 7, 13, 17, N-30	350/450
								14.50m to 14.95m 7, 18, 19, N-37	300/450

consistency		RELATIVE DENSITY		TYPE OF SAMPLE		TYPE OF FIELD TEST	
SPT(N), Blows/300mm		SPT(N), Blows/300mm		D-disturbed sample	U-Undisturbed sample	SPT	Standard penetration test
Very soft	0 to 2	Very loose	0 to 4			VT	Shear vane test
Soft	2 to 4	Loose	4 to 10			PT	pocket penetrometer test
Medium	4 to 8	Medium				q _s	=Kgf/cm ²
Stiff	8 to 15	dense	10 to 30			K	Permeability
Very stiff	15 to 30	Dense	30 to 50				
Hard	30 to 50	Very dense	Over 50				

Figure 4

STANDARD PENETRATION TEST

Project: W.T.P	Date started..15/06/2000	Location:Phum prek W.T.P, khan toul kork, Phnom Penh Kingdom of Cambodia.
Owner :	Date finished 15/06/2000	Size 120mm ,Elevation:: + 10.395
Contractor :	Method :Rotary Auger	On 15/06/2000 Time...07h00Am
sub contractor :	Depth to water flow : 3.20m.	On 15/06/2000 Time. 11 h30am
	Depth to water level: 1.70m.	

DEPTH and TYPE OF SAMPLE					DESCRIPTION OF STRATA	DEPTH and THICK.	LEGEND of SOIL	S P T (N) BLOWS/300MM	RECOVERY RATIO (MM)
(M)	(M)	D	U	No					
0					1/ Made ground(brown silt,clay and sandy) encountered from ground surface to 1.00m.	0.00			
1					Medium brown clay and lean SILT(ML), encountered from 1.00m to 3.50m depth.	(3.50)		1.50 to 1.95m = 1, 2, 3, N-5	200/450
2		D		1				3.00 to 3.45m = 1, 2, 3, N-5	250/450
3									
4					2/ Very loose dark-grey silty fine SAND(MS).	(1.50)		4.50m to 4.95m = 1, 1, 1, N-2	400/450
5		D		4					
6					3/ Very soft brown clay, SILT(ML).	(2.00)		6.00m to 6.45m = 0, 1, 1, N-2	300/450
7		D		6					
8					4/ Stiff grey, yellow and brown fat CLAY(CH).	(1.00)		7.50m to 7.95m = 3, 4, 7, N-11	350/450
9		D		8					
10					5/ Very stiff orange, grey and yellow fine to medium sandy lean CLAY(CL).	(1.50)		9.00m to 9.45m = 6, 12, 14, N-26	300/450
11		D		10				10.50m to 10.95m 10, 11, 11, N-22	320/450
12					6/ Medium dense yellow and grey very clayey medium to coarse SAND(CS), gravel.	(3.50)		12.00m to 12.45m 8, 13, 16, N-29	370/450
13		D		11					
14					7/ Dense greenish-grey very clayey medium to coarse SAND(CS), with gravel.	(2.50)		13.50m to 13.95m 9, 18, 29, N-47	300/450
15		D		12					

consistency		RELATIVE DENSITY		TYPE OF SAMPLE		TYPE OF FIELD TEST	
SPT(N),Blows/300mm		SPT(N),Blows/300mm		D-disturbed sample		SPT	Standard penetration test
Very soft	0 to 2	Very loose	0 to 4	U-Undisturbed sample		VT	Shear vane test
Soft	2 to 4	Loose	4 to 10			PT	pocket penetrometer test
Medium	4 to 8	Medium	10 to 30			q _u	=Kgf/cm ²
Stiff	8 to 15	dense	30 to 50			K	Permeability
Very stiff	15 to 30	Dense	Over 50				
Hard	30 to 50	Very dense.					

Figure 5

RESEARCH AND DESIGN ENTERPRISE		FIELD BORING LOG		SHEET ?				
SOIL TESTING LABORATORY		BOREHOLE No..T-1						
STANDARD PENETRATION TEST								
Project: W.T.P		Date started..14/06/2000		Location:Phum prek W.T.P, khan toul kork, Phnom Penh Kingdom of Cambodia.				
Owner :		Date finished 14/06/2000		Size 120mm ,Elevation:: + 10.395				
Contractor :		Method :Rotary Auger		On 14/06/2000 Time...07h00Am				
sub contractor :		Depth to water flow : 3.20m.		On 14/06/2000 Time. 11 h30am				
Depth to water level: 1.40m.								
DEPTH and TYPE OF SAMPLE					DEPTH and THICK.	LEGEND of SOIL	SPT (N) BLOWS/300MM	RECOVERY RATIO (MM)
(M)	(M)	D	U	No				
15	-	D		13	15.50		15.00m to 15.45 = 10, 15, 30, N-45	270/450
16	-							
17	-	D		14	(2.50)		16.50m to 16.95m 12, 26, 25, N-51	250/450
18	-	D		15	18.00		16.50m to 16.95m 6, 20, 30, N-50	270/450
19	-							
20	-							
21	-							
22	-							
23	-							
24	-							
25	-							
26	-							
27	-							
28	-							
29	-							
30	-							
End of borehole No T-1 at 18.00m depth.								
Consistency		RELATIVE DENSITY		TYPE OF SAMPLE		TYPE OF FIELD TEST		
SPT(N),Blows/300mm		SPT(N),Blows/300mm		D-disturbed sample		SPT Standard penetration test		
Very soft 0 to 2		Very loose 0 to 4		U-Undisturbed sample		VT Shear vane test		
Soft 2 to 4		Loose 4 to 10				PT pocket penetrometer test		
Medium 4 to 8		Medium 10 to 30				q _u =Kgf/cm ²		
Stiff 8 to 15		Dense 30 to 50				K Permeability		
Very stiff 15 to 30		Very dense Over 50				Figure 5a		
Hard 30 to 50								

STANDARD PENETRATION TEST

Project: W.T.P	Date started..14/06/2000	Location:Phum prek W.T.P, khan toul kork, Phnom Penh Kingdom of Cambodia.
Owner :	Date finished 14/06/2000	Size 120mm ,Elevation.: + 11.240
Contractor :	Method :Rotary Auger	On 14/06/2000 Time...06h30Am
sub contractor :	Depth to water flow : 3.20m.	On 14/06/2000 Time. 12 h30pm
	Depth to water level: 1.40m.	

DEPTH and TYPE OF SAMPLE					DESCRIPTION OF STRATA	DEPTH and THICK.	LEGEND of SOIL	S P T (N) BLOWS/300MM	RECOVERY RATIO (MM)
(M)	(M)	D	U	No					
0					1/ Made ground (Brown clay, silt, sand and crushed brick, crushed stone, encountered from ground surface to 2.00m depth.	0.00			
1						(2.00)			
2		D		1	2/ Medium brown clay lean SILT(ML).	2.00		1.50 to 1.95m = 2, 3, 3, N-6	200/450
3			U	2		(1.00)			
4		D		3	3/ Soft brown silt, fat CLAY(CH).	(1.00)		3.00 to 3.45m = 1, 2, 2, N-4	350/450
5					4/ Very loose black peat, clay and fine SAND. (MS).	(1.00)			
6		D		4	5/ Soft brown fat CLAY(CH).	5.00		4.50m to 4.95m = 1, 0, 1, N-1	400/450
7			U	5		(1.00)			
8		D		6	6/ Very loose dark-grey silty fine SAND(MS).	(1.00)			
9					7/ Medium brownish-grey fat SILT(MH).	7.50		6.50m to 6.95m = 1, 0, 0, N<1	400/450
10		D		7				7.50m to 7.95m = 4, 6, 9, N-15	250/450
11					8/ Medium dense yellow, grey very clayey fine to coarse SAND(CS), with gravel.	(4.50)		9.00m to 9.45m = 5, 8, 12, N-20	300/450
12		D		10		12.00		10.50m to 10.95m 5, 10, 12, N-22	270/450
13					9/ Dense yellow, grey very clayey medium to coarse SAND(CS), with gravel.	(1.50)		12.00m to 12.45m 11, 16, 17, N-33	300/450
14		D		12		13.50		13.50m to 13.95m 6, 12, 16, N-28	450/450
15					10/ Medium dense greenish-grey very clayey fine to coarse SAND, with gravel.	(1.50)			

consistency		RELATIVE DENSITY		TYPE OF SAMPLE		TYPE OF FIELD TEST	
SPT(N),Blows/300mm		SPT(N),Blows/300mm		D-disturbed sample		SPT Standard penetration test	
Very soft	0 to 2	Very loose	0 to 4	U-Undisturbed sample		VT	Shear vane test
Soft	2 to 4	Loose	4 to 10			PT	pocket penetrometer test
Medium	4 to 8	Medium				q _u	=Kgf/cm ²
Stiff	8 to 15	dense	10 to 30			K	Permeability
Very stiff	15 to 30	Dense	30 to 50				
Hard	30 to 50	Very dense	Over 50				

Figure 6

RESEARCH AND DESIGN ENTERPRISE SOIL TESTING LABORATORY				FIELD BORING LOG BOREHOLE No..T-2				SHEET 2	
STANDARD PENETRATION TEST									
Project: W.T.P		Date started..14/06/2000			Location:Phum prek W.T.P, khan toul kork, Phnom Penh Kingdom of Cambodia.				
Owner :		Date finished 14/06/2000			Size 120mm ,Elevation: + 11.240				
Contractor :		Method :Rotary Auger			On 14/06/2000		Time...06h30Am		
sub contractor :		Depth to water flow : 3.20m.			On 14/06/2000		Time. 12 h30pm		
DEPTH and TYPE OF SAMPLE		DESCRIPTION OF STRATA				DEPTH and THICK.	LEGEND of SOIL	S P T (N) BLOWS/300MM	RECOVERY RATIO (MM)
(M)	(M)	D	U	No					
15	-			13	11/ Very dense grey and yellow very clayey medium to coarse SAND(CS), with gravel.	(1.00)		15.00m to 15.45 = 14, 29, 21, N>50	350/400
16	-				12/ Dense grey and yellow very clayey medium to coarse SAND(CS), with gravel.	(1.00)		1blow = 5mm.	
17	-	D		14		17.00		16.50m to 16.95m 8, 19, 25, N-44	330/450
18	-				End of borehole No T-2 at 17.00m depth.				
19	-								
20	-								
21	-								
22	-								
23	-								
24	-								
25	-								
26	-								
27	-								
28	-								
29	-								
30	-								
consistency		RELATIVE DENSITY		TYPE OF SAMPLE			TYPE OF FIELD TEST		
SPT(N),Blows/300mm		SPT(N),Blows/300mm		D-disturbed sample			SPT Standard penetration test		
Very soft	0 to 2	Very loose	0 to 4	U-Undisturbed sample			VT Shear vane test		
Soft	2 to 4	Loose	4 to 10				PT pocket penetrometer test		
Medium	4 to 8	Medium					q _u =Kg/cm ²		
Stiff	8 to 15	dense	10 to 30				K Permeability		
Very stiff	15 to 30	Dense	30 to 50				Figure 6a		
Hard	30 to 50	Very dense	Over 50						

STANDARD PENETRATION TEST

Project: W.T. P	Date started..14/06/2000	Location:Phum prek W.T.P, khan toul kork, Phnom Penh Kingdom of Cambodia.
Owner :	Date finished 14/06/2000	Size 120mm ,Elevation:.. ± 11.39C
Contractor :	Method :Rotary Auger	On 14/06/2000 Time...13h0pm
sub contractor :	Depth to water flow : 3.30m.	On 14/06/2000 Time. 18 h30pm
	Depth to water level: 2.60m.	

DEPTH and TYPE OF SAMPLE					DESCRIPTION OF STRATA	DEPTH and THICK.	LEGEND of SOIL	S P T (N) BLOWS/300MM	RECOVERY RATIO (MM)
(M)	(M)	D	U	No					
0	-								
1	-				2/ Medium brown, grey and yellow fat CLAY.	2.00		1.50 to 1.95m = 2, 3, 3, N-6	370/450
2	-	D		1	Brown silt, clay and sand from 0.50m to 2.00m.	2.00			
3	-		U	2	2/ Medium brown, grey and yellow fat CLAY.	2.50			
4	-	D		3	3/ Soft brown silty lean CLAY(CL).	3.00			
5	-		D	4	4/ Very loose dark-grey silty fine SAND(MS).	4.00		3.00 to 3.45m = 1, 3, 1, N-4	300/450
6	-		U	5					
7	-	D		6	5/ Medium brown, dark-grey silty lean CLAY (CL).	4.00		5.00m to 5.45m = 1, 2, 2, N-4	250/450
8	-		D	7				6.00m to 6.45m = 2, 3, 3, N-6	200/450
9	-	D		8				7.50m to 7.95m = 2, 3, 3, N-6	350/450
10	-		D	9	6/ Stiff yellow and grey fine to medium sandy lean CLAY(CL).	8.00		9.00m to 9.45m = 3, 4, 4, N-8	350/450
11	-		D	10				10.50m to 10.95m 4, 5, 8, N-13	300/450
12	-		D	11	7/ Medium dense greenish-grey very clayey fine to coarse SAND(CS), with gravel.	11.50			
13	-		D	12				12.00m to 12.45m 6, 10, 16, N-26	350/450
14	-		D	12	8/ Dense greenish-grey, light-grey very clayey medium to coarse SAND(CS), with gravel.	13.50		13.50m to 13.95m 8, 11, 15, N-26	450/450

consistency		RELATIVE DENSITY		TYPE OF SAMPLE		TYPE OF FIELD TEST	
SPT(N),Blows/300mm	SPT(N),Blows/300mm	SPT(N),Blows/300mm		D-disturbed sample		SPT Standard penetration test	
Very soft 0 to 2	Very loose 0 to 4	U-Undisturbed sample		VT Shear vane test		PT pocket penetrometer test	
Soft 2 to 4	Loose 4 to 10			q _b =Kgf/cm ²		K Permeability	
Medium 4 to 8	Medium dense 10 to 30						
Stiff 8 to 15	Dense 30 to 50						
Very stiff 15 to 30	Very dense Over 50						
Hard 30 to 50						Figure 7	

STANDARD PENETRATION TEST

Project: W.T.P	Date started: 14/06/2000	Location: Phum prek W.T.P, Khan Toul Kork, Phnom Penh Kingdom of Cambodia.
Owner :	Date finished: 14/06/2000	Size 120mm, Elevation: + 11.390
Contractor :	Method: Rotary Auger	On 14/06/2000 Time: 13h0pm
sub contractor :	Depth to water flow: 3.30m.	On 14/06/2000 Time: 18 h30pm
	Depth to water level: 2.60m.	

DEPTH and TYPE OF SAMPLE					DESCRIPTION OF STRATA	DEPTH and THICK.	LEGEND of SOIL	SPT (N) BLOWS/300MM	RECOVERY RATIO (MM)
(M)	(M)	D	U	No					
15		D		13	8/ Dense greenish-grey, light-grey very clayey medium to coarse SAND(CS), with gravel.	(4.50)		15.00m to 15.45m = 11, 16, 19, N-35	400/450
16				14					
17		D		14					
18				15	9/ Very dense grey, yellow very clayey medium to coarse SAND(CS), with gravel.	18.50		16.50m to 16.95m 6, 13, 30, N-43	450/450
19		D		15					
20		D		16		20.00		18.00m to 18.45m 13, 18, 24, N-42	370/450
21					End of borehole No T-3 at 20.00m depth.			19.50m to 19.95m 3, 17, 35, N-52	350/450
22									
23									
24									
25									
26									
27									
28									
29									
30									

consistency		RELATIVE DENSITY		TYPE OF SAMPLE		TYPE OF FIELD TEST	
SPT(N),Blows/300mm		SPT(N),Blows/300mm					
Very soft	0 to 2	Very loose	0 to 4	D-disturbed sample	SPT	Standard penetration test	
Soft	2 to 4	Loose	4 to 10	U-Undisturbed sample	VT	Shear vane test	
Medium	4 to 8	Medium			PT	pocket penetrometer test	
Stiff	8 to 15	dense	10 to 30		q _w	=Kgf/cm ²	
Very stiff	15 to 30	Dense	30 to 50		K	Permeability	
Hard	30 to 50	Very dense	Over 50				

Figure 7a

Appendix 5- 7 Planned Facilities and Equipment

1) Facilities and Equipment

Facility and Equipment	Contents and Specifications
1.Intake Facility	
1.1 Intake pump (New)	3 sets Vertical mixed flow pump 36.7m ³ / min × 21.0 m × 185 kW × 50 Hz × 3 kV
1.2 Intake gate (Rehab.)	4 sets Replacement of the operating rods of the gates Operating apparatus with bevel gear 4 sets 50 mm × 7.16 m 2 sets 50 mm × 13.42 m 2 sets
1.3 Overhead traveling crane (Rehab.)	1 set Replacement of trolley of the crane Hoisting Load : 6.0 ton Hoisting height : 8.0m Motor : 5.5 kW × 380 V Traverse motion : 0.75 kW × 380 V
1.4 Air valve (Rehab.)	1 set The existing valve shall be removed. A new Dia.75mm air exhaust valve shall be installed.
1.5 Air Vessel (Rehab.)	1 set 18 m ³ × 2 vessels The existing vessels under the ground shall be abandoned. The new facility shall be constructed above the ground. Piping shall be connected with 1,200 mm new raw water main and 700 mm existing raw water main as standby.
2. Raw Water Mains	
2.1 Raw water valve chamber (New)	1 chamber New connecting pipes (900 mm × 2 pipes) shall be installed to the flanged branch of the existing header pipe of the raw water main. Raw water valve chamber (RC, W 5.10 m × L 3.90 m × H 3.33 m) Branch valve 900 mm, Butterfly valve 2 sets
2.2 Raw water mains (New)	1,500 m Dia. 1,200 mm Ductile iron pipe with inner mortar lining, Class 3
2.3 Connecting pipe between raw water mains and receiving well (New)	Approx. 50 m 1,200m Ductile iron pipe with inner mortar lining, Class 3
3. Receiving Well	
3.1 Receiving well (New)	1 chamber RC, W 5.30 m × L 15.90 m × H 6.60 m (Average depth of water 5.00m)
3.2 Raw water flow controlling valve (New)	1 set 1,200 mm Butterfly valve with Baffle (incl. operating apparatus)
3.3 Raw water flow meter (New)	2 sets Weir (SUS316) and float type flow meter Weir length: 1.8 m for new WTP and 3.15 m for the existing WTP
4. Coagulation and Sedimentation Facility	
4.1 Rapid mixing basin (New)	2 basins for existing and new treatment facility Existing ; RC, W 3.15 m × L 5.00 m × Water depth 4.55 m New ; RC, W 1.80 m × L 5.00 m × Water depth 4.55m
4.2 Rapid mixing method	No mechanical equipment (mixing using waterfall at the weir)

4.3 Connecting pipe (New)	2 sets Connecting pipe between the rapid mixing basin and raw water channel of flocculation basin <ul style="list-style-type: none"> • For existing treatment facility ; a 1,350 mm ductile cast iron pipe with inner mortal lining, Class 3 • For new treatment facility ; a 1,000 mm ductile cast iron pipe with inner mortal lining, Class 3
4.4 Flocculation basin (New)	8 basins RC, W 5.50 m × L 7.00 m × H 3.70 m (Average depth of water 3.46 m)
4.5 Flocculator (New)	8 sets Mechanical flocculator 4.5 m × 3.7 kW × 380 V
4.6 Inlet gate of flocculation basin (New)	8 sets Manual operation rectangular gate 450 mm × 450 mm
4.7 Chemical sedimentation basin (New)	4 basins Horizontal flow type sedimentation basin ; RC, W 11.30 m × L 50.00 m × Average depth of water 2.54 m
4.8 Baffle wall at inlet, middle and outlet (New)	4 sets Baffle wall with a opening for cleaning the basin
4.9 Baffle wall at inlet of the existing basins (Improve.)	6 sets Installation of baffle wall at the inlet of the existing basin to reduce turbulence, short-circuit flow and dense flow
4.10 drain valve for settled sludge (New)	8 sets 350mm Top Valve
4.11 Pressure water shooting device (New)	1 set 75 mm ductile cast iron pipes with inner mortal lining, Class 3
4.12 Settled water collecting trough (New)	24 sets Orifice notch type
4.13 Drain valve in settled water channel (New)	3 sets 100mm top valve
5. Rapid sand filter	
5.1 Rapid sand filter (New)	8 basins RC, W 4.50 m × L 10.85 m = 48.825 m ² / basin
5.2 Inlet gate (New)	16 sets W 630 mm × H 380mm Outside screw type power-operated gate (SUS316)
5.3 Filter flow regulator (New)	8 sets Siphon type filter flow regulator (SUS316) Q(Normal) = 300 m ³ / hour, Q(Max) = 399 m ³ / hour connecting diameter 300 mm
5.4 Filtered water valve (New)	8 sets Flangeless butterfly valve with air type actuator 300mm
5.5 Water backwash valve (New)	8 sets Flangeless butterfly valve with air type actuator 450mm
5.6 Air scour valve (New)	8 sets Flangeless butterfly valve with air type actuator 250mm
5.7 Drain valve (New)	8 sets Hand-operated sluice valve with handle 150 mm
5.8 Drain valve in the adjusting equipment room (New)	8 sets Hand-operated sluice valve with handle 75mm
5.9 Filter sand (New)	For 8 filters Sand type: Silica Effective diameter: 1.0mm Uniformity coefficient: below 1.5 Sand thickness 1.0 m
5.10 Filter underdrain device (New)	391 m ² for 8 basins Water and air backwash perforated device

5.11 Filter control desk (New)	4 sets 2 filters duo operated type
6. Chemical feeding facility	
6.1 Chemical building (New)	1 building Ground floor = 540 m ² , 1st floor = 396 m ² , mezzanine floor = 144 m ² The building consists of chemical feeding room, chlorine feeding room, water quality testing laboratory, chlorine neutralization room and chemicals/chlorine storage room.
6.2 Aluminum sulfate solution and feeding equipment (New)	4 solution tanks inner 2.0 m × H 2.6 m, FRP
	4 mixers Vertical type power-operated mixer 450 mm × 2 stages × 3.7 kW × 380 V × 50 Hz
	4 liquid level gauge Terminal type liquid level gauge (3 contact)
	2 feeding equipments W 0.8 m × L 1.5 m × H 0.7m, Triangular notch weir with flow display panel (an angle of 30 degrees)
6.3 Slaked lime feeding equipment (New)	2 mixing tanks W 2.0 × L 3.0 × H 2.5 m (effective depth 2.0), RC
	2 Mixers 800mm × 1 stage × 5.5 kW × 0.4 kW × 50 Hz
	4 liquid level gauge Terminal type liquid level gauge (3 contact)
	1 mixer for saturator Vertical type power-operated mixer 250 mm × 2 stages × 3.7 kW × 380 V × 50 Hz
	1 saturator for milky slaked lime tank 350mm × 950mm
	1 flow meter for service water 100mm, Orifice type flow meter 20 ~ 100 m ³ / hour
	Service water pipe: 150mm ductile cast iron pipe with inner mortal lining, Class 3
6.4 Chlorine feeding equipment (New)	4 feeding equipments (2 for pre-chlorination and 2 for post-chlorination) Self standing cabinet type
	2 vacuum adjustment equipment (1 for pre-chlorination and 1 for post-chlorination) Wall mounted manifold pipe type Feeding quantity ; Max 40 kg / hour feeding pressure ; Max 1.0 Mpa
	4 ejectors (2 for pre-chlorination and 2 for post-chlorination) Working flow rate ; 400 L / min. Working pressure ; 0.6 Mpa Diameter ; 50 mm
	4 flow meters (2 for pre-chlorination and 2 for post-chlorination) built-in cabinet style Flow range ; 0 ~ 40 kg / hour
	4 service water pump Discharge rate ; 0.4 m ³ / min. Total head ; 23 ~ 25m
	Kind of pipe ; 100 mm ductile cast iron pipe with inner mortal lining, Class 3
	Chlorine gas cylinder; 30 cylinders

6.5 Chlorine gas neutralization equipment (New)	<p>1 set</p> <p>Neutralization capacity ; 1,000 kg</p> <p>Exhauster ; FRP-made anti-corrosion turbo fan, Capacity of 60 m³ / min., Static pressure 250 mmAg</p> <p>5.5KW × 380V × 50Hz</p> <p>Neutralization tower ; PVC-made cylindrical vertical type dual filled tower</p> <p>1.05 m × 2 towers × H 1.2m</p> <p>Caustic soda ; Steel rectangular tank with PVC lining</p> <p>4.5m × 2.0m × 1.5m × 1 tank</p> <p>Caustic soda pump ; PVC made pump</p> <p>1.2 m³ / min. × 10mAg × 7.5KW × 380V × 50Hz × 1 set</p> <p>Detector of chlorine gas leak ; 6 sets (incl. transmitter and receiver)</p> <p>Detection range : 0 ~ 3 ppm</p>
7. Water Reservoir	
7.1 Distribution reservoir (New)	<p>5,000 m³, 1 basin, RC</p> <p>W 24.8m × L 66.8m × H 3.85m (effective depth 3.10 m)</p>
7.2 Connecting pipe (New)	<p>1 pipe, between filtered water channel and the new reservoir</p> <p>700mm ductile cast iron pipe with inner mortar lining, Class 3</p>
7.3 Flow meter (New)	<p>1 set</p> <p>Insertion type piezoelectric flow meter, 700mm</p>
7.4 Connecting pipe (New)	<p>1 set, between the reservoir and distribution/transmission pump</p> <p>700mm ductile cast iron pipe with inner mortar lining, Class 3</p>
7.5 Distribution pump (Rehav.)	<p>3 sets</p> <p>Installation in the existing NO.1 pump room</p> <p>35.0 m³ / min. × 42m × 320KW × 3KV × 50Hz</p> <p>Rehabilitation of suction pipe and delivery pipe</p>
7.6 Distribution pump (New)	<p>1 set</p> <p>Installation in the existing NO.2 pump room</p> <p>17.5m³/min × 42m × 180kw × 3kv × 50Hz</p>
7.7 Connecting pipe (Rehav.)	<p>1 pipe</p> <p>One 800mm existing distribution main shall be abandoned.</p> <p>Installation of a new connecting pipe between the distribution main (1.350mm) and ADB financed transmission main</p> <p>1,000mm ductile cast iron pipe with inner mortar lining, Class 3</p>
8. Water quality testing lab.	
8.1 Water quality testing lab. (New)	Establishment in the chemical feeding building
8.2 Water quality analysis equipment (New)	<p>1 set</p> <p>Necessary equipment, glass installment and test reagent (see the next table)</p>
8.3 Sampling pump (New)	<p>2 sets of horizontal type pumps for sampling raw water (incl. standby)</p> <p>2 sets of submerged motor pumps for sampling the settled water of the existing sedimentation basin (incl. standby)</p> <p>2 sets of submerged motor pumps for sampling the settled water of new sedimentation basins (incl. standby)</p> <p>2 sets of submerged motor pumps for sampling the filtered water of existing filters (incl. standby)</p> <p>2 sets of submerged motor pumps for sampling the filtered water of new filters (incl. standby)</p>
9. Electrical and metering instrumentation	
9.1 Activation panel for intake pump (New)	<p>2 sets</p> <p>Installation in the existing intake electric room</p>
9.2 Subsidiary relay panel for the activation panel (New)	<p>1 set</p> <p>Installation in the existing electrical room</p>
9.3 Control line (New)	<p>1 line</p> <p>Installation with new raw water main between the intake and the treatment plant</p>

9.4 Activation panel for distribution pump (New)	1 set Installation of a panel for the pump ($Q = 17.5 \text{ m}^3 / \text{min.}$) in the existing electric room of the treatment plant
9.5 Central control and monitoring panel (Remodeling)	1 set Modification of the mosaic and remodeling of the desk
9.6 Relay panel for central control and monitoring panel (Extension)	1 set Installation in the central control and monitoring room
9.7 Light for chemical building and lighting rod (New)	1 set
9.8 Water level gauge at intake (Rehab.)	1 set Ultra-sonic indicator
9.9 Raw water flow meter (New)	2 sets Float type flow meter and integrating meter for the existing and new water treatment facility
9.10 Head loss meter for filter (New)	8 sets Differential pressure type head loss indicator
9.11 Water level for distribution reservoir (New)	1 set Water level indicator for new distribution reservoir

2) Equipment in the Water Quality Monitoring Laboratory

Equipment	Number
1. Fume Hood (with Blower), Ceramitite	1
2. Center Table (with Sink)	1
3. Center Table with Reagent Shelf (with Glass Door)	2
4. Jar Tester, 6-Shafts	1
5 Digital Thermometer	1
6. Personal pH Meter (with Electrode)	1
7. Digital Temperature , Humidity and Dew Point Meter	1
8. Electrical Conductivity Meter	1
9. Direct Reading Type Turbidimeter	1
10. Drying Oven	1
11. Autoclave	1
12. Rack with Metal Fittings	1
13. Magnetic Mixer	1
14. Water Distillation Apparatus	1
15. Beaker, Glass, etc.	Necessary numbers
16. Testing Reagent	Necessary numbers

Appendix 5- 8 Operation and Maintenance Costs of Electricity and Chemicals

1. Electricity Cost

(1) Electricity consumption of intake pump

$$185 \text{ kw} \times 3 \text{ sets} \times 24 \text{ hours/day} \times 365 \text{ days/year} = \underline{4,861,800 \text{ kWh/year}}$$

(2) Electricity consumption of water treatment facility

Flocculator

$$2 \text{ kW} \times 12 \text{ sets} \times 24 \text{ hours/day} \times 365 \text{ days/year} = 210,240 \text{ kWh/year}$$

$$3.7 \text{ kW} \times 8 \text{ sets} \times 24 \text{ hours/day} \times 365 \text{ days/year} = 259,296 \text{ kWh/year}$$

Backwash pump

Assuming that: a filter is washed every 36 hours (1.5 days) Total numbers of filter washing per day: $20 \text{ filters} \times 24/36 = 13.4 \text{ filters/day}$

Assuming that water backwashing time per filter is 24 minute.

$$45 \text{ kw} \times 13.4 \text{ filters/day} \times 24/60 \times 365 \text{ days/year} = 88,038 \text{ kWh/year}$$

Air blower for backwashing

Assuming that air backwashing time per 1 filter is 5 minutes:

$$45 \text{ kw} \times 13.4 \text{ filters/day} \times 5/60 \times 365 \text{ days/year} = 18,342 \text{ kWh/year}$$

Agitator of dissolving aluminum sulfate

Assuming that the number of solution per day is 3 tanks and the operation time per tank is 1 hour.

$$3.7 \text{ kw} \times 3 \text{ times/day} \times 1 \text{ hour/time} \times 365 \text{ days/year} = 4,052 \text{ kWh/year}$$

Agitator of dissolving slaked lime

24 hours/day operation to avoid settlement of slaked lime

$$5.5 \text{ kw} \times 2 \text{ sets} \times 24 \text{ hours/day} \times 365 \text{ days/year} = 96,360 \text{ kWh/year}$$

$$0.4 \text{ kw} \times 1 \text{ set} \times 24 \text{ hours/day} \times 365 \text{ days/year} = 3,504 \text{ kWh/year}$$

Feed water pump for chlorine

$$7.5 \text{ kw} \times 1 \text{ set} \times 24 \text{ hours/day} \times 365 \text{ days/year} = 65,700 \text{ kWh/year}$$

Pump and blower for chlorine gas neutralization

The electricity consumption for this equipment is not estimated because of emergency use only.

Sampling ball

$$0.75 \text{ kw} \times 5 \text{ sets} \times 24 \text{ hours/day} \times 365 \text{ days/year} = 32,850 \text{ kWh/year}$$

Others (Compressor, air conditioning apparatus, lights, ect)

Assuming that these electricity consumptions are 1 percent of the total consumption estimated above

$$5,640,182 \times 0.01 = \underline{55,818 \text{ kWh/year}}$$

Total : 834,200 kWh/year

(3) Electricity consumption of distribution and transmission pumps

The pump operation plan to distribute 150,000 m³/day is as follows:

Distribution pump (2,100 m ³ /hr、 320kw) 2 sets	4,200 m ³ /hour = 100,800 m ³ /day
Same as above (1,050 m ³ /hr、 180kw) 2 sets	1,050 m ³ /hr = 25,200 m ³ /day
Transmission pump (1,050 m ³ /hr、 180kw) 2 sets	<u>1,050 m³/hr = 25,200 m³/day</u>
Total	6,300 m ³ /hr = 151,200 m ³ /日

320kw × 2sets × 24hours/day × 365days/year	= 5,606,400 kWh/Year
180kw × 2sets × 24hours/day × 365days/year	<u>= 3,153,600 kWh/Year</u>
Total	<u>8,760,000 kWh / 年</u>

(2) Chemicals consumption for water treatment

Aluminum Sulfate

Average optimum feeding rate is 23.5 mg/L based on the 1999 jar tester data.

$$158,400\text{m}^3/\text{day} \times 23.5\text{mg}/\text{L} \times 10^{-3} \times 365\text{days}/\text{year} = \underline{1.359 \text{ ton}/\text{year}}$$

Slaked lime

Average feeding rate is 10 mg/L and half a year is required feeding to adjust pH value

$$158,400\text{m}^3/\text{day} \times 10\text{mg}/\text{L} \times 10^{-3} \times 365\text{days}/\text{year} \times 1/2 \text{ year} = \underline{579 \text{ ton}/\text{year}}$$

Chlorination

Pre-Chlorination (2 mg/L feeding during the period December to May 6 months when algae generation occurs)

$$158,400\text{m}^3/\text{day} \times 2\text{mg}/\text{L} \times 10^{-3} \times 180\text{days}/\text{year} = 57 \text{ ton}/\text{year}$$

Post-Chlorination

$$158,400\text{m}^3/\text{day} \times 1.5\text{mg}/\text{L} \times 10^{-3} \times 365\text{day}/\text{year} = \underline{87 \text{ ton}/\text{year}}$$

Total quantity of Chlorine gas: 144ton/年

Table 1 Operation and maintenance cost estimation (Electricity and chemicals)

		Annual Consumption	Annual Cost Estimate
Electricity	Water treatment	834,000 kWh/year	400 million Riel
	Water intake	4,862,000 kWh/year	2,334 million Riel
	Water transmission and distribution	8,760,000 kWh/year	4,205 million Riel
	Subtotal	14,456,000 kWh/year	6,46 million Riel
Chemicals	Aluminum Sulfate	1,359 tons/year	326,000 US \$
	Slaked lime	289 tons/yea	35,000 US \$
	Chlorine gas	144 tons/year	158,000 US \$
	Subtotal	–	519,000 US \$ = 1,998 million Riel
Total	–	8,937 million Riel	

(Estimation conditions)

1 US \$ = 3,850 riel

Power tariff : 480 Riel/kWh = 0.09 US \$/kWh (for Phum Prek WTP)

Aluminum Sulfate : 240 US \$/ton (including transportation cost)

Slaked lime : 120 US \$/ton (including transportation cost)

Chlorine gas : 1,100 US \$/ton (including transportation cost)

Appendix 5-9 Permission of Installation of Raw Water Mains

KINGDOM OF CAMBODIA
NATION RELIGION KING

Phnom Penh, Dated: 22nd June, 2000

PHNOM PENH WATER SUPPLY AUTHORITY
(PPWSA)

No: _____

To:

GOVERNOR OF PHNOM PENH MUNICIPALITY

Objective: Request for Installation of Transmission Pipe sized 1,200mm from Raw Water Pumping Station to Phum Prek Water Treatment Plant.

- References:
- Minutes of Discussion on the Basic Design Study on the Project for Expansion of Phum Prek Water Treatment Plant in the Kingdom of Cambodia between Japan International Cooperation Agency and Phnom Penh Water Supply Authority dated on 23 June 2000.
 - Letter of Japan International Cooperation Agency to Kingdom of Cambodia No. JC 11-177 on Basic Design Study on the Project for Expansion of Phum Prek Water Treatment Plant in the Kingdom of Cambodia.

Refer to the mentioning in the above objective and references, Phnom Penh Water Supply Authority has the honor to inform the Governor that Government of Japan has entrusted to Japan International Cooperation Agency for Basic Design Study on the Project for Expansion of Phum Prek Water Treatment Plant which has been requested of Grant from Government of Japan in 1997. Japan International Cooperation Agency has revealed that for this basic design, it is necessary that the Transmission Pipe sized 1,200mm from Raw Water Pumping Station in front of Council for Development of Cambodia to Phum Prek Water Treatment Plant should be installed as mentioned in attached Drawing.

To smoothly implement the Grant, Phnom Penh Water Supply Authority request to Governor of Phnom Penh Municipality's kind cooperation to officially permit as above request.

Yours faithfully
General Director of Phnom Penh Water Supply Authority
EK SONN CHAN

Response from Governor of Phnom Penh Municipality

Agreed to install pipe crossing the Garden except two places can be escaped.

Signature of Governor
23-June-2000

ព្រះរាជាណាចក្រកម្ពុជា
ជាតិ សាសនា ព្រះមហាក្សត្រ



រដ្ឋាករទឹកស្វយ័តក្រុងភ្នំពេញ

1.2.55.5

ភ្នំពេញ, ថ្ងៃទី ២២ ខែ មិថុនា ឆ្នាំ ២០០០

លេខ: ២១២ ល.ស
ថ្ងៃទី ២២ ខែ ០៦ ឆ្នាំ ២០០០
367
28.6.00
367

សូមពោរព័ទ្ធនៃ

ឯកទុត្តមប្រតិភូរាជរដ្ឋាភិបាលទទួលបន្ទុកអភិបាលរាជធានីភ្នំពេញ

កម្មវត្ថុ: សំណើសុំអនុញ្ញាតដឹកដាក់បំពង់ទឹក ទំហំ ១.២០០មម ប្រវែង ១.៥០០ម ចេញពីស្ថានីយ៍ បូមទឹកល្អក់ មកទល់ និងអាងទទួលទឹករោងចក្រភូមិព្រែក ។

យោង: - កិច្ចពិភាក្សា នៃការសិក្សាគម្រោងពង្រីករោងចក្រផលិតទឹកស្អាតភូមិព្រែក រវាងភាគីភ្នាក់ងារសហប្រតិបត្តិការអន្តរជាតិ នៃប្រទេសជប៉ុន និងរដ្ឋាករទឹកស្វយ័តក្រុងភ្នំពេញ ចុះថ្ងៃទី ២៣ ខែកក្កដា ឆ្នាំ ២០០០ ។

Handwritten notes:
សេចក្តីជូនដំណឹង
ស្តីពីការសិក្សាគម្រោងពង្រីក
រោងចក្រផលិតទឹកស្អាតភូមិព្រែក
នៃប្រទេសជប៉ុន

- សារលិខិតរបស់ភ្នាក់ងារសហប្រតិបត្តិការអន្តរជាតិ នៃប្រទេសជប៉ុន ប្រចាំព្រះរាជាណាចក្រកម្ពុជា លេខ JC 11-177 ចុះថ្ងៃទី ១២ ខែ កក្កដា ឆ្នាំ ២០០០ ស្តីពីការមកដល់របស់គណៈប្រតិភូជប៉ុន លើការសិក្សាគម្រោងពង្រីកសមត្ថភាពរោងចក្រផលិតទឹកស្អាតភូមិព្រែក ។

សេចក្តីដូចមានចែងក្នុងកម្មវត្ថុខាងលើ រដ្ឋាករទឹកស្វយ័តក្រុងភ្នំពេញ សូមជំរាបជូនឯកទុត្តមប្រតិភូ មេត្តាជ្រាបថា ៖ រដ្ឋាភិបាលជប៉ុន បានបញ្ជូនប្រតិភូរបស់ភ្នាក់ងារសហប្រតិបត្តិការអន្តរជាតិ នៃប្រទេសជប៉ុន ដើម្បីធ្វើការសិក្សាគម្រោងពង្រីករោងចក្រផលិតទឹកស្អាត (Basic Design) ទៅលើគម្រោងពង្រីកសមត្ថភាពផលិតទឹកស្អាតរោងចក្រភូមិព្រែក ដែលភាគីកម្ពុជាបានស្នើសុំជំនួយឥតសំណងពីរាជរដ្ឋាភិបាលជប៉ុន នាឆ្នាំ ១៩៩៧ ។ ក្នុងការសិក្សានេះ ភាគីជប៉ុនបានដឹងថា ចាំបាច់ត្រូវដាក់បំពង់មួយទំហំ ១.២០០មម ប្រវែង ១.៥០០ម ពីស្ថានីយ៍បូមទឹកល្អក់នៅមុខស្ថានីយ៍ការក្រុមប្រឹក្សាអភិវឌ្ឍន៍កម្ពុជាមករោងចក្រភូមិព្រែកដូចដែលមានបង្កើតស្រាប់ត្រូវរៀបចំជាមួយនេះ ។

ដើម្បីអនុវត្តបាននូវគម្រោងជំនួយឥតសំណងនេះ យើងខ្ញុំសូមឯកទុត្តមប្រតិភូ រាជរដ្ឋាភិបាលទទួលបន្ទុកអភិបាលរាជធានីភ្នំពេញ មេត្តាអនុញ្ញាត ដោយក្តីអនុគ្រោះ ។

សូមឯកទុត្តមប្រតិភូ មេត្តាទទួលនូវការគោរពដ៏ខ្ពង់ខ្ពស់អំពីយើងខ្ញុំ ។

Signature and stamp:
អគ្គនាយក
ហក សុខចាន់

ទីស្នាក់ការ: ខាងលើស្ថានីយ៍វាយស្វាយយានកម្ពុជា ខ្នងស្នាក់: ០២៣-៧២៤ ០៤៦ ខ្នងស្នាក់-ខ្នងស្នាក់: ៧៥៥ - ២៣-៧២៥ ៧៦៦

Appendix 5- 10 Permission of Installation of Raw Water Mains (Telecommunication building site)

24/08/00

07:52

PHNOM PENH WATER SUPPLY → 81335802793

NO.001

001



KINGDOM OF CAMBODIA
NATION-RELIGION-KING

PHNOM PENH WATER SUPPLY AUTHORITY
PROJECT MANAGEMENT UNIT

ADDRESS: North of Cambodia Railway Station
PHNOM PENH
TEL: 855-23 427 657. Fax: 855-23 427 657

Date: 23 August 2000

Message No.: 093 - PMU-GR/00

Total Page: 3 including this cover sheet


To: Tokyo Engineering Consultants Co. Ltd.
Fuji Building, 3-7-4 Kasugasaki
Chiyoda-Ku, Tokyo, Japan

Attention: Mr. Hirotaka SATO
M.E (Environment & Sanitary)
M.W.R.A (Water Resources Administration)
Overseas Department
Fax: 813-3580-2793

Subject: Request for the installation of 1,200mm water pipe crossing Bayon
Satellite Station

Dear Sir,

Please find the attached letter from Ministry of Posts and Telecommunications on the approval of pipe installation crossing Bayon Satellite Station together with its translation into English.

Best regards, 

Long Naro
Director of Technical and Project DPT
PPWSA



ព្រះរាជាណាចក្រកម្ពុជា
Kingdom of Cambodia
ជាតិ សាសនា ព្រះមហាក្សត្រ
Nation - Religion - King

ទិស្តីការ

ក្រសួងប្រៃសណីយ៍ និង ទូរគមនាគមន៍
Ministry of Posts and Telecommunications

លេខ : 1391 បទ បណ

រដ្ឋាករទឹកស្អាតក្រុងភ្នំពេញ
លេខ: 115
ទីស្នាក់ការ: 116.08.00.01.11.30
ទីស្នាក់ការ: 09

លេខ: 085 GR រាជធានីភ្នំពេញ ថ្ងៃទី 15 ខែ 08 ឆ្នាំ 2000
ពេលវេលា: 17:00 ព្រឹក 7:30
ទីស្នាក់ការ: STPD

រដ្ឋមន្ត្រី ក្រសួងប្រៃសណីយ៍និងទូរគមនាគមន៍
ជំរះ
លោកអគ្គនាយករដ្ឋាករទឹកស្អាតក្រុងភ្នំពេញ

រដ្ឋាករទឹកស្អាតក្រុងភ្នំពេញ
លេខ: 434
ថ្ងៃទី 15 ខែ 08 ឆ្នាំ 2000
លេខ: 16:00

កម្មវត្ថុ: អំពីការណែនាំស្តីអំពីការដាក់បំពង់ទឹកទំហំ 1.200 មម ក្នុងកាត់ស្ថានីយ៍ផ្កាយរណបយ៉ែន ។
យោង: លិខិតលេខ 223 ល.ស ចុះថ្ងៃទី 10.07.2000 របស់រដ្ឋាករទឹកក្រុងភ្នំពេញ.

សេចក្តីដូចមានចែងក្នុងកម្មវត្ថុនិងយោងខាងលើ ខ្ញុំមានកិត្តិយសសូមជំរះលោកអគ្គនាយកជ្រាបថា :
ផ្អែកតាមលទ្ធផលនៃការពិភាក្សារវាងមន្ត្រីនាយកដ្ឋានទូរគមនាគមន៍អន្តរជាតិនៃក្រសួងប្រៃសណីយ៍និងទូរគមនាគមន៍
និងតំណាងរដ្ឋាករទឹកស្អាតក្រុងភ្នំពេញរួមជាមួយជំនាញបច្ចេកទេសជប៉ុន ក្រសួងប្រៃសណីយ៍និងទូរគមនាគមន៍បាន
ឯកភាពអនុញ្ញាតដោយការណែនាំក្នុងការស្ថាបនាដាក់បំពង់ទឹកតាមបណ្តោយផ្លូវក្នុងស្ថានីយ៍ផ្កាយរណបយ៉ែនខាង
ជើងអាគាររដ្ឋបាល ដោយតម្រូវឱ្យមានវិធានការណែនាំដូចខាងក្រោមនៅមុនពេលសំរេចបើកការដ្ឋាន :

- 1- រដ្ឋាករទឹកស្អាតក្រុងភ្នំពេញសិក្សាលទ្ធភាពនៃគំរោងនិងបង្ហាញលទ្ធផលថាមិនចំពាលដល់ដំណើរការនៃ
ស្ថានីយ៍ផ្កាយរណប ។
- 2- ត្រូវធ្វើកិច្ចសន្យាជាធារាភ័យរវាងស្ថិតិភាពនិងជួសជុលរាល់ការខូចខាតក្នុងស្ថានីយ៍ដែលបង្កឡើងដោយ
ការដ្ឋានជីកដាក់បំពង់ទឹកនេះ ។

អាស្រ័យហេតុដូចបានជំរះជូនខាងលើ សូមលោកអគ្គនាយកជ្រាបនិងចាត់ចែងអនុវត្តន៍តាមអនុលោមតាម
ជោគជ័យ ។

សូម លោកអគ្គនាយក ទទួលនូវសេចក្តីរាប់អានដ៏ជ្រាលជ្រៅបំផុត ។ វ

ចម្លងជូន:

- សាលាក្រុងភ្នំពេញ " ដើម្បីជូនជ្រាប "
- នាយកដ្ឋានផែនការហិរញ្ញវត្ថុ " ដើម្បីមុខការ "
- នាយកដ្ឋានទូរគមនាគមន៍អន្តរជាតិ " ដើម្បីមុខការ "
- ឯកសារ កាលប្បវត្តិ.

ស្រុយស
[Signature and Stamp]

កាន់ត្រូវដឹងលេខ ១៣ ទី ១០២ សង្កាត់ភ្នំពេញ ខណ្ឌដូនពេញ
ទូរស័ព្ទ : 855-23.426993 / 426510
ទូរសារ : 855-23.426992 / 426011

Corner street 13 and 102 Wat Phnom
Section - Daun Penh District P.Penh
Tel : 855-23.426993 / 426510
Fax : 855-23.426992 / 426011

**KINGDOM OF CAMBODIA
NATION RELIGION KING**

Phnom Penh, Dated: 15 August, 2000

Cabinet

Ministry of Posts and Telecommunications

No.: _____

Minister of Posts and Telecommunications

officially informs

General Director of Phnom Penh Water Supply Authority

Objective: The request for the installation of 1,200mm water pipe crossing Bayon Satellite Station

Reference: Letter No. 223 _____ of Phnom Penh Water Supply Authority dated on 10 July 2000

In accordance with the objective and reference mentioned above, we have the honor to inform General Director that based on the results of the discussion between International Telecommunication Department of Ministry of Posts and Telecommunications and representative of Phnom Penh Water Supply Authority including Japanese expert, Minister of Posts and Telecommunications has officially permitted for the installation of water pipe along the road at the north of Administration Building in Bayon Satellite Station. Some below measures shall be taken prior opening the site:

1. Phnom Penh Water Supply Authority shall study on the feasibility of the project indicating that there is no any bad affect to the operation of Satellite Station.
2. Phnom Penh Water Supply Authority shall ensure the safety and repair all the damage parts in the station resulting from the installation of water pipe.

This above description is informative to General Director and we wish you implementing it successfully.

Best regards,

Copied to:

- Phnom Penh Municipality
- Financial Planning Department "Official"
- International Telecommunication Department "Official"
- Document, file

MINISTER


SO KHUN

Appendix 5- 11 Registration of Landfill Land of Phum Prek Water Treatment Plant

PHNOM PENH LAND DEPARTMENT
មន្ទីរព្រំប្រទល់ស្រុកភ្នំពេញ
ក្រសួងសេដ្ឋកិច្ច និងហិរញ្ញវត្ថុ
 LAND OFFICE, DAUN PENH

KINGDOM OF CAMBODIA
ព្រះរាជាណាចក្រកម្ពុជា
ជាតិ សាសនា ព្រះមហាក្សត្រ
 NATION RELIGION KING

DRAWING OR LOCATION OF HOUSE No. 45, ROAD No. 106
 រូបប្រយោជន៍ទីតាំងផ្ទះលេខ...45... ផ្លូវលេខ...106...
SANGKAT SRAH CHAK, KHAN DAUN PENH
សង្កាត់...ខណ្ឌ... ភ្នំពេញ
 ផ្ទាល់លេខ...1... សង្កាត់លេខ...36... 1
 LOT No. ...1.2000. SHEET No. REQUESTED BY PPSA
 ទម្រង់លេខ...1.2000. ទំព័រលេខ... REQUESTED BY PPSA
 SCALE



ប្រទេសកម្ពុជា
PHNOM PENH LAND DEPARTMENT
No.

ប្រទេសកម្ពុជា
REAL ESTATE TITLE DEEDS (ORIGIN)

ព្រះរាជាណាចក្រកម្ពុជា
KINGDOM OF CAMBODIA
ជាតិ សាសនា ព្រះមហាក្សត្រ
NATION RELIGION KING
នៃព្រះរាជាណាចក្រកម្ពុជា
ID No. ...
RELAND DEPARTMENT

LIST No. SHEET No. LOT No. HOUSE No. ROAD No. SANKATS RAS CHAIK DAUN PENH ID No. ...

LOT IDENTIFICATION				HOUSE IDENTIFICATION				VITAL RECORD OF OWNER				EXCHANGE	
BORDER	SOIL TYPE	L	W	BORDER	TYPE OF HOUSE	FLOOR	AREA (A)	AREA (B)	HISTORY	NATIONALITY	OTHER	OTHER	OTHER
		①			12.71.1A	E ₀	134.48	134.48	NAME AND FAMILY NAME (HUSBAN/WIFE) BIRTH DATE AND PLACE				
		②			B	E ₀	308.04						
		③			C	E ₀	484.57						
		④			D	E ₀	420.40						
					E	E ₀	403.00		① NORTH LOT OF VILLAGE No 6 LOT No. 31				
						E ₁	413.00		② EST LOT No. 31, LOT No. 33				
						E ₂	407.00						
					F	E ₀	289.48		③ SOUTH LOT No. 353, ROAD No. 106				
					G	E ₀	72.00						
						E ₁	72.00		④ WEST BOEUNG KAK (LAKE)				
					H	E ₀	596.40						
						E ₁	596.40						
					I	E ₀	804.65						
					BUILDING	E ₁	804.65						
					J	E ₀	331.28						
						E ₁	5590.40						
					RESERVOIR	L	736.88						
						M	78.00						
						N	78.00						
						O	89.28						
						P	2560.36						
						Q	2739.00						

SEEN AND APPROVED
MEAS FENG HANN
24-04-2000
DAUN PENH GOVERNOR
SUON RINDY

MAO SOKHOM
LAND OFFICE, DAUN PENH

RIGHT THUMB PRINT OF OWNER
LACH PATANA
PPNSA'S REP.

