

Chapter 7

***INTERCEPTOR SEWER
DEVELOPMENT***

CHAPTER 7 INTERCEPTOR SEWER DEVELOPMENT

7.1 Introduction

Collection of wastewater in Tau Hu, Ben Nghe - Doi, Te (THBNDT) zone is proposed to utilize the existing combined sewer system as much as possible for reasons of economy. Then the interceptor sewer is required to collect the dry weather flow from the existing combined sewer system. This section describes the process for the selection of an optimum interceptor system for THBNDT zone from the technical and economical points of view.

Furthermore, the THBNDT zone borders the Nhieu Loc - Thi Nghe (NLTN) basin to the north. An environmental improvement project for the NLTN basin is currently being conducted by the World Bank as described in Section 2.4, Chapter 2, Vol. I, Main Report.

A wastewater treatment plant for the NLTN project was proposed at a site bordering on the north of the THBNDT WWTP site in JICA M/P study. However, the proposed site was about 9.5 km from the NLTN project area, thus requiring about 9.5 km of conveyance sewer and two (2) intermediate pumping station as proposed in the study. In order to reduce the construction cost of the conveyance sewer system, the NLTN project made a further effort and has found a possible site of its wastewater treatment plant closer to the collection area in District 2, which is about 7 km from its project area.

Consequently, the sewerage system for the THBNDT zone has not been integrated with the NLTN project and each project has been designed independently for the reasons of economy as described above.

7.2 Planning Concept and Design Criteria

7.2.1 Target Year to be Designed

Target year of the definitive plan is defined as the year of 2010. While, target year of the interceptor sewer design is proposed in the year 2020 same as the target year of Master Plan, because it is rather difficult to increase the sewer capacity by stepwise than other facilities as treatment plant and pumping stations. Therefore, interceptor sewers are proposed to design with the design wastewater discharge in the year 2020.

7.2.2 Design Criteria

The proposed design criteria in F/S are reviewed based on Vietnamese and Japanese Standard. As a result, the following is proposed for the criteria.

| | |
|----------------|--------------------|
| Pipe material: | D<300mm - PVC pipe |
|----------------|--------------------|

| | |
|----------------------------|--|
| | D>300mm - centrifugal concrete pipe |
| Unit Wastewater Discharge: | 335 l/c/d (consisting of domestic, commercial, institutional and home industrial wastewater) |
| Design Flow: | Hourly maximum flow (1.4 times of daily average dry weather flow in year 2020) plus groundwater infiltration (10% of daily average dry weather flow) |
| Flow system: | Gravitation |
| Flow equation: | Manning equation |
| | n = 0.010 for PVC pipe |
| | n = 0.013 for concrete pipe |
| Minimum velocity: | 0.7 m/s |
| Standard slope: | see Table 7.1 |
| Minimum earth covering: | 1.2 m |
| Manhole: | every 30m (pipe diameter<1200mm) every 50m (pipe diameter>1200mm) |

The criteria may be adjusted upon a condition of soil and land if necessary.

7.3 Division of Sewerage Area

The sewerage area of 2,791.6 ha is separated by Tau Hu – Ben Nghe and Doi Te canals into three (3) areas; 1) left bank area of Tau Hu - Ben Nghe canal, 2) isolated area by Tau Hu - Ben Nghe and Doi Te canal, and 3) right bank area of Doi – Te canal. And these three (3) separated sewerage areas are further divided into 24 sub-zones as shown in Fig. 7.1 and listed in table below. The division is made based on existing combined sewer networks, canals, rivers, main roads and topography.

| Sub-zone | Area (ha) | Covered District |
|---|-----------|------------------------|
| (1) Tau Hu – Ben Nghe Canal Left Bank - East Area | | |
| 1. Sub-zone 1 | 132.4 | 1 |
| 2. Sub-zone 2 | 141.2 | 1, 3 |
| 3. Sub-zone 3 | 22.0 | 1 |
| 4. Sub-zone 4 | 72.9 | 1 |
| 5. Sub-zone 5 | 71.8 | 1, 3 |
| 6. Sub-zone 6 | 47.0 | 1 |
| 7. Sub-zone 7 | 232.1 | 1, 3, 5, 10 |
| 8. Sub-zone 8 | 44.9 | 1, 5 |
| 9. Sub-zone 9 | 40.4 | 5, 10 |
| 10. Sub-zone 10 | 23.7 | 5 |
| Sub Total of East Area | 828.4 | |
| (2) Tau Hu – Ben Nghe Canal Left Bank - West Area | | |
| 11. Sub-zone 11 | 78.5 | 5, 10 |
| 12. Sub-zone 12 | 15.2 | 5 |
| 13. Sub-zone 13 | 277.1 | 5, 10, 11 |
| 14. Sub-zone 14 | 214.5 | 5, 6, 10, 11, Tan Binh |
| 15. Sub-zone 15 | 168.6 | 5, 6, 11, Tan Binh |
| 16. Sub-zone 16 | 111.1 | 6 |

| | | |
|---|---------|---|
| Sub Total of West Area | 865.0 | |
| Total of Left Bank | 1,693.4 | |
| (3) Islands between Tau Hu – Ben Nghe and Doi – Te Canals | | |
| 17. Khanh Hoi | 350.2 | 4 |
| 18. Ong Kieu | 3.9 | 4 |
| 19. Hung Phu | 76.7 | 8 |
| 20. Tung Thien Vuong | 82.0 | 8 |
| 21. Binh Dong | 48.6 | 8 |
| Sub Total of Island Area | 561.4 | |
| (4) Doi – Te Canal Right Bank | | |
| 22. Rach Ong | 133.0 | 8 |
| 23. Pham The Hien | 195.8 | 8 |
| 24. Binh Dang | 208.0 | 8 |
| Sub Total of Right Bank | 536.8 | |
| Grand Total | 2,791.6 | |

Note : The following areas are excluded from the sewerage service area. The excluded area is estimated at 273.4 ha.

- (1) Zoo = 20.6 ha in sub-zone 1
- (2) Thong Nhat Palace = 12.6 ha in sub-zone 2
- (3) Tao Dan Park = 19.7 ha in sub-zone 2
- (4) Phu Tho Stadium = 24.4 ha in sub-zone 12 and 7.9 ha in sub-zone 13
- (5) Saigon River = 59.5 ha, Tau Hu – Ben Nghe Canal = 46.5 ha, Doi – Te Canal = 66.8 ha, Other Rivers/Canals = 15.4 ha

The population by sub-zones in 1997, 2010 and 2020 are estimated as follows:

| Sub-zone | 1997 | | 2010 | | 2020 | |
|---|--------------------|--------------------------------|--------------------|--------------------------------|--------------------|--------------------------------|
| | Covered Population | Population Density (person/ha) | Covered Population | Population Density (person/ha) | Covered Population | Population Density (person/ha) |
| (1) Tan Hu – Ben Nghe Canal Left Bank - East Area | | | | | | |
| 1. Sub-zone 1 | 19,933 | 151 | 19,871 | 150 | 19,823 | 150 |
| 2. Sub-zone 2 | 44,971 | 318 | 44,688 | 316 | 44,470 | 315 |
| 3. Sub-zone 3 | 12,543 | 570 | 12,428 | 565 | 12,340 | 561 |
| 4. Sub-zone 4 | 51,513 | 707 | 48,331 | 663 | 46,034 | 631 |
| 5. Sub-zone 5 | 32,333 | 450 | 32,041 | 446 | 31,820 | 443 |
| 6. Sub-zone 6 | 38,341 | 816 | 36,044 | 767 | 34,374 | 731 |
| 7. Sub-zone 7 | 163,247 | 703 | 159,187 | 686 | 156,189 | 673 |
| 8. Sub-zone 8 | 31,366 | 699 | 28,425 | 633 | 26,355 | 587 |
| 9. Sub-zone 9 | 25,949 | 642 | 25,038 | 620 | 24,363 | 603 |
| 10. Sub-zone 10 | 21,874 | 923 | 19,777 | 834 | 18,303 | 772 |
| Sub total of East Area | 442,070 | 534 | 425,830 | 514 | 414,071 | 500 |
| (2) Tan Hu – Ben Nghe Canal Left Bank - West Area | | | | | | |
| 11. Sub-zone 11 | 62,892 | 801 | 61,771 | 787 | 60,936 | 776 |
| 12. Sub-zone 12 | 10,679 | 703 | 9,310 | 613 | 8,377 | 551 |
| 13. Sub-zone 13 | 153,275 | 553 | 147,211 | 531 | 142,958 | 516 |
| 14. Sub-zone 14 | 132,401 | 617 | 129,482 | 604 | 126,901 | 592 |
| 15. Sub-zone 14 | 88,578 | 525 | 89,250 | 529 | 89,308 | 530 |
| 16. Sub-zone 14 | 69,864 | 629 | 68,795 | 619 | 68,083 | 613 |
| Sub total of West Area | 517,689 | 598 | 505,819 | 585 | 496,563 | 574 |
| Sub total | 959,759 | 567 | 931,649 | 550 | 910,634 | 538 |

| | | | | | | |
|---|-----------|-----|-----------|-----|-----------|-----|
| (3) Islands between Tan Hu – Ben Nghe and Doi – Te Canals | | | | | | |
| 17.Khanh Hoi | 219,217 | 626 | 213,228 | 609 | 209,134 | 597 |
| 18.Ong Kieu | 1,434 | 372 | 1,077 | 279 | 864 | 224 |
| 19.Hung Phu | 67,220 | 876 | 59,739 | 779 | 54,806 | 714 |
| 20.Tung Thien Vuong | 51,588 | 629 | 44,295 | 540 | 40,847 | 498 |
| 21.Binh Dong | 21,369 | 440 | 19,952 | 411 | 18,926 | 390 |
| Sub total of Island | 360,828 | 643 | 338,291 | 603 | 324,577 | 578 |
| (4) Doi – Te Canal Right Bank | | | | | | |
| 22.Rach Ong | 68,615 | 523 | 67,480 | 515 | 66,778 | 509 |
| 23.Pham The Hien | 40,361 | 219 | 42,796 | 232 | 44,768 | 243 |
| 24.Binh Dang | 39,140 | 202 | 41,562 | 215 | 43,525 | 225 |
| Sub total of Right | 148,116 | 288 | 151,838 | 295 | 155,071 | 302 |
| Grand Total | 1,468,703 | 526 | 1,421,778 | 509 | 1,390,282 | 498 |

7.4 Design Wastewater Discharge

In the Project Area, the considerable portion of the toilet waste is treated by the individual septic tank. However, the sufficient treatment efficiency of the septic tank is not expected because of their insufficient maintenance. Hence, the treatment efficiency of the septic tank is ignored to determine the domestic wastewater quality and quantity. The wastewater discharge is defined as wastewater consisting both toilet waste and gray water.

Wastewater discharge for interceptor sewer design in each sub-zone is estimated as below.

| Sub-zone | Design Wastewater Discharge (m ³ /day) (2020) | | |
|---|--|-------------|---------|
| | Wastewater | Groundwater | Total |
| (1) Tau Hu – Ben Nghe Canal Left Bank – East Area | | | |
| 1. Sub-zone 1 | 9,297 | 664 | 9,961 |
| 2. Sub-zone 2 | 20,856 | 1,490 | 22,346 |
| 3. Sub-zone 3 | 5,788 | 413 | 6,201 |
| 4. Sub-zone 4 | 21,589 | 1,542 | 23,131 |
| 5. Sub-zone 5 | 14,924 | 1,066 | 15,990 |
| 6. Sub-zone 6 | 16,121 | 1,152 | 17,273 |
| 7. Sub-zone 7 | 73,252 | 5,232 | 78,484 |
| 8. Sub-zone 8 | 12,361 | 883 | 13,244 |
| 9. Sub-zone 9 | 11,427 | 816 | 12,243 |
| 10. Sub-zone 10 | 8,585 | 613 | 9,198 |
| Sub total of East | 194,200 | 13,871 | 208,071 |
| (2) Tau Hu – Ben Nghe Canal Left Bank – West Area | | | |
| 11. Sub-zone 11 | 28,580 | 2,041 | 30,621 |
| 12. Sub-zone 12 | 3,928 | 281 | 4,209 |
| 13. Sub-zone 13 | 67,047 | 4,789 | 71,836 |
| 14. Sub-zone 14 | 59,517 | 4,251 | 63,768 |
| 15. Sub-zone 15 | 41,885 | 2,992 | 44,877 |
| 16. Sub-zone 16 | 31,931 | 2,281 | 34,212 |
| Sub total of East | 232,888 | 16,635 | 249,523 |

| | | | |
|---|---------|--------|---------|
| Sub Total of Left | 427,088 | 30,506 | 457,594 |
| (3) Islands between Tau Hu – Ben Nghe and Doi – Te Canals | | | |
| 17. Khanh Hoi | 98,084 | 7,006 | 105,090 |
| 18. Ong Kieu | 405 | 29 | 434 |
| 19. Hung Phu | 25,704 | 1,836 | 27,540 |
| 20. Tung Thien Vuong | 19,158 | 1,368 | 20,526 |
| 21. Binh Dong | 8,876 | 634 | 9,510 |
| Sub Total of Island | 152,227 | 10,873 | 163,100 |

| | | | |
|-------------------------------|---------|--------|---------|
| (4) Doi – Te Canal Right Bank | | | |
| 22. Rach Ong | 31,319 | 2,237 | 33,556 |
| 23. Pham The Hien | 20,996 | 1,500 | 22,496 |
| 24. Binh Dang | 20,413 | 1,458 | 21,871 |
| Sub Total of Right | 72,728 | 5,195 | 77,923 |
| Total | 652,043 | 46,574 | 698,617 |

7.5 Outline of Each Sewerage Sub-Zone

As stated above, THBNDT zone is separated into three (3) sewerage areas. The existing land use condition of three (3) sewerage areas are as follows.

(1) Left Bank Area of Tau Hu – Ben Nghe Canal

The area has been developed as the central area of Ho Chi Minh City since French colonial era. Combined sewer system was also installed along the roads. In the East area covering District 1, 3 and 5 is fully developed with an adequate road networks, some potential roads can be installed interceptor sewer are along and parallel to the canals. While in West area consisting of District 6, 10 and 11 is very congested area and China Town called “Cho Lon” is located along Tau Hu canal. In this West area, only Tran Van Kieu road along Tau Hu canal is recognized as the potential route of the interceptor sewer. From these different land use conditions, this left bank area of Tau Hu - Ben Nghe canal is further divided into two (2) sewerage zones as East zone and West Zone.

(2) Isolated Area by Tau Hu – Ben Nghe and Doi – Te Canals

In this area, roads are existed along both canals of Tau Hu – Ben Nghe and Doi – Te. There are no alternative routes for installation of the interceptor sewer except along the canals. This area is also further divided into four (4) small sewerage zone by canal as Khan Hoi, Hung Phu, Tung Thien Vuong and Binh Dong.

(3) Right Bank Area of Doi – Te Canal

This area has not been fully developed yet. Road networks are not sufficient to develop the sewer system, however, this area will be developed in near future. The sewerage system needs to be also developed harmonically with the land development. The Vietnamese standards stipulate that the sewerage development for newly developed area

must be covered by separate sewer system. Hence the separate sewer system is proposed in this right bank area of Doi – Te canal.

7.6 Construction Method

Construction method of pipe installation is reviewed. According to geological condition and cost consideration, the following method is most appropriate:

| Trench depth (m) | method |
|------------------|-----------------------------|
| 0 - 4 | open cut without sheet pile |
| 4 - 10 | open cut with sheet pipe |
| 10 < | pipe jacking |

In general, sheet pile can be applied up to a trench depth of 10m. For a deeper than 10m-trench, pipe jacking or shield tunneling method is considered. Shield tunneling method is more expensive than pipe jacking method in general. In addition, pit for pipe jacking method should be installed roughly every 300 m for this study area. The pit is used for the connection between the secondary and primary interceptor. Therefore, pipe jacking method is proposed. After geological survey is done, more detail review will be carried out.

7.7 Proposed Interceptor Sewers and Construction Cost

Sewerage development in seven sub zone is described in this section.

(1) East Area of Left Bank of Tau Hu - Ben Nghe Canal

Main and Secondary Interceptor is shown in Fig. 7.2.

Route : Main Interceptor ⇒ along Ton Duc Thang – Ham Nghi – Tran Hung Dao streets and reaches the intermediate wastewater pumping station

Route : Secondary Interceptor ⇒ under the streets perpendicular to Ben Chuong Duong street

Diversion chamber, mentioned in the next section, is installed at existing drainage pipe before Ben Nghe Canal and Saigon River. All wastewater is collected by the chamber. Then wastewater is carried through Secondary Interceptor to Main Interceptor.

The following is summarized main characteristic of the interceptors.

| | | |
|----------------------|-------------|-----------------------|
| Length | : Main | 6,538 m |
| | : Secondary | 5,639 m |
| Interceptor Diameter | : Main | φ 300 mm ~ φ 2,200 mm |

| | | |
|---------------------|-----------|--|
| Trench Depth | Secondary | ϕ 225 mm ~ ϕ 800 mm |
| | Main | 4.4 ~ 9.7 m |
| | Secondary | 2.0 ~ 4.8 m |
| Construction Method | Main | Open Cut Method 2,671 m Pipe Jacking Method 3,867 m |
| | Secondary | Open Cut Method 5,637 m |
| | Total | 156 billion VND |
| Construction Cost | Main | 136 billion VND |
| | Secondary | 20 billion VND |
| | Total | 156 billion VND |

(2) West Area of Left Bank of Tau Hu - Ben Nghe Canal

The interceptor for West Area of Left Bank of Tau Hu - Ben Nghe Canal is proposed under the operation/maintenance road for the Tau Hu - Ben Nghe Canal, and connects to the main interceptor sewer coming from the East Area before crossing Tau Hu Canal (Fig. 7.1). The following is summarized main characteristic of the interceptors.

Main Features

| | | |
|----------------------|---|---------------------------------|
| Total Length | : | 3,885 m |
| Interceptor Diameter | : | ϕ 500 mm - ϕ 2,000 mm |
| Trench Depth | : | 5.6 - 9.6 m |
| Construction Method | : | Open Cut Method : 1,580 m |
| | : | Pipe Jacking Method : 2,305 m |
| Construction Cost | : | 131 billion VND |

(3) Khanh Hoi Sub-Zone

Two (2) lines of interceptor sewer are proposed under Ben Van Don and Ton That Thuyet roads running along the Ben Nghe and Te canals, respectively. The interceptor sewer along the Ben Van Don road joins the other one running along Tong That Thuyet road and the merged interceptor sewer finally joins the main sewer installed in Rach Ong sub-zone after crossing Te canal.

Main Features

| | | |
|----------------------|---|--|
| Total Length | : | 6,513 m (including canal crossing) |
| Interceptor Diameter | : | ϕ 300 mm - ϕ 1,200 mm |
| Trench Depth | : | 2.3 - 7.9 m |
| Construction Method | : | Open Cut Method |
| Canal Crossing | : | Canal Name : Te Canal |
| | : | Length : 179 m |
| | : | Construction Method : Pipe Jacking Method |
| | : | System : Siphon with ϕ 900 mm x 2 lines |
| Construction Cost | : | 38 billion VND |

(4) Hung Phu Sub-Zone

Two (2) lines of interceptor sewer are proposed under the Ben Ba Dinh and Ben Nguyen Duy roads on both sides of sub-zone along the canals. After joining both interceptor sewers at the intersection of Chanh Hung and Ben Nguyen Duy roads, the merged interceptor sewer connects to the main sewer with a diameter of $\phi 2200$ mm coming from the Left Bank of Tau Hu - Ben Nghe Canal.

Main Features

| | |
|----------------------|---------------------------------|
| Total Length | : 4,435 m |
| Interceptor Diameter | : $\phi 300$ mm - $\phi 900$ mm |
| Trench Depth | : 1.9 - 11 m |
| Construction Method | : Open Cut Method |
| Construction Cost | : 19 billion VMD |

(5) Tung Thien Vuong Sub-Zone

Two (2) lines of interceptor sewer are proposed under the Ben Binh Dong and Ben Nguyen Duy roads on both sides of sub-zone along the canals. After joining both interceptor sewers, the merged interceptor sewer connects to the interceptor sewer for Hung Phu Sub-Zone.

Main Features

| | |
|----------------------|---------------------------------|
| Total Length | : 4,739 m |
| Interceptor Diameter | : $\phi 300$ mm - $\phi 600$ mm |
| Trench Depth | : 1.9 - 8 m |
| Construction Method | : Open Cut Method |
| Construction Cost | : 22 billion VMD |

(6) Binh Dong Sub-Zone

Interceptor sewers are proposed under roads surrounding Binh Dong sub-zone. Collected wastewater by the interceptor sewers is transferred to the main sewer in Tung Thien Vuong sub-zone. Crossing under Ngang No.1 canal by pipe jacking method is proposed near by the bridge.

Main Features

| | |
|----------------------|--------------------------------------|
| Total Length | : 2,543 m (including canal crossing) |
| Interceptor Diameter | : $\phi 300$ mm - $\phi 400$ mm |
| Trench Depth | : 2.0 m - 5.1 m |
| Construction Method | : Open Cut Method |
| Canal Crossing | : Canal Name : Ngang 1 Canal |
| | : Length : 42 m |

Construction Method : Open Cut Method
 System : Siphon with ϕ 300 mm
 x 2 lines

Construction Cost : 6 billion VMD

(7) Rach Ong, Pham The Hien, and Binh Dang Sub-Zone

The interceptors for Rach Ong, Pham The Hien, and Binh Dang are planned to connect the interceptors from the area isolated by Tau Hu – Ben Nghe and Doi – Te Canal. In addition, the interceptor is collected sanitary sewer in Rach Ong, Pham The Hien, and Binh Dang. The characteristic of the interceptor is as follows:

Main Features

Total Length : 6,154 m
 Interceptor Diameter : ϕ 400 mm - ϕ 1,500 mm
 Trench Depth : 1.9 - 11 m
 Construction Method : Open Cut Method : 3,350 m
 Pipe Jacking Method : 2,804 m
 Construction Cost : 139 billion VMD

7.8 Diversion Chamber

7.8.1 Introduction

Purpose of diversion chamber is to intercept wastewater from combined sewer. The diversion chamber is installed nearby outlet of the existing combined sewer under the existing road or sidewalk. All existing combined sewers are affected by tide from canals. Therefore, high water level must be considered to design diversion chamber.

Diversion chamber is needed as follows:

| | |
|--------------------------------------|----|
| East Area of Left Bank of THBN Canal | 28 |
| West Area of Left Bank of THBN Canal | 12 |
| Khanh Hoi | 29 |
| Hung Phu | 7 |
| Tung Thien Vuong | 21 |
| Binh Dong | 2 |
| Total | 99 |

7.8.2 Design Condition

The proposed typical diversion chamber is shown in Fig. 7.3. Typical plane internal dimension is proposed as 2m x 2.2m. The orifice is designed to divert the wastewater to

the interceptor sewer. The size of orifice is designed by the design flowrate in each existing pipe. A flap gate is installed at the center of the diversion chamber.

Based on the sewage flow conditions in the combined sewer and water level conditions of receiving water bodies, following four (4) cases should be taken into consideration to divert the design wastewater to the interceptor sewer.

| Case | Flow Condition | Water level of Down Stream |
|------|------------------|----------------------------|
| A | Dry weather flow | Low tide |
| B | Wet weather flow | Low tide |
| C | Dry weather flow | High tide |
| D | Wet weather flow | High tide |

Hydraulic condition of diversion chamber under the different four (4) cases mentioned above are explained in Fig. 7.4 and Fig. 7.5.

Design highest water level of receiving water bodies is applied at +1.4 m above mean sea level at Mui Nai based on tidal data between 1993 and 1997.

7.8.3 Preliminary Design

According to hydraulic condition in each case, wastewater and rain water flow described as follows:

| Case | flow to outlet | flow to orifice |
|--------|----------------|---------------------------|
| Case A | none | design flowrate |
| Case B | yes | design flowrate or more |
| Case C | none | design flowrate |
| Case D | yes | more than design flowrate |

Size of orifice is determined in the condition of Case A and C. To avoid attaching solid waste or other garbage, a size of orifice is designed as big as possible. To do so, upper edge of orifice is set just below the invert level of drainage pipe (Fig. 7.3).

A size of orifice is determined by a capacity of the design flowrate in each drainage pipe in dry weather. Design flowrate is estimated by a computer simulation of MOUSE released by Danish Hydraulic Institute. Fig. 7.2 shows a size of orifice at secondary interceptor.

In Case D, flowrate to orifice is the largest. Total volume flowing to interceptor is 3 times higher than design flow. The design concept of interceptor is not allowed to flow over design flowrate. Therefore, it is proposed that a gate be installed at a diversion chamber.

A reduction of the flowrate by gate is proposed to be daily average wastewater flowrate

as a safety. From a result of MOUSE, nine diversion chambers should be installed gate to be a hourly average wastewater flowrate in an interceptor. Diversion chamber selected an installation of gate is shown in Fig. 7.2.

To control gate, maintenance person should stay near the diversion chamber with gate for 24 hr. For safe and effective operation, a relationship of water volume and water level should be investigated after the installation.

TABLE 7.1 STANDARD SLOPE FOR DESIGN CRITERIA

| Diameter (mm) | Slope, I (‰) | Vfull (m/s) | Qfull (m ³ /s) | Design Criteria in Vietnam | |
|------------------|-----------------|----------------|------------------------------|----------------------------|----------|
| | | | | Vmin | Imin (‰) |
| 300 | 2.3 | 0.7 | 0.05 | 0.8 | 4.0 |
| 350 | 2.2 | 0.7 | 0.07 | 0.8 | 4.0 |
| 400 | 2.1 | 0.8 | 0.10 | 0.8 | 2.5 |
| 450 | 2.0 | 0.8 | 0.13 | 0.9 | - |
| 500 | 2.0 | 0.9 | 0.17 | 0.9 | - |
| 600 | 1.9 | 0.9 | 0.27 | 1.0 | - |
| 700 | 1.7 | 1.0 | 0.38 | 1.0 | - |
| 800 | 1.5 | 1.0 | 0.51 | 1.0 | - |
| 900 | 1.5 | 1.1 | 0.70 | 1.15 | - |
| 1000 | 1.4 | 1.1 | 0.90 | 1.15 | - |
| 1100 | 1.3 | 1.2 | 1.11 | 1.15 | - |
| 1200 | 1.2 | 1.2 | 1.35 | 1.15 | - |
| 1300 | 1.2 | 1.3 | 1.67 | 1.3 | - |
| 1500 | 1.2 | 1.4 | 2.45 | 1.3 | - |
| 1600 | 1.2 | 1.4 | 2.91 | 1.5 | - |
| 1800 | 1.2 | 1.6 | 3.98 | 1.5 | - |
| 2000 | 1.2 | 1.7 | 5.27 | 1.5 | - |
| 2500 | 1.0 | 1.8 | 8.73 | 1.5 | - |
| 3000 | 0.9 | 1.9 | 13.47 | 1.5 | - |





FIG. 7.1 SUB-ZONES AND INTERCEPTOR ROUTE









FIG. 7.3 PROPOSED TYPICAL SECTION DIVERSION CHAMBER
(Sample as Secondary Interceptor No.7)




Case A (Dry Weather Flow & Low Tide)




Case B (Wet Weather Flow & Low Tide)

FIG. 7.4 HYDRAULIC CONDITION OF DIVERSION CHAMBER - CASE A & B
(Sample as Secondary Interceptor No.7)



Case C (Dry Weather Flow & High Tide)



Case D (Wet Weather Flow & High Tide)

FIG. 7.5 HYDRAULIC CONDITION OF DIVERSION CHAMBER - CASE C & D
(Sample as Secondary Interceptor No.7)

Chapter 8

INTERMEDIATE

WASTEWATER PUMPING

STATION (IWPS)

CHAPTER 8 INTERMEDIATE WASTEWATER PUMPING STATION (IWPS)

8.1 Necessity of Intermediate Wastewater Pumping Station and Its Proposed Site

A total length of the interceptor and conveyance sewers amount to approximately 8.6 km. If no intermediate wastewater pumping station (hereinafter referred to as “IWPS”) will be constructed, depth of the conveyance sewer at the wastewater treatment plant would be estimated at deeper than GL.-19.0 m. Hence, an ISPS is proposed to construct at the appropriate depth of interceptor or conveyance sewers, taking into consideration of the following technical and economical points of view:

- (a) to optimize the project cost consisting of construction and O/M costs,
- (b) to apply the conventional construction method for conveyance sewer, and
- (c) to assure easier maintenance work of the conveyance sewer.

An appropriate location of IWPS would be selected nearby connection point with interceptor and conveyance sewers, which is almost center of total length of both sewers. However, IWPS is proposed to construct at swampy area having some illegal houses in Ward 4 in District 8 as shown in Fig. 8.1, which is about 200 m to the south from the Doi canal, considering the following view points:

- (a) IWPS site would be selected to keep away from the concentrated urbanized area, because of high countermeasure cost for environmental deterioration, such as noise, bad smell, vibration, etc.
- (b) Sufficient land with about 0.66 ha (60 m x 110 m) for construction of IWPS could not acquire along the proposed north conveyance sewer from Doi canal.
- (c) Shield tunnel method was selected as most suitable one for construction of conveyance sewer crossing of Tau Hu and Doi canals.
- (d) The proposed swampy area is the nearest open space from the junction with interceptor, which has a possibility of land acquisition and compensation for almost all illegal houses, resulting in the shortest of the conveyance sewer line by the shield tunnel method.

8.2 Planning Concept and Design Criteria

Planning concept and design criteria has been established, aiming to propose more practical, economical and sustainable project. These are as follows:

(1) Stepwise Construction

IWPS is proposed to construct step by step to meet the design wastewater flow in two phases, of which target year is 2005 and 2010. However, for preparation of the definitive plan, main features and dimension of each facility and equipment shall be determined

basically based on the design criteria of Master Plan and checked its availability on Phase 1 and 2.

(2) Design Wastewater Flow

Design wastewater flow (DWF) for IWPS is to be basically set to meet the wet weather hourly maximum wastewater flow including ground infiltration assumed to be at 10 % of daily discharge. DWF in Phase 1 and 2 are estimated as shown in table below.

| Phase | Wastewater Flow (m ³ /day) | | | |
|-------------|---------------------------------------|--------------|-----------------|-------------------------------------|
| | Dry Weather | | Wet Weather | |
| | Daily Discharge | Infiltration | Max. Daily Flow | Max. Hourly Flow |
| Phase 1 | 127,700 | 12,800 | 141,000 | 192,000 (133.3 m ³ /min) |
| Phase 2 | 426,500 | 42,700 | 469,000 | 640,000 (444.4 m ³ /min) |
| Master Plan | 465,500 | 46,500 | 512,000 | 699,000 (485.4 m ³ /min) |

Note: 1. Wet weather max. hourly wastewater flow is assumed to be at 1.4 times of dry weather daily discharge plus ground infiltration assumed to be at 10 % of daily discharge.

2. Target year of Phase 1, 2 and Master Plan is 2005, 2010 and 2020 respectively

(3) Design Water Level (DWL)

Design water levels at the inlet and outlet chambers of IWPS connecting up and down conveyance sewers is planned as the table below:

| Place | Design High Water Level | | | Design Mean Water Level | | |
|----------------|-------------------------|---------|--------|-------------------------|---------|--------|
| | (DHWL) | | (m) | (DMWL) | | (m) |
| | Phase 1 | Phase 2 | M/P | Phase 1 | Phase 2 | M/P |
| Inlet Chamber | -11.59 | -10.91 | -10.72 | -11.74 | -11.25 | -11.18 |
| Outlet Chamber | +0.10 | +0.10 | +0.10 | -0.11 | -0.11 | -0.11 |

Note: 1. DHWL represents water level at wet weather hourly maximum flow of 133.3 m³/s in Phase 1, 444.3 m³/s in Phase 2 and 485.4 m³/s in Master Plan (M/P).

2. DMWL represents water level at wet weather average daily flow of 97.9 m³/min. in Phase 1, 325.7 m³/min. in Phase 2 and 355.6 m³/min. in M/P.

(4) Geological Condition

Soil investigation at the proposed intermediate pumping site were conducted in the Feasibility Study. According to the on-site soil survey results, the sub-soil consist of the following layers:

| Layer | Depth (m) | Thickness (m) | Materials | N-Value | Notation |
|-------|--------------|------------------|---|---------|----------|
| 1 | 1.35 – 4.5 | 3.15 | Very soft, high plasticity blackish gray organic clay | 0 | OH |
| 2 | 4.5 – 8.5 | 4.0 | Medium dense, yellowish gray clayey sand | 12 – 15 | SC |
| 3 | 8.5 – 11.0 | 2.5 | Medium dense yellow silty sand | 14 – 15 | SM |
| 4 | 11.0 – 32.0 | 21.0 | All medium dense soils. brownish yellow, reddish brown, pinkish brown and yellowish brown silty clayey sand | 13 – 18 | SM,SC |
| 5 | 32.0 – 39.0 | 7.0 | Medium dense, brownish yellow silty sand | 13 – 18 | SM |
| 6 | 39.0 – 41.0 | 2.0 | Medium dense, reddish brown, well graded sand | 14 – 18 | SW,SM |
| 7 | 41.0 – 42.5 | 1.5 | Medium dense, brownish yellow silty sand | 20 – 32 | SM |
| 8 | 42.5 – 50.0 | 7.5 | Hard, high plasticity brownish gray clay | 36 – 46 | CH |

According to the soil test, characteristics of the sub-soil are summarized as follows:

| | | |
|---------------------------------|---|----------------------------------|
| * Natural Moisture Contents(Wn) | : | 14.0 – 111.9 % |
| * Specific Gravity(Gs) | : | 2.576 – 2.691 |
| * Liquid Limit(Lw) | : | 17.1 – 115.2 % |
| * Plastic Limit(Pw) | : | 12.9 – 57.2 % |
| * Wet Density(rt) | : | 1.367 – 2.116 g/cm ³ |
| * Dry Density(rd) | : | 0.645 – 1.804 g/cm ³ |
| * Cohesion(C) | : | 0.057 – 0.538 kg/cm ² |

8.3 Alternative Study

Grit chamber is generally installed before pump equipment to remove grit, solid and other inorganic substance that might clog and wear away the pump equipment (Forward Grid Chamber Method). However, the invert elevation of the conveyance sewer connecting to the IWPS reaches about EL.-13 m. Consequently, the grit chamber have to be constructed at very deep depth of EL.-15 m, resulting in its high construction cost, long construction period and hard operation and maintenance work after construction.

To cope with these problems, Backward Grit Chamber Method that the grit chamber is installed after pump equipment has recently been developed, taking into account of some mechanical countermeasures.

So, the following two options of alignment of the grit chamber have been examined to determine an optimum one in the previous Feasibility Study.

- (a) Option A: Backward Grid Chamber Method (refer to Fig. 8.2)
- (b) Option B: Forward Grid Chamber Method (refer to Fig. 8.3)

According to the comparative study on these options as shown in the table below, Option A has been recommended, because of its technically and economically feasible.

COMPARISON FOR TWO OPTIONS OF GRIT CHAMBER

| Option A | Option B |
|---|--|
| Backward Grid Chamber | Forward Grid Chamber |
| <i>Advantage</i> | |
| <p>(Structure Design)</p> <ol style="list-style-type: none"> 1. Depth of Grit Chamber is about 10 m shallower. 2. Length of Grit Chamber is about 8 m shorter. 3. Height of Bar Screen is Smaller. 4. Size of devices for scraper and chain-driven rake to clean the channel and screen reduced and gate. 5. Volume of building under ground is reduced. (approximately 30 % smaller) 6. Area of building is reduced. <p>(Construction Cost)</p> <ol style="list-style-type: none"> 7. Construction cost of is estimated lower. Especially the cost of civil work is reduced to 70 % of Option B. <p>(Operation & Maintenance)</p> <ol style="list-style-type: none"> 8. O/M cost of mechanical and electrical equipment is estimated lower because the device sizes are smaller. | Subjects are contrary to Disadvantage of Option A . |
| <i>Disadvantage</i> | |
| <p>(Structure & Equipment Design)</p> <ol style="list-style-type: none"> 1. Pump should be a solid permissible type to prevent jamming from larger solids. <p>(Construction Cost)</p> <ol style="list-style-type: none"> 2. Cost of pump equipment may be slightly higher owing to a special impeller of pump. <p>(Operation & Maintenance)</p> <ol style="list-style-type: none"> 3. More frequent maintenance is required. | Subjects are contrary to Advantage of Option A . |

8.4 Proposed Definitive Plan

In general, IWPS consists of two (2) facilities, pumping station and grit chamber. In the pumping station, emergency gate, fine screen, main pump and electrical equipment are to be installed. Inlet and outlet gate and grit removal equipment are to be installed in the grit chamber.

8.4.1 Pumping Station

(1) Major Mechanical and Electrical Equipment

Design Water Level and Pump Head

Based on the design water level at the inlet and outlet of the conveyance sewer mentioned before, the water levels for design of pump equipment by Phase were estimated as follows:

| Phase | Inlet Chamber | Pump Before Screen | Pit After Screen | Discharge Sump | Grit Chamber | Outlet Chamber |
|---------|---------------|--------------------|------------------|----------------|--------------|----------------|
| Phase 1 | -12.247 | -12.400 | -12.500 | +0.55 | +0.50 | +0.45 |
| Phase 2 | -11.353 | -11.500 | -11.600 | +0.55 | +0.50 | +0.45 |

Static pump head (Hs) and total pump head (Ht) are estimated as follows:

$H_s = \text{DWL in discharge sump} - \text{DWL in pump pit (before screen)}$

$H_t = H_s + H_l$

Where, H_l = Hydraulic losses of screen, pipe and other losses

H_l is estimated to be about 1.0m for fine screen and other facilities. Design static head and total pump head are estimated as follows:

| Phase | Hs(m) | Hl(m) | Ht(m) |
|---------|-------|-------|-------|
| Phase 1 | 12.95 | 1.0 | 14.0 |
| Phase 2 | 12.05 | 1.0 | 13.1 |

Pump Type Alternatives

The conventional pump applied for sewage system is generally classified into four types, such as (i) Axial Flow Pump, (ii) Mixed Flow Pump, (iii) Mixed Flow Pump with Volute Casing, (iv) Centrifugal Pump. The application ranges in total pump head and bore size are summarized below:

| Pump Type | Total Pump Head (m) | Available Pump Diameter (mm) |
|---------------------------------------|---------------------|------------------------------|
| Axial Flow Pump | Less than 5 | More than 400 |
| Mixed Flow Pump | 3 to 12 | More than 400 |
| Mixed Flow Pump with Volute Casing | 5 to 20 | More than 400 |
| Centrifugal Pump | More than 5 | More than 80 |

In consideration of the above applicable ranges, the following three (3) alternative pump types are studied.

- (a) Alternative 1: Vertical Shaft Mixed Flow Pump with Volute Casing (dry pit type)
- (b) Alternative 2: Submersible Motor Mixed Flow Pump with Volute Casing
- (c) Alternative 3: Vertical Shaft Mixed Flow Pump (wet pit type)

Note: Since required suction lift for the IWPS is high, vertical shaft type pumps and submersible motor type pump are proposed.

As the results of comparative study shown in Tables 8.1(1/3), (2/3) and (3/3), Alternative 2 “ Submersible Motor Mixed Flow Pump with Volute Casing “ is recommended as the most applicable and economical pump type taking into consideration of the following technical and economical points.

- (a) Against clogging, Alternative 1&2 are superior than Alternative 3.
- (b) Construction cost of mechanical and electrical works for Alternative 2 is lowest.
- (c) Since siphon type is adopted for Alternative 2, yearly energy consumption is lowest among three (3) Alternatives.
- (d) Area and height of the pumping station for Alternative 2 is smallest.
- (e) Auxiliary system such as sealing water system or lubricating water system is not required.

Note: Replacing of mechanical seals and maintenance work of submersible motor pump can be made in Vietnam. Re-winding of submersible motor needs to be done by the original manufacturer at this moment, however re-winding may be possible in few years time in Vietnam.

Unit Capacity and Number of Pump

Based on required pump capacities for phase 1&2 and in year 2020, the following three (3) alternative plans are examined in order to select optimum unit pump capacity and number of pump.

Note) Design pump capacities for phase 2 and Master Plan in 2020 are 640,000 m³/day

and 699,000 m³/day respectively. A difference between these capacities is only 59,000 m³/day. In order to meet this capacity increment and make the minimized construction cost of the pumping station, concept of replacement of impeller in 2020 is applied in the study. In phase 2, smaller size of impeller will be supplied to meet a capacity of 640,000 m³/day. In the year 2020, the impeller will be replaced to larger size to meet a capacity of 699,000 m³/day.

| Alternative | Phase 1 | Phase 2 | In Year 2020 |
|-------------|--|---|--|
| 1 | 44.5 m ³ /min x 3 + 1 stand-by | ○ ○ ○ ○ 44.5 m ³ /min (additional pump) 133.2 m ³ /min x 2 + 1 stand-by (small impeller) | ○ ○ ○ ○ 44.5 m ³ /min ○ ○ ● 153.7 m ³ /min (large impeller) |
| 2 | 66.7 m ³ /min x 2 + 1 stand-by | ○ ○ ○ 66.7 m ³ /min (additional pump) 122.1 m ³ /min x 2 + 1 stand-by (small impeller) | ○ ○ ○ 66.7 m ³ /min ○ ○ ● 142.7 m ³ /min (large impeller) |
| 3 | 133.3 m ³ /min x 1 + 1 stand-by | ○ ○ ○ 117.4 m ³ /min (additional pump) 103.7 m ³ /min x 3 (small impeller) | ○ ○ ○ 117.4 m ³ /min (large impeller) ○ ● 133.3 m ³ /min |

The comparison of three (3) alternative plans including construction cost is shown in Table 8.2. This comparison study is made under the following conditions.

- Unit capacity and number of pump should be determined to suit a hourly wastewater fluctuation as shown in Table 8.3.
- Unit capacity and number of pump should be determined considering design capacity increment of the pumping station from 192,000 m³/day for phase 1 to 699,000 m³/day in year 2020.
- At least one (1) stand-by unit should be prepared. Usually, stand-by unit has a biggest capacity in the pumping station.

As shown in Table 8.2, the construction cost for Alternative 3 (133.3 m³/min x 2, 103.7 m³/min x 3) is the cheapest if the civil and building works for Phase 1&2 will be constructed at Phase 1 stage. However, most frequent pump operation (start and stop) is anticipated for Alternative 3. Usually the pump unit capacity will be designed according to phases of the project. For this study, capacity of Phase 2 is much larger than that of Phase 1. In this point of view, pump unit capacity of Phase 2 would be larger than pump unit capacity of Phase 1. Pump unit capacity of phase 1 (133.3 m³/min) seems large comparing with pump unit capacity of phase 2 (103.7 m³/min).

Alternative 1 (44.5 m³/min. x 4, 133.2 m³/min x 3) have an advantage in terms of non-frequent pump operation, however pump unit capacity seems too small comparing with required total P/S capacity in the year 2020. Unit capacity of small pump for Alternative 1 is 44.5 m³/min which capacity is less than one tenth of total P/S capacity of 485.4 m³/min. The construction cost for Alternative 1 is the highest.

Alternative 2 ($66.7 \text{ m}^3/\text{min} \times 3$, $122.1 \text{ m}^3/\text{min} \times 3$) is recommended due to the following reasons:

- (a) Frequent pump operation (start and stop) is not anticipated.
- (b) The difference of construction cost between Alternative 2 and 3 is less than two (2) percent.
- (c) Pump unit capacity for Phase 1 and 2 are adequate.
 Small pump: about 1/8 of total P/S capacity
 Large pump: about 1/4 of total P/S capacity

Siphon System

Siphon system is proposed for design of the pump discharge system taking into consideration of the following technical and economical points.

- (a) Area of the pumping station is reduced.
- (b) Loss of non-return and butterfly valve is eliminated. As a result, total head of pump is reduced and energy consumption of the motor is also reduced.
- (c) Mechanical equipment cost can be minimized.

Instead of non-return valve and butterfly valve, siphon breaker valve is proposed to install at top of pipe to prevent reverse flow from grit chamber when the pump stops. DC motor is proposed as driving unit of the siphon breaker valve in order to open the valve even in case of power failure.

Emergency Gate

The emergency gate is proposed at the inlet of the IWPS in order to prevent the flooding of pumping station due to excessive storm water flowing into the pump. The emergency gate will be closed if the suction water level reaches to HHWL and be closed within two (2) minutes by its own weight. The emergency gate can be opened/closed by an electric motor during normal operation.

The storm water, which will be stored in the interceptor will be discharged by the main sewage pumps after the rain stops.

The sizes of emergency gate are proposed to be 2000mm square and 1600mm square for Phase 1 and 2 respectively to maintain the flow velocity through the gate not more than 1.0m/s at maximum daily wastewater flow.

Garbage Disposal Method

Garbage, rubbish and other materials in the sewer water are collected by the fine screen, which is installed in the IWPS. These garbage and other materials are transported by horizontal conveyor and inclined conveyor to the concrete made garbage-collecting box

located outside of the station. In Phase 1, the stored garbage in the garbage-collecting box are cleared by man(s) and transported by the dump truck to the dumping area. Frequency of these works depends on the volume flowing into the station. In Phase 2, garbage, rubbish and other materials will be ground, washed and dehydrated by the grinding equipment, etc. and stored in the hopper.

Power Source of Pump Operation

The proposed pump is driven by an electric motor. The power source is supplied from the “Saigon South 4” sub-station through the WWTP and “Chanh Hung” sub-station, of which voltage is 22kV. The station will receive two (2) lines of 22kV as loop line at a new electric pole installed inside the IWPS area. 22kV incoming panels are installed at high voltage receiving area outside of the pumping station. Since the pump type is submersible motor type with voltage of AC380V, a 22kV/0.38kV step down transformer is installed in the electrical room. The 0.38kV also supplies electricity to each feeder in motor control center (MCC). MCC supply 380V to all the auxiliary equipment such as emergency gate, fine screen, conveyor, grit removal equipment, etc. The electrical room is located at B1 floor to reduce the building height minimize. 22kV/0.38kV transformer panel, main pump starter panel, MCC, battery and charger panel, relay panel, etc. are installed in the electrical room. The control room is located at ground floor. Supervisory panel, which monitors pump operating conditions such as start/stop, major and minor faults, etc. and suction/discharge water level conditions is installed in the control room.

The stand-by generating unit with capacities of 750kVA and 1500kVA is proposed for Phase 1 and 2 respectively. With these capacities, more than 80% of phase capacity can be discharged to the treatment plant as shown in the following table.

| Phase | Stand-by generator capacity | Equipment covered by the generator |
|---------|-----------------------------|--|
| Phase 1 | 750kVA | 66.7m ³ /min x 2, air inlet fan, lighting, battery |
| Phase 2 | 1500kVA | 122.1m ³ /min x 2, air inlet fan, lighting, battery |

Other Major Equipment

The other major mechanical and electrical equipment to be required for installation, operation and maintenance works of IWPS are listed in Tables 8.5(1/2) and (2/2).

(2) Civil Works

The proposed pumping station consist of inlet pit, pump well, pump and electrical room, and related structures. The civil works of these structures are composed temporary works, earth works, foundation work, reinforced concrete work, and others. The general layout of pumping station is shown in Fig. 8.4. Structural drawings of pumping station are shown in Figs 8.5(1/3) to (3/3), and design concept of for each component of the facilities is described below:

Inlet Pit

Wastewater collected from the project area of 3,065 ha flow into the inlet pit through the new interceptor sewer of 2,000 mm dia. constructed in Phase 1 and new interceptor of 1,800 mm dia. constructed in Phase 2. Inlet pit is planed at the front of pumping station. The inlet pit will be constructed with reinforced concrete and designed to provide four sluice gates of 1,500 mm W x 1,500 mm H, which is used at emergency shut down.

Main features of the pit are as follows:

| Inlet Pipe | | Inlet Pit | | Number of | |
|-----------------|---------------|-----------|-------|-----------|----------------|
| Diameter | Bed Elevation | Width | Depth | Length | Emergency Gate |
| (mm) | (EL. m) | (m) | (m) | (m) | (nos.) |
| 2,000 and 1,800 | -12.50 | 3.00 | 14.50 | 15.80 | 4 |

Pump Well

The pump well is a reinforced concrete substructure for installation of fine trash screen and pump equipment. Pump well consists of two zones, mechanical screening zone and pump well zone.

Mechanical screening zone is divided into four channels, of which dimension are 3.5 m in width, 2.1 m in depth and 11.0 m in length to keep steady flow under lower velocity of 0.5 m/s, and solids and other inorganic materials in collected wastewater will be screened automatically by fine screen equipment installed at underground mechanical room, of which floor elevation of EL.-6.0 m.

Pump well zone is planned to have sufficient width, depth and length to storage enough wastewater for continuous pump operation as much as possible. Pump well forms one room having no partition wall. Bottom elevation of the pump well is designed to be deeper more than 3.7 times of the maximum pump bore from the pump stop level (L.L.W.L) of EL.-13.30 m.

Main features of pump well are as follows:

| Width (m) | Water Depth from DWL (m) | Length (m) | Flow Elevation (EL. m) | | |
|--------------|-----------------------------|---------------|------------------------|--------|--------|
| | | | Top | Middle | Bottom |
| 28.90 | 5.10 | 3.00 | +2.00 | -6.00 | -17.00 |

Pump Room

Pump room is also reinforced concrete sub-structure adjacent to the pump well and is designed to have sufficient space for installation, operation and maintenance of pump

equipment (vertical shaft mixed flow pump: 3 units of ø700, 3 units of ø1000). Main features of the pump room are as follows:

| Width (m) | Length (m) | Height (m) | Number of Story (nos.) | Floor Elevation (EL. m) | | |
|--------------|---------------|---------------|---------------------------|-------------------------|--------|--------|
| | | | | Top | Middle | Bottom |
| 28.90 | 13.00 | 11.00 | 2 | +2.30 | -6.00 | -17.00 |

Operation and Maintenance Building

O/M building is planned to provide pump motor room, generator room, electrical room, storage room and administration room including accommodation for operators. O/M building is designed to be two stories reinforced concrete super-structure having enough space of about 1,300 m² required for sufficient operation and maintenance. Main features of each room is as follows:


| Room | Location (Floor) | Area (m ²) | Width (m) | Length (m) | Height (m) | Equipment |
|----------------|-----------------------|---------------------------|--------------|---------------|---------------|-------------------------|
| Pump Motor | 1 st floor | 375 | 13.0 | 28.9 | 11.0 | Pump: 6 sets, others |
| Generator | 1 st floor | 113 | 7.8 | 14.5 | 5.5 | Generator: 2 sets |
| Electric | 1 st floor | 127 | 8.8 | 14.5 | 5.5 | Electric panels |
| Storage | 1 st floor | 141 | 8.5 | 16.6 | 5.5 | Spare parts, others |
| Administration | 2 nd floor | 480 | 16.6 | 28.9 | 5.5 | Office, accommodation |
| Others | 2 nd floor | 100 | 6.0 | 16.6 | 5.5 | Entrance, lobby, others |

8.4.2 Grit Chamber

(1) Main Features of Grit Chamber

Main features of grit chamber are calculated as follows.

Design Surface Load of Grit Chamber: $L_s = 1,800 \text{ m}^3/\text{m}^2\cdot\text{day}$



$$v / V = H / h \quad V = Q / (W \times L)$$

$$T = (W \times L \times H) / Q$$

Where, v : Sedimentation Velocity of Particles (m / s)
 minimum remove particle diameter = 0.2 mm (assumed)
 specific gravity of sand = 2.65 (assumed)
 then $v = 0.021$ m / s
 V : Average Velocity in Grit Chamber (0.325 m / s)
 H : Effective Depth of Grit Chamber (m)
 T : Retention time (30 ~ 60 sec.) → use 60 sec.
 h : Depth of Sand Pit (more than 0.30 m) → use 0.50 m
 Q : Maximum inflow of wastewater (485.4 m³/min./60 sec = 8.09 m³/s)

$$L = V \times T = 0.325 \text{ m/sec.} \times 60 \text{ sec.} = 19.5 \text{ m}$$

$$W = Q / (V \times T \times v) = 8.090 \text{ m}^3/\text{s} / (0.325 \times 60 \times 0.021) = 20.0 \text{ m}$$

$$H = T \times v = 60 \times 0.021 = 1.26 \text{ m}$$

Therefore, main features of grit chamber are as follows:

$$5.0 \text{ m (W)} \quad \times \quad 19.5 \text{ m (L)} \quad \times \quad 2.0 \text{ m (H + h)} \quad \times \quad 4 \text{ chambers}$$

(effective depth 1.50 m + sand pit 0.50 m)

(2) Major Mechanical and Electrical Equipment

Grit Removal Equipment

The conventional grit removal equipment using in grit chamber is generally classified into three types, such as (i) Bucket conveyor type, (ii) Screw conveyor type and (iii) Grab bucket type. Alternative study for identification of the most appropriate grit removal equipment has been made as follows:

- (a) Alternative 1: Fixed type bucket conveyor
- (b) Alternative 2: Traveling type grab bucket
- (c) Alternative 3: Screw conveyor with sand pump

As the results of comparative study for these alternatives as shown in Tables 8.4 (1/2) and (2/2), Alternative 2 “Traveling type grab bucket” is recommended by the following reasons:

- (a) Equipment cost of Alternative 2 is much cheaper than those of Alternative 1 and 3.
- (b) Construction of grab bucket is simple.
- (c) Maintenance work is easiest since all mechanical parts are equipped above water.
- (d) Even if large amount of grit are flowing into chamber, any damages will not be expected to the equipment.

Gate

Sluice gate of 1,500 mm W x 1,500 mm H is designed to install at each inlet and outlet of grit chamber. These gates are used to dry up and to maintain the grit chamber.

(3) Civil Works

The proposed grid chamber consists of discharge sump, grit chamber, outlet pit and related structures. The civil works of these structures are composed of temporary works, earth works, foundation work, reinforced concrete work and others. The general layout of pumping station is shown in Fig. 8.4. Structural drawings of grit chamber are shown in Figs. 8.5 (1/3) to (3/3). Design concept for each component of the grit chamber is described below:

Discharge Sump

Discharge sump is planned at the front of grit chamber. The discharge sump will be constructed with reinforced concrete and designed to have sufficient space to convey smoothly pumped up wastewater to 4 grit chambers through the sluice gates of 1,500 mm (W) × 1,500 mm (H).

Main features of the discharge sump are as follows:

| Width (m) | Water Depth (m) | Length (m) | Elevation (EL. m) | |
|----------------|--------------------|---------------|-------------------|-------|
| | | | Bottom | Top |
| 28.00 to 21.50 | 2.05 | 7.00 | -1.85 | +2.30 |

Grit Chamber

Grit chamber is reinforced concrete substructure and has a function to remove the grit from a wastewater to the outside of pumping station. Grit chamber is designed to divide into four channels with sufficient width, length and depth to settle the grit in wastewater.

Main features of grit chamber are as follows.

| Width (m) | Water Depth (m) | Length (m) | Number of Channel (nos.) | Elevation (EL. m) | |
|--------------|--------------------|---------------|-----------------------------|-------------------|-------|
| | | | | Bottom | Top |
| 5.00 | 2.00 | 19.50 | 4 | -1.85 | +2.30 |

Outlet Pit

Outlet pit is adjacent reinforced concrete sub-structure having a function to convey wastewater from grid chamber to conveyance sewers connected with wastewater treatment plant. Two conveyance sewers are box culverts of 1,300 mm (W) x 1,200 mm (H) to be constructed in Phase 1 and 2,000 mm (W) x 1,700 mm (H) to be installed in Phase 2.

Main features of outlet pit are as follows:

| Width (m) | Water Depth (m) | Length (m) | Elevation (EL. m) | |
|--------------|--------------------|---------------|-------------------|-------|
| | | | Bottom | Top |
| 23.50 | 1.88 | 4.00 | -1.85 | +2.30 |

8.4.3 Landscape Design

The IWPS site is located suburban area of the District 8 and surroundings of the site generally in use of agriculture land use at present time, however recent land use characteristics shows a residential encroaching feature and the whole area will become a residential area in future urban land use planning scheme. The landscaping of the IWPS site shall meet with these tendency, so that aesthetic landscape design solution shall be essential in harmony with future vicinity residential environment. Fig. 8.6 shows proposed landscape layout plan for the IWPS site.

(1) Proposed Landscape

Main access for motor vehicle shall be minimum 4.0 m in width and concrete paving finish, and colored concrete block paving with 2.0 m in width shall be installed at office entrance surroundings and pedestrian path for aesthetic consideration.

All facility sites shall be enclosed by fence with 2.4 m in height and major gate door shall be minimum 6.0 m in width of enough space for motor vehicle goes in.

Plantings shall be introduced for establishing aesthetic and safety environmental condition of the facility site. Medium trees as major objectives shall be introduced for provision of rich greenery with seasonal flowering for the vicinity site of residential area. Some small flowering shrubs shall be also provided for an accent of the planting layout scheme. Along the enclosure fence especially it faces to the access road, species of flowering shrub, vine and creeper shall be introduced as a hedge planting.

Facility spaces in which without any paving provision shall be furnished with turf grass or some proper ground cover plants in strategic points, so that all the facility space will be covered with clean and greenfly with amicable environment accordingly.

(2) Related considerations

Existing access road shall be widened to 7.0 m in width in order to consider smooth and safety traffics of motor lorry vehicles for the operation and maintenance purpose. The area surroundings of waste water pumping station site is going to be a new housing development area, so that the pumping station site should be considered vicinity environmental condition with aesthetic solution with landscaping.

8.5 Bill of Quantities

Bill of quantities of civil work is shown in Table 8.6.

Table 8.1(1/3) Comparison of Sewerage Pump Type




| Item | Alternative 1 Vertical shaft mixed flow pump with volute casing | Alternative 2 Submersible motor mixed flow pump with volute casing (siphon type) | Alternative 3 Vertical shaft mixed flow pump |
|--|---|---|--|
| <p>1. Pump Specification</p> <p>1-1. Main pump for phase 1</p> <p>1) Bore x Capacity x Head</p> <p>2) Quantity</p> <p>3) Speed</p> <p>4) Efficiency</p> <p>5) Motor</p> <p>1-2. Main pump for phase 2</p> <p>1) Bore x Capacity x Head</p> <p>2) Quantity</p> <p>3) Speed</p> <p>4) Efficiency</p> <p>5) Motor</p> | <p>700mm dia. x 66.7m³/min x 14.9m 2 + 1 (stand-by) 735min-1 80% 240kw</p> <p>1000mm dia. x 122.1m³/min x 14.4m 2 + 1 (stand-by) 593min-1 83% 400kw</p> | <p>700mm dia. x 66.7m³/min x <u>14m</u> 2 + 1 (stand-by) 735min-1 <u>79%</u> <u>220kw</u></p> <p>1000mm dia. x 122.1m³/min x <u>13.5m</u> 2 + 1 (stand-by) 593min-1 <u>82%</u> <u>380kw</u></p> | <p>700mm dia. x 66.7m³/min x 14.9m 2 + 1 (stand-by) 735min-1 79% 240kw</p> <p>1000mm dia. x 122.1m³/min x 14.4m 2 + 1 (stand-by) 593min-1 82% 400kw</p> |
| 2. Installation Layout |  <p>Pump is installed in a dry pit (pump room). Pump impeller can be inspected after removing bearing frame and casing cover. For inspection, suction valve should be closed.</p> |  <p>Pump and motor are always submerged in a water. Pump impeller can be inspected only after the pump is lifted up from water.</p> |  <p>Pump is always submerged in a water. Pump impeller can be inspected only after the pump is lifted up from water.</p> |

Table 8.1(2/3) Comparison of Sewerage Pump Type

| Item | Alternative 1 Vertical shaft mixed flow pump with volute casing | Alternative 2 Submersible motor mixed flow pump with volute casing (siphon type) | Alternative 3 Vertical shaft mixed flow pump |
|---|---|--|---|
| 3. Related Equipment | | | |
| 1) Suction valve | 700mm dia. manual butterfly valve x 3 1000mm dia. manual butterfly valve x 3 | <u>N.A.</u> | N.A. |
| 2) Discharge valve | 700mm dia. motor operated butterfly valve x 3 1000mm dia. motor operated butterfly valve x 3 | <u>N.A.</u> <u>N.A.</u> | 700mm dia. motor operated butterfly valve x 3 1000mm dia. motor operated butterfly valve x 3 |
| 3) Non-return valve | 700mm dia. check valve x 3 1000mm dia. check valve x 3 | <u>N.A.</u> <u>N.A.</u> | 700mm dia. check valve x 3 1000mm dia. check valve x 3 |
| 4) Siphon breaker valve | N.A. N.A. | <u>150mm dia. siphon breaker valve x 3</u> <u>200mm dia. siphon breaker valve x 3</u> | N.A. N.A. |
| 3) Pipe | 700mm to 1000mm dia. cast iron | 700mm to 1000mm dia. cast iron | 700mm to 1000mm dia. cast iron |
| 4) Electrical equipment | H.V. panels, L.V. panels, etc. | H.V. panels, L.V. panels, etc. | H.V. panels, L.V. panels, etc. |
| 5) Generator | 300kVA / 600kVA | <u>750kVA / 1500kVA</u> | 300kVA / 600kVA |
| 6) Overhead crane | 10ton | 10ton | 20ton |
| 7) Aux. equipment | Sealing water system | <u>N.A.</u> | Lubricating water system |
| 4. Comparison | | | |
| 1) Area and depth required for civil works (pump room only) | Area: 32m W x 13m L = 416m ² Depth: 19m | Area: 32m W x 9m L = 288m ² Depth: 19m | Area: 32m W x 12m L = 384m ² Depth: 18m |
| 2) Height required for sub-structure (pump room only) | 11m | <u>8m</u> | 11m |
| 3) Installation | Easy. Alignment for intermediate shafts are required. | Easy. | Installation work is the most difficult. |

Table 8.1(3/3) Comparison of Sewerage Pump Type

| Item | Alternative 1 Vertical shaft mixed flow pump with volute casing | Alternative 2 Submersible motor mixed flow pump with volute casing (siphon type) | Alternative 3 Vertical shaft mixed flow pump |
|---|--|--|--|
| 4) Operation | Pump can start any time, since impeller is always submerged in the water. | Pump can start any time, since impeller is always submerged in the water. | Pump can start any time, since impeller is always submerged in the water. |
| 5) Maintenance | Pump inside can be inspected from the inspection hole of suction casing. | Pump is required to lift up and disassemble when inspection of pump impeller is necessary. | Pump is required to lift up and disassemble when inspection of pump impeller is necessary. |
| 6) Life of equipment | 20years | <u>15years due to submersible motor</u> | 20years |
| 7) Clogging | Since there is no obstacle in a water passage except impeller, not so frequent clogging will be anticipated. | Since there is no obstacle in a water passage except impeller, not so frequent clogging will be anticipated. | Since intermediate bearing supports are required, more frequent clogging will be anticipated than Alternative 1&2. |
| 8) Corrosion | Depends on material used. | Depends on material used. | Depends on material used. |
| 9) Reliability | If periodical maintenance is carried out, long life operation and high reliability is expected. | Periodical maintenance for submersible motor is especially required. | If periodical maintenance is carried out, long life operation and high reliability is expected. |
| 10) Accomplishment | Many. Over 3000mm dia. | (Volute type submersible motor pump) <u>Up to 800mm dia.</u> (Dry type submersible motor) <u>Up to 420kw for 400V class</u> | Many. Over 3000mm dia. |
| 5. Construction cost Unit: Million VND 1 Yen= 134.15 VND 5-1) Mechanical and electrical works (initial cost) | <p>Phase 1</p> <p>105,737</p> <p>101%</p> <p>Phase 2</p> <p>98,882</p> <p>115%</p> | <p>Phase 1</p> <p>104,814</p> <p>100%</p> <p>Phase 2</p> <p>86,040</p> <p>100%</p> | <p>Phase 1</p> <p>112,750</p> <p>108%</p> <p>Phase 2</p> <p>111,906</p> <p>130%</p> |
| 5-2) Mechanical and electrical works (running cost) | <p>240kw x 2sets x 8760hrs x (240kwx3 + 400kwx2) x 8760hrs x 141,000m3/day / 192,000m3/day x 781VND/kw =</p> <p>2412</p> <p>109%</p> | <p>220kw x 3sets x 8760hrs x (220kwx3 + 380kwx2) x 8760hrs x 141,000m3/day / 192,000m3/day x 781VND/kw =</p> <p>2211</p> <p>100%</p> | <p>240kw x 2sets x 8760hrs x (240kwx3 + 400kwx2) x 8760hrs x 141,000m3/day / 192,000m3/day x 781VND/kw =</p> <p>2412</p> <p>109%</p> |
| | | 7119 | 7621 |
| | | 100% | 107% |

TABLE 8.2 COMPARISON OF UNIT CAPACITY AND NOS. OF PUMP

| Items | Alt.1 | | Alt.2 | | Alt.3 | |
|--|--|--|---|--|---|---|
| | Phase 1 | Year 2020 | Phase 1 | Year 2020 | Phase 1 | Year 2020 |
| 1. Unit capacity and nos. of pump | 44.5 m³/min | 153.7 m³/min | 66.7 m³/min | 142.7 m³/min | 133.3 m³/min | 117.4 m³/min |
| Pump dia. | 44.5 m ³ /min x 3 + 1 stand-by 600 mm x (3 + 1) | 153.7(*1) m ³ /min x 2 + 1 stand-by *1 (485.4-44.5x4)/2 = 153.7 1100 mm x (2 + 1) | 66.7 m ³ /min x 2 + 1 stand-by 700 mm x (2 + 1) | 142.7(*2) m ³ /min x 2 + 1 stand-by *2 (485.4-66.7x3)/2 = 142.7 1000 mm x (2 + 1) | 133.3 m ³ /min x 1 + 1 stand-by 1000 mm x (1 + 1) | 117.4(*3) m ³ /min x 3 *3 (485.4-133.3)/3 = 117.4 900 mm x (3) |
| Total capacity as P/S | 178 m ³ /min | 639.1 m ³ /min including Phase 1 | 200.1 m ³ /min | 628.2 m ³ /min including Phase 1 | 266.6 m ³ /min | 618.8 m ³ /min including Phase 1 |
| 2. Motor output Total motor output | 160 kW x (3 + 1) 640 kW | 490 kW x (2 + 1) 2110 kW including Phase 1 | 230 kW x (2 + 1) 690 kW | 460 kW x (2 + 1) 2070 kW including Phase 1 | 440 kW x (1 + 1) 880 kW | 380 kW x (3) 2020 kW including Phase 1 |
| 3. Pump room -Width (m) -Length (m) -Area (M ²) | 15 13 195 | 31 13 403 | 13 13 169 | 29 13 377 | 13 13 169 | 27 13 351 |
| 4. Ratio of total P/S capacity vs daily average wastewater | 44.5x4x60x24/141,000= 1.82 | (44.5x4+153.7x3)x60 x24/512,000= 1.8 | 66.7x3x60x24/141,000= 2.04 | (66.7x3+142.7x3)x60 x24/512,000= 1.77 | 133.3x2x60x24/141,000= 2.72 | (133.3x2+117.4x3)x 60x24/512,000= 1.74 |
| 5. Frequency of pump operation for Phase 1 pump operating condition | 1 st pump start: -12.30 2 nd pump start: -12.10 3 rd pump start: -11.80 Stop: -13.20 | | 1 st pump start: -12.15 2 nd pump start: -11.80 Stop: -13.20 | | 1 st pump start: -11.80 Stop: -13.20 | |
| Maximum suction water level during operation (m) | -11.69 | | -11.41 | | -11.06 | |
| Frequency of pump operation | 1 st pump: 68 / day 2 nd pump: 51 / day 3 rd pump: 19 / day Ave. 34.5 / day / unit, (Phase 1) | Max. 5 times/hr (Phase 2) | 1 st pump: 92 / day 2 nd pump: 46 / day Ave. 46 / day / unit, (Phase 1) | Max. 6 times/hr (Phase 2) | 1 st pump: 113 / day Ave. 56.5 / day / unit, (Phase 1) | Max. 7 times/hr (Phase 2) |
| 6. Construction cost (Unit: Million VND) 1) Civil & building works 2) Mecha. & Elect. Work Total cost | 59,368 70,150 129,518 | - 91,432 91,432 | 55,226 69,540 124,766 | - 81,493 81,493 | 51,281 71,432 122,713 | - 69,051 69,051 |

TABLE 8.3 HOURLY WASTEWATER FLUCTUATION

| Hourly maximum discharge of wastewater: | | |
|---|---------------------------|---------------------------|
| Phase 1 | Phase 2 | Master Plan |
| 133.3 m ³ /min | 444.4 m ³ /min | 485.4 m ³ /min |

| Time | % | Wastewater Fluctuation | | | | | |
|-------|-------|------------------------|---------------------|--------------------|---------------------|--------------------|---------------------|
| | | Phase 1 | | Phase 2 | | Phase 3 | |
| | | m ³ /hr | m ³ /min | m ³ /hr | m ³ /min | m ³ /hr | m ³ /min |
| 0 | 0.033 | 4,700 | 78.3 | 15,633 | 260.6 | 17,067 | 284.4 |
| 1 | 0.029 | 4,113 | 68.5 | 13,679 | 228.0 | 14,933 | 248.9 |
| 2 | 0.029 | 4,113 | 68.5 | 13,679 | 228.0 | 14,933 | 248.9 |
| 3 | 0.028 | 3,931 | 65.5 | 13,076 | 217.9 | 14,275 | 237.9 |
| 4 | 0.026 | 3,638 | 60.6 | 12,099 | 201.7 | 13,209 | 220.1 |
| 5 | 0.031 | 4,406 | 73.4 | 14,656 | 244.3 | 16,000 | 266.7 |
| 6 | 0.042 | 5,875 | 97.9 | 19,542 | 325.7 | 21,333 | 355.6 |
| 7 | 0.053 | 7,411 | 123.5 | 24,652 | 410.9 | 26,912 | 448.5 |
| 8 | 0.057 | 7,999 | 133.3 | 26,606 | 444.4 | 29,045 | 485.4 |
| 9 | 0.052 | 7,344 | 122.4 | 24,427 | 407.1 | 26,667 | 444.4 |
| 10 | 0.050 | 7,050 | 117.5 | 23,450 | 390.8 | 25,600 | 426.7 |
| 11 | 0.048 | 6,756 | 112.6 | 22,473 | 374.5 | 24,533 | 408.9 |
| 12 | 0.046 | 6,463 | 107.7 | 21,496 | 358.3 | 23,467 | 391.1 |
| 13 | 0.046 | 6,463 | 107.7 | 21,496 | 358.3 | 23,467 | 391.1 |
| 14 | 0.044 | 6,169 | 102.8 | 20,519 | 342.0 | 22,400 | 373.3 |
| 15 | 0.042 | 5,875 | 97.9 | 19,542 | 325.7 | 21,333 | 355.6 |
| 16 | 0.042 | 5,875 | 97.9 | 19,542 | 325.7 | 21,333 | 355.6 |
| 17 | 0.042 | 5,875 | 97.9 | 19,542 | 325.7 | 21,333 | 355.6 |
| 18 | 0.045 | 6,373 | 106.2 | 21,197 | 353.3 | 23,140 | 385.7 |
| 19 | 0.049 | 6,870 | 114.5 | 22,851 | 380.9 | 24,946 | 415.8 |
| 20 | 0.047 | 6,666 | 111.1 | 22,174 | 369.6 | 24,207 | 403.4 |
| 21 | 0.044 | 6,169 | 102.8 | 20,519 | 342.0 | 22,400 | 373.3 |
| 22 | 0.040 | 5,581 | 93.0 | 18,565 | 309.4 | 20,267 | 337.8 |
| 23 | 0.038 | 5,288 | 88.1 | 17,588 | 293.1 | 19,200 | 320.0 |
| Total | 1.000 | 141,000 | | 469,000 | | 512,000 | |

Note) Wastewater fluctuation (%) in Table is referred from
 Japanese design manual of wastewater treatment (JDM) "




TABLE 8.4 (1/2) COMPARISON OF GRIT REMOVAL TYPE




| Items | Rotary Bucket Conveyor Type | Grab Bucket Type | Screw Conveyor Type with Sand Pump |
|--|--|--|--|
| 1. Installation Layout |  |  |  |
| 2. Design | V-buckets are rotated with double chains installed at each side of chamber Since width of V-bucket cover almost whole length of chamber and the buckets moves continuously, removing capacity of grit is high. Grits removed by V-buckets are transported by conveyors to hopper | A bucket, which is installed on a travelling crane, grabs grit in a chamber and carries them to the designated point. One grab bucket will move to whole area of grit chamber. Grits are transported by conveyors to hopper. | A screw conveyor is installed at a bottom of chamber and by a movement of screw, grits are collected to the end of chamber. Collected are transported to the designated point by sand pump. |
| 3. Comparison 3.1) Operation | Automatic operation can be applied. | All the movement such as lowering/lifting, traversing and travelling should be operated by a operator. | Automatic operation can be applied. |

TABLE 8.4 (2/2) COMPARISON OF GRIT REMOVAL TYPE

| Items | Rotary Bucket Conveyor Type | Grab Bucket Type | Screw Conveyor Type with Sand Pump |
|--|--|--|---|
| 3.2) Maintenance | When chains are damaged, a chamber should be dewatered. Maintenance can be done on a floor. | Since all mechanical parts are equipped above water, maintenance can be done on a floor. maintenance can be done on a | When screw conveyor, gearbox, etc. are damaged, a chamber should be dewatered. |
| 3.3) Consumables | Shoe, chain, etc. need to be replaced periodically. | Only bearings of motors need to be replaced after their design life. | Seal, submerged bearing, etc. needed to be replaced periodically. |
| 3.4) Grit removing capacity | High | Low | High |
| 3.5) Safety when large amount of grit flowing into chamber | Scraper and chains are embedded in a sand. | Safety since all mechanical parts are equipped above water. | Screw and gearbox are embedded in a sand. |
| 3.6) Height of building | 6m | 11m | 2 to 3m |
| 3.7) Depth of chamber | 4.4m | 4.4m | 7m |
| 3.8) Length of chamber | 19.5m | 19.5m | Since length of screw is limited up to 7 to 9m, in case screw conveyor is applied for 19.5m, two (2) screws for each chamber are required to install. |
| 3.9) Equipment Cost (Million VND) | | | |
| Total cost of Phase 1&2 including conveyor system and hopper | 23,120 172% | 13,477 100% | 26,422 196% |

TABLE 8.5(1/2) MAJOR MECHANICAL EQUIPMENT LIST


| Item | No. | Name | Model | Specification | 1st | 2nd | Total | Remarks |
|-----------------|-----|------------------------------|--------------------------------|--|-----|-----|-------|-----------------------------|
| 1. Pump Well | 1 | Inlet gate | Cast iron made sluice gate | 1500mm W x 1500mm H | 2 | 2 | 4 | |
| | 2 | Fine screen | Rotary front raking type | 3500mm W x 6400mm H | 1 | 3 | 4 | |
| | | Bar screen | Hand raking type | 3500mm W x 6400mm H | 1 | 0 | 1 | Temporary use until phase 2 |
| | 3 | Horizontal conveyor | Belt type | 750mm W x 8000mm L | 1 | *1 | 1 | * 1 Extension of belt |
| | 4 | Garbage grinder | Vertical rotary type | 1.0m ³ /hr | 1 | - | 1 | |
| | 5 | Garbage washing equipment | Mixing type | 1.0m ³ /hr | 1 | - | 1 | |
| | 6 | Dehydrating equipment | Screw type | 1.0m ³ /hr | 1 | - | 1 | |
| | 7 | Inclined conveyor | Belt with fin | 1050mm W x 14850mm H | 1 | - | 1 | |
| | 8 | Hopper | Cut gate type | 7m ³ | 1 | - | 1 | |
| | 9 | Stop log guide frame | Steel made | 3500mm W x 8000mm H | 2 | 2 | 4 | With one (1) stop log |
| | | | | | | | | |
| | 1 | Main sewage pump | Vertical shaft mixed flow pump | 700mm dia. x 667m ³ /m x 14.5m | 3 | - | 3 | |
| | | | with volute casing | 1000mm dia. x 122.1m ³ /m x 14m | - | 3 | 3 | |
| | 2 | Motor for Item 1 | Wound rotor induction | AC3.3kV x 50Hz x 230kw | 3 | - | 3 | |
| | | | | AC3.3kV x 50Hz x 460kw | - | 3 | 3 | |
| | 3 | Suction valve | Cast iron made butterfly valve | 700mm dia. x PN6 | 3 | - | 3 | |
| | | | | 1000mm dia. x PN6 | - | 3 | 3 | |
| | 4 | Non-return valve | Cast iron made swing type | 700mm dia. x PN10 | 3 | - | 3 | |
| 2. Pump Room | | | | 1000mm dia. x PN10 | - | 3 | 3 | |
| | 5 | Discharge valve | Cast iron made butterfly valve | 700mm dia. x PN10 | 3 | - | 3 | |
| | | | | 1000mm dia. x PN10 | - | 3 | 3 | |
| | 6 | Pipework | Ductile cast iron | 700mm dia. x PN7.5 | 3 | - | 3 | |
| | | | | 1000mm dia. x PN7.5 | - | 3 | 3 | |
| | 7 | Overhead crane | Crab type | 10ton | 1 | - | 1 | |
| | 8 | Drain pump | Submersible pump | 50mm dia. | 2 | - | 2 | |
| | | | | | | | | |
| | | | | | | | | |
| 3. Grit Chamber | 1 | Inlet gate for grit chamber | Cast iron made sluice gate | 1500mm W x 1500mm H | 2 | 2 | 4 | |
| | 2 | Grit removal equipment | Grab bucket type | 5000mm W x 19500mm L | 1 | - | 1 | |
| | 3 | Horizontal/inclined conveyor | Trough type | 600mm W x 17500mm L | 1 | - | 1 | |
| | 4 | Hopper | Cut gate type | 3.5m ³ | 1 | - | 1 | |
| | 5 | Outlet gate for grit chamber | Cast iron made sluice gate | 1500mm W x 1500mm H | 2 | 2 | 4 | |


TABLE 8.5(2/2) MAJOR ELECTRICAL EQUIPMENT LIST

| Item | No. | Name | Model | Spec | 1st | 2nd | Total | Remarks |
|-------------------------|-----|---------------------------------|---------|--------------------------|-----|-----|-------|---------|
| 1. Electrical Equipment | 1 | H.V. Incoming | Outdoor | AC22kV x 50Hz | 1 | - | 1 | |
| | 2 | Transformer | Outdoor | AC22kV/AC3kV x 2000kVA | 1 | - | 1 | |
| | 3 | Battery charger panel | | DC | 1 | - | 1 | |
| | 4 | 3.3kV Incoming panel | | AC3.3kV x 50Hz | 1 | - | 1 | |
| | 5 | Sewage pump panel | | AC3.3V x 50Hz x 230kw | 3 | - | 3 | |
| | | | | AC3.3V x 50Hz x 460kw | - | 3 | 3 | |
| | 6 | Aux. transformer panel | | AC3.3kV/380V x 500kVA | 1 | 0 | 1 | |
| | 7 | L.V. switchboard | | AC380V x 50Hz | 1 | 0 | 1 | |
| | 8 | Motor control center | | AC380V x 50Hz | 12 | 4 | 16 | |
| | 9 | Aux. relay panel (pump) | | AC380V x 50Hz | 2 | 2 | 4 | |
| | 10 | Aux. relay panel (grit chamber) | | AC380V x 50Hz | 2 | 0 | 2 | |
| | 11 | Aux. relay panel (pump well) | | AC380V x 50Hz | 2 | 2 | 4 | |
| | 12 | Instrument panel | | | 2 | 0 | 2 | |
| | 13 | Local panel | | AC380V x 50Hz | 1 | 1 | 2 | |
| | 14 | Stand-by generating unit | | AC3.3kV x 50Hz x 300kVA | 1 | 0 | 1 | |
| | | | | AC3.3kV x 50Hz x 1100kVA | 0 | 1 | 1 | |
| | 15 | Supervisory panel | | | 1 | 0 | 1 | |
| | 16 | Cable | | | 1 | 1 | 2 | |
| | | | | | | | | |


TABLE 8.6 BILL OF QUANTITIES FOR INTERMEDIATE WASTEWATER PUMPING STATION

| Item | Unit | Quantities | Remark |
|---|----------------|------------|---------------------------------|
| 1. Earth Work | | | |
| (1) Sheathing | m ² | 3,520 | Steel Sheet Pile |
| (2) Excavation | m ³ | 27,464 | |
| (3) Backfill | m ³ | 8,592 | |
| (4) Surplus Soil | m ³ | 18,872 | |
| (5) Filling | m ³ | 14,268 | Sand |
| 2. Foundation Work | | | |
| (1) RC Pile (400x400x20) | nos. | 321 | |
| (2) Sand Mat (t=20 cm) | m ³ | 340 | |
| 3. Concrete Work | | | |
| (1) Leveling Concrete (180 kg/cm ²) | m ³ | 170 | t=10cm |
| (2) Reinforced Concrete (210 kg/cm ²) | m ³ | 4,800 | Concrete Volume |
| 4. O/M Office | | | |
| (1) Building (Rainforced Concrete) | m ² | 2,551 | |
| (2) Gard Fence (Steel Net, H=2.4 m) | m | 357 | Road side 120m, Other side 237m |
| 5. O/M Road | | | |
| (1) Road Construction (Grade V) | m ² | 1,680 | |
| (2) Landscaping(Planting) | m ² | 1,990 | |





1 F PLAN VIEW



SECTION A-A

FIG. 8.2 COMPARISON STUDY ON INTERMEDIATE WASTEWATER PUMPING STATION
(OPTION A - PROPOSED)





FIG. 8.3 COMPARISON STUDY ON INTERMEDIATE WASTEWATER PUMPING STATION (OPTION B)

SCALE 1:450



1 F PLAN VIEW

FIG. 8.5(1/3) PRELIMINARY DRAWING OF INTERMEDIATE WASTEWATER PUMPING STATION

FIG. 8.5(2/3) PRELIMINARY DRAWING OF INTERMEDIATE WASTEWATER PUMPING STATION



B I F PLAN VIEW

SCALE 1:450





FIG. 8.5(3/3) PRELIMINARY DRAWING OF INTERMEDIATE WASTEWATER PUMPING STATION

PROPOSED LANDSCAPE SCHEMATIC PLAN FOR INTERMEDIATE WASTEWATER PUMPING STATION




FIG. 8.6 LANDSCAPE PLAN FOR THE INTERMEDIATE WASTEWATER PUMPING STATION SITE