



7.1.4

Distribution Tank


Distribution Tank Structure Calculation



SECTION 1-1



SECTION 2-2




1. Section 1-1 Calculation

Calculate by 2 side fixed type

Calculation point is $\frac{1}{2} \times L$ ($L = 4.30^m$, $\frac{L}{2} \div 2.00^m$) upper point from bottom.

Lower side from this point is 3 sides fixed type, so stress is less than this point.

$$P_w(\text{water pressure}) = 7.45 + 3.10 - 2.00 = 8.55 \text{ t/m}^2$$



$$M_{(\text{end})} = \frac{8.55 \times 4.80^2}{12} = 16.42 \text{ t.m}$$

$$M_{(\text{center})} = \frac{8.55 \times 4.80^2}{24} = 8.21 \text{ t.m}$$

$$\text{Shearing force} = \frac{8.55 \times 4.80}{2} = 20.52 \text{ t}$$

Necessary Reinforcement


$$A_s_{(\text{end})} = \frac{16.42 \times 10^5}{1600 \times 0.9 \times 43} = 26.52 \text{ cm}^2$$

$$D25 @ 125 \quad A_s = 39.27 \text{ cm}^2$$

$$A_s_{(\text{center})} = \frac{8.21 \times 10^5}{1600 \times 0.9 \times 43} = 13.26 \text{ cm}^2$$

$$D18 @ 125 \quad A_s = 20.36 \text{ cm}^2$$

Shearing Stress



$$\tau = \frac{14.96 \times 10^3}{100 \times 43} = 3.5 \text{ kg/cm}^2 < 3.6 \text{ kg/cm}^2 \quad \text{O.K.}$$

2. Section 2-2 Calculation

$$P_w = 7.45 - 3.00 = 4.45 \text{ t/m}^2$$

$$M_{\text{(end)}} = \frac{4.45 \times 4.80^2}{12} = 8.54 \text{ t.m}$$

$$M_{\text{(center)}} = \frac{4.45 \times 4.80^2}{24} = 4.27 \text{ t.m}$$

$$S = \frac{4.45 \times 4.80}{2} = 10.68 \text{ t}$$


Necessary Reinforcement

$$A_s_{\text{(end)}} = \frac{8.54 \times 10^5}{1600 \times 0.9 \times 43} = 13.8 \text{ cm}^2$$

$$D16 @ 125 \quad A_s = 16.08 \text{ cm}^2$$

$$A_s_{\text{(center)}} = \frac{4.27 \times 10^5}{1600 \times 0.9 \times 43} = 6.9 \text{ cm}^2$$

$$D12 @ 125 \quad A_s = 9.05 \text{ cm}^2$$



$$\tau = \frac{8.46 \times 10^3}{100 \times 43} = 2.0 \text{ kg/cm}^2 < 3.6 \text{ kg/cm}^2 \quad \text{O.K.}$$

7.1.5

Disinfection Tank

CALCULATION FOR WATER TREATMENT PLANT STRUCTURES**DISINFECTION TANK**

(The calculation based on Japanese standard)

1-GEOMETRY DIMENSIONS FOR CALCULATION

(As shown on drawings attached):

Ground level: GL = 2.20

Bottom level of disinfection tank: BL = -2.23

Water level of disinfection tank: 3.27

Thickness of final sedimentation tank 0.70 m

*And all other dimensions shown on the drawing attached***2-PARAMETERS FOR CALCULATION:**Concrete: Grade C21, $R_n = 70$ (Kg/cm²) $R_s = 3.6$ (Kg/cm²)Reinforcement type All: $R_a = 1600$ (Kg/cm²)Back fill sand: $\gamma_s = 1.80$ T/m³ ; Coefficient of earth pressure at 0.5

Internal friction 20deg

3-LOAD CALCULATION (BASE ON JAPANESE STANDARD):**3.1-Water load**

According to highest water level and bottom level as illustrated in the drawing, water loads to be calculated and shown on the attached drawing.

3.2-Live load:-Live load for all operating floor and walking way : $q_{live} = 0.50$ T/m²

-Horizontal uniform load due to surcharge load on ground surface:


$$p_{h-surc} = 0.50 \text{ T/m}^2 \times K_o = 0.25 \text{ T/m}^2$$

4-ANALYSING BY SAP 2000: THERE ARE 3 COMBOS FOR ANALYSING AS ATTACHED HEREAFTER:


ALL THE LOADS, FACTORS, AND OTHER INPUT DATUM TO BE TAKEN IN ANALYSIS AND CALCULATED BY SAP 20

According to combo UPLIFT, the disinfection tank can not be uplifted.

DISINFECTION TANK



NOTE: THIS FOR VALUES OF LOADS ONLY.
COMBOS ARE TO BE CONSIDERED IN
ANALYSIS BY SAP 2000



LOAD COMBINATION MULTIPLIERS

COMBO	TYPE	CASE	FACTOR	TYPE	TITLE
COMB1	ADD				Bypass water way full of water, Disinfection tank empty
	BYPASSWA	1.0000	STATIC(OTHER)		
	SOIL	1.0000	STATIC(OTHER)		
	SURCHARG	1.0000	STATIC(LIVE)		
	SELF	1.0000	STATIC(DEAD)		
	CINDERCO	1.0000	STATIC(DEAD)		
COMB2	ADD				Disinfection tank full of water, Bypass water way empty
	WATER	1.0000	STATIC(OTHER)		
	SOIL	1.0000	STATIC(OTHER)		
	SURCHARG	1.0000	STATIC(LIVE)		
	SELF	1.0000	STATIC(DEAD)		
	CINDERCO	1.0000	STATIC(DEAD)		
COMB3	ADD				all tank full of water
	WATER	1.0000	STATIC(OTHER)		
	SOIL	1.0000	STATIC(OTHER)		
	SURCHARG	1.0000	STATIC(LIVE)		
	SELF	1.0000	STATIC(DEAD)		
	CINDERCO	1.0000	STATIC(DEAD)		
	BYPASSWA	1.0000	STATIC(OTHER)		
ENVE	ENVE				MAX MIN OF ALL COMBOS FOR CALCULATING BAR ARRANGEMENT
	COMB1	1.0000	COMBO		
	COMB2	1.0000	COMBO		
	COMB3	1.0000	COMBO		

5-CALCULATION FOR BAR ARRANGEMENT:

Base on attached results of shell forces analised by SAP2000, choosing the most dangerous forces for calculation:

$$A_o = M / R_n b h_o^2 \quad \text{Where: } M: \text{Maximum bending moment(T.m)}$$

$$h_o: \text{Effective depth of bearing area(cm)}$$

$$h_o = (\text{Element thickness} - \text{Cover thickness})$$

$$b: \text{Width of calculated area(cm)}$$

Required area of reinforcement:

$$F_a = M / \gamma R_n b h_o \quad \text{Where: } \gamma = 0.5 + ((1 - 2A_o)^{1/2}) / 2$$

5-1 SLABS AND WALLS:

Moments	Values (T.m)	A _o	γ	F _a (cm ²)	Bar arrangement		Remarks
					φ(mm)	a(mm)	
(Bottom	21.150	0.0898	0.953	23.92	24	150	125
Slab level	13.400	0.0482	0.975	14.81	24	250	
-2.23)	-20.220	0.0728	0.962	20.85	20	125	
0.7	-5.600	0.0202	0.990	5.61	20	250	

Moments	Values (T.m)	A _o	γ	F _s (cm ²)	Bar arrangement		Remarks
					ϕ (mm)	a(mm)	
Outside wall	20.200	0.1561	0.915	32.10	24	125	<i>not in dwg</i>
(longitudinal wall)	-21.250	0.1642	0.910	33.95	24	125	
	-8.700	0.0672	0.965	13.10	16	125	
0.5	13.600	0.1051	0.944	20.93	20	125	
Wall of bypass	10.700	0.0827	0.957	16.25	18	125	<i>125</i>
	-5.500	0.0425	0.978	8.17	14	150	
Water way	6.400	0.0494	0.975	9.54	14	125	
0.5	-7.600	0.0587	0.970	11.39	14	125	
Partition Wall	19.500	0.1507	0.918	30.88	24	125	
	11.600	0.0896	0.953	17.69	18	125	
	-18.900	0.1460	0.921	29.84	22	125	
0.5	-11.420	0.0882	0.954	17.40	18	125	
Temporary Wall	-14.800	0.1143	0.939	22.91	20	125	<i>not in dwg</i>
	10.600	0.0819	0.957	16.10	16	100	
	-10.500	0.0811	0.958	15.94	16	125	
0.5	11.100	0.0858	0.955	16.89	18	125	

6- CALCULATION FOR PILE QUANTITY (as attached sheets):

(Pile number to be decided by pile calculation sheet, please refer to pile calculation sheet for more information)

7- CHECKING UPLIFT IN CASE GROUND WATER LEVEL UPTO +2.2

SAP2000 v6.11 File: DISIN_PILE Ton-m Units PAGE 1

March 28, 2001 11:25

LOAD COMBINATION MULTIPLIERS

COMBO TYPE CASE FACTOR TYPE TITLE

UPLIFT ADD Checking uplift , when ground water level up to +2.2
 SELF 1.0000 STATIC(DEAD)
 CINDERCO 1.0000 STATIC(DEAD)
 UPLIFT 1.0000 STATIC(OTHER)

SAP2000 v6.11 File: DISIN_PILE Ton-m Units PAGE 2

March 28, 2001 11:25

JOINT REACTIONS

JOINT LOAD	F1	F2	F3	M1	M2	M3
11 UPLIFT	87.2393	82.1116	-272.8340	0.0000	0.0000	0.0000
29 UPLIFT	-100.3916	145.8210	-218.5379	0.0000	0.0000	0.0000
31 UPLIFT	-122.3266	-89.5038	93.7949	0.0000	0.0000	0.0000
32 UPLIFT	135.4789	-138.4288	88.5533	0.0000	0.0000	0.0000

Total uplift upto the bottom slab = -309.02 Ton

Tensile capacity of one pile as calculated is 20 ton (In case the pile be pulled up)

So the number of piles needed for preventing structure from uplifting is : 15.5 piles

, but as number of piles calculated and arranged on DWG No.: PE-254-01 is 144 piles for disinfection tank of phase 1, so uplift will never occur


BOTTOM SLAB LEVEL -2.23
(M₂₂ - ENVE COMBO Max)

+13.4


+10.92


+21.45

BOTTOM SLAB LEVEL -2.23
(M₂₂ - ENVE COMBO Min)










OUTSIDE WALL (Y=0)
(ENVE COMBO Max (M₁₁))


-3.5 0.0 3.5 7.0 10.5 14.0 17.5 21.0 24.5

456	639	432	461	462	463	464	465	466	467	468	469	470	471	472	473	474	114
455	626	427	451	452	453	457	458	459	460	461	462	463	464	465	466	467	21
710	734	719	722	725	728	731	734	737	740	743	746	749	752	755	758	761	252
714	717	728	723	726	729	732	735	738	741	744	747	750	753	756	759	762	256
715	718	721	724	727	730	733	736	739	742	745	748	751	754	757	760	763	257

OUTSIDE WALL (Y=0)
(ENVE COMBO Min (M₂₂))


-21.0 -17.5 -14.0 -10.5 -7.0 -3.5 0.0 3.5 7.0






OUTSIDE WALL OF BYPASS WATER WAY
(ENVE COMBO Min (M₂₂))


-21.0 -17.5 -14.0 -10.5 -7.0 -3.5 0.0 3.5 7.0





OUTSIDE WALL OF BYPASS WATER WAY (X=0)
(ENVE COMBO Min (M₁₁))


-10.5 -7.0 -3.5 0.0 3.5 7.0 10.5 14.0 17.5






DISINFECTION TANK PARTITION WALL (X=+5.5)
(ENVE COMBO Min (M₂₂))


-21.0 -17.5 -14.0 -10.5 -7.0 -3.5 0.0 3.5 7.0





DISINFECTION TANK PARTITION WALL (X=+5.5)
(ENVE COMBO Max (M₁₁))

-3.5 0.0 3.5 7.0 10.5 14.0 17.5 21.0 24.5










TEMPORARY WALL (X=+32.95)
(ENVE COMBO Max (M₁₁))



Disin_pile

SAP2000 v6.11 File: DISIN_PILE Ton-m Units PAGE 1
March 11, 2001 10:01

DISINFECTION TANK
REACTIONS FOR CALCULATING PILE QUANTITY

LOAD COMBINATION MULTIPLIERS


COMBO	TYPE	CASE	FACTOR	TYPE	TITLE
PILECOM	ADD	BYPASSWA	1.0000	STATIC(BEAD)	all tanks full of water
		WATER	1.0000	STATIC(BEAD)	
		SELF	1.0000	STATIC(BEAD)	
		CIMENCO	1.0000	STATIC(BEAD)	

SAP2000 v6.11 File: DISIN_PILE Ton-m Units PAGE 2
March 11, 2001 10:01

JOINT REACTIONS

JOINT	LOAD	P1	P2	P3	M1	M2	R3
11	PILECOM	-326.6234	-345.1300	1351.1139	0.0000	0.0000	0.0000
29	PILECOM	409.0375	-511.5520	1434.6942	0.0000	0.0000	0.0000
31	PILECOM	-1527.1966	775.6477	1775.3442	0.0000	0.0000	0.0000
32	PILECOM	1444.7045	1228.0893	<u>1745.1485</u>	0.0000	0.0000	0.0000

$$\Sigma = 6425.912$$



$$\text{Preaction} = \frac{6425.912}{34.5 \times 19.5} = 9.552 (\text{T/m}^2)$$

Pile capacity = 45 ton \Rightarrow one pile can be used for an area of 4.71m²

\Rightarrow R.C pile to be arranged as on drawing No. -PE - WWTP - 254 - 01