

7.5

Capacity of Facility

1. Basic Data and Condition

1.1. Design Period

Phase I = 2001 ~ 2005 (Modified Aeration Process)

Phase II = 2006 ~ 2010 (Modified Aeration Process)

Final Phase = 2011 ~ 2020 (Conventional Activated Sludge Process)

1.2. Sewer System

Combined Sewer System (Storm Water Discharged Overflow Chamber $Q_{maxH} \rightarrow$ Diversion Chamber)

1.3. Design Location (Sewer Development Area)

Tau Hu – Ben Nghe, Doi – Te Area (THBNDT Area) in Ho Chi Minh City.

1.4. Design Area (Service Area)

Phase I = 828.4 ha

Phase II = 828.4 + 1,963.2 = 2,791.6 ha

Final Phase = 2,791.6 ha

1.5. Design Population

Phase I = 425,830 persons in 2010 year, 2005 year = 432,076 persons

Phase II = 1,390,282 persons in 2020 year, 2010 year = 1,421,778 persons

Final Phase = 1,390,282 persons in 2020 year

1.6. Domestic Wastewater Flow

1997 year = 170 l/person-day

2000 year = 200 l/person-day

2005 year = 260 l/person-day. Design Wastewater Flow per capita

2010 year = 300 l/person-day (Phase I & Phase II)

2020 year = 335 l/person-day (Final Phase)

1.7. Diurnal Wastewater Flow

$Q_{aveD} = Q_{maxD}$

$Q_{maxH} = Q_{maxRH} = 1.4 * Q_{maxD}$ (Domestic Wastewater) + Groundwater

1.8. Design Wastewater Flow

Phase I: $Q_{\max D} (= Q_{\text{ave}D}) = 141,000 \text{ m}^3/\text{day}$

$$\begin{aligned} Q_{\max H} (= Q_{\max RH}) &= 1.4 * Q_{\max D} + \text{Groundwater} \\ &= 192,000 \text{ m}^3/\text{day} \end{aligned}$$

Phase II : $Q_{\max D} (= Q_{\text{ave}D}) = 469,000 \text{ m}^3/\text{day}$

$$\begin{aligned} Q_{\max H} (= Q_{\max RH}) &= 1.4 * Q_{\max D} + \text{Groundwater} \\ &= 640,000 \text{ m}^3/\text{day} \end{aligned}$$

Final Phase: $Q_{\max D} (= Q_{\text{ave}D}) = 512,000 \text{ m}^3/\text{day}$

$$\begin{aligned} Q_{\max H} (= Q_{\max RH}) &= 1.4 * Q_{\max D} + \text{Groundwater} \\ &= 699,000 \text{ m}^3/\text{day} \end{aligned}$$

□ Ground Water Flow = 10% of Domestic Wastewater ($Q_{\max D}$)

1.9. Formula Wastewater Flow Calculation

Manning's Formula

$n = 0.013$ (HP) – 0.010 (SP, DCIP, VP, etc)

1.10. Design Wastewater Characteristics (Pollutant Load)

$\text{BOD} = 60 \text{ g/person-day} * 1,390,282 \text{ persons} \div 512,000 \text{ m}^3/\text{day} = 162.9 \text{ mg/l} \rightarrow 163 \text{ mg/l}$

$\text{SS} = 60 \text{ g/person-day} * 1,390,282 \text{ persons} \div 512,000 \text{ m}^3/\text{day} = 162.9 \text{ mg/l} \rightarrow 163 \text{ mg/l}$

1.11. Design Wastewater Characteristics For WWTP

Refer to “Mass Balance” Calculation. Result from the Mass Balance Calculation take side streams into consideration and decide:

$\text{BOD} = 163 * 1.20 = 196 \rightarrow 200 \text{ mg/l}$

$\text{SS} = 163 * 1.30 = 212 \rightarrow 210 \text{ mg/l}$

1.12. Design Effluent Quality (VIETNAMESE STANDARD TCXD 188 – 1996)

| | | |
|--------------|---------------------|---|
| Phase I: | BOD = 50 mg/l below | □ TCXD 188 – 1996: Urban Wastewater Standard For Discharge |
| | SS = 100 mg/l below | |
| Phase II: | BOD = 50 mg/l below | □ Phase I = Limitation values “B” Phase II = Limitation values “B” |
| | SS = 100 mg/l below | |
| Final Phase: | BOD = 20 mg/l below | Final Phase = Limitation values “A” |
| | SS = 50 mg/l below | |

1.13. Design WWTP Removal Efficiency (Considering Recycle Water Loading)

| Item | Designed Water Quality (mg/l) | | Removal Efficiency (%) | | | Remarks |
|------|-------------------------------|----------|------------------------|----------------------|--------|--|
| | Influent | Effluent | Primary Sed. Tank | AT + Final Sed. Tank | Total | |
| BOD | 200 | 20 | 40 | 83.3 | 90.0 | Total Removal Efficiency = 90~95% possibly |
| | (200) | (50) | (30) | (64.3) | (75.0) | Total Removal Efficiency = About 70% |
| SS | 210 | 30 | 50 | 71.4 | 85.7 | Total Removal Efficiency = 90~95% possibly |
| | (210) | (60) | (35) | (56) | (71.4) | - |

Aeration Tank Water Quality: BOD = 120 mg/l (140 mg/l)

SS = 105 mg/l (137 mg/l)

() shows Phase I & II

1.14. Wastewater Treatment System and Necessary Train

| | | |
|--------------|---|-------------|
| Phase I: | Modified Aeration Process | (1/8 train) |
| Phase II: | Modified Aeration Process | (4/8 train) |
| Final Phase: | Conventional Activated Sludge Process (for AO System, take Step Aeration System together) | (8/8 train) |

1.15. Sludge Treatment System

"Separate Thickening ~ Sludge Storage ~ Dewatering ~ Composting"

* Separate Thickening : Raw Sludge = Gravity Thickener

Excess Sludge = Centrifugal Thickener

* Sludge Storage Tank : Mechanical Mixing

* Dewatering : Centrifugal Dewatering

1.16. Excess Sludge Final Disposal System

Disposal of WWTP by sanitary landfill

* Composting, screenings, scum, grit etc...

1.17. Inlet Pipes

(Phase I): \square $1,300^W * 1,200^H * 0.5\text{‰} * 2\text{Box}$, BL = - 3.314 m (L.P.S. Point)

(Phase II): \square $2,000^W * 1,700^H * 0.4\text{‰} * 2\text{Box}$, BL = - 3.890 m (L.P.S. Point)

\square Lift Pumping Station BL = - 3.890 - 0.300 + α = - 4.200 m

1.18. WWTP Ground Level

Present GL \square + 0.600 m

Design GL = + 2.200 m (About 1.6 m banking)

1.19. Condition at Outlet Point

Outlet Point: "Tac Ben Ro Canal" (Tidal River)

HWL = + 1.650 m (100 Year Probability, Nha Be Point)

LWL = - 2.690 m (" ")

1.20. WWTP Inlet Fluctuation

Actual Result of Water Supply Following

1.21. WWTP Inlet Water Increase

Refer to "Inlet Wastewater Increase"

1.22 Initial Consideration

- (1) Installation of Bypass Waterway
(Primary Sedimentation Tank, Aeration Tank, Final Sedimentation Tank, Disinfection Tank, Design to Bypass Waterway all Water Establishment)
- (2) Division of Aeration Tank (devices into 4 = 1 : 1.5 : 1.5 : 2.25)
- (3) Set up Step Waterway for Step Aeration System
- (4) Extension of each Tank (including Disinfection Tank)
- (5) Subdivision of Gravity Thickener. Total 2 tanks → change to 4 tanks

1.23. Characteristic of Inlet Pipes / Flow, Velocity, Water Depth, Water Level

| Phase | Flow Category | Flow (m ³ /sec) | Velocity (m/sec) | Water Depth (m) | Water Level (m) |
|----------|-------------------|----------------------------|------------------|-----------------|-----------------|
| Phase I | Q _{maxD} | 1.632 | 0.848 | 0.740 | -3.460 |
| | Q _{maxH} | 2.222 | 0.909 | 0.940 | -3.260 |
| Phase II | Q _{maxD} | 4.294 | 0.994 | 1.080 | -3.120 |
| | Q _{maxH} | 5.868 | 1.068 | 1.373 | -2.827 |

□ Lift Pumping Station Inflow Bottom Level = - 4.200m

□ Inlet Pipes :

(Phase I): □ $1,300^W + 1,200^H + 0.5\text{‰} + 2\text{Box}$, BL = - 3.314 m (L.P.S. Point)

(Phase II): □ $2,000^W + 1,700^H + 0.4\text{‰} + 2\text{Box}$, BL = - 3.890 m (L.P.S. Point)

1.24. Sludge Density (Conventional Activated Sludge Process)

- (1) Raw Sludge (Primary Sedimentation Tank Sludge) = 2.0 ~ 4.0 → 2.0%
- (2) Excess Sludge (Final Sedimentation Tank Sludge) = 0.5 ~ 1.0% → 0.6%
- (3) Density of Return Sludge = 3,000 ~ 6,000mg/l
- (4) Combined Sludge = 1.0% (Raw Sludge + Excess Sludge)
- (5) Gravity Thickened Sludge (Combined Sludge) = 2.5%
- (6) " (Raw Sludge) = 3.0%
- (7) Centrifugal Thickening Sludge = 4.0%
- (8) Dewatering Sludge = 20 ~ 22% → 20% (Centrifugal Dewatering)
- (9) Compost Sludge = 30 ~ 40% (No Additive)
= 40 ~ 50% (Additive)

1.25. Solids Capture Rate (SS)

- (1) Gravity Thickening (Combined Sludge) = 80 ~ 90%
- (2) " (Raw Sludge) = 80 ~ 90%
- (3) Centrifugal Thickening = 85 ~ 95%
- (4) Floatation Thickening = 85 ~ 95%
- (5) Dewatering Sludge (Centrifugal, Beltpress, Filter Press) = 90 ~ 95%

1.26. Sludge Generated Rate (Removed SS)

- (1) Conventional Process = 100%
- (2) Batch Process (High Loading) = 100%
- (3) Batch Process (Low Loading) = 75%
- (4) OD Process = 75%
- (5) Long Time Aeration Process = 75%
- (6) Rotating Contractor Process = 92%

1.27. Design Amount of Sludge Production (Solid Amount = t/day): Dry Base

$Q_{\max D} \text{ (m}^3\text{/day)} * \text{Inlet SS Density (mg/l)} * 10^{-6} *$

$\text{Total WWTP SS Removal Rate (\%)} * 10^{-2} *$

$\text{Sludge Generation Rate SS per Removed Sludge (\%)} * 10^{-2}.$

1.28. Design Amount of Sludge Production (m³/day): Wet Base

$\text{Design Amount Sludge Production (t/day)} *$

$100 / \text{Density of Sludge (\%)} \div \text{Specific Gravity (t/m}^3\text{)}$

(Note): In general, Gravity Rate of wet base sludge is 1.0 t/m³ (Dewatering Cake, Composting Sludge is shown considering a part).

2. Recycle Flow Loading (WWTP Design Inflow Water Quality – Design Influent Quality)

There is a case that SS load of wastewater quality (influent) reaches over 100% depending on the operation (condition). But the operation works is fine, SS load of recycle flow will be kept around 20 ~ 40%. Also BOD load of recycle flow is generally below 20% (Maintenance management guideline in Japanese Standard).

2.1. Mass Balance Calculation

(1) SS Solids Recovery (Solids Capture Rate)

- ① Gravity Thickening Sludge (Raw Sludge) = 80 ~ 90%
- ② Centrifugal Thickening Sludge (Excess Sludge) = 85 ~ 95%
- ③ Sludge Dewatering (Centrifugal Dewatering) = 90 ~ 95%
- ④ Additive Rate of Polymer = 1.0%

(2) Mass Balance Calculation

$$D = 85 - (X_1 \cdot r_1) + r_2$$

D: Design Sludge Production

R: Solids in Recycle Flow

X_1 : Inlet Solids at Thickener (Gravity and Centrifugal Thickener)

X_3 : Inlet Solids at Dewatering Facility

X_4 : Dewatering Cake

r_1 : SS Recovery Rate of Thickener = 80 ~ 95% (Gravity and Centrifugal Thickener)

r_3 : SS Recovery Rate of Dewatering Facility = 90 ~ 95%

r_2 : Additive Rate of Polymer = 1.0%

(Note)

Calculate the Sludge Production of each facilities at the case of Inlet Solid = 100, Design Sludge Production (D) = 85, and take the mass balance of all WWTP then confirm the loading rate of recycle flows.

Loading rate to design a WWTP facilities is calculated by the following equation:

Design WWTP Inlet Water Quality = WWTP Inlet Water Quality + Recycle Water Load (* WWTP Inlet Water Quality = Pollutant Loading / Design Wastewater)

(3) Case Study (Mass Balance)

[1] Case 1: (Lower Collection Rate)

$$r_1 = 80\%, r_3 = 90\%, r_2 = 1.0\%$$

$$X_1 = D * 1/[r_1 * (r_3 + r_2)] = 85 * 1/[0.80 * (0.90 + 0.01)] = 116.8 \rightarrow 117$$

$$X_3 = X_1 * r_1 = 117 * 0.80 = 93.6 \rightarrow 94$$

$$X_4 = X_3 * r_3 = 94 * 0.90 = 84.6 \rightarrow 85$$

[2] Case 2: (Higher Collection Rate)

$$r_1 = 95\%, r_3 = 95\%, r_2 = 1.0\%$$


$$X_1 = D * 1/[r_1 * (r_3 + r_2)] = 85 * 1/[0.95 * (0.95 + 0.01)] = 93.2 \rightarrow 93$$

$$X_3 = X_1 * r_1 = 93 * 0.95 = 88.4 \rightarrow 88$$

$$X_4 = X_3 * r_3 = 88 * 0.95 = 83.6 \rightarrow 84$$

(4) Mass Balance Calculation Result of WWTP (Final Phase)

(Primary Sedimentation SS Removal Rate = 50%)



(Legend)

Upstream = Case 1. (Lower)


Downstream = Case 2. (Higher)

□ Thickening = Gravity + Centrifugal Thickener

□ Dewatering = Centrifugal Dewatering

(5) Mass Balance Calculation Result of WWTP (Phase I, II)

(Primary Sedimentation SS Removal Rate = 35%)



(Legend)

Upperstreams = Case 1. (Lower)

Downstreams = Case 2. (Higher)

□Thickening = Gravity + Centrifugal Thickener

□Dewatering = Centrifugal Dewatering

2.2. WWTP Design Influent Water Quality Determination

(1) Consideration

It is difficult decided SS capture rate, sludge density, density of Separate Water, because there are many factors such as wastewater treatment flow, operating condition, influent character, character area etc ...

[1] The density of total solids of Separate Water is desirable less than 1,000 mg/l. It is necessary to keep less than 5,000 mg/l in the worst case.

[2] Return Pollutant Load is generally described below:

In case of good operation, SS loading recycle flow generally 20 ~ 40%, sometimes it reaches 100%. BOD Loading Recycle Flow is generally below 20% (Design Criteria).

(2) WWTP Design Influent Quality

[1] Calculation Result of Mass Balance (SS Return Load)

$$9 \sim 32\% \rightarrow 30\%$$

[2] Return Load

Recycle Flow Rate, result of mass balance calculation is decided as below:

SS Recycle Rate = 30%

BOD Recycle Rate = 20%

[3] WWTP Design Influent Quality

$$\text{BOD} = 163 * 1.20 = 196 \rightarrow 200 \text{ mg/l}$$

$$\text{SS} = 163 * 1.30 = 212 \rightarrow 210 \text{ mg/l}$$

3. Design Criteria for Main Facilities

3.1 Primary Sedimentation Tank

| Item | Conventional Activated Sludge System | Modified Aeration System |
|--------------------------------|--|---|
| Surface Loading | 50 m ³ /m ² -day | 100 m ³ /m ² -day About |
| Effective Depth | 3.0 m | Same Left |
| Overflow Weir Loading | 250 m ³ /m-day | 500 m ³ /m ² -day About |
| Length : Width Ratio | 3:1~5:1 | Same Left |
| Width of Tank | 2.5 ~ 5.0m (@0.5 m) | Same Left |
| Bottom Slope of Tank | 1/100 ~ 2/100 | Same Left |
| BOD Removal Efficiency | 40% | 30% |
| SS Removal Efficiency | 50% | 35% |
| COD Removal Efficiency | 30 ~ 50% (Other reference) | - |
| Bypass Waterway | Establish | Same Left |
| Length of Sludge Collector | Up to about 40 m | Same Left |
| Slope of Hopper | 60° over | Same Left |
| Baffle Wall Opening Efficiency | 15% Above | Same Left |
| Baffle Plate | Install | Same Left |
| Freeboard | 50 cm About (Beam to clear Tank) | Same Left |
| Diameter of Sludge Pipe | 150 mm Above | Same Left |

□ Load for Modified Aeration System = Result of "Pilot Plant Experiment Work".

3.2. Aeration Tank (Conventional Activated Sludge Process)

HRT = 6.0 hr (Step Aeration Process = 4.0 ~ 6.0 hr)

MLSS = 1,500 ~ 2,000 mg/l (Step Aeration Process = 1,000 ~ 1,500 mg/l)

Return Sludge Ratio = 50 ~ 100% (Normal ~ Maximum)

☐ Return Sludge Pump = No stand by Pump

Effective Depth = 5.5 m

Density of Return Sludge = 3,000 ~ 6,000 mg/l

BOD-SS Loading = 0.2 ~ 0.4 kg-BOD/kg-SS-day

ASRT = 3 ~ 6 days, SRT \geq 4 day, $S_a \geq$ 3 day

Width Waterway = Water Depth 1 ~ 2 times with in

Freeboard = 80 cm about (Beam to clear Tank)

Bypass Waterway = Establish

Division of Tank = 4 Division (1 : 1.5 : 1.5 : 2.25)

Baffle Wall opening efficiency: Part enter bottom = $1.0^{(W)}m * 1.0^{(H)}m * 1 \text{ Place/Wall}$

Upper part overside bottom = $0.5^{(W)}m * 0.3^{(H)}m * 2 \text{ Place/Wall}$

* Opening way for water flow

1 Scale Tank = 2,500 ~ 7,500 m³/day-tank

Operation process: 0 = Aerobic zone, A = Anaerobic zone or No Air zone (Only mixing)

(1) Operation with Regular Conventional Activated Sludge Process = 0 + 0 + 0 + 0

(2) Operation with Controlling Filamentous Bulking = A + 0 + 0 + 0 or A + 0 + A + 0

☐ Operation with Controlling Nitrification Reaction N-BOD increase in treated water.

(3) Operation along Energy = A + 0 + 0 + 0 or A + 0 + A + 0

(4) Beginning of operation, Loading operation

3.3. Aeration Tank (Modified Aeration Process)

BOD-SS Loading = 1.5 ~ 3.0 kg-BOD/kg-SS-day (4.0 kg-BOD/kg-SS-day below)

BOD Volume Loading = 0.6 ~ 2.4 kg/m³-day

MLSS = 400 ~ 800 mg/l

Sludge Age = 0.3 ~ 0.5 day

Air Feeding = 2 ~ 4 Time of Wastewater Volume

HRT = 1.5 ~ 2.5 hr

Return Sludge Ratio = 5 ~ 10%

SVI = 50 About

BOD Removal Rate = 70% About

Excess Sludge Production Rate = 1 ~ 2 % About

☐ (BOD-SS Loading) = Result of "Pilot Plant Experiment Work".

3.4. Final Sedimentation Tank

| Item | Conventional Activated Sludge System | Modified Aeration System |
|--------------------------------|--|---|
| Surface Loading | 25 m ³ /m ² -day [After revise of temperature] | 58 m ³ /m ² -day below |
| Effective Depth | 3.5 m | Same Left |
| Overflow Weir Loading | 120 m ³ /m-day | 240 m ³ /m ² -day About |
| Sludge Hopper | QmaxD * 30 min. | Same Left |
| Length : Width Ratio | 3:1 ~ 5:1 | Same Left |
| Bottom Slope of Tank | 1/100 ~ 2/100 | Same Left |
| Slope Hopper | 60° over | Same Left |
| Baffle Wall opening efficiency | 15% Above | Same Left |
| Bypass Waterway | Establish | Same Left |
| Freeboard | 50 cm About (Beam to clear Tank) | Same Left |
| Baffle Plate | Install | Same Left |
| Diameter of Sludge Pipe | 150 mm Above | Same Left |

□ Load for Modified Aeration System = Result of "Pilot Plant Experiment Work".

3.5. Disinfection Tank

| Item | Conventional Activated Sludge System | Modified Aeration System |
|--------------------------|---|--------------------------|
| Contact Time | More than 15 minute (QmaxRH to consider) | Same Left |
| In Tank Average Velocity | Velocity at with Sludge does not settlement | Same Left |
| Freeboard | 50 cm About (Beam to clear Tank) | Same Left |

3.6. Gravity Thickener (For Raw Sludge)

Solid Surface Loading = 90 kg/m²-day
 Effective Depth = 4.0 m About
 Density of Thickened Sludge = 2.0 ~ 4.0% → 3.0%
 Dimension Thickener = Cycle (Standard)
 Bottom Slope = 5/100 Above
 Diameter of Sludge Pipe = 150 mm Above
 Diameter for Sludge Pump = 80 mm Above

3.7. Centrifugal Thickener (For Excess Sludge)

Density of Thickened Sludge = 4.0 %
 Operation Time = 24 hours continuous operation, with stand by.

3.8. Sludge Dewatering (Centrifugal Dewatering Method)

Density of Cake = 18 ~ 25% → 20% (Centrifuge)
 Operation Time = 24 hours continuous operation, with stand by.

3.9. Sludge Composting Facilities

For market product = During composting material has to be kept at a temperature over 65C for 2 days.

Composting Period = 10 ~ 14 days (Standard)

☐ If not stabilized material should be cured without any Mechanical Aeration for another = 30 ~ 60 days (Natural Aeration), and = 20 ~ 30 days (Mechanical Drying)

High of Storing Compost at Composting Tank = Less than 3.0 m (Standard)

= Less than 5.5 m (Additive)

Air = 10 ~ 20 Ne/min-m³ (Standard)

☐ In case reducing of composting period

Stores Area, Capacity of Hopper = 1 ~ 2 day

Purpose of composting in this Study = Safety Stabilization, handling (No balance for product market).

Required Quality of Product for Market:


PHI = 6.0 ~ 8.5, Water Content = 30 ~ 40%

BOD = 30 mg/g-DS less, C/N Ratio = 20 less

Wastewater Treatment System Flow

Inlet (Gravity Sewer from Intermediate Sewage Pumping Station): 2 Trains

(Phase I = 1 train)



5. Capacity Calculation of WWTP

5.1. Inflow Gate

| Item | Final Phase | Phase I |
|--------------------|--|---|
| QmaxH | 699,000 m ³ /day | 192,000 m ³ /day |
| Dimension | 1,500mm * 4 unit | 1,500mm * 2 (1) unit |
| Inflow Water Depth | H = 1.373 m | H = 0.940 m |
| Velocity | $V = Q/A$ $= 2.023 / (1.5 * 1.373) = 0.982 \text{ m/sec}$ | (2pond) $V_1 = 1.111 / (1.5 * 0.940) = 0.788 \text{ m/sec}$ (1pond) $V_2 = 2.222 / (1.5 * 0.940) = 1.576 \text{ m/sec}$ |
| Gate Loss | $h = 1.5 * V^2 / 2g$ $= 1.5 * 0.982^2 / 2g = 0.074 \text{ m}$ | $h_1 = 1.5 * V_1^2 / 2g$ (2 pond) $= 1.5 * 0.788^2 / 2g = 0.048 \text{ m}$ $h_2 = 1.5 * V_2^2 / 2g$ (1pond) $= 1.5 * 1.576^2 / 2g = 0.190 \text{ m}$ |
| | <input type="checkbox"/> Use h = 200mm | <input type="checkbox"/> Same Left |

5.2. Coarse Screen

| Item | Final Phase | Phase I |
|--------------------|--|---|
| QmaxH | 699,000 m ³ /day | 192,000 m ³ /day |
| Dimension | 3.5m ^w *100mm*60°*FB-9* 4unit | 3.5m ^w *100mm*60°*FB-9* 2(1) unit |
| Inflow Water Depth | H = 1.373 m | H = 0.940 m |
| Velocity | $V = Q/A$ $= 2.023 / (0.100 * 1.373 * 3.5 / 0.109)$ $= 0.459 \text{ m/sec}$ | $V_1 = Q/A \text{ (1pond)}$ $= 2.222 / (0.100 * 0.940 * 3.5 / 0.109)$ $= 0.736 \text{ m/sec}$ $V_2 = Q/A \text{ (2pond)}$ $= 1.111 / (0.100 * 0.940 * 3.5 / 0.109)$ $= 0.368 \text{ m/sec}$ |
| Screen Loss | $h = 2.34 * \sin 60^\circ * (9/100)^{4/3} * 0.459^2 / 2g$ $= 0.001 \text{ m}$ <input type="checkbox"/> Use h = 200mm | $h_1 = 2.34 * \sin 60^\circ * (9/100)^{4/3} * 0.736^2 / 2g$ $= 0.002 \text{ m (1pond)}$ $h_2 = 2.34 * \sin 60^\circ * (9/100)^{4/3} * 0.368^2 / 2g = 0.001 \text{ m (2pond)}$ <input type="checkbox"/> Same Left (Note) The Pumping Station will extend in the Phase II, But in the Phase I, just about 1/2 of capacity of Pumping Station will be constructed. Facilities depend on the requirements of the run off. |

5.3. Grit Chamber (Simple Type)

| Item | Final Phase | Phase I |
|--------------------|---|---|
| QmaxH | 699,000 m ³ /day | 192,000 m ³ /day |
| Dimension of Tank | 3.5m ^w * 3.0m ^l * 4 tank | 3.5m ^w * 3.0m ^l * 2 (1) tank |
| Inflow Water Depth | H = 1.373 m | H = 0.940 m |
| Surface Area | A = 3.5 * 3.0 * 4 = 42.0m ² | A ₁ = 3.5 * 3.0 * 1 = 10.5m ² A ₂ = 3.5 * 3.0 * 2 = 21.0m ² |
| Surface Loading | 699,000 / 42.0 = 16,643 m ³ /m ² -day | 192,000 / 10.5 = 18,286 m ³ /m ² -day 192,000 / 21.0 = 9,143 m ³ /m ² -day |
| Velocity | V = 2.023/(3.5*1.373) = 0.421m/sec | V ₁ = 2.222/(3.5*0.940) = 0.675m/sec V ₂ = 1.111/(3.5*0.940) = 0.338m/sec |
| (Note) | Establish simple Grit Chamber in WWTP, because Grit Chamber and Screen already treated at Intermediate Sewage Pumping Station | |

5.4. Primary Sedimentation Tank

| Item | Final Phase | Phase I |
|-----------------------|--|---|
| Q _{maxD} | 512,000 m ³ /day | 141,000 m ³ /day |
| Treatment System | Conventional Activated Sludge Process | Modified Aeration Process |
| Number of Train | 10 tank 20 waterway/train * 8 trains = 80 tank 160 waterway | 10 tank 20 waterway/train * 1 train = 10 tank 20 waterway |
| Required Surface Area | SA = 512,000/(50*8*20) = 64.0 m ² /waterway | SA = 141,000/(50*1*20) = 141.0 m ² /waterway |
| Dimension of Tank | 5.0m ^w * 13.0m ^L * 3.0m ^H * 10 tank 20 waterway/train * 8 trains (Hunch of bottom) = 300 ^w * 600 ^H 0.3 * 0.6 * 1/2 = □ 0.09 m ³ /m | 5.0m ^w * 13.0m ^L * 3.0m ^H * 10 tank 20 waterway/train * 1 train Same Left |
| Required Weir Length | L = 512,000/(250*8) = 256.0 m/train = 12.8 m/waterway → 13.0 m/waterway | L = 141,000/(250*1) = 564.0 m/train = 28.2 m/waterway |
| | | Same Left |
| Surface Area | Both side 4.5m + Outlet side 4.0m A = 5.0 * 13.0 * 1 = 65.0 m ² /waterway | Same Left Same Left |
| Volume | V = 65.0*3.0-[0.09*(13.0*2+5.0)] = 192.21 m ³ /waterway | Same Left |
| Surface Loading | 50 m ³ /m ² -day (Standard) 512,000/(65*160) = 49.2 m ³ /m ² -day (OK) | - 141,000/(65.0*20) = 108.5 m ³ /m ² -day |
| Retention Time | 1.5 hr (Standard) 192.21/3,200 * 24 = 1.44 hr (OK) | - 192,21/7,050 * 24 = 0.65 hr |

| Item | Final Phase | Phase I |
|-------------------------|---|--|
| Overflow Weir | 250 m ³ /m-day (Standard) | - |
| Loading | $3,200 / (4.5 * 2 + 4.0) = 246.2$ m ³ /m-day (OK) | $141,000 / [(4.5 * 2 + 4.0) * 20 * 1] = 542.3$ m ³ /m-day |
| Length and Width | 3:1 ~ 5:1 (Standard) | Same Left |
| Ratio | L:W = 13.0: 5.0 = 2.6:1 □ 3:1 (OK) | |
| Average Velocity | 0.20 m/min below (Standard) QmaxD = 3,200 m ³ /day-waterway = 2.22 m ³ /min-waterway V(ave) = $2.22 / (5.0 * 3.0 - 0.09 * 2) =$ 0.150m/min (OK) | Same Left QmaxD = 7,050 m ³ /day-waterway = 4.90 m ³ /min-waterway V(ave) = $4.90 / (5.0 * 3.0 - 0.09 * 2) =$ 0.331m/min |
| Volume of Raw Sludge | Density of Sludge = 2.0% $512,000 * 210 * 0.50 * 10^{-6} =$ 53,760 t/day $53,760 / 2.0 * 10^2 = 2,688$ m ³ /day | Same Left $141,000 * 210 * 0.35 * 10^{-6} =$ 10,364 t/day $10,364 / 2.0 * 10^2 = 518.2$ m ³ /day |
| Bypass Waterway | Establish | Same Left |
| Sludge Hopper | 1 tank 2 waterway Establish 1 place | Same Left |

5.5. Aeration Tank

| Item | Final Phase | Phase I |
|--------------------|---|---|
| Q _{maxD} | 512,000 m ³ /day = 64,000 m ³ /day-train = 6,400 m ³ /day-tank | 141,000 m ³ /day = 141,000 m ³ /day-train = 14,100 m ³ /day-tank |
| Treatment System | Conventional Activated Sludge Process | Modified Aeration Process |
| Number of Train | 10 tank / train * 8 trains = 80 tank | 10 tank / train * 1 train = 10 tank |
| BOD (in) | 512,000 * 200 * (1 - 0.40) * 10 ⁻³ = 61,440 kg/day | 141,000 * 200 * (1 - 0.30) * 10 ⁻³ = 19,740 kg/day |
| SS (in) | 512,000 * 210 * (1 - 0.50) * 10 ⁻³ = 53,760 kg/day | 141,000 * 210 * (1 - 0.35) * 10 ⁻³ = 19,247 kg/day |
| BOD (Removal) | 512,000 * (120 - 20) * 10 ⁻³ = 51,200 kg/day | 141,000 * (140 - 50) * 10 ⁻³ = 12,690 kg/day |
| Required Volume | V = 64,000 / 24 * 6.0 = 16,000 m ³ /train = 1,600 m ³ /tank | V = 141,000 / 24 * 2.0 = 11,750 m ³ /train = 1,175 m ³ /tank |
| Dimension of Tank | 10.5 m ^w * 28.0 m ^L * 5.5 m ^H * 10 tank / train * 8 trains (Hunch of bottom and top side) 500 ^w * 500 ^H * 4 place | 10.5 m ^w * 28.0 m ^L * 5.5 m ^H * 10 tank / train * 1 train Same Left |
| Volume | V = 10.5 * 28.0 * 5.5 * 1 - (0.5 ² * 1/2 * 2 * 28) = 1,610.0 m ³ /tank | Same Left |
| HTR | 6.0 hr (Standard) 1,610.0/6,400 * 24 = 6.04 hr (OK) | 1.5 ~ 2.5 hr (Standard) 1,610.0/14,100 * 24 = 2.74 hr (OK) |
| BOD-SS Loading | 0.2~0.4kg-BOD/kg-SS-day (Standard) 61,400/(1,610.0*80*1,500 ~ 2,000/10 ³) = 0.318 ~ 0.239 kg-BOD/kg-SS-day (OK) | 1.5~3.0kg-BOD/kg-SS-day (Standard), 4.0 kg-BOD/kg-SS-day below (Result of Pilot Plant Experiment Work) 19,740/(16,100.0*80*400 ~ 800/10 ³) = 3.07 ~ 1.53 kg-BOD/kg-SS-day (OK) |
| BOD Volume Loading | 0.600 kg/m ³ -day (Standard) 61,440/(1,610.0 * 80) = 0.477 kg/m ³ -day (OK) | 0.60 ~ 2.40 kg/m ³ -day (Standard). 19,740/(16,100.0 * 80) = 1.226 kg/m ³ -day (OK) |

| Item | Final Phase | Phase I |
|-------------------------|--|---|
| Volume of Return Sludge | Return Sludge Ratio = 50% (Ordinary) ~ 100 % (Max) $R_r = (MLSS - C_i) / (C_r - MLSS) * 10^2$ C _i : Density of SS Influent (= 105mg/l) C _r : Density of Return Sludge (= 6,000mg/l) MLSS = 1,500~2,000mg/l → 1,700mg/l R _{r1} (In case MLSS = 1,700mg/l) $= (1,700 - 105) / (6,000 - 1,700) * 10^2$ = 37.09% R _{r2} (In case MLSS = 2,000mg/l, Normal Operation) $= (2,000 - 105) / (6,000 - 2,000) * 10^2$ = 47.38% (□ 50%) $Q_r = Q_i * R_r / 10^2$ Q _r : Volume of Return Sludge Q _i : Influent Sewer Flow Rate R _r : Return Sludge Ratio $Q_r = 512,000 * 50 \sim 100 / 10^2$ = 256,00 ~ 512,000 m ³ /day = 177.78 ~ 355.56 m ³ /min □ No Stand-by Pump | Return Sludge Ratio = 5 ~ 10% MLSS = 400 ~ 800 mg/l Same Left $Q_r = 141,000 * 5 \sim 10 / 10^2$ = 7,050 ~ 14,100 m ³ /day = 4.90 ~ 9.79 m ³ /min □ Same Left |
| F/M Ratio | 0.40kg-BOD/kg-MLVSS (Standard) $F/M = (61,440 + 512,000 * 0.5 \sim 1.0 * 20 * 10^{-3}) / (1,610.0 * 80 * 1,500 \sim 2,000 * 0.8 * 10^{-3}) = 0.431 \sim 0.348$ kg - BOD/kg -MLVSS (OK) □ MLVSS/MLSS = 0.80 | - $F/M = (19,740 + 141,000 * 0.05 \sim 0.10 * 50 * 10^{-3}) / (16,100 * 400 \sim 800 * 0.8 * 10^{-3}) = 3.900 \sim 1.984$ kg-BOD/kg-MLVSS |
| Sludge Age ① | Sa 3.0days (Standard) $Sa = 1,610.0 * 80 * 1,500 \sim 2,000 * 10^{-3} / 53,760 = 3.6 \sim 4.8$ days (OK) | □ Same Left 0.3 ~ 0.5day (Standard) $Sa = 16,100 * 400 \sim 800 * 10^{-3} / 19,247 = 0.3 \sim 0.7$ day (OK) |

| Item | Final Phase | Phase I |
|-------------------------|--|--|
| ② | SRT4.0days $SRT = (V_a * MLSS + V_s * MLSS) / (Q_w * Cr + Q * SSo)$ Vs: Volume of Final Sedimentation Tank = 71,979 m ³ Qw: Volume of Excess Sludge = 6,397.5 m ³ /day SSo: Density of SS Wastewater = 30mg/l $SRT = (1,610 * 80 * 1,500 \sim 2,000 + 71,979 * 1,500 \sim 2,000) / (6,397.5 * 6,000 + 512,000 * 30) = 5.6 \sim 7.5$ days (OK) | - Same Left Vs = 17,995 m ³ Qw = 1,796.3 m ³ /day SSo = 60 mg/l $SRT = (16,100 * 400 \sim 800 + 17,995 * 400 \sim 800) / (1,796.3 * 2,000 + 141,000 * 60) = 1.1 \sim 2.3$ days (OK) |
| ③ | ASRT (Part of Aerobic SRT) According to the Operating Condition. O + O + O + O (Regular Operation) A + O + O + O (Controlling Filamentous Bulking and Other Operation) A + O + A + O (") □ O = Aerobic Part □ A = Anaerobic Part | Same Left |
| Operation Process | | |
| Water Volume per 1 tank | 2,500 ~ 7,500 m ³ /day-tank (Standard) V = 512,000/80 = 6,400 m ³ /day-tank (OK) | Same Left |
| Tank Division | 4 Division (1 : 1.5 : 1.5 : 2.25) | Same Left |
| Opening of Baffle | Up-size (Both side * 2 places) | Same Left |
| Wall Size | = 0.5m ^w * 0.3m ^h * 2 places Down-size (central Bottom * 1 place) = 1.0m ^w * 1.0m ^h * 1 place | Same Left |
| Tank Width | Water Depth * 1 ~ 2 times (Standard) T.W. = 10.5/ 5.5 = 1.91 times (OK) | Same Left |
| Bypass waterway | Establish | Same Left |
| Step Waterway | Establish | Same Left |

5.6. Final Sedimentation Tank

| Item | Final Phase | Phase I |
|------------------------|--|--|
| Q _{maxD} | 512,000 m ³ /day = 64,000 m ³ /day-train = 3,200 m ³ /day-waterway | 141,000 m ³ /day = 141,000 m ³ /day-train = 7,050 m ³ /day-waterway |
| Treatment System | Conventional Activated Sludge Process | Modified Aeration Process |
| Number of Train | 10 tank 20 waterway/train * 8 trains = 80 tank 160 waterway | 10 tank 20 waterway/train * 1 train = 10 tank 20 waterway |
| Required Surface Area | A = 64,000/25 = 2,560 m ² /train = 2,560/20 = 128 m ² /waterway | A = 141,000/58 = 2,431 m ² /train = 2,431/20 = 122 m ² /waterway |
| Dimension of Tank | 5.0m ^w * 26.0m ^L * 3.5m ^H * 10 tank 20 waterway/train * 8 trains (Hunch of Bottom) 300mm ^w * 600mm ^H 0.3 * 0.6 * 1/2 = 0.09 m ³ /m | 5.0m ^w * 26.0m ^L * 3.5m ^H * 10 tank 20 waterway/train * 1 train Same Left |
| Required Weir Length | L = 64,000/120 = 534.0 m/train = 534/20 = 26.7 → 27.0 m/waterway □ 13.5m * Both side * 2 place/waterway | L = 141,000/120 = 1,175 m/train = 1,175/20 = 58.8 m/waterway Same left |
| Surface Area | A = 5.0 * 26.0 * 1 = 130.0 m ² /waterway (OK) | Same Left |
| Volume | V = 130.0 * 3.5 - [0.09*(26.0*2 + 5.0)] = 449.87 m ³ /waterway | Same left |
| Surface Loading | 25 m ³ /m ² -day (Standard) | 58 m ³ /m ² -day (Result of Pilot Plant Experiment Work) |
| Retention Time | 3,200/130.0 = 24.6 m ³ /m ² -day (OK) 3.0 hr (Standard) 449.87/3,200 * 24 = 3.37 hr (OK) | 7,050/130.0 = 54.2 m ³ /m ² -day (OK) - 449.87/7,050 * 24 = 1.53 hr |
| Overflow Weir Loading | 120 m ³ /m-day (Standard) 3,200/(13.5*2) = 118.5 m ³ /m-day (OK) | - 7,050/(13.5*2) = 261.1 m ³ /m-day |
| Length and Width Ratio | 3:1 ~ 5:1 (Standard) 26.0 : 5.0 = 5.2 : 1 □ 5 : 1 (OK) | Same Left Same Left |

| Item | Final Phase | Phase I |
|-------------------------|---|---|
| Average Velocity | 0.200m/min (Standard) V(ave) = $\frac{2.22}{(5.0 \times 3.5 - 0.09 \times 2)}$ $= 0.128 \text{ m/min}$ (OK) | - V(ave) = $\frac{4.90}{(5.0 \times 3.5 - 0.09 \times 2)}$ $= 0.283 \text{ m/min}$ (OK) |
| Volume of Excess Sludge | Density of Sludge = 0.6% $512,000 * 210 * (1-0.50) * 0.714 * 10^{-6}$ $= 38.385 \text{ t/day}$ $38.385 / 0.6 * 10^2 = 6,397.5 \text{ m}^3/\text{day}$ | Same Left $141,000 * 210 * (1-0.35) * 0.560 * 10^{-6}$ $= 10.778 \text{ t/day}$ $10.778 / 0.6 * 10^2 = 1,796.3 \text{ m}^3/\text{day}$ |
| Volume of Sludge Hopper | QmaxD * 30 min $V = 3,200 / (24 \times 60) * 30 = 66.7$ $\text{m}^3/\text{waterway} = 133.4 \text{ m}^3/\text{tank}$ Upper Tank Volume = $10.5 * 3.0 * 3.5$ $= 110.3 \text{ m}^3$ Necessary Hopper Volume = $133.4 - 110.3 = 23.1 \text{ m}^3$ above $(10.5 * 3.0 + 0.8^2) / 2 * H \geq 23.1$ $\text{m}^3(\text{V})$ $H = 1.5 \text{ m}$ above - ① Excess Sludge Volume = $6,397.5$ $\text{m}^3/\text{day-tank}$ $(10.5 * 3.0 + 0.8^2) / 2 * H \geq 80 * 1/2$ [12 hour Pull Out Sludge] $H = 2.5 \text{ m}$ above - ② | Same Left |
| | A cross-sectional diagram showing a rectangular tank at the top with dimensions 3.0m width and 13.5m length. Below it is a trapezoidal hopper with a bottom width of 0.8m and sloped sides. The total height from the base of the hopper to the top of the tank is indicated as 10.5m on the right side. On the left side, two segments are labeled 5.0m each, totaling 10.0m. Labels include "Sludge Hopper" pointing to the lower section and "Outflow Trough + Triangular Notch" pointing to the upper section. | Same Left |
| Bypass Waterway | □ Hopper = 2 waterway 1 Place □ 1 Tank 2 waterway □ Sludge Hopper Depth = 2.5m above Establish | Same Left Same Left Same Left Same Left |

5.7. Disinfection Tank

| Item | Final Phase | Phase I |
|-------------------|--|--|
| QmaxD | 512,000 m ³ /day = 355.56 m ³ /min = 5.926 m ³ /sec | 141,000 m ³ /day = 97.92 m ³ /min = 1.632 m ³ /sec |
| Treatment System | Conventional Activated Sludge Process | Modified Aeration Process |
| Required Volume | $V = 512,000 / (24 \times 60) \times 15 = 5,334 \text{ m}^3$ | 1/2 System will be constructed on the Phase I |
| Dimension of Tank | 5.0m ^W * 54m ^L * 5.0m ^H * 3bend 4waterway 1tank (Ifunch of bottom) 300mm ^W * 300mm ^H $0.3 \times 0.3 \times 1/2 = 0.045 \text{ m}^3/\text{m}$ | 5.0m ^W * 27.0m ^L * 5.0m ^H * 3bend 4waterway 1tank Same Left |
| Section Area | $A = 5.0 \times 5.0 - (0.3 \times 0.3 \times 1/2 \times 2)$ = 24.910 m ² /waterway | Same Left |
| Volume | $V = 24.910 \times 54.0 \times 4$ = 5,380.56 m ³ > 5,334 m ³ (OK) | $V = 24.910 \times 27.0 \times 4$ = 2,690.28 m ³ > 2,667 m ³ (OK) |
| Average Velocity | $V(\text{ave}) = 5.926 / 24.910 = 0.238 \text{ m/sec}$ (OK) | $V(\text{ave}) = 1.632 / 24.910 = 0.066 \text{ m/s}$ (OK) |
| Contact Time | $T = 5,380.56 / 355.56 = 15.1 \text{ min}$ (OK) □ Contact Time of Effluent Pipe is not considered | $T = 2,690.28 / 97.92 = 27.5 \text{ min}$ (OK) □ Same Left |
| Bypass Waterway | Establish | Same Left |

5.8. Gravity Thickener (For Raw Sludge)

| Item | Final Phase | Phase I |
|----------------------------|---|--|
| Volume of Raw Sludge | Density = 2.0% (1.5%) 53.760 t/day (D.S) 2,688 m ³ /day (3,584 m ³ /day) | Same Left 10.364 t/day (D.S) 518.200 m ³ /day (690.933 m ³ /day) |
| Required Surface Area | $A = 53.760 \times 10^3 / 90 = 598 \text{ m}^2$ | $A = 10.364 \times 10^3 / 90 = 115.2 \text{ m}^2$ |
| Dimension of Tank | 14.0m * 3.5m ^{II} * 4tanks | 14.0m * 3.5m ^{II} * 1tank |
| Surface Area | $A = \pi * 7.0^2 * 4 = 615.8 \text{ m}^2$ (OK) | $A = \pi * 7.0^2 * 1 = 153.9 \text{ m}^2$ (OK) |
| Volume | $V = 615.8 * 3.5 = 2,155.3 \text{ m}^3$ | $V = 153.9 * 3.5 = 538.65 \text{ m}^3$ |
| Solid Surface Loading | $53.760 * 10^3 / 615.8 = 87.3 \text{ kg/m}^2\text{-day}$ (OK) | $10.364 * 10^3 / 153.9 = 67.3 \text{ kg/m}^2\text{-day}$ (OK) |
| Retention Time | $T = 2,155.3 / 2,688 * 24 = 19.2 \text{ hr}$ (OK) (In case Density of Raw Sludge = 1.5%); CHECK $T' = 2,155.3 / 3,584 * 24 = 14.4 \text{ hr}$ (OK) | $T = 538.65 / 518.200 * 24 = 24.9 \text{ hr}$ (OK) (Same Left) $T' = 538.65 / 690.933 * 24 = 18.7 \text{ hr}$ (OK) |
| Volume of Thickened Sludge | Density of Sludge = 3.0% $53.760 / 3.0 * 10^3 = 1,792.0 \text{ m}^3\text{/day}$ | Same Left $10.364 / 3.0 * 10^3 = 345.5 \text{ m}^3\text{/day}$ |
| (Note) | ① In case of Effective Depth = 4.0m, Retention Time will be more than 22.0 hr. Consider H= 3.5m to keep thickened and Sedimentation zones. | ① Same Left |
| | ② In case of sludge is small at the operation start Time, pipes are arranged to use a gravity thickener for the Combined Sludge. (Bypass Pipe Establish). | ② Same Left |

5.9. Centrifugal Thickener (For Excess Sludge)

| Item | Final Phase | Phase I |
|--------------------------------|--|---|
| Volume of Excess Sludge | Density of Sludge = 0.6% 38.385 t/day (D.S) $6,397.5 \text{ m}^3/\text{day}$ | Same Left 10.778 t/day (D.S) $1,796.3 \text{ m}^3/\text{day}$ |
| Volume of Thickened Sludge | Density of Sludge = 4.0% $38.385/4.0 \times 10^{-2} = 959.6 \text{ m}^3/\text{day}$ | Same Left $10.778/4.0 \times 10^{-2} = 269.5 \text{ m}^3/\text{day}$ |
| Centrifugal Thickener Capacity | $70 \text{ m}^3/\text{hour} \times 6 \text{ unit}$ | $70 \text{ m}^3/\text{hour} \times 2 \text{ unit}$ |

5.10. Sludge Storage Tank

| Item | Final Phase | Phase I |
|------------------------|--|--|
| Volume of Inlet Sludge | ① Gravity Thickened Sludge: Density of Sludge = 3.0% 53,760 t/day (D.S) 1,792.0 m ³ /day ② Centrifugal Thickened Sludge: Density of Sludge = 4.0% 38,385 t/day (D.S) 959.6 m ³ /day ③ Total: Density of Sludge (Ave) = 3.35% 92,145 t/day (D.S) 2,751.6 m ³ /day | ① Same Left: Same Left 10,364 t/day (D.S) 345.5 m ³ /day ② Same Left: Same Left 10,778 t/day (D.S) 269.5 m ³ /day ③ Same Left: Density of Sludge (Ave) = 3.44% 21,142 t/day (D.S) 615.0 m ³ /day |
| Required Volume | Retention Time = 12 hr above □ Operation Time of Dewatering Machine = 24 hr/day. $V = 2,751.6 \times 12/24 = 1,376 \text{ m}^3$ | Same Left □ Same Left $V = 615.0 \times 12/24 = 308 \text{ m}^3$ |
| Dimension of Tank | Will be change with Dewatering and Centrifugal Thickener Building. $V = 1,376 \text{ m}^3$ | Same Left $V = 308 \text{ m}^3$ |
| Retention Time | $T = 1,376/2,751.6 \times 24 = 12.0 \text{ hr above}$ | $T = 308/615.0 \times 24 = 12.0 \text{ hr above}$ |

5.11. Sludge Dewatering (Centrifugal Dewatering)

| Item | Final Phase | Phase I |
|---------------------------------|---|--|
| Volume of Inlet Sludge | Density of Sludge = 3.35% 92.145 t/day (D.S) 2,751.6 m ³ /day | Density of Sludge = 3.44% 21.142 t/day (D.S) 615.0 m ³ /day |
| Operation Time | 24 hr/day Continued Operation □ Stand by Correspondence. | Same Left □ Same Left |
| Dewatering Cake Volume | Density of Sludge = 20.0% $92.145/20.0 \times 10^2 = 461 \text{ m}^3/\text{day}$ | Same Left $21.142/20.0 \times 10^2 = 106 \text{ m}^3/\text{day}$ |
| Centrifugal Dewatering Capacity | 30m ³ /hour * 6 unit | 30m ³ /hour * 2 unit |

5.12. Composting Facility

| Item | Final Phase | Phase I |
|------------------------|--|--|
| Volume of Inlet Sludge | Dewatering Cake: Density of Sludge = 20.0% 92.145 t/day 461 m ³ /day | Dewatering Cake: Density of Sludge = 20.0% 21.142 t/day (D.S) 106 m ³ /day |

7.6

Hydraulic Calculation

1. BASIC DESIGN CRITERIA.

1.1 Sewerage System

Combined Sewer System. (Over $Q_{\max H}$ wastewater volume won't influence into the WWTP, because it will be discharged at the Storm Overflow Chamber. Refer to Sewer Pipe Design).

1.2 Formula

Manning's Formula

$n = 0.013$ (HP, DCIP, SP), 0.010 (VP, VU, FRPM)

1.3 Design Wastewater Quantity (Unit: m^3/day)

| Items | Final Phase | Phase I | Phase II | Remarks |
|--------------|-------------|---------|----------|----------------------------|
| $Q_{\max D}$ | 512,000 | 141,000 | 469,000 | $Q_{ave D} = Q_{\max D}$ |
| $Q_{\max H}$ | 699,000 | 192,000 | 640,000 | $Q_{\max H} = Q_{\max RH}$ |

□ Return Sludge Quantity = Daily Maximum Wastewater Quantity * 100% (Max)
(Daily Fluctuation Rate)

$$Q_{ave D} = Q_{\max D}$$

$$Q_{\max H} = Q_{\max RH}$$

$$= 1.4 * Q_{\max D} \text{ (Domestic wastewater) + groundwater}$$

1.4 Specification of Inlet Pipe

(Phase I) □ $1,300^W * 1,200^H * 0.5\text{‰} * 2\text{Box}$; BL = - 3.314 m (L.P.S. Point)

(Phase II) □ $2,000^W * 1,700^H * 0.4\text{‰} * 2\text{Box}$; BL = - 3.890 m (L.P.S. Point)

1.5 Specification of Effluent Pipe

$$\odot 2,500 \text{ mm} * 1.2\text{‰} \text{ (HP)}, L \square 100\text{m}$$

1.6 Outline of WWTP Site

1) Location: Binh Hung / Binh Chanh District

2) Administrative Situation: Green Area (Future)

3) Design Ground Elevation GL = + 2.200m (Present condition GL = + 0.600m)

1.7 Condition of Outlet

(1) Outlet: Tac Ben Ro Canal

(2) Water Level of Outlet (Tidal River): HWL = + 1.650m

LWL = - 2.690 m

Nha Be Point (100 Year Probability)

1.8 Water Velocity, Water Depth, Water Level

(Bottom Level of Inlet Pipe) Phase I = - 3.314 m, Phase II = - 3.890 m

□ L.P.S. Inflow Bottom Level (BL) = - 3.890 - 0.300 + α = - 4.200 m

| Item | | QmaxD | QmaxII | Remarks |
|-------------|-------------------|--------|--------|----------------|
| Discharge | m ³ /s | 1.632 | 2.222 | QaveD = QmaxD |
| | | 4.294 | 5.868 | |
| Velocity | m/s | 0.848 | 0.909 | QmaxH = QmaxRH |
| | | 0.994 | 1.068 | |
| Water Depth | m | 0.740 | 0.940 | |
| | | 1.080 | 1.373 | |
| Water Level | m | -3.460 | -3.260 | |
| | | -3.120 | -2.827 | |

Upper Row = Phase I

Lower Row = Phase II

1.9 Outline of Wastewater Treatment Plant (Final Phase)

(1). Primary Sedimentation Tank

$5.0\text{m}^{(W)} * 13.0\text{m}^{(L)} * 3.0\text{m}^{(H)} * 10 \text{ tanks } 20 \text{ waterway/train} * 8 \text{ trains,}$

Overflow Weir Length = 13.0m/waterway, Including Bypass Waterway

(2). Aeration Tank

$10.5\text{m}^{(W)} * 28.0\text{m}^{(L)} * 5.5\text{m}^{(H)} * 10 \text{ tanks / train } * 8 \text{ trains}$

Including Bypass Waterway

(3). Final Sedimentation Tank

$5.0\text{m}^{(W)} * 26.0\text{m}^{(L)} * 3.5\text{m}^{(H)} * 10 \text{ tanks } 20 \text{ waterway/train} * 8 \text{ trains,}$

Overflow Weir Length = 27.0m/waterway, Including Bypass Waterway

(4). Disinfection Tank

$5.0\text{m}^{(W)} * 54.0\text{m}^{(L)} * 5.0\text{m}^{(H)} * 3 \text{ bends } 4 \text{ waterway } * 1 \text{ tank } * 1 \text{ train,}$

Including Bypass Waterway

□ $5.0\text{m}^{(W)} * 27.0\text{m}^{(L)} * 5.0\text{m}^{(H)} * 3 \text{ bends } 4 \text{ waterway } * 1 \text{ tank } * 2 \text{ trains,}$

(Future: In Case of Two Outflow System) , Including Bypass Waterway

1.10 Design Condition and Future Consideration

- (1) Treatment process and capacity is designed in each phase as follows:

| | Process | Train | QmaxD (m ³ /day) | QmaxH (m ³ /day) |
|-------------|-------------------------------|-------|-----------------------------|-----------------------------|
| Phase I | Modified Aeration | 1/8 | 141,000 | 192,000 |
| Phase II | Modified Aeration | 4/8 | 469,000 | 640,000 |
| Final Phase | Conventional Activated Sludge | 8/8 | 512,000 | 699,000 |

- (2) Design Capacity

Facilities to be constructed in Phase I and Phase II are mainly designed at a capacity of QmaxD or QmaxH of Phase I and Phase II, respectively. However, some of facilities in Phase I and Phase II are designed at a capacity of Final Phase because of more economical and only 8% increase in design Flow of wastewater from Phase II to Final Phase. The following items are considered to be designed at a capacity of Final Phase.

- 1) Phase I - Facilities to be constructed at a capacity of Final Phase
 - Effluent Pipe of WWTP ($\Phi 2,500 \times 1.2\% \times 1$ unit)
 - Connection Pipe between Outflow Pit of FST and Secondary Treated Effluent Tank ($\Phi 2,500 \times 1$ unit)
 - Inlet Pipe (pressurized) ($1,800\text{mm} \times 2$ unit)
- 2) Phase II - Facilities to be constructed at a capacity of Final Phase
 - Disinfection Tank

- (3) Review of Outlet Location of WWTP in Phase II

It is very important to review another outlet location in Phase II. If effluent can be flowed to Xom Cui Canal in addition to Tac Ben Ro Canal, wastewater processing facilities can be lowered one meter. It can reduce the construction cost. The decision, whether another outlet of WWTP can be installed or not, is determined by the result of EIA and other relating considerations. Therefore, the review will be executed very carefully in Phase II. It will be important review because hydraulic characteristic of WWTP is determined.

2. FORMULA

2.1 Effluent Pipe / Connection Pipe

(1) Circle Pipe

$$h = (f_e + \partial * L/D + f_o) * V^2 / (2 * g)$$

h: Head Loss (m)

f_e : Inlet Loss (= 0.5)

f_o : Outlet Loss (= 1.0)

g: Gravitation Acceleration (= 9.8m/s)

V: Velocity (= Q/A, m/s)

∂ : Friction Head Loss Coefficient ($8 * g * n^2 / R^{1/3}$, $R = D/4$)

L: Length (m)

D: Diameter (m)

(2) General Section

$$hf = (n^2 * V^2 * L) / R^{4/3}$$

hf: Friction Head Loss (m)

n: Roughness Coefficient (= 0.013 ~ 0.010)

R: Hydraulic Radius (m)

$R = D/4$ (Circular Pipe Flowing full)

$R = \text{Area} / \text{Wetted Perimeter} = B * H / (B + 2H)$ (General Section)

B: Width (m), H: Water Depth (m)

$$hf = (f * L * V^2) / (2 * g * R)$$

f: Friction Head Loss Coefficient (General Section) = $2 * g * n^2 / R^{1/3}$

2.2 Disinfection Tank.

(1). Suppressed Rectangular Weir

$$Q = C * B * h^{3/2}$$
$$h = [Q / (1.84 * B)]^{2/3}$$

Q: Overflow Rate (m³/s)

B: Weir Width (m)

h: Overflow Water Depth (m)

C: Discharge Coefficient (=1.84)

(2) Friction Head Loss

$$h_f = I * L$$

I: Hydraulic Slope

$$I = (Q/K)^2 = [(n * V) / R^{2/3}]^2$$
$$R = B * H / (B + 2 * H)$$

B: Width (m)

H: Water Depth (m)

(3) Bend Loss: 180° Bend

$$h_f = f * V^2 / 2g * n = 1.4 * V^2 / 2g * n$$

f: Bend Loss Coefficient (=1.4)

n: Number of Bends

(4) Inflow Gate (Submerged Orifice)

$$Q = C * B * H * \sqrt{2 * g * h}$$

C: Discharged Coefficient (= 0.6)

B: Gate Width (m)

H: Gate Hight (m)

h: Head Loss (m)

$$h = [Q / (0.6 * B * H)]^2 * 1 / (2 * g)$$

(5) Inflow Gate (Gate Discharge Formula)

$$h = [Q / (0.73 * B * H)]^2 * 1 / (2 * g)$$

2.3 Sedimentation Tank

(1) Outflow Waterway (Inlet Waterway): Friction Head Loss

$$h_L = I * L$$

h_L : Friction Head Loss (m)

I: Slope

L: Length (m)

$$I = (n * V / R^{2/3})^2$$

(2) Outflow Trough:

$$h_c = [r * Q^2 / (g * B^3)]^{1/3}$$

h_c : Critical Depth (m)

r : Non Uniform Velocity Distribution Coefficient (= 1.10)

Q : Outlet Discharge Rate (m³/s)

B : Trough Width (m)

$$h_o = \sqrt{3 * h_c} \quad (\text{Free Overflow})$$

h_o : Water Depth at Upstream of Contracted Trough

□ Bottom Slope of Trough $i = 0$

$$h_o = \sqrt{(2 * h_c^3 / h_c + h_c^2)} \quad (\text{Submerged Overflow})$$

(3) Triangular Notch (Triangle Weir)

$$Q = C * h^{5/2}$$

Q : Discharge (m³/s)

C : Discharge Coefficient (= 1.42)

h : Overflow Depth (m)

$$h = (q / 1.42)^{2/5}$$

q : Overflow Rate Per Notch (m³/s)

(4) Inflow Gate (Case of Entrance Loss / Outlet Loss)

$$h = 1.5 * V^2 / (2 * g)$$

□ In other cases, refer to Gate Discharge Formula

2.4 Aeration Tank / Distribution Tank

(1) Suppressed Rectangular Weir

$$h = [Q / (1.84 * B)]^{2/3}$$

(2) Movable Weir

$$Q = C * B * H^{3/2}$$

Q: Overflow Rate for 1 unit (m³/s)

C: Discharge Coefficient (= 1.84)

B: Weir Width (m)

H: Overflow Water Depth (m)

$$h = [Q/(1.84 * B)]^{2/3}$$

2.5 Measurement Range of Discharge at Outflow Weir (Reference)

Refer to Hydraulic Formula Handbook (Japan)

Suppressed Rectangular Weir of Disinfection Tank

B = 5.0m (Maximum Width at Hydraulic Formula Handbook (Japan))




Range of Water Head = 0.030 ~ 0.800 m








Measurement Range of Discharge = 4,320 ~ 611,712 m³/day

= 50 ~ 7,080 l/sec

* Here in B = 5.0 m

List of Formula

| Name of formula | Formulas | Application |
|--------------------|--|--|
| (1) Manning | $V = (1/n) * I^{1/2} R^{2/3}$ V: Average Velocity (m/s) n: Roughness Coefficient I: Hydraulic Gradient R: Hydraulic Radius (m) | Iron Concrete Pipe, Waterway |
| (2) Darcy-Weisbach | $hf = f * (L/D) * (V^2/2g)$ f: Coefficient of Friction Head Loss L: Straight Length Pipe (m) D: Diameter (m) $f = 0.02 + 1/(2.000D)$ | Cast iron or Pressure Pipe with mortar lining or Steel Pipes |
| (3) Francis | $L = Q/(1.84 * h^{3/2})$: Full Overflow $L = Q/[1.84 * (h_1 + 1.4h_2) * \sqrt{h_1}]$: Not Full Overflow L: Length Weir (m) Q: Over Quantity (m ³ /s) h, h ₁ , h ₂ : Overflow Depth (m)  | Suppressed Rectangle Weir |
| (4) Thomson | $Q = 1.42h^{5/2}$ h: Overflow Depth (m)  | Triangle Weir Sedimentation Tank Weir Plate |
| (5) Oki | $Q = 1.84 b h^{3/2}$  b: Length of Weir (m) h: Water Depth (m) | Rectangle Weir |
| (6) Bill Mount | $Q = Q_1 \{1 - (h_2/h_1)^n\}^{0.385}$ Q ₁ : Over Quantity with Water Depth when Gravity Free Flow (m ³ /s) h ₁ : Weir Angle Upstream Water Depth (m) h ₂ : Weir Angle Downstream Water Level (m) n: (Suppressed Weir 1.50, Rectangular Weir 1.45, Rectangular Weir 2.50) | Submerged Sharp-crested Weir |

| | | |
|------------------------------|--|--|
| <p>(6)</p> <p>Bill Mount</p> |  | |
| <p>(7) Tomas-Camp</p> | <p> $h_o = \sqrt{3} \text{ hcl}$: Gravity Downstream Flow $h_o = \sqrt{(2 \text{ hcl}^3 / \text{hl}) + \text{hl}^2}$: Non-Gravity of Downstream Flow h_o : Shape Upstream Side Water Depth (m) hcl : Maximum Water Depth (m) hl : Shape Downstream Trough Water Level (m) $\text{hcl} = \sqrt[3]{(\alpha Q^2 / g B^4)}$ α : Kinetic Correction Coefficient by Flow Velocity (distribution connection = 1) Q : Downstream Total Flow (m^3/s) B : Trough Width (m) \square Bottom Slope Trough Water Level </p> | <p>Overflow Trough at Sedimentation</p> |
| <p>(8)</p> <p>Kirusmel</p> | <p> $h = \beta \sin \theta (t/b)^{4/3} V^2 / 2g$ h : Head Loss of Screen Bar (m) β : Coefficient of Screen Section Bars θ : Angle of Screen ($^\circ$) t : Slope of Screen (mm) b : Space between of Screen Bar (mm) </p> <div style="display: flex; justify-content: space-around; align-items: flex-end;"> <div style="text-align: center;">  <p>Vertical section</p> <div style="display: flex; justify-content: space-around;"> <div style="text-align: center;">  $\beta = 1.60$ (a) </div> <div style="text-align: center;">  $\beta = 1.77$ (b) </div> </div> </div> <div style="text-align: center;">  <p>Side section</p> <div style="display: flex; justify-content: space-around;"> <div style="text-align: center;">  $\beta = 2.34$ (c) </div> <div style="text-align: center;">  $\beta = 1.73$ (d) </div> </div> </div> </div> | <p>An amendment of 10 cm Head Loss is usually considered rubbish accumulated</p> |

[Loss of Shape]

$$h = f \cdot V^2 / 2g$$

f: Shape Loss Coefficient

| | [f] |
|-----------------|-----------------|
| (1) Outlet Flow | 1.0 |
| (2) Bend (90°) | 1.0 |
| " (180°) | 1.4 ~ 3.0 |
| (3) Turn (45°) | 0.13 (CIP Φ900) |
| " (90°) | 0.2 (CIP Φ900) |
| (4) Orifice | 3.0 |
| (5) Inlet Flow | 0.5 |

Reference

| Shape of Weir | Flow Range Q(l/s) | Size of Reference Weir and Overflow Range | | | | | | | | |
|---------------|----------------------|---|------------------------------|--------------------|--------------------|--------------------|------|------|--------------------|--------------------|
| | | Width Bxb(m) | Range of Overflow water h(m) | L ₁ (m) | L ₂ (m) | L ₃ (m) | L(m) | W(m) | P ₁ (m) | P ₂ (m) |
| Suppressed | 6~67 | 0.6 | 0.030~0.150 | ≥ 1.35 | 0.30 | ≥ 1.05 | 0.15 | 0.30 | 0.50 | 0.60 |
| | 9~190 | 0.9 | 0.030~0.225 | ≥ 2.05 | 0.45 | ≥ 1.60 | 0.23 | 0.30 | 0.60 | 0.75 |
| | 12~400 | 1.2 | 0.030~0.300 | ≥ 2.70 | 0.60 | ≥ 2.10 | 0.30 | 0.30 | 0.70 | 0.90 |
| | 15~690 | 1.5 | 0.030~0.375 | ≥ 3.40 | 0.75 | ≥ 2.65 | 0.38 | 0.4 | 0.90 | 1.05 |
| | 20~1430 | 2.0 | 0.030~0.500 | ≥ 4.50 | 1.00 | ≥ 3.50 | 0.50 | 0.50 | 1.20 | 1.50 |
| | 30~3950 | 3.0 | 0.030~0.750 | ≥ 6.75 | 1.50 | ≥ 5.25 | 0.75 | 0.75 | 1.70 | 2.00 |
| | ★(This time) 50~7080 | 5.0 | 0.030~0.800 | ≥ 9.0 | 1.60 | ≥ 7.40 | 0.80 | 1.00 | 2.00 | 2.50 |
| Rectangle | 4~92 | 0.9x0.36 | 0.030~0.270 | ≥ 1.71 | 0.54 | ≥ 1.44 | - | 0.20 | 0.50 | 0.60 |
| | 5~150 | 1.2x0.48 | 0.030~0.312 | ≥ 2.14 | 0.63 | ≥ 1.83 | - | 0.25 | 0.60 | 0.75 |
| Triangle | 2~25 | 0.60 | 0.070~0.200 | ≥ 1.00 | 0.40 | ≥ 0.80 | - | 0.12 | 0.35 | 0.50 |
| | 2~48 | 0.80 | 0.070~0.260 | ≥ 1.32 | 0.52 | ≥ 1.06 | - | 0.30 | 0.60 | 0.75 |

Quantity Formula

Suppressed Rectangle Weir

$$Q = C \cdot B \cdot h^{3/2}$$

$$C = 1.785 + (0.00295/h + 0.237 \cdot h/W) \cdot (1 + e)$$

Here in:

Q: Overflow (m³/s), B: Width of Weir (m), h: Depth of Water (m), C: Discharge Coefficient (m^{1/2}/s), W: Height from Bottom of Trough to the Top of the Weir (m).

Explanation:

This Formula is used = JIS B 8302. The Adapted Range is B □ 0.5m, W = 0.3 ~ 2.5m,

h = 0.03 ~ 0.8m (Use in the Range of h < W and h < B/4)

In this Range, 95% of Flow Quantity is certain.

Uncertain Quantity is ± 1.7 %.

3. CALCULATION OF HYDRAULIC PROFILE
 3.1 Effluent Pipe Head Loss (Disinfection Tank Outflow Pit Water Level)

| Item | | Unit | QmaxD | QmaxH |
|----------------------|--------------------|-------------------|------------------------------|---------|
| Quantity | | m ³ /d | 512,000 | 699,000 |
| | | m ³ /s | 5.926 | 8.090 |
| Establishment Number | | Number | 1 | 1 |
| Unit Flow | | m ³ /s | 5.926 | 8.090 |
| Effluent Pipe Form | | - | Ø2,500 mm (HP) * 1.2‰ | |
| Section Area | | m ² | A = 4.909 | |
| Length | | m | About 100 | |
| Velocity | | m/s | 1.207 | 1.648 |
| Effluent Water Level | | m | HWL = + 1.650, LWL = - 2.690 | |
| Head Loss | Inlet Loss | m | 0.037 | 0.069 |
| | Outlet Loss | m | 0.074 | 0.139 |
| | Straight Pipe Loss | m | 0.045 | 0.083 |
| | Total | m | 0.156 | 0.291 |
| Water Level | | m | + 1.810 | + 1.950 |

| | | | |
|-------|--|--|--|
| NOTE: | $h = (f_c + \partial * L/D + f_o) * V^2/2g$, $\partial = 8gn^2/R^{1/3}$, $R = D/4$, $n = 0.013$ | | |
| | (Section Area) | | |
| | $A = \pi * 2.5^2 * 1/4 = 4.909 \text{ m}^2$ | | |
| | (Velocity) $V = Q/A$ | | |
| | $V(Q_{\max D}) = 5.926/4.909 = 1.207 \text{ m/s}$ | | |
| | $V(Q_{\max H}) = 8.090/4.909 = 1.648 \text{ m/s}$ | | |
| | $R = 2.500/4 = 0.625$, $\partial = 8 * 9.8 * 0.013^2/0.625^{1/3} = 0.015$ | | |
| | (Inlet Loss) | | |
| | $h(Q_{\max D}) = 0.5 * 1.207^2/2g = 0.037 \text{ m}$ | | |
| | $h(Q_{\max H}) = 0.5 * 1.648^2/2g = 0.069 \text{ m}$ | | |
| | (Outlet Loss) | | |
| | $h(Q_{\max D}) = 1.0 * 1.207^2/2g = 0.074 \text{ m}$ | | |
| | $h(Q_{\max H}) = 1.0 * 1.648^2/2g = 0.139 \text{ m}$ | | |
| | (Straight Pipe Loss) | | |
| | $h(Q_{\max D}) = 0.015 * 100/2.5 * 1.207^2/2g = 0.045 \text{ m}$ | | |
| | $h(Q_{\max H}) = 0.015 * 100/2.5 * 1.648^2/2g = 0.083 \text{ m}$ | | |
| | (Water Level) | | |
| | $WL(Q_{\max D}) = + 1.650 + 0.156 + \alpha = + 1.810 \text{ m}$ | | |
| | $WL(Q_{\max H}) = + 1.650 + 0.291 + \alpha = + 1.950 \text{ m}$ | | |

3.2 Disinfection Tank, Outflow Weir Head Loss
(End Point Water Level of Disinfection Tank)

| Item | Unit | QmaxD | QmaxH |
|----------------------------|---|---------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Establishment Number | Number | 1 | 1 |
| Unit Flow | m ³ /s | 5.926 | 8.090 |
| Dimension of Overflow Weir | Suppressed Rectangular Weir B = 5.0m (Fixed Weir) | | |
| Downstream Water Level | m | + 1.810 | + 1.950 |
| Weir Level | m | + 2.000 | |
| Overflow Water Depth | m | 0.746 | 0.918 |
| Water Level | m | + 2.750 | + 2.920 |

| | |
|--------------|---|
| NOTE: | $h = [Q/(1.84 * B)]^{2/3}$ |
| | <p>(Overflow Water Depth) $h(Q_{maxD}) = [5.296/(1.84 * 5.0)]^{2/3} = 0.746 \text{ m}$ $h(Q_{maxH}) = [8.090/(1.84 * 5.0)]^{2/3} = 0.918 \text{ m}$</p> <p>(Water Level) $WL(Q_{maxD}) = + 2.000 + 0.746 + \alpha = + 2.750 \text{ m}$ $WL(Q_{maxH}) = + 2.000 + 0.918 + \alpha = + 2.920 \text{ m}$</p> <p>Comment: In case of H.W.L of discharged river, it is possible to discharge by gravity flow. Because the top level of discharged weir is set higher than the High water level in the discharged pit, therefore, hydraulically, it is separated from discharged river. Therefore, gate at discharged point or closing equipment is not hydraulically necessary.</p> |

3.3 Disinfection Tank Inside Head Loss (Inlet Point Water Level of Disinfection Tank)

| Item | Unit | QmaxD | QmaxH |
|--------------------------------|--------------------|---|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Establishment Number | Number | 1 | 1 |
| Unit Flow | m ³ /s | 5.926 | 8.090 |
| Dimension of Disinfection Tank | - | 5.0m ^(W) * 54.0m ^(L) * 5m ^(H) * 3 bend 4 waterway * 1 tank | |
| Downstream Water Level | m | + 2.750 | + 2.920 |
| Velocity | m/s | 0.237 | 0.313 |
| Head Loss | Straight Pipe Loss | m | 0.001 |
| | Bend Loss | m | 0.012 |
| | Total | m | 0.013 |
| Water Level | m | + 2.770 | + 2.950 |

| | |
|--------------|--|
| NOTE: | $h_L = I * L, I = (Q/K)^2 = [(n * V)/R^{2/3}]^2,$ $R = B * H / (B + 2H), hf = 1.4 * V^2 / 2g * n$ <p>(Velocity) $V = Q/A$ $V(Q_{maxD}) = 5.926 / (5.0 * 5.00) = 0.237 \text{ m/s}$ $V(Q_{maxH}) = 8.090 / (5.0 * 5.17) = 0.313 \text{ m/s}$</p> <p>(Hydraulic Slope) $I(Q_{maxD}) = [(0.013 * 0.237) / 1.667^{2/3}]^2 = 4.803 * 10^{-6}$ $I(Q_{maxH}) = [(0.013 * 0.313) / 1.685^{2/3}]^2 = 9.685 * 10^{-6}$</p> <p>(Hydraulic Radius) $R(Q_{maxD}) = 5.0 * 5.00 / (5.0 + 2 * 5.00) = 1.667 \text{ m}$ $R(Q_{maxH}) = 5.0 * 5.17 / (5.0 + 2 * 5.17) = 1.685 \text{ m}$</p> <p>(Friction Head Loss) $hL(Q_{maxD}) = 4.803 * 10^{-6} * 54.0 * 4 = 0.001 \text{ m}$ $hL(Q_{maxH}) = 9.685 * 10^{-6} * 54.0 * 4 = 0.002 \text{ m}$</p> <p>(Bend Loss) $hf(Q_{maxD}) = 1.4 * 0.237^2 / 2g * 3 = 0.012 \text{ m}$ $hf(Q_{maxH}) = 1.4 * 0.313^2 / 2g * 3 = 0.021 \text{ m}$</p> <p>(Water Level) $WL(Q_{maxD}) = + 2.750 + 0.013 + \alpha = + 2.770 \text{ m}$ $WL(Q_{maxH}) = + 2.920 + 0.023 + \alpha = + 2.950 \text{ m}$</p> <p>(Disinfection Tank Bottom Level) $H = 5.0 \text{ m}$ $BL = + 2.770 - 5.000 = - 2.230 \text{ m}$</p> |
|--------------|--|

3.4 Disinfection Tank Inflow Gate Head Loss
(Inlet Pit Water Level of Disinfection Tank)

| Item | Unit | QmaxD | QmaxH |
|--------------------------|-------------------|--|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Establishment Number | Number | 1 | 1 |
| Unit Flow | m ³ /s | 5.926 | 8.090 |
| Downstream Water Level | m | + 2.770 | + 2.950 |
| Dimension of Inflow Gate | - | 2,000mm ^(W) * 2,000mm ^(H) * 1 Gate | |
| Velocity | m/s | 1.482 | 2.023 |
| Gate Head Loss | m | 0.168 | 0.313 |
| Water Level | m | + 2.940 | + 3.270 |

| | |
|-------|--|
| NOTE: | <p>Bypass Waterway Line (Bypass Gate = 2,000mm * 1 Gate + Stop Log) Inlet gate (2,000mm^(W) * 2,000mm^(H) * 1 Gate) $h = 1.5 * V^2/2g$, or $h = [Q/(0.73 * B * H)]^2 * 1/2g$.</p> |
| | <p>(Velocity) $V = Q/A$ $V(QmaxD) = 5.926/(2.0 * 2.0) = 1.482$ m/s $V(QmaxH) = 8.090/(2.0 * 2.0) = 2.023$ m/s</p> <p>(Gate Head Loss) $h(QmaxD) = 1.5 * 1.482^2/2g = 0.168$ m $h(QmaxH) = 1.5 * 2.023^2/2g = 0.313$ m</p> <p>(Water Level) $WL(QmaxD) = + 2.770 + 0.168 + \alpha = + 2.940$ m $WL(QmaxH) = + 2.950 + 0.313 + \alpha = + 3.270$ m</p> |

3.5 Disinfection Tank ~ Secondary Treatment Water Tank Connection Part Head Loss (Water Level of Secondary Treatment Water Tank)

| Item | Unit | QmaxD | QmaxH |
|---------------------------|-------------------|-------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Establishment Number | Number | 1 | 1 |
| Unit Flow | m ³ /s | 5.926 | 8.090 |
| Downstream Water Level | m | + 2.940 | + 3.270 |
| Dimension of Connection | - | 5.0m ² | |
| Section Area | m ² | 25.0 | |
| Connection Method | - | Direct Connection | |
| Velocity | m/s | 0.237 | 0.324 |
| Connection Part Head Loss | m | 0.004 | 0.008 |
| Water Level | m | + 2.950 | + 3.280 |

| | |
|-------|--|
| NOTE: | $V = Q/A, h = 1.5 * V^2/2g$ |
| | (Section Area) |
| | $A = 5.0 * 5.0 = 25.0 \text{ m}^2$ |
| | (Velocity) |
| | $V(Q_{\text{maxD}}) = 5.926/25.0 = 0.237 \text{ m/s}$ |
| | $V(Q_{\text{maxH}}) = 8.090/25.0 = 0.324 \text{ m/s}$ |
| | (Connected Part Head Loss) |
| | $h(Q_{\text{maxD}}) = 1.5 * 0.237^2/2g = 0.004 \text{ m}$ |
| | $h(Q_{\text{maxH}}) = 1.5 * 0.324^2/2g = 0.008 \text{ m}$ |
| | (Water Level) |
| | $WL(Q_{\text{maxD}}) = + 2.940 + 0.004 + \alpha = + 2.950 \text{ m}$ |
| | $WL(Q_{\text{maxH}}) = + 3.270 + 0.008 + \alpha = + 3.280 \text{ m}$ |

3.6 Secondary Treatment Water Tank ~ Final Sedimentation Tank, Outflow Pit
Connection Pipe Head Loss (Final Sedimentation Tank Outflow Pit Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------------|-------------------|----------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Establishment Number | Number | 1 | 1 |
| Unit Flow | m ³ /s | 5.926 | 8.090 |
| Downstream Water Level | m | + 2.950 | + 3.280 |
| Dimension of Pipe Connection | mm | ⊙2,500 (SP) * 1 pipe | |
| Section Area | m ² | 4.909 | |
| Length | m | About 65 | |
| Velocity | m/s | 1.207 | 1.648 |
| Connection Pipe Head Loss | m | 0.140 | 0.262 |
| Water Level | m | + 3.090 | + 3.550 |

| | |
|-------|---|
| NOTE: | $h_c = (1.5 + \delta * L/D) * V^2/2g$, $R = D/4 = 2.5/4 = 0.625$ $\delta = 8 * g * n^2/R^{1/3}$, $n = 0.013$ |
| | <p>(Section Area) $A = \pi * 2.5^2 * 1/4 = 4.909 \text{ m}^2$</p> <p>(Velocity) $V(Q_{\text{maxD}}) = 5.926/4.909 = 1.207 \text{ m}$ $V(Q_{\text{maxH}}) = 8.090/4.909 = 1.648 \text{ m}$</p> <p>(Connection Pipe Head Loss) $\delta = 8 * 9.8 * 0.013^2/0.625^{1/3} = 0.015$ $h(Q_{\text{maxD}}) = (1.5 + 0.015 * 65/2.5) * 1.207^2/2g = 0.140 \text{ m}$ $h(Q_{\text{maxH}}) = (1.5 + 0.015 * 65/2.5) * 1.648^2/2g = 0.262 \text{ m}$</p> <p>(Water Level) $WL(Q_{\text{maxD}}) = + 2.950 + 0.140 + \alpha = + 3.090 \text{ m}$ $WL(Q_{\text{maxH}}) = + 3.280 + 0.262 + \alpha = + 3.550 \text{ m}$</p> |

3.7 Final Sedimentation Tank, Outflow Waterway Head Loss
(Final Sedimentation Tank, Outflow Waterway, Upstream Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------|---|---------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Process of Calculation | Normally the Head Loss of waterway system is high, if all the waterway is designed by open waterway, therefore the combination system of pressure pipe and open waterway are used for designing. Head Loss is calculated by longest waterway for fail-safety. | | |

(8/8Q) To Secondary Treatment Water Tank

(Open waterway) B = 2.0m

Final S.T

AT

Primary S.T

Primary ST

AT

Final S.T

Pressure Pipe = 2.0m

(Open waterway) B = 2.0m

(H) (G) (F) (E)

(A) = 5/8Q

(B) Bend 90°

(C) = 4/8Q

(D) Bend 90°

| | |
|--|---|
| | Distribution Tank (4 Division * 2 trains) |
| | Bypass Waterway (Open), B = 1.5 m |

| | |
|----------------------|----------------------------------|
| (A) Division: 5/8 Q; | L □ 100 m (About) |
| (B) 90° Bend: 4/8 Q; | Pit |
| (C) Division: 4/8 Q; | L □ 185 m (About), Pressure Pipe |
| (D) 90° Bend: 4/8 Q; | Pit |
| (E) Division: 4/8 Q; | L □ 120 m (About) |
| (F) Division: 3/8 Q; | L □ 120 m (About) |
| (G) Division: 2/8 Q; | L □ 120 m (About) |
| (H) Division: 1/8 Q; | L □ 120 m (About) |

(1) Part (A) Critical Depth (Part (A) Downstream Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------|-------------------|-------------------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Flow Rate | - | 5/8 Q | 5/8 Q |
| Unit Flow | m ³ /s | 3.704 | 5.056 |
| Downstream Water Level | m | + 3.090 | + 3.550 |
| Dimension of Waterway | - | 2.0 m ^w * 1 (open) | |
| Critical Depth | m | 0.727 | 0.895 |
| Bottom Level | m | + 2.700 | |
| Water Level | m | + 3.430 | + 3.600 |

| | |
|-------|--|
| NOTE: | $h = [1.10 * Q^2 / (g * B^2)]^{1/3}$ |
| | (Critical Depth) |
| | $h(Q_{maxD}) = [1.10 * 3.704^2 / (9.8 * 2.0^2)]^{1/3} = 0.727 \text{ m}$ |
| | $h(Q_{maxH}) = [1.10 * 5.056^2 / (9.8 * 2.0^2)]^{1/3} = 0.895 \text{ m}$ |
| | (Water Level) |
| | $WL(Q_{maxD}) = + 2.700 + 0.727 + \alpha = + 3.430 \text{ m}$ |
| | $WL(Q_{maxH}) = + 2.700 + 0.895 + \alpha = + 3.600 \text{ m}$ |

(2) Part (A) Friction Head Loss (Part (A) Upstream Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------|-------------------|------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Flow Rate | Number | 5/8 Q | 5/8 Q |
| Unit Flow | m ³ /s | 3.704 | 5.056 |
| Downstream Water Level | m | + 3.430 | + 3.600 |
| Dimension of Waterway | - | 2.0 m * 1 (open) | |
| Length | m | About 100 | |
| Water Depth | m | 0.730 | 0.900 |
| Velocity | m/s | 2.537 | 2.809 |
| Bottom Level | m | + 2.700 | |
| Friction Head Loss | m | 0.344 | 0.361 |
| Water Level | m | + 3.780 | + 3.970 |

| | |
|-------|--|
| NOTE: | $V = Q/A$; $I = [(n * V)/R^{2/3}]^2$; $h = I * L$ $R = B * H / (B + 2H)$; $n = 0.013$ |
| | <p>(Velocity) $V(Q_{maxD}) = 3.704 / (2.0 * 0.730) = 2.537 \text{ m/sec}$ $V(Q_{maxH}) = 5.056 / (2.0 * 0.900) = 2.809 \text{ m/sec}$</p> <p>(Hydraulic Radius) $R(Q_{maxD}) = 2.0 * 0.730 / (2 + 2 * 0.730) = 0.422 \text{ m}$ $R(Q_{maxH}) = 2.0 * 0.900 / (2 + 2 * 0.900) = 0.474 \text{ m}$</p> <p>(Hydraulic Slope) $I(Q_{maxD}) = [0.013 * 2.537 / 0.422^{2/3}]^2 = 3.436 * 10^{-3}$ $I(Q_{maxH}) = [0.013 * 2.809 / 0.474^{2/3}]^2 = 3.608 * 10^{-3}$</p> <p>(Friction Head Loss) $h(Q_{maxD}) = 3.436 * 10^{-3} * 100 = 0.344 \text{ m}$ $h(Q_{maxH}) = 3.608 * 10^{-3} * 100 = 0.361 \text{ m}$</p> <p>(Water Level) $WL(Q_{maxD}) = + 3.430 + 0.344 + \alpha = + 3.780 \text{ m}$ $WL(Q_{maxH}) = + 3.600 + 0.361 + \alpha = + 3.970 \text{ m}$</p> |

(3) Part (B): 90° Bend Head Loss (Part (B) Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------|-------------------|---------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Flow Rate | - | 4/8 Q | 4/8 Q |
| Unit Flow | m ³ /s | 2.963 | 4.045 |
| Downstream Water Level | m | + 3.780 | + 3.970 |
| Head Loss | m | 0 | 0 |
| Water Level | m | + 3.780 | + 3.970 |

| | |
|-------|--|
| NOTE: | <p>90° Bend Head Loss at pit "part (B)" is neglected, because a bottom elevation of the pit is designed to the same level as invert of Pressure Pipe.</p> <p>However Head Loss Inlet and Outlet, and Friction Loss of Pressure Pipe is considered.</p> |
|-------|--|

(4) Part (C): Pressure Conduit Pipe Head Loss (Part (C) Upstream Water Level)

| Item | | Unit | QmaxD | QmaxH |
|----------------------------|--------------------|-------------------|--|---------|
| Quantity | | m ³ /d | 512,000 | 699,000 |
| | | m ³ /s | 5.926 | 8.090 |
| Flow Rate | Number | | 4/8 Q | 4/8 Q |
| Unit Flow | | m ³ /s | 2.963 | 4.045 |
| Downstream Water Level | | m | + 3.780 | + 3.970 |
| Dimension of Pressure Pipe | | - | 2.0 m ^(W) *2.0 m ^(D) * 1 (Pressure Conduit Pipe) | |
| Section Area | | m ² | 4.000 | |
| Length | | m | About 185 | |
| Velocity | | m/s | 0.741 | 1.011 |
| Head Loss | Inlet/Outlet Loss | m | 0.042 | 0.078 |
| | Straight Pipe Loss | m | 0.029 | 0.055 |
| | Total | m | 0.071 | 0.133 |
| Water Level | | m | + 3.860 | + 4.110 |

| | | | |
|-------|--|--|--|
| NOTE: | $h = 1.5 * V^2 / 2g$, $hf = (n^2 * V^2 * L) / R^{4/3}$ $R = B * H / (B + 2H)$; $V = Q / A$; $n = 0.013$ | | |
| | (Section Area) | | |
| | $A = 2.0 * 2.0 = 4.000 \text{ m}^2$ | | |
| | (Velocity) | | |
| | $V(Q_{\text{maxD}}) = 2.963 / 4.000 = 0.741 \text{ m/s}$ | | |
| | $V(Q_{\text{maxH}}) = 4.045 / 4.000 = 1.011 \text{ m/s}$ | | |
| | (Hydraulic Radius) | | |
| | $R = 2.0 * 2.0 / (2.0 + 2 * 2.0) = 0.667 \text{ m}$ | | |
| | (Inlet and Outlet Loss) | | |
| | $h(Q_{\text{maxD}}) = 1.5 * 0.741^2 / 2g = 0.042 \text{ m}$ $h(Q_{\text{maxH}}) = 1.5 * 1.011^2 / 2g = 0.078 \text{ m}$ | | |
| | (Straight Loss) | | |
| | $hf(Q_{\text{maxD}}) = (0.013^2 * 0.741^2 * 185) / 0.667^{4/3} = 0.029 \text{ m}$ $hf(Q_{\text{maxH}}) = (0.013^2 * 1.011^2 * 185) / 0.667^{4/3} = 0.055 \text{ m}$ | | |
| | (Water Level) | | |
| | $WL(Q_{\text{maxD}}) = + 3.780 + 0.071 + \alpha = + 3.860 \text{ m}$ | | |
| | $WL(Q_{\text{maxH}}) = + 3.970 + 0.133 + \alpha = + 4.110 \text{ m}$ | | |

(5) Part (D): 90° Bend Head Loss (Part (D) Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------|-------------------|---------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Flow Rate | - | 4/8 Q | 4/8 Q |
| Unit Flow | m ³ /s | 2.963 | 4.045 |
| Downstream Water Level | m | + 3.860 | + 4.110 |
| Head Loss | m | 0 | 0 |
| Water Level | m | + 3.860 | + 4.110 |

NOTE:

The Bend Loss will be neglected, because upstream of the bend is open Waterway. However Head Loss of Inlet, Outlet and Loss of Pressure Pipe is considered.

(6) Part (E) Critical Depth (Part (E) Downstream Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------|-------------------|-------------------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Flow Rate | - | 4/8 Q | 4/8 Q |
| Unit Flow | m ³ /s | 2.963 | 4.045 |
| Downstream Water Level | m | + 3.860 | + 4.110 |
| Dimension of Waterway | - | 2.0 m ^w * 1 (open) | |
| Critical Depth | m | 0.627 | 0.771 |
| Bottom Level | m | + 3.400 | |
| Water Level | m | + 4.030 | + 4.180 |

| | |
|-------|--|
| NOTE: | $h = [1.10 * Q^2 / (g * B^2)]^{1/3}$ |
| | <p>(Critical Depth)</p> <p>$h(Q_{maxD}) = [1.10 * 2.963^2 / (9.8 * 2.0^2)]^{1/3} = 0.627 \text{ m}$</p> <p>$h(Q_{maxH}) = [1.10 * 4.045^2 / (9.8 * 2.0^2)]^{1/3} = 0.771 \text{ m}$</p> <p>(Water Level)</p> <p>$WL(Q_{maxD}) = + 3.400 + 0.627 + \alpha = + 4.030 \text{ m}$</p> <p>$WL(Q_{maxH}) = + 3.400 + 0.771 + \alpha = + 4.180 \text{ m}$</p> |

(7) Part (E) Friction Head Loss (Part (E) Upstream Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------|-------------------|-------------------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Flow Rate | Number | 4/8 Q | 4/8 Q |
| Unit Flow | m ³ /s | 2.963 | 4.045 |
| Downstream Water Level | m | + 4.030 | + 4.180 |
| Dimension of Waterway | - | 2.0 m ^w * 1 (open) | |
| Length | m | About 120 | |
| Water Depth | m | 0.630 | 0.780 |
| Velocity | m/s | 2.352 | 2.593 |
| Bottom Level | m | + 3.400 | |
| Friction Head Loss | m | 0.398 | 0.410 |
| Water Level | m | + 4.430 | + 4.590 |

| | |
|-------|--|
| NOTE: | $V = Q/A$; $I = [(n * V)/R^{2/3}]^2$; $h = I * L$ $R = B * H / (B + 2H)$; $n = 0.013$ |
| | <p>(Velocity) $V(Q_{maxD}) = 2.963 / (2.0 * 0.630) = 2.352 \text{ m/s}$ $V(Q_{maxH}) = 4.045 / (2.0 * 0.780) = 2.593 \text{ m/s}$</p> <p>(Hydraulic Radius) $R(Q_{maxD}) = 2.0 * 0.630 / (2 + 2 * 0.630) = 0.387 \text{ m}$ $R(Q_{maxH}) = 2.0 * 0.780 / (2 + 2 * 0.780) = 0.438 \text{ m}$</p> <p>(Hydraulic Slope) $I(Q_{maxD}) = [0.013 * 2.352 / 0.387^{2/3}]^2 = 3.315 * 10^{-3}$ $I(Q_{maxH}) = [0.013 * 2.539 / 0.438^{2/3}]^2 = 3.416 * 10^{-3}$</p> <p>(Friction Head Loss) $h(Q_{maxD}) = 3.315 * 10^{-3} * 120 = 0.398 \text{ m}$ $h(Q_{maxH}) = 3.416 * 10^{-3} * 120 = 0.410 \text{ m}$</p> <p>(Water Level) $WL(Q_{maxD}) = + 4.030 + 0.398 + \alpha = + 4.430 \text{ m}$ $WL(Q_{maxH}) = + 4.180 + 0.410 + \alpha = + 4.590 \text{ m}$</p> |

(8) Part (F) Friction Head Loss (Part (F) Upstream Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------|-------------------|-------------------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Flow Rate | Number | 3/8Q | 3/8Q |
| Unit Flow | m ³ /s | 2.222 | 3.034 |
| Downstream Water Level | m | + 4.430 | + 4.590 |
| Dimension of Waterway | - | 2.0 m ^w * 1 (open) | |
| Length | m | About 120 | |
| Water Depth | m | 1.030 | 1.190 |
| Velocity | m/s | 1.079 | 1.275 |
| Bottom Level | m | + 3.400 | |
| Friction Head Loss | m | 0.058 | 0.074 |
| Water Level | m | + 4.490 | + 4.670 |

| | |
|--------------|--|
| NOTE: | $V = Q/A$; $I = [(n*V)/R^{2/3}]^2$; $h = I*L$ $R = B*H/(B+2H)$; $n = 0.013$ |
| | <p>(Velocity) $V(Q_{maxD}) = 2.222/(2.0*1.030) = 1.079 \text{ m/s}$ $V(Q_{maxH}) = 3.034/(2.0*1.190) = 1.275 \text{ m/s}$</p> <p>(Hydraulic Radius) $R(Q_{maxD}) = 2.0*1.030/(2+2*1.030) = 0.507 \text{ m}$ $R(Q_{maxH}) = 2.0*1.190/(2+2*1.190) = 0.543 \text{ m}$</p> <p>(Hydraulic Slope) $I(Q_{maxD}) = [0.013*1.079/0.507^{2/3}]^2 = 4.867 * 10^{-4}$ $I(Q_{maxH}) = [0.013*1.275/0.543^{2/3}]^2 = 6.202 * 10^{-4}$</p> <p>(Friction Head Loss) $h(Q_{maxD}) = 4.867 * 10^{-4} * 120 = 0.058 \text{ m}$ $h(Q_{maxH}) = 6.202 * 10^{-4} * 120 = 0.074 \text{ m}$</p> <p>(Water Level) $WL(Q_{maxD}) = + 4.430 + 0.058 + \alpha = + 4.490 \text{ m}$ $WL(Q_{maxH}) = + 4.590 + 0.074 + \alpha = + 4.670 \text{ m}$</p> |

(9) Part (G) Friction Head Loss (Part (G) Upstream Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------|-------------------|-----------------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Flow Rate | Number | 2/8Q | 2/8Q |
| Unit Flow | m ³ /s | 1.482 | 2.023 |
| Downstream Water Level | m | + 4,490 | + 4,670 |
| Dimension of Waterway | - | 2.0 m ^w * (open) | |
| Length | m | About 120 | |
| Water Depth | m | 1.090 | 1.270 |
| Velocity | m/s | 0.680 | 0.796 |
| Bottom Level | m | + 3,400 | |
| Friction Head Loss | m | 0.022 | 0.028 |
| Water Level | m | + 4,520 | + 4,700 |

| | |
|-------|---|
| NOTE: | $V = Q/A$; $I = [(n*V)/R^{2/3}]^2$; $h = I*L$ |
| | $R = B*H/(B+2H)$; $n = 0.013$ |
| | (Velocity) |
| | $V(Q_{maxD}) = 1.482/(2.0*1.090) = 0.680 \text{ m/s}$ |
| | $V(Q_{maxH}) = 2.023/(2.0*1.270) = 0.796 \text{ m/s}$ |
| | (Hydraulic Radius) |
| | $R(Q_{maxD}) = 2.0*1.090/(2+2*1.090) = 0.522 \text{ m}$ |
| | $R(Q_{maxH}) = 2.0*1.270/(2+2*1.270) = 0.559 \text{ m}$ |
| | (Hydraulic Slope) |
| | $I(Q_{maxD}) = [0.013*0.680/0.522^{2/3}]^2 = 1.859 * 10^{-4}$ |
| | $I(Q_{maxH}) = [0.013*0.796/0.559^{2/3}]^2 = 2.325 * 10^{-4}$ |
| | (Friction Head Loss) |
| | $h(Q_{maxD}) = 1.859 * 10^{-4} * 120 = 0.022 \text{ m}$ |
| | $h(Q_{maxD}) = 2.325 * 10^{-4} * 120 = 0.028 \text{ m}$ |
| | (Water Level) |
| | $WL(Q_{maxD}) = + 4,490 + 0.022 + \alpha = + 4,520 \text{ m}$ |
| | $WL(Q_{maxH}) = + 4,670 + 0.028 + \alpha = + 4,700 \text{ m}$ |

(10) Part (II) – Friction Head Loss (Part (II) - Upstream Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------|-------------------|-------------------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Flow Rate | Number | 1/8 Q | 1/8 Q |
| Unit Flow | m ³ /s | 0.741 | 1.011 |
| Downstream Water Level | m | + 4.520 | + 4.700 |
| Dimension of Waterway | - | 2.0 m ^w * 1 (open) | |
| Length | m | About 120 | |
| Water Depth | m | 1.120 | 1.300 |
| Velocity | m/s | 0.331 | 0.389 |
| Bottom Level | m | + 3.400 | |
| Friction Head Loss | m | 0.005 | 0.007 |
| Water Level | m | + 4.530 | + 4.710 |

| | |
|-------|--|
| NOTE: | $V = Q/A$; $I = [(n * V)/R^{2/3}]^2$; $h = I * L$ $R = B * H/(B+2H)$; $n = 0.013$ |
| | (Velocity) $V(Q_{maxD}) = 0.741/(2.0*1.120) = 0.331 \text{ m/s}$ $V(Q_{maxH}) = 1.011/(2.0*1.300) = 0.389 \text{ m/s}$ |
| | (Hydraulic Radius) $R(Q_{maxD}) = 2.0 * 1.120/(2.0 + 2 * 1.120) = 0.528 \text{ m}$ $R(Q_{maxH}) = 2.0 * 1.300/(2.0 + 2 * 1.300) = 0.565 \text{ m}$ |
| | (Hydraulic Slope) $I(Q_{maxD}) = [0.013*0.331/0.528^{2/3}]^2 = 4.339 * 10^{-5}$ $I(Q_{maxH}) = [0.013*0.389/0.565^{2/3}]^2 = 5.475 * 10^{-5}$ |
| | (Friction Head Loss) $h(Q_{maxD}) = 4.339 * 10^{-5} * 120 = 0.005 \text{ m}$ $h(Q_{maxH}) = 5.475 * 10^{-5} * 120 = 0.007 \text{ m}$ |
| | (Water Level) $WL(Q_{maxD}) = + 4.520 + 0.005 + \alpha = + 4.530 \text{ m}$ $WL(Q_{maxH}) = + 4.700 + 0.007 + \alpha = + 4.710 \text{ m}$ |
| | |
| | |
| | |
| | |

3.8 Final Sedimentation Tank, Outflow Trough Head Loss (Trough Upstream Water Level): Free Overflow

| Item | Unit | QmaxD | QmaxH |
|------------------------|-------------------|------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Establishment Number | Number | 20*8*2=320 | 320 |
| Unit Flow | m ³ /s | 0.019 | 0.025 |
| Downstream Water Level | m | + 4.530 | + 4.710 |
| Trough Width | m | 0.500 | |
| Trough Bottom Level | m | + 4.800 | |
| Trough Bottom Slope | % | i = 0 | |
| Trough Head Loss | m | 0.095 | 0.113 |
| Water Level | m | + 4.900 | + 4.920 |

| | |
|-------|--|
| NOTE: | $h_c = [1.10 * Q^2 / (g * B^2)]^{1/3}$, $h_o = \sqrt{3} * h_c$ (Free Overflow) |
| | <p>(Critical Depth)</p> $h_c (Q_{maxD}) = [1.10 * 0.019^2 / (9.8 * 0.5^2)]^{1/3} = 0.055 \text{ m}$ $h_c (Q_{maxH}) = [1.10 * 0.025^2 / (9.8 * 0.5^2)]^{1/3} = 0.065 \text{ m}$ |
| | <p>(Trough Head Loss)</p> $h_o(Q_{maxD}) = \sqrt{3} * 0.055 = 0.095 \text{ m}$ $h_o(Q_{maxH}) = \sqrt{3} * 0.065 = 0.113 \text{ m}$ |
| | <p>(Water Level)</p> $WL(Q_{maxD}) = + 4.800 + 0.095 + \alpha = + 4.900 \text{ m}$ $WL(Q_{maxH}) = + 4.800 + 0.113 + \alpha = + 4.920 \text{ m}$ |

3.9 Final Sedimentation Tank, Triangular Notch Head Loss
(Final Sedimentation Tank, Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------|-------------------|--------------------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Establishment Number | Number | 20*8=160 | 160 |
| Unit Flow | m ³ /s | 0.037 | 0.051 |
| Downstream Water Level | m | + 4.900 | + 4.920 |
| Triangular Notch Form | - | Wear Plate (Triangular Weir) | |
| Notch Degree | No/m | 7 (Trough L = 27.0 m/waterway) | |
| Number of Notch | Number/waterway | 7 * 27.0 = 189 | |
| Bottom Level | m | + 5.000 | |
| Overflow Depth | m | 0.029 | 0.032 |
| Water Level | m | + 5.030 | + 5.040 |

| | |
|-------|--|
| NOTE: | $h = (q/1.42)^{2/5}$ |
| | (Quantity per Notch) |
| | $V(Q_{maxD}) = 0.037/189 = 1.958 * 10^{-4} \text{ m}^3/\text{s}$ |
| | $V(Q_{maxH}) = 0.051/189 = 2.698 * 10^{-4} \text{ m}^3/\text{s}$ |
| | (Overflow Depth) |
| | $h(Q_{maxD}) = [(1.958 * 10^{-4}) / 1.42]^{2/5} = 0.029 \text{ m}$ |
| | $h(Q_{maxH}) = [(2.698 * 10^{-4}) / 1.42]^{2/5} = 0.032 \text{ m}$ |
| | (Water Level) |
| | $WL(Q_{maxD}) = + 5.000 + 0.029 + \alpha = + 5.030 \text{ m}$ |
| | $WL(Q_{maxH}) = + 5.000 + 0.032 + \alpha = + 5.040 \text{ m}$ |
| | (Final Sedimentation Tank Bottom Level) II = 3.5 m |
| | BL = + 5.030 - 3.500 = + 1.530 (most shallow point) |

3.10 Final Sedimentation Tank, Inflow Gate Head Loss
(Final Sedimentation Tank, Upstream Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------|-------------------|--|-----------|
| Quantity | m ³ /d | 1,024,000 | 1,211,000 |
| | m ³ /s | 11.852 | 14.016 |
| Establishment Number | Number | 10*8=80 | 80 |
| Unit Flow | m ³ /s | 0.148 | 0.175 |
| Downstream Water Level | m | + 5.030 | + 5.040 |
| Dimension of Gate | - | 500mm ^(W) * 500mm ^(H) * 80 pcs | |
| Velocity | m/s | 0.592 | 0.700 |
| Gate Head Loss | m | 0.027 | 0.038 |
| Water Level | m | + 5.060 | + 5.080 |

| | |
|--------------|--|
| NOTE: | Return Sludge = QmaxD * 100% (Max) $h = 1.5 * V^2 / 2g$, $V = Q/A$ |
| | (Velocity) $V(QmaxD) = 0.148 / (0.5 * 0.5) = 0.592 \text{ m/s}$ $V(QmaxH) = 0.175 / (0.5 * 0.5) = 0.700 \text{ m/s}$ (Gate Head Loss) $h(QmaxD) = 1.5 * 0.592^2 / 2g = 0.027 \text{ m}$ $h(QmaxH) = 1.5 * 0.700^2 / 2g = 0.038 \text{ m}$ (Water Level) $WL(QmaxD) = + 5.030 + 0.027 + \alpha = + 5.060 \text{ m}$ $WL(QmaxH) = + 5.040 + 0.038 + \alpha = + 5.080 \text{ m}$ |

3.11 Aeration Tank, Overflow Weir Head Loss (Aeration Tank, Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------|-------------------|--------------------------------------|-----------|
| Quantity | m ³ /d | 1,024,000 | 1,211,000 |
| | m ³ /s | 11.852 | 14.016 |
| Establishment Number | Number | 10*8=80 | 80 |
| Unit Flow | m ³ /s | 0.148 | 0.175 |
| Downstream Water Level | m | + 5.060 | + 5.080 |
| Overflow Weir Form | - | Suppressed Rectangle Weir, B = 8.25m | |
| Weir Level | m | + 5.200 | |
| Overflow Depth | m | 0.046 | 0.051 |
| Water Level | m | + 5.250 | + 5.260 |

| | |
|--------------|---|
| NOTE: | $h = [Q/(1.84 * B)]^{2/3}$ |
| | (Overflow Depth) |
| | $h(Q_{maxD}) = [0.148/(1.84 * 8.25)]^{2/3} = 0.046 \text{ m}$ |
| | $h(Q_{maxH}) = [0.175/(1.84 * 8.25)]^{2/3} = 0.051 \text{ m}$ |
| | (Water Level) |
| | $WL(Q_{maxD}) = + 5.200 + 0.046 + \alpha = + 5.250 \text{ m}$ |
| | $WL(Q_{maxH}) = + 5.200 + 0.051 + \alpha = + 5.260 \text{ m}$ |
| | (Aeration Tank, Bottom Level) H = 5.5 m |
| | $BL = + 5.250 - 5.500 = - 0.250 \text{ m}$ |

3.12 Aeration Tank, Inflow Movable Weir Head Loss
(Aeration Tank, Inflow Waterway Water Level)

| Item | Unit | QmaxD | QmaxH |
|----------------------------------|-------------------|-------------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Establishment Number | Number | 10*8=80 | 80 |
| Unit Flow | m ³ /s | 0.074 | 0.101 |
| Downstream Water Level | m | + 5.250 | + 5.260 |
| Dimension of Inflow Movable Weir | - | Movable Weir, B = 500mm | |
| Weir Level | m | + 5.500 | |
| Overflow Depth | m | 0.186 | 0.229 |
| Water Level | m | + 5.690 | + 5.730 |

| | |
|-------|--|
| NOTE: | $h = [Q/(1.84 * B)]^{2/3}$ |
| | <p>(Overflow Depth) $h(Q_{maxD}) = [0.074/(1.84 * 0.5)]^{2/3} = 0.186 \text{ m}$ $h(Q_{maxH}) = [0.101/(1.84 * 0.5)]^{2/3} = 0.229 \text{ m}$</p> <p>(Water Level) $WL(Q_{maxD}) = + 5.500 + 0.186 + \alpha = + 5.690 \text{ m}$ $WL(Q_{maxH}) = + 5.500 + 0.229 + \alpha = + 5.730 \text{ m}$</p> |

3.13 Aeration Tank, Step Movable Weir Head Loss
(Aeration Tank, Step Waterway Level)

| Item | Unit | QmaxD | QmaxH |
|--------------------------------|-------------------|---|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Establishment Number | Number | 80*4=320 | 320 |
| Unit Flow | m ³ /s | 0.019 | 0.025 |
| Downstream Water Level | m | + 5.250 | + 5.260 |
| Dimension of Step Movable Weir | - | Movable Weir, B = 500mm * 4 places/tank (4 Point Step) | |
| Weir Level | m | + 5.500 | |
| Overflow Depth | m | 0.075 | 0.090 |
| Water Level | m | + 5.580 | + 5.590 |

| | |
|-------|--|
| NOTE: | $h = [Q / (1.84 * B)]^{2/3}$ |
| | (Overflow Depth) |
| | $h(Q_{maxD}) = [0.019 / (1.84 * 0.5)]^{2/3} = 0.075 \text{ m}$ |
| | $h(Q_{maxH}) = [0.025 / (1.84 * 0.5)]^{2/3} = 0.090 \text{ m}$ |
| | (Water Level) |
| | $WL(Q_{maxD}) = + 5.500 + 0.075 + \alpha = + 5.580 \text{ m}$ |
| | $WL(Q_{maxH}) = + 5.500 + 0.090 + \alpha = + 5.590 \text{ m}$ |

3.14 Primary Sedimentation Tank, Outflow Trough Head Loss (Primary Sedimentation Tank, Outflow Trough Upstream Water Level): Free Overflow

| Item | Unit | QmaxD | QmaxH |
|-----------------------------------|-------------------|------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Establishment Number | Number | 20*8*2=320 | 320 |
| Unit Flow | m ³ /s | 0.019 | 0.025 |
| Downstream Water Level | m | + 5.690 | + 5.730 |
| Trough Width | m | 0.500 | |
| Trough Bottom Level | m | + 5.800 | |
| Trough Bottom Slope | % | i = 0 | |
| Critical Depth & Trough Head Loss | m | 0.094 | 0.113 |
| Water Level | m | + 5.900 | + 5.920 |

| | |
|-------|---|
| NOTE: | $h = \sqrt{3} * [1.10 * Q^2 / (g * B^2)]^{1/3} = \text{Free Overflow}$ |
| | (Critical Depth and Trough Head Loss) |
| | $h_o(Q_{\max D}) = \sqrt{3} * [1.10 * 0.019^2 / (9.8 * 0.5^2)]^{1/3} = 0.094 \text{ m}$ |
| | $h_o(Q_{\max H}) = \sqrt{3} * [1.10 * 0.025^2 / (9.8 * 0.5^2)]^{1/3} = 0.113 \text{ m}$ |
| | (Water Level) |
| | $WL(Q_{\max D}) = + 5.800 + 0.094 + \alpha = + 5.900 \text{ m}$ |
| | $WL(Q_{\max H}) = + 5.800 + 0.113 + \alpha = + 5.920 \text{ m}$ |

**3.15 Primary Sedimentation Tank Triangular Notch Head Loss
(Primary Sedimentation Tank Water Level)**

| Item | Unit | QmaxD | QmaxH |
|------------------------|-------------------|--------------------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Establishment Number | Number | 20*8=160 | 160 |
| Unit Flow | m ³ /s | 0.037 | 0.051 |
| Downstream Water Level | m | + 5.900 | + 5.920 |
| Triangular Notch Form | - | Wear Plate (Triangular Weir) | |
| Notch Degree | Pitch/m | 7 (Trough, L = 13.0m/waterway) | |
| Number of Notch | Number/waterway | 7 * 13.0 = 91 | |
| Bottom Level | m | + 6.000 | |
| Overflow Depth | m | 0.038 | 0.043 |
| Water Level | m | + 6.040 | + 6.050 |

| | |
|--------------|---|
| NOTE: | $h = (q/1.42)^{2/5}$ |
| | (Overflow Rate per Notch) |
| | $q(Q_{\max D}) = 0.037/91 = 4.066 * 10^{-4} \text{ m}^3/\text{s}$ |
| | $q(Q_{\max H}) = 0.051/91 = 5.604 * 10^{-4} \text{ m}^3/\text{s}$ |
| | (Overflow Depth) |
| | $h(Q_{\max D}) = (4.066 * 10^{-4}/1.42)^{2/5} = 0.038 \text{ m}$ |
| | $h(Q_{\max H}) = (5.604 * 10^{-4}/1.42)^{2/5} = 0.043 \text{ m}$ |
| | (Water Level) |
| | $WL(Q_{\max D}) = + 6.000 + 0.038 + \alpha = + 6.040 \text{ m}$ |
| | $WL(Q_{\max H}) = + 6.000 + 0.043 + \alpha = + 6.050 \text{ m}$ |
| | (Primary Sedimentation Tank Bottom Level) H = 3.0 m |
| | $BL = + 6.040 - 3.000 = + 3.040 \text{ m (most shallow point)}$ |

3.16 Primary Sedimentation Tank, Inflow Movable Weir Head Loss
(Primary Sedimentation Tank, Upstream Water Level)

| Item | Unit | QmaxD | QmaxH |
|----------------------------------|-------------------|-------------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Number | Number | 10*8=80 | 80 |
| Unit Flow | m ³ /s | 0.074 | 0.101 |
| Downstream Water Level | m | + 6.040 | + 6.050 |
| Dimension of Inflow Movable Weir | - | Movable Weir, B = 500mm | |
| Weir Level | m | + 6.200 | |
| Overflow Depth | m | 0.186 | 0.229 |
| Water Level | m | + 6.390 | + 6.430 |

| | |
|-------|---|
| NOTE: | $h = [Q/(1.84 * B)]^{2/3}$ |
| | (Overflow Depth) |
| | $h(Q_{maxD}) = [0.074/(1.84 * 0.5)]^{2/3} = 0.186 \text{ m}$ |
| | $h(Q_{maxH}) = [0.101/(1.84 * 0.5)]^{2/3} = 0.229 \text{ m}$ |
| | (Water Level) |
| | $WL(Q_{maxD}) = + 6.200 + 0.186 + \alpha = + 6.390 \text{ m}$ |
| | $WL(Q_{maxH}) = + 6.200 + 0.229 + \alpha = + 6.430 \text{ m}$ |

3.17 Bypass Waterway Critical Depth
(Part of Final Sedimentation Tank, Downstream Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------------|-------------------|--------------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Establishment Number | Number | 8 | 8 |
| Unit Flow | m ³ /s | 0.741 | 1.011 |
| Downstream Water Level | m | + 4.530 | + 4.710 |
| F.S.T. Waterway Bottom Level | m | + 3.400 | |
| Dimension of Waterway | - | 1.5 m " * 1 (open)/train | |
| Critical Depth | m | 0.301 | 0.371 |
| Bypass Waterway Bottom Level | m | + 4.700 | |
| Water Level | m | + 5.010 | + 5.080 |

| | |
|--------------|--|
| NOTE: | $h = [(1.10 * Q^2) / (g * B^3)]^{1/3}$; |
| | <p>(Critical Depth)</p> <p>$h(Q_{maxD}) = [1.10 * 0.741^2 / 9.8 * 1.5^3]^{1/3} = 0.301 \text{ m}$</p> <p>$h(Q_{maxH}) = [1.10 * 1.011^2 / 9.8 * 1.5^3]^{1/3} = 0.371 \text{ m}$</p> <p>(Water Level)</p> <p>$WL(Q_{maxD}) = + 4.700 + 0.301 + \alpha = + 5.010 \text{ m}$</p> <p>$WL(Q_{maxH}) = + 4.700 + 0.371 + \alpha = + 5.080 \text{ m}$</p> |

3.18 Bypass Waterway Friction Head Loss
(Part of Final Sedimentation Tank, Upstream Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------|-------------------|-------------------------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Establishment Number | Number | 8 | 8 |
| Unit Flow | m ³ /s | 0.741 | 1.011 |
| Downstream Water Level | m | + 5.010 | + 5.080 |
| Dimension of Waterway | - | 1.5 m ^w * 1 (open)/train | |
| Length | m | About 30 | |
| Water Depth | m | 0.310 | 0.380 |
| Velocity | m/s | 1.594 | 1.774 |
| Bottom Level | m | + 4.700 | |
| Friction Head Loss | m | 0.098 | 0.100 |
| Water Level | m | + 5.110 | + 5.180 |

| | |
|--------------|--|
| NOTE: | $V = Q/A$; $I = [(n * V)/R^{2/3}]^2$; $h = I * L$ $R = B * H / (B + 2H)$; $n = 0.013$ |
| | <p>(Velocity) $V(Q_{maxD}) = 0.741 / (1.5 * 0.310) = 1.594 \text{ m/s}$ $V(Q_{maxH}) = 1.011 / (1.5 * 0.380) = 1.774 \text{ m/s}$</p> <p>(Hydraulic Radius) $R(Q_{maxD}) = 1.5 * 0.310 / (1.5 + 2 * 0.310) = 0.219 \text{ m}$ $R(Q_{maxH}) = 1.5 * 0.380 / (1.5 + 2 * 0.380) = 0.252 \text{ m}$</p> <p>(Hydraulic Slope) $I(Q_{maxD}) = [0.013 * 1.594 / 0.219^{2/3}]^2 = 3.253 * 10^{-3}$ $I(Q_{maxH}) = [0.013 * 1.774 / 0.252^{2/3}]^2 = 3.341 * 10^{-3}$</p> <p>(Friction Head Loss) $h(Q_{maxD}) = 3.253 * 10^{-3} * 30 = 0.098 \text{ m}$ $h(Q_{maxH}) = 3.341 * 10^{-3} * 30 = 0.100 \text{ m}$</p> <p>(Water Level) $WL(Q_{maxD}) = + 5.010 + 0.098 + \alpha = + 5.110 \text{ m}$ $WL(Q_{maxH}) = + 5.080 + 0.100 + \alpha = + 5.180 \text{ m}$</p> |

3.19 Bypass Waterway, Critical Depth
(Part of Aeration Tank, Downstream Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------------|-------------------|--------------------------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Establishment Number | Number | 8 | 8 |
| Unit Flow | m ³ /s | 0.741 | 1.011 |
| Downstream Water Level | m | + 5.110 | + 5.180 |
| Dimension of Waterway | - | 1.5 m ^w * 1 (open)/ train | |
| Critical Depth | m | 0.301 | 0.371 |
| Bypass Waterway Bottom Level | m | + 5.200 | |
| Water Level | m | + 5.510 | + 5.580 |

| | |
|-------|--|
| NOTE: | $h = [(1.10 * Q^2) / (g * B^2)]^{1/3};$ |
| | (Critical Depth) |
| | $h(Q_{maxD}) = [1.10 * 0.741^2 / 9.8 * 1.5^2]^{1/3} = 0.301 \text{ m}$ |
| | $h(Q_{maxH}) = [1.10 * 1.011^2 / 9.8 * 1.5^2]^{1/3} = 0.371 \text{ m}$ |
| | (Water Level) |
| | $WL(Q_{maxD}) = + 5.200 + 0.301 + \alpha = + 5.510 \text{ m}$ |
| | $WL(Q_{maxH}) = + 5.200 + 0.371 + \alpha = + 5.580 \text{ m}$ |

3.20 Bypass Waterway Friction Head Loss
(Part of Aeration Tank, Upstream Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------|-------------------|--------------------------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Establishment Number | Number | 8 | 8 |
| Unit Flow | m ³ /s | 0.741 | 1.011 |
| Downstream Water Level | m | + 5.510 | + 5.580 |
| Dimension of Waterway | - | 1.5 m ^w * 1 (open)/ train | |
| Length | m | About 30 | |
| Water Depth | m | 0.310 | 0.380 |
| Velocity | m/s | 1.594 | 1.774 |
| Bottom Level | m | + 5.200 | |
| Friction Head Loss | m | 0.098 | 0.100 |
| Water Level | m | + 5.610 | + 5.680 |

| | |
|-------|--|
| NOTE: | $V = Q/A$; $I = [(n * V)/R^{2/3}]^2$; $h = I * L$ $R = B * H / (B + 2H)$; $n = 0.013$ |
| | <p>(Velocity) $V (Q_{maxD}) = 0.741 / (1.5 * 0.310) = 1.594 \text{ m/s}$ $V (Q_{maxH}) = 1.011 / (1.5 * 0.380) = 1.774 \text{ m/s}$</p> <p>(Hydraulic Radius) $R(Q_{maxD}) = 1.5 * 0.310 / (1.5 + 2 * 0.310) = 0.219 \text{ m}$ $R(Q_{maxH}) = 1.5 * 0.380 / (1.5 + 2 * 0.380) = 0.252 \text{ m}$</p> <p>(Hydraulic Slope) $I(Q_{maxD}) = [0.013 * 1.594 / 0.219^{2/3}]^2 = 3.253 * 10^{-5}$ $I(Q_{maxH}) = [0.013 * 1.774 / 0.252^{2/3}]^2 = 3.341 * 10^{-5}$</p> <p>(Friction Head Loss) $h(Q_{maxD}) = 3.253 * 10^{-5} * 30 = 0.098 \text{ m}$ $h(Q_{maxH}) = 3.341 * 10^{-5} * 30 = 0.100 \text{ m}$</p> <p>(Water Level) $WL(Q_{maxD}) = + 5.510 + 0.098 + \alpha = + 5.610 \text{ m}$ $WL(Q_{maxH}) = + 5.580 + 0.100 + \alpha = + 5.680 \text{ m}$</p> |

3.21 Bypass Waterway Critical Depth
(Part of Primary Sedimentation Tank, Downstream Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------------|-------------------|--------------------------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Establishment Number | Number | 8 | 8 |
| Unit Flow | m ³ /s | 0.741 | 1.011 |
| Downstream Water Level | m | + 5.610 | + 5.680 |
| Dimension of Waterway | - | 1.5 m ^w * 1 (open)/ train | |
| Critical Depth | m | 0.301 | 0.371 |
| Bypass Waterway Bottom Level | m | + 5.700 | |
| Water Level | m | + 6.010 | + 6.080 |

| | |
|-------|--|
| NOTE: | $h = [(1.10 * Q^2) / (g * B^2)]^{1/3}$; |
| | (Critical Depth) |
| | $h(Q_{maxD}) = [1.10 * 0.741^2 / 9.8 * 1.5^2]^{1/3} = 0.301 \text{ m}$ |
| | $h(Q_{maxH}) = [1.10 * 1.011^2 / 9.8 * 1.5^2]^{1/3} = 0.371 \text{ m}$ |
| | (Water Level) |
| | $WL(Q_{maxD}) = + 5.700 + 0.301 + \alpha = + 6.010 \text{ m}$ |
| | $WL(Q_{maxH}) = + 5.700 + 0.371 + \alpha = + 6.080 \text{ m}$ |

3.22 Bypass Waterway, Friction Head Loss
(Part of Primary Sedimentation Tank, Upstream Water Level)

| Item | Unit | QmaxD | Hmax |
|------------------------|-------------------|-------------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Establishment Number | Number | 8 | 8 |
| Unit Flow | m ³ /s | 0.741 | 1.011 |
| Downstream Water Level | m | + 6.010 | + 6.080 |
| Dimension of Waterway | - | 1.5 m * 1 (open)/ train | |
| Length | m | About 15 | |
| Water Depth | m | 0.310 | 0.380 |
| Velocity | m/s | 1.594 | 1.774 |
| Bottom Level | m | + 5.700 | |
| Friction Head Loss | m | 0.049 | 0.050 |
| Water Level | m | + 6.060 | + 6.130 |

| | |
|--------------|--|
| NOTE: | $V = Q/A$; $I = [(n * V)/R^{2/3}]^2$; $h = I * L$ $R = B * H / (B+2H)$; $n = 0.013$ |
| | <p>(Velocity) $V (Q_{maxD}) = 0.741 / (1.5 * 0.310) = 1.594 \text{ m/s}$ $V (Q_{maxH}) = 1.011 / (1.5 * 0.380) = 1.774 \text{ m/s}$</p> <p>(Hydraulic Radius) $R (Q_{maxD}) = 1.5 * 0.310 / (1.5 + 2 * 0.310) = 0.219 \text{ m}$ $R (Q_{maxH}) = 1.5 * 0.380 / (1.5 + 2 * 0.380) = 0.252 \text{ m}$</p> <p>(Hydraulic Slope) $I (Q_{maxD}) = [0.013 * 1.594 / 0.219^{2/3}]^2 = 3.253 * 10^{-3}$ $I (Q_{maxH}) = [0.013 * 1.774 / 0.252^{2/3}]^2 = 3.341 * 10^{-3}$</p> <p>(Friction Head Loss) $h(Q_{maxD}) = 3.253 * 10^{-3} * 15 = 0.049 \text{ m}$ $h(Q_{maxH}) = 3.341 * 10^{-3} * 15 = 0.050 \text{ m}$</p> <p>(Water Level) $WL(Q_{maxD}) = + 6.010 + 0.049 + \alpha = + 6.060 \text{ m}$ $WL(Q_{maxH}) = + 6.080 + 0.050 + \alpha = + 6.130 \text{ m}$</p> |

3.23 Primary Sedimentation Tank, Inflow Waterway Friction Head Loss
(Primary Sedimentation Tank, Inflow Waterway Upstream Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------|-------------------|---------------------------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Establishment Number | Number | 8 | 8 |
| Unit Flow | m ³ /s | 0.741 | 1.011 |
| Downstream Water Level | m | + 6.390 | + 6.430 |
| Dimension of Waterway | - | 1.0 m ^w * 1 (open) / train | |
| Length | m | About 115 | |
| Water Depth | m | 0.590 | 0.630 |
| Velocity | m/s | 1.256 | 1.605 |
| Bottom Level | m | + 5.800 | |
| Friction Head Loss | m | 0.175 | 0.275 |
| Water Level | m | + 6.570 | + 6.710 |

NOTE:

$$I = [(n * V)/R^{2/3}]^2; h = I * L; V = Q/A$$

$$R = B * IL/(B+2H); n = 0.013$$

(Velocity)

$$V(Q_{maxD}) = 0.741/(1.0*0.590) = 1.256 \text{ m/s}$$

$$V(Q_{maxH}) = 1.011/(1.0*0.630) = 1.605 \text{ m/s}$$

(Hydraulic Radius)

$$R(Q_{maxD}) = 1.0*0.590/(1.0+2*0.590) = 0.271 \text{ m}$$

$$R(Q_{maxH}) = 1.0*0.630/(1.0+2*0.630) = 0.279 \text{ m}$$

(Hydraulic Slope)

$$I(Q_{maxD}) = [0.013*1.256/0.271^{2/3}]^2 = 1.520 * 10^{-3}$$

$$I(Q_{maxH}) = [0.013*1.605/0.279^{2/3}]^2 = 2.388 * 10^{-3}$$

(Friction Head Loss)

$$h(Q_{maxD}) = 1.520 * 10^{-3} * 115 = 0.175 \text{ m}$$


$$h(Q_{maxH}) = 2.388 * 10^{-3} * 115 = 0.275 \text{ m}$$

(Water Level)

$$WL(Q_{maxD}) = + 6.390 + 0.175 + \alpha = + 6.570 \text{ m}$$

$$WL(Q_{maxH}) = + 6.430 + 0.275 + \alpha = + 6.710 \text{ m}$$

3.24. Distribution Tank Movable Weir Head Loss
(Distribution tank, Upstream Water Level)

| Item | Unit | QmaxD | QmaxH |
|---|-------------------|---|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Establishment Number | Number | 8 | 8 |
| Unit Flow | m ³ /s | 0.741 | 1.011 |
| Downstream Water Level | m | + 6.570 | + 6.710 |
| Weir Form | - | Movable Weir B = 1.0m (4 Division * 2 Trains) | |
| Weir Level | m | + 6.900 | |
| Overflow Depth | m | 0.545 | 0.671 |
| Water Level | m | + 7.450 | + 7.580 |
| Distribution Tank Plan | | | |
|  | | | |

NOTE:

$$h = [Q / (1.84 * B)]^{2/3}$$

(Overflow Depth)

$$h(Q_{\max D}) = [0.741 / 1.84 * 1.0]^{2/3} = 0.545 \text{ m}$$

$$h(Q_{\max H}) = [1.011 / 1.84 * 1.0]^{2/3} = 0.671 \text{ m}$$

(Water Level)

$$WL(Q_{\max D}) = + 6.900 + 0.545 + \alpha = + 7.450 \text{ m}$$

$$WL(Q_{\max H}) = + 6.900 + 0.671 + \alpha = + 7.580 \text{ m}$$

3.25. Distribution Tank ~ Discharge Tank Connection Pipe Head Loss
(Discharge Tank Water Level)

| Item | Unit | QmaxD | QmaxH |
|------------------------------|-------------------|-------------------------|---------|
| Quantity | m ³ /d | 512,000 | 699,000 |
| | m ³ /s | 5.926 | 8.090 |
| Establishment Number | Number | 2 | 2 |
| Unit Flow | m ³ /s | 2.963 | 4.045 |
| Downstream Water Level | m | + 7.450 | + 7.580 |
| Dimension of Connection Pipe | - | 1,800 mm * 2 trains | |
| Section Area | m ² | 3.240 / train | |
| Length and Bend | m | About 300, 90° bend * 1 | |
| Velocity | m/s | 0.915 | 1.248 |
| Connection Pipe Head Loss | m | 0.084 | 0.156 |
| Bend/Inlet/Outlet Loss | m | 0.107 | 0.199 |
| Total | m | 0.191 | 0.355 |
| Water Level | m | + 7.650 | + 7.940 |

NOTE: $h = (n^2 * V^2 * L) / R^{4/3}$; $R = B * H / (B + 2H)$, $n = 0.013$
 $h = 1.0 * V^2 / 2g * n$; $n = 1$ (90° Bend); $V = Q/A$, $h = 1.5 * V^2 / 2g$

(Section Area)

$$A = 1.8 * 1.8 = 3.240 \text{ m}^2 / \text{train}$$

(Velocity)

$$V(Q_{\max D}) = 2.963 / 3.240 = 0.915 \text{ m/s}$$

$$V(Q_{\max H}) = 4.045 / 3.240 = 1.248 \text{ m/s}$$

(Hydraulic Radius)

$$R = 1.8 * 1.8 / (1.8 + 2 * 1.8) = 0.600 \text{ m}$$

(Connected Pipe Head Loss)

$$h(Q_{\max D}) = (0.013^2 * 0.915^2 * 300) / 0.600^{4/3} = 0.084 \text{ m}$$

$$h(Q_{\max H}) = (0.013^2 * 1.248^2 * 300) / 0.600^{4/3} = 0.156 \text{ m}$$

(Bend Loss) + (Inlet Loss) + (Outlet Loss)

$$h(Q_{\max D}) = 2.5 * 0.915^2 / 2g * 1 = 0.107 \text{ m}$$

$$h(Q_{\max H}) = 2.5 * 1.248^2 / 2g * 1 = 0.199 \text{ m}$$

(Water Level)

$$WL(Q_{\max D}) = + 7.450 + 0.191 + \alpha = + 7.650 \text{ m}$$

$$WL(Q_{\max H}) = + 7.580 + 0.355 + \alpha = + 7.940 \text{ m}$$