

7. Design of Optimum Power Plant

7.1. General Design Concept of Sihanoukville Power Project

The Sihanoukville Power Plant will be designed on the basis of the following design concept:

- **Plant Capacity and Expansion Plan**

The Plant has a capacity of 180 MW but could be expanded to 270 MW capacity in future. However 180 MW plant would be constructed dividing into two stages at an interval of several years. And the time of expansion from 180 MW to 270 MW is expected not in near future but one decade or so after the completion of 180 MW plant.

Then a definition of plant capacity and construction stages are set as follows:

Plant nominal capacity: 180 MW

Definition of construction stages and these capacities:

- The works of first 90 MW capacity plant ; Stage 1
- The works of second 90 MW capacity plant ; Stage 2
- The works of last 90 MW expansion plant ; Stage 3

In this report, the detailed studies including required specifications of equipment, plant layout, construction cost, construction schedule, economic analysis, etc. will be discussed for the first two stages, Stage 1 and Stage 2. However any specific study will not be carried out for Stage 3 except for the issues of environmental impact study and required area space for the final plant.

- **Utilities**

Main utilities required for operation and maintenance of gas turbine combined cycle power plant are fuel(s), electricity, cooling water, plant make-up water, fire-fighting water, miscellaneous chemicals, lubricants, etc.

(i) Fuel(s)

Natural gas is used as main fuel and diesel oil is used as back up fuel. The availability of natural gas is now under study, but the pipeline of gas is expected to come to the plant from west edge of the plant boundary. Diesel oil will be supplied from Sihanoukville Oil Terminal through the oil pipeline, which will run along the railway and reach to the north-west edge of the plant boundary. The gas pipeline will have a capacity for all three stages.

(ii) Electricity

The electric power necessary for normal start-up and normal shutdown operation of the plant will be supplied via step-down transformer from 220 kV transmission line. While, the electric power for normal continuous operation will be fed via step-down transformer from output circuit of the associated generators.

(iii) Cooling Water

The seawater will be used as the cooling medium for the turbine steam condensers. The seawater will be taken from and discharged to the sea in the west of the plant. The cooling water intake and discharged structures will be installed on the seabed of approx. 5 m depth, with enough distance to avoid hot water recirculation. Incoming and outgoing cooling water pipes are located under the seabed and under the ground from the seacoast to the plant with crossing the road and the railroad.

(iv) Plant Make-Up Water

Plant make-up water will be taken from Prey Treng Pond. However the water of Prey Treng Pond is already used by Sokimex Oil Terminal and the near-by residents, in addition, the water flow is not so plenty in dry season. Therefore a raw water storage tank with one month capacity will be provided in the plant.

(v) Fire Fighting Water

The water of Prey Treng Pond will be used for fire fighting. Two fire fighting water pumps, one is of electric motor-driven and the other is of diesel engine-driven, will be installed in the border of the pond.

(vi) Chemicals and Lubricants

Many kinds of chemicals and lubricants are required for operation and maintenance of gas turbine combined cycle power plant.

In Cambodia, all these chemicals and lubricants are assumed to be imported from other countries. Therefore, storage tanks and facilities for several months will be provided in the plant considering a required period for procurement.

- Power Transmission

The plant will be connected to 220 kV double-circuit transmission line. The transmission line will come from Takeo Substation via Kampot and enter into the plant at northeast edge of the plant boundary.

The plant will also provide a connection of high voltage transmission line to the city center of Sihanoukville. This transmission line will run south of the plant.

- Redundancy design philosophy

In general, “N + 1” basis will be applied to the equipment (or system) that is required to be operated continuously for maintaining full-output operation of the plant. Where, “N” is the required numbers of equipment for generating 100 % output of the plant.

However, “N” basis (i.e.. no spare) will be applied to the equipment categorized below:

- Main, but costly equipment, such as:
gas turbine, HRSG, steam turbine, steam condenser, cooling water pump, etc.
- Equipment being unlikely to suffer frequent and/or accidental damages, such as:
piping system, transformer, circuit breaker, etc.
- Equipment being considered not to be essential for continuous operation of the plant, such as:
ventilation and air conditioning system, waste water treatment system, storing equipment, maintenance equipment, equipment for emergency use, etc.

For the control and supervising system, the following philosophy will be applied:

- Local instrument and controls will be single.
- Central control systems which is base on microprocessor technologies will be duplicate for main equipment, such as gas turbine, HRSG, steam turbine, etc.
- Data-way system for communication among the above mentioned central control systems will be duplicate.

- Black Start and Emergency Electric Power Source

Emergency diesel generator will be installed to be able to start of the plant without incoming power supply. And UPS (Uninterruptible Power Supply) system will also be provided for supplying DC power for emergency control and lighting for safety shutdown of the plant.

- Inspection and Maintenance Philosophy

Workshop and chemical laboratory will be provided in the plant.

Normal inspection, maintenance and repairing will be carried out in situ, however a special maintenance for gas turbine will be carried out by gas turbine manufacturer in their factories.

7.2. Basic Design Conditions of Power Plant

7.2.1. Site Conditions

(1) Topography

The site area is generally hilly area covered with grass with elevation of EL. 1.0 m ~ 8.0 m, and a slope of approximately 1/50 - 1/70. Two creeks crossing the site are flow into a pond, that forms a part of southern border of the site area.

(2) Geology

The overburden in the site area is composed of mostly sand and silty sand with partly interbedded clayey layer having thickness of approximately 4 - 26 m. Rather thick overburden has been found in the area between two canals and swamps on southern boundary of the site. The overburden is thinning northwards.

(3) Meteorology

- | | |
|------------------------|--|
| a. Ambient Temperature | 28.8 °C (Ave.), 33.7 °C (Max.), 24.5 °C (Min.) |
| b. Relative Humidity | 86% (Max. monthly ave.), 76% (Min. monthly ave.) |

- c. Rainfall 3,200 mm (Annual ave.), 675 mm (Max. monthly ave.)
45.3 mm/10 min (50 years-return period)
- d. Wind Averaged wind speed : 3 - 6m/sec
Wind direction : W and SW in rainy seasons
N and S in dry season
Maximum wind speed and direction :
24 m/sec, W-NW observed in 1996

(4) Oceanography

(a) Tide Level

| | | |
|---------------------------------|---|-----------------|
| CDL (Chart Datum Level) | = | - 1.07 m + MSL* |
| MHWL (Mean High Water Level) | = | 0.37 m + MSL* |
| MSL (Mean Sea Level) | = | + 0.08 m + MSL* |
| MLWL (Mean Low Water Level) | = | - 0.17 m + MSL* |
| HHWL (Highest High Water Level) | = | + 1.17 m + MSL* |
| LLWL (Lowest Lower Water Level) | = | - 1.06 m + MSL* |

* MSL at Hatien in Vietnam

(b) Wind Wave Height and Period

Probable wind wave with a return period of 50 years estimated as 3.8 m in significant wave height and 6.5 sec as significant wave period.

(5) Site Ground Elevation

The site ground elevation was determined to be 4.1 m + MSL considering the balance of soil for site preparation, safety for the maximum tide level and possible wave run-up height, and siphon limit of cooling water system.

7.2.2. Fuels

(1) Kind of Fuels

Sihanoukville gas turbine combined cycle project will use natural gas as main fuel and diesel oil as standby fuel. Refer to Section 3.1 regarding availability of fuels.

(2) Natural Gas Properties

The anticipated chemical composition and heating value based on typical natural gas are shown in Table 7.2-1.

Table 7.2-1 Properties of Typical Natural Gas

| Components | Unit | |
|--------------------------------|--------------------|--------|
| CO ₂ | vol. % | 1.65 |
| N ₂ | vol. % | 1.92 |
| CH ₄ | vol. % | 95.49 |
| C ₂ H ₆ | vol. % | 0.72 |
| C ₃ H ₈ | vol. % | 0.07 |
| C ₄ H ₁₀ | vol. % | 0.02 |
| C ₅ H ₁₂ | vol. % | 0.10 |
| High Heating Value | kJ/Nm ³ | 38,700 |
| Low Heating Value | kJ/Nm ³ | 34,920 |

(3) Diesel Oil Properties

The anticipated chemical composition and heating value are shown in Table 7.2-2.

Table 7.2-2 Properties of Diesel Oil

| Components | Unit | |
|--------------------|-------|--------|
| Carbon | wt. % | 86.22 |
| Hydrogen | wt. % | 13.10 |
| Oxygen | wt. % | 0.10 |
| Nitrogen | wt. % | 0.08 |
| Sulfur | wt. % | 0.20 |
| Water & Sediment | wt. % | 0.00 |
| Ash | wt. % | 0.00 |
| High Heating Value | kJ/kg | 44,430 |
| Low Heating Value | kJ/kg | 41,470 |

7.2.3. Cooling Water

- (1) **Quality** Sea Water

- (2) **Temperature**
 - Condenser Design Temperature 29°C
 - Permissible Temperature Rise 7°C

- (3) **Water Levels**
 - See Section 7.2.1.(4).

7.2.4. Raw Water

(1) Source

Prey Treng Pond is the most likely fresh water source for the power plant.

(2) Quantity

In dry season, fresh water discharge observed at Prey Treng Pond is approx. 17 lit/sec in the end of February 2001. The quantity of fresh water is enough for the power plants. However, the 1-month reservoirs will be installed against water shortage during dry season considering increase of future fresh water demand for other consumers.

Variation of rainfall in dry season (from November to March) through 1991 to 2001 is as shown in Fig.7.2-1.

Return period of rainfall in dry season of 2001 is calculated as 1.4 year based on the above variation as shown in Table 7.2-3. As a result, the raw water quantity is expected to be supplied mainly from the Prey Treng Pond.

(3) Water Quality

Water analysis of Prey Treng Pond is shown in the Table 7.2-4.

Table 7.2-3 Non-Excess Probability Dry Season Rainfall at Sihanoukville

| Return Period (year) | Probability (%) | Rd (mm) |
|-------------------------|--------------------|------------|
| 20 | 5.00 | 23.51 |
| 10 | 10.00 | 88.74 |
| 5 | 20.00 | 167.69 |
| 3 | 33.33 | 241.46 |
| 2 | 50.00 | 318.75 |
| 1.5 | 66.67 | 396.04 |
| 1.2 | 83.33 | 492.83 |
| 1.1 | 90.91 | 558.42 |

RD : Rainfall in Dry Season (November - March)

Dry year : Probability 10% occurrence of Rd less than 88.74 mm.




Fig.7.2-1 Variation of Rainfall in Dry Season

Table 7.2-4 Quality of Fresh Water

| Parameter | Unit | Dry Season | Rainy Season |
|------------------------|---------------------------------------|-----------------------|--------------|
| Color | - | Yellowish | Yellowish |
| Odor | - | No | No |
| pH | - | 9.0 | 6.9 |
| Salinity | ppt | 0 | 0 |
| Transparency | m | 1.3 | 2.2 |
| Dissolved Oxygen | mg/l | 5.3 | 6.8 |
| Turbidity | NTU | 3.2 | 2.2 |
| Total Hardness | mg/l as CaCO ₃ | 12.0 | 8.1 |
| Total Suspended Solids | mg/l | 1.0 | 2.0 |
| Total Solids | mg/l | 65.0 | 36.0 |
| Carbon Dioxide | mg/l | 2.11 | 2.07 |
| Cations | | | |
| Sodium | mg/l as Na | 3.142 | 2.60 |
| Potassium | mg/l as K | 0.809 | 0.315 |
| Calcium | mg/l as Ca | ND | ND |
| Magnesium | mg/l as Mg | 2.92 | 1.96 |
| Manganese | mg/l as Mn | Limit of Quantitation | ND |
| Iron | mg/l as Fe | 0.918 | 0.731 |
| Ammonia Nitrogen | mg/l as NH ₃ -N | 0.185 | 0.14 |
| Anions | | | |
| Chloride | mg/l as Cl | 4.76 | 5.82 |
| Bicarbonate Alkalinity | mg/l as CaCO ₃ | 12.0 | 2.07 |
| Sulfate | mg/l as SO ₄ ²⁻ | 3.1 | 2.1 |
| Silica | mg/l as SiO ₂ | 28.0 * | 4.06 |
| COD | mg/l | 35.93 | 37.85 |
| Oil and Grease | mg/l | ND | ND |

* should be checked by further analysis

7.2.5. Seismic Design Condition

In Cambodia, the seismic coefficient defined as “the fraction of a weight to be used as a horizontal force in a quasistatic analysis” could be set as 0.05.

As for Tsunami, the area around the site has rare possibility of earthquake and Tsunami. In case of any Tsunami in the Gulf of Thai, that cannot reach to the site due to islands scattered in front of Sihanoukville.

7.2.6. Selection of Intake and Discharge Facility Types

For selecting the type of intake and discharge facility, estimation of construction cost and features of each type are compared between 1) Rubble stone type, 2) Steel pipe pile type and 3) Buried pipe type.

Considering construction cost in addition to less environmental impact, the buried pipe type is most prosperous.

7.3. Configuration of Combined Cycle Power Plant

7.3.1. Outline of Power Plant

Outline of power plant is as follows,

- Plant capacity 180 MW
 Stage 1 : 1 × 90 MW
 Stage 2 : 1 × 90 MW
- Type of power plants Gas turbine combined cycle
- Plant site OP-4 site in Sihanoukville
 (Approx. 2 km south of Sokimex Oil Terminal)
- Mode of operation Base load operation
- Fuel Natural Gas and Diesel Oil
- Cooling water Seawater
- Fresh water Prey Treng Pond next to the site and the water reservoir will be installed in the site for shortage of water during dry season

7.3.2. Type of Combined Cycle Power Plant

Gas turbine combined cycle power plant is composed of gas turbines, HRSGs and steam turbines. On the gas turbine combined cycle power plant, one and more gas turbine(s) and correspondent number of steam turbine(s) are equipped to have necessary plant capacity. The number of HRSGs is the same as that of gas turbines and the waste heat in the gas turbine exhaust gases is converted to steam by the HRSGs to be utilized for steam turbines.

There are two types for gas turbine combined cycle power plant. One is single shaft type and the other is multiple shaft type. Table 7.3-1 shows the characteristics of both types.

Table 7.3-1 Comparison between Single Shaft and Multiple Shaft Configurations

| | Single Shaft | Multiple Shaft |
|---------------|--------------|--|
| Capital Cost | Base | Same |
| Efficiency | Base | Better at higher load Worse at lower load |
| Availability | Base | Same |
| Operability | Base | Worse |
| Required Area | Base | Smaller |

7.3.3. Capacity of Gas Turbines

One and more gas turbines are combined with a steam turbine to have necessary plant capacity for multiple shaft type gas turbine combined cycle plant.

It is necessary to decrease an influence of forced outage of the equipment on power system by applying many smaller gas turbines judging from the power system stability point.

For power system in Cambodia, the maximum permissible capacity drop is approx. 30 MW in case of stop of one (1) gas turbine judging from the power system stability point. Therefore, the maximum capacity of gas turbine is approx. 20 MW and the number of gas turbines is 3 sets for each stage of 90 MW.

7.3.4. Steam Condition

Steam condition at steam turbine inlet is as follows,

At natural gas firing

- Steam pressure 5.4 MPa
- Steam temperature 493°C

At diesel oil firing

- Steam pressure 5.5 MPa
- Steam temperature 497 °C

7.3.5. Condenser Vacuum

For the Project, inlet temperature of cooling water is 29°C, outlet inlet temperature of cooling water is 36°C (29+7) and saturation temperature is 40°C (36+4). Therefore, condenser vacuum is 7.38 kPa which is equivalent to the saturation pressure of 40°C.

7.4. Particulars of Main Equipment

7.4.1. Gas Turbine

(1) Major Specifications of Gas Turbine

The major specifications of gas turbines are as follows.

- (a) Capacity 20 MW class
- (b) Type Indoor
- (c) Fuel Natural gas and diesel oil
- (d) Number 3 sets per stage

(2) Performance at Site Conditions

Fuel type, atmospheric pressure, ambient temperature, relative humidity, etc will change the performance of gas turbine.

Natural gas and diesel oil will be used as fuels for the Project and regarding atmospheric condition atmospheric pressure is 1,013 hPa, ambient temperature is 28.8°C and relative humidity is 81% in Sihanoukville. Table 7.4-1 (natural gas firing) and Table 7.4-2 (diesel oil firing) show the performance of gas turbine at the above-mentioned site condition.

Table 7.4-1 Performance of Typical Gas Turbines with N.G. at Site Conditions

| | | | | |
|--------------------------|-----------|----------|--------|--------|
| Manufacturer | GE | ANSALDO | ABB | MHI |
| Model | LM2500-PE | AGT25000 | GT10B | MFT8 |
| Capacity (kW) | 19,670 | 23,480 | 22,220 | 22,610 |
| Heat Rate (kJ/kWh) | 10,216 | 10,513 | 11,015 | 10,262 |
| Exhaust Temperature (°C) | 538 | 479 | 557 | 482 |

Table 7.4-2 Performance of Typical Gas Turbines with D.O. at Site Conditions

| | | | | |
|--------------------------|-----------|----------|--------|--------|
| Manufacturer | GE | ANSALDO | ABB | MHI |
| Model | LM2500-PE | AGT25000 | GT10B | MFT8 |
| Capacity (kW) | 19,640 | 22,680 | 21,460 | 21,830 |
| Heat Rate (kJ/kWh) | 10,295 | 10,605 | 11,112 | 10,350 |
| Exhaust Temperature (°C) | 547 | 481 | 559 | 484 |

(3) Standard Gas Turbine

Each manufacturer has its peculiar model of gas turbine and a gas turbine made by one manufacturer has different performance and capacity compared to gas turbines made by other manufacturers. Therefore, we image the gas turbine (called the standard gas turbine hereafter) which has average performance of the gas turbines made by manufacturers so that we carry out the future feasibility study.

The performance of the standard gas turbine at site condition is as follows,

(a) Natural Gas Firing

- Capacity 20,600 kW
- Heat Rate 10,500 kJ/kWh (2,508 kcal/kWh)
- Exhaust Temperature 514°C

(b) Diesel oil Firing

- Capacity 20,000 kW
- Heat Rate 10,593 kJ/kWh (2,530 kcal/kWh)
- Exhaust Temperature 518°C

(4) Main Components of Gas Turbine

A gas turbine is composed of air filtration system, compressor, combustion system, turbine, exhaust gas system, lubricating oil system and starting system.

A gas turbine is connected to the generator through a reduction gear or directly.

(5) Maintenance Schedule





Periodical maintenance is required for gas turbines to keep high efficiency and ensure reliability. Generally combustor inspection takes place at intervals of 12,000 equivalent operation hours and hot gas path inspection takes place every 24,000 equivalent operation hours, i.e. after 1.5 years and 3 years respectively. Major inspection generally occurs every 48,000 equivalent operation hours (6 years).

7.4.2. Heat Recovery Steam Generator (HRSG)

(1) Type of HRSG

HRSG is installed to utilize heat of exhaust gas from gas turbine in order to produce steam for steam turbine. There are several types of HRSG shown in Table 7.4-3. Suitable type is selected according to the steam condition and available installation area or standard design of manufacturer.

Table 7.4-3 Type of HRSG

| stage of steam pressure | | circulation of boiler water | | gas flow direction |
|-------------------------|---|-----------------------------|--|--------------------|
| single-pressure |  | natural circulation |  | horizontal |
| multi-pressure |  | forced circulation |  | vertical |

(2) Stages of Steam Pressure

There are two types of HRSG in relation to number of stages of steam pressure. It is preferable to select multi-pressure HRSG for the Project to improve efficiency.

(3) Circulation System of Boiler Water

There are two types of boiler water circulation system, i.e. natural circulation and forced circulation. Natural circulation utilizes the difference of densities of water and water/vapour mixture within the circulation system. Forced circulation circulates the boiler water using boiler circulation pump. Table 7.4-4 shows comparison of characteristics of these two circulation types.

(4) Gas Flow Direction

There are two types of HRSG in relation to gas flow direction, i.e. horizontal gas flow type and vertical gas flow type. Table 7.4-5 shows comparison of these two types.

(5) Estimated Main Spec. of HRSG

| Item | Unit | Natural Gas | | Diesel Oil | |
|------------------------|------|---|-------|------------|-------|
| | | HP | LP | HP | LP |
| Evaporation | t/h | 85.8* | 20.6* | 84.9* | 20.2* |
| Steam pressure | MPa | 5.7 | 0.74 | 5.8 | 0.74 |
| Steam temperature | °C | 496 | 235 | 500 | 235 |
| Feedwater temperature | °C | 60 | | 135 | |
| Number of installation | | One for each GT (Three for each stage of 90 MW) | | | |

* Total evaporation of three HRSGs for 90 MW

(6) Stacks

A common stack will be provided for three HRSGs to help disperse the flue gas into the atmosphere.

The height will be 50 m and the diameter will be 3.9 m.

Table 7.4-4 Comparison between Natural Circulation and Forced Circulation Type of HRSG





| Schematic system | | natural circulation | forced circulation |
|-----------------------------|--------------------------------|--|--|
| | |  |  |
| Applicable Range | Circulation Ratio | 14 ~ 6 | ~ 4 |
| | Pressure | below 17.7 MPa | below 19.6 MPa |
| Startup Time | | Base | Shorter |
| Reliability | Stability of Water Circulation | Base | Better |
| | Possibility of Trouble | Base | Higher |
| Size | Height | Circulation system is simple. | Circulation system is rather complicated. |
| | Required space | Base | Same |
| Cost | Pressure parts | Base | Same |
| | Non-pressure parts | Base (100%) | Lighter (90%) |
| | Steel structure | Base (100%) | Same |
| Auxiliary Power Consumption | | Base (100%) | Same |
| Maintenance | | Base | Larger (120%) |
| Construction cost | | Base | Maintenance cost of BCPs increase. |
| | | | Same |

Table 7.4-5 Comparison of Type of HRSG

| | | Horizontal Gas Flow Type | Vertical Gas Flow Type |
|------------------------------------|------------------------------|--|--|
| Features of HRSG | |  |  |
| Features | Heat Exchange Area | Base | Same |
| | Pressure Drop of Exhaust Gas | Base | Same |
| | Startup Time&Load Variation | Base | Same |
| Size | Height | Base | Same |
| | Required space | Base (1 0 0 %) | Smaller(9 8 %) |
| Cost | Heat Exchange Tube Header | Base | Same |
| | Non-pressurized Parts | Base (1 0 0 %) | Lighter (8 3 %) |
| | Steel Frame | Base (1 0 0 %) | Heavier (1 3 3 %) |
| | Number of Welding | Base (1 0 0 %) | Smaller (6 7 %) |
| | Number of Module | 2Modules | 1Module |
| Ease of Maintenance and Inspection | | Base (Scaffolding is required.) | Easier (Scaffolding is not required.) |
| Construction Cost | | Base | Same |

7.4.3. Steam Turbine

(1) Type

There are two types of steam turbines that are used for gas turbine combined cycle plant by exhaust flow direction. One is axial exhaust turbine and the other is down exhaust turbine.

The axial exhaust turbine has higher efficiency because of lower exhaust loss and it is possible to reduce the construction cost of foundation and building of steam turbine because of lower required level of installation. Therefore, the axial exhaust turbine has an advantage over down exhaust turbine.

The axial exhaust turbine will be applied to the Project.

(2) Major Specification

The major specification of the steam turbine for the Project is as follows.

- Type Axial exhaust turbine
- Rated output 28,200 kW
- Rated speed of turbine 3,000 rpm
- Steam condition Steam pressure (HP/LP) : 5.4 MPa / 0.7 MPa
Steam temperature (HP/LP) : 493°C / 234°C
- Condenser vacuum 7.38 kPa
- Number of installation One for each stage of 90 MW

(3) Main Components of Steam Turbine

A steam turbine is composed of cylinder, blading, rotor, bearing, valves, control oil system, lubricating oil system and barring system.

A steam turbine is connected to the generator through a reduction gear or directly.

A condenser will be installed to condense the exhaust steam from a steam turbine by cooling water.

7.4.4. Generator

Main specifications of generator are recommended as mentioned below, considering every factor such as most advanced and proven technologies applicable in the world-wide market, economics, reliability, operationability and maintainability.

(1) Type of Protection and Cooling Method

Gas turbine generator and steam turbine generator will be of indoor type, considering easy operation and maintenance works in spite of weather conditions. As unit capacity of generator for this power plant will be less than about 50 MVA, applicable type will be open air cooled type, totally enclosed air cooled type with air-to-water heat exchanger or totally enclosed hydrogen cooled type with hydrogen gas-to- water heat exchanger, considering economical and technical points of view.

From view points of procurement of high purity hydrogen gas, safe operation and easy maintenance, application of totally enclosed hydrogen cooled type should be avoided.

Application of totally enclosed air cooled type is preferably recommended because of its better efficiency than open air cooled type. However, in case that gas turbine generator simple cycle will be installed and operated in advance of installation of whole combined cycle plant with boiler and steam turbine generator system, application of open air cooled type may be allowed for gas turbine generator, since cooling water may not be applicable.

(2) Rated Capacity and Rated Power Factor

Rated output of generator will be equal to the rated output of gas turbine or steam turbine as usual.

Rated power factor of 0.85 is recommended as most suitable, taking into account general application practice of power factor for air cooled generator and past records of average power factor of the network load in Phnom Penh.

(3) Rated Voltage

Rated voltage of generator can be determined as most suitable by manufacturers according to their design criteria, since generator output voltage is stepped up through main transformer to the rated voltage of the transmission lines and, therefore, is not subject to any external restraint.

(4) Insulation Class and Permissible Temperature Rise

Considering the importance of this power plant, application of class F insulation material and permissible temperature rise of class B is recommended to attain higher reliability.

(5) Type of Excitation System

Generally, either brushless excitation system or static excitation system is applicable to this project. Brushless type is preferable for this project because of its easy and less maintenance works.

7.5. Scope of Works

The power plant for the Project will be furnished on full turnkey basis including all works such as erection work, civil work, etc.

The Sihanoukville power plant will be implemented in three stages (i.e., Stages 1, 2 and 3). Each 90 MW plant will be constructed in each stage. However, common works such as site preparation, etc. have to be done in Stage 1.

The philosophy of expansion from Stage 1 (90 MW) to Stage 2 (total 180 MW) is as follows.

Note : The term "All works" means all works necessary for the whole plant of Stage 1, Stage 2 and Stage 3.

| | Stage 1 (90 MW) | Stage 2 (Total 180 MW) |
|---|--|----------------------------|
| Civil Works | | |
| Excavation | All works | None |
| Leveling and site preparation | All works | None |
| Soil disposal | All works | None |
| Foundations | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Intake pipes and discharge pipes | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Cooling water pump pit | Works related to 1st 90 MW and 2nd 90 MW | None |
| Bridge and culvert construction work of cooling water lines for crossing the existing provincial road/railway | All works | None |
| Road in the premises | All works | None |
| Tree planting and garden | All works | None |
| Parking lots | All works | None |
| Fence | All works | None |
| Fresh water pump pit | Works related to 1st 90 MW and 2nd 90 MW | None |
| RC raw water reservoirs | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| RC filtered water storage tanks | Works related to 1st 90 MW and 2nd 90 MW (common use) | None |
| RC tanks for wastewater treatment plant | Works related to 1st 90 MW and 2nd 90 MW | None |
| Architectural Works | | |
| Administration building | All works | None |
| Gas turbine rooms | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Steam turbine rooms | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Central control room | Works related to 1st 90 MW and 2nd 90 MW | None |
| Electrical room | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Emergency diesel generator room | Works related to 1st 90 MW and 2nd 90 MW | None |
| Pump rooms | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Canteen building | All works | None |
| Work shop | Works related to 1st 90 MW and 2nd 90 MW | None |
| Warehouse | Works related to 1st 90 MW and 2nd 90 MW | None |

| | Stage 1 (90 MW) | Stage 2 (Total 180 MW) |
|---|---|--|
| Water treatment house | Works related to 1st 90 MW and 2nd 90 MW | None |
| Guardhouse | All works | None |
| Ventilation and air conditioning system | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Diesel oil receiving house | Works related to 1st 90 MW and 2nd 90 MW | None |
| Fresh water pump house | Works related to 1st 90 MW and 2nd 90 MW | None |
| Mechanical Equipment | | |
| Gas turbine sets | Works related to 1st 90 MW (3 gas turbines) | Works related to 2nd 90 MW (3 gas turbines) |
| HRSG sets and stacks | Works related to 1st 90 MW (3 HRSGs) | Works related to 2nd 90 MW (3 HRSGs) |
| Steam turbine sets | Works related to 1st 90 MW (1 steam turbine) | Works related to 2nd 90 MW (1 steam turbine) |
| Deaerators | Works related to 1st 90 MW (3 deaerators) | Works related to 2nd 90 MW (3 deaerators) |
| Condensers | Works related to 1st 90 MW (1 condenser) | Works related to 2nd 90 MW (1 condenser) |
| Steam and water system | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Main cooling water system | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Closed circuit cooling water system | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Fuel gas treatment/supply system | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Diesel oil receiving system | Works related to 1st 90 MW and facilitated for link with 2nd 90 MW | Works related to 2nd 90 MW |
| Oil storage tanks | Works related to 1st 90 MW (1 oil storage tank) | Works related to 2nd 90 MW (1 oil storage tank) |
| Diesel oil supply pumps | 2 × 100% pumps (1 normal operation and 1 common standby for 1st 90 MW and 2nd 90 MW) | 1x100% pump |
| Diesel oil supply system | Works related to 1st 90 MW and facilitated for link with 2nd 90 MW | Works related to 2nd 90 MW |
| Pumps for water treatment system | 2 × 100% pumps (1 normal operation and 1 common standby for 1st 90 MW and 2nd 90 MW) | 1x100% pump |
| Pre-treatment system | 2 × 100% trains (1 normal operation and 1 common standby for 1st 90 MW and 2nd 90 MW) | 1x100% train |
| Fresh water transfer line | Works related to 1st 90 MW and facilitated for link with 2nd 90 MW | Works related to 2nd 90 MW |
| Demineralization plant | 2 × 100% trains and 1x100% regeneration equipment | 1x100% train |
| Demineralized water storage tanks | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Demineralized water transfer line | Works related to 1st 90 MW and facilitated for link with 2nd 90 MW | Works related to 2nd 90 MW |
| Potable water system | Works related to 1st 90 MW and facilitated for link with 2nd 90 MW | Works related to 2nd 90 MW |
| Wastewater treatment system | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Air compressors | 2 × 100% compressors (1 normal operation and 1 common standby for 1st 90 MW and 2nd 90 MW) | 1x100% compressor |

| | Stage 1 (90 MW) | Stage 2 (Total 180 MW) |
|---|--|--|
| Compressed air distribution system | Works related to 1st 90 MW and facilitated for link with 2nd 90 MW | Works related to 2nd 90 MW |
| Cranes and Lifts | Works related to 1st 90 MW (Overhead crane for gas turbine building is of common use) | Works related to 2nd 90 MW |
| Fire prevention and fighting system | All pumps and works related to 1st 90 MW for hydrant system and facilitated for link with 2nd 90 MW / Fire fighting system for 1st 90 MW equipment | Fire fighting system for 2nd 90 MW equipment |
| Control and Instrumentation System | | |
| Overall plant supervisory control system | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Gas turbine generator supervisory control system | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| HRSB supervisory control system | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Steam turbine generator supervisory control system | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Data acquisition system | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Common facilities supervisory control system | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Uninterruptible power supply for C & I system | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Telecommunication equipment to/from load dispatching center | Works related to 1st 90 MW and expandable hardware capability for 2nd 90 MW | Works related to 2nd 90 MW |
| Electrical Equipment | | |
| Generators and main circuit equipment | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Transformers | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| High voltage and low voltage station electrical system | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| DC system | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Emergency diesel generator set | Works related to 1st 90 MW and 2nd 90 MW (common use) | None |
| Operational instruction system | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Grounding system | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Lighting system | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Lightning system | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| In-plant substation | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| Supervisory, operational and protective system for electrical equipment | Works related to 1st 90 MW | Works related to 2nd 90 MW |
| In-house communication system | Works related to 1st 90 MW and facilitated for link with 2nd 90 MW | Works related to 2nd 90 MW |

7.6. Outline of Plant

7.6.1. Expected Performance of Plant

The performance of gas turbine combined cycle power plant applying the standard gas turbines is as follows;

(1) At Natural Gas Firing

| | | |
|--------------------|-----------------------|-------------------------------|
| • Gross output | Gas turbines | 61,800 kW (3 × 20,600 kW) |
| | Steam turbine | 28,200 kW |
| | Total | 90,000 kW |
| • Net plant output | | 87,400 kW |
| • Heat rate (LHV) | At generator terminal | 7,205 kJ/kWh (1,721 kcal/kWh) |
| | At send out point | 7,419 kJ/kWh (1,772 kcal/kWh) |

Fig.7.6-1 shows the preliminary heat balance of gas turbine combined cycle power plant at natural gas firing.

(2) At Diesel Oil Firing

| | | |
|--------------------|-----------------------|-------------------------------|
| • Gross output | Gas turbines | 60,000 kW (3 × 20,000 kW) |
| | Steam turbine | 25,700 kW |
| | Total | 85,700 kW |
| • Net plant output | | 83,100 kW |
| • Heat rate (LHV) | At generator terminal | 7,418 kJ/kWh (1,772 kcal/kWh) |
| | At send out point | 7,650 kJ/kWh (1,827 kcal/kWh) |

Fig.7.6-2 shows the preliminary heat balance of gas turbine combined cycle power plant at diesel oil firing.




Fig.7.6-1 Heat Balance of Gas Turbine Combined Cycle Power Plant (Natural Gas)




Fig.7.6-2 Heat Balance of Gas Turbine Combined Cycle Power Plant (Diesel Oil)

7.6.2. Steam/Water Cycle

(1) Steam Cycle

High-pressure superheated steam and low-pressure superheated steam are produced in the HRSG by heat of gas turbine's exhaust gas. Those steams expand in the steam turbine and rotate a generator that is connected with the steam turbine directly or through a reduction gear.

Turbine steam bypass system is provided with bypass facilities capable of allowing both steam turbine and HRSG unit start up or re-start ties to be minimized, and the unit to remain in operation supplying the unit auxiliary power demand, following disconnection from the grid.

The steam, which is exhausted from the steam turbine enters a condenser and is condensed by cooling water.

Heating steam for feedwater is supplied to a deaerator from the low-pressure steam line.

Refer to Fig. 7.6-3.

(2) Water Cycle


Condensate water is fed from a condenser to a deaerator directly (in case of diesel oil firing) or via LP economizer (in case of natural gas firing) by condensate pumps before entering the HRSG. The water is heated by the deaerator using low-pressure steam (in case of diesel oil firing) or by hot feedwater recirculation at LP economizer (in case of natural gas firing), and supplied to HRSGs by boiler feed water pumps as feedwater.

Two high-pressure boiler feedwater pumps and two low-pressure boiler feedwater pumps will be provided for each HRSG. The high-pressure boiler feedwater pumps will supply feedwater to the high-pressure line.

The feedwater temperature entering the HRSGs has to be controlled to prevent sulfuric acid corrosion and carbonic acid corrosion on the outside surface of the economizer tubes.

In this Project, the feedwater temperature is controlled to 135°C by steam heating in deaerator when firing oil, and to 60°C by hot feedwater recirculation at LP economizer when firing natural gas.

Refer to Fig. 7.6-3.



Note :
 — shows the steam line.
 — shows the water line.

Fig.7.6-3 Steam and Water System of Gas Turbine Combined Cycle Power Plant

7.6.3. Fuel Supply and Storage System

(1) Kind of Fuel

Natural gas and diesel oil will be used as fuel for the Project.

(2) Natural Gas Supply Plan

Natural gas will be used as main fuel. The natural gas will be supplied to the site boundary by pipeline.

A filter separator unit for each gas turbine is recommended for protecting the gas turbine fuel equipment from particulates and moisture carry-over from the gas treatment plant. Gas flow meters will be installed in the incoming supply pipeline and the gas turbine supply pipelines.

(3) Diesel Oil Supply Plan

Diesel oil will be used as standby fuel when natural gas is not available. In Cambodia, all of liquid fuels are currently imported.

Diesel oil for the Project will be supplied from Sokimex Oil Terminal because the site is located approx. 2 km south of this oil terminal. For the Project, pipeline transport is selected because of the short distance between the site and the oil terminal.

(4) Diesel Oil Storage Plan

The storage tank capacity will be 5,180 ton equivalent to oil consumption for 14 days. One storage tank per each stage will be installed.

7.6.4. Cooling Water System

(1) Outline

The cooling water system will be provided to supply cooling water to power plant equipment that requires a cooling medium for their operation. The cooling

water system consists of primary cooling water system with seawater (herein after called Main Cooling Water System) and secondary cooling water system with fresh water (herein after called Closed Circuit Cooling Water System).

(2) Main Cooling Water System

The main cooling water system provides the total seawater requirements for the condensers and the closed circuit cooling water system.

The main cooling water system will be of once through type using seawater drawn from an off shore intake and an adequate interval between intake and discharge points will be considered to prevent the hot water from recirculation into the cooling water intake.

It is desirable that the temperature rise of main cooling water system will be not more than 7°C under the rated conditions to minimize the effect on aquatic organisms, fishes, etc. Furthermore, the effluence should result in a temperature increase of no more than 3°C at the edge of the zone that is 100 m away from the point of discharge.

The quantity of cooling water per stage is estimated as follows:

- | | |
|--|---------------------------|
| a. For condenser | : 8,000 m ³ /h |
| b. For closed circuit cooling water system | : 1,000 m ³ /h |
| c. Total per stage of 90 MW | : 9,000 m ³ /h |

The main cooling water system will consist of screening plant, chlorine injection system, cooling water pumps, seawater booster pumps for closed circuit cooling water system, etc.

Fig.7.6-4 shows the flow diagram of main cooling water system.




Fig.7.6-4 Flow Diagram of Main Cooling Water System

(3) Closed Circuit Cooling Water System

The closed circuit cooling water system is provided to supply cooling water to the miscellaneous power plant equipment that requires a cooling medium for their operation.

Demineralized water will be used as an intermediate cooling medium between the equipment coolers and seawater. The cooling water is cooled by seawater using the water coolers.

Each Stage will be provided with a closed circuit cooling water system. Each system consists of water coolers, head tank, circulating pumps and distribution system.

7.6.5. Fresh Water Supply System

(1) Fresh Water Source

Fresh water demand for the plant with capacity of $90 \text{ MW} \times 2$ is about $9 \text{ m}^3/\text{h}$ and after extension ($90 \text{ MW} \times 3$) it is about $13 \text{ m}^3/\text{h}$. Prey Treng Pond is the most suitable for fresh water source of the power station because of near location. However, it is expected that water supply from Prey Treng Pond is not sufficient in dry season. Therefore, the water reservoirs are necessary.

(2) Fresh Water Supply System

The water supply system will provide the total requirement of main plant cycle make-up, potable and auxiliary service water for the power plant.

The principal demand of fresh water is as follows.

- a. Demineralized water for main plant cycle make-up.
- b. Demineralized water for make-up and re-filling to closed circuit cooling water system.
- c. Potable water for power plant services.
- d. Filtered water to auxiliary station services (floor washing, irrigation, etc.)

The system is illustrated in Fig.7.6-5.




Fig.7.6-5 Flow Diagram of Fresh Water Supply System

7.6.6. Wastewater Treatment System

The wastewater treatment system will be designed to collect and process the waste water discharged from the power station so that the effluent water quality meets the applicable environmental regulatory standards before it is discharged or reused.

The system will handle the liquid wastes from various plant sources including regularly discharged chemical waste, intermittently discharged chemical waste, oil waste, sewage waste and storm water run off. Each type of wastewater will be collected in a separate collection system and will then be treated with a process most appropriate to the nature of the waste.

The system is illustrated in Fig.7.6-6.




Fig. 7.6-6 Flow Diagram of Wastewater Treatment System

7.6.7. Compressed Air Supply System

Compressed air supply system is composed of instrument and service compressed air systems. The normal working pressure of both systems will be 7 bar (g).

The system is illustrated in Fig.7.6-7.

The instrument air system will supply clean, dry and oil free compressed air for operation of diaphragm valves, valve positioners, pneumatic controllers, transmitters and other control devices requiring compressed air for operation.

The service air system will supply compressed air required for maintenance tools or operational purposes in the area of gas turbine rooms, steam turbine rooms, HRSGs, fuel oil pumping units, workshop, warehouse, laboratory, etc.




Fig.7.6-7 Flow Diagram of Compressed Air System

7.6.8. Electrical System

(1) Configuration of Station Auxiliary Electrical Supply System

Considering reliability, operationability and economics, recommendable configuration of generator output circuits and station auxiliary electrical supply system is as shown in Fig.7.6-8. In this scheme, when the in-plant substation is live under electrical power receiving from transmission line, start-up power for gas turbine can be received through either one of two routes. One is through substation, main transformer and block transformer and the other is through substation and station transformer. Generator is synchronized with and put into the live substation at the circuit breaker in LV side of main transformer. It is generator low voltage side synchronization system. As shown in Fig.7.6-8, three windings type is applied to main transformer, to attain simple layout and economics.

Station transformer is used commonly for Stage 1 and Stage 2 and serves station common loads.

(2) Emergency Diesel Generator

A emergency diesel generator will be provided for whole power station to supply electric power for safe preservation of the plant and for start up of a gas turbine generator unit under blackout condition of the whole power station. The blackout condition of the whole power station means that all generating units have no electric generation and no electric power can be expected from external networks such as transmission lines.

(3) In-Plant Substation and Future Extension

As shown in Fig.7.6-8, double busses and single circuit breaker scheme is recommended for 220 kV in-plant substation. For the time being, almost all of generated power is scheduled to be sent to Phnom Penh through Kampot and Takeo. Transmission line with two circuits is planned from the power station to Kampot. It is recommended that first circuit will be installed at Stage 1 and second circuit will be installed at Stage 2, considering economics. Area plan for the in-plant substation includes appropriate area space necessary for future extension such as Stage 3 and transmission line feeder to Sihanoukville city area.




Fig.7.6-8 *Preferable Typical Scheme for Station Auxiliary Electrical Supply*

7.6.9. Control and Supervising System

(1) System Configuration

Considering reliability, maintainability and flexibility for future extension, distributed control system (DCS) is applied and control and supervising functions are centralized in central control room. DCS is based on micro-computer technologies and the systems are distributed as per function group such as Station common control, station data management, gas turbine control, steam turbine control and coordination control, heat recovery steam generator control and etc. This scheme is ordinary for thermal power plant, including combined cycle power plant, in the worldwide market.

Redundancy design concept such as duality will be applied to vital control and supervising functions including communication data way.

(2) Human-Machine Interface

CRT operation concept will be applied for human-machine interface to achieve most efficient operation and monitoring. Operator's console with touch screen controlled CRT's will be provided in most suitable allocation for operation and monitoring of the plant. All information necessary for operation and monitoring of the plant will be displayed in manner of characters and graphics and operators can operate the plant by touch screen operation and / or key board operation with CRT's.

(3) In-House Communication Systems

Communication systems will be provided for exchange of operation data and direct telephone system between the power station and the dispatching center in Phnom Penh, and sending and receiving of intertrip protection signal for transmission line. For data way, optical cable system as first way and power line carrier system as back- up will be recommended. Both of optical cable and power line(transmission line) will be installed separately as a part of other transmission line project. Optical fiber integrated grounding wire will be recommended to be installed instead of simple grounding wire for transmission line.

7.6.10. Fire Protection System

The fire protection system will be provided to minimize the damage by a fire for the power plant equipment and buildings. One fire engine will be provided. The carbon dioxide (CO₂) system will be provided for the area where use of wet system is not suitable.

The system will comprise fire detection and fire fighting system.

A main fire detection panel will be located in the central control room of power plants and a local fire panel will be located in each block area. Fire fighting system will be able to be started in the main fire detection panel or local fire panels.

Fire fighting system of non attended equipment and region (i.e. outdoor transformers, oil tanks, etc.) will be actuated automatically by the fire alarm signals of the detectors.

Each fire protection system will form a complete system as defined by the National Fire Protection Association (NFPA) Codes and recommended practices.

7.6.11. Design of Foundation

(1) Oil Storage Tank

Considering the SPT value near the tank, shallow foundation can be applied by improving partly the ground by replacing soil.

Approximately 1 m depth of soil layer shall be replaced by compacted sand layer to avoid any consolidation and liquifaction.

(2) Heavy Equipment such as HRSG, Gas Turbine, etc.

The location of HRSG, gas turbine and main transformer is around borehole BH-3, where under thick overburden of silty sand the layer with SPT value of over 50 at approximately - 10 m + EL. could be as supporting layer for steel piles of about 900 mm dia. as their foundation works.

(3) Intake and Outlet of Cooling Water System

Intake and outlet structures are located offshore westward of the site with a water depth of approximately 5 m. Pipes connecting those facilities to intake pit and discharge pit, respectively, are buried under sea bed. Overburden that consists of sand with very loose, 0 SPT value, should be replaced by rubble stones and reinforced soil up to supporting layer. Thickness of rubble stone should be more than 1.5 m.

(4) Offshore Cooling Water Pipes

Pipes are buried under the seabed with a depth of approximately 2 m below the seabed.

Foundation shall consist of 0.5 m thick rubble stone layer and reinforced soil covering pipes on it.

7.6.12. Building Work

(1) General

Buildings and the related architectural structures are mainly as follows;

(a) Main Buildings

- 1) powerhouse inclusive of central control room, gas turbine room, steam turbine room, electrical room, pump room, emergency diesel generator room, etc.
- 2) administration building

(b) Ancillary Buildings

- 3) workshop
- 4) warehouse
- 5) canteen building
- 6) guard house
- 7) water treatment house

(c) Outdoors

- 8) stack
- 9) perimeter wall fence
- 10) gardening

(2) Site Condition for Building Design

Buildings are designed and specified in consideration with the site conditions shown below.

(a) Meteorological Condition

- 1) wind speed; 26.9(m/s): provable wind speed with return period over 50 years
- 2) rainfall; 127.3 (mm/hr): provable rain fall with return period over 50 years
- 3) atmosphere; sea coast, heavily salt laden atmosphere
- 4) average temperature; D.B.T. 28.8 (°C)
- 5) average relative humidity ; 81 (%)

(b) Geological Condition

The ground surface of the site is layered with silt and sand at 10 ~ 15 m deep on sand stone layer ($N > 50$) as shown on the geological survey data. In this land condition, consideration will be given to structural design of the building. It is necessary for foundation of main buildings and structures to be reinforced with concrete piles against unequal subsidence.

(c) Seismic Condition

Earthquake over magnitude 4 has never been recorded in Cambodia.

In this condition, following seismic design criteria will be applied to the Project;

$$Cd = C \bullet I \bullet K$$

Where: Cd : equivalent seismic coefficient at the ground level

C : base seismic coefficient of 0.05

I : importance factor of building and structure

K : structural type factor

Vertical seismic load will not be considered.

(3) Main Buildings and Structure

(a) Powerhouse

Powerhouse houses six (6) gas turbine generators, two (2) steam turbine generators and their associates equipment for the Stage 1 of 90 MW and Stage 2 of 90 MW. The powerhouse for Stage 1 should be provided with preparatory joint structure and covering walls for Stage 2 extension.

The powerhouse will be framed by structural steel of superstructure and be supported by pile foundation, and its exterior walls and roof shall be finished with corrugated steel sheet.

(b) Administration Building

The administration building will include office room, conference room, guest room, directors room, communication computer room, chemical laboratory, and sanitary rooms in the building.

The building to be constructed in Stage 1 will be of two stories with reinforced concrete made, and be sized enough to cover accommodation through whole stages as requested.

(c) Ancillary Building

Workshop ; Mechanical and electrical workshop will be provided with tool shelves and a lifter in the building for repairing and inspection of machines. The building will be made of structural steel with steel corrugated sheet roof and walls.

Warehouse ; The building of warehouse will be made of structural steel with steel corrugated sheet roof and wall.

Guardhouse ; Guardhouse is situated in adjacent to the administration building.

Canteen building ; Canteen building will be provided near the administration building.

Water treatment house ; For water treatment equipment including chemical injection system, the water treatment house will be provided, which is reinforced concrete made. A stock room of water treatment chemicals is also needed in the house.

(d) Outdoors

Stack, site perimeter fence, gardening and so on will be necessary to complete the work of power plant.

(4) Ventilation and Air-conditioning System

The recommended design condition and configuration of ventilation/air conditioning system are as follows;

(a) Design Condition

1) Outdoor air condition

Dry bulb temperature; 33°C, Relative humidity; 81%

2) Indoor air condition

1. Air conditioned rooms (central control room, relay room, administration building etc.)

Dry bulb temperature ; 25°C, Relative humidity ;50 ± 5%

For control equipment rooms ; 23~24°C will be preferable

2. Ventilated rooms (gas/steam turbine generator room, auxiliary rooms, etc.)

Dry bulb temperature ; 38°C max. (outdoor air temperature +5°C)

Mechanical ventilation will be provided for keeping the limit.

7.7. Plant Layout

Fig.7.7-1 shows the plot plan of the combined cycle power station. The area of power station premises will be approx. 13.1 ha.

(1) Power Plant Zone

Power plants of Stage 1 and 2 will be located in the center of the site and the extension space for Stage 3 will be taken up on the north side of Stage 1 and 2 area.

Fig.7.7-2 shows the general arrangement of the power plant.

(2) In-plant Substation Zone

In-plant substation area will be located on the east side of power plant area in consideration of the transmission line route from the substation to Kampot, which is to the northeast from the power station, and prevention of direct attack of sea breeze. The extension space for Stage 3 is included in the area. The substation area will be also located midway between Stage 1 and Stage 3 power plants in consideration of the bus duct connection between each generator transformer and the substation. Furthermore, a future extension space will be taken up in the east part of the in-plant substation area to supply power to Sihanoukville City and an industrial zone that is under planning.

(3) Oil Storage Yard

Oil storage yard will be located in the north part of the site because Sokimex Oil Terminal lies on the north side of the site. Two diesel oil storage tanks will be installed for Stage 1 and Stage 2 in the yard. An extension space will be taken up in the north part of the yard to install an additional future tank for Stage 3.

(4) Administration Zone and Access


An administration building will be located on the south side of power plant area. The building faces the sea (the west) and there is an open space with garden and parking lots in front of the building. There is Prey Treng Pond on the south side of the building. An access from the existing provincial road to the power station will be located in the southwest part of the site and a guardhouse and a fire station will be installed at the entrance of the power station.

(5) Other Zones

Cooling water pump pit is located in the northwest part of the site and discharge pipes are located in the southwest part of the site to ensure sufficient intervals between intake and discharge points of cooling water.

Water treatment plant and wastewater treatment plant is located in the south part of the site because Prey Treng Pond as fresh water source is on the south side of the site.

Warehouse and workshop are located near the Stage 1 power plant zone.




| BORE HOLE | U.T.M. CO-ORDINATE | | GROUND ELEV. (M.S.L.) |
|-----------|--------------------|-------------|-----------------------|
| | NORTHING (M) | EASTING (M) | |
| BH-1 | 118353.434 | 341481.508 | 7.48 |
| BH-2 | 118298.631 | 341858.293 | 9.71 |
| BH-3 | 1182790.830 | 341722.928 | 5.36 |
| BH-4 | 1182544.270 | 341458.663 | 3.88 |
| BH-5 | 1182518.102 | 341958.978 | 3.01 |
| BH-6 | 1182531.186 | 341881.314 | 3.50 |
| BH-7 | 1183142.967 | 341681.314 | 11.01 |
| BH-8 | 1182803.914 | 341473.271 | 2.19 |
| BH-9 | 1182777.746 | 341972.888 | 8.12 |

- LEGEND**
- ▲ PERMANENT HORIZONTAL AND VERTICAL CONTROL
 - △ TRAVERSE STATION (TEMPORARY)
 - WATER PIPELINE
 - ⊕ SPOT HEIGHT
 - CONTOUR LINE INTERVAL 0.50 M.
 - BORE HOLE
 - BUILDING
 - 1-SW ONE STOREY WOODEN HOUSE
 - 1-SC ONE STOREY CONCRETE HOUSE
 - TREES PERIMETER
 - #X.XX TREE WITH STEM DIAMETER
 - BOUNDARY LINE

- NOTES**
1. THE CO-ORDINATE AND ELEVATION WAS REFERED FROM G.P.S. "CB-11"
 2. THE CO-ORDINATES WHERE SHOWN IN THIS DRAWING ARE U.T.M. CO-ORDINATE.
 3. THE ELEVATION REFERED FROM MEAN SEA LEVEL.
 4. MORE INFORMATION SEE SURVEY REPORT.

| STA. | U.T.M. CO-ORDINATE | | ELEVATION (M.S.L.) | REMARKS |
|-------|--------------------|-------------|--------------------|-------------------|
| | NORTHING (M) | EASTING (M) | | |
| CB-11 | 117632.855 | 337812.508 | 8.480 | CONCRETE MONUMENT |
| CB-20 | 118292.327 | 341341.277 | 3.346 | CONCRETE MONUMENT |
| CB-21 | 118257.109 | 341405.936 | 3.102 | CONCRETE MONUMENT |
| CB-22 | 1183102.181 | 341405.512 | 3.442 | CONCRETE MONUMENT |
| CB-23 | 1183221.407 | 341538.451 | 20.223 | CONCRETE MONUMENT |
| CB-24 | 1183220.930 | 341291.716 | 2.320 | CONCRETE MONUMENT |
| CB-25 | 1183379.873 | 348353.658 | 18.428 | CONCRETE MONUMENT |
| CB-26 | 1185144.836 | 350827.338 | 3.272 | CONCRETE MONUMENT |
| CB-27 | 1185075.562 | 350795.057 | 2.455 | CONCRETE MONUMENT |



| No. | REVISION | APPROVE | DATE |
|-----|----------|---------|------|
| | | | |
| | | | |

CONSULTANTS
NEWJEC
 NEWJEC INC.
 OSAKA JAPAN

PROJECT
 SIHANOUKVILLE
 CCGT FEASIBILITY STUDY
 SIHANOUKVILLE, CAMBODIA

TITLE

| | | |
|-----------------|------|-----------|
| ARCHITECT | | |
| STRUC. ENGINEER | | |
| CIVIL ENGINEER | | |
| ENVIR. ENGINEER | | |
| SURVEY ENGINEER | | |
| DRAWN BY | | SHEET No. |
| CHECKED BY | DATE | DATE |
| APPROVED BY | DATE | SCALE |

Fig.7.7-1 Plot Plan for Combined Cycle Power Station




Fig.7.7-2 General Arrangement of Power Plants

8. Results of Environmental Impact Study

8.1. Possible Environmental Impact of the Project

8.1.1. Impacts of Project Construction

Plans and Assumptions

Impact study is based on the following plan and assumptions:

- a. In general, each stage will be constructed separately, one after the other.
- b. Site grading for all stages will be carried out at the start of construction of Stage 1.
- c. Some structures that will serve more than one stage (such as workshop, warehouse, fresh water pump pit, canteen, etc.) will be sized for Stage 1 to also serve Stage 2 or Stages 2 and 3.
- d. Stacks, cooling water structures and pollution control systems for all units will be designed to comply with environmental requirements at ultimate site development of 270 MW even though the Stages 1 and 2 may operate for years before ultimate site development is achieved.

Potential Impacts

The main potential impacts of construction are the following:

- a. Traffic congestion and accidents along the access road.
- b. Noise.
- c. Squatting and encroachment on areas near the plant site.
- d. Erosion and sedimentation during site preparation.
- e. Siltation and salinization of soil during construction of cooling water system.
- f. Water pollution to Prey Treng Pond due to spills, sanitary wastes and process wastes during construction.
- g. Resettlement of households from project areas.
- h. Cumulative effects of interference with operating units by construction works of extension.
- i. Creation of temporary employment and economic activity.

8.1.2. Impacts of Operation

Potential Impacts. The main potential impacts of operation are outlined in the following paragraphs, even though they do not appear to be serious.

- a. Air Pollution by exhaust gas.
- b. Water pollution to the seawater and Prey Treng Pond by effluents from the plant.
- c. Mortality of marine ichthyoplankton by heated cooling water and chlorination of cooling water.
- d. Contribution to permanent employment and economic activity in the Sihanoukville area.

8.2. Impact Mitigation Planning

8.2.1. Impact Mitigation by Plant Design

Mitigation of impacts through avoidance and minimization of project and environmental conflicts is an important general theme of the feasibility study that is already documented by the following events:

- a. The JICA Study Team includes an environmental specialist to actively pursue environmental matters.
- b. Environmental considerations have been addressed from the beginning of the feasibility study and were an integral part of project site selection and evaluation.
- c. A year-long environmental baseline survey was carried out to develop information for a full environmental impact assessment and environmental mitigation plan for the project.
- d. Preliminary design of the cooling water intake and discharge structures has already reduced (i) the potential for aesthetic impacts and impacts of construction by arranging for pipelines to be placed under the seabed and (ii) reduced the potential for environment and impingement of fish at the intake structure by specifying a low intake velocity of 0.2 m/s.
- e. Arrangements for chlorination of the cooling water have already considered chlo-

rine shocking method.

- f. Preliminary design work for the cooling water discharge structures has already attempted to reduce the size of the thermal mixing zone by the design and placement of the structures.
- g. Cumulative effects of constructing one stage while operating one or more other stages have already been considered to ensure the adequacy of dry-season water supply and available space for construction laydown.
- h. In general, the environmental standards of Cambodia is considered in the development of the project design and mitigating measures. Where there are gaps or ambiguities in the Cambodian standards, the design will follow World Bank or comparable guidelines.
- i. Efforts to obtain plant makeup water from Prey Treng Pond without significantly disrupting the seasonal water levels or ecological structure of the pond, or interfering with Sokimex's water supply, have already been considered in the choice of water source and preliminary design of the make-up water system. Tentative plans call for on-site water storage tanks with storage capacity sufficient to provide make-up water for 1 month.
- j. Stack configuration and height have been established on the basis of more than 50 runs of the US EPA ISC3 (Industrial Source Complex 3) model. Finally, the common stack with 50-m height (one per stage) was selected to satisfy all Cambodia standards even when diesel oil is used for three stages.
- k. To reduce costs, impacts and future interference of operating units and units under construction, construction of Stage 1 will include some facilities for Stages 2 and 3.
- l. Public participation in mitigation planning has included interviews of selected stakeholders by the environmental baseline survey team concerning demographic, socio-economic, ecological, fisheries and archaeological conditions in the project area; and discussions between landowners (of areas required for the project) and the office of the 1st Deputy Governor of Sihanoukville concerning their willingness to sell their land to the project.
- m. To facilitate Government approval of the project, Ministry of Environment should be contacted as early as possible after completion of the EIA for advice on

submittal of the Environmental Examination Application and the EIA. After Government approval of the project, a land acquisition committee will be formed to handle all aspects of land acquisition. This committee and the office of the Governor of Sihanoukville Municipal Province will handle all aspects of resettlement of residents from the acquired land. Therefore the EIA report will not include any plans for resettlement or restoration of income of these residents.

8.2.2. Mitigation During Project Construction

The following requirements should be addressed in tender documents:

- a. Control traffic congestion along the access road by vehicles used for construction.
- b. Control night-time noise along the access road by vehicles used for construction.
- c. Control squatting and encroachment in the site and wastewater.
- d. Control diseases and promote safety of workers.
- e. Protect Prey Treng Pond from sedimentation during site preparation.
- f. Control spoils from cooling system construction.
- g. Management resettlement to provide adequate benefits without attracting newcomers to the site.
- h. Minimize interference with operating unit(s) during construction of Stages 2 or 3.
- i. Provide convenient construction lay-down area for Stage 3. (this is a responsibility of project owner)
- j. Provide guidance for temporary employment to encourage the distribution of project benefits to affected persons and communities.

8.2.3. Mitigation During Project Operation

- a. Monitor the concentration of NO_x, SO_x and particulars emission in flue gas once each month.
- b. Prevent accidental spills of fuel or chemical.
- c. Monitor operation and maintenance of wastewater treatment facilities, including periodic testing of effluents prior to discharge.
- d. Monitor cooling water's dispersion condition and react to findings.

9. Organization for Management and Operation of Power Plant

9.1. Organization and Personal Allocation

Sihanoukville C/C Power Station is the first large-scale fossil-fired power station in Cambodia, this power station should be properly organized so as to meet its specific property and features.

The organization of Sihanoukville C/C Power Station and the responsibility of each perennial are shown in Fig.9.1-1.

In case of Stage 1 and Stage 2 (180 MW) Power Plant, the organization would consist of about 150 members. However, it is necessary to reconsider allotted duties and the numbers of each section personnel according to the actual conditions of the organization management and the capacity of personnel in the EDC.

9.2. Training Plan of Operation and Maintenance Engineer

A training program is classified into the following three types basically.

- (1) Classroom in Cambodia domestic and other foreign countries
- (2) OJT (On the Job Training)
- (3) Training by advisors after beginning commercial operation

Program of classroom training and OJT is shown in Table 9.2-1.

It is a tremendous social loss to make a significant high efficiency power plant like a combined cycle fall into unoperational conditions that results in failure of power supply, due to human error, inappropriate maintenance of equipment and inappropriate control of materials.

Therefore, to operate the plant effectively and continuously and to improve operation and maintenance personnel ability, several contractor's engineers of large experience should be stayed continuously at the plant as the advisor after completion of the plant up to expiration of the warranty period.

The following technical experts take charge of the advisor.

- (1) Gas turbine engineer
- (2) Steam turbine engineer
- (3) C&I engineer

The schedule of Training Plan is shown in the Fig.9.2-1.

| Combined Cycle P/S | Function |
|--|---|
| <pre> graph TD SR[Superintendent's room] --- OS[Office section] SR --- TS[Technology section] SR --- OpS[Operation section] SR --- MS[Maintenance section] OS --- AP[Administration personnel] OS --- AccP[Accounting personnel] TS --- TP[Technical personnel] TS --- CP[Chemical personnel] OpS --- O[Operator] OpS --- LP[Logistics personnel] MS --- EMP[electrical maintenance personnel] MS --- MPP[Mechanical maintenance personnel] subgraph PersonnelCounts P1[3] --- SR P2[26] --- OS P3[7] --- AccP P4[12] --- TP P5[7] --- CP P6[53] --- OpS P7[16] --- LP P8[16] --- EMP P9[11] --- MPP P10[151] --- Total end </pre> <p>personnel (Stage 1 & 2)</p> <p>3</p> <p>26</p> <p>7</p> <p>12</p> <p>7</p> <p>53</p> <p>16</p> <p>16</p> <p>11</p> <p>Total 151</p> | <ul style="list-style-type: none"> • Overall management (station manager, and 2 vice station managers (administration, technical)) • Administration (Commercial, Personnel matter, Labor management, Education, Health administration, Public welfare, Document management etc) • Others (Drivers, Medical staffs, Security guards, Office workers) • Accounting, Material procurement, etc. • Data Evaluation and Statistics (Environment, Efficiency of the plant etc) • Chemical affairs (Quality control of supply water, Chemical analysis, etc.) • Operation (4 groups on 3 shifts) • Logistics for Operation (Material control for operation such as fuel, disposal control of sludge, sewage & etc., planning an education for operating, etc.) • Maintenance (Electrical & C&I) • Maintenance (GT, ST & HRSG, BOP) |

Fig.9.1-1 Organization and Function of Sihanoukville Combined Cycle Power Station

Table 9.2-1 Program of Classroom Training and OJT

| Type | Location | Subject | Trainer | Trainee | Duration (Working Day) | Time | Number of Trainees |
|-----------|--------------------------------|--------------------------------|---|--|---|---|------------------------------|
| Classroom | | General | Consultant | Managers & Engineers | 1 | at start of project | 3 ~ 4 |
| | | Project management | | | 4 | | |
| | in Foreign Countries | Design/Environment | Contractor and/or Electric Power Co. | Engineers & Technicians | 15 | during manufacturing | 5 ~ 6 personnel × 2 times |
| | | Operation | | | 43 | | |
| | | Maintenance & Material control | | | 2 | | |
| | | Power Station Tour | | | 2 | | |
| at Site | Operation | Contractor | Engineers & Technicians | 10 | during erection | 10 personnel × 2 times | |
| | Maintenance & Material control | | | 5 | | | |
| | Construction | Contractor | Technicians | full time during construction/ erection/ operation | during construction/ erection/ operation | all operators & maintenance personnel | |
| Operation | | | | | | | |
| OJT | at Site | Maintenance & Material control | | | | | |




Fig.9.2-1 Schedule of Training Plan

10. Expected Project Implementation Schedule

The expected project implementation schedule is shown in Fig. 10-1.


This schedule is based on the optimum power development plan discussed in Chapter 2.

At the time of start of this feasibility study, the Sihanoukville power plant had been envisaged to be commenced in 2004 (90 MW) and in 2005 (90 MW) according to the then existing power development plan of Cambodia. However, that power development plan was already amended by EDC in 2000. According to the latest power development plan included in EDC's annual report of the year 2000, the Sihanoukville power plant with 90 MW capacity is planned to be commenced in 2007 in a high scenario without IPP2. This annual report does not discuss about the power development plan after 2007, so the time of commencement of the 2nd stage of Sihanoukville (90 MW) is not shown in the report.


The optimum power development plan in Chapter 2 of this report suggests that the required time of commencement of Sihanoukville power plant should be 2006 for Stage 1 and 2008 for Stage 2 in Base Case, and 2006 for Stage 1 and 2009 for Stage 2 in Low Case, respectively. The implementation schedule of 180 MW power plant shown in Fig. 9-1 is based on two years interval for the case of Base Case.

While the construction plan of the transmission line between Kampot and Sihanoukville has not been decided until now. The required period from commencement of feasibility study to completion of construction of this transmission line is assumed approximately 53 months in Fig.10-1. As shown in Fig.10-1, a possible commencement time of the Sihanoukville power plant depends on the implementation schedule of transmission line. Therefore, for keeping the implementation schedule of power plant, the feasibility study of transmission line is recommended to start before making a decision on the Sihanoukville Power Plant Project.

Fig.10-1 Approximate Implementation Schedule of 180 MW CCGT



Schedule of Transmission Line Between Kampot and Sihanoukville



11. Economic and Financial Analysis

11.1. Construction Cost

The construction cost for the Sihanoukville Combined Cycle power plant is estimated to be 100.2 Million for Stage 1 and 74.6 Million for Stage 2 as shown in Table 11.1-1.

Table 11.1-1 Estimate of Construction Cost (as of 2001)

(unit : 1,000 \$)

| | Stage 1 | | | Stage 2 | | |
|--|---------------|---------------|----------------|---------------|--------------|---------------|
| | F/C | L/C | Total | F/C | L/C | Total |
| Mechanical | 44,290 | 3,330 | 47,620 | 41,100 | 3,090 | 44,190 |
| Electrical | 19,250 | 1,230 | 20,480 | 14,610 | 930 | 15,540 |
| Civil Works | 5,450 | 6,650 | 12,100 | 2,520 | 3,090 | 5,610 |
| Building & Structure | 3,400 | 1,830 | 5,230 | 1,570 | 850 | 2,420 |
| Spare Parts & Others | 6,720 | 0 | 6,720 | 3,470 | 0 | 3,470 |
| Subtotal | 79,110 | 13,040 | 92,150 | 63,270 | 7,960 | 71,230 |
| Note: The above items include physical contingency of 5 %. | | | | | | |
| Training | 100 | 0 | 100 | 50 | 0 | 50 |
| Owner's Administration Fee | 0 | 2,600 | 2,600 | 0 | 1,300 | 1,300 |
| Engineering Consultant Fee | 4,390 | 0 | 4,390 | 2,040 | 0 | 2,040 |
| Land Acquisition | 0 | 740 | 740 | 0 | 0 | 0 |
| Resettlement & Compensation | 0 | 30 | 30 | 0 | 0 | 0 |
| Mine Survey | 0 | 190 | 190 | 0 | 0 | 0 |
| Subtotal | 4,490 | 3,560 | 8,050 | 2,090 | 1,300 | 3,390 |
| Grand Total | 83,600 | 16,600 | 100,200 | 65,360 | 9,260 | 74,620 |

| | F/C | L/C | Total |
|---|-------|-------|--------|
| Associated Transmission Line (Site ~ Kampot) | 8,640 | 2,160 | 10,800 |

11.2. Economic Analysis

11.2.1. Objective

Economic analysis is carried out to verify the economic validity of the implementation of project from the viewpoint of the whole Cambodian economy.

11.2.2. Fuel and Fuel Price

CIF price (Cost, insurance and freight) are used for oil fuels because the all oil fuels in Cambodia are imported from overseas at the moment.

Concerning the natural gas, of which exploring is expected in future; the estimated exploring cost is envisaged to be higher than the world market and to be consumed in the domestic due to the less efficiency of the gas reserve. The natural gas price is estimated 4 \$/MMBTU at power plant site including the markup provisionally.

Table 11.2-1 Fuel Prices for Economic Analysis

| Fuel Type | Fuel Price (CIF Price) | Remarks |
|--------------------|------------------------|--|
| Diesel Oil *1) | 237 \$/MT | Average from 1996 Nov. ~ 2001. July |
| Heavy Fuel Oil *2) | 154 \$/MT | Average from 1996 Nov.~ 2001. August |
| Natural Gas | 4.0 \$/MMBTU | Engineer's assumptions (L.H.V. base) 3.5 \$/MMBTU and 4.5 \$/MMBTU are also testified in the economic analysis. |

Source: *1) and *2) EDC

11.2.3. Fuel Shift

Since some fuel types seem to be applicable to the project at the moment, the following fuel scenarios are considered in the economic analysis.

- (1) Natural Gas will be used for whole period of 20-years economic lifetime from the beginning (**Base Case**).
- (2) Diesel Oil will be used for the first 5 years and Natural Gas will be used for the next 15 years.

- (3) Diesel Oil will be used for the first 10 years and Natural Gas will be used for the next 10 years.
- (4) Diesel Oil will be used for whole period of 20-years economic lifetime from the beginning.

11.24. Calculation Conditions

The project characteristics, which were revealed in the course of the study, and assumed condition, are summarized in Table 11.2-2.

Table 11.2-2 Project Characteristics and Assumed Conditions

| Items | Value | Unit | Remarks | | | | | | | | | | | | | | | | | | | | | | | | |
|----------------------------------|------------|------------|--|------|------|------|--------|------|------|------|--------|------|----|----|----|----|----|----|----|------|---|---|----|----|----|----|----|
| Installed capacity | 180 | MW | 90 MW x 2 stages | | | | | | | | | | | | | | | | | | | | | | | | |
| Capacity Factor (Average 54%) | | % | <table border="1"> <tr> <td></td> <td>2006</td> <td>2007</td> <td>2008</td> <td>2009</td> <td>2010</td> <td>2011</td> <td>2012 ~</td> </tr> <tr> <td>ST-1</td> <td>24</td> <td>75</td> <td>55</td> <td>63</td> <td>67</td> <td>70</td> <td>50</td> </tr> <tr> <td>ST-2</td> <td>-</td> <td>-</td> <td>18</td> <td>63</td> <td>67</td> <td>70</td> <td>50</td> </tr> </table> | | 2006 | 2007 | 2008 | 2009 | 2010 | 2011 | 2012 ~ | ST-1 | 24 | 75 | 55 | 63 | 67 | 70 | 50 | ST-2 | - | - | 18 | 63 | 67 | 70 | 50 |
| | 2006 | 2007 | 2008 | 2009 | 2010 | 2011 | 2012 ~ | | | | | | | | | | | | | | | | | | | | |
| ST-1 | 24 | 75 | 55 | 63 | 67 | 70 | 50 | | | | | | | | | | | | | | | | | | | | |
| ST-2 | - | - | 18 | 63 | 67 | 70 | 50 | | | | | | | | | | | | | | | | | | | | |
| Construction cost | 164.4 | M.\$ | Excluding Engineering and Administration Fees ST-1: 93.2 M.\$, ST-2 :71.2 M.\$ | | | | | | | | | | | | | | | | | | | | | | | | |
| Scheduled maintenance days | 49 | Days | For kW and kWh adjustments use only | | | | | | | | | | | | | | | | | | | | | | | | |
| Forced outage rate | 8.0 | % | | | | | | | | | | | | | | | | | | | | | | | | | |
| Station use | 2.8 | % | | | | | | | | | | | | | | | | | | | | | | | | | |
| Natural Gas | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Fixed O/M cost | 20.0 | \$/kW-year | | | | | | | | | | | | | | | | | | | | | | | | | |
| Fuel price | 4.0 | \$/MMBTU | LHV base, domestic price including markup | | | | | | | | | | | | | | | | | | | | | | | | |
| Heat rate | 6,829 | BTU/kWh | | | | | | | | | | | | | | | | | | | | | | | | | |
| Fuel cost | 27.32 | \$/MWh | | | | | | | | | | | | | | | | | | | | | | | | | |
| Variable O/M | 1.0 | \$/MWh | | | | | | | | | | | | | | | | | | | | | | | | | |
| Diesel Oil | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Fuel price | 6.02 | \$/MMBTU | LHV base, CIF Price for Diesel :237 \$/ton | | | | | | | | | | | | | | | | | | | | | | | | |
| Heat rate | 7,030 | BTU/kWh | | | | | | | | | | | | | | | | | | | | | | | | | |
| Fuel cost | 42.32 | \$/MWh | | | | | | | | | | | | | | | | | | | | | | | | | |
| Variable O/M | 2.5 | \$/MWh | | | | | | | | | | | | | | | | | | | | | | | | | |
| Construction period | 2 | Years | Disbursement schedule are 40 % and 60 %. | | | | | | | | | | | | | | | | | | | | | | | | |
| Construction start | 2004, 2006 | | 2-staged construction | | | | | | | | | | | | | | | | | | | | | | | | |
| Operation start | 2006, 2008 | | Each operation of 90 MW | | | | | | | | | | | | | | | | | | | | | | | | |
| Economic life time | 20 | Years | | | | | | | | | | | | | | | | | | | | | | | | | |

A diesel power plant with equivalent capacity to the project is set as an alternative thermal power plant in view of current supply system in Cambodia.

The following table shows the plant properties to be used as the representative of equivalent diesel power plant.

Table 11.2-3 Characteristics of Alternative Diesel and Assumed Conditions

| Items | Value | Unit | Remarks |
|----------------------------|------------|------------|---|
| Installed capacity | 197.8 | MW | 98.9 MW x 2 stages, (Middle Speed) |
| Annual generation | | GWh | 2006 2007 2008 2009 2010 2011 2012~ ST-1 192.8 602.4 441.8 506.1 538.2 562.3 401.7 ST-2 - - 144.5 506.1 538.2 562.3 401.7 |
| Construction cost | 271.0 | M.\$ | Excluding Engineering and Administration Fees |
| Scheduled maintenance days | 28 | days | |
| Forced outage rate | 20 | % | |
| Station use | 4.6 | % | |
| Fixed O/M cost | 21.0 | \$/kW-year | |
| Variable O/M cost | 3.0 | \$/MWh | |
| Fuel Price | 3.99 | \$/MMBTU | LHV base, CIF Price for HFO: 154.0 \$/ton |
| Heat rate | 7,888 | BTU/kWh | HFO |
| Fuel cost | 31.49 | \$/MWh | HFO |
| Construction period | 2 | years | Disbursement schedules are 50 % and 50 %. |
| Construction start | 2004, 2006 | | 2-staged construction |
| Operation start | 2006, 2008 | | Each operation of 90 MW |
| Economic life time | 20 | years | |
| kW Adjustment | 1.099 | | |
| kWh Adjustment | 1.019 | | |

11.25. Calculation Cases and Results

(1) Calculation Cases

10 calculation cases, with combination of fuel conversion scenario and natural gas price, are conducted as shown in Table 11.2-4.

Case Nos. 100s, 200s and 300s are focusing on the timing of natural gas fuel

availability and Case No. 400 represents the case of diesel oil for the whole economic life time to understand the economic advantage of the natural gas. Concerning the natural gas price, 4.0, 3.5 and 4.5 \$/MMBTU are assumed.

(2) Calculation Results

Table 11.2-4 also presents the results of economic analysis. Typical case (Case No. 100) is demonstrated in Table 11.2-5.

The economic indices show the excellent economic performance of the project except the Case No. 400 because the construction cost of the project is cheaper than that of the alternative diesel power plant and the natural gas fuel cost is also cheaper than the heavy fuel oil.

Table 11.2-4 Calculation Cases and Summary of Results

1. Calculation Cases

| Se.No. | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|---------------------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Case No. | 100 | 110 | 120 | 200 | 210 | 220 | 300 | 310 | 320 | 400 |
| A Fuel Conversion Scenario | | | | | | | | | | |
| (1) Natural Gas for full 20 years | | | | | | | | | | |
| (2) Diesel Oil 5 years + NG 15 years | | | | | | | | | | |
| (3) Diesel Oil 10 years + NG 10 years | | | | | | | | | | |
| (4) Diesel Oil for full 20 years | | | | | | | | | | |
| B Natural Gas Fuel Price | | | | | | | | | | |
| (1) 4.0 US\$/MMBTU | | | | | | | | | | |
| (2) 3.5 US\$/MMBTU | | | | | | | | | | |
| (3) 4.5 US\$/MMBTU | | | | | | | | | | |
| C Diesel Oil Price (CIF) | | | | | | | | | | |
| (1) 237 US\$/ton | | | | | | | | | | |

Note: means Base Case.

2. Calculation Results

| Economic Internal Rate of Return (EIRR) | % | N.A | N.A | N.A | N.A | N.A | N.A | N.A | N.A | N.A | N.A | N.A | N.A | N.A | N.A | N.A | N.A | N.A | N.A | 3.81*1 |
|---|--------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------|
| Net Present Value of Cost | M.US\$ | 249.3 | 233.7 | 264.2 | 276.3 | 266.5 | 299.0 | 294.1 | 303.6 | 321.7 | | | | | | | | | | |
| Net Present Value of Benefit | M.US\$ | 345.0 | 345.0 | 345.0 | 345.0 | 345.0 | 345.0 | 345.0 | 345.0 | 345.0 | | | | | | | | | | |
| B - C | M.US\$ | 95.7 | 111.3 | 80.8 | 68.7 | 78.5 | 46 | 50.9 | 41.4 | 23.3 | | | | | | | | | | |
| B/C | | 1.38 | 1.48 | 1.31 | 1.25 | 1.29 | 1.15 | 1.17 | 1.14 | 1.07 | | | | | | | | | | |

Note: Net Present Value as of 2001 is discounted value with 10 % discount rate.

N.A means EIRR>100 %

*1: For the Case No. 400, B-C becomes positive on condition that the discount rate is higher than 3.81 %, unless B-C becomes negative.

11.3. Financial Analysis

11.3.1. Objective

Financial analysis is carried out to verify the financial feasibility of the project from the viewpoint of the project owner and lenders. Therefore, market prices, which include taxes & duties, and subsidiaries, are used in the analysis.

Financial analysis is conducted in US\$ term because US\$ currency is prevalent in Cambodia¹ as well as Cambodian Riel.

11.3.2. Power Tariff Forecast

The average power tariff as of 2000 is 554 Riel/kWh² (or 14.57US¢ /kWh) and the power tariff rate is shown in Table 11.3-1.

The future power tariff is assumed based on EDC Report, ADB Project Report³ and the World Bank Project Report⁴, which are shown in Tables 11.3-2 and 11.3-3.

Table 11.3-2 Future Power Tariff Scenario (Riel/kWh)

| | 2001 | 2002 | 2003 | 2004 | 2005 | 2006 | 2007 |
|--------------------|------|------|------|------|------|------|------|
| ADB ^{*1)} | 652 | 700 | 752 | 728 | 730 | 746 | 778 |
| EDC ^{*2)} | 608 | 613 | 620 | 628 | 636 | 646 | 656 |

*1) ADB "Provincial Power Supply Project", November 2000, Appendix-9, Page 4, Table A9.1

*2) EDC Report, page 14

¹ Invoice of power tariff is made in Cambodian Riel and payment is allowed to be done by Riel or US\$ term for an example.

² "Prepared and Analyses Study, EDC's Strategic Planning for Year 2001, 2002 and 2003 within Planning until 2010", Page 14, EDC, November 2000

³ "Report and Recommendation of the President to the Board of Directors on a Proposed Loan to the Kingdom of Cambodia for the Provincial Power Supply Project", November 2000

⁴ "The World Bank Cambodia Rural Electrification and Transmission Project (PHRD TF025765) Feasibility Study Report for the Transmission Link between Phnom Penh and the Southern Region of Cambodia, Project Overview", April 2001

Table 11.3-3 Exchange Rate Forecast (Riel/\$) and Power Tariff Forecast (¢/kWh)

| | 2001 | 2002 | 2003 | 2004 | 2005 | 2006 | 2007 |
|---------------------------|-------|-------|-------|-------|-------|-------|-------|
| Exc. Rate ^{*3)} | 3,971 | 4,149 | 4,335 | 4,530 | 4,734 | 4,946 | 5,169 |
| EDC | 15.31 | 14.79 | 14.31 | 13.86 | 13.44 | 13.06 | 12.68 |
| ADB ^{*4)} | 16.42 | 16.87 | 17.35 | 16.07 | 15.42 | 15.08 | 15.05 |
| World Bank ^{*5)} | 16.1 | 16.1 | 16.1 | 14.5 | 13.8 | 13.4 | 12.5 |

*3) EDC Report, page 14

*4) ¢/kWh for ADB portion is calculated by using the above exchange rate.

*5) World Bank "Project Overview Report", Page 58, Table 7

Note: Exchange Rate against US\$ is assumed to be devaluated 4.5 % annually by EDC.

Based on the above forecast, the average power tariff from the year 2006 onwards is assumed to be 13.0 ¢/kWh.

However, the average power tariff consists of the following cost. Therefore, the power tariff contributing to the project finance is the power tariff less indirect cost.

- Direct operation costs (Fuel cost, Fixed O/M and Variable O/M costs)
- Power purchase cost from IPP
- Maintenance cost of transmission and distribution lines
- Overhead head

According to the EDC's statement of operation, the costs other than the direct operation cost in 1997 and 1999 were approximately 85% of total costs. Therefore, power tariff contributing to the project is set at 11.05 ¢/kWh (13 ¢/ kWh × 85% = 11.05).

Table 11.3-1 Tariff Structure of EDC (as of November 2001)

| 1. Phnom Penh Operation (Effective in August 2000) | | Existing Power Tariff | |
|---|----------------------------|-----------------------|-------------------------|
| | | Riel/kWh | c/kWh (1US\$=3900 Riel) |
| Sector | | | |
| I. Residential Sector | | | |
| | 0-50 kWh/month | 350 | 8.97 |
| | 51-100 kWh/month | 550 | 14.10 |
| | >100 kWh/month | 650 | 16.67 |
| II. Industrial & Handicraft Sector | | | |
| | <45,000 kWh/month | 600 | 15.38 |
| | 45,000 - 80,000 kWh/month | 550 | 14.10 |
| | 80,000 - 130,000 kWh/month | 550 | 14.10 |
| | >130,000 kWh/month | 500 | 12.82 |
| | MidiumVoltage | 480 | 12.31 |
| III. Commercial & Service Sectors | | | |
| | <45,000 kWh/month | 650 | 16.67 |
| | 45,000 - 80,000 kWh/month | 600 | 15.38 |
| | 80,000 - 130,000 kWh/month | 600 | 15.38 |
| | >130,000 kWh/month | 500 | 12.82 |
| | MidiumVoltage | 480 | 12.31 |
| IV. Hotels & Guest Houses | | | |
| | <45,000 kWh/month | 650 | 16.67 |
| | 45,000 - 80,000 kWh/month | 600 | 15.38 |
| | 80,000 - 130,000 kWh/month | 600 | 15.38 |
| | >130,000 kWh/month | 500 | 12.82 |
| | MidiumVoltage | 480 | 12.31 |
| V. Embassy, Foreigners' Houses,NGO Go | | 800 | 20.51 |
| VI. Government Institutions | | 700 | 17.95 |

| 2. Sihanoukville Operation (Effective in Feb.& Jul.1999) | | Riel/kWh | c/kWh | |
|---|----------------------------|------------|-------|-------|
| Sector | | | | |
| I. Residential Sector | | 500 | 12.82 | |
| II. Industrial & Handicraft Sector | | | | |
| | <20,000 kWh/month | 670 | 17.18 | |
| | 20,000 - 50,000 kWh/month | 670/610 a) | 17.18 | 15.64 |
| | 50,000 - 110,000 kWh/month | 670/560 | 17.18 | 14.36 |
| | >110,000 kWh/month | 670/513 | 17.18 | 13.15 |
| III. Commercial & Service Sector | | | | |
| | <20,000 kWh/month | 740 | 18.97 | |
| | 20,000 - 50,000 kWh/month | 685 | 17.56 | |
| | 50,000 - 110,000 kWh/month | 625 | 16.03 | |
| | >110,000 kWh/month | 570 | 14.62 | |
| IV. Hotel & Guest Houses | | | | |
| | <20,000 kWh/month | 760 | 19.49 | |
| | 20,000 - 50,000 kWh/month | 700 | 17.95 | |
| | 50,000 - 110,000 kWh/month | 650 | 16.67 | |
| | >110,000 kWh/month | 610 | 15.64 | |
| V. Houses for Foreigners | | 740 | 18.97 | |
| VI. Embassy, Government Institutions | | 760 | 19.49 | |

Note: a) 670/610 - night/day time

| 3. Siem Reap Operation (Effective in July 1999) | | Riel/kWh | c/kWh | |
|--|----------------------------|----------|-------|--|
| Sector | | | | |
| Overall Sector | | | | |
| | <20,000 kWh/month | 875 | 22.44 | |
| | 20,000 - 50,000 kWh/month | 735 | 18.85 | |
| | 50,000 - 110,000 kWh/month | 670 | 17.18 | |
| | >110,000 kWh/month | 620 | 15.90 | |

| 4. Kampong Cham Operation | | Riel/kWh | c/kWh | |
|----------------------------------|--|----------|-------|--|
| Sector | | | | |
| Flat Rate | | 850 | 21.79 | |

11.3.3. Fuel Cost and Fuel Conversion

The fuels applicable to the project are assumed to be diesel oil and natural gas.

(1) Fuel Cost

The fuel prices used in the financial analysis are market prices including the taxes and duties.

Taxes and duties shown in Table 11.3-4 are considered in the financial analysis.

Table 11.3-4 Taxes and Duties on Fuel

| Fuel Type | Import Tax | Social Fund | VAT |
|-------------|---------------------|-------------|------|
| Diesel Oil | 20 % | 1.40 \$/ton | 10 % |
| Natural Gas | None ^{*1)} | 1.40 \$/ton | 10 % |

Note: Taxes and duties for natural gas are assumed values.

*1) Natural Gas is assumed to be domestic product.

The fuel cost before taxes and duties are set at 237 \$/ton (CIF Price) for diesel oil and 4.0 \$/MMBTU (L.H.V. base) for natural gas. Annual escalation of 2 % is estimated for diesel oil and 0 % for natural gas from the year 2001 onwards.

(2) Fuel Shift

As mentioned in the economic analysis, natural gas is expected to be exploited in Cambodia in future. The timing of fuel shift is assumed as follows as well as economic analysis.

- (a) Natural Gas will be used for whole period of 20-years economic lifetime from the beginning (**Base Case**).
- (b) Diesel Oil will be used for the first 5 years and Natural Gas will be used for the next 15 years.
- (c) Diesel Oil will be used for the first 10 years and Natural Gas will be used for the next 10 years.
- (d) Diesel Oil will be used for whole period of 20-years economic lifetime from the beginning.

11.34. Implementation Method

The following two implementation methods for Sihanoukville C.C. Project are considered.

- (1) Option 1 : EDC will implement the project by using official loan.
- (2) Option 2 : The private investor will implement the project by his own finance and loans, and sell the power to EDC based on the Power Purchase Agreement (BOT).

11.35. Calculation Conditions

Based on the above considerations, the calculation conditions in the financial analysis are summarized in Table 11.3-5.

Table 11.3-5 Sihanoukville C.C. Project Calculation Conditions

| <i>Items</i> | <i>EDC Project</i> | | | | | <i>IPP Project (BOT)</i> | | |
|---|----------------------------|-------|-------|-------|-------|---|-------|-----|
| Installed Capacity | 90 MW × 2 stages = 180 MW | | | | | | | |
| Annual Capacity Factor (Average 54%) | 2006 | 2007 | 2008 | 2009 | 2010 | 2011 | 2012~ | |
| | ST-1 | 24% | 75% | 55% | 63% | 67% | 70% | 50% |
| | ST-2 | - | - | 18% | 63% | 67% | 70% | 50% |
| Station Use | 2.8 % | | | | | | | |
| T/L and Distribution Loss | 15.7% | | | | | 0% (Sales at P/S exit) | | |
| Salable Energy | Generation Energy × 81.94% | | | | | Generation Energy × 97.2% | | |
| Construction Cost for Stage 1 | After escalation | | | | | Import tax will be exempted. ^{*1)} | | |
| F/C | 101.6 Million \$ | | | | | 101.6 Million \$ | | |
| L/C inc. duties and taxes | 45.3 Million \$ | | | | | 31.9 Million \$ | | |
| Total (inc. T/L) | 146.9 Million \$ | | | | | 133.5 Million \$ | | |
| Construction Cost for Stage 2 | After Escalation | | | | | Import tax will be exempted. ^{*1)} | | |
| F/C | 75.5 Million \$ | | | | | 75.5 Million \$ | | |
| L/C inc. duties and taxes | 29.5 Million \$ | | | | | 18.8 Million \$ | | |
| Total (inc. T/L) | 105.0 Million \$ | | | | | 94.3 Million \$ | | |
| Escalation | | | | | | | | |
| L/C | 2.4 % per annum | | | | | | | |
| F/C | 2.4 % per annum | | | | | | | |
| Disbursement Schedule | 2004 | 2005 | 2006 | 2007 | 2008 | | | |
| Stage 1 | 22.8% | 50.3% | 26.9% | - | - | | | |
| Stage 2 | - | - | 22.2% | 51.3% | 26.5% | | | |

| <i>Items</i> | <i>EDC Project</i> | <i>IPP Project (BOT)</i> |
|---|--|--|
| Finance Planning | | |
| Financial Source | Subsidiary Loan - 1 | OIL US\$ Loan |
| Interest Rate (=IDC) | 3.5 % per annum | LIBOR+1 % *2) (3.46 + 1 = 4.46) |
| Commitment Fee | - | 0.25 % of remaining loan |
| Grace Period | 8 years | 5 years |
| Repayment Period | 23 years including grace period | 15 years |
| Loan Limit | 100 % of F/C or 85 % of the project cost | 60 % of debt portion |
| Top Front Fee | - | 1.0 % of loan amount |
| Finance Source | Subsidiary Loan - 2 | Bank Syndicate Loan |
| Interest rate (=IDC) | 3.5 % per annum | LIBOR+2.5 % (3.46 + 2.5=5.96) |
| Commitment Fee | - | 0.5 % |
| Front End Fee | - | 1.25 % of loan amount |
| Grace Period | 8 years | 5 years |
| Repayment Period | 23 years inc. 5 years grace period | 15 years including grace period |
| Loan Limitation | 100 % of F/C or 90 % of the construction cost inc. IDC | None |
| Equity : Debt | - | 30 % : 70 % |
| Economic Life Time | 20 years | |
| Depreciation Method | Accelerated method with 11 % for 20-years economic lifetime | |
| Power Tariff as of 2006 excluding maintenance cost of T/L, D/S and overhead | 11.05 ¢/kWh | ¢/kWh for PPA PPA: Power Purchase Agreement |
| Operation Cost | ST-1: 40.2 \$/kW-year (inc. T/L: 41.5) ST-2: 31.7 \$/kW-year | |
| Fixed O/M Cost | Natural Gas : 1.0 \$/MWh Diesel Oil : 2.5 \$/MWh | |
| Variable O/M Cost | Natural Gas : 30.27 \$/MWh Diesel Oil : 58.28 \$/MWh | |
| Fuel Cost | | |
| Tax and Duties | | |
| Profit Tax | 20% | 9 % with 8 years Tax Holiday *1) |
| Commencement of Operation | Stage 1: 2006 Sep.1 Stage 2: 2008 Sep.1 | |
| Discount Rate | 10 % | |
| Exchange Rate | 1 \$ = 4000 Riel as of 2001 | |

Note : *1) Power Purchase Agreement between Leader Universal Holdings Berhad Delcom Services SDN BHD INTERCORE INC. and EDC, Appendix K, page 94.

*2) LIBOR is 3.46 % as of October, 2001 (Source: www.bankrate.com/brm/news/biz/ratechart.asp)

11.3.6. Calculation Cases and Calculation Results

(1) Calculation Cases

Based on the above considerations, 27 cases as summarized in Table 11.3-6 are conducted.

(a) Case numbers of 1000s are the cases that the project is implemented by Subsidiary Loan-1.

- (b) Case numbers of 2000s are the cases that the project is implemented by Subsidiary Loan-2.
- (c) Case numbers of 3000s are the case that the project is implemented by IPP and the power tariff for PPA, which satisfies the ROE of 20%, is calculated. Power selling to EDC is assumed at power station outlet.
- (d) Case numbers of 4000s are focusing on generation cost excluding VAT and Profit Tax to compare the power purchase cost from Vietnam and IPP1. And distribution loss is also excluded for the comparison basis.

In association with the above implementation methods, Table 11.3-7 shows the summary of the total project cost including all costs.

(2) Calculation Results

Table 11.3-6 also shows the calculation results of the financial analysis and Case No. 1000 is demonstrated in Table 11.3-8.

(a) Project IRR

If the natural gas is used for the full economic lifetime or put into the operation before the 5th year, the project IRR of 10% is expected. On the other hand, if the diesel oil is used for the full economic life time, the project IRR cannot be calculated and the financial attractiveness will be eliminated.

Therefore, from the viewpoint of the project EIRR, the financial attractiveness will be expected on condition that the natural gas becomes available before the 5th year from the commencement of commercial operation.

(b) ROE & DSCR

As shown in Table 11.3-7, since EDC bears IDC portion only under the Subsidiary Loan Agreement, ROE presents the good performance for any cases. However, in view of DSCR, the minimum DSCR becomes less than 1.0 or negative if diesel oil is fired more than 10 years during the operation period. The DSCR less than 1.0 means that EDC has to borrow the additional loan for the interest payment and principal repayment due to shortage of own cash.

Therefore, the implementation of the project will be accepted by the Lenders if the natural gas is warranted to be put into the operation before the 5th year

from the commencement of the commercial operation, unless the implementation will not be accepted.

(c) Levelised Production Cost

At the price of natural gas of 4.0 \$/MMBTU, levelised production cost including taxes and duties under the effective power tariff of 11.05 ¢/kWh varies from 7.84 ¢/kWh to 9.45 ¢/kWh for the cases that the natural gas will be put into the project within the first 5 years during the operation period and 10.96 ¢/kWh to 12.85 ¢/kWh if natural gas is put into the project on 11th year or not put into the project. If the natural gas is available from the beginning of the operation, levelised production cost can be expected to be 30 % less in comparison with the case that the natural gas is put into the operation on 11th year.

(d) IPP Project

In case of the IPP project, the hurdle rate for the financial feasibility is set at 20 % of ROE. To achieve the ROE more than 20 %, the power tariff selling to EDC (at P/S exit) requires from 7.70 ¢/kWh to 9.85 ¢/kWh under the condition that natural gas is put into within 5 years and its price is 4.0 \$/MMBTU.

These selling prices will be equivalent to 9.13 ¢/kWh to 11.68 ¢/kWh at consumer's end level taken into account of T/L and D/L loss of 15.7%.

EDC has to purchase at more expensive cost than that of EDC implementation because the selling price to EDC at consumer's end is higher than the levelised production cost for the case of EDC.

If the diesel oil is used for the full operation period, the selling price of 14.39 ¢/kWh to EDC exceeds the expected power tariff of 13.00 ¢/kWh and cannot be accepted by EDC.

(e) Production Cost without Taxes

- Comparison with the current purchase tariff from IPP1

EDC purchases the power from IPP1s in Phnom Penh Operations at 8.94 ¢/kWh (1997) to 10.95 ¢/kWh (2000) based on the PPA. The above purchase prices do not include the duties and taxes, because EDC bears duties and taxes imposed on fuel, of which fuel is used by IPP1, instead of

IPP1.

The levelised production cost for Case No. 4000 is excluded duties and taxes, and profit tax to keep the same cost level with the current purchase tariff from IPP1.

The levelised production cost of the project of 5.78 ¢/kWh is clearly lower than the current purchase tariff from IPP1.

- Comparison with the power import from Vietnam

According to Power Purchase Agreement signed on July 24, 2000, the conditions on the power purchase from Vietnam are set as follows:

- a. Commencement of power purchase : year 2003⁵
- b. Source of supply : Thot Not substation via Chau Doc
- c. Interconnecting point : Border between Cambodia and Vietnam
- d. Metering point : Chau Doc substation
- e. Supply capacity : 80 MW between 2003 to 2005
: 200 MW after year 2005
- f. Power tariff effectiveness : 5 years
- g. Currency in payment : US\$

Table 11.3-9 Power Purchase Prices from Vietnam

| | | |
|------------------------------------|--------------------------------|------------|
| Dry Season (November ~ June 30) | Peak hours (18:00 ~ 22:00) | 8.50 ¢/kWh |
| | Normal hours (04:00 ~ 18:00) | 6.25 ¢/kWh |
| | Off-peak hours (22:00 ~ 04:00) | 4.50 ¢/kWh |
| Wet Season (July ~ October 31) | Peak hours (18:00 ~ 22:00) | 8.00 ¢/kWh |
| | Normal hours (04:00 ~ 18:00) | 6.00 ¢/kWh |
| | Off-peak hours (22:00 ~ 04:00) | 3.00 ¢/kWh |

The average purchase price at the border is estimated to be about 6.0 ¢/kWh⁶.

If the purchase price of 6.0 ¢/kWh at the border price converts to the equivalent prices at Takeo and at Phnom Penh taking into consideration

⁵ As mentioned in Section 2.4, available import year seems to be delayed.

⁶ Dry Season = $(8.5 \times 4 + 6.25 \times 14 + 4.5 \times 6) / 24 = 6.2$, Rainy Season = $(8.0 \times 4 + 6.0 \times 14 + 3.0 \times 6) / 24 = 5.6$, whole year = $(6.2 \times 8 + 5.6 \times 4) / 12 = 6.0$

of transmission line loss, the above border price will be as shown in Table 11.3-10 in comparison with the levelised production costs of Case No. 4000 and 4100.

Table 11.3-10 Comparison of Purchase Price and LPC

| | Power Purchase From Vietnam | Levelised Production Cost (LPC) |
|---------------|---|---------------------------------|
| At Phnom Penh | $6.0 / (1 - 0.02) = 6.12 \text{ ¢/kWh}$ | 5.78 ¢/kWh (No. 4000) |
| At Takeo | $6.0 / (1 - 0.01) = 6.06 \text{ ¢/kWh}$ | 5.73 ¢/kWh (No. 4100) |

Note) T/L loss from Chau Doc to Phnom Penh and to Takeo is assumed to be 2.0 % and 1.0 % respectively as mentioned before.

Based on the above comparison, it is expected that if the natural gas, of which exploring cost is 4.0 \$/MMBTU, will be put into the operation from the commencement of the commercial operation, production cost of the project will be less than the purchase price from Vietnam.

Further more, if the Sihanoukville Industrial Zone is realized in future⁷, the project will be more advantageous in virtue of its location.

⁷ According to ADB information, the improvement of Sihanoukville Air Port from the domestic air port to the international air port is under negotiation between RGC and Bangkok Airways to induce the overseas investors.

Table 11.3-6 Calculation Cases and Results for Financial Analysis

| Se.No. | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 |
|--|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|----|
| Case No. | 1000 | 1010 | 1020 | 1100 | 1110 | 1120 | 1200 | 1210 | 1220 | 1300 | 1400 | 2000 | 2010 | 2100 | 2110 | 2120 | 2300 | 3000 | 3010 | 3020 | 3100 | 3110 | 3120 | 3300 | 4000 | 4100 | |
| 1. Calculation Cases | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| A. Finance Sources | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| (1) Subsidiary Loan - 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| (2) Subsidiary Loan - 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| (3) OIL + Bank Syndicate Loan | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| B. Implementation Method | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| (1) Implemented by EDC | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| (2) IPP | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| C. Fuel Conversion Scenario | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| (1) Natural Gas for full 20 years | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| (2) Diesel 5 years + NG 15 years | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| (3) Diesel 10 years + NG 10 years | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| (4) Diesel Oil for full 20 years | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| D. Natural Gas Price (inc. Taxes) | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| (1) 4.43 US\$/MMBTU | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| (2) 3.88 US\$/MMBTU | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| (3) 4.98 US\$/MMBTU | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| E. Diesel Oil Price (inc. Taxes) | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| (1) 326.54 US\$/ton | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| F. T/L from Kampot to Site | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| (1) Including T/L (11.8 M.US\$) | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| (2) Excluding T/L | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| G. Power consumption at Phnom Penh | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| (1) Phnom Penh | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| (2) Takeo | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| H. Value Added Tax & Profit Tax | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| (1) No VAT | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| (2) No Profit Tax | | | | | | | | | | | | | | | | | | | | | | | | | | | |

2. Calculation Results

| | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|--|------|------|------|-------|------|-------|-------|-------|-------|-------|------|------|------|------|-------|------|-------|-------|------|------|------|------|------|-------|-------|------|------|
| 1. Project IRR (%) | 11.6 | 12.7 | 10.5 | 6.6 | 7.1 | 5.9 | 3.0 | 3.4 | 2.6 | N.A. | 13.2 | 11.6 | 12.7 | 10.5 | 6.6 | 7.1 | 5.9 | N.A. | 8.9 | 9.0 | 8.9 | 10.0 | 10.1 | 10.0 | 8.0 | 20.7 | 21.0 |
| Stage-1 | 16.5 | 17.7 | 15.2 | 12.1 | 12.8 | 11.2 | 7.1 | 7.5 | 6.5 | N.A. | 16.5 | 16.5 | 17.7 | 15.2 | 12.1 | 12.8 | 11.2 | N.A. | 14.1 | 14.1 | 14.2 | 16.9 | 17.1 | 16.7 | 12.3 | 27.6 | 28.0 |
| Stage-2 | 13.5 | 14.5 | 12.3 | 8.7 | 9.7 | 8.1 | 4.8 | 5.2 | 4.3 | N.A. | 14.5 | 13.5 | 14.5 | 12.3 | 8.7 | 9.7 | 8.1 | N.A. | 10.9 | 11.0 | 10.9 | 12.6 | 12.8 | 12.5 | 9.6 | 23.0 | 23.1 |
| Stage-1 & Stage-2 | 210 | 224 | 197 | 46 | 48 | 43 | 1 | 4 | -2 | N.A. | 237 | 210 | 224 | 196 | 45 | 47 | 43 | N.A. | 15.0 | 15.0 | 14.9 | 14.7 | 14.7 | 14.8 | 15.0 | 30.9 | 31.3 |
| Stage-1 | 244 | 258 | 230 | 91 | 94 | 88 | 33 | 35 | 31 | N.A. | 244 | 245 | 258 | 230 | 91 | 94 | 88 | N.A. | 29.4 | 29.4 | 29.5 | 30.2 | 30.3 | 30.2 | 29.2 | 33.7 | 34.2 |
| Stage-2 | 213 | 226 | 199 | 59 | 61 | 57 | 14 | 16 | 11 | N.A. | 238 | 213 | 226 | 199 | 59 | 61 | 56 | N.A. | 20.0 | 20.0 | 20.0 | 19.9 | 19.9 | 20.0 | 20.1 | 31.0 | 31.4 |
| Stage-1 & Stage-2 | 1.0 | 1.1 | 0.9 | 1.0 | 1.1 | 0.9 | 0.1 | 0.1 | 0.1 | -0.6 | 1.1 | 1.0 | 1.1 | 0.9 | 1.0 | 1.1 | 0.9 | -0.6 | 1.0 | 1.0 | 1.0 | 0.6 | 0.5 | 0.7 | 0.9 | 1.8 | 1.8 |
| 3. Min. Debt Service Coverage Ratio | 1.5 | 1.6 | 1.4 | 1.5 | 1.6 | 1.4 | 0.2 | 0.2 | 0.2 | -0.9 | 1.5 | 1.5 | 1.6 | 1.3 | 1.5 | 1.6 | 1.3 | -0.9 | 1.5 | 1.5 | 1.5 | 2.3 | 2.4 | 2.2 | 1.2 | 2.6 | 2.7 |
| Stage-1 | 1.5 | 1.6 | 1.4 | 1.1 | 1.1 | 1.1 | 0.1 | 0.1 | 0.1 | -0.9 | 1.5 | 1.5 | 1.6 | 1.3 | 1.1 | 1.1 | 1.1 | -0.9 | 1.2 | 1.2 | 1.2 | 1.0 | 0.9 | 1.1 | 1.1 | 2.4 | 2.4 |
| Stage-2 | 8.12 | 7.77 | 8.49 | 10.07 | 9.90 | 10.28 | 11.44 | 11.36 | 11.55 | 13.04 | 7.90 | 8.15 | 7.79 | 8.53 | 10.10 | 9.92 | 10.31 | 13.08 | 7.26 | 6.89 | 7.66 | 9.14 | 8.94 | 9.34 | 11.86 | 6.09 | 6.02 |
| Stage-1 & Stage-2 | 7.48 | 7.12 | 7.84 | 8.65 | 8.39 | 8.91 | 10.34 | 10.21 | 10.48 | 12.59 | 7.48 | 7.49 | 7.13 | 7.86 | 8.66 | 8.41 | 8.94 | 12.61 | 6.34 | 5.96 | 6.73 | 7.52 | 7.25 | 7.80 | 11.25 | 5.40 | 5.34 |
| 4. Levelised Production Cost (¢/kWh) | 7.84 | 7.48 | 8.20 | 9.45 | 9.24 | 9.67 | 10.96 | 10.86 | 11.08 | 12.83 | 7.72 | 7.86 | 7.50 | 8.23 | 9.47 | 9.26 | 9.71 | 12.88 | 6.86 | 6.48 | 7.25 | 8.43 | 8.20 | 8.66 | 11.59 | 5.78 | 5.73 |
| Stage-1 | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | 7.70 | 7.32 | 8.09 | 9.85 | 9.68 | 10.04 | 12.13 | - | - |
| Stage-2 | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Stage-1 & Stage-2 | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| Power Tariff for PPA (¢/kWh) at P/S exit | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |

**Table 11.3-7 Total Project Cost and Finance Arrangement for
Sihanoukville Combined Cycle Project**

Subsidiary Loan - 1

(Unit :Million US\$)

| | Stage-1 | | | Stage-2 | | | Stage-1 & Stage-2 | | |
|----------------------|--------------|-------------|--------------|-------------|-------------|--------------|-------------------|-------------|--------------|
| | F/C | L/C | Total | F/C | L/C | Total | F/C | L/C | Total |
| Construction Cost | 79.9 | 16.0 | 95.9 | 62.4 | 8.8 | 71.2 | 142.3 | 24.8 | 167.1 |
| Physical Contingency | 3.8 | 0.6 | 4.4 | 3.0 | 0.4 | 3.4 | 6.8 | 1.0 | 7.8 |
| Price Contingency | 8.5 | 1.6 | 10.1 | 10.1 | 1.4 | 11.5 | 18.6 | 3.0 | 21.6 |
| Duties and Taxes | 0.0 | 24.7 | 24.7 | 0.0 | 18.9 | 18.9 | 0.0 | 43.6 | 43.6 |
| IDC by EDC | 7.6 | 0.0 | 7.6 | 5.4 | 0.0 | 5.4 | 13.0 | 0.0 | 13.0 |
| Associated T/L | 9.4 | 2.4 | 11.8 | 0.0 | 0.0 | 0.0 | 9.4 | 2.4 | 11.8 |
| Total | 109.2 | 45.3 | 154.5 | 80.9 | 29.5 | 110.4 | 190.1 | 74.8 | 264.9 |

| | Stage-1 | | Stage-2 | | Stage-1 & Stage-2 | |
|--------------|--------------|---------------|--------------|---------------|-------------------|---------------|
| | Amount | Portion | Amount | Portion | Amount | Portion |
| Loan - A | 122.2 | 79.1% | 86.1 | 78.0% | 208.3 | 78.6% |
| RGC | 24.7 | 16.0% | 18.9 | 17.1% | 43.6 | 16.5% |
| EDC | 7.6 | 4.9% | 5.4 | 4.9% | 13 | 4.9% |
| Total | 154.5 | 100.0% | 110.4 | 100.0% | 264.9 | 100.0% |

2. Subsidiary Loan - 2

(Unit :Million US\$)

| | Stage-1 | | | Stage-2 | | | Stage-1 & Stage-2 | | |
|---------------------------|--------------|-------------|--------------|-------------|-------------|--------------|-------------------|-------------|--------------|
| | F/C | L/C | Total | F/C | L/C | Total | F/C | L/C | Total |
| Construction Cost inc.IDC | 81.7 | 16.0 | 97.7 | 63.7 | 8.8 | 72.5 | 145.4 | 24.8 | 170.2 |
| Physical Contingency | 3.8 | 0.6 | 4.4 | 3.0 | 0.4 | 3.4 | 6.8 | 1.0 | 7.8 |
| Price Contingency | 8.5 | 1.6 | 10.1 | 10.1 | 1.4 | 11.5 | 18.6 | 3.0 | 21.6 |
| Duties and Taxes | 0.0 | 24.7 | 24.7 | 0.0 | 18.9 | 18.9 | 0.0 | 43.6 | 43.6 |
| IDC by EDC | 7.6 | 0.0 | 7.6 | 5.4 | 0.0 | 5.4 | 13.0 | 0.0 | 13.0 |
| Associated T/L | 9.4 | 2.4 | 11.8 | 0.0 | 0.0 | 0.0 | 9.4 | 2.4 | 11.8 |
| Total | 111.0 | 45.3 | 156.3 | 82.2 | 29.5 | 111.7 | 193.2 | 74.8 | 268.0 |

| | Stage-1 | | Stage-2 | | Stage-1 & Stage-2 | |
|------------------|--------------|---------------|--------------|---------------|-------------------|---------------|
| | Amount | Portion | Amount | Portion | Amount | Portion |
| Loan - B inc.IDC | 124.0 | 79.3% | 87.4 | 78.2% | 211.4 | 78.9% |
| RGC | 24.7 | 15.8% | 18.9 | 16.9% | 43.6 | 16.3% |
| EDC | 7.6 | 4.9% | 5.4 | 4.8% | 13.0 | 4.9% |
| Total | 156.3 | 100.0% | 111.7 | 100.0% | 268.0 | 100.0% |

3. Overseas Investment Loan + Bank Syndicate Loan

(Unit :Million US\$)

| | Stage-1 | | | Stage-2 | | | Stage-1 & Stage-2 | | |
|----------------------|--------------|-------------|--------------|-------------|-------------|--------------|-------------------|-------------|--------------|
| | F/C | L/C | Total | F/C | L/C | Total | F/C | L/C | Total |
| Construction Cost | 79.9 | 16.0 | 95.9 | 62.4 | 8.8 | 71.2 | 142.3 | 24.8 | 167.1 |
| Physical Contingency | 3.8 | 0.6 | 4.4 | 3.0 | 0.4 | 3.4 | 6.8 | 1.0 | 7.8 |
| Price Contingency | 8.5 | 1.6 | 10.1 | 10.1 | 1.4 | 11.5 | 18.6 | 3.0 | 21.6 |
| Duties and Taxes | 0.0 | 11.3 | 11.3 | 0.0 | 8.2 | 8.2 | 0.0 | 19.5 | 19.5 |
| IDC & Financial Fee | 8.9 | 0.0 | 8.9 | 6.2 | 0.0 | 6.2 | 15.1 | 0.0 | 15.1 |
| Associated T/L | 9.4 | 2.4 | 11.8 | 0.0 | 0.0 | 0.0 | 9.4 | 2.4 | 11.8 |
| Total | 110.5 | 31.9 | 142.4 | 81.7 | 18.8 | 100.5 | 192.2 | 50.7 | 242.9 |

| | Stage-1 | | Stage-2 | | Stage-1 & Stage-2 | |
|---------------------|--------------|---------------|--------------|---------------|-------------------|---------------|
| | Amount | Portion | Amount | Portion | Amount | Portion |
| OIL | 59.9 | 42.1% | 42.2 | 42.0% | 102.1 | 42.0% |
| Bank Syndicate Loan | 39.8 | 27.9% | 28.1 | 28.0% | 67.9 | 28.0% |
| IPP Own Finance | 42.7 | 30.0% | 30.2 | 30.0% | 72.9 | 30.0% |
| Total | 142.4 | 100.0% | 100.5 | 100.0% | 242.9 | 100.0% |

Table 11.3-8 (1/2) Profit and Loss Statement for Case No. 1000

| Case No. | 1000 | 1st Stage | | 2nd Stage | | | | | |
|---------------------------|---|-----------|------------|-----------|----------|-------|-------|-------|--|
| Rated Capacity | 90 MW | 90 MW | 90 MW | | | | | | |
| Construction Period | 2 years | 2 years | 2 years | | | | | | |
| Subsidiary Loan Condition | | | | | | | | | |
| Source - A Loan | 122.2 MU\$ | 5.5% | 86.1 MU\$ | 3.5% | 8 years | | | | |
| Relend by MEF to EDC | 24.7 MU\$ | 8 years | 18.9 MU\$ | 23 years | 23 years | | | | |
| Total Loan Amount | 146.9 MU\$ | | 105.0 MU\$ | | | | | | |
| EDC Equity | 7.6 MU\$ | | 5.4 MU\$ | | | | | | |
| Total Project Cost | 154.5 MU\$ | | 110.4 MU\$ | | | | | | |
| Construction Cost | 122.2 MU\$ | | 86.1 MU\$ | | | | | | |
| Operation Start | 2006 year | 9 months | 2008 year | 9 months | | | | | |
| Years | 2006 | 2007 | 2008 | 2009 | 2010 | 2011 | 2012 | 2028 | |
| Capacity Factor | 0.24 | 0.75 | 0.55 | 0.63 | 0.70 | 0.50 | 0.50 | 0.33 | |
| Generation Energy | 189.2 | 591.3 | 433.6 | 496.7 | 528.2 | 551.9 | 394.2 | 260.2 | |
| Station Use | 5.3 | 16.6 | 12.1 | 13.9 | 14.8 | 15.5 | 11 | 7.3 | |
| Sending-out Energy | 183.9 | 574.7 | 421.5 | 482.8 | 513.4 | 536.4 | 383.2 | 252.9 | |
| T/L and D/S Loss | 28.9 | 90.2 | 66.2 | 75.8 | 80.6 | 84.2 | 60.2 | 39.7 | |
| Salable Energy | 155.0 | 484.5 | 355.3 | 407.0 | 432.8 | 452.2 | 323 | 213.2 | |
| Fixed O/M cost | 40.2 \$/KW-year for Plant | | | | | | | | |
| | 41.5 \$/KW-year including Transmission Line | | | | | | | | |
| Transmission Line | | | | | | | | | |
| Economic Life Time | | | | | | | | | |
| T/L and D/S Loss | | | | | | | | | |

| Scheduled Maintenance | - days | Fuel Type | 1 | NG |
|-----------------------|----------|-------------------|---------------------------|----|
| Forced Outage Rate | - | Fuel Price | 4.43 \$/MBtu | |
| Station Use | 2.8% | Fuel Cost | 8.29 \$/ton | |
| Economic Life Time | 20 years | Fuel Conversion | 1 | 1 |
| T/L and D/S Loss | 15.7% | Conversion System | 1 | 1 |
| | | Conversion System | 0.0 MU\$ for Whole Stages | |

| Fuel Cost as of | | Fuel Escalation | | | | | | | | | | | | | | | | | |
|-----------------|--------|-----------------|-----------------|--------------------|---------------|--------------|--------------|--------------|-----------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Type No. | Symbol | Fuel Name | Fuel Price-(CF) | Fuel Price aff Tax | Fuel Price -2 | Efficiency | Fuel Cost | Variable O/M | Fuel Escalation | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
| 1 | NG | Natural Gas | 4.0 \$/MBtu | 4.43 \$/MBtu | 4.43 \$/MBtu | 6829 Btu/kWh | 30.27 \$/MWh | 1.0 \$/MWh | 0.0% | - | - | - | - | - | - | - | - | - | - |
| 2 | DC | Diesel Oil | 237 \$/ton | 326.5 \$/ton | 8.29 \$/ton | 7030 Btu/kWh | 38.28 \$/MWh | 2.5 \$/MWh | 2.0% | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 |

| Fuel Cost as of | | Fuel Escalation | | | | | | | | | | | | | | | | | |
|-----------------|--------|-----------------|-----------------|--------------------|---------------|--------------|--------------|--------------|-----------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Type No. | Symbol | Fuel Name | Fuel Price-(CF) | Fuel Price aff Tax | Fuel Price -2 | Efficiency | Fuel Cost | Variable O/M | Fuel Escalation | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
| 1 | NG | Natural Gas | 4.0 \$/MBtu | 4.43 \$/MBtu | 4.43 \$/MBtu | 6829 Btu/kWh | 30.27 \$/MWh | 1.0 \$/MWh | 0.0% | - | - | - | - | - | - | - | - | - | - |
| 2 | DC | Diesel Oil | 237 \$/ton | 326.5 \$/ton | 8.29 \$/ton | 7030 Btu/kWh | 38.28 \$/MWh | 2.5 \$/MWh | 2.0% | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 |

| Fuel Cost as of | | Fuel Escalation | | | | | | | | | | | | | | | | | |
|-----------------|--------|-----------------|-----------------|--------------------|---------------|--------------|--------------|--------------|-----------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Type No. | Symbol | Fuel Name | Fuel Price-(CF) | Fuel Price aff Tax | Fuel Price -2 | Efficiency | Fuel Cost | Variable O/M | Fuel Escalation | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
| 1 | NG | Natural Gas | 4.0 \$/MBtu | 4.43 \$/MBtu | 4.43 \$/MBtu | 6829 Btu/kWh | 30.27 \$/MWh | 1.0 \$/MWh | 0.0% | - | - | - | - | - | - | - | - | - | - |
| 2 | DC | Diesel Oil | 237 \$/ton | 326.5 \$/ton | 8.29 \$/ton | 7030 Btu/kWh | 38.28 \$/MWh | 2.5 \$/MWh | 2.0% | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 |

| Fuel Cost as of | | Fuel Escalation | | | | | | | | | | | | | | | | | |
|-----------------|--------|-----------------|-----------------|--------------------|---------------|--------------|--------------|--------------|-----------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Type No. | Symbol | Fuel Name | Fuel Price-(CF) | Fuel Price aff Tax | Fuel Price -2 | Efficiency | Fuel Cost | Variable O/M | Fuel Escalation | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
| 1 | NG | Natural Gas | 4.0 \$/MBtu | 4.43 \$/MBtu | 4.43 \$/MBtu | 6829 Btu/kWh | 30.27 \$/MWh | 1.0 \$/MWh | 0.0% | - | - | - | - | - | - | - | - | - | - |
| 2 | DC | Diesel Oil | 237 \$/ton | 326.5 \$/ton | 8.29 \$/ton | 7030 Btu/kWh | 38.28 \$/MWh | 2.5 \$/MWh | 2.0% | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 |

| Fuel Cost as of | | Fuel Escalation | | | | | | | | | | | | | | | | | |
|-----------------|--------|-----------------|-----------------|--------------------|---------------|--------------|--------------|--------------|-----------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Type No. | Symbol | Fuel Name | Fuel Price-(CF) | Fuel Price aff Tax | Fuel Price -2 | Efficiency | Fuel Cost | Variable O/M | Fuel Escalation | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 |
| 1 | NG | Natural Gas | 4.0 \$/MBtu | 4.43 \$/MBtu | 4.43 \$/MBtu | 6829 Btu/kWh | 30.27 \$/MWh | 1.0 \$/MWh | 0.0% | - | - | - | - | - | - | - | - | - | - |
| 2 | DC | Diesel Oil | 237 \$/ton | 326.5 \$/ton | 8.29 \$/ton | 7030 Btu/kWh | 38.28 \$/MWh | 2.5 \$/MWh | 2.0% | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 | 394.2 |

11.4. Conclusion

In the course of the economic and financial analyses, the following conclusions are induced under the current assumed conditions.

- (1) Total project cost including the duties and taxes, IDC and other financial fees, and the associated transmission line from the Site to Kampot is anticipated to be 155 Million US\$ for Stage 1 and 110 Million US\$ for Stage 2 respectively.
- (2) If the natural gas is put into the operation before the 5th year from the commencement of the commercial operation, the good economic and financial performances are expected. On the other hand, if the diesel oil is fired during the full operation period, the economic and financial feasibility of the project will not be expected.
- (3) Especially, if the natural gas is available from the beginning of the commercial operation, production cost of the project will be much lower than the current purchase price from IPP1 and be less expensive than the power purchase from Vietnam in future.
- (4) Natural Gas price of 4.0 \$/MMBTU seems to be rather conservative in comparison with the current world market prices⁸. Therefore, if the natural gas price is available at less than 4.0 \$/MMBTU, more economic and financial attractiveness will be expected.
- (5) Based on the above considerations, Fig.11.4-1 presents the various power costs related to the EDC activities and results of financial analysis. As shown in Fig.11.4-1, Sianoukville C.C Power Plant with natural gas firing for full 20 years operation period presents the lowest cost among the each cost level and is expected to contribute to reduction of future power tariff of EDC remarkably.
- (6) The only issue to be overcome by EDC in order to implement the project seems to be financial problem. The current management of EDC has been suffering from a

⁸ According to “2001 World Development Indicators, World Bank”, the average price of natural gas from the year 1998 to 2000 is 2.72 \$/MMBTU at Europe and 2.81 \$/MMBTU in US.

deficit since 1997. Under the current financial situation of EDC, it seems to be difficult to bear the IDC, even though the EDC occupies only 5 % of the total project cost. Since Sihanoukville Combined Cycle Project requires the huge investment amounted to be around 265 Million US\$ and is the first big project for EDC, the improvement of the EDC management will be desirable until the implementation of the project.

12. Issues in Implementation of Project

12.1. Fuel

In the Project, natural gas is planned as main fuel and diesel is as back-up fuel. However, as stated in Section 3.1, natural gas is not available at present in Cambodia. The Cambodian government is studying several options to make natural gas available, namely, development of gas resources offshore in the Cambodian territory and import from neighboring countries. However, every option has some issues respectively, then it seems to be difficult to get conclusion in a short time.

The most preferable option to realize utilization of natural gas would be a development in the Cambodian territory. That could be considered the most beneficial solution to Cambodia due to effective use of own natural energy resources, proceeding a plan by own decision without disturbance by others and saving of foreign currency.

Meanwhile, according to the information of the gas developer, Woodside Co., the development of natural gas in offshore Cambodia is not necessarily favorable in economic aspect because of relatively small reserved volume per well. This means that many wells should be drilled, then the development cost becomes higher. In addition, since, at present, there is no significant gas consumer other than this Sihanoukville power project in Cambodia, the construction cost of pipeline per unit volume of gas becomes more costly. Generally price of natural gas tends to become cheaper in proportion to increase of demand. It is said that the size of 180 MW power generation is rather small to ensure economical price of natural gas, and preferable size would be larger than 300 MW.

Therefore, attainable gas price counting such disadvantageous conditions in is a key point to realize this Project.

If the Cambodia government makes a policy that future power development is based on gas fired gas turbine combined cycles, and shows in his power development plan a planned size and commissioning time of specific power plant, that plan would accelerate strongly the development of natural gas.

12.2. Implementation Schedule

12.2.1. Relation with Transmission Line between Kampot and Sihanoukville

In the study of the optimum power development plan, the Sihanoukville power plant is concluded to commence Stage 1 in 2006 and Stage 2 in 2008. However, as shown in Fig.10-1, the attainable commissioning time of Stage 1 depends on the schedule of transmission line between Kampot and Sihanoukville.

The concrete plan of this transmission line is not exist so far, and neither a feasibility study is commenced. The schedule shown in Fig.10-1 is only an imaginary and not-confirmed schedule that can keep the required completion of the Sihanoukville power plant. Therefore, to ensure the schedule of completion time of the power plant, the feasibility study of transmission line is recommended to start as soon as possible without waiting the final decision of the power plant construction.

12.2.2. Relation with Available Time of Natural Gas

Meanwhile, another issue is a time that natural gas becomes available to the Plant if it is intended to use natural gas from the start of the Plant. The Plant is planned to use diesel oil as back-up fuel, therefore, the Plant can be operated by using diesel oil until natural gas comes with a demerit by high fuel cost in short period. However, even if diesel oil is used initially, the specific available time of natural gas needs to be confirmed at the time of decision of construction of the Project. Otherwise, it would become difficult to convince a lender to arrange a loan for the Project.

According to the information from the developer of natural gas, the expected time from a signing of production sharing contract (PSC) to commercial production of natural gas is about 5 years. However, so far the signing of PSC between CNPA and the developer is not yet done, therefore it is questionable whether natural gas becomes available in 2006. In addition, to conclude to supply natural gas to the Project it is required to agree the price of gas. Generally this kind negotiation requires so long period, so, to assure the commissioning time of the Project as required, the relevant parties, MIME and EDC, should take an initiative of the negotiation.

12.3. Structure of Power Generation in Cambodia

At present, the biggest power supply source is IPP1 with capacity of 37.1 MW, which is a independent power supplier. Other power plants are mostly of small diesel power plant with capacities between several thousand kW to 20 MW less. In addition to these, Kirirom hydropower (12 MW), which is also IPP, is planned to start in 2003, and the power trade with Vietnam is planned to start in 2004. And, excepting the Sihanoukville power plant, all planned power plants in future are of hydro power plant, namely Kamchay (47- 127 MW), Stung Atay (110 MW), St. Russei Chrum (125 MW) and Battambang (60 MW).

IPP1 and Kirirom can not be expected to take a role of load adjusting operation because of Take-or-Pay power purchase agreement. And other hydro power plants will be operated to generate power in correspondence to a utilizable water quantity without load adjusting. Therefore load adjustable power sources are only the Sihanoukville P/P, C-6 (18MW) and the interconnection with Vietnam except the existing diesel power plants that are planned to retire in future.

The Sihanoukville power plant is a new and high efficiency plant, therefore, it is expected to operate on high base-load and supply cheap power. However, due to the above situations the Sihanoukville P/P could not operate at so high load as to perform the expected role.

Another problem related to hydropower is that the operation load of hydropower is significantly different by the seasons, namely, high-load operation in the wet season and low-load operation in the dry season. To compensate this load difference the thermal power plant has to operate on high load in the dry season and low load in the wet season. The capacity of such thermal power plant is determined considering the minimum load of hydropower in the dry season, that results in the low capacity factor and low economic performance of thermal power plant. In other words, higher reserve margin is required as a whole power generation system.

From the above mentioned points of view, it goes without saying that introduction of IPP with high power price should be avoided, but the power generation balance be-

tween hydropower and thermal power should also be studied in the power development plan with considering the investment cost and operation cost required in whole system.

Expansion of thermal power generation capacity in future power development would be beneficial to realize a cheaper price of natural gas.

12.4. Management, Operation and Personal Allocation

Most of power plants in Cambodia are of diesel generator power plant except one small capacity boiler-turbine power plant. They have never experienced of operation of gas turbine as well as gas turbine combined power plant. Therefore, it is recommended that the operators or staff to be assigned to the Sihanoukville power plant will have training immediately after the decision of construction, preferably actual operation training in a similar power plant outside the country. In addition, during the first 2 or 3 years operation of the Plant, for training EDC's operators, it is recommended to employ skillful expatriate engineers as temporary staffs who are assigned to the operation team leaders. For management and administration for a whole power plant, it is also recommended to employ expatriate staff for initial stage, who can manage and make plans for operation, maintenance & inspection, procurement of materials, etc.

The required number of staff for the Sihanoukville power plant is estimated 151 at the time of Stage 2 completion. Of them, the number of engineer is 115.

While the total number of employee of EDC as of 2000 is 1,513, and the total number of personnel classified into "Engineer", "Vocational Technician" and "Skilled worker" is 858. And, the number of employees belong to the power plants is about 540 in total, about 330 in Phnom Penh area and about 210 in the regional power stations, respectively.

From the above data, the present staff capacity of EDC seems to be able to supply the required staff for the Sihanoukville power station on the condition that the existing old diesel power plants in Phnom Penh area will be closed down step by step. However, this needs relocation of a significant number of employees from the capital city Phnom Penh to the regional city Sihanoukville, of which distance is about 260 km. Therefore, some part of staff may be required to be hired newly in the Sihanoukville area.

12.5. Finance

In the course of the study, the project cost including the associated transmission line from the site to Kampot is estimated to be 265 Million US\$ (or 31,800 Million Japanese Yen), in which an official soft loan will be applied amounted to 212 Million US\$ (or 25,400 Million Japanese Yen).

The JBIC loan is also one of the candidates of the official soft loan. The latest loan amount financed by JBIC to the Government of Cambodia was 4,100 Million Japanese Yen, which was applied to “Sihanoukville Port Urgent Rehabilitation Project” in 1999. Since the required finance amount of 25,400 Million Japanese Yen extremely exceeds the above actual finance amount, JBIC may not be able to afford the required finance by itself. Co-finance by JBIC and ADB is also one of the alternatives for the finance planning.

Stage 2 is planned to be constructed after 2 years since Stage 1 is constructed. However, the implementation of Stage 2 might be delayed in view of the finance procurement.

13. Overall Assessment and Recommendation

13.1. Overall Assessment

- (1) The Sihanoukville power plant is recommended to commence on 2006 for Stage 1 of 90 MW and 2008 for Stage 2 of another 90 MW. However, possible commencement time will depend on the schedule of transmission line between Takeo and Sihanoukville and also depend on the time natural gas becomes available.
- (2) The most preferable plant type is natural gas fired gas turbine combined cycle plant.
- (3) The optimum plant site is Option-4, which is located about 9 km away from the urban area of Sihanoukville City in north-northeast direction and just near Sokimex Oil Terminal.
- (4) The fuels used in the plant are natural gas as main and diesel oil for back up. Supply source of natural gas is still under studying on several options, but the most preferable option may be development in Cambodia territory.
- (5) The power plant is preferably use natural gas from the start of the operation. The target price of natural gas is around 4.0 \$/MMBTU (LHV Base, tax free) to keep the levelised power production cost of less than 6 ¢/kWh.
- (6) The levelised production cost is estimated to remain 7.8 ¢/kWh in the financial analysis even though the natural gas (4 \$/MMBTU) is put into the operation from the commencement. The production costs of natural gas combined cycle power plants in Southeast Asia are said to be 4.0 ~ 5.0 ¢/kWh. The above 7.8 ¢/ kWh seems to be still expensive in comparison with those in Southeast Asia.
The reasons why the production cost of the project becomes rather expensive may be explained by the following circumstances, which the power sector in Cambodia encounters.
 - (a) The natural gas price is envisaged to be relatively costly in comparison with the world market prices due to the inefficiency of the gas fields and un-

development of natural gas demand in Cambodia.

- (b) MIME and EDC plan the implementation of hydropower plants in future. Due to the introduction of hydropower plants in future, the project has to be operated not as a base load power plant but as a load adjustment power plant.
 - (c) The plant cost has to become rather costly due to the small output capacity and small unit capacity of the plant because of the constraint resulting from the small power system in Cambodia.
- (7) With the project design, the environmental management plan and the environmental monitoring plan (as set forth in this report and in the EIA Report), environmental impacts can be mitigated to ensure project compliance with applicable environmental standards and guidelines of Cambodia and major lending institutions.

13.2. Recommendation

- (1) The feasibility study of transmission line between Kampot and Sihanoukville should be commenced as soon as possible.
- (2) For accelerating the development of natural gas, MIME and EDC should actively participate in the process of development and negotiation with gas developer, and be recommended to indicate the concrete demand forecast of natural gas in Cambodia.
- (3) The power development plan should be made considering optimum balance of hydropower plant and thermal power plant. Installation of additional power plant using natural gas would encourage the development of natural gas.