# Annex to 3.4.1 Description Of Proposed Measures For Wastewater **Collection, Treatment And Disposal**

# Contents

## **EXISTING TREATMENT PLANTS**

1.	ABU NUSEIR	SA3-156
2.	AQABA	SA3-161
3.	AS SAMRA	SA3-167
4.	BAQA	SA3-178
5.	FUHIS	SA3-183
6.	IRBID CENTRAL	SA3-187
7.	JERASH EAST	SA3-194
8.	KARAK	-SA3-199
9.	KUFRANJA	SA3-205
10.	MA'AN	SA3-211
11.	МАДАВА	SA3-216
12.	MAFRAO	SA3-222
13.	RAMTHA	SA3-228
14.	SALT	SA3-234
15.	TAFIELAH	SA3-238
16.	WADI ARAB	SA3-243
17.	WADI ESSIR	SA3-248

## TREATMENT PLANTS UNDER CONSTRUCTION

18.	WADI HASSAN	SA3-253
19.	WADI MOUSA	SA3-258

## PLANNED TREATMENT PLANTS

20.	AL JEEZA	SA3-265
21.	AL MAZAR AL SHAMALI	SA3-272
22.	DAIR ABI SAID	SA3-276
23.	DAIR ALLA	SA3-281
24.	JERASH WEST	SA3-286
25.	KOFUR ASAD	SA3-290
26.	AQABA SOUTH COAST	SA3-295
27.	NAUR	SA3-299
28.	NORTH QUEEN ALIA AIRPORT	SA3-304
29.	NORTH JORDAN VALLEY	SA3-311
30.	SHUNA SOUTH	SA3-319
31.	TORRA	SA3-324
32.	UM AL BASATEEN	SA3-329
33.	WADI SHALLALA	SA3-330
34.	WADI ZARQA	SA3-339
35.	MAZAR, MUTA, ADNANIYA	SA3-344
36.	DEAD SEA EAST COAST	SA3-348

#### Page

## **17. WADI ESSIR TREATMENT PLANT**

Wadi Essir Treatment Plant receives sewage from the town Wadi Essir only. However, only about 10 % of the town drains to the Wadi Essir Treatment Plant, while the other 90 % discharge their sewage to Amman (As Samra). Figure 17.1 shows the existing sewerage system of Wadi Essir Sewerage System.

The plant was put in operation in 1996 to a capacity of  $4,000 \text{ m}^3/\text{d}$ . Presently only less than a quarter of its capacity is used. For details of the existing system it is referred to Section 17 of Annex 3.1. Primary treatment facilities consist of screens without grit chambers. Biological wastewater treatment is done in two trains of 2 anaerobic ponds (parallel), 2 aerated ponds (parallel) and 4 maturation ponds (2 parallel and 2 in series). Presently, only one anaerobic pond is in operation. Submersible pumps lifting water and jetting it back to the water surface do aeration of the aerobic ponds. Treated wastewater may be chlorinated, if required.

Figure 17.2 shows the existing and future treatment system. The projection of the wastewater production is shown in the following table (acc. to Consultant's Study Report). The plant will reach its final capacity not before

2020: 3,700 m<sup>3</sup>/d (32,000 connected inhabitants)

if not additional villages will be connected. Therefore, an extension is not required before 2020.

Receiving water is the Wadi Essir downstream of its confluent with the Wadi El Bakhath discharging finally into the Kafrein Reservoir. From there water will flow to the Jordan Valley for ultimate reuse.

Without chlorination of the plant's effluents the fecal coliform count was found as 1,600 in 100 ml in 1999. Therefore, the effluent could be reused for unrestricted irrigation, if safety chlorination would be provided. However, if other water quality parameters of the effluent would allow unrestricted irrigation, due to the helminthes eggs content the effluent can be reused for restricted irrigation only.

Suitable irrigation areas are identified east of the existing treatment plant (see Figure 17.3). The effluents could supply irrigation water for an area of about 40 ha in 2020 taking into account the demand for plantation of olive and forest trees (see following table). Irrigable land (downstream of the plant) may be supplied by gravity flow.

## **Consultant's Study Report:**

TYPSA, Symonds Travers Morgan and Universal Engineering Consulting: "Wastewater collection, treatment, disposal and/or reuse systems project for the catchment area of Yarmouk River and Jordan River. Interim Report", July 1998

Melyepterv: "Wadi Essir sewage treatment plant. Final Engineering", July 1987



FIGURE 17.1: General Layout of Sewerage System - WADI ESSIR







**FIGURE 17.3:** 

Potential Reuse Areas - WADI ESSIR

#### **17 WADI ESSIR**

#### SCENARIO 0 "Consultants' Study"

(acc. to Consultant's Study Report)

#### Basic data:

Popu	lation in 1994:	11.000 (living in service zone of Wadi Essir Treatment Plant)							
Grow	th rate (previous period)	Unit %	1994 -	<b>2000</b> 3,24	<b>2005</b> 3,24	<b>2010</b> 3,24	<b>2015</b> 3,24	<b>2020</b> 3,24	
Spec.	water demand	l/c/d	90	110	115	130	143	143	
Comr	nercial demand	m³/d							
Small	industrial demand	m³/d							
Pasto	ral demand	m³/d							
Cover	age	%	0	80	80	85	85	85	
Retur	n factor	-	0,8	0,8	0,8	0,8	0,8	0,8	
Losse	es/inflow	% 202 / //	0	0	0	0	0	0	
Speci	fic pollutional load	GROD²(c∖α	65	65	65	65	65	65	
		Unit	1994	2000	2005	2010	2015	2020	
Popu	lation	C	11 000	13 319	15 621	18 321	21 488	25 202	
гора	Connected (sewerage)	c C	0	10.655	12 497	15 573	18 265	21 422	
	Not connected (sewerage)	c	11.000	2.664	3.124	2.748	3.223	3.780	
Wate	r demand			445		(	4.40	( 10	
	Domestic demand	l/c/d	90	110	115	130	143	143	
	Commercial demand	m*/a	990	1.400	1.790	2.382	3.073	3.604	
	Small industrial demand	m³/d							
	Pastoral demand	m³/d							
	Total	m³/d	990	1.465	1.796	2.382	3.073	3.604	
Waste	ewater production								
	Return flow (w.demand)	m³/d	0	938	1.150	1,620	2.090	2.451	
	Losses/inflow	m³/d	0	0	0	0	0	0	
	Total	m³/d	0	938	1.150	1.620	2.090	2.451	
		m³/month	0	28.130	34.492	48.589	62.685	73.520	
		m³/a	0	342.252	419.654	591.161	762.673	894.496	
Pollu	tional load								
	Poll. load (dom.demand)	kgBOD₅/d	0	693	812	1.012	1.187	1.392	
	Poll. load (com.demand)	kgBOD₅/d							
	Poll. load (small ind.)	kgBOD₅/d							
	Others	kgBOD <sub>5</sub> /d							
	Totai load	kgBOD₅/d	0	693	812	1.012	1.187	1.392	
Reus	e of wastwater								
	Inflow to the treatment plant	m³/a	0	342.252	419.654	591.161	762.673	894.496	
	Losses in treatment plant	%	10	10	10	10	10	10	
	(due to infiltr./evap.)	m³/a	0	34.225	41.965	59.116	76.267	89.450	
	Effluent of treatment plant	m³/a	0	308.027	377.689	532.045	686.406	805.046	
	Net water demand per ha	m³/d/ha		60	60	60	60	60	
	Irrigable reuse area	ha	0	14	17	24	31	37	
18104	demand for infration	Oliver		60	m3/d/ha /-	ook poried d	cond)		
vvaler	aemana ivi intigativii	Clives		00		vear heunn neu	na na j		

## 18. WADI HASSAN TREATMENT PLANT (under construction)

Wadi Hassan Treatment Plant is part of the sewerage system considered by the long-term development in Greater Irbid Area (compare description of the Treatment Plant Irbid Central under Section 6). It will receive wastewater from An Nu'ayyma, Kitm and Shatana.

The plant will be completed end of 2000, while the sewage collection network will be put into operation not before 2001 (for details of the existing system refer to Section 18 of Annex 3.1). The projection of the wastewater production shows that the capacity of the plant  $(1,600 \text{ m}^3/\text{d})$  will be reached in about 2010 (acc. to Consultant's Study Report, see following table).

At present there are no specific plans to implement a reuse scheme for the effluents of Wadi Hassan Treatment Plant. However, the Consultant proposes to reuse the treated effluent in agricultural land north of the plant's side (see Figure 18.3). The effluents could supply irrigation water (gravity flow) for an area of about 50 ha in 2020 (see following table) taking into account the irrigation demand for alfalfa and barley.

A further possibility of reuse could be the reuse of the treated wastewater at the Jordan University of Science and Technology (JUST). Wastewater could be discharged by gravity from the Wadi Hassan Plant to JUST.

In July 2000 the Ministry of Water and Irrigation prepared Terms of Reference for a study for reuse of treated wastewater for the Greater Irbid Area. It is proposed that the German Development Bank (Kreditanstalt fuer Wiederaufbau, KfW) will finance this study.

#### **Consultant's Study Report:**

RRI, DAR and Sigma: "Technical, economical and financial Feasibility Study. Phase B. Feasibility study of preferred alternatives for wastewater collection and treatment systems in the Greater Irbid area", March 1992

RRI, DAR and Sigma: "Wastewater collection and treatment systems in the Greater Irbid area. Stage II. Reuse of treated wastewater and utilization of stabilized sludge", March 1995

DAR: "Update of the feasibility study. Wastewater collection and treatment systems in the Greater Irbid area. Stage 2. Wadi Shallala." November 1998.







The Study on Water Resources Management in The Hashemite Kingdom of Jordan Final Report/Supporting Report Part-A "Master Plan"





**FIGURE 18.3:** 

Potential Reuse Areas – WADI HASSAN (acc. to Min. of Agriculture)

#### **18 WADI HASSAN**

#### SCENARIO 0 "Consultants' Study"

(acc. to Consultant's Study Report)

Dasic uata.	Basic	data:
-------------	-------	-------

Population in 1994:	0	P	opulation in 20	00:	18.300		
Growth rate (previous period) Spec.water demand Commercial demand Small industrial demand Pastoral demand	<b>Unit</b> % l/c/d m³/d m³/d m³/d	1994 - -	<b>2000</b> - 85	<b>2005</b> 3,50 90	<b>2010</b> 3,50 95	<b>2015</b> 3,25 100	<b>2020</b> 3,25 105
Coverage Return factor Losses/inflow Specific pollutional load	% - gBOD₅/c/d	0 0,8 0 65	85 0,8 0 65	85 0,8 0 65	85 0,8 0 65	85 0,8 0 65	85 0,8 0 65
	Unit	1994	2000	2005	2010	2015	2020
Population Connected (sewerage) Not connected (sewerage)	с с с	0 0 0	18.300 15.555 2.745	21.735 18.474 3.260	25.814 21.942 3.872	30.290 25.747 4.544	35,543 30,212 5,331
Water demand Domestic demand Commercial demand Small industrial demand Pastoral demand	l/c/d - m³/d m³/d ៣³/d ៣³/d	0	85 1.556	90 1.956	95 2.452	100 3.029	105 3,732
Total	m³/d	0	1.556	1.956	2.452	3.029	3.732
Wastewater production Return flow (w.demand) Losses/inflow	m³/d m³/d	0 0	1.058 0	1.330 0	1.668 0	2.060 0	2.538 0
Total	m³/d m³/month m³/a	0 0 0	1.058 31.732 386.075	1.330 39.905 485.509	1.668 50.027 608.667	2.060 61.792 751.808	2.538 76.133 926.288
Pollutional load Poll. load (dom.demand) Poll. load (com.demand) Poll. load (small ind.) Others	kgBOD₅/d kgBOD₅/d kgBOD₅/d kgBOD₅/d	0	1.011	1.201	1.426	1.674	1.964
Total load	kgBOD₅/d	0	1.011	1.201	1.426	1.674	1.964
Reuse of wastwater Inflow to the treatment plant Losses in treatment plant (due to infiltr./evap.) Effluent of treatment plant Net water demand per ha Irrigable reuse area	m³/a % m³/a m³/a/ha ha	0 0 0 0	386.075 10 38.608 347.468 45 21	485.509 10 48.551 436.958 45 27	608.667 10 60.867 547.801 45 33	751.808 10 75.181 676.627 45 41	926.288 10 92.629 833.660 45 51

Water demand for irrigation

Alfalfa, barley

45 m³/d/ha

## **19. WADI MOUSA TREATMENT PLANT (under construction)**

The sewerage scheme of Wadi Mousa (presently under construction) is located close to the ancient Nabataean city of Petra in the southern part of Jordan. The communities of Wadi Mousa, Taiba, B'doul and Beida will be connected to the proposed scheme. Figure 19.1 shows the layout of the proposed sewerage system.

Due to the vicinity to the ancient Nabataean city of Petra the development of tourism in Wadi Mousa is expected to contribute significantly to the resident population. The contribution will be two-fold, directly through attracting new residents to the town and indirectly by increasing the number of hotel visitors. The projection of the wastewater production takes into account this fact (acc. to Consultant's Study Report, see following table).

The project foresees the construction of a Treatment Plant designed for the wastewater production in 2020. The biological process selected includes nitrogen removal and is a modification of the activated sludge process known as modified Ludzack-Ettinger (MLE). This MLE process differs from conventional activated sludge in the configuration of the reactor sections. The process consists of a biological reactor followed by secondary settling. The activated sludge removed by the secondary settling tank is returned to the biological reactor to maintain process dynamics. The reactor for the proposed process consists of two zones: an "anoxic" zone without aeration, followed by an aerated or "oxic" zone. In addition, some treated effluent known as "mixed liquor" from the end of the aerobic zone is recycled to the head of the anoxic zone. Polishing (maturation) ponds serve for tertiary treatment. Produced sludge will be treated by sludge holding tanks (for thickening and anaerobic stabilization) followed by drying beds. Figure 19.2 shows the proposed treatment system.

The projection of the wastewater production is shown in the following table (acc. to Consultant's Study Report). The plant will be implemented in two phases, whereby the final capacity will be reached

in 2020: 4,900 m<sup>3</sup>/d (24,000 connected resident inhabitants plus peak season tourists: 4,500 hotel guests and 2,700 day visitors)

Construction works of sewerage system and treatment plant will be completed early 2001.

According to the Consultant's proposal a storage basin (6,800 m<sup>3</sup>) is required to equalize seasonal differences in supply and demand for irrigation. Such areas have been identified north of the Sad Um El Hiran plant site shown in Figure 19.3. In 2020 about 80 ha may be irrigated with treated effluent, forest trees and olives as well as about barley as winter crop (see following table).

It is discussed to involve the private sector in a management contract in operation and maintenance the water supply and wastewater system of Wadi Mousa (see ABT Report of 1999). This contract would include 86 km of wastewater collectors, 4 sewage pumping stations and the treatment plant of a present capacity of 3,400 m<sup>3</sup>/d.

## **Consultant's Study Report:**

CDM: "Wadi Mousa water supply and wastewater project. Stage II. Final design report", September 1996.

ABT: "Technical review meeting. Management contract water supply and wastewater system Wadi Mousa", November 1999.



#### FIGURE 19.1: General Layout of Proposed Sewerage System - WADI MOUSA



FIGURE 19.2:

Layout of Proposed Wastewater Treatment Plant - WADI MOUSA



FIGURE 19.3a:

SA3-262

Potential Reuse Areas - WADI MOUSA (acc. to CDM Consultant)





Potential Reuse Areas - WADI MOUSA (acc. to Min. of Agriculture)

#### **19 WADI MOUSA**

#### SCENARIO 0 "Consultants' Study"

(acc. to Consultant's Study Report)

#### Basic data:

Population in 1994	16.850						
	Unit	1994	2000	2005	2010	2015	2020
Growth rate (previous period)	%	-	3,44	3,44	3,44	2,52	2,52
Spec.water demand	l/c/d	-	141	150	159	168	177
Commercial demand	m³/d						
Small industrial demand	m³/d						
Pastoral demand	m³/d						
Coverage	%	0	46	53	60	63	65
Return factor	-	0,8	0,8	0,8	0,8	0,8	0,8
Losses/inflow	%	0	0	0	0	0	0
Specific pollutional load	gBOD <sub>5</sub> /c/d	65	65	65	65	65	65

	Unit	1994	2000	2005	2010	2015	2020
Population	с	16.850	20.641	24,444	28,948	32.776	37.119
Connected (sewerage)	c	0	9.495	12.955	17.369	20.649	24.127
Not connected (sewerage)	c	16.850	11.146	11,489	11.579	12.127	12.992
Hotel guests and day visitors	С		5.700		6.250		7.200
Water demand							
Domestic demand	l/c/d	-	141	150	159	168	177
	m³/d	-	2.910	3.667	4.603	5.506	6.570
Commercial demand	m³/d						
Small industrial demand	m³/d						
Pastoral demand	m³/d						
Tourist demand	m³/d	-	2.070	2.270	2.470	2.660	2.840
Total	m³/d	0	4.980	5.937	7.073	8.166	9.410
Wastewater production							
Return flow (w.demand)	m³/d	0	1.833	2.517	3.395	4.116	4.893
Losses/inflow	m³/d	0	0	0	0	0	0
Total	m³/d	0	1.833	2.517	3,395	4.116	4.893
	m³/month	0	54.983	75.514	101.847	123.475	146.797
	m³/a	0	668.965	918.750	1.239.138	1,502.279	1.786.030
Pollutional load							
Poll. load (dom.demand)	kgBOD₅/d	0	617	842	1.129	1.342	1.568
Poll, load (com.demand)	kgBOD₅/d						
Poll, load (small ind.)	kgBOD₅/d						
Others	kgBOD <sub>5</sub> /d						
Total load	kgBOD₅/d	0	617	842	1.129	1.342	1.568
Pouse of wastwater							
Inflow to the treatment plant	m³/a	0	668 965	918 750	1 239 138	1 502 279	1 786 030
Losses in treatment plant	%	0	10	10	10	10	10
(due to infiltr /evap.)	m³/a	ō	66.896	91.875	123.914	150,228	178.603
Effluent of treatment plant	m³/a	Ō	602.068	826.875	1.115.224	1.352.051	1.607.427
Net water demand per ha	m³/d/ha		53	53	53	53	53
Irrigable reuse area	ha	0	31	43	58	70	83

Water demand for irrigation

Forest trees, olives, barley

53 m³/d/ha

## 20. AL JEEZA TREATMENT PLANT

#### 1. Long term development in South Amman Area

According to the Consultants Study Report the long-term strategy for the South Amman Area foresees two independent sewerage schemes and two wastewater treatment plants:

- *North Queen Alia Airport Treatment Plant (eastern drainage area)* This treatment plant will receive the wastewater of the eastern drainage area.
- *Al Jeeza Treatment Plant (western drainage area)* This treatment plant will receive the wastewater of the western drainage area.

Details of proposed North Queen Alia Airport system are given under Section 28.

#### 2. Proposed Al Jeeza Treatment Plant

Figure 20.1 shows the layout of the proposed sewerage system, which will be implemented in 3 Phases.

The project foresees the construction of the Al Jeeza Treatment Plant designed for the wastewater production in 2020. It will be based on an extended aeration process including maturation ponds for tertiary treatment. Produced sludge will be treated by sludge holding tanks and drying beds. Figure 20.2 shows the proposed treatment system. The projection of the wastewater production is shown in the following table (acc. to Consultant's Study Report). The plant will be implemented in two phases, whereby the final capacity will be reached

#### in 2020: 8,800 m<sup>3</sup>/d (87,300 connected inhabitants)

The effluents could supply irrigation water for an area of about 60 ha in 2020 taking into account the demand for alfalfa as summer crop, and barley as winter crop (see following table). Suitable land for irrigation was identified in the direct southwestern surroundings of the treatment plant. A pump station together with feeder mains to the irrigation areas will be constructed. Proposed wastewater reuse areas are presented in the Figure 28.3.

The investment costs (Phase 1, 2 and 3) based on 1994 prices are:

Treatment plant	3.91 million JD
Local sewerage	7.76 million JD
Collector sewerage	2.89 million JD
Trunk sewerage	3.30 million JD
Irrigation facilities	1.02 million JD
Total capital costs	18.88 million JD

Investment costs subdivided in Phases 1 (2002/11), 2 (2012/20) and 3 (2021/26) are as follows:

(price	basis	2000,	in	mio.	JD)
--------	-------	-------	----	------	-----

	Phase 1	Phase 2	Phase 3
Treatment plant	3.90	3.46	1.91
Local sewerage	1.69	0.69	1.07
Collector sewerage	3.58	0.35	0
Trunk sewerage	2.80	1.87	0
Subtotal capital costs	11.98	6.37	2.98
Engineering +Contingencies (30 %)	3.59	1.97	0.89
Total	15.57	8.28	3.87

## **Consultant's Study Report:**

Montgomery Watson: "Technical and economic Feasibility Study and detailed Final Design of the collection, treatment and reuse of wastewater from communities South of Amman. Feasibility Study", June 1995

Volume I: Main Report Volume II: Drawings



FIGURE 20.1: General Layout of Proposed Sewerage System - AL JEEZA









FIGURE 20.3b: Potential Reuse Areas - AL JEEZA (acc. Min. of Agriculture)

#### 20 AL JEEZA

#### SCENARIO 0 "Consultants' Study"

Basic data:

(acc. to Consultant's Study Report of Montgomery Watson 1995) Option 5: Sewage Treatment Plant B (STP B)

Population in 1994:		41.700						
Grow	/th rate (previous period)	Unit %	1 <b>994</b>	<b>2000</b> 2,82	<b>2005</b> 2,90	<b>2010</b> 2,90	<b>2015</b> 2,90	<b>2020</b> 2,90
Spec Com Smal Pasto	warcial demand I industrial demand oral demand	1/C/d m³/d m³/d m³/d	/6	89	97	105	113	121
Cove	rage	%	0	0	100	100	100	100
Loss	es/inflow	~	0,65	0,00 0	0,65	0,84 0	0,84	0,83
Spec	ific pollutional load	gBOD <sub>5</sub> /c/d	65	65	65	65	65	65
		Unit	1994	2000	2005	2010	2015	2020
Рори	lation	с	41.700	49.272	56.843	65.578	75.654	87.279
	Connected (sewerage) Not connected (sewerage)	c c	0 41.700	0 49.272	56.843 0	65.578 0	75.654 0	87.279 0
Wate	r demand				-	-	_	Ŭ
TTUIC	Domestic demand	l/c/d	76	89	97	105	113	121
	Commercial demand	m²/d m³/d	3.169	4.385	5.514	6.886	8.549	10.561
	Small industrial demand	m³/d						
	Pastoral demand	m³/d						
	Total	m³/d	3.169	4.385	5.514	6.886	8.549	10.561
Wast	ewater production							
	Return flow (w.demand)	m³/d	0	0	4.687	5.784	7.181	8.765
	LOSSES/ITTIOW	ni-7u	U	0	0	U	U	U
	Total	m³/d	0	0	4.687	5.784	7.181	8.765
		m³/month m³/a	0	0	140.602 1 710 654	173.518 2 111 139	215.433 2.621.096	262.963
		in , a	Ũ	0	1.110.004	2.111.100 ·	2.021.030	0.155.011
Pollu	tional load	kaROD (d	0		2.005	4.000	4.545	
	Poll, load (dom.demand)	kgBOD <sub>5</sub> /u kgBOD <sub>-</sub> /d	0	Ų	3.695	4.263	4.918	5.673
	Polit load (contratand)	kgBOD <sub>5</sub> /d						
	Others	kgBOD₅/d						
	Total load	kgBOD₅/d	0	0	3.695	4.263	4.918	5.673
Reuse	e of wastwater							
	Inflow to the treatment plant	m³/a	0	0	1.710.654	2.111.139	2.621.096	3.199.377
	Losses in treatment plant	%	0	0	10	10	10	10
	(due to inflitr./evap.)	m³/a	0	0	171.065	211.114	262.110	319.938
	Net water demand per ha	m³/d/ha	Ū	60	60	60	2.330.980	2.879.440
	Irrigable reuse area	ha	0	0	70	87	108	131
Water	demand for irrigation	Alfalfa, barley		60	m³/d/ha			
	MOA's proposal:	Summer crops: Winter crops:	alfa barl	lfa ey				

## 21. AL MAZAR AL SHAMALI TREATMENT PLANT TREATMENT PLANT

The proposed Scheme of Al Mazar Al Shamali area is located southeast of Irbid. Presently, there exists no sewerage system. The following communities will be connected to the proposed scheme: Mazar Al Shamali, Dair Yousef, Johfiah, Habka, Hofa El Mazar and Samad. Figure 21.1 shows the layout of the proposed sewerage system.

The project foresees the construction of a Treatment Plant designed for the wastewater production in 2020. It will be based on an extended aeration process including slow sand filtration as tertiary treatment. Gravity thickeners and decanter centrifuge will treat produced sludge. Figure 21.2 shows the proposed treatment system. The projection of the wastewater production is shown in the following table (acc. to Consultant's Study Report). The plant will be implemented in two phases, whereby the final capacity will be reached

in 2020:  $4,500 \text{ m}^3/\text{d}$  (40,100 connected inhabitants)

Due to the very steep flanks of the valley of Wadi Jurum there are no substantial areas of agricultural land available for irrigation without extremely high pumping costs. Therefore, it is recommended to discharge all treated effluent to the Wadi Jurum without any reuse.

The investment costs based on 1998 prices are:

Treatment plant (primary and secondary treatment)	3.85 million JD
Networks	8.07 million JD
Tertiary treatment and pipeline	0.56 million JD
Dam/storage (pond for reuse)	0 million JD
Total base costs	12.49 million JD
Physical contingencies	1.25 million JD
Engineering	1.37 million JD
Total investment costs	15.11 million JD

According to the Consultant's Study Report implementation of proposed construction measures were foreseen during the years 2007 to 2009 (Phase I).

#### **Consultant's Study Report:**

TYPSA, Symonds Travers Morgan and Universal Engineering Consulting: "Wastewater collection, treatment, disposal and/or reuse systems project for the catchment area of Yarmouk River and Jordan River. Final Report", December 1998



The Study on Water Resources Management in The Hashemite Kingdom of Jordan Final Report/Supporting Report Part-A "Master Plan"



The Study on Water Resources Management in The Hashemite Kingdom of Jordan Final Report/Supporting Report Part-A "Master Plan"

#### 21 AL MAZAR AL SHAMALI

#### SCENARIO 0 "Consultants' Study"

(acc. to Consultant's Study Report)

#### Basic data:

Population in 1994:	21.228						
	Unit	1994	2000	2005	2010	2015	2020
Growth rate (previous period)	%	-	3,12	3,12	3,12	3,12	3,12
Spec.water demand	l/c/d	-	141	141	141	141	141
Commercial demand	m³/d						
Small industrial demand	m³/d						
Pastoral demand	m³/d						
Coverage	%	0	0	0	85	85	85
Return factor	-	0,8	0,8	0,8	0,8	0,8	0,8
Losses/inflow	%	0	0	0	0	0	0
Specific pollutional load	gBOD <sub>5</sub> /c/d	65	65	65	65	65	65

	Unit	1994	2000	2005	2010	2015	2020
Population	с	21.228	25.525	29.763	34.705	40.468	47.187
Connected (sewerage)	с	0	0	0	29.499	34.398	40.109
Not connected (sewerage)	С	21.228	25.525	29.763	5.206	6.070	7.078
Water demand							
Domestic demand	l/c/d -		141	141	141	141	141
	m³/d	0	3.599	4.197	4.893	5,706	6.653
Commercial demand	m³/d						
Small industrial demand	m³/d						
Pastoral demand	m³/d						
Total	m³/đ	0	3.599	4.197	4.893	5.706	6.653
Wastewater production							
Return flow (w.demand)	m³/d	0	0	0	3.328	3.880	4.524
Losses/inflow	m³/d	0	0	0	0	0	0
Total	m³/d	0	0	0	3.328	3.880	4.524
	m³/month	0	0	0	99.826	116,402	135.729
	m³/a	0	0	0	1.214.553	1.416.221	1.651.374
Pollutional load							
Poll. load (dom.demand)	kgBOD₅/d	0	0	0	1.917	2.236	2.607
Poll. load (com.demand)	kgBOD <sub>5</sub> /d						
Poll. load (small ind.)	kgBOD <sub>5</sub> /d						
Others	kgBOD₅/d						
Total load	kgBOD <sub>5</sub> /d	0	0	0	1.917	2.236	2.607
Pause of wastwater							
Inflow to the treatment plant	m³/a	0	0	0	1.214.553	1.416.221	1.651.374
Losses in treatment plant	%	õ	5	5	5	5	5
(due to infiltr./evap.)	m³/a	0	0	Ō	60.728	70.811	82.569
Effluent of treatment plant	m³/a	0	0	0	1.153.825	1.345.410	1.568.805
Net water demand per ha	m³/d/ha	-	-	-	-	-	-
Irrigable reuse area	ha	-	-	-	-	-	-

Water demand for irrigation

no reuse system proposed