

<b>DESIGN CALCULATION COVER SHEET</b>								
<b>Project</b>	Detailed Design on Port Reactivation Project in La Union Province.			<b>Project Code</b>	JC1N004			
<b>Section</b>	<b>BUILDING WORKS</b>			Calc. File No.				
<b>Sub-Section</b>	<b>POWER SUPPLY STATION</b>			Calc. Index No.				
<b>Subject:</b>  <p style="text-align: center; font-weight: bold;">STRUCTURAL DESIGN</p>								
<b>Calculation Objective:</b>  <p style="text-align: center;">The objective of the calculation is to provide a safe structure for the occupation of the building, by the use of the Republic of El Salvador and American design standards.</p>								
<u>References, Calculation Notes and Comments</u>  <p>The Structural Analysis has been made using the program: "STAAD-III rev 21.1W, RESEARCH ENGINEERS, Inc.". The analysis of the structure considers only the concrete frames to resist the vertical and lateral forces, not considering the walls in the model.</p> <p>Two models for the structure have been constructed:</p> <ol style="list-style-type: none"> <li>1- For the calculation of the Dead &amp; Live load.</li> <li>2- For the calculation of the seismic forces.</li> </ol> <p>The Key for the STAAD-III rev 21.1W program is attached for future convinience.</p> <p>All the design has been made by calculations sheet created for the project in Microsoft Excel, and based in the following bibliography:</p> <ol style="list-style-type: none"> <li>1. Building Code Requirements for Structural Concrete (318M-99), American Concrete Institute (ACI).</li> <li>2. Technical Specification for Seismic Design, Ministry of Public Works, El Salvador, 2001.</li> <li>3. AISC, American Institute of Steel Construction, ninth Edition, 1989.</li> <li>4. UBC, Uniform Building Code, Volume 2: Structural Engineering Design Provisions, 1997.</li> </ol>								
<b>Rev</b>	Prepared		No. of Pages	Checked		Reviewed		Superseded by Calc No.
	by	Date		by	Date	by	Date	
O	Rubén Martínez	Jul-02	61	A. MORIOKA	Jul-02	<i>[Signature]</i>	12 Aug 02	
A	<i>[Signature]</i>			<i>[Signature]</i>				
B								
C								

<b>PROJECT:</b> Detailed Design on Port Reactivation Project In La Union Province	Calc. File No.		Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
<b>SUBJECT:</b> Dead & Live Load	Date	July-02	Page	1/61

## - DEAD LOAD

### Reinforced Concrete Slab

Slab 1 thickness = 0.15 m      Weight = 360.00 kg/m<sup>2</sup>

Slab 2 thickness = 0.12 m      Weight = 288.00 kg/m<sup>2</sup>

### Ceiling

The ceiling consists of cement fiber board with aluminium frame.

Weight = 20.00 kg/m<sup>2</sup>

### Floor finish

The floor finish consists of Ceramic Tile

Weight = 60.00 kg/m<sup>2</sup>

### Asphalt protection.

The asphalt protection is used for the roof.

Weight = 15.00 kg/m<sup>2</sup>

### Concrete protection.


The concrete protection is used for the Generator room and roof.

Weight = 48.00 kg/m<sup>2</sup>      th = 0.02 m

<b>PROJECT:</b> Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
<b>SUBJECT:</b> Dead & Live Load	Date	July-02	Page	2/ 61

**Walls**

a) Concrete Hollow Block wall, th = 0.20 m




Area of block = 0.08 m<sup>2</sup>

Weight of block = 14.06 kg

Hole filled with concrete = 9.41 kg  
23.47 kg

**Wall weight = 293.37 kg/m<sup>2</sup>**

b) Concrete Hollow Block wall, th = 0.15 m



Area of block = 0.08 m<sup>2</sup>

Weight of block = 11.34 kg

Hole filled with concrete = 6.72 kg  
18.06 kg

**Wall weight = 225.75 kg/m<sup>2</sup>**

**Concrete block wall weights**

Block	W height (m)	thickness (m)	W weight (kg/m <sup>2</sup> )	Dist. Weight (kg/m)
20 cm	4.00	0.20	293.37	1173.47
15 cm	4.00	15.00	225.75	902.99

**WEIGHTS PER LEVEL**

a) Roof

Concrete slab, th=0.12m	288.00	}	Wd =	371.00	kg/m <sup>2</sup>
Ceiling	20.00				
Asphalt protection	15.00				
Concrete protection	48.00				

<b>PROJECT:</b> Detailed Design on Port Reactivation Project In La Union Province	Calc. File No.	Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
<b>SUBJECT:</b> Dead & Live Load	Date	Page	3/ 61

**b) First floor, Generator room**

Concrete slab, th=0.15m	360.00	}	Wd =	408.00	kg/m <sup>2</sup>
Concrete protection	48.00				

**c) First floor, other.**

Concrete slab, th=0.15m	360.00	}	Wd =	420.00	kg/m <sup>2</sup>
Floor finish	60.00				

**- LIVE LOAD**

Area	Room	Live load (kg/m <sup>2</sup> )	
		Wm	Wi
Roof	Roof, slope < 5 %	100	50
Machine room	Generator room	500	---
	Transformer room		
Office		250	---

**Roof Loads**

Roof Area =  m<sup>2</sup>

Area of Border Beam =  m<sup>2</sup>

L =  m

Roof Dead Load = 171.1 ton

Roof Live load = 39.82 ton

Roof Live load for seismic = 19.91 ton

Load for STAAD :

Total roof load for Seismic Analysis = 191.04 ton

# of Joints =

Load per Joint = 4.776 ton/joint

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
SUBJECT: Dead & Live Load	Date	July-02	Page	4/ 61

### BEAM LOADS

Beams in Axis 1

Tributary area = <span style="border: 1px solid black; padding: 2px;">9.00</span> m <sup>2</sup>	Wdead = 742.0 kg/m
L dist = <span style="border: 1px solid black; padding: 2px;">4.50</span> m	Wlive = 200.00 kg/m

Beams in Axis 2

From A to B Axis

Tributary area = <span style="border: 1px solid black; padding: 2px;">9.00</span> m <sup>2</sup>	Wdead = 742.0 kg/m
L dist = <span style="border: 1px solid black; padding: 2px;">4.50</span> m	Wlive = 200.00 kg/m

From B to C Axis

Tributary area = <span style="border: 1px solid black; padding: 2px;">6.50</span> m <sup>2</sup>	Wdead = 689.0 kg/m
L dist = <span style="border: 1px solid black; padding: 2px;">3.50</span> m	Wlive = 185.71 kg/m

Beams in Axis 3

From A to B Axis

Tributary area = <span style="border: 1px solid black; padding: 2px;">9.00</span> m <sup>2</sup>	Wdead = 742.0 kg/m
L dist = <span style="border: 1px solid black; padding: 2px;">4.50</span> m	Wlive = 200.00 kg/m

From B to C Axis

Tributary area = <span style="border: 1px solid black; padding: 2px;">6.00</span> m <sup>2</sup>	Wdead = 636.0 kg/m
L dist = <span style="border: 1px solid black; padding: 2px;">3.50</span> m	Wlive = 171.43 kg/m

Beams in Axis 4

From A to B Axis

Tributary area = <span style="border: 1px solid black; padding: 2px;">9.32</span> m <sup>2</sup>	Wdead = 768.4 kg/m
L dist = <span style="border: 1px solid black; padding: 2px;">4.50</span> m	Wlive = 207.11 kg/m

From B to C Axis

Tributary area = <span style="border: 1px solid black; padding: 2px;">6.07</span> m <sup>2</sup>	Wdead = 643.4 kg/m
L dist = <span style="border: 1px solid black; padding: 2px;">3.50</span> m	Wlive = 173.43 kg/m

Beams in Axis 5

From A to B Axis

Tributary area = <span style="border: 1px solid black; padding: 2px;">9.64</span> m <sup>2</sup>	Wdead = 794.8 kg/m
L dist = <span style="border: 1px solid black; padding: 2px;">4.50</span> m	Wlive = 214.22 kg/m

PROJECT: Detailed Design on Port Reactivation Project In La Union Province	Calc. File No.		Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
SUBJECT: Dead & Live Load	Date	July-02	Page	5/ 61

From B to C Axis

$$\begin{aligned} \text{Tributary area} &= \boxed{6.14} \text{ m}^2 \\ \text{L dist} &= \boxed{3.50} \text{ m} \end{aligned}$$

$$\begin{aligned} W_{\text{dead}} &= 650.8 \text{ kg/m} \\ W_{\text{live}} &= 175.43 \text{ kg/m} \end{aligned}$$

Beams in Axis 6

From A to B Axis

$$\begin{aligned} \text{Tributary area} &= \boxed{9.32} \text{ m}^2 \\ \text{L dist} &= \boxed{4.50} \text{ m} \end{aligned}$$

$$\begin{aligned} W_{\text{dead}} &= 768.4 \text{ kg/m} \\ W_{\text{live}} &= 207.11 \text{ kg/m} \end{aligned}$$

From B to C Axis

$$\begin{aligned} \text{Tributary area} &= \boxed{6.57} \text{ m}^2 \\ \text{L dist} &= \boxed{3.50} \text{ m} \end{aligned}$$

$$\begin{aligned} W_{\text{dead}} &= 696.4 \text{ kg/m} \\ W_{\text{live}} &= 187.71 \text{ kg/m} \end{aligned}$$

Beams between Axis 1 & 2

$$\begin{aligned} \text{Tributary area} &= \boxed{9.00} \text{ m}^2 \\ \text{L dist} &= \boxed{4.50} \text{ m} \end{aligned}$$

$$\begin{aligned} W_{\text{dead}} &= 742.0 \text{ kg/m} \\ W_{\text{live}} &= 200.00 \text{ kg/m} \end{aligned}$$

Beams between Axis 2 & 3 and Axis 3 & 4

From A to B Axis

$$\begin{aligned} \text{Tributary area} &= \boxed{9.00} \text{ m}^2 \\ \text{L dist} &= \boxed{4.50} \text{ m} \end{aligned}$$

$$\begin{aligned} W_{\text{dead}} &= 742.0 \text{ kg/m} \\ W_{\text{live}} &= 200.00 \text{ kg/m} \end{aligned}$$

From B to C Axis

$$\begin{aligned} \text{Tributary area} &= \boxed{6.00} \text{ m}^2 \\ \text{L dist} &= \boxed{3.50} \text{ m} \end{aligned}$$

$$\begin{aligned} W_{\text{dead}} &= 636.0 \text{ kg/m} \\ W_{\text{live}} &= 171.43 \text{ kg/m} \end{aligned}$$

Beams between Axis 4 & 5 and Axis 5 & 6

From A to B Axis

$$\begin{aligned} \text{Tributary area} &= \boxed{9.64} \text{ m}^2 \\ \text{L dist} &= \boxed{4.50} \text{ m} \end{aligned}$$

$$\begin{aligned} W_{\text{dead}} &= 794.8 \text{ kg/m} \\ W_{\text{live}} &= 214.22 \text{ kg/m} \end{aligned}$$

From B to C Axis

$$\begin{aligned} \text{Tributary area} &= \boxed{6.14} \text{ m}^2 \\ \text{L dist} &= \boxed{3.50} \text{ m} \end{aligned}$$

$$\begin{aligned} W_{\text{dead}} &= 650.8 \text{ kg/m} \\ W_{\text{live}} &= 175.43 \text{ kg/m} \end{aligned}$$

<b>PROJECT:</b> Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
<b>SUBJECT:</b> Dead & Live Load	Date	July-02	Page	6/ 61

Beams in A Axis.

$$\begin{array}{l} \text{Tributary area} = \boxed{5.25} \text{ m}^2 \\ \text{L dist} = \boxed{3.00} \text{ m} \end{array}$$

From 1 to 4 Axis

$$\begin{array}{l} W_{\text{dead}} = 649.3 \text{ kg/m} \\ W_{\text{live}} = 175.00 \text{ kg/m} \end{array}$$

$$\begin{array}{l} \text{Tributary area} = \boxed{6.57} \text{ m}^2 \\ \text{L dist} = \boxed{3.50} \text{ m} \end{array}$$

From 4 to 6 Axis

$$\begin{array}{l} W_{\text{dead}} = 696.4 \text{ kg/m} \\ W_{\text{live}} = 187.71 \text{ kg/m} \end{array}$$

Beams in B Axis and between Axis B & C

$$\begin{array}{l} \text{Tributary area} = \boxed{5.25} \text{ m}^2 \\ \text{L dist} = \boxed{3.00} \text{ m} \end{array}$$

From 1 to 2 Axis

$$\begin{array}{l} W_{\text{dead}} = 649.3 \text{ kg/m} \\ W_{\text{live}} = 175.00 \text{ kg/m} \end{array}$$

$$\begin{array}{l} \text{Tributary area} = \boxed{4.50} \text{ m}^2 \\ \text{L dist} = \boxed{3.00} \text{ m} \end{array}$$

From 2 to 4 Axis

$$\begin{array}{l} W_{\text{dead}} = 556.5 \text{ kg/m} \\ W_{\text{live}} = 150.00 \text{ kg/m} \end{array}$$

$$\begin{array}{l} \text{Tributary area} = \boxed{6.14} \text{ m}^2 \\ \text{L dist} = \boxed{3.00} \text{ m} \end{array}$$

From 4 to 6 Axis

$$\begin{array}{l} W_{\text{dead}} = 759.3 \text{ kg/m} \\ W_{\text{live}} = 204.67 \text{ kg/m} \end{array}$$

Beams in C Axis

$$\begin{array}{l} \text{Tributary area} = \boxed{5.25} \text{ m}^2 \\ \text{L dist} = \boxed{3.00} \text{ m} \end{array}$$

From 2 to 4 Axis

$$\begin{array}{l} W_{\text{dead}} = 649.3 \text{ kg/m} \\ W_{\text{live}} = 175.00 \text{ kg/m} \end{array}$$

$$\begin{array}{l} \text{Tributary area} = \boxed{6.57} \text{ m}^2 \\ \text{L dist} = \boxed{3.50} \text{ m} \end{array}$$

From 2 to 4 Axis

$$\begin{array}{l} W_{\text{dead}} = 696.4 \text{ kg/m} \\ W_{\text{live}} = 187.71 \text{ kg/m} \end{array}$$

Beams between B & C Axis

$$\begin{array}{l} \text{Tributary area} = \boxed{5.25} \text{ m}^2 \\ \text{L dist} = \boxed{3.00} \text{ m} \end{array}$$

From 2 to 4 Axis

$$\begin{array}{l} W_{\text{dead}} = 649.3 \text{ kg/m} \\ W_{\text{live}} = 175.00 \text{ kg/m} \end{array}$$

$$\begin{array}{l} \text{Tributary area} = \boxed{6.57} \text{ m}^2 \\ \text{L dist} = \boxed{3.50} \text{ m} \end{array}$$

From 2 to 4 Axis

$$\begin{array}{l} W_{\text{dead}} = 696.4 \text{ kg/m} \\ W_{\text{live}} = 187.71 \text{ kg/m} \end{array}$$

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
SUBJECT: Seismic Load	Date	July-02	Page	7 / 61

**SEISMIC FORCES**

$$V = C_s W$$

$$C_s = (A I C_o / R) (T_o / T)^{2/3}$$

Coefficient of Acceleration, A =

Importance Factor, I =

Response Modification Factor, R =

Soil Conditions Factors

$C_o =$

$T_o =$

Period of the Structure,  $T = C_t h n^{3/4}$

Type of structure coefficient,  $C_t =$  (For concrete frames system)


The Period of the Structure and the  $C_s$  coefficient is calculated by the structural program (STAAD-III):

SEISMIC FORCE DIRECTION	Period T (sec.)	Coefficient Cs
X-Direction (Strong direction)	0.33	0.201
Z-Direction (Weak direction)	0.32	0.201



JOINT

STRUCTURE DATA  
 TYPE = SPACE  
 NJ = 57  
 NM = 82  
 NE = 0  
 NS = 17  
 NL = 2  
 XMAX = 32.0  
 YMAX = 4.5  
 ZMAX = 11.5



J=57, M=82

UNIT MET. MIO.

S T A A D . P O S T - P L O T (REV: 21.1M)

DATE: JUL 10, 2002

TITLE: POWER SUPPLY STATION

<b>CALCULATION</b>	
Detailed Design	
on Port Reactivation Project	
in La Union Province	
CALC FILE No.:	
CALC INDEX No.:	PAGE 8
INITIAL	DATE
PREPARED BY	R.M.G. July/02
CHECKED BY	A.M. July/02

<b>PROJECT:</b> Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
<b>SUBJECT:</b> Input for Dead & Live model	Date	July-02	Page	9 / 61

```

*****
*
*           S T A A D - III
*           Revision 21.1W
*           Proprietary Program of
*           RESEARCH ENGINEERS, Inc.
*           Date=   MAY 10, 2002
*
*****

```


1. STAAD SPACE POWER SUPPLY STATION
2. \*DEAD & LIVE FORCES
3. INPUT WIDTH 72
4. \*FRAMES 2 TO 6
5. UNIT METER MTON
6. JOINT COORDINATES
7. 1 0 0 0 4 18 0 0
8. 5 25 0 0 6 32 0 0
9. 7 0 0 4.50 10 18 0 4.50
10. 11 25 0 4.50 12 32 0 4.50
11. 13 6.00 0 11.50 15 18 0 11.50
12. 16 25 0 11.50 17 32 0 11.50
13. 18 0 4.50 0 24 18 4.50 0
14. 25 21.5 4.50 0 28 32 4.50 0
15. 29 0 4.50 4.50 35 18 4.50 4.50
16. 36 21.5 4.50 4.50 39 32 4.50 4.50
17. 40 6.00 4.50 8.00 44 18 4.50 8.00
18. 45 21.5 4.50 8.00 48 32 4.50 8.00
19. 49 6.00 4.50 11.50 53 18 4.50 11.50
20. 54 21.50 4.50 11.50 57 32.00 4.50 11.50
21. MEMBER INCIDENCES
22. \*COLUMNS
23. 1 1 18; 2 2 20; 3 3 22; 4 4 24; 5 5 26
24. 6 6 28 7; 8 8 31; 9 9 33; 10 10 35
25. 11 11 37; 12 12 39; 13 13 49; 14 14 51
26. 15 15 53; 16 16 55; 17 17 57
27. \*BEAMS
28. 18 18 19 27; 28 29 30 37; 38 40 41 45
29. 46 49 50 53
30. 54 18 29 64; 65 31 40 73; 74 40 49 82
31. MEMBER PROPERTY AMERICAN
32. \*COLUMNS
33. 1 TO 17 PRI YD 0.45 ZD 0.45
34. \*BEAMS
35. \*NUMERIC AXIS BEAMS
36. 54 56 58 60 62 64 PRI YD 0.45 ZD 0.30
37. 65 67 69 71 73 PRI YD 0.45 ZD 0.30
38. 74 76 78 80 82 PRI YD 0.45 ZD 0.30
39. \*BEAMS IN LETTER AXIS DIRECTION
40. 18 TO 53 PRI YD 0.40 ZD 0.30

<b>PROJECT:</b> Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
<b>SUBJECT:</b> Input for Dead & Live model	Date	July-02	Page	10 / 61

41. \*BEAMS BETWEEN NUM. AXIS  
 42. 55 57 59 61 63 66 68 PRI YD 0.35 ZD 0.25  
 43. 70 72 75 77 79 81 PRI YD 0.35 ZD 0.25  
 44. CONSTANT  
 45. E 2526713. ALL  
 46. DENSITY CONCRETE ALL  
 47. SUPPORT  
 48. 1 TO 17 FIXED  
 49. LOAD 1 DEAD LOAD  
 50. SELFWEIGHT Y -1  
 51. MEMBER LOAD  
 52. 54 56 58 UNI GY -0.742  
 53. 65 74 UNI GY -0.689  
 54. 67 76 UNI GY -0.636  
 55. 60 64 UNI GY -0.769  
 56. 69 78 UNI GY -0.644  
 57. 62 UNI GY -0.795  
 58. 71 80 UNI GY -0.651  
 59. 73 82 UNI GY -0.697  
 60. 55 57 59 UNI GY -0.742  
 61. 66 75 68 77 UNI GY -0.636  
 62. 61 63 UNI GY -0.795  
 63. 70 79 72 81 UNI GY -0.651  
 64. 18 TO 23 28 29 UNI GY -0.650  
 65. 24 TO 27 UNI GY -0.697  
 66. 30 TO 33 UNI GY -0.556  
 67. 34 TO 37 UNI GY -0.760  
 68. 38 TO 41 46 TO 49 UNI GY -0.650  
 69. 42 TO 45 50 TO 53 UNI GY -0.697  
 70. LOAD 2 LIVE LOAD  
 71. MEMBER LOAD  
 72. 54 56 58 UNI GY -0.200  
 73. 65 74 UNI GY -0.186  
 74. 67 76 UNI GY -0.172  
 75. 60 64 UNI GY -0.207  
 76. 69 78 UNI GY -0.174  
 77. 62 UNI GY -0.214  
 78. 71 80 UNI GY -0.176  
 79. 73 82 UNI GY -0.188  
 80. 55 57 59 UNI GY -0.200  
 81. 66 75 68 77 UNI GY -0.172  
 82. 61 63 UNI GY -0.215  
 83. 70 79 72 81 UNI GY -0.176  
 84. 18 TO 23 28 29 UNI GY -0.175  
 85. 24 TO 27 UNI GY -0.188  
 86. 30 TO 33 UNI GY -0.150  
 87. 34 TO 37 UNI GY -0.205  
 88. 46 TO 49 UNI GY -0.175  
 89. 50 TO 53 UNI GY -0.188  
 90. PERFORM ANALYSIS

JOINT

STRUCTURE DATA  
 TYPE = SPACE  
 NJ = 57  
 NM = 82  
 NE = 0  
 NS = 17  
 NL = 2  
 XMAX = 32.0  
 YMAX = 4.5  
 ZMAX = 11.5



J=57, M=82

UNIT MET MIO

ST A A D P O S T - P L O T (REV: 21.1W)  
 TITLE: POWER SUPPLY STATION

DATE: JUL 10, 2002

**CALCULATION**

Detailed Design			
on Port Reactivation Project			
In La Union Province			
CALC FILE No.:			
CALC INDEX No.:	PAGE	7	
PREPARED BY	INITIAL	DATE	
CHECKED BY	R.M.G	July/02	
	A.M.	July/02	

<b>PROJECT:</b> Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.		Checked by	A.MORIJOKA
<b>SUBJECT:</b> Input for Seismic model	Date	July-02	Page	12 / 61

```

*****
*
*           S T A A D - III
*           Revision 21.1W
*           Proprietary Program of
*           RESEARCH ENGINEERS, Inc.
*           Date=   JUL 10, 2002
*
*****

```

1. STAAD SPACE POWER SUPPLY STATION
2. \*SEISMIC FORCES
3. INPUT WIDTH 72
4. \*FRAMES 2 TO 6
5. UNIT METER MTON
6. JOINT COORDINATES
7. 1 0 0 0 4 18 0 0
8. 5 25 0 0 6 32 0 0
9. 7 0 0 4.50 10 18 0 4.50
10. 11 25 0 4.50 12 32 0 4.50
11. 13 6.00 0 11.50 15 18 0 11.50
12. 16 25 0 11.50 17 32 0 11.50
13. 18 0 4.50 0 24 18 4.50 0
14. 25 21.5 4.50 0 28 32 4.50 0
15. 29 0 4.50 4.50 35 18 4.50 4.50
16. 36 21.5 4.50 4.50 39 32 4.50 4.50
17. 40 6.00 4.50 8.00 44 18 4.50 8.00
18. 45 21.5 4.50 8.00 48 32 4.50 8.00
19. 49 6.00 4.50 11.50 53 18 4.50 11.50
20. 54 21.50 4.50 11.50 57 32.00 4.50 11.50
21. MEMBER INCIDENCES
22. \*COLUMNS
23. 1 1 18; 2 2 20; 3 3 22; 4 4 24; 5 5 26
24. 6 6 28 7; 8 8 31; 9 9 33; 10 10 35
25. 11 11 37; 12 12 39; 13 13 49; 14 14 51
26. 15 15 53; 16 16 55; 17 17 57
27. \*BEAMS
28. 18 18 19 27; 28 29 30 37; 38 40 41 45
29. 46 49 50 53
30. 54 18 29 64; 65 31 40 73; 74 40 49 82
31. MEMBER PROPERTY AMERICAN
32. \*COLUMNS
33. 1 TO 17 PRI YD 0.45 ZD 0.45
34. \*BEAMS
35. \*NUMERIC AXIS BEAMS
36. 54 56 58 60 62 64 PRI YD 0.45 ZD 0.30
37. 65 67 69 71 73 PRI YD 0.45 ZD 0.30
38. 74 76 78 80 82 PRI YD 0.45 ZD 0.30
39. \*BEAMS IN LETTER AXIS DIRECTION
40. 18 TO 53 PRI YD 0.40 ZD 0.30

<b>PROJECT:</b> Detailed Design on Port Reactivation Project In La Union Province	Calc. File No.		Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
<b>SUBJECT:</b> Input for Seismic model	Date	July-02	Page	161

```

41. *BEAMS BETWEEN NUM. AXIS
42. 55 57 59 61 63 66 68 PRI YD 0.35 ZD 0.25
43. 70 72 75 77 79 81 PRI YD 0.35 ZD 0.25
44. CONSTANT
45. E 2526713. ALL
46. DENSITY CONCRETE ALL
47. SUPPORT
48. 1 TO 17 FIXED
49. DEFINE UBC LOAD
50. ZONE 0.4 I 1.2 RWX 12 RWZ 12 S 3.00 CT 0.073 TS 0.90
51. SELFWEIGHT
52. JOINT WEIGHT
53. 18 TO 57 WEIGHT 4.776
54. LOAD 1 EQ X
55. UBC LOAD X 1
56. LOAD 2 EQ Z
57. UBC LOAD Z 1
58. PERFORM ANALYSIS PRINT LOAD DATA
    
```

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
SUBJECT: Input for Seismic model	Date	July-02	Page	4 / 61

\*SEISMIC FORCES

LOADING    1    EQ X  
-----

LOADING    2    EQ Z  
-----

```

*****
*
*  CALC/USED PERIOD FOR X  UBC =  0.3312/  0.3312 SEC  *
*  C, C-ALT =  0.1158 ,  4.4701, LOAD FACTOR = 1.000  *
*  UBC FACTOR V =  0.2016 X   292.43 =    58.95 MTON  *
*
*****
    
```

```

*****
*
*  CALC/USED PERIOD FOR Z  UBC =  0.3202/  0.3202 SEC  *
*  C, C-ALT =  0.1178 ,  4.4701, LOAD FACTOR = 1.000  *
*  UBC FACTOR V =  0.2016 X   292.43 =    58.95 MTON  *
*
*****
    
```

JOINT	LATERAL LOAD (MTON),	LOAD - 1
-----	-----	FACTOR - 1.000
18	FX	1.514
19	FX	1.316
20	FX	1.607
21	FX	1.316
22	FX	1.607
23	FX	1.316
24	FX	1.623
25	FX	1.347
26	FX	1.638
27	FX	1.347
28	FX	1.530
29	FX	1.514
30	FX	1.316
31	FX	1.730
32	FX	1.396
33	FX	1.730
34	FX	1.396
35	FX	1.745
36	FX	1.427
37	FX	1.761
38	FX	1.427
39	FX	1.652
40	FX	1.366

<b>PROJECT:</b> Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
<b>SUBJECT:</b> Input for Seismic model	Date	July-02	Page 15 / 61

41	FX	1.373
42	FX	1.459
43	FX	1.373
44	FX	1.474
45	FX	1.404
46	FX	1.490
47	FX	1.404
48	FX	1.381
49	FX	1.479
50	FX	1.294
51	FX	1.572
52	FX	1.294
53	FX	1.588
54	FX	1.325
55	FX	1.603
56	FX	1.325
57	FX	1.495

\* -----  
 \* TOTAL = 58.954 AT LEVEL 4.500 METE  
 \*

JOINT		LATERAL LOAD (MTON),	LOAD - 2
			FACTOR - 1.000
18	FZ	1.514	
19	FZ	1.316	
20	FZ	1.607	
21	FZ	1.316	
22	FZ	1.607	
23	FZ	1.316	
24	FZ	1.623	
25	FZ	1.347	
26	FZ	1.638	
27	FZ	1.347	
28	FZ	1.530	
29	FZ	1.514	
30	FZ	1.316	
31	FZ	1.730	
32	FZ	1.396	
33	FZ	1.730	
34	FZ	1.396	
35	FZ	1.745	
36	FZ	1.427	
37	FZ	1.761	
38	FZ	1.427	
39	FZ	1.652	
40	FZ	1.366	
41	FZ	1.373	
42	FZ	1.459	
43	FZ	1.373	
44	FZ	1.474	
45	FZ	1.404	
46	FZ	1.490	



<b>PROJECT:</b> Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
<b>SUBJECT:</b> Input for Seismic model	Date	July-02	Page	6 / 61

47	FZ	1.404
48	FZ	1.381
49	FZ	1.479
50	FZ	1.294
51	FZ	1.572
52	FZ	1.294
53	FZ	1.588
54	FZ	1.325
55	FZ	1.603
56	FZ	1.325
57	FZ	1.495

\* -----  
 \* TOTAL =           58.954 AT LEVEL       4.500 METE  
 \*

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
SUBJECT: Vertical Loads	Date	July-02	Page	17 / 61

**VERTICAL LOADS**

Axis	Roof (ton)		First Floor (ton)		
	Dead Load	Live Load	Area (m <sup>2</sup> )	Dead	Live
1-A	8.22	1.15	6.75	2.84	3.38
2-A	11.81	1.89	13.50	5.67	6.75
3-A	10.91	1.76	13.50	5.67	6.75
4-A	11.76	1.95	14.63	6.14	7.31
5-A	12.82	2.19	15.75	6.62	7.88
6-A	8.11	1.20	7.88	3.31	3.94
1-B	8.10	1.14	6.75	2.84	3.38
2-B	19.94	3.05	24.00	10.08	12.00
3-B	23.07	3.27	34.50	14.49	17.25
4-B	24.54	3.56	35.65	14.97	17.83
5-B	27.21	4.03	21.00	8.82	10.50
6-B	16.79	2.45	18.00	7.56	9.00
2~3-B'	0.00	0.00	0.00	0.00	0.00
3~4-B'	0.00	0.00	0.00	0.00	0.00
2-C	10.52	1.34	10.50	4.41	5.25
3-C	16.67	2.22	21.00	8.82	10.50
4-C	17.19	2.30	21.70	9.11	10.85
5-C	19.04	2.57	12.25	5.15	6.13
6-C	11.40	1.48	6.13	2.57	3.06

Wd = 420.0 kg/m<sup>2</sup>

Wl = 500.0 kg/m<sup>2</sup>

Axis	ton				Pile Bearing Capacity
	Walls	Footing	Total		
1-A	6.16	2.03	23.77	80.00	o.k!!!
2-A	9.68	2.03	37.83	80.00	o.k!!!
3-A	7.04	2.03	34.16	80.00	o.k!!!
4-A	7.63	2.03	36.83	80.00	o.k!!!
5-A	8.21	2.03	39.75	80.00	o.k!!!
6-A	4.11	2.03	22.69	80.00	o.k!!!
1-B	5.77	2.03	23.25	80.00	o.k!!!
2-B	10.27	2.03	57.37	80.00	o.k!!!
3-B	0.00	2.03	60.11	80.00	o.k!!!
4-B	6.75	2.03	69.68	80.00	o.k!!!
5-B	0.00	2.03	52.59	80.00	o.k!!!
6-B	6.75	2.03	44.58	80.00	o.k!!!
2~3-B'	0.00	2.03	2.03	80.00	o.k!!!
3~4-B'	0.00	2.03	2.03	80.00	o.k!!!
2-C	7.63	2.03	31.18	80.00	o.k!!!
3-C	7.04	2.03	47.28	80.00	o.k!!!
4-C	11.73	2.03	53.22	80.00	o.k!!!
5-C	8.21	2.03	43.13	80.00	o.k!!!
6-C	8.21	2.03	28.76	80.00	o.k!!!

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
SUBJECT: Input for Dead & Live model	Date	July-02	Page	18 / 61

SUPPORT REACTIONS -UNIT MTON METE								STRUCTURE TYPE = SPACE
JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM Z	
1	1	1.10	8.22	0.57	0.87	-0.03	-1.64	
	2	0.21	1.15	0.11	0.16	0.00	-0.32	
2	1	-0.10	11.81	0.57	1.10	-0.03	0.13	
	2	-0.02	1.89	0.11	0.19	0.00	0.03	
3	1	0.01	10.91	0.51	1.11	-0.01	-0.05	
	2	0.00	1.76	0.10	0.19	0.00	-0.01	
4	1	0.37	11.76	0.54	1.19	0.00	-0.61	
	2	0.08	1.95	0.11	0.20	0.00	-0.12	
5	1	0.19	12.82	0.55	1.20	0.01	-0.36	
	2	0.03	2.19	0.11	0.20	0.00	-0.07	
6	1	-1.47	8.11	0.50	1.03	0.02	2.07	
	2	-0.29	1.20	0.10	0.17	0.00	0.42	
7	1	1.05	8.10	-0.50	-0.70	-0.02	-1.55	
	2	0.21	1.14	-0.10	-0.14	0.00	-0.31	
8	1	0.47	19.94	1.09	1.87	-0.01	-0.71	
	2	0.05	3.05	0.11	0.19	0.00	-0.07	
9	1	-0.07	23.07	1.89	3.16	0.00	0.07	
	2	-0.01	3.27	0.17	0.29	0.00	0.01	
10	1	0.54	24.54	2.00	3.35	0.00	-0.86	
	2	0.10	3.56	0.17	0.29	0.00	-0.16	
11	1	0.27	27.21	2.21	3.67	0.00	-0.50	
	2	0.04	4.03	0.19	0.32	0.00	-0.08	
12	1	-2.35	16.79	1.33	2.27	0.00	3.35	
	2	-0.40	2.45	0.14	0.23	0.00	0.57	
13	1	1.29	10.52	-1.66	-2.18	-0.02	-1.93	
	2	0.21	1.34	-0.22	-0.30	0.00	-0.31	
14	1	-0.15	16.67	-2.46	-3.26	-0.01	0.19	
	2	-0.02	2.22	-0.28	-0.38	0.00	0.03	

<b>PROJECT:</b> Detailed Design on Port Reactivation Project In La Union Province	Calc. File No.		Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
<b>SUBJECT:</b> Input for Dead & Live model	Date	July-02	Page	18 / 61

**SUPPORT REACTIONS -UNIT MTON METE      STRUCTURE TYPE = SPACE**  
 -----

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM Z
15	1	0.38	17.19	-2.55	-3.36	-0.01	-0.61
	2	0.06	2.30	-0.28	-0.38	0.00	-0.10
16	1	0.23	19.04	-2.82	-3.75	0.01	-0.42
	2	0.04	2.57	-0.31	-0.42	0.00	-0.07
17	1	-1.76	11.40	-1.77	-2.31	0.02	2.50
	2	-0.28	1.48	-0.23	-0.30	0.00	0.40

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
SUBJECT: Input for Seismic model	Date	July-02	Page 20 / 61

SUPPORT REACTIONS -UNIT MTON METE		STRUCTURE TYPE = SPACE					
JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM Z
1	1	-2.46	-1.25	-0.14	-0.37	-0.13	7.51
	2	-0.08	-1.88	-2.30	-6.20	0.37	0.17
2	1	-3.28	0.21	0.01	0.02	-0.08	8.73
	2	-0.04	-2.38	-3.30	-8.96	0.15	0.10
3	1	-3.21	-0.05	0.00	0.00	-0.07	8.62
	2	-0.04	-2.63	-3.68	-10.00	0.05	0.09
4	1	-3.13	0.25	0.01	0.03	-0.07	8.51
	2	-0.03	-2.69	-3.78	-10.26	0.05	0.07
5	1	-3.12	-0.13	0.01	0.03	-0.08	8.50
	2	-0.02	-2.66	-3.73	-10.15	-0.05	0.05
6	1	-2.35	0.92	0.05	0.16	-0.10	7.36
	2	0.03	-2.09	-2.93	-8.02	-0.37	-0.03
7	1	-3.05	-1.27	-0.14	-0.37	-0.15	9.23
	2	0.08	1.88	-2.32	-6.23	0.37	-0.16
8	1	-4.09	0.09	-0.03	-0.05	-0.32	10.79
	2	0.02	1.26	-4.08	-10.11	0.08	-0.07
9	1	-4.07	0.02	0.02	0.02	-0.30	10.78
	2	0.04	1.31	-4.58	-11.34	0.03	-0.09
10	1	-3.99	0.30	0.02	0.04	-0.30	10.67
	2	0.03	1.35	-4.70	-11.64	0.03	-0.08
11	1	-4.00	-0.25	-0.01	0.00	-0.32	10.69
	2	0.03	1.33	-4.64	-11.51	-0.03	-0.08
12	1	-3.11	1.20	0.12	0.25	-0.42	9.38
	2	0.01	1.06	-3.68	-9.15	-0.20	-0.05
13	1	-3.35	-1.54	0.06	0.10	0.37	9.89
	2	0.02	1.12	-2.81	-8.24	0.24	-0.04
14	1	-4.31	0.25	-0.01	-0.02	0.25	11.33
	2	0.00	1.32	-3.25	-9.38	0.04	0.00


<b>PROJECT:</b> Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
<b>SUBJECT:</b> Input for Selsmic model	Date	July-02	Page	2 / 61

**SUPPORT REACTIONS -UNIT MTON METE      STRUCTURE TYPE = SPACE**  
 -----

JOINT	LOAD	FORCE-X	FORCE-Y	FORCE-Z	MOM-X	MOM-Y	MOM Z
15	1	-4.12	0.29	0.00	0.02	0.25	11.04
	2	-0.01	1.34	-3.33	-9.63	0.04	0.02
16	1	-4.13	-0.25	0.03	0.06	0.26	11.06
	2	-0.01	1.33	-3.30	-9.54	-0.05	0.04
17	1	-3.20	1.22	0.00	0.06	0.38	9.68
	2	-0.04	1.03	-2.55	-7.49	-0.33	0.09

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
SUBJECT: Vertical Loads	Date	Page	22 / 61

**Design for foundation F-1**



Thickness,  $h =$   cm

$d =$   cm

Clear cover =  cm

- Shrinkage and temperature reinforcement, ACI 7.12.

Minimum Gross area ratio =  Total area of steel = 13.86 cm<sup>2</sup>  
 Area by layer =  $A_s/2 =$  6.93 cm<sup>2</sup>

Bar denomination,  $N =$   Bar Area ( $A_v$ ) = 1.27 cm<sup>2</sup>

Number of bars = 5.47 Use 6 - N4


Pitch = 19.24 cm 6 - N 4 @ 19 cm

Minimum spacing for ties, ACI 11.5.4.

$S_1 = d/2 =$  26.55 cm  
 $S_2 =$  60.00 cm
 }
 Use  $S =$  25.00 cm

PROJECT: Detailed Design on Port Reactivation Project In La Union Province	Calc. File No.	Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
SUBJECT: Pile design	Date	July-02	Page 23 / 61

**BEARING CAPACITY OF SQUARE DRIVEN CONCRETE PILES**



Side dimension =  m

Properties  
In Top Soil:

Properties  
In Bearing Stratum:

N of hits by SPT =  N       N

$\phi = \sqrt{12N + 20}$

$\phi =$   °       °

$\gamma =$   ton/m<sup>3</sup>       ton/m<sup>3</sup>

$N_q =$       

$\delta =$   °       °

$KH_c =$       

Factor of safety (F.S.) =

Pressure due to soil:

**Qult = Qt + Qf**

- Tip Resistance (Qt)

$P_1 =$   ton/m<sup>2</sup>

$Q_p = P_t \times N_q \times A_t$        $P_t = P_3 =$  10.42 ton/m<sup>2</sup>

$P_2 =$  8.58 ton/m<sup>2</sup>

$P_3 =$  10.42 ton/m<sup>2</sup>

Pile Area = 0.160 m<sup>2</sup>

**Qp = 241.79 ton**

- Friction Capacity (Qf)

Consider Friction ?  Y/N

$Q_f = \sum(KH_c) \times P_o \times \tan(\delta) \times S$

$S_1 = 2BLD$        $S_1 =$  4.80 m<sup>2</sup>

$P_{o1} = (P_1 + P_2)/2$

$S_2 = 2BL'D$        $S_2 =$  0.80 m<sup>2</sup>

$P_{o2} = (P_2 + P_3)/2$

$P_{o1} =$  4.292 ton/m<sup>2</sup>

$P_{o2} =$  9.502 ton/m<sup>2</sup>

**Qf = 0.00 ton**

Qult = Qt + Qf

Qult = 241.79 ton

Qadm = Qult / F.S.

**Qadm = 80.60 ton**



PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
SUBJECT: Pile design	Date	July-02	Page 21 / 61

**PILE SEISMIC STRESS**  
based on chung equation

mark	size (cm)	length (m)	I (cm <sup>4</sup> )	kh (kg/cm <sup>3</sup> )	(cm-1) (cm-1)	L	I 3
P1	40	7	2.13E+05	3.169	0.00472	3.3	0.022
P2	45	7	3.42E+05	2.901	0.00422	3.0	0.026

N of piles	nl 3	Q (t)	Q (t/n)	y0 (cm)	M0 (t m)	Mmax (t m)	lm (m)
17	0.381	58.6	3.4	0.1	3.7	0.8	3.3
0	0.000	0.0	0.0	0.0	0.0	0.0	3.7

Σ= 17      0.381      58.6

Young's Modulus, E = 3.00E+05 kg/cm<sup>2</sup>  
Seismic force, Q = 58.6 t


N = 9  
E0 = 63

40 x 40		
L (cm)	M (t m)	Q (t)
0	3.7	3.4
-50	2.1	2.6
-100	1.0	1.9
-150	0.2	1.3
-200	-0.3	0.8
-250	-0.6	0.4
-300	-0.7	0.1
-350	-0.8	-0.1
-400	-0.7	-0.2
-450	-0.6	-0.2
-500	-0.5	-0.2
-550	-0.4	-0.2
-600	-0.3	-0.2
-650	-0.2	-0.2
-700	-0.1	-0.1
-750	-0.1	-0.1

45 x 45		
L (cm)	M (t m)	Q (t)
0	0.0	0.0
-50	0.0	0.0
-100	0.0	0.0
-150	0.0	0.0
-200	0.0	0.0
-250	0.0	0.0
-300	0.0	0.0
-350	0.0	0.0
-400	0.0	0.0
-450	0.0	0.0
-500	0.0	0.0
-550	0.0	0.0
-600	0.0	0.0
-650	0.0	0.0
-700	0.0	0.0
-750	0.0	0.0

<b>PROJECT:</b> Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
<b>SUBJECT:</b> Pile design	Date	July-02	Page 25 / 61

**PILE DESIGN**



$f_c = 350.00 \text{ kg/cm}^2$

At release,  $f_c = 280.00 \text{ kg/cm}^2$

Section Area = 1600  $\text{cm}^2$

Section Inertia = 213333.3  $\text{cm}^4$

- Prestressing Force

Cables.

Uncoated seven wire stress relieved strands.  
 $\phi = 12.7 \text{ mm}$ . Area = 92.90  $\text{mm}^2$ .

Ultimate Strength,  $F_{pu} = 17,500.0 \text{ kg/cm}^2$

# of strands to use = 6

Prestressing force,  $P_o = 0.70 F_{pu} A = 68.28 \text{ ton}$

Allowable stress

At service

$0.4 f_c = 140 \text{ kg/cm}^2$

At release

$0.4 f_c = 112 \text{ kg/cm}^2$

a) Stress at release

Axial Load,  $P_a = 0.00 \text{ ton}$

Excentricity,  $e = 0.00 \text{ cm}$

Moment,  $M_a = 0.00 \text{ ton-m}$

$c = 20.00 \text{ cm}$

$(P_a + P_o) / A \pm (P_o e c / I + M_a c / I)$

$42.68 \pm 0.00$

Stress 1 = 42.68  $\text{kg/cm}^2 < 0.4f_c \text{ o.k!!!}$

Stress 2 = 42.68  $\text{kg/cm}^2 < 0.4f_c \text{ o.k!!!}$

b) Stress at Service

Axial Load,  $P_a = 80.60 \text{ ton}$

Excentricity,  $e = 0.00 \text{ cm}$

Moment,  $M_a = 3.65 \text{ ton-m}$

Prestress force,  $P_e = 58.04 \text{ cm (15% losses)}$

$(P_a + P_e) / A \pm (P_e e c / I + M_a c / I)$


$86.65 \pm 34.25$

Stress 1 = 120.90  $\text{kg/cm}^2 < 0.4f_c \text{ o.k!!!}$

Stress 2 = 52.40  $\text{kg/cm}^2 < 0.4f_c \text{ o.k!!!}$

<b>PROJECT:</b> Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
<b>SUBJECT:</b> Column design	Date	July-02	Page 26/61

### COLUMN DESIGN (5-A)



$H = 0.45 \text{ m}$   
 $B = 0.45 \text{ m}$   
 $f'c = 280 \text{ kg/cm}^2$   
 $f_y = 4200 \text{ kg/cm}^2$

Area = 2,025 cm<sup>2</sup>  
 Inertia z = 341,719 cm<sup>4</sup>  
 Inertia y = 341,719 cm<sup>4</sup>

**Forces and Moments**

From Structural Analysis (ton , m) :

TYPE OF LOAD	AXIAL	MOMENT		SHEAR	
	P	Mz-z	Mx-x	Vx	Vz
Dead Load	12.03	0.30	2.70	0.17	2.03
Live Load	2.59	0.07	0.41	0.03	0.31
Seismic Load x	0.32	10.81	0.10	4.20	0.04
Seismic Load z	1.35	0.10	9.67	0.05	3.34

COMB.	Pu	Mu z-z	Mu x-x	Vu x	Vu z
C1	21.25	0.54	4.48	0.29	3.37
C2	15.46	17.80	---	6.89	---
C3	16.90	---	19.41	---	8.19

$C1 = 1.4 \text{ DL} + 1.7 \text{ LL}$   
 $C2 = 0.75(1.4\text{DL} + 1.7\text{LL} + 1.87\text{SL}_y)$   
 $C3 = 0.75(1.4\text{DL} + 1.7\text{LL} + 1.87\text{SL}_z)$

Forces for design.

$Pu_z = 16.90 \text{ ton}$        $Pu_x = 15.46 \text{ ton}$   
 $Mu_{x-x} = 19.41 \text{ ton-m}$        $Mu_{z-z} = 17.80 \text{ ton-m}$   
 $Vu_z = 6.89 \text{ ton}$        $Vu_x = 8.19 \text{ ton}$

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
SUBJECT: Column design	Date	July-02	Page	27 / 61

Orthogonal Combination

$$M_x = 100\%EQX + 30\%EQZ$$

$$M_z = 100\%EQZ + 30\%EQX$$

$$M_x = M_x + M_z(H/B) \left( \frac{1-\beta}{\beta} \right) \quad \beta = 0.65$$

$$M_z = M_z + M_x(B/H) \left( \frac{1-\beta}{\beta} \right) \quad \beta = 0.65$$

Slenderness.

if  $klu/r > 22$  Consider Slenderness.

$$k = 2.0 \quad lu = \boxed{4.02} \text{ m} \quad r = (\text{Inertia}/\text{Area})^{1/2}$$

Y Direction

$$r = 0.130 \text{ m} \quad klu/r = 61.892 > 22 \text{ Consider slenderness}$$

Z Direction

$$r = 0.130 \text{ m} \quad klu/r = 61.892 > 22 \text{ Consider slenderness}$$

Slenderness

$$M_c = \delta_b M_b + \delta_s M_s$$

$$\delta_b = cm / (1 - P_u / \phi P_c) \quad cm = 1.0$$

$$P_c = \pi^2 EI / (klu)^2 \quad E = 2526713 \text{ ton/m}^2$$

$$P_u = \text{Axial Force} = 21.25 \text{ ton}$$

X Dir. :

Z Dir. :

$$\text{Inertia} = 0.0034 \text{ m}^2$$

$$\text{Inertia} = 0.0034 \text{ m}^2$$

$$P_c = 1318.30 \text{ ton}$$

$$P_c = 1318.30 \text{ ton}$$

$$\delta_b = 1.017$$

$$\delta_b = 1.019$$

$$M_u \text{ x-x} = 18.10 \text{ ton-m}$$

$$M_u \text{ z-z} = 19.77 \text{ ton-m}$$

<b>PROJECT:</b> Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
<b>SUBJECT:</b> Column design	Date	July-02	Page 28 / 61

- Design by flexure and Axial load

Z Direction :  $\phi = 0.70$

Gross Area (Ag) = 0.20 m<sup>2</sup> = 313.91 in<sup>2</sup>

h = 0.45 m = 17.72 in

P = 15.46 ton = 34.08 kips

M = 18.10 ton-m = 1571.20 kips-in

**Pu/Ag = 0.11 Mu/Agh = 0.28**

From the Load-Moment strength interaction diagram R4-60.90,  
the  $\rho$  value is:

$\rho =$   %  $As = Ag \times \rho = 22.28 \text{ cm}^2$

Bar denomination =  Bar area = 3.88 cm<sup>2</sup>

Quantity of bars = 5.74

Use 6 N 7

X Direction :  $\phi = 0.7$

Gross Area (Ag) = 0.20 m<sup>2</sup> = 313.91 in<sup>2</sup>

h = 0.45 m = 17.72 in

P = 16.90 ton = 37.26 kips

M = 19.77 ton = 1716.32 kips-in

**Pu/Ag = 0.12 Mu/Agh = 0.31**

From the Load-Moment strength interaction diagram R4-60.90,  
the  $\rho$  value is:


$\rho ?$   %  $As = Ag \times \rho = 25.31 \text{ cm}^2$

Bar Denomination =  Bar area = 3.88 cm<sup>2</sup>

Quantity of bars = 6.52

Use 8 N 7

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by R.Martinez
SECTION: Power Supply Station	Calc. Index No.		Checked by A.MORIOKA
SUBJECT: Column design	Date	July-02	Page 29/61



**SHEAR DESIGN.**

X Direction :

$bw = 450.00 \text{ mm}$

$d = 388.89 \text{ mm}$

$f_y = 4200 \text{ kg/cm}^2$   
 $411.90 \text{ Mpa}$

$f'_c = 280 \text{ kg/cm}^2$   
 $27.46 \text{ Mpa}$

Shear Strength provided by concrete.

$V_c = (\sqrt{f'_c} / 6) bw d$

$V_c = 152,839.5 \text{ Newton}$   
 $15,584.7 \text{ kg}$

$V_c = (1 + Nu / 14Ag) (\sqrt{f'_c} / 6) bw$

$Nu = 15.46 \text{ ton}$   
 $151,596 \text{ Newton}$

$V_c = 161,012.2 \text{ Newton}$   
 $16,418.1 \text{ kg}$

$V_c = 15,584.73 \text{ kg}$

<b>PROJECT:</b> Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
<b>SUBJECT:</b> Column design	Date	July-02	Page	30/61

$$V_n = V_c + V_s \quad V_s = V_u / \phi - V_c \quad \phi = 0.85$$

$$V_u = 6.89 \text{ ton} \quad V_s = (7,478.7) \text{ kg}$$

$$V_s = A_v f_y d / s \quad ; \quad S_{req} = A_v f_y d / V_s$$

$$\text{Bar denomination} = \boxed{3}$$

$$\text{Bar area} = 0.71 \text{ cm}^2$$

$$\# \text{ of legs} = \boxed{2}$$

$$\text{Spacing, } S_{req} = -31.12 \text{ cm}$$

Max. spacing of shear reinforcement.

$$\left. \begin{array}{l} d/2 = 19.44 \text{ cm} \\ 60 \text{ mm} = 60 \text{ cm} \end{array} \right\} S_2 = 19.44 \text{ cm}$$

$$(1/3) (\sqrt{f'_c} / 6) b_w d = 50946.49 \text{ Newton} \\ 5,194.9 \text{ kg} > V_s, \text{ o.k.}$$

$$S_2 = 19.44 \text{ cm}$$

Minimum Shear Reinforcement

$$A_v = (1/3) b_w S / f_y$$

$$S_3 = 3 A_v f_y / b_w$$

$$S_3 = 39.13 \text{ cm}$$

**Use 2 legs of N 3 @ 19 cm**

<b>PROJECT:</b> Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
<b>SUBJECT:</b> Column design	Date	July-02	Page	3 / 61

Z Direction :

$bw = 450.00 \text{ mm}$ 
 $f_y = \boxed{4200} \text{ kg/cm}^2$   
 $411.90 \text{ Mpa}$

$d = \boxed{388.89} \text{ mm}$ 
 $f'_c = 280.00 \text{ kg/cm}^2$   
 $27.46 \text{ Mpa}$

Shear Strenght provided by concrete.

$V_c = (\sqrt{f'_c} / 6) bw d$

$V_c = 152,839.5 \text{ Newton}$   
 $15,584.7 \text{ kg}$

$V_c = (1+Nu/14Ag) (\sqrt{f'_c} / 6) bw$

$Nu = 16.90 \text{ ton}$   
 $165,763 \text{ Newton}$

$V_c = 161,776.0 \text{ Newton}$   
 $16,496.0 \text{ kg}$

}

$V_c = 15,584.73 \text{ kg}$

$V_n = V_c + V_s$        $V_s = V_u / \phi - V_c$        $\phi = 0.85$

$V_u = 8.19 \text{ ton}$        $V_s = (5,954.4) \text{ kg}$

$V_s = A_v f_y d / s$       ;       $S_{req} = A_v f_y d / V_s$

Bar denomination =  $\boxed{3}$       Bar area =  $0.71 \text{ cm}^2$

# of legs =  $\boxed{2}$       Spacing,  $S_{req} = -39.09 \text{ cm}$

Max. spacing of shear reinforcement.

$d/2 = 19.44 \text{ cm}$

$60 \text{ mm} = 60 \text{ cm}$

}

$S_2 = 19.44 \text{ cm}$

$(1/3) (\sqrt{f'_c} / 6) bw d = 50946.49 \text{ Newton}$   
 $5,194.9 \text{ kg} > V_s, \text{ o.k.}$

$S_2 = 19.44 \text{ cm}$

Minimum Shear Reinforcement


$A_v = (1/3) bw S / f_y$        $S_3 = 3 A_v f_y / bw$        $S_3 = 39.13 \text{ cm}$

**Use 2 legs of N 3 @ 19 cm**



PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
SUBJECT: Column design	Date	July-02	Page	32/61

### COLUMN DESIGN (4-B)



H = 0.45 m  
 B = 0.45 m  
 $f'c = 280 \text{ kg/cm}^2$   
 $f_y = 4200 \text{ kg/cm}^2$

Area = 2,025 cm<sup>2</sup>

Inertia z = 341,719 cm<sup>4</sup>

Inertia y = 341,719 cm<sup>4</sup>

**Forces and Moments**

From Structural Analysis (ton , m) :

TYPE OF LOAD	AXIAL		MOMENT		SHEAR	
	P	Mz-z	Mx-x	Vx	Vz	
Dead Load	15.89	0.60	2.36	0.38	1.40	
Live Load	3.56	0.14	0.29	0.10	0.17	
Seismic Load x	0.32	10.35	0.05	4.02	0.02	
Seismic Load z	1.38	0.09	11.85	0.04	4.79	

COMB.	Pu	Mu z-z	Mu x-x	Vu x	Vu z
C1	28.30	1.08	3.80	0.70	2.25
C2	20.41	18.05	---	7.26	---
C3	21.89	---	21.83	---	9.33

C1 = 1.4 DL + 1.7 LL  
 C2 = 0.75( 1.4DL + 1.7LL + 1.87SLy)  
 C3 = 0.75( 1.4DL + 1.7LL + 1.87SLz)

Forces for design.

Pu z = 21.89 ton      Pu x = 20.41 ton  
 Mu x-x = 21.83 ton-m      Mu z-z = 18.05 ton-m  
 Vu z = 7.26 ton      Vu x = 9.33 ton

<b>PROJECT:</b> Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
<b>SUBJECT:</b> Column design	Date	July-02	Page 23/61

**Orthogonal Combination**

$$M_x = 100\%EQX + 30\%EQZ$$

$$M_z = 100\%EQZ + 30\%EQX$$

$$M_x = M_x + M_z(H/B) \left( \frac{1-\beta}{\beta} \right) \quad \beta = 0.65$$

$$M_z = M_z + M_x(B/H) \left( \frac{1-\beta}{\beta} \right) \quad \beta = 0.65$$

Slenderness.

if  $klu/r > 22$  Consider Slenderness.

$$k = 2.0 \quad lu = 4.02 \text{ m} \quad r = (\text{Inetia/Area})^{1/2}$$

Y Direction

$$r = 0.130 \text{ m} \quad klu/r = 61.892 > 22 \text{ Consider slenderness}$$

Z Direction

$$r = 0.130 \text{ m} \quad klu/r = 61.892 > 22 \text{ Consider slenderness}$$

Slenderness

$$M_c = \delta b M_b + \delta s M_s$$

$$\delta b = cm / (1 - P_u / \phi P_c) \quad cm = 1.0$$

$$P_c = \pi^2 EI / (klu)^2 \quad E = 2526713 \text{ ton/m}^2$$

$$P_u = \text{Axial Force} = 28.30 \text{ ton}$$

X Dir. :

Z Dir. :

$$\text{Inertia} = 0.0034 \text{ m}^2$$

$$\text{Inertia} = 0.0034 \text{ m}^2$$

$$P_c = 1318.30 \text{ ton}$$

$$P_c = 1318.30 \text{ ton}$$

$$\delta b = 1.023$$

$$\delta b = 1.024$$

$$M_u \text{ x-x} = 18.46 \text{ ton-m}$$

$$M_u \text{ z-z} = 22.36 \text{ ton-m}$$

<b>PROJECT:</b> Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
<b>SUBJECT:</b> Column design	Date	July-02	Page	34/61

- Design by flexure and Axial load

Z Direction :  $\phi = 0.70$

Gross Area (Ag) = 0.20 m<sup>2</sup> = 313.91 in<sup>2</sup>

h = 0.45 m = 17.72 in

P = 20.41 ton = 44.99 kips

M = 18.46 ton-m = 1601.90 kips-in

**Pu/Ag = 0.14      Mu/Agh = 0.29**

From the Load-Moment strength interaction diagram R4-60.90,  
the  $\rho$  value is:

$\rho =$   %  $As = Ag \times \rho = 22.28 \text{ cm}^2$

Bar denomination =  Bar area = 3.88 cm<sup>2</sup>

Quantity of bars = 5.74

**Use 6 N 7**

X Direction :  $\phi = 0.7$

Gross Area (Ag) = 0.20 m<sup>2</sup> = 313.91 in<sup>2</sup>

h = 0.45 m = 17.72 in

P = 21.89 ton = 48.25 kips

M = 22.36 ton = 1941.17 kips-in

**Pu/Ag = 0.15      Mu/Agh = 0.35**

From the Load-Moment strength interaction diagram R4-60.90,  
the  $\rho$  value is:


$\rho =$   %  $As = Ag \times \rho = 28.35 \text{ cm}^2$

Bar Denomination =  Bar area = 3.88 cm<sup>2</sup>

Quantity of bars = 7.31

**Use 8 N 7**

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
SUBJECT: Column design	Date	July-02	Page 35/61



**SHEAR DESIGN.**

X Direction :

$b_w = 450.00 \text{ mm}$

$d = 388.89 \text{ mm}$

$f_y = 4200 \text{ kg/cm}^2$   
411.90 Mpa

$f'_c = 280 \text{ kg/cm}^2$   
27.46 Mpa

Shear Strength provided by concrete.

$V_c = (\sqrt{f'_c} / 6) b_w d$

$V_c = 152,839.5 \text{ Newton}$   
15,584.7 kg

$V_c = (1 + N_u / 14 A_g) (\sqrt{f'_c} / 6) b_w$

$N_u = 20.41 \text{ ton}$   
200,118 Newton

$V_c = 163,628.1 \text{ Newton}$   
16,684.8 kg

$V_c = 15,584.73 \text{ kg}$

<b>PROJECT:</b> Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
<b>SUBJECT:</b> Column design	Date	Page	36 / 61

$$V_n = V_c + V_s \quad V_s = V_u/\phi - V_c \quad \phi = 0.85$$

$$V_u = 7.26 \text{ ton} \quad V_s = (7,042.4) \text{ kg}$$

$$V_s = A_v f_y d / s \quad ; \quad S_{req} = A_v f_y d / V_s$$

Bar denomination =

Bar area = 0.71 cm<sup>2</sup>

# of legs =

Spacing,  $S_{req} = -33.05 \text{ cm}$

Max. spacing of shear reinforcement.

$$\left. \begin{array}{l} d/2 = 19.44 \text{ cm} \\ 60 \text{ mm} = 60 \text{ cm} \end{array} \right\} S_2 = 19.44 \text{ cm}$$

$$(1/3) (\sqrt{f'_c} / 6) b_w d = 50946.49 \text{ Newton}$$

$$5,194.9 \text{ kg} > V_s, \text{ o.k.}$$

$S_2 = 19.44 \text{ cm}$

Minimum Shear Reinforcement

$$A_v = (1/3) b_w S / f_y$$

$$S_3 = 3 A_v f_y / b_w$$

$S_3 = 39.13 \text{ cm}$

**Use 2 legs of N 3 @ 19 cm**

<b>PROJECT:</b> Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
<b>SUBJECT:</b> Column design	Date	July-02	Page	37 / 61

Z Direction :

$b_w = 450.00 \text{ mm}$ 
 $f_y = 4200 \text{ kg/cm}^2$   
 $411.90 \text{ Mpa}$

$d = 388.89 \text{ mm}$ 
 $f'_c = 280.00 \text{ kg/cm}^2$   
 $27.46 \text{ Mpa}$

Shear Strenght provided by concrete.

$$V_c = (\sqrt{f'_c} / 6) b_w d$$

$V_c = 152,839.5 \text{ Newton}$   
 $15,584.7 \text{ kg}$

$$V_c = (1 + N_u / 14 A_g) (\sqrt{f'_c} / 6) b_w$$

$N_u = 21.89 \text{ ton}$   
 $214,656 \text{ Newton}$

$V_c = 164,411.9 \text{ Newton}$   
 $16,764.8 \text{ kg}$

}  $V_c = 15,584.73 \text{ kg}$

$V_n = V_c + V_s$ 
 $V_s = V_u / \phi - V_c$ 
 $\phi = 0.85$

$V_u = 9.33 \text{ ton}$ 
 $V_s = (4,610.3) \text{ kg}$

$V_s = A_v f_y d / s$ 
;
 $S_{req} = A_v f_y d / V_s$

Bar denomination = 
Bar area = 0.71 cm<sup>2</sup>

# of legs = 
Spacing,  $S_{req} = -50.49 \text{ cm}$

Max. spacing of shear reinforcement.

$d/2 = 19.44 \text{ cm}$ 
}  $S_2 = 19.44 \text{ cm}$

$60 \text{ mm} = 60 \text{ cm}$

$(1/3) (\sqrt{f'_c} / 6) b_w d = 50946.49 \text{ Newton}$   
 $5,194.9 \text{ kg} > V_s, \text{ o.k.}$

$S_2 = 19.44 \text{ cm}$

Minimun Shear Reinforcement


$A_v = (1/3) b_w S / f_y$ 
 $S_3 = 3 A_v f_y / b_w$ 
 $S_3 = 39.13 \text{ cm}$

**Use 2 legs of N 3 @ 19 cm**

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
SUBJECT: Foundation beam design	Date	Page	38 / 61

### FOUNDATION BEAM DESIGN (FB-1)

Outer End



H = 60.00 cm

b = 35.00 cm

f<sub>c</sub> = 280 kg/cm<sup>2</sup>

f<sub>y</sub> = 4200 kg/cm<sup>2</sup>

Forces and Moments, from Structural Analysis (ton , m) :

TYPE OF LOAD	MOMENT
	Mz-z
Dead Load	7.06
Live Load	6.12
Seismic Load x	0.10
Seismic Load z	11.85

COMBINATION	Mu z-z
C1	20.29
C2	15.36
C3	31.84

C1 = 1.4 DL + 1.7 LL

C2 = 0.75( 1.4DL + 1.7LL + 1.87SL<sub>y</sub>)

C3 = 0.75( 1.4DL + 1.7LL + 1.87SL<sub>z</sub>)

Force for design: Mu z-z = 31.84 ton-m

d = 52.62 cm

Clear cover = 5.00 cm

$f_y^2/1.7bf_c A_s^2 - f_y d A_s + Mu/\phi = 0$

$\phi = 0.90$

$1058.8A_s^2 - 220999 A_s + 3537291.7 = 0$

$A_s = 17.47 \text{ cm}^2$

As<sub>min</sub> = (4/3)As<sub>req</sub> :

$(4/3)As_{req} = 23.29 \text{ cm}^2$   
 $(14/f_y) b d = 6.14 \text{ cm}^2$

As<sub>min</sub> = 6.14 cm<sup>2</sup>

As<sub>max</sub> :  $\rho b = 0.0459$  As<sub>max</sub> (0.75ρb) = 63.47 cm<sup>2</sup>

As = 17.47 cm<sup>2</sup> o.k!! As < A<sub>max</sub>


Bar denomination, N = 7

Bar Area (A<sub>v</sub>) = 3.88 cm<sup>2</sup>

Number of bars = 4.50 Use 5 - N 7

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
SUBJECT: Foundation beam design	Date	July-02	Page 39 / 61

**FOUNDATION BEAM DESIGN (FB-1)**  
Center



H = 60.00 cm  
 b = 35.00 cm  
 $f_c = 280 \text{ kg/cm}^2$   
 $f_y = 4200 \text{ kg/cm}^2$

Forces and Moments, from Structural Analysis (ton , m) :

TYPE OF LOAD	MOMENT
	Mz-z
Dead Load	3.58
Live Load	3.06
Seismic Load x	0.60
Seismic Load z	1.50

COMBINATION	Mu z-z
C1	10.21
C2	8.50
C3	9.76

C1 = 1.4 DL + 1.7 LL  
 C2 = 0.75( 1.4DL + 1.7LL + 1.87SLy)  
 C3 = 0.75( 1.4DL + 1.7LL + 1.87SLz)

Force for design:  $Mu \text{ z-z} = 10.21 \text{ ton-m}$

$d = 52.78 \text{ cm}$                       Clear cover = 5.00 cm

$f_y^2/1.7bf_c As^2 - f_yd As + Mu/\phi = 0$                        $\phi = 0.90$

$1058.8As^2 - 221666 As + 1134888.9 = 0$                        $As = 5.25 \text{ cm}^2$

$As_{min} = (4/3)As_{req}$  :

$(4/3)As_{req} = 7.00 \text{ cm}^2$   
 $(14/f_y) b d = 6.16 \text{ cm}^2$                       }  $As_{min} = 6.16 \text{ cm}^2$

$As_{max} : \rho_b = 0.0459$                        $As_{max} (0.75\rho_b) = 63.66 \text{ cm}^2$

$As = 6.16 \text{ cm}^2$                       o.k!!  $As < A_{max}$

Bar denomination, N = 6                      Bar Area ( $A_v$ ) = 2.85 cm<sup>2</sup>

Number of bars = 2.16                      Use 3 - N 6



PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by R. Martinez
SECTION: Power Supply Station	Calc. Index No.		Checked by A.MORIOKA
SUBJECT: Foundation beam design	Date	July-02	Page 40 / 61

b) Shear Reinforcement

Base =  cm       $f_y = \frac{4200}{411.89}$  kg/cm<sup>2</sup>

d =  cm       $f_c = \frac{280}{27.46}$  Mpa

$V_c = (1/6) \sqrt{f_c} b_w d = 16.41$  ton

$V_n = V_c + V_s$        $V_s = V_u / \phi - V_c$        $\phi = 0.85$

TYPE OF LOAD	SHEAR $V_y$
--------------	-------------

Dead Load	6.05
Live Load	5.25
Seismic Load x	4.37
Seismic Load z	0.01

COMBINATION	$V_y$
C1	17.40
C2	19.18
C3	13.06

C1 = 1.4 DL + 1.7 LL  
 C2 = 0.75( 1.4DL + 1.7LL + 1.87SL<sub>y</sub>)  
 C3 = 0.75( 1.4DL + 1.7LL + 1.87SL<sub>z</sub>)

Force for design:       $V_u = \text{input } 19.18$  ton

$V_s = 6,153.0$  kg

Bar denomination =       Bar area = 0.71 cm<sup>2</sup>

# of legs =       Spacing,  $S_{req} = 51.19$  cm

Max. spacing of shear reinforcement.

$d/2 = 26.31$  cm }  
 $30 \text{ mm} = 30$  cm }  $S_2 = 26.31$  cm

$(1/3) \sqrt{f_c} b_w d = 102727$  Newton  
 104,744 kg >  $V_s$ , o.k.

$S_2 = 26.31$  cm

Minimum Shear Reinforcement


$A_v = (1/3) b_w S / f_y$        $S_3 = 3 A_v f_y / b_w$        $S_3 = 5031.4$  cm

**Use 2 legs of N 3 @ 26 cm**

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
SUBJECT: Foundation beam design	Date	July-02	Page 4 / 161

**FOUNDATION BEAM DESIGN (FB-2)**

Outer End



H = 60.00 cm  
 b = 30.00 cm  
 f<sub>c</sub> = 280 kg/cm<sup>2</sup>  
 f<sub>y</sub> = 4200 kg/cm<sup>2</sup>

Forces and Moments, from Structural Analysis (ton , m) :

TYPE OF LOAD	MOMENT
	Mz-z
Dead Load	4.97
Live Load	4.50
Seismic Load x	0.10
Seismic Load z	11.05

COMBINATION	Mu z-z
C1	14.61
C2	11.10
C3	26.45

C1 = 1.4 DL + 1.7 LL  
 C2 = 0.75( 1.4DL + 1.7LL + 1.87SL<sub>y</sub>)  
 C3 = 0.75( 1.4DL + 1.7LL + 1.87SL<sub>z</sub>)

Force for design: Mu z-z = 26.45 ton-m

d = 52.62 cm

Clear cover = 5.00 cm

$f_y^2/1.7b f_c A_s^2 - f_y d A_s + M_u/\phi = 0$        $\phi = 0.90$

$1235.3A_s^2 - 220999 A_s + 2939291.7 = 0$        $A_s = 14.47 \text{ cm}^2$

A<sub>smin</sub> = (4/3)A<sub>sreq</sub> :

$(4/3)A_{sreq} = 19.29 \text{ cm}^2$   
 $(14/f_y) b d = 5.26 \text{ cm}^2$

A<sub>smin</sub> = 5.26 cm<sup>2</sup>

A<sub>smax</sub> :  $\rho b = 0.0459$       A<sub>smax</sub> (0.75ρb) = 54.40 cm<sup>2</sup>

**A<sub>s</sub> = 14.47 cm<sup>2</sup>      o.k!! A<sub>s</sub> < A<sub>max</sub>**

Bar denomination, N = 7


Bar Area (A<sub>v</sub>) = 3.88 cm<sup>2</sup>

Number of bars = 3.73      Use 4 - N 7

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
SUBJECT: Foundation beam design	Date	Page	42 / 61

### FOUNDATION BEAM DESIGN (FB-2)

Center



H = 60.00 cm

b = 30.00 cm

f<sub>c</sub> = 280 kg/cm<sup>2</sup>

f<sub>y</sub> = 4200 kg/cm<sup>2</sup>

Forces and Moments, from Structural Analysis (ton , m) :

TYPE OF LOAD	MOMENT
	Mz-z
Dead Load	2.48
Live Load	2.26
Seismic Load x	1.40
Seismic Load z	0.10

COMBINATION	Mu z-z
C1	7.31
C2	7.45
C3	5.63

C1 = 1.4 DL + 1.7 LL

C2 = 0.75( 1.4DL + 1.7LL + 1.87SL<sub>y</sub>)

C3 = 0.75( 1.4DL + 1.7LL + 1.87SL<sub>z</sub>)

Force for design: Mu z-z = 7.45 ton-m

d = 52.62 cm

Clear cover = 5.00 cm

$f_y^2 / 1.7b^2 f_c A_s^2 - f_y d A_s + Mu / \phi = 0$        $\phi = 0.90$

$1235.3A_s^2 - 220999 A_s + 827666.67 = 0$        $A_s = 3.83 \text{ cm}^2$

As<sub>min</sub> = (4/3)As<sub>req</sub> :

$(4/3)A_{sreq} = 5.10 \text{ cm}^2$   
 $(14/f_y) b d = 5.26 \text{ cm}^2$

} As<sub>min</sub> = 5.10 cm<sup>2</sup>

As<sub>max</sub> :       $\rho_b = 0.0459$       As<sub>max</sub> (0.75ρ<sub>b</sub>) = 54.40 cm<sup>2</sup>

**As = 5.10 cm<sup>2</sup>      o.k!! As < Amax**

Bar denomination, N = 7

Bar Area (A<sub>v</sub>) = 3.88 cm<sup>2</sup>

Number of bars = 1.32      Use 2 - N 7

PROJECT: Detailed Design on Port Reactivation Project In La Union Province	Calc. File No.		Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
SUBJECT: Foundation beam design	Date	July-02	Page	43 / 61

b) Shear Reinforcement

Base =  cm       $f_y = \frac{4200}{411.89}$  kg/cm<sup>2</sup>

$d = \frac{52.62}{27.46}$  cm       $f_c = \frac{280}{27.46}$  Mpa

$V_c = (1/6) \sqrt{f_c} b o d = 14.06$  ton

$V_n = V_c + V_s$        $V_s = V_u / \phi - V_c$        $\phi = 0.85$

TYPE OF LOAD	SHEAR Vy
Dead Load	4.97
Live Load	4.50
Seismic Load x	0.05
Seismic Load z	4.79

COMBINATION	Vy
C1	14.61
C2	11.03
C3	17.67

C1 = 1.4 DL + 1.7 LL  
 C2 = 0.75( 1.4DL + 1.7LL + 1.87SLy)  
 C3 = 0.75( 1.4DL + 1.7LL + 1.87SLz)

Force for design:       $V_u = \frac{17.67}{}$  ton

$V_s = 6,730.6$  kg

Bar denomination =       Bar area = 0.71 cm<sup>2</sup>

# of legs =       Spacing,  $S_{req} = 46.79$  cm

Max. spacing of shear reinforcement.

$d/2 = 26.31$  cm }  
 $30 \text{ mm} = 30$  cm }  $S_2 = 26.31$  cm

$(1/3) (\sqrt{f_c} / 6) b w d = 880480.1$  Newton  
 89,781 kg >  $V_s$ , o.k.

$S_2 = 26.31$  cm

Minimun Shear Reinforcement


$A_v = (1/3) b w S / f_y$        $S_3 = 3 A_v f_y / b w$        $S_3 = 5870.0$  cm

Use 2 legs of N 3 @ 26 cm

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.		Checked by	AMORIOKA
SUBJECT: Beam design	Date	July-02	Page	44 / 161

### ROOF BEAM DESIGN (B-1)

Column End



H = 45.00 cm  
 b = 30.00 cm  
 $f_c = 280 \text{ kg/cm}^2$   
 $f_y = 4200 \text{ kg/cm}^2$

Forces and Moments, from Structural Analysis (ton , m) :

TYPE OF LOAD	MOMENT
	Mz-z
Dead Load	8.07
Live Load	1.29
Seismic Load x	0.05
Seismic Load z	5.04

COMBINATION	Mu z-z
C1	13.49
C2	10.19
C3	17.19

C1 = 1.4 DL + 1.7 LL  
 C2 = 0.75( 1.4DL + 1.7LL + 1.87SLy)  
 C3 = 0.75( 1.4DL + 1.7LL + 1.87SLz)

Force for design:  $Mu \text{ z-z} = 17.19 \text{ ton-m}$

$d = 37.62 \text{ cm}$

Clear cover = 5.00 cm

$$f_y^2 / 1.7 b f_c A_s^2 - f_y d A_s + M_u / \phi = 0$$

$$\phi = 0.90$$

$$1235.3 A_s^2 - 157999 A_s + 1909650 = 0$$

$$A_s = 13.51 \text{ cm}^2$$

$A_{smin} = (4/3) A_{sreq}$  :

$$\left. \begin{aligned} (4/3) A_{sreq} &= 18.02 \text{ cm}^2 \\ (14/f_y) b d &= 3.76 \text{ cm}^2 \end{aligned} \right\}$$

$$A_{smin} = 3.76 \text{ cm}^2$$

$$A_{smax} : \rho b = 0.0459$$

$$A_{smax} (0.75 \rho b) = 38.89 \text{ cm}^2$$

$$A_s = 13.51 \text{ cm}^2$$

**o.k!!  $A_s < A_{max}$**

Bar denomination, N = 7


Bar Area ( $A_v$ ) = 3.88 cm<sup>2</sup>

Number of bars = 3.48

**Use 4 - N 7**

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
SUBJECT: Beam design	Date	July-02	Page 45 / 61

**ROOF BEAM DESIGN (B-1)**  
Center (between B & C Axis)



H = 45.00 cm  
 b = 30.00 cm  
 f<sub>c</sub> = 280 kg/cm<sup>2</sup>  
 f<sub>y</sub> = 4200 kg/cm<sup>2</sup>

Forces and Moments, from Structural Analysis (ton , m) :

TYPE OF LOAD	MOMENT
	Mz-z
Dead Load	7.97
Live Load	1.06
Seismic Load x	0.14
Seismic Load z	0.58

COMBINATION	Mu z-z
C1	12.96
C2	9.92
C3	10.53

C1 = 1.4 DL + 1.7 LL  
 C2 = 0.75( 1.4DL + 1.7LL + 1.87SL<sub>y</sub>)  
 C3 = 0.75( 1.4DL + 1.7LL + 1.87SL<sub>z</sub>)

Force for design: Mu z-z = 12.96 ton-m

d = 37.62 cm

Clear cover = 5.00 cm

$f_y^2 / 1.7b f_c A_s^2 - f_y d A_s + Mu / \phi = 0$        $\phi = 0.90$

$1235.3A_s^2 - 157999 A_s + 1440000 = 0$        $A_s = 9.88 \text{ cm}^2$

$A_{smin} = (4/3)A_{sreq}$  :

$(4/3)A_{sreq} = 13.17 \text{ cm}^2$   
 $(14/f_y) b d = 3.76 \text{ cm}^2$  }       $A_{smin} = 3.76 \text{ cm}^2$

$A_{smax} : \rho b = 0.0459$        $A_{smax} (0.75\rho b) = 38.89 \text{ cm}^2$

$A_s = 9.88 \text{ cm}^2$       o.k!!  $A_s < A_{max}$

Bar denomination, N = 7

Bar Area (A<sub>v</sub>) = 3.38 cm<sup>2</sup>

Number of bars = 2.55      Use 3 - N 7

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
SUBJECT: Beam design	Date	July-02	Page	26 / 61

b) Shear Reinforcement

Base =  cm       $f_y = \frac{4200}{411.89}$  kg/cm<sup>2</sup>

d =  cm       $f_c = \frac{280}{27.46}$  Mpa

$V_c = (1/6) \sqrt{f_c} b o d = 10.05$  ton

$V_n = V_c + V_s$        $V_s = V_u / \phi - V_c$        $\phi = 0.85$

TYPE OF LOAD	SHEAR $V_y$
Dead Load	5.72
Live Load	0.98
Seismic Load x	0.10
Seismic Load z	1.22

COMBINATION	$V_y$
C1	9.67
C2	7.40
C3	8.97

C1 = 1.4 DL + 1.7 LL  
 C2 = 0.75( 1.4DL + 1.7LL + 1.87SLy)  
 C3 = 0.75( 1.4DL + 1.7LL + 1.87SLz)

Force for design:  $V_u = \frac{9.67}{}$  ton

$V_s = 1,327.6$  kg

Bar denomination =       Bar area = 0.71 cm<sup>2</sup>

# of legs =       Spacing,  $S_{req} = 169.61$  cm

Max. spacing of shear reinforcement.

$d/2 = 18.81$  cm }  
 $30 \text{ mm} = 30$  cm }  $S_2 = 18.81$  cm

$(1/3) (\sqrt{f_c} / 6) b_w d = 629482.1$  Newton  
 64,187 kg >  $V_s$ , o.k.

$S_2 = 18.81$  cm

Minimum Shear Reinforcement


$A_v = (1/3) b_w S / f_y$        $S_3 = 3 A_v f_y / b_w$        $S_3 = 5870.0$  cm

Use 2 legs of N 3 @ 18 cm

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
SUBJECT: Beam design	Date	July-02	Page 47 / 61

### ROOF BEAM DESIGN (B-2)

End



H = 40.00 cm

b = 30.00 cm

f<sub>c</sub> = 280 kg/cm<sup>2</sup>

f<sub>y</sub> = 4200 kg/cm<sup>2</sup>

Forces and Moments, from Structural Analysis (ton , m) :

TYPE OF LOAD	MOMENT
	Mz-z

Dead Load	7.39
Live Load	1.83
Seismic Load x	3.35
Seismic Load z	0.15

COMBINATION	Mu z-z
C1	13.46
C2	14.79
C3	10.30

C1 = 1.4 DL + 1.7 LL

C2 = 0.75( 1.4DL + 1.7LL + 1.87SL<sub>y</sub>)

C3 = 0.75( 1.4DL + 1.7LL + 1.87SL<sub>z</sub>)

Force for design: Mu z-z = 14.79 ton-m

d = 32.62 cm

Clear cover = 5.00 cm

$f_y^2/1.7bf_c A_s^2 - f_y d A_s + Mu/\phi = 0$        $\phi = 0.90$

$1235.3A_s^2 - 136999 A_s + 1643458.3 = 0$        $A_s = 13.68 \text{ cm}^2$

$A_{smin} = (4/3)A_{sreq}$  :

$(4/3)A_{sreq} = 18.25 \text{ cm}^2$   
 $(14/f_y) b d = 3.26 \text{ cm}^2$  }  $A_{smin} = 3.26 \text{ cm}^2$

$A_{smax} : \rho_b = 0.0459$        $A_{smax} (0.75\rho_b) = 33.72 \text{ cm}^2$

$A_s = 13.68 \text{ cm}^2$       o.k!!  $A_s < A_{max}$

Bar denomination, N = 7

Bar Area (A<sub>v</sub>) = 3.88 cm<sup>2</sup>


Number of bars = 3.53      Use 4 - N 7



PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
SUBJECT: Beam design	Date	July-02	Page	43 / 61

### ROOF BEAM DESIGN (B-2)

Center



H = 40.00 cm  
 b = 30.00 cm  
 $f_c = 280 \text{ kg/cm}^2$   
 $f_y = 4200 \text{ kg/cm}^2$

Forces and Moments, from Structural Analysis (ton , m) :

TYPE OF LOAD	MOMENT
	Mz-z
Dead Load	5.58
Live Load	1.39
Seismic Load x	0.08
Seismic Load z	0.27

COMBINATION	Mu z-z
C1	10.18
C2	7.74
C3	8.01

C1 = 1.4 DL + 1.7 LL  
 C2 = 0.75( 1.4DL + 1.7LL + 1.87SLy)  
 C3 = 0.75( 1.4DL + 1.7LL + 1.87SLz)

Force for design:  $Mu_{z-z} = 10.18 \text{ ton-m}$

$d = 32.62 \text{ cm}$

Clear cover = 5.00 cm

$$f_y^2 / 1.7b f_c A_s^2 - f_y d A_s + M_u / \phi = 0$$

$$\phi = 0.90$$

$$1235.3 A_s^2 - 136999 A_s + 1130555.6 = 0$$

$$A_s = 8.98 \text{ cm}^2$$

$A_{smin} = (4/3)A_{sreq}$  :

$$\left. \begin{aligned} (4/3)A_{sreq} &= 11.97 \text{ cm}^2 \\ (14/f_y) b d &= 3.26 \text{ cm}^2 \end{aligned} \right\}$$

$$A_{smin} = 3.26 \text{ cm}^2$$

$$A_{smax} : \rho b = 0.0459$$

$$A_{smax} (0.75\rho b) = 33.72 \text{ cm}^2$$

$$A_s = 8.98 \text{ cm}^2$$

**o.k!!  $A_s < A_{max}$**

Bar denomination, N = 7

Bar Area ( $A_v$ ) = 3.88 cm<sup>2</sup>

Number of bars = 2.31


**Use 3 - N 7**



PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
SUBJECT: Beam design	Date	July-02	Page 50 / 61

**ROOF BEAM DESIGN (B-3)**

End



H = 35.00 cm  
 b = 25.00 cm  
 f<sub>c</sub> = 280 kg/cm<sup>2</sup>  
 f<sub>y</sub> = 4200 kg/cm<sup>2</sup>

Forces and Moments, from Structural Analysis (ton , m) :

TYPE OF LOAD	MOMENT
	Mz-z
Dead Load	4.01
Live Load	0.57
Seismic Load x	0.78
Seismic Load z	0.10

COMBINATION	Mu z-z
C1	6.58
C2	6.03
C3	5.08

C1 = 1.4 DL + 1.7 LL  
 C2 = 0.75( 1.4DL + 1.7LL + 1.87SL<sub>y</sub>)  
 C3 = 0.75( 1.4DL + 1.7LL + 1.87SL<sub>z</sub>)

Force for design: Mu z-z = 6.58 ton-m

d = 27.78 cm

Clear cover = 5.00 cm

$$f_y^2/1.7bf_c A_s^2 - f_y d A_s + Mu/\phi = 0$$

φ = 0.90

$$1482.4A_s^2 - 116666 A_s + 731444.44 = 0$$

A<sub>s</sub> = 6.87 cm<sup>2</sup>

A<sub>smin</sub> = (4/3)A<sub>sreq</sub> :

$$\left. \begin{aligned} (4/3)A_{sreq} &= 9.16 \text{ cm}^2 \\ (14/f_y) b d &= 2.31 \text{ cm}^2 \end{aligned} \right\}$$

A<sub>smin</sub> = 2.31 cm<sup>2</sup>

A<sub>smax</sub> : ρ<sub>b</sub> = 0.0459      A<sub>smax</sub> (0.75ρ<sub>b</sub>) = 23.93 cm<sup>2</sup>

A<sub>s</sub> = 6.87 cm<sup>2</sup>      o.k!! A<sub>s</sub> < A<sub>max</sub>

Bar denomination, N = 6


Bar Area (A<sub>v</sub>) = 2.85 cm<sup>2</sup>

Number of bars = 2.41

Use 3 - N 6

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
SUBJECT: Beam design	Date	July-02	Page 5 / 61

**ROOF BEAM DESIGN (B-3)**  
Center



H = 35.00 cm  
 b = 25.00 cm  
 $f_c = 280 \text{ kg/cm}^2$   
 $f_y = 4200 \text{ kg/cm}^2$

Forces and Moments, from Structural Analysis (ton , m) :

TYPE OF LOAD	MOMENT
	Mz-z
Dead Load	3.03
Live Load	0.62
Seismic Load x	0.36
Seismic Load z	0.03

COMBINATION	Mu z-z
C1	5.30
C2	4.48
C3	4.01

C1 = 1.4 DL + 1.7 LL  
 C2 = 0.75( 1.4DL + 1.7LL + 1.87SLy)  
 C3 = 0.75( 1.4DL + 1.7LL + 1.87SLz)

Force for design:  $Mu_{z-z} = 5.30 \text{ ton-m}$

$d = 27.94 \text{ cm}$

Clear cover = 5.00 cm

$f_y^2/1.7b^2f_c As^2 - f_yd As + Mu/\phi = 0 \quad \phi = 0.90$

$1482.4As^2 - 117332 As + 588444.44 = 0 \quad As = 5.38 \text{ cm}^2$

$As_{min} = (4/3)As_{req}$  :

$(4/3)As_{req} = 7.17 \text{ cm}^2$   
 $(14/f_y) b d = 2.33 \text{ cm}^2$  }  $As_{min} = 2.33 \text{ cm}^2$

$As_{max} : \rho_b = 0.0459 \quad As_{max} (0.75\rho_b) = 24.07 \text{ cm}^2$

$As = 5.38 \text{ cm}^2 \quad \text{o.k!! } As < As_{max}$

Bar denomination, N = 5

Bar Area ( $A_v$ ) = 1.98 cm<sup>2</sup>

Number of bars = 2.72      Use 3 - N 5

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
SUBJECT: Beam design	Date	July-02	Page 52 / 61

b) Shear Reinforcement

Base =  cm

$f_y =$  kg/cm<sup>2</sup>  
411.89

$d =$  cm

$f_c =$  kg/cm<sup>2</sup>  
27.46 Mpa

$V_c = (1/6) \sqrt{f_c} b o d = 6.29$  ton

$V_n = V_c + V_s$        $V_s = V_u / \phi - V_c$        $\phi = 0.85$

TYPE OF LOAD	SHEAR Vy
--------------	-------------

COMBINATION	Vy
C1	5.06
C2	4.14
C3	3.86

Dead Load	3.20
Live Load	0.34
Seismic Load x	0.25
Seismic Load z	0.05

C1 = 1.4 DL + 1.7 LL  
C2 = 0.75( 1.4DL + 1.7LL + 1.87SLy)  
C3 = 0.75( 1.4DL + 1.7LL + 1.87SLz)

Force for design:       $V_u =$  ton

$V_s = (341.8)$  kg

Bar denomination =

Bar area = 0.71 cm<sup>2</sup>

# of legs =

Spacing,  $S_{req} = -494.84$  cm

Max. spacing of shear reinforcement.

$d/2 = 14.13$  cm }  
30 mm = 30 cm }  $S_2 = 14.13$  cm

$(1/3) \sqrt{f_c / 6} b w d = 393979.7$  Newton  
40,173 kg >  $V_s$ , o.k.

$S_2 = 14.13$  cm

Minimum Shear Reinforcement

$A_v = (1/3) b w S / f_y$


$S_3 = 3 A_v f_y / b w$

$S_3 = 7044.0$  cm

**Use 2 legs of N 3 @ 14 cm**

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
SUBJECT: Beam design	Date	July-02	Page 53 / 61

### CANTILEVER BEAM DESIGN (CB-1)



H = 35.00 cm

$f_c = 280 \text{ kg/cm}^2$

b = 20.00 cm

$f_y = 4200 \text{ kg/cm}^2$

L = 1.00 m


Width = 7.00 m

Wd = 371.00 kg/m<sup>2</sup>

Wd = 2597.00 kg/m

Wl = 100.00 kg/m<sup>2</sup>

Wd = 700.00 kg/m



Additional load, Pd = 1612.8 kg  
(from edge beam)

Forces and Moments, from Structural Analysis (ton , m) :

TYPE OF LOAD	MOMENT
	Mz-z
Dead Load	3.00
Live Load	0.35

Force for design:

$M_u \text{ z-z} = 4.79 \text{ ton-m}$

$C1 = 1.4 \text{ DL} + 1.7 \text{ LL}$

d = 27.78 cm

Clear cover = 5.00 cm

$f_y^2 / 1.7 b f_c A_s^2 - f_y d A_s + M_u / \phi = 0$

$\phi = 0.90$

$1852.9 A_s^2 - 116666 A_s + 532046.67 = 0$

$A_s = 4.95 \text{ cm}^2$

$A_{smin} = (4/3) A_{sreq}$

$(4/3) A_{sreq} = 6.60 \text{ cm}^2$   
 $(14/f_y) b d = 1.85 \text{ cm}^2$

$A_{smin} = 1.85 \text{ cm}^2$

$A_{smax} : \rho_b = 0.0459$

$A_{smax} (0.75 \rho_b) = 19.15 \text{ cm}^2$

$A_s = 4.95 \text{ cm}^2$

**o.k!!  $A_s < A_{max}$**

Bar denomination, N = 6

Bar Area ( $A_v$ ) = 2.85 cm<sup>2</sup>


Number of bars = 1.74

**Use 2 - N 6**



PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
SUBJECT: Beam design	Date	Page	55 / 61

EDGE BEAM DESIGN (B-4)



H = 60.00 cm

$f_c = 280 \text{ kg/cm}^2$

b = 20.00 cm

$f_y = 4200 \text{ kg/cm}^2$

Forces and Moments, from Structural Analysis (ton , m) :

TYPE OF LOAD	MOMENT
	Mz-z
Dead Load	1.41
Live Load	0.10

Force for design:

$Mu_{z-z} = 2.15 \text{ ton-m}$   
 $C1 = 1.4 \text{ DL} + 1.7 \text{ LL}$

d = 52.94 cm

Clear cover = 5.00 cm

$f_y^2 / 1.7 b f_c A_s^2 - f_y d A_s + M_u / \phi = 0$

$\phi = 0.90$

$1852.9 A_s^2 - 222332 A_s + 238408.89 = 0$

$A_s = 1.08 \text{ cm}^2$

$A_{smin} = (4/3) A_{sreq}$  :

$(4/3) A_{sreq} = 1.44 \text{ cm}^2$   
 $(14/f_y) b d = 3.53 \text{ cm}^2$

$A_{smin} = 3.53 \text{ cm}^2$

$A_{smax} : \rho_b = 0.0459 \quad A_{smax} (0.75 \rho_b) = 36.49 \text{ cm}^2$

$A_s = 3.53 \text{ cm}^2 \quad \text{o.k!! } A_s < A_{max}$

Bar denomination, N = 5

Bar Area ( $A_v$ ) = 1.98  $\text{cm}^2$

Number of bars = 1.78


Use 2 - N 5





PROJECT: Detailed Design on Port Reactivation Project in La Union Provin	Calc. File No.	Prepared by	H.WATANABE
SECTION: Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
SUBJECT: Slab design	Date	July-02	Page 59 / 61

Slab S2 for roof



$lx = 3.5$  m

$ly = 4.5$  m

$ly/lx = 1.3$

$t = 12$  cm

coefficient of bend (thioretical result fix end)

$d = 7.35$ cm	$Mx1/(w lx^2) = 0.070$	
$fc = 280$ kg/cm <sup>2</sup>	$Mx2/(w lx^2) = 0.040$	
$fy = 4200$ kg/cm <sup>2</sup>	$My1/(w ly^2) = 0.056$	
	$My2/(w ly^2) = 0.028$	

$wDL = 0.443$  t/m<sup>2</sup>  
 $wLL = 0.020$  t/m<sup>2</sup>

DL	LL
$Mx1 = 0.38$ tm/m	$Mx1 = 0.02$ tm/m
$Mx2 = 0.22$ tm/m	$Mx2 = 0.01$ tm/m
$My1 = 0.30$ tm/m	$My1 = 0.01$ tm/m
$My2 = 0.15$ tm/m	$My2 = 0.01$ tm/m

$1.4DL + 1.7LL$	$fy/1.7bfc'$	$fyd$	$Mu/f$	
$Mx1 = 0.56$ tm/m	370.6	30870	62331 As=	2.07 cm <sup>2</sup> /m
$Mx2 = 0.32$ tm/m	370.6	30870	35618 As=	1.17 cm <sup>2</sup> /m
$My1 = 0.45$ tm/m	370.6	30870	49865 As=	1.65 cm <sup>2</sup> /m
$My2 = 0.22$ tm/m	370.6	30870	24932 As=	0.82 cm <sup>2</sup> /m

	Short Span			Long Span		
	Use Ba	Area cm <sup>2</sup>	Pitch cm	Use Bar	Area cm <sup>2</sup>	Pitch cm
End	3	0.71	34.4	3	0.71	43.2
Center	3	0.71	60.9	3	0.71	87.4

Thickne (mm)	Location	Shorter Side (Direction)				Longer Side (Direction)			
		Edge Strip		Middle Strip		Edge Strip		Middle Strip	
		End	Center	End	Center	End	Center	End	Center
S2 120	Top	D10-@200		-		D10-@250		-	
	Bottom	D10-@200				D10-@250			

PROJECT: Detailed Design on Port Reactivation Project in La Union Provin	Calc. File No.	Prepared by	H.WATANABE
SECTION: Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
SUBJECT: Slab design	Date	July-02	Page 58 / 61

**Slab S1** for 1st floor

lx = 3.5 m

ly = 4.5 m

ly/lx = 1.3

t = 15 cm

coefficient of bend (thioretical result fix end)

d = 10.35 cm	$Mx1/(w lx^2) =$	$0.070$	
fc = 210 kg/cm <sup>2</sup>	$Mx2/(w lx^2) =$	0.040	
fy = 4200 kg/cm <sup>2</sup>	$My1/(w lx^2) =$	0.056	
	$My2/(w lx^2) =$	0.028	

	$wDL =$	$0.450$ t/m <sup>2</sup>	
	$wLL =$	0.500 t/m <sup>2</sup>	

<b>DL</b>		<b>LL</b>	
Mx1 = 0.39 tm/m		Mx1 = 0.43 tm/m	
Mx2 = 0.22 tm/m		Mx2 = 0.25 tm/m	
My1 = 0.31 tm/m		My1 = 0.34 tm/m	
My2 = 0.15 tm/m		My2 = 0.17 tm/m	

	<b>1.4DL+1.7LL</b>		$fy2/1.7bfc'$		$fyd$		$Mu/f$	
Mx1 =	1.27 tm/m		494.1		43470		141011 As =	3.37 cm <sup>2</sup> /m
Mx2 =	0.73 tm/m		494.1		43470		80578 As =	1.89 cm <sup>2</sup> /m
My1 =	1.02 tm/m		494.1		43470		112809 As =	2.68 cm <sup>2</sup> /m
My2 =	0.51 tm/m		494.1		43470		56404 As =	1.32 cm <sup>2</sup> /m



	Short Span			Long Span		
	Use Ba	Area cm <sup>2</sup>	Pitch cm	Use Bar	Area cm <sup>2</sup>	Pitch cm
End	3.4	0.99	29.3	3.4	0.99	37.0
Center	3	0.71	37.6	3	0.71	54.1

Thickne (mm)	Location	Shorter Side (Direction)				Longer Side (Direction)			
		Edge Strip		Middle Strip		Edge Strip		Middle Strip	
		End	Center	End	Center	End	Center	End	Center
S1 150	Top	D10,D13-@200				-			
	Bottom	D10-@200				D10-@250			

PROJECT: Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.	Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
SUBJECT: Outside electric equipment foundation design	Date	July-02	Page 57 / 61

FOUNDATION DESIGN

a) Transformer foundation



Foundation Weight = 5.76 ton


Area of contact = 6.00 m<sup>2</sup>

Generator Weight = 15.00 ton

Soil Pressure = 3.46 ton/m<sup>2</sup>


Total weight = 20.76 ton

Provide a 3.50 ton/m<sup>2</sup> underneath foundation



<b>PROJECT:</b> Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R.Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
<b>SUBJECT:</b> Outside electric equipment foundation design	Date	July-02	Page	60 / 61

Reinforcement



$d = 0.50 \text{ m}$

Pressure =  $3.46 \text{ ton/m}^2$

$M = 0.433 \text{ ton-m}$

$H = 15.00 \text{ cm}$

$f_c = 210 \text{ kg/cm}^2$

$b = 100.00 \text{ cm}$

$f_y = 4200 \text{ kg/cm}^2$

Force for design:  $M_u = 1.3 \times M = 0.56 \text{ ton-m}$

$d = 7.94 \text{ cm}$

Clear cover =  $5.00 \text{ cm}$

$f_y^2 / 1.7 b f_c A_s^2 - f_y d A_s + M_u / \phi = 0$        $\phi = 0.90$

$494.1 A_s^2 - 33332 A_s + 62472.222 = 0$        $A_s = 1.93 \text{ cm}^2$

$A_{smin} = (4/3) A_{sreq}$ :

$(4/3) A_{sreq} = 2.57 \text{ cm}^2$	}	$A_{smin} = 2.65 \text{ cm}^2$
$(14/f_y) b d = 2.65 \text{ cm}^2$		

$A_{smax}$ :       $\rho_b = 0.0345$        $A_{smax} (0.75 \rho_b) = 20.51 \text{ cm}^2$

$A_s = 2.65 \text{ cm}^2$       o.k!  $A_s < A_{max}$

Bar denomination,  $N = 5$

Bar Area ( $A_v$ ) =  $1.98 \text{ cm}^2$

Number of bars =  $1.34$       Use 2 - N 5      N5 @ 25 cm

- Shrinkage and temperature reinforcement, ACI 7.12.

$d = 53.73 \text{ cm}$

Clear cover =  $5.00 \text{ cm}$

Minimum Gross area ratio =  $0.180\%$       Total area of steel =  $18 \text{ cm}^2$

Area by layer =  $A_s / 2 = 9 \text{ cm}^2$

Bar denomination,  $N = 4$

Bar Area ( $A_v$ ) =  $1.27 \text{ cm}^2$

Number of bars =  $7.10$       Use 8 - N 4      Pitch =  $33.74 \text{ cm}$



PROJECT: Detailed Design on Port Reactivation Project In La Union Province	Calc. File No.	Prepared by	R.Martinez
SECTION: Power Supply Station	Calc. Index No.	Checked by	A.MORIOKA
SUBJECT: Outside electric equipment foundation design	Date	July-02	Page 6 / 61

Minimum spacing for ties, ACI 11.5.4.

$$\begin{array}{l}
 S1 = d/2 = 26.87 \text{ cm} \\
 S2 = 60.00 \text{ cm}
 \end{array}
 \left. \vphantom{\begin{array}{l} S1 \\ S2 \end{array}} \right\} \text{Use } S = 25.00 \text{ cm}$$

N 4 @ 25 cm

**b) Electric foundation type-A**



Foundation Weight = 1.54 ton



Area of contact = 1.00 m<sup>2</sup>

Equipment Weight = 1.50 ton

Soil Pressure = 3.04 ton/m<sup>2</sup>

Total weight = 3.04 ton

**c) Electric foundation type-B**



Foundation Weight = 1.91 ton

Area of contact = 1.00 m<sup>2</sup>


<b>PROJECT:</b> Detailed Design on Port Reactivation Project in La Union Province	Calc. File No.		Prepared by	R. Martinez
<b>SECTION:</b> Power Supply Station	Calc. Index No.		Checked by	A.MORIOKA
<b>SUBJECT:</b> Outside electric equipment foundation design	Date	July-02	Page	6/A 161

Equipment Weight =  ton

Soil Pressure = 3.41 ton/m<sup>2</sup>


Total weight = 3.41 ton

**d) Electric foundation type-C**



Foundation Weight = 3.16 ton

Area of contact = 1.85 m<sup>2</sup>




Equipment Weight =  ton

Soil Pressure = 3.33 ton/m<sup>2</sup>


Total weight = 6.16 ton

**e) Electric foundation type-D**



Foundation Weight = 0.38 ton

Area of contact = 0.36 m<sup>2</sup>



Equipment Weight =  ton

Soil Pressure = 2.16 ton/m<sup>2</sup>

Total weight = 0.78 ton

