

MINISTRY OF INDUSTRY AND HANDICRAFTS  
ELECTRICITE DU LAOS

**THE STUDY  
ON  
MASTER PLAN  
OF  
TRANSMISSION LINE AND SUBSTATION SYSTEM  
IN  
LAO PEOPLE'S DEMOCRATIC REPUBLIC**

**FINAL REPORT  
(MAIN REPORT)**

SEPTEMBER 2002

JAPAN INTERNATIONAL COOPERATION AGENCY

NIPPON KOEI CO., LTD.  
TOKYO ELECTRIC POWER COMPANY

M P N

J R

02-146

## PREFACE

In response to a request from the Government of Lao People's Democratic Republic, the Government of Japan decided to conduct the Study on Master Plan of Transmission and Substation System in Lao P.D.R. and entrusted the study to the Japan International Cooperation Agency (JICA).

JICA sent a study team headed by Mr. Ko NAKAJIMA of Nippon Koei Co., Ltd. organized by Nippon Koei Co., Ltd. and Tokyo Electric Power Company to Lao P.D.R. six times from March 2001 to September 2002.

The team held discussions with the officials concerned of the Government of Lao P.D.R., and conducted related field surveys. After returning to Japan, the team conducted further studies and compiled the final results in this report.

I hope this report will contribute to the improvement of the situation of electricity supply in Lao P.D.R. and to enhancement of friendly relations between our two countries.

I wish to express my sincere appreciation to the officials concerned of the Government of Lao P.D.R. for their close cooperation throughout the study.

September 2002



---

Takao KAWAKAMI

President

Japan International Cooperation Agency

September 2002

Mr. Takaaki Kawakami  
President  
Japan International Cooperation Agency  
Tokyo, Japan

Dear Mr. Kawakami,

### **Letter of Transmittal**


We are pleased to submit you the final report on the Study on Master Plan of Transmission and Substation System in Lao People's Democratic Republic.

This study was conducted by the joint venture of Nippon Koei Co., Ltd. and Tokyo Electric Power Company under a contract to JICA, during the period from March 2001 to September 2002. In conducting the study, we have formulated the Master Plan for the optimum transmission and substation system in Lao P.D.R. up to 2020.

We wish to take this opportunity to express our sincere gratitude to the officials concerned of JICA, the Ministry of Foreign Affairs and the Ministry of Economy, Trade and Industry. We would also like to express our gratitude to the officials concerned of the Ministry of Industry and Handicrafts, the Electricite du Laos and Embassy of Japan in Lao P.D.R. for their cooperation and assistance throughout our field survey.

Finally, we hope that this report will contribute to further promotion of the project.

Very truly yours,



---

Ko NAKAJIMA  
Team Leader

The Study on Master Plan of Transmission and  
Substation System in Lao P.D.R

Nippon Koei Co., Ltd.

**THE STUDY ON MASTER PLAN  
OF  
TRANSMISSION LINE AND SUBSTATION SYSTEM  
IN  
LAO PEOPLE'S DEMOCRATIC REPUBLIC**

**FINAL REPORT**

**(Main Report)**

**CONTENTS**

**Executive Summary**

***Part - I Master Plan***

**Chapter 1 Introduction**

1.1	Background of the Study.....	I - 1
1.2	Objective and Scope of the Study .....	I - 2
1.2.1	Objective of the Study .....	I - 2
1.2.2	Scope of the Study .....	I - 2
1.2.3	Study Area .....	I - 3
1.3	Approach and Methodology of the Study .....	I - 4
1.3.1	Investigation Stage.....	I - 4
1.3.2	System Planning Stage .....	I - 5
1.3.3	Master Plan Study Stage .....	I - 6
1.4	The Study Team and Counterpart Staffs .....	I - 8
1.5	Schedule and Progress of the Study.....	I - 9
1.6	Provision of Equipment.....	I - 9
1.7	Transfer of Knowledge and Technology.....	I - 10

**Chapter 2 Lao People's Democratic Republic**

2.1	Profile of the Country.....	II - 1
2.1.1	Geography and Population.....	II - 1
2.1.2	Climate, Flora and Fauna.....	II - 2
2.1.3	Administrative Structure .....	II - 3
2.2	Social and Economic Conditions.....	II - 4
2.2.1	Overall Social Conditions .....	II - 4
2.2.2	Overall Economic Conditions .....	II - 5
2.2.3	National Budget.....	II - 7
2.2.4	Balance of Payment .....	II - 9
2.2.5	External Debt .....	II - 10
2.2.6	Trade .....	II - 10
2.2.7	Foreign Investment and Assistance .....	II - 11
2.2.8	Infrastructure.....	II - 11
2.2.9	National Economic Policy and Plans .....	II - 13
2.3	Outline of Energy Sector.....	II - 18

2.3.1	Energy Policy .....	II - 18
2.3.2	Indigenous Energy Resources .....	II - 19
2.3.3	Demand and Supply of Energy .....	II - 21

### **Chapter 3 Current Situation of Power Sector**

3.1	Overview .....	III - 1
3.1.1	General .....	III - 1
3.1.2	Electrification of the Country.....	III - 2
3.1.3	Administration of Power Sector .....	III - 2
3.2	Organizations and Functions of Institutions.....	III - 3
3.2.1	Ministry of Industry and Handicraft (MIH).....	III - 3
3.2.2	Electricite du Laos (EDL).....	III - 4
3.2.3	Department of Investment Promotion (DIP) .....	III - 5
3.2.4	Committee for Planning and Cooperation (CPC).....	III - 5
3.2.5	Science, Technology and Environment Agency (STEA) .....	III - 6
3.2.6	Lao National Committee for Energy (LNCE) .....	III - 6
3.2.7	Provincial and District Authorities .....	III - 6
3.2.8	Private Sector Participation to Power Development Activities .....	III - 6
3.2.9	Power Sector Construction Company .....	III - 6
3.3	Existing Power Facilities .....	III - 7
3.3.1	Generation Facilities including IPP .....	III - 7
3.3.2	Transmission Line and Substation Facilities .....	III - 8
3.3.3	Distribution Facilities .....	III - 9
3.3.4	International Connecting Lines .....	III - 10
3.3.5	Communications Facilities in Power Sector .....	III - 11
3.3.6	Load Dispatching Center .....	III - 11
3.4	Historical Electricity Demand and Supply .....	III - 12
3.4.1	Past Energy Consumption Record.....	III - 12
3.4.2	Past Record of Peak Load.....	III - 13
3.4.3	Energy Consumption by Consumer Type.....	III - 14
3.4.4	Gross Generation in Lao PDR .....	III - 15
3.5	Electricity Law .....	III - 17
3.6	Power Sector Policy Statement .....	III - 18
3.6.1	Specific Objectives .....	III - 18
3.6.2	Policy Implementation Plan .....	III - 19
3.7	Electricity Standards .....	III - 19
3.8	Power Tariff System.....	III - 20
3.8.1	Domestic Power Tariff System .....	III - 20
3.8.2	EDL's Export and Import Tariffs .....	III - 21
3.8.3	IPP Tariffs for Export to EGAT and EDL .....	III - 22
3.9	O & M of Transmission System.....	III - 23
3.9.1	Present O & M Organization of EDL .....	III - 23
3.9.2	Present O & M Manuals for Power Facilities .....	III - 25
3.9.3	Education and Training of EDL Employees .....	III - 25
3.9.4	Costs of O & M of Transmission System.....	III - 26
3.9.5	Issues of O & M for Transmission Lines and Substations .....	III - 26
3.10	Environmental Law and Legislation.....	III - 27

3.10.1 Present Situation .....	III - 27
3.10.2 Major Articles of the Law .....	III - 27
3.11 Existing Expansion Plan of Power System .....	III - 30
3.11.1 Generating Facilities.....	III - 30
3.11.2 Domestic Transmission Grids.....	III - 30
3.11.3 Transmission Systems for Power Exports .....	III - 31
3.11.4 Current Plan of 500 kV Power System in Lao PDR .....	III - 32
3.11.5 Export Plan to Thailand and Vietnam by 500 kV Lines .....	III - 35
3.11.6 Lao National Grid Company (LNGC) .....	III - 36
3.11.7 On-going Electrification Project .....	III - 37
3.11.8 ADB Study for the Northern Area Rural Power Distribution Project (TA).....	III - 38
3.12 Foreign Assistance to Power Sector .....	III - 38
3.12.1 Recent External Assistance .....	III - 38
3.12.2 New Projects expected for Immediate Future .....	III - 39
3.13 Financial Situation of EDL .....	III - 39

#### **Chapter 4 Generation Development Plan**

4.1 Generation Development Plan .....	IV - 1
4.1.1 Overview .....	IV - 1
4.1.2 Plans for Export Purpose.....	IV - 2
4.1.3 Plans for Domestic Purpose .....	IV - 4
4.1.4 Off-Grid Systems .....	IV - 5
4.2 Development Plan for the Study.....	IV - 8

#### **Chapter 5 Electricity Demand Forecast**

5.1 Existing Power Demand Forecast .....	V - 1
5.2 Methodology of Team's Demand Forecast.....	V - 3
5.3 Socio-Economy and Demography.....	V - 4
5.4 Electricity Demand Forecast by the Team .....	V - 6
5.4.1 Demographic Analysis.....	V - 6
5.4.2 Forecast of Residential Demand.....	V - 7
5.4.3 Demand Forecast for Industry and Commercial & Service Sector .....	V - 10
5.4.4 Demand Forecast for Agriculture Sector .....	V - 14
5.4.5 Electricity Demand for Particular Projects .....	V - 15
5.4.6 System Loss .....	V - 15
5.4.7 Peak Power Demand.....	V - 16
5.4.8 Result of Electricity Demand Forecast (Base Case) .....	V - 16
5.4.9 Electricity Demand Forecast in High and Low Scenarios.....	V - 17
5.5 Electricity Demand Forecast for EDL's Power Supply System .....	V - 19
5.5.1 Energy and Peak Demand by Substation.....	V - 19
5.5.2 Energy and Peak Demand for EDL's Transmission Network.....	V - 19
5.6 Demand - Supply Balance .....	V - 20

#### **Chapter 6 Formulation of the Optimum Transmission System**

6.1 Methodology of Formulation .....	VI - 1
6.2 Principles for Formulation of Expansion Plan .....	VI - 2
6.2.1 Conditions for Formulation of Expansion Plan .....	VI - 2
6.2.2 Major Demand Areas.....	VI - 3

6.2.3	Power Source to Demand Areas .....	VI - 5
6.2.4	Basic Technical Criteria and Conditions for the Study.....	VI - 5
6.2.5	Environmental Consideration.....	VI - 6
6.3	Criteria for Selection of the Optimum Systems.....	VI - 7
6.4	Current System and Expansion Plan.....	VI - 8
6.4.1	Current Transmission System.....	VI - 8
6.4.2	Current Expansion Plan.....	VI - 9
6.5	Prospective Substations.....	VI - 11
6.5.1	Selection Criteria.....	VI - 11
6.5.2	Prospective Substations in the Northern Region.....	VI - 12
6.5.3	Prospective Substations in the Central 1 Region.....	VI - 13
6.5.4	Prospective Substations in the Central 2 Region.....	VI - 14
6.5.5	Prospective Substations in the Southern Region.....	VI - 14
6.6	Prospective Transmission Lines.....	VI - 15
6.6.1	Prospective Lines.....	VI - 15
6.6.2	Alternative Transmission Systems.....	VI - 15
6.6.3	Circumstances along Line Routes.....	VI - 21
6.7	Methodology of Analysis for the Optimum System .....	VI - 25
6.7.1	General.....	VI - 25
6.7.2	Tools for Analysis .....	VI - 27
6.7.3	Basic Particulars for Analysis .....	VI - 27
6.8	Optimum Development Plan (Base Plan).....	VI - 33
6.8.1	Selected Systems.....	VI - 33
6.8.2	Optimization of Selected System .....	VI - 36
6.8.3	Results of System Analysis.....	VI - 41
6.9	Case Study on System Operation .....	VI - 46
6.9.1	Coexistence of Import and Export.....	VI - 46
6.9.2	Example of System Operation for Base Plan in 2005.....	VI - 47
6.9.3	Example of System Operation for Base Plan in 2020.....	VI - 49
6.10	Case Study on Alternation of Generation Development Program .....	VI - 51
6.10.1	Alternation of Present Generation Development Program .....	VI - 51
6.10.2	Results of System Analysis.....	VI - 51

## **Chapter 7 Conceptual Design and Cost Estimate of the Projects**

7.1	Basic Design Criteria .....	VII - 1
7.1.1	National Standards and Regulations.....	VII - 1
7.1.2	Climatic Conditions .....	VII - 1
7.1.3	Design Particulars for Transmission Lines .....	VII - 3
7.1.4	Design Particulars for Substation Equipment .....	VII - 4
7.2	Preliminary Design of 115 kV Transmission Lines .....	VII - 5
7.2.1	Selection of Conductor and Ground-wire .....	VII - 6
7.2.2	Insulator Design.....	VII - 7
7.2.3	Ground Clearance.....	VII - 8
7.2.4	Tower Configuration .....	VII - 9
7.2.5	Preliminary Tower Design.....	VII - 10
7.2.6	Preliminary Design of Foundation.....	VII - 11
7.2.7	Standard Quantities of 115 kV Transmission Lines.....	VII - 12

7.3	Preliminary Design of Substations .....	VII - 13
7.3.1	Design Concept.....	VII - 13
7.3.2	Busbar Arrangement .....	VII - 15
7.3.3	Main Transformers .....	VII - 16
7.3.4	Switchgear and other Equipment .....	VII - 17
7.4	Reinforcement Plan for Transmission and Substation System .....	VII - 19
7.4.1	Sub-projects for Transmission Line.....	VII - 19
7.4.2	Sub-projects for Substation .....	VII - 21
7.5	Cost Estimate of Projects.....	VII - 26
7.5.1	Cost Estimate of Transmission Lines.....	VII - 26
7.5.2	Cost Estimate of Substation .....	VII - 29
7.5.3	Total Construction Cost for Optimum Transmission System.....	VII - 31
7.6	Implementation Schedule and Cost Disbursement Schedule .....	VII - 31
7.6.1	Implementation Schedule .....	VII - 31
7.6.2	Disbursement Schedule of the Project Costs.....	VII - 32
7.7	Economic Analysis of the Optimum System .....	VII - 34
7.7.1	Premises.....	VII - 34
7.7.2	Benefits.....	VII - 35
7.7.3	Economic Costs .....	VII - 36
7.7.4	Results of Evaluation.....	VII - 36
7.7.5	Financial Analysis of the Project .....	VII - 37
7.8	Recommendation on Dispersed Power Supply.....	VII - 37

## **Chapter 8 Selection of the Highest Priority Project**

8.1	Candidates for the Highest Priority Project .....	VIII - 1
8.2	Selection Criteria for the Highest Priority Project .....	VIII - 2
8.3	Evaluation Method.....	VIII - 3
8.4	Results of Evaluation .....	VIII - 4
8.4.1	Specific Information of Subproject to Each Evaluation Item.....	VIII - 4
8.4.2	Summary of Evaluation and the Selected Highest Priority Project .....	VIII - 8
8.5	Effect of the Highest Priority Project.....	VIII - 9

## **Chapter 9 Conclusion and Recommendation**

9.1	Conclusion .....	IX - 1
9.1.1	Optimum Transmission Systems.....	IX - 1
9.1.2	The Highest Priority Project.....	IX - 3
9.2	Recommendation .....	IX - 4
9.2.1	Updating of the Formulated Master Plan.....	IX - 4
9.2.2	New Organization for Operation and Maintenance .....	IX - 5
9.2.3	Electrification in the Off-grid Areas.....	IX - 6
9.2.4	Optimum Operation of the Comprehensive Power System of EDL .....	IX - 6
9.2.5	Establishment of the Central Load Dispatching Center .....	IX - 7
9.2.6	Examination on the Reservoir Operation.....	IX - 7
9.2.7	Energy from IPP Plants .....	IX - 8



## Tables in Part I

Table 1.2-1	Study Stage .....	I - 3
Table 1.4-1	The Study Team and Counterpart Staffs.....	I - 8
Table 1.5-1	Towns Visited .....	I - 9
Table 1.6-1	Equipment List.....	I - 9
Table 2.1-1	Country Summary.....	II - 1
Table 2.1-2	Records of Weather (1976-1999).....	II - 2
Table 2.1-3	Power Region .....	II - 3
Table 2.2-1	Structure of the Economy in 1989 and 1998.....	II - 5
Table 2.2-2	GDP Growth, Inflation and Current Account Deficit.....	II - 6
Table 2.2-3	Economic Growth Indicators .....	II - 6
Table 2.2-4	Average Exchange Rate from 1990 to 2001 .....	II - 7
Table 2.2-5	General Government Budget, 1996 - 99.....	II - 7
Table 2.2-6	Basic Hypothesis for the 5 Year Plan (GDP Growth & Public Investment Plan) .....	II - 8
Table 2.2-7	Public Sector Expenditure (Actual and Projected).....	II - 8
Table 2.2-8	Macro Economic Indicator (Actual & Planned) .....	II - 9
Table 2.2-9	Balance of Payments .....	II - 9
Table 2.2-10	External Debt and Resource Flows .....	II - 10
Table 2.2-11	Trade .....	II - 10
Table 2.2-12	Foreign Direct Investment and Donor Assistance.....	II - 11
Table 2.3-1	Hydraulic Power Potential.....	II - 19
Table 2.3-2	Historical Commercial Energy Consumption .....	II - 21
Table 3.1-1	Electrification Rates .....	III - 2
Table 3.3-1	Existing Power Plants .....	III - 7
Table 3.3-2	Existing 115/22 kV Substations (as of July 2002) .....	III - 9
Table 3.3-3	Existing Distribution Facilities .....	III - 10
Table 3.3-4	Inter-connection Lines .....	III - 11
Table 3.4-1	Energy and Peak Demand for the Year 1990 – 2000 (1) ~ (5)	
Table 3.4-2	Summary of Energy Consumption and Peak Load .....	III - 13
Table 3.4-3	Energy Consumption by Category for 1991 - 2000	
Table 3.4-4	Shares of Energy Consumption by Category for whole Country.....	III - 15
Table 3.4-5	Number of Customer by Category .....	III - 15
Table 3.4-6	Statistics of Historical Generation in Laos by Power Station	
Table 3.4-7	Statistics of Import Energy for 1975 - 2000	
Table 3.4-8	Statistics of Export Energy by Power Sources 1971 - 2000	
Table 3.4-9	Energy Balance for Whole Country	
Table 3.8-1	Historical EDL's Power Tariffs .....	III - 21
Table 3.8-2	New Power Tariffs (Effective on May 2002) .....	III - 21
Table 3.8-3	Trading Tariffs for Export and Import.....	III - 22
Table 3.8-4	Other Import Tariffs.....	III - 22
Table 3.8-5	Historical Tariff (Theun Hinboun IPP).....	III - 23
Table 3.8-6	Historical Tariff (Houay Ho IPP).....	III - 23
Table 3.11-1	National Transmission Grid Development Plan .....	III - 31
Table 3.11-2	Planned Transmission Lines for Exports .....	III - 32
Table 3.11-3	IPP Export to Vietnam.....	III - 36
Table 3.12-1	Loans to Power Sector .....	III - 38

Table 3.13-1	Brief Compiled EDL Income Statement .....	III - 41
Table 3.13-2	EDL Operation Indicators .....	III - 41
Table 3.13-3	EDL Balance Sheet .....	III - 42
Table 4.1-1	MOSES Ranking of Export Scheme.....	IV - 3
Table 4.1-2	MOSES Ranking of Domestic Supply Scheme by HDSS .....	IV - 4
Table 4.1-3	Present Level of Off-Grid Supplies .....	IV - 6
Table 4.1-4	List of Existing Small/Micro Hydropower Plants	
Table 4.1-5	Small/Micro Hydropower Development Plans .....	IV - 7
Table 4.1-6	List of Existing Diesel Generation Plants	
Table 4.2-1	Domestic Generation Development Projects Prepared by EDL.....	IV - 9
Table 4.2-2	IPP Generation Development Program Estimated by EDL .....	IV - 9
Table 5.1-1	EDL's Electricity Demand Forecast	
Table 5.1-2	Summary of Power Demand Forecast by EDL.....	V - 2
Table 5.1-3	Base Case Domestic Load Forecast by PSSS.....	V - 2
Table 5.1-4	High Domestic Load Forecast by PSSS.....	V - 3
Table 5.1-5	Demand Forecast by HDSS .....	V - 3
Table 5.3-1	Gross Domestic Products by Sector at Constant Price 1990.....	V - 4
Table 5.3-2	Shares of GDP by Sector .....	V - 5
Table 5.3-3	Summary of Population Census 1995 .....	V - 5
Table 5.3-4	District-wise Population and Households	
Table 5.3-5	Population Projection (Whole country) .....	V - 6
Table 5.3-6	Population Growth Rate.....	V - 6
Table 5.4-1	Population Forecast by District	
Table 5.4-2	Number of Households by District (Total)	
Table 5.4-3	Number of Households by District (Urban Area)	
Table 5.4-4	Number of Households by District (Rural Area)	
Table 5.4-5	Estimated Electrification Ratio by District	
Table 5.4-6	Electrification Ratio for Whole Country.....	V - 8
Table 5.4-7	Annual Energy Consumption (PSSS).....	V - 8
Table 5.4-8	Average Energy Consumption per Household.....	V - 9
Table 5.4-9	Average Energy Consumption per Household (Actual in 1999).....	V - 9
Table 5.4-10	Average Energy Consumption per Household (Applied to Demand Forecast) .....	V - 9
Table 5.4-11	Relation of Growth Rates in GDP and Energy Consumptions.....	V - 12
Table 5.4-12	Relation Factor (Elasticity) .....	V - 12
Table 5.4-13	Estimated Growth Rates of GDP.....	V - 12
Table 5.4-14	Estimated Growth Rates of Energy Consumptions .....	V - 13
Table 5.4-15	Principal Non-Residential Power Demand.....	V - 13
Table 5.4-16	Detail of Engine Driven Pumps installed under NIPMP .....	V - 14
Table 5.4-17	Electricity Demand for Particular Projects .....	V - 15
Table 5.4-18	Summary of Power Demand Forecast for Whole Country	
Table 5.4-19	Summary of Electricity Demand Forecast (Whole Country) .....	V - 16
Table 5.4-20	Energy Demand Forecast of All Districts	
Table 5.4-21	Peak Demand Forecast of All Districts	
Table 5.4-22	Estimated Growth of GDP for High and Low Scenarios .....	V - 17
Table 5.4-23	Estimated Growth Rates of Energy Consumptions .....	V - 17
Table 5.4-24	Electricity Demand Forecast (High Scenario).....	V - 18
Table 5.4-25	Electricity Demand Forecast (Low Scenario).....	V - 18
Table 5.5-1	Energy Demand by Substation (Including Transmission & Distribution Losses)	

Table 5.5-2	Peak Loads by Substation (Including Transmission & Distribution Losses)	
Table 5.5-3	Peak Loads by Substation (Excluding Transmission Losses)	
Table 5.5-4	Peak Load of Each Transmission Network.....	V - 20
Table 5.5-5	Energy Demand of Each Transmission Network.....	V - 20
Table 5.6-1	Electricity Supply Capacity of EDL's Power Stations for 2000 - 2020	
Table 6.4-1	Characteristics of Existing Transmission Lines (as of the year 2001)	
Table 6.4-2	Characteristics of Existing HV Substations (as of the year 2001)	
Table 6.4-3	EDL's Expansion Plan .....	VI - 10
Table 6.5-1	Prospective Substations in the Northern Region .....	VI - 13
Table 6.5-2	Prospective Substations in the Central 1 Region.....	VI - 13
Table 6.5-3	Prospective Substations in the Central 2 Region.....	VI - 14
Table 6.5-4	Prospective Substations in the Southern Region.....	VI - 14
Table 6.6-1	Existing and Planned 115 kV Transmission Lines	
Table 6.7-1	Maximum Fault Current Level.....	VI - 28
Table 6.7-2	Normal Fault Clearing Time by Main Protective Relay .....	VI - 29
Table 6.7-3 (1)	Generator Model; GENSAL.....	VI - 30
Table 6.7-3 (2)	Exciter Model; SCRX.....	VI - 30
Table 6.7-3 (3)	Governor Model; IEEEG3.....	VI - 30
Table 6.7-3 (4)	PSS Model; IEEEEST .....	VI - 30
Table 6.7-4 (1)	Generator Model; GENROU.....	VI - 31
Table 6.7-4 (2)	Exciter Model; SCRX.....	VI - 31
Table 6.7-4 (3)	Governor Model; IEEEG1.....	VI - 31
Table 6.7-4 (4)	PSS Model; IEEEEST .....	VI - 31
Table 6.7-5	Rated Capacity of Transmission Line .....	VI - 31
Table 6.7-6	Line Constants .....	VI - 32
Table 6.7-7	Characteristics of Transformers .....	VI - 32
Table 6.8-1	Ongoing Transmission Lines .....	VI - 33
Table 6.8-2	Transmission Lines to be installed by 2005.....	VI - 33
Table 6.8-3	Transmission Lines to be installed by 2010.....	VI - 34
Table 6.8-4	Transmission Lines to be installed by 2015.....	VI - 35
Table 6.8-5	Transmission Lines to be installed by 2020.....	VI - 35
Table 6.8-6	Conditions of Examinations .....	VI - 36
Table 6.8-7	Relationship between "Conductor Size with Lowest Annual Cost" and "Power Flow" .....	VI - 36
Table 6.8-8	The Route Adopted the Different Conductor from the Most Economical Size .....	VI - 39
Table 6.8-9	Annual Costs of 115 kV and 230 kV Transmission Lines .....	VI - 40
Table 6.8-10	Construction Costs of 115 kV and 230 kV Substations.....	VI - 40
Table 6.8-11	Results of Power Flow and Voltage Analysis at any Single Contingencies in 2005 (Base Plan, Generation: Rated Capacity)	
Table 6.8-12	Results of Power Flow and Voltage Analysis at any Single Contingencies in 2010 (Base Plan, Generation: Rated Capacity)	
Table 6.8-13	Results of Power Flow and Voltage Analysis at any Single Contingencies in 2015 (Base Plan, Generation: Rated Capacity)	
Table 6.8-14	Results of Power Flow and Voltage Analysis at any Single Contingencies in 2020 (Base Plan, Generation: Rated Capacity)	
Table 6.8-15	Maximum 3 phase Short Circuit Currents and Locations .....	VI - 42
Table 6.8-16	Maximum One Phase to Ground Fault Currents and Locations .....	VI - 42
Table 6.8-17	Results of Stability Analysis (Base Plan in 2005, Generation: Rated Capacity).....	VI - 43
Table 6.8-18	Results of Stability Analysis (Base Plan in 2010, Generation: Rated Capacity).....	VI - 44
Table 6.8-19	Results of Stability Analysis (Base Plan in 2015, Generation: Rated Capacity).....	VI - 44

Table 6.8-20	Results of Stability Analysis (Base Plan in 2020, Generation: Rated Capacity) .....	VI - 45
Table 6.9-1	Situations of Import and Export .....	VI - 46
Table 6.9-2	Import and Export under Recommendable System Operation..... (Base Plan in 2005, Generation: Rated Capacity)	VI - 47
Table 6.9-3	Results of Power Flow and Voltage Analysis at any Single Contingencies in 2005 (Base Plan, Opened System Operation, Generation: Rated Capacity)	
Table 6.9-4	Results of Stability Analysis in 2005 .....	VI - 48
	(Base Plan, Opened System Operation, Generation: Rated Capacity)	
Table 6.9-5	Import and Export under Recommendable System Operation in 2020 .....	VI - 49
	(Base Plan, Generation: Firm Capacity)	
Table 6.9-6	Results of Power Flow and Voltage Analysis at any Single Contingencies in 2020 (Base Plan, Opened System Operation, Generation: Rated Capacity)	
Table 6.9-7	Results of Stability Analysis in 2020 .....	VI - 50
	(Base Plan, Opened System Operation, Generation: Firm Capacity)	
Table 6.10-1	Alternation of Generation Development Program.....	VI - 51
Table 6.10-2	Results of Power Flow and Voltage Analysis at any Single Contingencies in 2010 (Alternation of Generation Development Program, Generation: Rated Capacity)	
Table 6.10-3	Results of Power Flow and Voltage Analysis at any Single Contingencies in 2015 (Alternation of Generation Development Program, Generation: Rated Capacity)	
Table 6.10-4	Results of Power Flow and Voltage Analysis at any Single Contingencies in 2020 (Alternation of Generation Development Program, Generation: Rated Capacity)	
Table 6.10-5	Results of Stability Analysis .....	VI - 52
	(Alternation of Generation Development Program in 2010)	
Table 6.10-6	Results of Stability Analysis .....	VI - 53
	(Alternation of Generation Development Program in 2015)	
Table 6.10-7	Results of Stability Analysis .....	VI - 53
	(Alternation of Generation Development Program in 2020)	
Table 7.1-1	Maximum Temperature in	
Table 7.1-2	Minimum Temperature in	
Table 7.1-3	Mean Temperature in	
Table 7.1-4	Maximum Wind Velocity (Gust)	
Table 7.1-5	Annual Precipitation in MM	
Table 7.1-6	Thunderstorm Days	
Table 7.1-7	Insulation Co-ordination .....	VII - 4
Table 7.1-8	Standards Applied to the Design.....	VII - 5
Table 7.2-1	Conductors and Ground-wire .....	VII - 6
Table 7.2-2	Safety factors of Conductors and Ground wires .....	VII - 7
Table 7.2-3	Maximum Working Tension and Every Day Stress (EDS) .....	VII - 7
Table 7.2-4	Insulator Size.....	VII - 7
Table 7.2-5	Safety Factors of Insulator Set .....	VII - 8
Table 7.2-6	Minimum Conductor's Height above Ground.....	VII - 8
Table 7.2-7	Insulation Gaps .....	VII - 9
Table 7.2-8	Swinging Angle of Conductor and applied Clearance.....	VII - 9
Table 7.2-9	Values of Clearance Diagram .....	VII - 9
Table 7.2-10	Typical Tower Configurations.....	VII - 10
Table 7.2-11	Loading Conditions and Safety Factors.....	VII - 11
Table 7.2-12	Tower Weights and Foundation Loads transferred from Towers.....	VII - 11
Table 7.2-13	Concrete Volumes of Pad and Chimney Type Foundations .....	VII - 12
Table 7.2-14	Tower Type and Tower Number per 10 km Long.....	VII - 12

Table 7.2-15	Average Quantities of 115 kV Transmission Lines per 10 km Long.....	VII - 12
Table 7.3 -1	Standard Clearance of Busbars.....	VII - 15
Table 7.3-2	Transformer Arrangement for a new 115 kV Substation .....	VII - 17
Table 7.3-3	Standard Ratings of Circuit Breakers .....	VII - 18
Table 7.3-4	Standard Constitution of Equipment .....	VII - 18
Table 7.3-5	Unit Capacity of Static Capacitor .....	VII - 18
Table 7.4-1	Transmission Line Sub-projects up to the year 2005.....	VII - 20
Table 7.4-2	Transmission Line Sub-projects from the year 2006 to 2010 .....	VII - 20
Table 7.4-3	Transmission Line Sub-projects from the year 2011 to 2015.....	VII - 21
Table 7.4-4	Transmission Line Sub-projects from the year 2016 to 2020 .....	VII - 21
Table 7.4-5	Transformer Additional and Replacement Program	
Table 7.5-1	Standard Unit Prices for 115 kV Transmission Lines per km.....	VII - 27
Table 7.5-2	Estimation for 115 kV T/L Construction Cost	
Table 7.5-3	Share of FC and LC for each Work Item .....	VII - 29
Table 7.5-4	Construction Costs for Transmission Line Projects.....	VII - 29
Table 7.5-5	Commissioning Year and Construction Costs for each Transmission Line project	
Table 7.5-6	Standard Unit Prices for Substation Projects	
Table 7.5-7	Construction Costs for the Substation Projects.....	VII - 30
Table 7.5-8	Total Construction Costs for the Optimum Transmission System .....	VII - 31
Table 7.6-1	Disbursement Schedule of Project Costs .....	VII - 33
Table 7.6-2	Disbursement Schedule of TL Projects .....	VII - 33
Table 7.6-3	Disbursement Schedule of Transmission Line Projects	
Table 7.6-4	Construction and Disbursement Schedule of Substation Projects	
Table 7.6-5	Investment Schedule for the Master Plan .....	VII - 34
Table 7.7-1	EIRR Calculation for TL/SS Development Project	
Table 7.7-2	Disbursement of the Project Costs excluding UXO Cost by 2010.....	VII - 36
Table 7.7-3	Results of Economic Analysis and its Sensitivity Analysis .....	VII - 37
Table 7.8-1	Alternative Power Supply Sources for Rural Electrification	
Table 8.4-1	Cost for Clearance of UXO.....	VIII - 4
Table 8.4-2	Conditions for Calculation of Saving Energy Import	
Table 8.4-3	Saving of Imported Energy .....	VIII - 6
Table 8.4-4	Number of Beneficiaries .....	VIII - 7
Table 8.4-5	Summary of Investment.....	VIII - 7
Table 8.4-6	Additional Energy Sales per Investment .....	VIII - 7
Table 8.4-7	Beneficiaries per Investment .....	VIII - 8
Table 8.4-8	Scoring of Subprojects .....	VIII - 8
Table 8.4-9	Result of Priority Evaluation by AHP.....	VIII - 9
Table 8.4-10	Evaluation Process by AHP Method	

## Figures in Part I

Figure 1.2-1	Flow of the Study .....	I - 3
Figure 1.5-1	Work Schedule	
Figure 2.1-1	Administrative Structure.....	II - 3
Figure 2.1-2	Power Region .....	II - 4
Figure 3.1-1	Power Sector Organization .....	III - 3
Figure 3.2-1	Organization of MIH.....	III - 3
Figure 3.2-2	Organization of EDL .....	III - 5
Figure 3.3-1	Nam Ngum 115 kV Transmission System (as of 2002).....	III - 8
Figure 3.4-1	Past Trend of Energy Consumption.....	III - 12
Figure 3.4-2	Past Trend of Peak Demand .....	III - 14
Figure 3.4-3	Daily Load Curve at Substations	
Figure 3.4-4	Energy Balance in 2000.....	III - 16
Figure 3.9-1	Organization of the Training Center .....	III - 26
Figure 3.11-1	ASEAN 500 kV Interconnection Plan .....	III - 34
Figure 5.3-1	Administrative Map of Lao PDR	
Figure 5.4-1	Relation between Growth Rates of GDP and Energy Consumption .....	V - 10
Figure 5.4-2	Relation between Growth Rates of GDP and Energy Consumption (Industry Sector).....	V - 11
Figure 5.4-3	Relation between Growth Rates of GDP and Energy Consumption (Service Sector).....	V - 11
Figure 5.4-4	Historical Trend of System Loss.....	V - 15
Figure 5.4-5	Peak Power Demand by District in 2020	
Figure 5.4-6	Energy Demand Forecast in 3 Scenarios .....	V - 18
Figure 5.4-7	Peak Load Forecast in 3 Scenarios .....	V - 18
Figure 5.6-1	Demand - Supply Balance of Central 1 & 2 plus Northern Region .....	V - 21
Figure 5.6-2	Demand - Supply Balance of Southern Region .....	V - 21
Figure 5.6-3	Demand - Supply Balance of EDL's National Grid.....	V - 22
Figure 6.1-1	Flow of System Planning .....	VI - 1
Figure 6.2-1	National Biodiversity Conservation Areas	
Figure 6.2-2	UXO Impact and Bombing Data (1965-75)	
Figure 6.4-1	Existing Transmission System (as of the year 2001)	
Figure 6.6-1	Transmission lines from Nam Beng PS.....	VI - 15
Figure 6.6-2	Transmission Line between Nam Leuk PS and Phonsavan SS .....	VI - 16
Figure 6.6-3	Transmission System in Vientiane.....	VI - 18
Figure 6.6-4	Transmission System in Central 2 and Southern Regions .....	VI - 19
Figure 6.6-5	Southern System .....	VI - 20
Figure 6.7-1	Flow of System Analysis .....	VI - 26
Figure 6.7-2	Relation among Elements for System Analysis.....	VI - 26
Figure 6.8-1	The Optimum Transmission System for Domestic Supply in 2020	
Figure 6.8-2 (1)	Power System Diagram in Lao PDR in 2005	
Figure 6.8-2 (2)	Power System Diagram in Lao PDR in 2010	
Figure 6.8-2 (3)	Power System Diagram in Lao PDR in 2015	
Figure 6.8-2 (4)	Power System Diagram in Lao PDR in 2020	
Figure 6.8-3	Relationship between Power Flow and Annual Cost.....	VI - 37
Figure 6.8-4	Power Flow & Voltage in 2005 (Base Plan, Generation: Rated Capacity)	

Figure 6.8-5	Power Flow & Voltage in 2010 (Base Plan, Generation: Rated Capacity)	
Figure 6.8-6	Power Flow & Voltage in 2015 (Base Plan, Generation: Rated Capacity)	
Figure 6.8-7	Power Flow & Voltage in 2020 (Base Plan, Generation: Rated Capacity)	
Figure 6.8-8	Short Circuit Current in 2005 (Base Plan, Generation: Rated Capacity)	
Figure 6.8-9	Short Circuit Current in 2010 (Base Plan, Generation: Rated Capacity)	
Figure 6.8-10	Short Circuit Current in 2015 (Base Plan, Generation: Rated Capacity)	
Figure 6.8-11	Short Circuit Current in 2020 (Base Plan, Generation: Rated Capacity)	
Figure 6.8-12	One Phase to Ground Fault Current in 2005 (Base Plan, Generation: Rated Capacity)	
Figure 6.8-13	One Phase to Ground Fault Current in 2010 (Base Plan, Generation: Rated Capacity)	
Figure 6.8-14	One Phase to Ground Fault Current in 2015 (Base Plan, Generation: Rated Capacity)	
Figure 6.8-15	One Phase to Ground Fault Current in 2020 (Base Plan, Generation: Rated Capacity)	
Figure 6.9-1	Power Flow & Voltage in 2005 (Base Plan, Opened System Operation, Generation: Rated Capacity)	
Figure 6.9-2	Power Flow & Voltage in 2020 (Base Plan, Opened System Operation, Generation: Firm Capacity)	
Figure 6.10-1	Power Flow & Voltage in 2010 (Alternation of Generation Development Program)	
Figure 6.10-2	Power Flow & Voltage in 2015 (Alternation of Generation Development Program)	
Figure 6.10-3	Power Flow & Voltage in 2020 (Alternation of Generation Development Program)	
Figure 7.1-1	Meteorological Situations	
Figure 7.2-1	Flow of Preliminary Design of 115 kV Transmission Line .....	VII - 5
Figure 7.2-2	Conductor Clearance Diagram of 115 kV Transmission Line	
Figure 7.2-3	115kV, 1cct: ACSR 240 sq.mm, 410 sq.mm Suspension Tower	
Figure 7.2-4	115kV, 1cct: ACSR 240 sq.mm, 410 sq.mm Tension Tower	
Figure 7.2-5	115kV, 2cct: ACSR 240 sq.mm, 410 sq.mm Suspension Tower	
Figure 7.2-6	115kV, 2cct: ACSR 240 sq.mm, 410 sq.mm Tension Tower	
Figure 7.3-1	Typical Single Diagram of New Substation applying Double Busbar System	
Figure 7.3-2	Typical Single Diagram of New Substation applying Single Busbar System	
Figure 7.3-3	Ground Fault Current .....	VII - 16
Figure 7.4-1	Single Line Diagram of Substation/Switching Station in Northern Region	
Figure 7.4-2	Single Line Diagram of Substation/Switching Station in Central 1 Region	
Figure 7.4-3	Single Line Diagram of Substation/Switching Station in Central 2 Region	
Figure 7.4-4	Single Line Diagram of Substation/Switching Station in Southern Region	
Figure 7.6-1	Common Implementation Schedule for Transmission Line Projects.....	VII - 32
Figure 7.6-2	Common Implementation Schedule for Substation Projects.....	VII - 32
Figure 7.8-1	Extension Plan of EDL's 115 kV and 22 kV Grid	

## **Part - II Facility Design for the Highest Priority Project**

### **Chapter 1 Overview of the Facility Design**

1.1	Selection of Facilities .....	I - 1
1.2	Design Policy.....	I - 2
1.2.1	Design Principle .....	I - 2
1.2.2	Locations of Substations .....	I - 2
1.2.3	Selection of Transmission Line Routes .....	I - 2
1.2.4	Climatic Conditions .....	I - 3
1.2.5	Environment.....	I - 4
1.2.6	Stability of System Operation .....	I - 4
1.2.7	Results of Preliminary Design.....	I - 5
1.3	Basic Plan of the Project Implementation .....	I - 5
1.3.1	Rationale of the Project Implementation .....	I - 5
1.3.2	Procedures for Implementation.....	I - 5

### **Chapter 2 Transmission Lines**

2.1	Transmission Line Route .....	II - 1
2.1.1	Outline of Line Route.....	II - 1
2.1.2	Land Preparation and Environment.....	II - 3
2.2	Design of Transmission Lines .....	II - 4
2.2.1	Determination of Design Conditions.....	II - 5
2.2.2	Conductor and Ground-wire Design.....	II - 6
2.2.3	Insulator Design .....	II - 7
2.2.4	Ground Clearance.....	II - 9
2.2.5	Determination of Tower Configuration .....	II - 9
2.2.6	Tower Design .....	II - 11
2.2.7	Foundation Design .....	II - 13
2.2.8	Crossing Point with 230 kV Theun Hinboun Line.....	II - 14
2.2.9	Quantities of Line Materials .....	II - 15

### **Chapter 3 Substations**

3.1	Design Concept.....	III - 1
3.2	Substation Site .....	III - 2
3.2.1	Pakxan Substation .....	III - 2
3.2.2	Thakhek Substation.....	III - 3
3.2.3	Pakbo Substation .....	III - 4
3.3	Design for Pakxan Substation .....	III - 5
3.3.1	General.....	III - 5
3.3.2	Design and Scope of Works .....	III - 5
3.4	Design for Thakhek Substation .....	III - 7
3.4.1	General.....	III - 7
3.4.2	Design and Scope of Works .....	III - 7
3.5	Design for Pakbo Substation.....	III - 8
3.5.1	General.....	III - 8
3.5.2	Design and Scope of Works .....	III - 9
3.6	Main facilities.....	III - 11



3.6.1	General Electrical Requirements.....	III - 11
3.6.2	Specification and Quantity of the Main Facilities .....	III - 11
3.6.3	Protection Relay System .....	III - 13
3.6.4	Spare Parts and Tools.....	III - 14
<b>Chapter 4 Implementation Plan</b>		
4.1	Implementation Policy .....	IV - 1
4.1.1	Overall Policy.....	IV - 1
4.1.2	Procurement of Facilities.....	IV - 3
4.2	Particular Conditions .....	IV - 4
4.3	Scope of Works.....	IV - 5
4.4	Plan of Supervision.....	IV - 6
4.5	Quality Control Plan .....	IV - 8
4.6	Implementation Schedule.....	IV - 9
<b>Chapter 5 Project Operation Plan</b>		
5.1	Organization.....	V - 1
5.1.1	Present Organization.....	V - 1
5.1.2	Reinforcement of Operation and Maintenance of 115 kV Systems.....	V - 3
5.2	O & M Manuals and Education.....	V - 7
<b>Chapter 6 Estimate of the Project Costs</b>		
6.1	Land and UXO.....	VI - 1
6.1.1	Compensation Costs for Lands and Right of Way (ROW).....	VI - 1
6.1.2	Costs for UXO Survey and Clearance .....	VI - 1
6.2	Construction Cost of Transmission Lines .....	VI - 2
6.3	Construction Cost of Substation Facilities .....	VI - 4
6.4	Total Project Costs.....	VI - 5
6.5	Disbursement Schedule of the Costs.....	VI - 6
<b>Chapter 7 Project Evaluation</b>		
7.1	Evaluation Criteria .....	VII - 1
7.1.1	Criteria for Economic Evaluation .....	VII - 1
7.1.2	Criteria for Financial Evaluation.....	VII - 3
7.2	Results of Evaluation and Sensitivity Analysis.....	VII - 4
7.2.1	Economic Internal Rate of Return.....	VII - 4
7.2.2	Financial Internal Rate of Return .....	VII - 4
<b>Chapter 8 Conclusion and Recommendation</b>		
8.1	Conclusion .....	VIII - 1
8.2	Recommendation .....	VIII - 4

## Tables in Part II

Table 2.2-1	Design Conditions of Conductor and Ground-wire .....	II - 6
Table 2.2-2	Conductor and Ground-wire .....	II - 6
Table 2.2-3	Maximum Working Tension and Every Day Stress .....	II - 7
Table 2.2-4	Insulator Size.....	II - 7
Table 2.2-5	Insulator Assemblies .....	II - 8
Table 2.2-6	Important crossing section .....	II - 8
Table 2.2-7	Size of Insulator Assembly .....	II - 9
Table 2.2-8	Minimum Height of Conductor above Ground.....	II - 9
Table 2.2-9	Insulator Gaps .....	II - 10
Table 2.2-10	Swinging Angle of Conductor and applied Clearance.....	II - 10
Table 2.2-11	Values of Clearance Diagram .....	II - 10
Table 2.2-12	Tower Configurations.....	II - 11
Table 2.2-13	Design Span Length .....	II - 12
Table 2.2-14	Loading Conditions and Safety Factors .....	II - 12
Table 2.2-15	Tower Weights and Foundation Loads transferred from Towers.....	II - 12
Table 2.2-16	Loading Conditions and Safety Factors .....	II - 13
Table 2.2-17	Results of Foundation Design .....	II - 14
Table 2.2-18	Number of Towers and the Total Weight of Towers.....	II - 15
Table 2.2-19	Quantities of Conductor and Ground-wire .....	II - 15
Table 2.2-20	Quantities of Insulators and Insulator Assemblies .....	II - 16
Table 2.2-21	Quantities of Fittings of Conductor and Ground-wire .....	II - 17
Table 2.2-22	Quantities of Tower Foundations .....	II - 17
Table 3.6-1	Quantity of the Main Facilities.....	III - 13
Table 4.3-1	Scope of Works.....	IV - 6
Table 5.1-1	115 kV Substation and Switching Station in Nam Ngum 1/Nam Leuk System .....	V - 2
Table 6.2-1	Share of FC and LC for each Work Item .....	VI - 3
Table 6.2-2	Construction Costs of Transmission Lines .....	VI - 3
Table 6.2-3	Total Construction Cost of Transmission Lines for the Project	
Table 6.2-4	Cost of Foundation Work for the Project	
Table 6.3-1	Construction Cost of Substation Facilities .....	VI - 5
Table 6.3-2	Construction Cost of Substation Facilities	
Table 6.4-1	Total Project Costs .....	VI - 6
Table 6.5-1	Disbursement Schedule .....	VI - 7
Table 7.1-1	Construction Costs (Project and MV/LV Networks).....	VII - 2
Table 7.1-2	Energy Required by Substations .....	VII - 2
Table 7.2-1	EIRR of the Project	
Table 7.2-2	Results of Computation for EIRR .....	VII - 4
Table 7.2-3	FIRR of the Project	
Table 7.2-4	Results of Computation for FIRR .....	VII - 4
Table 8.1-1	Estimated Project Cost.....	VIII - 3
Table 8.1-2	Estimated Disbursement Schedule of Project Cost.....	VIII - 3
Table 8.1-3	Project Implementation Schedule .....	VIII - 3

## Figures in Part II

Figure 2.1-1	Selected Transmission Line Route from Pakxan SS to Pakbo SS	
Figure 2.1-2	Selected Transmission Line Route from Pakxan SS to Thakhek SS	
Figure 2.1-3	Proposed Route of Nam Kading River Crossing (Scale 1:50,000)	
Figure 2.1-4	Selected Transmission Line Route from Thakhek SS to Pakbo SS	
Figure 2.1-5	Geological Features Map	
Figure 2.2-1	Flow of Design for the Project .....	II - 5
Figure 2.2-2	String Insulator Unit with Ball and Socket coupling	
Figure 2.2-3	Suspension Set	
Figure 2.2-4	Tension Set	
Figure 2.2-5	Suspension Tower: A1 Type	
Figure 2.2-6	Suspension Tower: A2 Type	
Figure 2.2-7	Tension Tower: B1 Type	
Figure 2.2-8	Tension Tower: C1 Type	
Figure 2.2-9	Tension Tower: D1, DE Type	
Figure 2.2-10	Tension Tower: D2 Type	
Figure 2.2-11(1)	Geological Features Map	
Figure 2.2-11(2)	Boring Data	
Figure 2.2-12	Figure of Foundation	
Figure 2.2-13	Image of the Cross Point with 230 kV Transmission Line	
Figure 2.2-14	Gantry Structure: GA Type	
Figure 2.2-15	Design of the Cross Point with 230 kV Transmission Line	
Figure 3.2-1	Pakxan SS Location .....	III - 2
Figure 3.2-2	Planned Thakhek SS Location.....	III - 3
Figure 3.2-3	Pakbo SS Location .....	III - 4
Figure 3.3-1	Pakxan Substation Single Line Diagram (as of July 2002)	
Figure 3.3-2	Pakxan Substation Existing 115 kV Switchyard Layout (as of July 2002)	
Figure 3.3-3	Pakxan Substation Single Line Diagram (after the Project)	
Figure 3.3-4(1)	Pakxan Substation 115 kV Switchyard Layout Plan	
Figure 3.3-4(2)	Pakxan Substation 115 kV Switchyard Layout Plan (Side View)	
Figure 3.3-5	Pakxan Substation 115 kV Switchyard Layout Plan.....	III - 5
Figure 3.4-1	Thakhek Substation Single Line Diagram (after the Project)	
Figure 3.4-2(1)	Thakhek Substation 115 kV Switchyard Layout Plan	
Figure 3.4-2(2)	Thakhek Substation 115 kV Switchyard Layout Plan (Side View)	
Figure 3.5-1	Pakbo Substation Single Line Diagram (after the SPRE project)	
Figure 3.5-2	Pakbo Substation Existing 115 kV Switchyard Layout (after the SPRE project)	
Figure 3.5-3	Pakbo Substation Single Line Diagram (after the Project)	
Figure 3.5-4(1)	Pakbo Substation 115 kV Switchyard Layout Plan	
Figure 3.5-4(2)	Pakbo Substation 115 kV Switchyard Layout Plan (Side View)	
Figure 3.5-5	Pakbo Substation 115 kV Switchyard Layout Plan .....	III - 9
Figure 4.1-1	Organization for the Project Implementation.....	IV - 1
Figure 4.6-1	Implementation Schedule	
Figure 5.1-1	Organizations of Branch Offices .....	V - 2
Figure 6.1-1	UXO Map along Pakxan SS to Pakbo SS Transmission Line	

## ABBREVIATIONS

ACSR	:	Aluminum Conductor Steel Reinforced
ADB	:	Asian Development Bank
AFTA	:	Association of Southeast Asian Nations Free Trade Area
ASEAN	:	Association of Southeast Asian Nations
BOT	:	Build, Operate, and Transfer
BOOT	:	Build, Own, Operate, and Transfer
CA	:	Concession Agreement
CB	:	Circuit Breaker
CIF	:	Cost, Insurance, and Freight
CPC	:	Committee for Planning and Cooperation
CPI	:	Consumer Price Index
CT	:	Current Transformer
DIP	:	Department of Investment Promotion
DL	:	Distribution Line
DOE	:	Department of Electricity in MIH
DS	:	Disconnecting Switch
EDS	:	Every Day Stress
EDL	:	Electricite du Laos
EGAT	:	Electricity Generating Authority of Thailand
EIA	:	Environmental Impact Assessment
EIRR	:	Economic Internal Rate of Return
EU	:	European Union
FIRR	:	Financial Internal Rate of Return
FOB	:	Free on Board
GEF	:	Global Environment Facility
GDP	:	Gross Domestic Product
GMS	:	Greater Mekong Sub-region
HDI	:	Human Development Index
HDSS	:	Hydropower Development Strategy Study
HV	:	High Voltage (230 kV and 115 kV in Laos)
ICB	:	International Competitive Bidding
IEC	:	International Electro-technical Committee
IDA	:	International Development Association
IKL	:	Isokeraunic Level
IMF	:	International Monetary Fund
IPP	:	Independent Power Producer
IRR	:	Internal Rate of Return
ISO	:	International Standards Organization
JBIC	:	Japan Bank for International Cooperation
JICA	:	Japan International Cooperation Agency
JIS	:	Japanese Industrial Standard
LAO P.D.R.	:	Lao People's Democratic Republic
LDC	:	Load Dispatching Center

LF	:	Load Factor
LNGC	:	Lao National Grid Company
LOLP	:	Loss of Load Probability
LRMC	:	Long Run Marginal Cost
LV	:	Low Voltage (380/220 V in Laos)
MIH	:	Ministry of Industry and Handicrafts
MOSES	:	Multi-Objective Scenario Evaluation System
MOU	:	Memorandum of Understanding
MV	:	Medium Voltage (34.5 kV and 22 kV in Laos)
NBCA	:	National Bio-diversity and Conservation Area
NEAP	:	National Environmental Action Plan
NETG	:	National Electricity Transmission Grid
NPV	:	Net Present Value
NTL	:	Non-Technical (Energy) Loss
OCC	:	Opportunity Cost of Capital
OH	:	Overhead (line)
OPGW	:	Optical fiber Ground-wire
O&M	:	Operation and Maintenance
PEA	:	Provincial Electricity Authority (in Thailand)
PIP	:	Public Investment Program
PLC	:	Power Line Carrier (communications)
PPA	:	Power Purchase Agreement
PS	:	Power Station
PSS/E	:	Power System Simulator for Engineering
PSSS	:	Power Sector Strategy Study (by ADB)
PT	:	Potential Transformer
RUS	:	Rated Ultimate Strength
SS	:	Substation
STEA	:	Science, Technology, and Environmental Agency
STEP	:	JICA Study Team for Electric Power Standard Establishment
SCF	:	Standard Conversion Factor
SHS	:	Solar Home System
SWS	:	Switching Station
TA	:	Technical Assistance
TL	:	Transmission Line
TOR	:	Terms of Reference
TR	:	Transformer
UNDP	:	United Nations Development Program
UNHCR	:	United Nations High Commissioner for Refugees
UXO	:	Unexploded Ordnance
WB	:	World Bank
WTO	:	World Trade Organization
WTP	:	Willingness to Pay

## UNITS

### LENGTH

mm	:	Millimeters
cm	:	Centimeters (10.0 mm )
m	:	Meters (100.0 cm)
km	:	Kilometers (1,000.0 m)

### EXTENT

cm <sup>2</sup>	:	Square-centimeters (1.0 cm x 1.0 cm)
m <sup>2</sup>	:	Square-meters (1.0 m x 1.0 m)
km <sup>2</sup>	:	Square-kilometers (1.0 km x 1.0 km)
ha	:	Hectares (10,000 m <sup>2</sup> )

### VOLUME

cm <sup>3</sup>	:	Cubic-centimeters (1.0 cm x 1.0 cm x 1.0 cm)
m <sup>3</sup>	:	Cubic-meters (1.0 m x 1.0 m x 1.0 m)

### WEIGHT

g	:	grams
kg	:	kilograms (1,000 g)
ton	:	Metric ton (1,000 kg)

### TIME

sec.	:	Seconds
min.	:	Minutes (60 sec.)
hr.	:	Hours (60 min.)

### CURRENCY

KIP	:	Lao Kip
US\$	:	United State Dollars
¥	:	Japanese Yen
ECU	:	Euro Currency Unit

### ELECTRIC

V	:	Volts (Joule/coulomb)
kV	:	Kilo volts (1,000 V)
A	:	Amperes (Coulomb/second)
kA	:	Kilo amperes (1,000 A)
W	:	Watts (active power) (J/s: Joule/second)
kW	:	Kilo watts (10 <sup>3</sup> W)
MW	:	Mega watts (10 <sup>6</sup> W)
GW	:	Giga watts (10 <sup>9</sup> W)
Wh	:	Watt-hours (watt x hour)
kWh	:	Kilo watt-hours (10 <sup>3</sup> Wh)
MWh	:	Mega watt-hours (10 <sup>6</sup> Wh)
GWh	:	Giga watt-hours (10 <sup>9</sup> Wh)
VA	:	Volt-amperes (apparent power)
kVA	:	Kilo volt-amperes (10 <sup>3</sup> VA)
MVA	:	Mega volt-amperes (10 <sup>6</sup> Wh)
var	:	Volt-ampere reactive (reactive power)
kvar	:	Kilo volt-ampere reactive (10 <sup>3</sup> var)
Mvar	:	Mega volt-ampere reactive (10 <sup>6</sup> var)

## ***EXECUTIVE SUMMARY***

## **Executive Summary**

### **(1) Background of the Study**

Lao PDR has an estimated hydropower generation potential of more than 18,000 MW in its territory. The Government of Lao PDR (GoL) has a basic policy for the power sector that aims to acquire foreign currencies by exporting electric energy to its neighboring countries and to raise electrification ratio of the country.

Export of electricity has greatly contributed to the country's revenue since commissioning of the Nam Ngum power station in 1971. Contribution of the energy export from Nam Ngum - Nam Leuk and Xeset systems to Thailand was US\$ 22 million (796 GWh) in 2001. This was 8 % of total foreign currency earnings of the country in the year. On the other hand, due to lack of the domestic transmission facilities, some areas of the country should import electricity at higher rate than that for export. Total amount of imported energy was US\$ 6.5 million (183 GWh) in 2001.

Recently, the World Bank (WB) and the Asian Development Bank (ADB) are assisting in development of transmission systems in combination with distribution networks in the northern area and the southern area. However, a master plan for the development of a comprehensive transmission system to cover the whole country has not been established.

Under the situation, GoL proposed in May 2000 to the Government of Japan a request for the Study on Master Plan of Transmission Line and Substation System in the country for the domestic power supply purpose. The Government of Japan entrusted to the Japan International Cooperation Agency (JICA) to examine the request. JICA discussed details of the request with officials of Ministry of Industry and Handicraft (MIH) and Electricite du Laos (EDL) during November 2000 and decided to conduct the Study.

### **(2) Objective of the Study**

Specific objectives of the study were to formulate an optimum development plan up to the year 2020 of the transmission lines and substations for domestic power supply over the country, to select the highest priority project from the optimum plan, and to design of the facilities for the highest priority project, taking into account the development program of EDL's power plants and efficient utilization of energy from IPPs' power plants.

The Study was carried out during a period of February 2001 to September 2002 in cooperation with the counterparts from EDL and accomplished in three (3) study stages; the investigation stage, system study stage, and the master plan formulation stage.



---

### (3) Results of Study

#### (3-1) Review on Existing Transmission Systems and Current Generation Development Plan

At present there are only 4 independently operated power systems in the country including importing systems as seen in Figure 6.4-1 of Part I.

EDL establishes its own generation development program for the domestic supply and IPP projects by the year 2020 in consultation with MIH as shown on Tables 4.2-1 and 4.2-2 of Part I, which was the base of the master plan study of the study team. Total 15 new power stations are programmed for domestic supply use with total installed capacity of 852 MW for annual average production of 3,936 GWh. The capacity to be developed is equivalent to 300 % of the current capacity, and the total production is 360 % of the current generation. Total installed capacity and average annual production of IPP plants in the year 2020 are planned to be 7,013 MW and 33,243 GWh, respectively.

#### (3-2) Electricity Demand Forecast

Electricity demand forecast was examined by year and by district until 2020. Both annual energy consumption in GWh and peak demand in MW were forecasted. Energy demand in each district was forecasted for four categories, residential, industrial, commercial & service and agricultural sectors.

The general electrification policy of the country in the Socio-Economic Development Strategy published by the GoL in March 2001 stipulates a rate of electrification of all households by the year 2020 to be 90%. Residential energy demand was forecasted based on this electrification policy for household. Energy demands of industrial sector and commercial & service sector were forecasted on the base of elasticity between growths of GDP and energy consumption in the respective sector. Energy demand for agricultural sector was separately forecasted. Following table summarizes results of the electricity demand forecast of the Team by the year 2020.

Descriptions	Unit	Scenari	2005	2010	2015	2020
Energy Demand	(GWh)	High	1,374	2,196	3,350	4,715
	(GWh)	Base	1,337	2,093	3,138	4,320
	(GWh)	Low	1,302	1,997	2,945	3,975
Losses	(GWh)	High	343	493	670	832
	(GWh)	Base	334	470	628	762
	(GWh)	Low	326	448	589	701
Total Energy Demand	(GWh)	High	1,672	2,688	4,020	5,547
	(GWh)	Base	1,672	2,563	3,765	5,082
	(GWh)	Low	1,628	2,445	3,534	4,676
Peak Demand	(MW)	High	340	512	765	1,055
	(MW)	Base	331	488	716	967
	(MW)	Low	322	465	672	890

### (3-3) Supply and Demand Balance

Balance of the total supply capability in the development plan of MIH/EDL and base-case electricity demand forecasted by the study team indicates the following:

- In the year 2005 when Central 1 and Central 2 will be interconnected, total installed capacity of interconnected transmission network is exactly the same as the assumed peak load of the network in 2005.
- In the year 2006, the completion of Nam Ngum 2 and Nam Beng 3 power stations will realize remarkable increase in the supply capacity of the interconnected network to meet the demand with sufficient reserved margin.
- After the year 2008 when the most demanding areas will be interconnected to form a unified national grid, supply capacities in both peak load and energy demand of the grid will continue to increase with the completion of various power plants in the generation development program of MIH/EDL, which are quite sufficient to meet the growing demand till the year 2020 as seen in Figure 5.6-3 of Part I.

### (3-4) Formulation of Optimum Transmission System

Power plants for domestic supply are basically EDL's own plants only excluding IPP plants. While, agreements of IPPs with the GoL have and will have such a particular term that approximately 5 % of total energy and power produced at its plant should be delivered for the domestic consumption. The team planned that only such IPP plants providing with generator(s) for solely supplying to the domestic demand and being separated from export-use facilities would be connected with the EDL's domestic transmission grid, for reasons of stable operation of the grid and a reliable supply. Other IPP plants having no solely generator(s) will not be connected to the national grid, but agreed energy for domestic supply will be delivered to their surrounding areas through 22 kV feeders from the plants for contributing to rural electrification.

The expansion plan of transmission systems was chronologically formulated taking into account the following elements.

- (a) Demands of power and energy forecasted in Chapter 5,
- (b) Policy of the GoL on electrification rate of the country to be 90% by 2020,
- (c) Linkage with availability of power and energy at the time, i.e., development program of power plants,
- (d) Effective utilization and reinforcement of the existing transmission facilities, and programmed development of transmission systems in the country under international organizations,
- (e) Satisfaction of criteria for systems and reliability,

- 
- (f) Impact to social and environment, and
  - (g) Facilities to be on the least cost basis

Results of the examinations on electricity demand, transmission distance and power flow concluded that 115 kV is the most economical system voltage for domestic supply by 2020. The plans of interconnections among power plants, substations and demand points were determined in comparisons of various alternatives for each section. Figure 6.8-1 of Part I shows the connections of points thus formulated till the year 2020.

The study team indicated the areas where EDL grids will not cover and recommended such alternative electricity sources as solar, mini/micro hydro, or diesel generator adequate for those areas.

### (3-5) Analysis of Optimum Transmission System

For verifying adequacy of the formulated system for the system planning criteria, the optimum system was analyzed by PSS/E computer software. The analyses were conducted for power flow, stability, fault current, line loss, etc. on various cases in every 5-year system. Results of the analyses concluded that the formulated optimum systems in each year were quite appropriate satisfying all the system planning criteria. Further, the study team recommends several operation plans of the future systems as one of the results of analyses.

### (3-6) Conceptual Facility Design and Cost Estimate of the Optimum System

The study team conducted the conceptual design of facilities for transmission lines and substations for the formulated optimum system applying the design criteria agreed between EDL and the team and also referring to the technical standards established by JICA STEP team. On the basis of the design, the study team estimated the total project cost of the optimum transmission and substation system over the whole country. Estimated total project cost on the ICB base was US\$ 480 million including the currently progressing and planned projects under assistance of IDA, ADB and other organizations.

### (3-7) Evaluation of Optimum Transmission Lines and Substation System

With the reasons that most of trunk transmission systems will be completed by the year 2008 and there might be some uncertainties in the EDL's development program of power stations after 2010, evaluation of the optimum system in the year 2010 was conducted. Cost included those for transmission lines and substations and MV & LV distribution networks (estimated by the study team) required for 2010 systems. Benefit was assumed to be incremental sales of energy to the areas through the formulated system, applying energy tariff that was estimated from the weighted willingness to pay of the existing and new customers deducted by generation cost. The generation cost was estimated from the ADB TA report. EIRR (Economic Internal Rate of Return) of the

optimum system thus computed was 23 % which turns out to be higher than the said OCC (Opportunity Cost of Capital) 11 % of Lao PDR and was judged as viable in economic terms.

EDL, an implementing agency of the project, is a power corporation that owns every facility from generation through transmission to distribution networks, and is responsible for the entire flow from power production to retail sale to energy users. This indicates uncertainty of hand-over or wholesale price between generation outlet and transmission inlet. Furthermore, this Project is to develop the transmission and sub-station facilities over the country, the project covers many remote and scattered demanding points, and the present power tariff includes subsidy. Under those conditions, revenue related to the transmission lines and substations is difficult to be identified. Assuming that 40 % of the current tariff regulated toward the year 2005 would be allocated for the portion of transmission lines, substations and distribution network, trial calculation of FIRR for the Project was carried out. Result of the calculation was however negative.

### (3-8) Selection of Highest Priority Project

The highest priority project was selected from candidates systems in the formulated optimum system to be developed by 2005, but the progressing project and the certain projects to be implemented under the international funds were excluded from candidates. The evaluation items for the candidate projects were determined through discussions with EDL as below:

- (a) Urgency of the subproject in the respect of the governmental development program,
- (b) Impact for environmental and UXO circumstances,
- (c) Saving of imported energy by a subproject,
- (d) Number of beneficiaries from a subproject, and
- (e) Efficiency of investment (e-1) : Energy sales per investment  
(e-2) : Beneficiaries per investment

The evaluation concluded that the section of Pakxan-Thakhek-Pakbo system was the highest priority project.

### (3-9) Facility Design of the Highest Priority Project

The study team achieved the preliminary design of the 115 kV double circuit of ACSR 240 mm<sup>2</sup> transmission line of Pakxan - Thakhek - Pakbo and the 115 kV substations at Pakxan, Thakhek, and Pakbo of the highest priority project.

The transmission line route was aligned over 300 km almost along the national road No.13 as seen in Figures 2.1-1 to 2.1-4 of Part II. The route was selected in details taking into account results of the examinations on environment, regional restriction of land use, security of the facilities, easiness of

---

construction and maintenance, and also referring to the advice of EDL. Most of the route passes in flat area, and soil conditions for towers deem to be quite solid so that no special foundations will be required for the line. Final route and soil condition will be confirmed by the field survey to be carried out in the detailed design stage of the project.

Each substation for the project is to be provided in the premises of the existing EDL substations or premises of the substation newly to be completed during 2004. No issues for land and environment are anticipated for the substations, accordingly.

Design of the facilities was done so as to meet various articles ruled in the Laotian Electric Power Technical Standard of the JICA STEP team and also to satisfy the design criteria agreed between EDL and the study team.

In accordance with results of the design, the team prepared the implementation schedule and estimated the project cost with its disbursement schedule. Estimated project cost for both transmission lines and substations was approximately US\$ 27.7 million. The Project needs 36 months to be completed from assignment of the consultants to the commissioning of all the facilities including 13 months for preparatory works and 23 months for manufacturing, construction, and tests.

The highest priority project was economically and financially evaluated in IRR analysis. EIRR for the project was worked out to be 23.9 % on the basis of save of import energy. FIRR of the Project was calculated to be 14.9 % on the basis of incremental energy sales. Both EIRR and FIRR are higher than OCC of 11 % assumed for the country, and the Project was judged to be viable.

Besides, following Project effects are assured by its implementation.

- (a) Reduction of import energy estimated at approximately 6,290 GWh or US\$ 32 million for a period of 15 years from 2006 to 2020.
- (b) Electrification of 980,000 persons in the area,
- (c) Contribution to development of regional industrial, agricultural, and commercial sectors,
- (d) Contribution to improvement of Basic Human Needs, and
- (e) Start-up of the comprehensive national transmission network.

Thus, the Project is recommended to be implemented at the earliest time.

In addition, the study team made various recommendations for the efficient and proper operation of the power system in the country in Chapter 8 of Part II.