


**參考資料 3**

**設計資料- 2**


## **参考資料 3.1**

### **設計検討書**

付図3. 1  
マリンバダ浄水場取水量の推移(2001年)



付図3. 2  
ナドゥガラ浄水場取水量の推移(2001年)



付表3. 1 給水区域内人口

Table Existing Transmission Pipe Hydraulic Calculation (Existig Condition)

No.	Service Area	GN No.	Population			Area (ha)	2005	2007	2010	2021
			1981	2001	Increase Ratio					
1 Malimboda WTP										
	402B	100		1,046		1,084	1,106	1,139	1,271	
	402A	100		1,472		1,526	1,556	1,604	1,789	
	402	100		765		793	809	833	930	
	400B	40		567		587	599	617	689	
	400	100		1,530		1,586	1,618	1,667	1,860	
	356B	100		883		915	934	962	1,073	
	356A	100		664		688	702	723	807	
	356	100		852		883	901	928	1,035	
	353B	100		727		754	769	792	884	
	353A	100		1,602		1,660	1,694	1,745	1,947	
	353	100		1,224		1,269	1,294	1,333	1,488	
	351B	100		2,044		2,119	2,161	2,227	2,484	
	351A	100		911		944	963	992	1,107	
	351	100		1,524		1,580	1,611	1,660	1,852	
	350A	100		764		792	808	832	929	
	350	100		1,453		1,506	1,536	1,583	1,766	
	Subtotal			18,028		18,686	19,061	19,639	21,910	
2 Devinuwara Elevated Tank										
	436C	50		421		436	445	459	512	
	435A	100		1,055		1,093	1,115	1,149	1,282	
	435	30		224		232	236	243	272	
	433H	100		1,238		1,283	1,309	1,349	1,505	
	433G	100		1,225		1,270	1,295	1,334	1,489	
	433F	100		1,300		1,347	1,375	1,416	1,580	
	433E	50		599		620	633	652	727	
	433D	100		1,459		1,512	1,543	1,589	1,773	
	433C	100		514		533	543	560	625	
	433B	100		952		987	1,007	1,037	1,157	
	433A	100		776		804	820	845	943	
	433	100		1,056		1,095	1,117	1,150	1,283	
	432	100		2,359		2,445	2,494	2,570	2,867	
	432A	100		949		984	1,003	1,034	1,153	
	Subtotal			14,126		14,641	14,936	15,388	17,168	
3 Gandara Ground Reservoir										
	438C	100		1,145		1,187	1,211	1,247	1,392	
	438A	60		672		697	711	732	817	
	437C	100		1,276		1,323	1,349	1,390	1,551	
	437B	100		1,134		1,175	1,199	1,235	1,378	
	437A	100		1,482		1,536	1,567	1,614	1,801	
	437	40		698		724	738	761	849	
	436C	50		421		436	445	459	512	
	435	70		522		541	551	568	634	
	433E	50		599		620	633	652	727	
	Subtotal			7,948		8,238	8,404	8,659	9,660	
4 Gandara Elevated Tank										
	438B	100		774		802	818	843	941	
	438A	40		448		464	474	488	544	
	438	100		1,283		1,330	1,357	1,398	1,559	
	437	60		1,048		1,086	1,108	1,141	1,273	
	436B	100		1,098		1,138	1,161	1,196	1,334	
	436A	100		847		878	896	923	1,029	
	436	100		2,767		2,868	2,926	3,014	3,363	
	Subtotal			8,265		8,566	8,738	9,003	10,045	
5 Kottegoda Elevated Tank										
	456A	30		188		195	199	205	228	
	451E	50		478		495	505	521	581	
	450D	10		130		135	138	142	158	
	450C	80		694		719	733	756	843	
	450B	100		989		1,025	1,046	1,077	1,202	
	450A	70		551		571	582	600	670	
	450	100		874		906	924	952	1,062	
	445A	100		454		471	480	495	552	
	445	100		445		461	471	485	541	
	444C	100		980		1,016	1,036	1,068	1,191	
	444B	100		1,065		1,104	1,126	1,160	1,294	
	444A	100		1,480		1,534	1,565	1,612	1,799	
	444	100		1,811		1,877	1,915	1,973	2,201	
	442C	100		790		819	835	861	960	
	442B	100		815		845	862	888	991	
	442A	100		402		417	425	438	489	
	442	100		802		831	848	874	975	
	441C	100		790		819	835	861	960	
	441B	100		669		693	707	729	813	
	441A	100		841		872	889	916	1,022	
	441	100		1,261		1,307	1,333	1,374	1,533	
	440C	100		439		455	464	478	534	
	440B	100		1,147		1,189	1,213	1,249	1,394	
	440A	100		1,228		1,273	1,298	1,338	1,492	
	440	100		920		954	973	1,002	1,118	
	439	100		1,078		1,117	1,140	1,174	1,310	
	Subtotal			21,321		22,099	22,543	23,226	25,912	
6 Dickwella Elevated Tank										

No.	Service Area	GN No.		Population			Area (ha)	2005	2007	2010	2021
				1981	2001	Increase Ratio					
		455C	100		796		825	842	867	967	
		455B	100		491		509	519	535	597	
		455A	100		750		777	793	817	912	
		455	80		748		775	791	815	909	
		454A	100		757		785	800	825	920	
		454	50		683		708	722	744	830	
		452F	100		1,387		1,438	1,467	1,511	1,686	
		452E	90		1,370		1,420	1,448	1,492	1,665	
		451E	50		478		495	505	521	581	
		451D	100		1,674		1,735	1,770	1,824	2,035	
		451C	100		1,427		1,479	1,509	1,555	1,734	
		451B	100		1,654		1,714	1,749	1,802	2,010	
		451A	60		631		654	667	688	767	
		451	100		996		1,032	1,053	1,085	1,211	
		450D	90		1,174		1,216	1,241	1,278	1,426	
		450C	20		173		180	183	189	211	
		450A	30		236		245	250	257	287	
		<b>Subtotal</b>			<b>15,425</b>		<b>15,988</b>	<b>16,309</b>	<b>16,803</b>	<b>18,747</b>	
	7	Naigala Elevated Tank									
		455	20		187		194	198	204	227	
		454	50		683		708	722	744	830	
		453B	10		116		120	122	126	140	
		453	10		106		110	112	115	128	
		452E	10		152		158	161	166	185	
		452D	100		1,076		1,115	1,138	1,172	1,308	
		452C	100		822		852	869	895	999	
		452B	100		1,504		1,559	1,590	1,638	1,828	
		452A	100		993		1,029	1,050	1,082	1,207	
		452	60		806		835	852	878	979	
		451A	40		421		436	445	458	511	
		<b>Subtotal</b>			<b>6,865</b>		<b>7,116</b>	<b>7,259</b>	<b>7,479</b>	<b>8,344</b>	
	8	Medagoda Elevated Tank									
		453D	100		1,853		1,921	1,959	2,019	2,252	
		453C	100		1,165		1,208	1,232	1,269	1,416	
		453B	90		1,040		1,078	1,100	1,133	1,264	
		453A	100		1,493		1,547	1,579	1,626	1,815	
		453	90		951		986	1,006	1,036	1,156	
		452	40		537		557	568	585	653	
		<b>Subtotal</b>			<b>7,040</b>		<b>7,297</b>	<b>7,443</b>	<b>7,669</b>	<b>8,556</b>	
	9	Brownhill Reservoir 1									
		430A	40		894		927	945	974	1,087	
		429B	100		984		1,020	1,040	1,072	1,196	
		429A	100		1,330		1,379	1,406	1,449	1,616	
		427	100		1,675		1,736	1,771	1,825	2,036	
		426C	100		1,087		1,127	1,149	1,184	1,321	
		426B	100		2,504		2,595	2,648	2,728	3,043	
		425C	100		1,428		1,480	1,510	1,556	1,736	
		425B	100		1,903		1,972	2,012	2,073	2,313	
		425A	100		1,120		1,161	1,184	1,220	1,361	
		425	100		1,322		1,370	1,398	1,440	1,607	
		417G	10		335		348	355	365	408	
		417F	70		1,296		1,343	1,370	1,411	1,575	
		417B	100		1,659		1,720	1,754	1,807	2,016	
		417A	70		2,016		2,090	2,132	2,196	2,450	
		416D	100		1,286		1,333	1,360	1,401	1,563	
		416C	100		1,900		1,969	2,009	2,070	2,309	
		416B	100		1,603		1,661	1,695	1,746	1,948	
		416A	100		1,465		1,518	1,549	1,596	1,781	
		416	100		1,273		1,319	1,346	1,387	1,547	
		415	60		622		645	658	678	756	
		<b>Subtotal</b>			<b>27,702</b>		<b>28,713</b>	<b>29,290</b>	<b>30,178</b>	<b>33,668</b>	
	10	Gabadaweediya Reservoir									
		420D	100		1,457		1,510	1,541	1,587	1,771	
		420C	100		947		982	1,001	1,032	1,151	
		420B	100		719		745	760	783	874	
		420A	100		1,876		1,944	1,984	2,044	2,280	
		420	100		1,166		1,209	1,233	1,270	1,417	
		417H	100		2,076		2,152	2,195	2,262	2,523	
		417G	90		3,018		3,128	3,191	3,287	3,668	
		417F	30		555		576	587	605	675	
		417E	100		3,125		3,239	3,304	3,404	3,798	
		417D	100		2,461		2,551	2,602	2,681	2,991	
		417C	100		2,251		2,333	2,380	2,452	2,736	
		417A	30		864		896	914	941	1,050	
		<b>Subtotal</b>			<b>20,515</b>		<b>21,264</b>	<b>21,691</b>	<b>22,348</b>	<b>24,933</b>	
	11	Nupe Reservoir									
		423B	100		1,032		1,070	1,091	1,124	1,254	
		423A	100		2,123		2,200	2,245	2,313	2,580	
		423	100		946		981	1,000	1,031	1,150	
		419	100		1,857		1,925	1,963	2,023	2,257	
		415A	100		1,447		1,500	1,530	1,576	1,759	
		415	40		415		430	439	452	504	
		414C	100		2,530		2,622	2,675	2,756	3,075	
		414B	100		3,260		3,379	3,447	3,551	3,962	
		414A	100		1,114		1,155	1,178	1,214	1,354	
		414	100		3,302		3,422	3,491	3,597	4,013	



付表3. 2 2001年人口・住宅センサス

**Census of Population and Housing – 2001 District Results**

District	Population 1981	Population 2001	Growth rate per annum	Remarks
Colombo	1,699,241	2,234,289	1.38	
Gampaha	1,390,862	2,066,096	2.00	
Kalutara	829,704	1,060,800	1.24	
Kandy	1,048,317	1,272,463	0.97	
Matale	357,354	442,427	1.07	
Nuwara-Eliya	603,577	700,083	0.74	
Galle	814,531	990,539	0.98	
Matara	643,786	761,236	0.84	
Hambantota	424,344	525,370	1.07	
Jaffna	738,788	*	-	Not done
Mannar	106,235	*	-	Done in 1 DS partially out of 4 DSS
Vavuniya	95,428	*	-	Done in 3 DSS completely out of 4 DSS
Mullaitivu	77,189	*	-	Not done
Kilinochchi	91,764	*	-	Not done
Batticaloa	330,333	*	-	Done in 6 DSS completely & 2 DSS partially out of 12 DSS
Ampara	388,970	589,344	2.10	
Trincomalee	255,948	*	-	Done in 7 DSS completely & 2 DSS partially out of 11 DSS
Kucunegale	1,211,801	1,452,369	0.91	
Puttalam	492,533	705,342	1.81	
Anuradhapura	587,929	746,466	1.20	
Polonnaruwa	261,563	359,197	1.60	
Badulla	640,952	774,555	0.95	
Moneragala	273,570	396,173	1.87	
Ratnapura	797,087	1,008,164	1.18	
Kegalle	684,944	779,774	0.65	
Total	14,846,750	16,864,687		
18 districts	13,151,065	16,864,687	1.25	

\* Incomplete



付表 3 . 3 マータラ地区人口および住宅（2001年センサス）

Population and Housing Units according to D.S. Division and Sector: Matara District (2001 Census: Provisional)

D.S. Division and Sector	Total no. of persons	Sex		Age		Housing Units	Collective Living Quarters	Institutions	Non-housing Units	Total Number of Units	Per Housing Populatio
		Male	Female	Under 18 years	18 years and over						
Akuressa	49,752	24,363	25,389	16,882	32,870	13,164	15	74	1,774	15,027	3.8
Athuraliya	30,176	14,683	15,493	10,364	19,812	7,877	8	36	894	8,815	3.8
Devinuwara	44,132	20,749	23,383	15,116	29,016	10,822	13	61	1,162	12,058	4.1
Dickwella	50,952	23,912	27,040	17,842	33,110	12,453	25	51	1,722	14,251	4.1
Hakmana	30,272	14,359	15,913	11,137	19,135	7,799	13	47	902	8,761	3.9
Kamburupitiya	37,420	17,784	19,636	12,656	24,764	10,102	40	62	1,419	11,623	3.7
Kirinda Puhulwella	19,458	9,275	10,183	6,548	12,910	5,210	2	54	608	5,874	3.7
Kotapola	63,951	31,653	32,298	24,189	39,762	17,576	43	50	2,632	20,301	3.6
Malimbada	31,484	14,735	16,749	10,396	21,088	8,115	13	31	1,068	9,227	3.9
Matara Four Gravets	108,461	51,761	56,700	34,518	73,943	25,615	139	156	4,593	30,503	4.2
Mulatiyana	45,972	22,385	23,587	16,066	29,906	12,655	5	43	1,482	14,185	3.6
Pasgoda	56,188	28,214	27,974	20,650	35,538	16,660	22	75	2,270	19,027	3.4
Pitabeddara	49,313	24,534	24,779	17,625	31,688	13,784	55	42	2,025	15,906	3.6
Thihagoda	30,865	14,688	16,177	9,804	21,061	8,151	14	39	912	9,116	3.8
Weliqama	66,528	32,345	34,183	22,716	43,812	15,874	88	98	2,316	18,376	4.2
Welipitiya	46,312	21,988	24,324	15,964	30,348	11,695	23	49	1,397	13,164	4.0
<b>District Total</b>	<b>761,236</b>	<b>367,428</b>	<b>393,808</b>	<b>262,473</b>	<b>498,763</b>	<b>197,552</b>	<b>518</b>	<b>968</b>	<b>27,176</b>	<b>226,214</b>	<b>3.9</b>
<b>Study Area</b>	<b>332,422</b>	<b>158,190</b>	<b>174,232</b>	<b>110,392</b>	<b>222,030</b>	<b>81,030</b>	<b>292</b>	<b>436</b>	<b>11,773</b>	<b>93,531</b>	<b>4.1</b>



付表 3 . 5 マータラ地区用途別給水栓数および使用水量

NO. OF CONNECTIONS

Category No./Application	No. of Connections					Monthly Consumption (m <sup>3</sup> /mo)					Percentage (%)	
	Registered	Acctual	Assessed	Balance	In use	Registered	Acctual	Assessed	Balance	In use	No. of Conn.	Consump.
Domestic	36,269	33,050	2,839	380	33,402		561,090	41,485		602,575	95.3	83.0
Gov. quarters	25	21	3	1	21		340	13		353	0.1	0.0
Gov. school	113	90	21	2	107		13,679	1,309		14,988	0.3	2.0
Gov. quarters	174	115	16	43	110		2,419	139		2,558	0.3	0.0
Stand post	426	83	33	310	113		9,255	3,227		12,482	0.3	2.0
Gov. Inst.	298	219	21	58	207		34,043	541		34,584	0.6	5.0
61	5	2	1	2	2		616	0		616	0.0	0.0
62	10	7	0	3	7		2,254	0		2,254	0.0	0.0
63	20	11	2	7	13		14,706	229		14,935	0.0	2.0
Comm. Inst.	1,109	857	82	170	800		22,539	1,593		24,132	2.3	3.0
Tourist Hotel	35	28	5	2	32		1,779	696		2,475	0.1	0.0
Indust./Const.	53	23	5	25	23		3,456	1,245		4,701	0.1	1.0
Other Comm./Private Inst.	12	7	2	3	7		268	175		443	0.0	0.0
Religious Inst.	218	181	32	5	186		9,452	632		10,084	0.5	1.0
82	19	13	2	4	13		581	71		652	0.0	0.0
	38,786	34,707	3,064	1,015	35,043		676,477	51,355		727,832	100.0	100.0

Domestic	36,468	33,186	2,858	424	33,533
Non-domestic	2,318	1,521	206	591	1,510

	Normal	Unmetered	Estimated	Disconnected	Total
Domestic	34,138	0	1,969	361	36,468
Non-domestic	1,593	0	266	459	2,318


付表3. 6 浄水場取水量と配水池配水量(2002年1~7月)

Average Daily Distribution/Transmission Quantites In Meter Cubes- 2002 (m3/day)


Location	January	February	March	April	May	June	July	Average	Total A (by S.R.)	Total B (WTP)	Remark
Malimbada to Uyanwatte	18,387	20,000	18,387	18,387	18,387	18,700	18,387	18,662		18,662	Treated
Nadugala to Uyanwatte	3,981	3,308	2,421	4,803	5,100	5,166	4,650	4,204		4,204	Treated
Malimbada to Isadeen	4,825	4,857	4,277	4,440	4,341	4,398	4,251	4,484		4,484	Treated
Brownshill II	8,461	7,800	8,062	8,348	8,975	8,364	8,433	8,349			included
Brownshill I	5,873	5,447	5,039	5,926	6,504	6,423	6,335	5,935	5,935		West
Nupe E.T.	5,752	5,326	5,119	5,430	5,456	5,280	5,366	5,390	5,390		West
Gabadaweediya E.T.	3,428	3,182	3,119	3,047	2,947	2,977	2,554	3,036	3,036		West
Kamburugamuwa E.T.	2,378	2,388	2,135	2,409	2,611	2,713	2,633	2,467	2,467		West
Mirissa Hill Top	1,163	1,318	1,190	1,230	1,190	1,230	1,190	1,216	1,216		West
Malimbada Distribution	859	1,014	1,167	1,313	1,149	1,221	1,297	1,146	1,146	1,146	West
Malimbada Dist: to Matara	217	357	322	360	347	359	337	328	328	328	West
Mirissa Hill Top (Weligama)	645	563	627	662	641	662	641	634	634		West
Devinuwara E.T.	1,310	1,359	1,357	1,376	1,434	1,279	1,359	1,353	1,353		East
Gandara G.R.	1,038	1,082	1,066	1,075	1,175	1,140	1,206	1,112	1,112		East
Gandara E.T.	951	903	755	859	1,026	931	897	903	903		East
Kottegododa E.T.	1,685	1,680	1,793	1,661	1,858	1,628	1,714	1,717	1,717		East
Dickwella G.R.	4,581	4,205	3,348	4,429	4,441	4,321	3,590	4,131	4,131		East
(Kudawella G.R.)	860	803	447	507	514	520	516	595	595		East
(Dickwella E. T.)	1,182	1,323	1,194	1,226	926	955	950	1,108	1,108		East
(Naigala E. T.)	1,611	1,797	1,487	1,596	1,478	1,600		1,367	1,367		East
(Yayawatta G. R.)	544	588	364	492	524	517	435	495	495		East
Total	29,880	28,824	27,037	29,777	30,779	30,164	29,119	29,369	29,369	28,825	



## Appendix 2.1 Hydraulic Analysis on New Transmission Pipeline



Appendix Figure 3.3.2 Water Supply Volume Diagram (2007)




Appendix Figure 3.3.3 Water Supply Volume Diagram (2009)









Appendix Figure 3.3.6 Water Supply Volume Diagram (2021)

Table . Existing and Expansion Pipe Diameter and Length at Existing Pipe Seaside Route (No. 1)

Case 1 PVC

No	from	to	Capacity Limit m3/d	Hydraulic Gradient ‰	Existing		Expansion														
					2002		2007		2009		2010		2011		2021						
					Pipe Dia and Length mm m	Flow m3/d	‰	Pipe Dia and Length mm m	Flow m3/d	‰	Pipe Dia and Length mm m	Flow m3/d	‰	Pipe Dia and Length mm m	Flow m3/d	‰	Pipe Dia and Length mm m				
1	Malimbada WTP	Uyanwatta PS	21,000	3.2	DIP 500 x 10,040	15,045 OK	1.8	DIP 500 x 10,040	16,689 OK	2.1	DIP 500 x 10,040	17,700 OK	2.4	DIP 500 x 10,040	19,268 OK	2.8	DIP 500 x 10,040	32,402 NO	7.2	DIP 500 x 10,040	
		(Additional Pipe)																			DIP 450 x 10,040
		(Combine Pipe)				15,045	1.8	500 x 10,040	16,689	2.1	500 x 10,040	17,700	2.4	500 x 10,040	19,268	2.8	500 x 10,040	32,402	2.5	620 x 10,040	
2	Devinuwara Junction	Devinuwara ET	—	14.7	CIP 150 x 400	2,419 NO	20.9	CIP 150 x 400	2,609 NO	24.1	CIP 150 x 400	2,696 NO	25.6	CIP 150 x 400	2,833 NO	28.1	CIP 150 x 400	3,987 NO	52.8	CIP 150 x 400	
		(Additional Pipe)						PVC 97 x 400			PVC 97 x 400			PVC 97 x 400			PVC 97 x 400			PVC 97 x 400	
		(Combine Pipe)				2,419	12.6	167 x 400	2,609	14.5	167 x 400	2,696	15.4	167 x 400	2,833	16.8	167 x 400	3,987	2.5	280 x 400	
3	Gandara Junction	Kottegoda Junction	—	4.5	ACP 400 x 4,960	10,449 OK	2.6	ACP 400 x 4,960	11,261 OK	3.0	ACP 400 x 4,960	11,647 OK	3.2	ACP 400 x 4,960	12,242 OK	3.5	ACP 400 x 4,960	17,225 NO	6.7	ACP 400 x 4,960	
		(Additional Pipe)																			DIP 350 x 4,960
		(Combine Pipe)				10,449	2.6	400 x 4,960	11,261	3.0	400 x 4,960	11,647	3.2	400 x 4,960	12,242	3.5	400 x 4,960	17,225	2.5	490 x 4,960	
4	Kottegoda Junction	Dickwella GR	—	3.3	ACP 300 x 5,190	7,381 NO	5.6	ACP 300 x 5,190	7,955 NO	6.5	ACP 300 x 5,190	8,227 NO	6.9	ACP 300 x 5,190	8,648 NO	7.6	ACP 300 x 5,190	12,167 NO	14.2	ACP 300 x 5,190	
		(Additional Pipe)						PVC 198 x 5,190			PVC 198 x 5,190			PVC 198 x 5,190			PVC 198 x 5,190			PVC 198 x 5,190	
		(Combine Pipe)				7,381	3.3	335 x 5,190	7,955	3.8	335 x 5,190	8,227	4.0	446 x 5,190	8,648	4.4	446 x 5,190	12,167	2.1	446 x 5,190	
5	Dickwella GR	Naigala	—	2.1	ACP 200 x 2,256	3,104 NO	8.2	ACP 200 x 2,256	3,345 NO	9.4	ACP 200 x 2,256	3,459 NO	10.0	ACP 200 x 2,256	3,636 NO	11.0	ACP 200 x 2,256	5,116 NO	20.6	ACP 200 x 2,256	
		(Additional Pipe)						PVC 198 x 2,256			PVC 198 x 2,256			PVC 198 x 2,256			PVC 198 x 2,256			PVC 198 x 2,256	
		(Combine Pipe)				3,104	2.3	259 x 2,256	3,345	2.7	259 x 2,256	3,459	2.8	259 x 2,256	3,636	0.9	331 x 2,256	5,116	1.8	331 x 2,256	
6	Dickwella GR	Medagoda ET	—	5.9	PVC 200 x 4,000	2,120 OK	4.0	PVC 200 x 4,000	2,285 OK	4.6	PVC 200 x 4,000	2,364 OK	4.9	PVC 200 x 4,000	2,486 OK	5.4	PVC 200 x 4,000	3,496 NO	10.2	PVC 200 x 4,000	
		(Additional Pipe)															DIP 300 x 4,000			DIP 300 x 4,000	
		(Combine Pipe)				2,120	4.0	200 x 4,000	2,285	4.6	200 x 4,000	2,364	4.9	200 x 4,000	2,486	0.4	336 x 4,000	3,496	0.8	336 x 4,000	
7	Malimbada WTP	Isadeen GR	—	3.1	DIP 350 x 8,800	7,306 OK	2.6	DIP 350 x 8,800	7,875 OK	3.0	DIP 350 x 8,800	8,144 NO	3.2	DIP 350 x 8,800	8,560 NO	3.5	DIP 350 x 8,800	12,044 NO	6.6	DIP 350 x 8,800	
		(Additional Pipe)															DIP 300 x 8,800			DIP 300 x 8,800	
		(Combine Pipe)				7,306	2.6	350 x 8,800	7,875	3.0	350 x 8,800	8,144	1.2	425 x 8,800	8,560	1.4	425 x 8,800	12,044	2.6	425 x 8,800	

C= 120

Table . Existing and Expansion Pipe Diameter and Length at Existing Pipe Seaside Route (No. 2) Alternative Additional Pipe Plan

Case 1 PVC

No	from	to	Capacity Limit m3/d	Hydraulic Gradient ‰	Existing		Expansion													
					2002		2007		2009		2010		2011		2021					
					Pipe Dia and Length mm m	Flow m3/d	‰	Pipe Dia and Length mm m	Flow m3/d	‰	Pipe Dia and Length mm m	Flow m3/d	‰	Pipe Dia and Length mm m	Flow m3/d	‰	Pipe Dia and Length mm m			
4	Kottegoda Junction	Dickwella GR	—	3.3	ACP 300 x 5,190	7,381 NO	5.6	ACP 300 x 5,190	7,955 NO	6.5	ACP 300 x 5,190	8,227 NO	6.9	ACP 300 x 5,190	8,648 NO	7.6	ACP 300 x 5,190	12,167 NO	14.2	ACP 300 x 5,190
		(Additional Pipe)						PVC 198 x 5,190			PVC 198 x 5,190			PVC 198 x 5,190			PVC 198 x 5,190			PVC 198 x 5,190
		(Combine Pipe)				7,381	3.3	335 x 5,190	7,955	3.8	335 x 5,190	8,227	4.0	335 x 5,190	8,648	4.4	335 x 5,190	12,167	3.0	414 x 5,190
5	Dickwella GR	Naigala	—	2.1	ACP 200 x 2,256	3,104 NO	8.2	ACP 200 x 2,256	3,345 NO	9.4	ACP 200 x 2,256	3,459 NO	10.0	ACP 200 x 2,256	3,636 NO	11.0	ACP 200 x 2,256	5,116 NO	20.6	ACP 200 x 2,256
		(Additional Pipe)						DIP 300 x 2,256			DIP 300 x 2,256			DIP 300 x 2,256			DIP 300 x 2,256			DIP 300 x 2,256
		(Combine Pipe)				3,104	0.7	336 x 2,256	3,345	0.8	336 x 2,256	3,459	0.8	336 x 2,256	3,636	0.9	336 x 2,256	5,116	1.1	366 x 2,256

C= 120

Table . Expansion Pipe Diameter and Length at Expansion Pipe Inland Route (No.1)

Case 1 PVC

No	from	to	Capacity Limit m3/d	Hydraulic Gradient ‰	Expansion															
					Existing		2007		2009		2010		2011		2021					
					2002		Flow		Flow		Flow		Flow		Flow		Flow			
Pipe Dia and Length mm m		m3/d	‰	Pipe Dia and Length mm m		m3/d	‰	Pipe Dia and Length mm m		m3/d	‰	Pipe Dia and Length mm m		m3/d	‰	Pipe Dia and Length mm m		m3/d	‰	Pipe Dia and Length mm m
1	Malimbada WTP	Diagaha GR	—	2.7	DIP 450 x 14,007	14,196 OK	2.6	DIP 450 x 14,007	15,908 NO	3.2	DIP 450 x 14,007	16,359 NO	3.4	DIP 450 x 14,007	16,939 NO	3.6	DIP 450 x 14,007	21,751 NO	5.8	DIP 450 x 14,007
		(Additional Pipe)												DIP 400 x 1,400			DIP 400 x 2,500			DIP 400 x 9,900
		(Combine Pipe)												16,359	3.1	460 x 14,007	16,939	3.0	469 x 14,007	21,751
2	Diagaha GR	Gandara GR	—	5.5	DIP 400 x 6,750	10,601 OK	2.7	DIP 400 x 6,750	11,381 OK	3.1	DIP 400 x 6,750	11,513 OK	3.2	DIP 400 x 6,750	11,718 OK	3.3	DIP 400 x 6,750	13,435 OK	4.2	DIP 400 x 6,750

Table . Expansion Pipe Diameter and Length at Expansion Pipe Inland Route (No.2) Alternative Additional Pipe Plan

Case 1 PVC

No	from	to	Capacity Limit m3/d	Hydraulic Gradient ‰	Expansion															
					Existing		2007		2009		2010		2011		2021					
					2002		Flow		Flow		Flow		Flow		Flow		Flow			
Pipe Dia and Length mm m		m3/d	‰	Pipe Dia and Length mm m		m3/d	‰	Pipe Dia and Length mm m		m3/d	‰	Pipe Dia and Length mm m		m3/d	‰	Pipe Dia and Length mm m		m3/d	‰	Pipe Dia and Length mm m
1	Malimbada WTP	Diagaha GR	—	2.7	DIP 450 x 14,007	14,196 OK	2.6	DIP 450 x 14,007	15,908 NO	3.2	DIP 450 x 14,007	16,359 NO	3.4	DIP 450 x 14,007	16,939 NO	3.6	DIP 450 x 14,007	21,751 NO	5.8	DIP 450 x 14,007
		(Additional Pipe)												DIP 450 x 1,200			DIP 450 x 2,200			DIP 450 x 8,700
		(Combine Pipe)												16,359	3.0	462 x 14,007	16,939	2.9	471 x 14,007	21,751
2	Diagaha GR	Gandara GR	—	5.5	DIP 400 x 6,750	10,601 OK	2.7	DIP 400 x 6,750	11,381 OK	3.1	DIP 400 x 6,750	11,513 OK	3.2	DIP 400 x 6,750	11,718 OK	3.3	DIP 400 x 6,750	13,435 OK	4.2	DIP 400 x 6,750

Table . Maximum Capacity of Existing Pump and Required Pump Capacity

Case 1 PVC

No	Pump Station	Pump to	Unit		Capacity M <sup>3</sup> /Hr	Head m	Operation Time Hr.	Flow Rate (m <sup>3</sup> /d)		Pump Flow Rate and Pump Head																	
			Duty	Stand by				Existing M <sup>3</sup> /d	Maximum M <sup>3</sup> /d	2007		2009		2011		2021											
										m <sup>3</sup> /d	m	m <sup>3</sup> /d	m	m <sup>3</sup> /d	m	m <sup>3</sup> /d	m										
1	Uyanwatta Pumping Station	Nupe Elevated Tank	Existing	1	0	250	33	20	5000	6000	2,957	OK	33	OK	3,187	OK	33	OK	3,464	OK	36	NO	4,874	OK	36	NO	
		Gabadaweediya Elevated Tank		1	0	250	33	20	5000	6000	3,966	OK	33	OK	4,274	OK	33	OK	4,646	OK	33	OK	6,536	NO	36	NO	
		Brownshill G.R. 1 & 2		2	1	525	60	24	25200	25200	13,622	OK	60	OK	14,728	OK	60	OK	18,158	OK	60	OK	26,492	NO	60	OK	
2	Gandara Pumping Station	Gandara Elevated Tank	Existing	1	1	126	31	12	1512	3024	2,130	OK	31	OK	2,323	OK	31	OK	2,556	OK	31	OK	3,682	NO	35	NO	
3	Dickwella Pumping Station	Dickwella Elevated Tank		1	1	135	36.1	12	1620	3240	2,157	OK	36	OK	2,325	OK	36	OK	2,526	OK	36	OK	3,555	NO	36	OK	
	Dickwella Pumping Station	Medagoda Elevated Tank		1	1	68.4	61	12	821	1642	2,120	NO	78	NO	2,285	NO	78	NO	2,486	NO	78	NO	3,496	NO	78	NO	
1	Uyanwatta Pumping Station	Nupe Elevated Tank	Proposed	1	1	250	36	24	-	6000									6,000	OK	36	OK	6,000	OK	36	OK	
		Gabadaweediya Elevated Tank		1	1	350	36	24	-	8400																	
		Brownshill G.R. 1 & 2		2	1	650	60	24	-	31200																	
2	Gandara Pumping Station	Gandara Elevated Tank	Proposed	1	1	200	35	24	-	4800																	
3	Dickwella Pumping Station	Dickwella Elevated Tank		1	1	200	36	24	-	4800																	
	Dickwella Pumping Station	Medagoda Elevated Tank		1	1	140	78	24	-	3360	3,360	OK	78	OK	3,360	OK	78	OK	3,360	OK	78	OK	3,360	OK	78	OK	
				1	1	70	78	24	-	1680																	

- (注)
- 1 既存ポンプ揚程はポンプ回り配管ロスを3mとみなし、ポンプ本体仕様を示される揚程から3mを引いたものをポンプ揚程とした。
  - 2 既存ポンプ能力は揚水量と揚程により決まる。従って、ポンプの交換時期は揚水量または揚程が満たない場合にポンプの追加又は交換を行うものとした。
  - 3 既存ポンプにおいて二重枠で囲まれている部分はポンプ能力(ポンプ揚水量又は揚程)が不足していることを示し、その年度までにポンプの交換を必要とする。
  - 4 交換するポンプの仕様及び交換を必要とする年度を計画(Proposed)内に示す。

Case 6 Existing Transmission Line Hydraulic Calculation (2007)

without Gandara

Case 1

C= 120

PVC

Total Q= 43.972 m<sup>3</sup>/d (= 27.500 + 5.500 + 10.972 m<sup>3</sup>/d)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark	
1	Malimboda WTP	24.276					LWL	36.40		Clear Water Re.	
2	Uyanwatta PS	15.045	500	10040	1.8	18.1	HWL	2.90	OK	Gravity Flow	
201	Uyanwatta PS						WL	29.90		Pump Head 33 m LWL -0.10 m	
3	Gabadaweediya Elevated Tank	3.966	300	500	1.8	0.9	HWL	27.65	OK	from 201	
202	Uyanwatta PS						WL	29.90		Pump Head 33 m LWL -0.10 m	
4	Nupe Elevated Tank	2.957	300	2000	1.0	2.0	HWL	27.29	OK	from 202 LWL 24.29 m	
204	Uyanwatta PS						WL	56.90		Pump Head 60 m LWL -0.10 m	
5	Brownshill Reservoir 1	7.754	500	2000	0.5	1.0	HWL	47.3	OK	from 204	
205	Uyanwatta PS						WL	56.90		Pump Head 60 m LWL -0.10 m	
6	Brownshill Reservoir 2	5.868	500	2000	0.3	0.6	HWL	47.3	OK	from 205 LWL 43.90 m	
7	Devinuwara Bulk Meter	5.868	500	3320	0.3	1.0	42.9				
8	Devinuwara Junction	5.868	450	900	0.5	0.5	42.5				
9	Devinuwara Elevated Tank	2.419	167	400	12.6	5.0	HWL	31.95	OK	LWL 26.68 m	
10	Gandara Junction	3.449	450	4090	0.2	0.8	41.64			150 Add + 97	
11	Gandara Ground Reservoir	0	225	400	0.0	0.0	41.64	HWL	30.53	OK	
11	Gandara Ground Reservoir						WL	54.31		Pump Head 31 m LWL 26.31 m	
12	Gandara Elevated Tank	0	150	80	0.0	0.0	54.31	HWL	54.00	OK	from 11
13	Kottegoda Junction	10.449	400	4960	2.6	12.9	28.7			from 10	
14	Kottegoda Ground Sump	3.068	400	80	0.3	0.0	28.72	HWL	14.20	OK	
14	Kottegoda Ground Sump						WL	39.20		Pump Head 31 m LWL 11.20 m	
15	Kottegoda Elevated Tank	3.068	300	29	1.1	0.0	39.2	HWL	35.50	OK	from 14
16	Dickwella Ground Reservoir	7.381	335	5190	3.1	16.1	12.7	HWL	5.05	OK	from 13 300 Add + 198
16	Dickwella Ground Reservoir						WL	34.35		Pump Head 36.1 m LWL 1.25 m	
17	Dickwella Elevated Tank	2.157	200	80	4.2	0.3	34.0	HWL	32.00	OK	from 16
16	Dickwella Ground Reservoir						WL	68.45		Pump Head 70.2 m LWL 54.50 m	
18	Naigala Elevated Tank	3.104	259	2256	2.2	5.0	63.5	HWL	60.00	OK	200 Add + 198
19	Kudawella Ground Reservoir	1.158	160	6000	3.9	23.4	40.1	HWL	-	-	No data
20	Yayawatta Ground Reservoir	963	160	4400	2.8	12.3	27.8	HWL	-	-	No data
16	Dickwella Ground Reservoir						HWL	76.25		Pump Head 61 m → 78 m LWL 1.25 m	
21	Medagoda Elevated Tank	2.120	200	4000	4.0	16.0	60.25	HWL	52.75	OK	34.95 m
22	Isadeen Ground Reservoir	7.306	350	8800	2.6	22.9	13.5	HWL	5.8	OK	from 1 LWL 2.10 m
23	Malimboda contact Tank	1.925	200	20	3.4	0.1	36.3	HWL	36	OK	from 1
24	Nadugara WTP						WL	34.00		Pump Head 25 m LWL 12.00 m	
2	Uyanwatta PS	5.500	350	5000	1.5	7.5	26.5	HWL	2.90	OK	

Note

C= 120 ( C= 125 )

The Quantity rate of Nupe ET from Uyanwatta is 42 %  
 Pump (Uyanwatta-Nupe ET) 135 m<sup>3</sup>/h 18 h = 2430 m<sup>3</sup>/d  
 Nupe E.T. 5752 m<sup>3</sup>/d  
 Water demand increase rate 16469 / 12977 1.269  
 Existing demand 12977 m<sup>3</sup>/d  
 2007 year demand 16469 m<sup>3</sup>/d  
 Proposed transmission line flow rate (Tot) 10601 m<sup>3</sup>/d  
 East side from Existing Gandara 7000 m<sup>3</sup>/d  
 Gandara Ground Reservoir 1987 m<sup>3</sup>/d  
 Gandara Elevated Tank 1614 m<sup>3</sup>/d  
 Isadeen Flow rate  
 Nupe E.T.\*0.58 4083 m<sup>3</sup>/d (2007)  
 Kamburuganawa ET 3223 m<sup>3</sup>/d (2007)  
 Total 7306 m<sup>3</sup>/d (2007)

Proposed Transmission Line (from Diyagaha Ground Reservoir to Gandara Junction 20+437)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark	
	Proposed Diyagaha Reservoir						LWL	66.00		HWL 72.00 m	
		10.601	400	5500	2.7	14.9	51.15			Total Length	
10	Gandara Junction	10.601	400	1250	2.7	3.4	47.78	HWL	41.64	OK	6750 m

Proposed Transmission Line (from Diyagaha Ground Reservoir to Gandara Junction 20+437)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark	
	Proposed Diyagaha Reservoir						LWL	66.00		HWL 72.00 m	
		10.601	400	5650	2.7	15.3	50.75			Total Length	
10	Gandara Junction	10.601	350	1100	5.2	5.7	45.03	HWL	41.64	OK	6750 m

Proposed Transmission Line (from Malimboda WTP to Diyagaha Ground Reservoir)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark	
							HWL	112.00		Total Length 14007 m LWL 36.00 m	
100	Proposed Diyagaha Reservoir	14.196	450	11307	2.6	29.4	82.60				
100	Proposed Diyagaha Reservoir	14.196	450	2700	2.6	7.0	75.58	HWL	72.00	OK	Pump Head 79 m HWL 72.00 m

Proposed Transmission Line (from Malimboda WTP to Diyagaha Ground Reservoir)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark	
							HWL	120.00		Total Length 14007 m LWL 36.00 m	
100	Proposed Diyagaha Reservoir	14.196	450	10007	2.6	26.0	93.98				
100	Proposed Diyagaha Reservoir	14.196	400	4000	4.7	18.8	75.18	HWL	72.00	OK	Pump Head 87 m HWL 72.00 m

Note:

Flow rate (Total) 14196 m<sup>3</sup>/d = 0.16431 m<sup>3</sup>/s  
 Diyagaha East of Diyagaha ( 2135 + 1460 = 3595 m<sup>3</sup>/d )  
 Diyagaha Distribution rate 3595 m<sup>3</sup>/d  
 Transmission flow rate 10601 m<sup>3</sup>/d

Case 7 Existing Transmission Line Hydraulic Calculation (2009) without Gandara Case 1 C=120 PVC  
 Total Q= 48,047 m<sup>3</sup>/d (= 27,500 + 5,500 + 15,047 m<sup>3</sup>/d)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark
1	Malimboda WTP	26.639					LWL	36.40		Clear Water Re.
2	Uyanwatta PS	16.689	500	10040	2.1	21.1	HWL	2.90	OK	Gravity Flow 500 Add + 0
201	Uyanwatta PS						WL	29.90		Pump Head 33 m LWL -0.10 m
3	Gabadaweediya Elevated Tank	4.274	300	500	2.1	1.1	HWL	27.65	OK	from 201
202	Uyanwatta PS						WL	29.90		Pump Head 33 m LWL -0.10 m
4	Nupe Elevated Tank	3.187	300	2000	1.2	2.4	HWL	27.29	OK	from 202 LWL 24.29 m
204	Uyanwatta PS						WL	56.90		Pump Head 60 m LWL -0.10 m
5	Brownhill Reservoir 1	8.358	500	2000	0.6	1.2	HWL	47.3	OK	from 204
205	Uyanwatta PS						WL	56.90		Pump Head 60 m LWL -0.10 m
6	Brownhill Reservoir 2	6.370	500	2000	0.4	0.8	HWL	47.3	OK	from 205 LWL 43.90 m
7	Devinuwara Bulk Meter	6.370	500	3320	0.4	1.3	HWL	42.6		
8	Devinuwara Junction	6.370	450	900	0.6	0.5	HWL	42.0		
9	Devinuwara Elevated Tank	2.609	167	400	14.5	5.8	HWL	31.95	OK	LWL 26.68 m 150 Add + 97
10	Gandara Junction	3.761	450	4090	0.2	0.8	HWL	41.21		from 8+from proposed Re 7500 m <sup>3</sup> /d
11	Gandara Ground Reservoir	0	225	400	0.0	0.0	HWL	41.21	OK	
11	Gandara Ground Reservoir						WL	54.31		Pump Head 31 m LWL 26.31 m
12	Gandara Elevated Tank	0	150	80	0.0	0.0	HWL	54.00	OK	from 11
13	Kottogoda Junction	11.261	400	4960	3.0	14.9	HWL	26.3		from 10
14	Kottogoda Ground Sump	3.306	400	80	0.3	0.0	HWL	14.20	OK	
14	Kottogoda Ground Sump						WL	39.20		Pump Head 31 m LWL 11.20 m
15	Kottogoda Elevated Tank	3.306	300	29	1.3	0.0	HWL	35.50	OK	from 14
16	Dickwella Ground Reservoir	7.955	335	5190	3.5	18.2	HWL	5.05	OK	from 13 300 Add + 198
16	Dickwella Ground Reservoir						WL	34.35		Pump Head 36.1 m LWL 1.25 m
17	Dickwella Elevated Tank	2.325	200	80	4.8	0.4	HWL	32.00	OK	from 16
16	Dickwella Ground Reservoir						WL	68.45		Pump Head 70.2 m LWL 54.50 m
18	Naigala Elevated Tank	3.345	259	2256	2.5	5.6	HWL	60.00	OK	200 Add + 198
19	Kudawella Ground Reservoir	1.248	160	6000	4.5	27.0	HWL	-	-	No data
20	Yayawatta Ground Reservoir	1.038	160	4400	3.2	14.1	HWL	-	-	No data
16	Dickwella Ground Reservoir						HWL	76.25		Pump Head 61 m → 78 m LWL 1.25 m
21	Medagoda Elevated Tank	2.285	200	4000	4.6	18.4	HWL	52.75	OK	34.95 m
22	Isadeen Ground Reservoir	7.875	350	8800	3.0	26.4	HWL	5.8	OK	from 1 LWL 2.10 m Dia. 350 Add + 0
23	Malimboda contact Tank	2.075	200	20	3.9	0.1	HWL	36	OK	from 1
24	Nadugara WTP						WL	34.00		Pump Head 25 m LWL 12.00 m
2	Uyanwatta PS	5.500	350	5000	1.5	7.5	HWL	2.90	OK	

Note C=120 (C=125)  
 The Quantity rate of Nupe ET from Uyanwatta is 42 %  
 Pump (Uyanwatta-Nupe ET) 135 m<sup>3</sup>/h 18 h = 2430 m<sup>3</sup>/d  
 Nupe E.T. 5752 m<sup>3</sup>/d  
 Water demand increase rate 17751 / 12977 = 1.368  
 Existing demand 12977 m<sup>3</sup>/d  
 2007 year demand 17751 m<sup>3</sup>/d  
 Proposed transmission line flow rate (Tot) 11381 m<sup>3</sup>/d  
 East side from Existing Gandara 7500 m<sup>3</sup>/d  
 Gandara Ground Reservoir 2141 m<sup>3</sup>/d  
 Gandara Elevated Tank 1740 m<sup>3</sup>/d  
 Isadeen Flow rate  
 Nupe E.T.\*0.58 4401 m<sup>3</sup>/d  
 Kamburuganawa ET 3474 m<sup>3</sup>/d  
 Total 7875 m<sup>3</sup>/d

Proposed Transmission Line (from Diyagaha Ground Reservoir to Gandara Junction 20+437)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark
	Proposed Diyagaha Reservoir						LWL	68.00		HWL 72.00 m
		11.381	400	3000	3.1	9.3	HWL	58.70		Total Length
10	Gandara Junction	11.381	400	3750	3.1	11.6	HWL	47.08	OK	6750 m 400 Add + 0

Proposed Transmission Line (from Diyagaha Ground Reservoir to Gandara Junction 20+437)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark
	Proposed Diyagaha Reservoir						LWL	68.00		HWL 72.00 m
		11.381	400	6000	3.1	18.6	HWL	49.40		Total Length
10	Gandara Junction	11.381	350	750	5.9	4.4	HWL	41.21	OK	6750 m

Proposed Transmission Line (from Malimboda WTP to Diyagaha Ground Reservoir)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark
							HWL	120.00		Total Length 14007 m LWL 36.00 m
		15.908	450	9000	3.2	28.8	HWL	91.20		Pump Head 87 m LWL 72.00 m
100	Proposed Diyagaha Reservoir	15.908	450	5007	3.2	16.0	HWL	72.00	OK	450 Add + 0

Proposed Transmission Line (from Malimboda WTP to Diyagaha Ground Reservoir)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark
							HWL	112.00		Total Length 14007 m LWL 36.00 m
		15.908	450	10507	3.2	33.6	HWL	78.38		Pump Head 79 m LWL 72.00 m
100	Proposed Diyagaha Reservoir	15.908	586	3500	0.9	3.2	HWL	75.23	OK	450 Add + 450

Note: Flow rate (Total) 15908 m<sup>3</sup>/d = 0.18412 m<sup>3</sup>/s  
 Diyagaha Distribution rate 4527 m<sup>3</sup>/d  
 Transmission flow rate 11381 m<sup>3</sup>/d  
 Diyagaha East of Diyagaha (2688 + 1839) = 4527 m<sup>3</sup>/d

Case 8 Existing Transmission Line Hydraulic Calculation (2010) without Gandara Case 1 C=120 PVC  
 Total Q= 49,849 m<sup>3</sup>/d (= 27,500 + 5,500 + 16,849 m<sup>3</sup>/d)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark
1	Malimboda WTP	27,990					LWL	36.40		Clear Water Re.
2	Uyanwatta PS	17,700	500	10040	2.4	24.1	12.3	HWL	2.90	OK Gravity Flow 500 Add + 0
201	Uyanwatta PS						WL	29.90		Pump Head 33 m LWL -0.10 m
3	Gabadaweediya Elevated Tank	4,420	300	500	2.2	1.1	28.8	HWL	27.65	OK from 201
202	Uyanwatta PS						WL	29.90		Pump Head 33 m LWL -0.10 m
4	Nupe Elevated Tank	3,296	300	2000	1.3	2.6	27.30	HWL	27.29	OK from 202 LWL 24.29 m
204	Uyanwatta PS						WL	56.90		Pump Head 60 m LWL -0.10 m
5	Brownshill Reservoir 1	8,641	500	2000	0.6	1.2	55.7	HWL	47.3	OK from 204
205	Uyanwatta PS						WL	56.90		Pump Head 60 m LWL -0.10 m
6	Brownshill Reservoir 2	6,843	500	2000	0.4	0.8	56.1	HWL	47.3	OK from 205 LWL 43.90 m
7	Devinuwara Bulk Meter	6,843	500	3320	0.4	1.3	42.6			
8	Devinuwara Junction	6,843	450	900	0.7	0.6	41.9			
9	Devinuwara Elevated Tank	2,696	167	400	15.4	6.2	35.8	HWL	31.95	OK LWL 26.68 m
10	Gandara Junction	4,147	450	4090	0.3	1.2	40.72			from 8+from proposed Re 7500 m <sup>3</sup> /d
11	Gandara Ground Reservoir	0	225	400	0.0	0.0	40.72	HWL	30.53	OK
11	Gandara Ground Reservoir						WL	54.31		Pump Head 31 m LWL 26.31 m
12	Gandara Elevated Tank	0	150	80	0.0	0.0	54.31	HWL	54.00	OK from 11
13	Kottogoda Junction	11,647	400	4960	3.2	15.9	24.8			from 10
14	Kottogoda Ground Sump	3,420	400	80	0.3	0.0	24.82	HWL	14.20	OK
14	Kottogoda Ground Sump	8,227					WL	39.20		Pump Head 31 m LWL 11.20 m
15	Kottogoda Elevated Tank	3,420	300	29	1.4	0.0	39.2	HWL	35.50	OK from 14
16	Dickwella Ground Reservoir	8,227	446	5190	1.0	5.2	19.7	HWL	5.05	OK from 13 ACP 300 198 Add + 350
16	Dickwella Ground Reservoir						WL	34.35		Pump Head 36.1 m LWL 1.25 m
17	Dickwella Elevated Tank	2,404	200	80	5.1	0.4	33.9	HWL	32.00	OK from 16 LWL 1.25 m
16	Dickwella Ground Reservoir						WL	68.45		Pump Head 70.2 m LWL 54.50 m
18	Naigala Elevated Tank	3,459	259	2256	2.6	5.9	62.6	HWL	60.00	OK 200 Add + 198
19	Kudawella Ground Reservoir	1,291	160	6000	4.8	28.8	33.8	HWL	-	No data
20	Yayawatta Ground Reservoir	1,073	160	4400	3.4	15.0	18.8	HWL	-	No data
16	Dickwella Ground Reservoir						HWL	76.25		Pump Head 61 m → 78 m LWL 1.25 m
21	Medagoda Elevated Tank	2,364	200	4000	4.9	19.6	56.65	HWL	52.75	OK from 1 LWL 34.95 m
22	Isadeen Ground Reservoir	8,144	425	8800	1.2	10.6	25.8	HWL	5.8	OK from 1 LWL 2.10 m
23	Malimboda contact Tank	2,146	200	20	4.1	0.1	36.3	HWL	36	OK from 1 Dia. 350 Add + 300
24	Nadugara WTP						WL	34.00		Pump Head 25 m LWL 12.00 m
2	Uyanwatta PS	5,500	350	5000	1.5	7.5	26.5	HWL	2.90	OK

Note C=120 (C=123) (C=125)

The Quantity rate of Nupe ET from Uyanwatta is 42 %  
 Pump (Uyanwatta-Nupe ET) 135 m<sup>3</sup>/h 18 h = 2430 m<sup>3</sup>/d  
 Nupe E.T. 5752 m<sup>3</sup>/d  
 Water demand increase rate 18356 / 12977 = 1.415  
 Existing demand 12977 m<sup>3</sup>/d  
 2007 year demand 18356 m<sup>3</sup>/d  
 Proposed transmission line flow rate (Tot) 11513 m<sup>3</sup>/d  
 East side from Existing Gandara 7500 m<sup>3</sup>/d  
 Gandara Ground Reservoir 2214 m<sup>3</sup>/d  
 Gandara Elevated Tank 1799 m<sup>3</sup>/d  
 Isadeen Flow rate  
 Nupe E.T.\*0.58 4551 m<sup>3</sup>/d  
 Kamburuganawa ET 3593 m<sup>3</sup>/d  
 Total 8144 m<sup>3</sup>/d

Proposed Transmission Line (from Diyagaha Ground Reservoir to Gandara Junction 20+437)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark
	Proposed Diyagaha Reservoir						LWL	68.00		HWL 72.00 m
		11,513	400	2000	3.2	6.4	61.60			Total Length
10	Gandara Junction	11,513	400	4750	3.2	15.2	46.40	HWL	40.72	OK 6750 m 400 Add + 0

Proposed Transmission Line (from Diyagaha Ground Reservoir to Gandara Junction 20+437)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark
	Proposed Diyagaha Reservoir						LWL	68.00		HWL 72.00 m
		11,513	400	6000	3.2	19.2	48.80			Total Length
10	Gandara Junction	11,513	350	750	6.1	4.6	44.23	HWL	40.72	OK 6750 m 400 Add + 0

Proposed Transmission Line (from Malimboda WTP to Diyagaha Ground Reservoir)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark
							HWL	120.00		Total Length 14007 m LWL 36.00 m
		16,359	450	12807	3.4	43.5	76.46			Pump Head 87 m HWL 72.00 m
100	Proposed Diyagaha Reservoir	16,359	586	1200	0.9	1.1	75.38	HWL	72.00	OK 450 Add + 450

Proposed Transmission Line (from Malimboda WTP to Diyagaha Ground Reservoir)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark
							HWL	120.00		Total Length 14007 m LWL 36.00 m
		16,359	450	12607	3.4	42.9	77.14			Pump Head 87 m HWL 72.00 m
100	Proposed Diyagaha Reservoir	16,359	555	1400	1.2	1.7	75.46	HWL	72.00	OK 450 Add + 400

Note: Flow rate (Total) 16358.99 m<sup>3</sup>/d = 0.18934 m<sup>3</sup>/s Diyagaha East of Diyagaha (2877 + 1969 = 4845.988 m<sup>3</sup>/d)  
 Diyagaha Distribution rate 4845.988 m<sup>3</sup>/d  
 Transmission flow rate 11513 m<sup>3</sup>/d



Case 9 Existing Transmission Line Hydraulic Calculation (2011) without Gandara Case 1 C=120 PVC  
 Total Q= 52,522 m<sup>3</sup>/d (= 27,500 + 5,500 + 19,522 m<sup>3</sup>/d)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark
1	Malimboda WTP	30.083					LWL 36.40			Clear Water Re.
2	Uyanwatta PS	19.268	500	10040	2.8	28.1	HWL 8.3	2.90	OK	Gravity Flow 500 Add + 0
201	Uyanwatta PS						WL 29.90			Pump Head 33 m LWL -0.10 m
3	Gabadaweediya Elevated Tank	4.646	300	500	2.4	1.2	HWL 28.7	27.65	OK	from 201
202	Uyanwatta PS						WL 32.90			Pump Head 33 m → 36 m LWL -0.10 m
4	Nupe Elevated Tank	3.464	300	2000	1.4	2.8	HWL 30.1	27.29	OK	from 202 LWL 24.29 m
204	Uyanwatta PS						WL 56.90			Pump Head 60 m LWL -0.10 m
5	Brownhill Reservoir 1	9.083	500	2000	0.7	1.4	HWL 55.5	47.3	OK	from 204
205	Uyanwatta PS						WL 56.90			Pump Head 60 m LWL -0.10 m
6	Brownhill Reservoir 2	7.575	500	2000	0.5	1.0	HWL 55.9	47.3	OK	from 205 LWL 43.90 m
7	Devinuwara Bulk Meter	7.575	500	3320	0.5	1.7	42.2			
8	Devinuwara Junction	7.575	450	900	0.8	0.7	41.5			
9	Devinuwara Elevated Tank	2.833	167	400	16.8	6.7	HWL 34.80	31.95	OK	LWL 26.68 m 150 Add + 97
10	Gandara Junction	4.742	450	4090	0.3	1.2	40.29			from 8+from proposed Re 7500 m <sup>3</sup> /d
11	Gandara Ground Reservoir	0	225	400	0.0	0.0	HWL 40.29	30.53	OK	
11	Gandara Ground Reservoir						WL 54.31			Pump Head 31 m LWL 26.31 m
12	Gandara Elevated Tank	0	150	80	0.0	0.0	HWL 54.31	54.00	OK	from 11
13	Kottogoda Junction	12.242	400	4960	3.5	17.4	22.9			from 10
14	Kottogoda Ground Sump	3.594	400	80	0.4	0.0	HWL 22.90	14.20	OK	
14	Kottogoda Ground Sump	8.648					WL 39.20			Pump Head 31 m LWL 11.20 m
15	Kottogoda Elevated Tank	3.594	300	29	1.5	0.0	HWL 39.2	35.50	OK	from 14
16	Dickwella Ground Reservoir	8.648	446	5190	1.0	5.2	HWL 17.7	5.05	OK	from 13 ACP 300 198 Add + 350
16	Dickwella Ground Reservoir						WL 34.35			Pump Head 36.1 m LWL 1.25 m
17	Dickwella Elevated Tank	2.526	200	80	5.6	0.4	HWL 33.9	32.00	OK	from 16 LWL 1.25 m
16	Dickwella Ground Reservoir						WL 68.45			Pump Head 70.2 m LWL 54.50 m
18	Naigala Elevated Tank	3.636	295	2256	1.6	3.6	HWL 64.8	60.00	OK	200 198 Add + 250
19	Kudawella Ground Reservoir	1.356	235	6000	0.8	4.8	60.0	HWL -	-	No data 160 Add + 198
20	Yayawatta Ground Reservoir	1.128	235	4400	0.6	2.6	HWL -	-	-	No data 160 Add + 198
16	Dickwella Ground Reservoir						HWL 76.25			Pump Head 61 m → 78 m LWL 1.25 m
21	Medagoda Elevated Tank	2.486	220	4000	3.4	13.6	HWL 62.7	52.75	OK	34.95 m
22	Isadeen Ground Reservoir	8.560	425	8800	1.4	12.3	HWL 24.1	5.8	OK	from 1 LWL 2.10 m 200 Add + 123 Dia. 350 Add + 300
23	Malimboda contact Tank	2.255	200	20	4.5	0.1	HWL 36.3	36	OK	from 1
24	Nadugara WTP						WL 34.00			Pump Head 25 m LWL 12.00 m
2	Uyanwatta PS	5.500	350	5000	1.5	7.5	HWL 26.5	2.90	OK	

Note C=120 (C=123) (C=125)  
 The Quantity rate of Nupe ET from Uyanwatta is 42 %  
 Pump (Uyanwatta-Nupe ET) 135 m<sup>3</sup>/h 18 h = 2430 m<sup>3</sup>/d  
 Nupe E.T. 5752 m<sup>3</sup>/d  
 Water demand increase rate 19293 / 12977 = 1.487  
 Existing demand 12977 m<sup>3</sup>/d  
 2007 year demand 19293 m<sup>3</sup>/d  
 Proposed transmission line flow rate (Tot) 11718 m<sup>3</sup>/d  
 East side from Existing Gandara 7500 m<sup>3</sup>/d  
 Gandara Ground Reservoir 2327 m<sup>3</sup>/d  
 Gandara Elevated Tank 1891 m<sup>3</sup>/d  
 Isadeen Flow rate  
 Nupe E.T.\*0.58 4784 m<sup>3</sup>/d  
 Kamburuganawa ET 3776 m<sup>3</sup>/d  
 Total 8560 m<sup>3</sup>/d

Proposed Transmission Line (from Diyagaha Ground Reservoir to Gandara Junction 20+437)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark
	Proposed Diyagaha Reservoir						LWL 68.00			HWL 72.00 m
10	Gandara Junction	11.718	400	3000	3.3	9.9	58.10			Total Length 6750 m
		11.718	400	3750	3.3	12.4	45.73	HWL 40.29	OK	400 Add + 0

Proposed Transmission Line (from Diyagaha Ground Reservoir to Gandara Junction 20+437)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark
	Proposed Diyagaha Reservoir						LWL 68.00			HWL 72.00 m
10	Gandara Junction	11.718	400	6000	3.3	19.8	48.20			Total Length 6750 m
		11.718	350	750	6.3	4.7	43.48	HWL 40.29	OK	

Proposed Transmission Line (from Malimboda WTP to Diyagaha Ground Reservoir)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark
							HWL 120.00			Total Length 14007 m LWL 36.00 m
100	Proposed Diyagaha Reservoir	16.939	450	11807	3.6	42.5	77.49			Pump Head 87 m HWL 72.00 m
		16.939	586	2200	1.0	2.2	75.29	HWL 72.00	OK	450 Add + 450

Proposed Transmission Line (from Malimboda WTP to Diyagaha Ground Reservoir)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark
							HWL 120.00			Total Length 14007 m LWL 36.00 m
100	Proposed Diyagaha Reservoir	16.939	555	2500	1.3	3.3	75.32	HWL 72.00	OK	450 Add + 400

Note: Flow rate (Total) 16939 m<sup>3</sup>/d = 0.19606 m<sup>3</sup>/s  
 Diyagaha East of Diyagaha (3101 + 2120 = 5221 m<sup>3</sup>/d)  
 Diyagaha Distribution rate 5221 m<sup>3</sup>/d  
 Transmission flow rate 11718 m<sup>3</sup>/d

Case 10 Existing Transmission Pipe Line Hydraulic Calculation (2021)

without Gandara Case 1 C= 120 PVC  
 (= 27,500 + 5,500 + 15,000 m<sup>3</sup>/d + 26,870 m<sup>3</sup>/d)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia. mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark
1	Malimboda WTP	47,619					LWL	36.40		Clear Water Re.
2	Uyanwatta PS	32,402	620	10040	2.5	25.1	11.3	HWL	2.90	OK
										Gravity Flow 500 Add + 450 mm
201	Uyanwatta PS						WL	32.90		Pump Head 33 m → 36 m LWL -0.10 m
3	Gabadaweediya Elevated Tank	6,536	300	500	4.5	2.3	30.7	HWL	27.65	OK
										from 201
202	Uyanwatta PS						WL	32.90		Pump Head 33 m → 36 m LWL -0.10 m
4	Nupe Elevated Tank	4,874	300	2000	2.6	5.2	27.7	HWL	27.29	OK
										from 202
204	Uyanwatta PS						WL	56.90		Pump Head 60 m LWL -0.10 m
5	Brownshill Reservoir 1	12,780	500	2000	1.3	2.6	54.3	HWL	47.3	OK
										from 204
205	Uyanwatta PS						WL	56.90		Pump Head 60 m LWL -0.10 m
6	Brownshill Reservoir 2	13,712	500	2000	1.5	3.0	53.9	HWL	47.3	OK
7	Devinuwara Bulk Meter	13,712	500	3320	1.5	5.0	38.9	HWL		
8	Devinuwara Junction	13,712	450	900	2.5	2.3	36.7	HWL		
9	Devinuwara Elevated Tank	3,987	280	400	2.5	1.0	35.7	HWL	31.95	OK
										LWL 26.68 m
10	Gandara Junction	9,725	450	4090	1.3	5.3	31.4	HWL		
11	Gandara Ground Reservoir	0	225	400	0.0	0.0	31.35	HWL	30.53	OK
										from 8+from proposed Re 7500 m <sup>3</sup> /d
										Distribution from New Transmission Pipe
11	Gandara Ground Reservoir						WL	58.31		Pump Head 31 m → 35 m LWL 26.31 m
12	Gandara Elevated Tank	0	150	80	0.0	0.0	58.31	HWL	54.00	OK
										from 11
13	Kottogoda Junction	17,225	490	4960	2.5	12.4	19.0	HWL		
14	Kottogoda Ground Sump	5,058	400	80	0.7	0.1	18.90	HWL	14.20	OK
										from 10 400 Add + 350
14	Kottogoda Ground Sump						WL	39.20		Pump Head 31 m LWL 11.20 m
15	Kottogoda Elevated Tank	5,058	300	29	2.8	0.1	39.1	HWL	35.50	OK
										from 14
16	Dickwella Ground Reservoir	12,167	446	5190	2.0	10.4	8.6	HWL	5.05	OK
										from 13 300 198 Add + 350
16	Dickwella Ground Reservoir						WL	34.35		Pump Head 36.1 m LWL 1.25 m
17	Dickwella Elevated Tank	3,555	200	80	10.5	0.8	33.5	HWL	32.00	OK
										from 16
16	Dickwella Ground Reservoir						WL	68.45		Pump Head 70.2 m LWL 1.25 m
18	Naigala Elevated Tank	5,116	295	2256	3.0	6.8	61.7	HWL	60.00	OK
19	Kudawella Ground Reservoir	1,909	235	6000	1.5	9.0	52.7	HWL	-	-
20	Yayawatta Ground Reservoir	1,588	235	4400	1.1	4.8	47.8	HWL	-	-
										No data 160 Add + 198
16	Dickwella Ground Reservoir						WL	59.25		Pump Head 61 m → 78 m LWL 1.25 m
21	Medagoda Elevated Tank	3,496	336	4000	0.8	3.2	56.1	HWL	52.75	OK
										from 1 350 Add + 300
22	Isadeen Ground Reservoir	12,044	425	8800	2.6	22.9	13.5	HWL	5.8	OK
										from 1
23	Malimboda contact Tank	3,173	200	20	8.5	0.2	36.2	HWL	36	OK
										from 1
24	Nadugara WTP						WL	34.00		Pump Head 25 m LWL 12.00 m
2	Uyanwatta PS	5,500	350	5000	1.5	7.5	26.5	HWL	2.90	OK

Note C= 120 (C= 123)  
 The Quantity rate of Nupe ET from Uyanwatta is 42 %  
 Pump (Uyanwatta-Nupe ET) 135 m<sup>3</sup>/h 18 h = 2430 m<sup>3</sup>/d  
 Nupe E.T. 5752 m<sup>3</sup>/d  
 Water demand increase rate 27147 / 12977 = 2.092  
 Existing demand 12977 m<sup>3</sup>/d  
 2007 year demand 27147 m<sup>3</sup>/d  
 Proposed transmission line flow rate (Total) 13435 m<sup>3</sup>/d  
 East side from Existing Gandara 7500 m<sup>3</sup>/d  
 Gandara Ground Reservoir 3275 m<sup>3</sup>/d  
 Gandara Elevated Tank 2660 m<sup>3</sup>/d  
 Isadeen Flow rate  
 Nupe E.T.\*0.58 6731 m<sup>3</sup>/d (2021)  
 Kamburaganuwa ET 5313 m<sup>3</sup>/d (2021)  
 Total 12044 m<sup>3</sup>/d (2021)

Proposed Transmission Line (from Diyagaha Ground Reservoir to Gandara Junction 20+437)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia. mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark
	Proposed Diyagaha Reservoir						LWL	68.00		HWL 72.00 m
		13,435	400	6500	4.2	27.3	40.70			Total Length
10	Gandara Junction	13,435	400	250	4.2	1.1	39.65	HWL	31.35	OK
										6750 m

Proposed Transmission Line (from Diyagaha Ground Reservoir to Gandara Junction 20+437)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia. mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark
	Proposed Diyagaha Reservoir						LWL	68.00		HWL 72.00 m
		13,435	400	5500	4.2	23.1	44.90			Total Length
10	Gandara Junction	13,435	350	1250	8.1	10.1	34.78	HWL	31.35	OK
										6750 m

Proposed Transmission Line (from Malimboda WTP to Diyagaha Ground Reservoir)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia. mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark
	Malimboda WTP						HWL	120.00		Total Length 14007 m LWL 36.00 m
		21,751	450	5307	5.8	30.8	89.22			Pump Head 87 m HWL 72.00 m
100	Proposed Diyagaha Reservoir	21,751	586	8700	1.6	13.9	75.30	HWL	72.00	OK
										450 Add + 450

Proposed Transmission Line (from Malimboda WTP to Diyagaha Ground Reservoir)

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia. mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Check the Water Pressure	Remark
	Malimboda WTP						HWL	120.00		Total Length 14007 m LWL 36.00 m
		21,751	450	4107	5.8	23.8	96.18			Pump Head 87 m HWL 72.00 m
100	Proposed Diyagaha Reservoir	21,751	555	9900	2.1	20.8	75.39	HWL	72.00	OK
										450 Add + 400

Note: Flow rate (Total) 21751 m<sup>3</sup>/d = 0.25174 m<sup>3</sup>/s  
 Diyagaha Distribution rate 8316 m<sup>3</sup>/d  
 Transmission flow rate 13435 m<sup>3</sup>/d  
 Diyagaha East of Diyagaha (4939 + 3377 = 8316 m<sup>3</sup>/d)

Table3.4.1 Existing Transmission Pipe Hydraulic Calculation (Existig Capacity)

C= 120 Max

No.	Reservoir & Elevated Tank	Water Flow m <sup>3</sup> /d	Pipe Dia. mm	Length m	Hydraulic Gradient ‰	Pipe Friction Loss (m)	Receiving Water Level (m)	Water Level m	Ground L. m	Remark
1	Malimboda WTP	30,000						LWL	36.40	Clear Water Re.
2	Uyanwatta PS	21,000	500	10040	3.2	32.1	4.3	HWL	2.90	OK Gravity Flow
201	Uyanwatta PS							WL	29.90	Pump Head 33 m LWL -0.10 m
3	Gabadaweediya Elevated Tank	4,000	300	500	1.8	0.9	29.0	HWL	27.65	OK from 201
202	Uyanwatta PS							WL	29.90	Pump Head 33 m LWL -0.10 m
4	Nupe Elevated Tank	2,200	300	2000	0.6	1.2	28.7	HWL	27.29	OK from 202 LWL 24.29 m
204	Uyanwatta PS							WL	56.90	Pump Head 60 m LWL -0.10 m
5	Brownshill Reservoir 1	13,700	500	2000	1.5	3.0	53.9	HWL	47.3	OK from 204
205	Uyanwatta PS							WL	56.90	Pump Head 60 m LWL -0.10 m
6	Brownshill Reservoir 2	13,700	500	2000	1.5	3.0	53.9	HWL	47.3	OK from 205 LWL 43.90 m
7	Devinuwara Bulk Meter	13,700	500	3320	1.5	5.0	38.9			
8	Devinuwara Junction	13,700	150	400	518.0	207.2	-168.3			
9	Devinuwara Elevated Tank	1,300	450	4090	0.0	0.0	-168.28	HWL	31.95	NO LWL 26.68 m
10	Gandara Junction	9,700	225	400	38.0	15.2	-183.5			from 8
11	Gandara Ground Reservoir	800	150	80	2.7	0.2	-183.70	HWL	30.53	NO
11	Gandara Ground Reservoir							WL	54.31	Pump Head 31 m LWL 26.31 m
12	Gandara Elevated Tank	500	150	80	1.1	0.1	54.22	HWL	54.00	OK from 11
13	Kottegoda Junction	11,500	400	80	3.2	0.3	-183.7			from 10
14	Kottegoda Ground Sump	11,500	300	29	12.8	0.4	-184.11	HWL	14.20	NO
14	Kottegoda Ground Sump							WL	39.20	Pump Head 31 m LWL 11.20 m
15	Kottegoda Elevated Tank	5,000	300	29	2.7	0.1	39.1	HWL	35.50	OK from 14
16	Dickwella Ground Reservoir	4,200	300	200	2.0	0.4	-184.1	HWL	5.05	NO from 13
16	Dickwella Ground Reservoir							WL	34.35	Pump Head 36 m LWL 1.25 m
17	Dickwella Elevated Tank	3,600	200	2256	10.8	24.4	10.0	HWL	32.00	NO from 16
16	Dickwella Ground Reservoir							WL	68.45	Pump Head 70 m LWL 1.25 m
18	Naigala Elevated Tank	1,800	200	4000	3.0	12.0	56.5	HWL	60.00	NO LWL 54.50 m
19	Kudawella Ground Reservoir	700	160	4400	1.5	6.6	49.9	HWL	-	-
20	Yayawatta Ground Reservoir	600	160	4400	1.2	5.3	44.6	HWL	-	-
16	Dickwella Ground Reservoir							HWL	59.25	Pump Head 61 m LWL 1.25 m
21	Medagoda Elevated Tank	900	200	4000	0.8	3.2	56.1	HWL	52.75	OK 34.95 m
22	Isadeen Ground Reservoir	8,000	350	8800	3.1	27.3	9.1	HWL	5.8	OK from 1 LWL 2.10 m
23	Malimboda contact Tank	2,000	200	20	3.6	0.1	36.3	HWL	36	OK from 1
24	Nadugara WTP							WL	34.00	Pump Head 25 m LWL 12.00 m
2	Uyanwatta PS	9,000	350	5000	3.8	19.0	15.0	HWL	2.90	OK

Note

C= 120

#### 4. EXISTING SERVICE RESERVIOR AND ELEVATED TANK

No	Reservior/Tank	Abstract from	Feed to	Volume M <sup>3</sup>	T.W.L. M MSL	B.W.L. M MSL	Type
1	Nadugala Ground Sump	Nadugala W.T.P.	Uyanwatta G.R.	225	15.0	12.0	Rectangular G.R.
2	Malimbada Clear Water Tank	Malimbada W.T.P	Isadeen G.R. & Isadeen G.R	1025	40.0	36.4	Circular G.R.
3	Uyanwatta Ground Reservior	Malimbada & Nadugala W.T.P.	Nupe, Gabadaweediya E.T. Brownsill G.R.- R1 & R2	1850	2.9	-0.1	Rectangular G.R.
4	Nupe Elevated Tank	Uyanwatta G.R. & Isadeen G.R.	Matara Town	900	27.29	24.29	Circular E.T.
5	Gabadaweediya Elevated Tank	Uyanwatta G.R.	Matara Town	900	27.65	24.65	Circular E.T.
6	Brownsill Ground Rservior 1	Uyanwatta G.R.	Matara Town	1800	47.3	43.9	Circular G.R.
7	Brownsill Ground Rservior 2	Uyanwatta G.R.	Devinuwara to Kudawella reserviors	1170	47.3	43.9	Rectangular G.R.
8	Devinuwara Elevated Tank	Brownsill Ground Rservior 2	Devinuwara Distribution	682	31.95	26.68	Circular E.T.
9	Gandara Break Pressure Tank	Brownsill Ground Rservior 2	Gandara Elevated Tank & Gandara Distribution	318	30.53	26.31	Circular G.R.
10	Gandara Elevated Tank	Gandara Break Pressure Tank	Gandara Distribution	455	54.00	50.5	Circular E.T.
11	Kottegoda Ground Sump	Brownsill Ground Rservior 2	Kottegoda Elevated Tank	225	14.20	11.20	Rectangular G.R.
12	Kottegoda Elevated Tank	Kottegoda Ground Sump	Kottegoda Distribution	450	35.50	32.00	Circular E.T.
13	Dickwella Ground Reservior	Brownsill Ground Rservior 2	Batheegama, Naigala, Medagoda Reserviors	1200	5.05	1.25	Circular G.R.
14	Dickwella Elevated Tank	Dickwella Ground Reservior	Dickwella Distribution	675	32.00	28.5	Circular E.T.
15	Naigala Elevated Tank	Dickwella Ground Reservior	Dickwella Distribution	450	60	54.5	Circular E.T.
16	Medagoda Elevated Tank	Dickwella Ground Reservior	Dickwella Distribution	180	52.75	34.95	Circular E.T.
17	Kudawella Ground Reservior	Naigala Elevated Tank	Kudawella Distribution	225			Rectangular G.R.
18	Yayawatta Ground Reservior	Kudawella Ground Reservior	Kudawella Distribution	112.5			Rectangular G.R.
19	Malimbada Distribution contact Tank	Malimbada Clear Water Tank	Malimbada Distribution	50	32.4	32.2	Square G.R.
20	Isadeen Ground Reservior	Malimbada Clear Water Tank	Kaburugamuwa Elevated Tank & Nupe Tank	1250	5.8	2.1	Rectangular G.R.
21	Kaburugamuwa Elevated Tank	Isadeen Ground Reservior	Kaburugamuwa Distribution & Mirissa Ground Reservior	450	-	-	Circular E.T.
22	Mirissa Ground Storage Tank	Kaburugamuwa Elevated Tank	Mirissa Hill Top Ground Reservior	125	4.15	2	Rectangular G.R.
23	Mirissa Hill top Reservior	Mirissa Hill Top Ground Storage Tank	Mirissa Distribution & Weligama Polwatta area	250	29.4	27.2	Rectangular G.R.

## 5. EXISTING PUMP STATION

No	Pump Station	Pump to	Type	Unit		Capacity		Head m	KW	Speed (rpm)	Operation Time (Hr.)	Year Installed
				Duty	Stand	M <sup>3</sup> /Hr	L/S					
	<b>Nadugala W.T.P.</b>											
1	Intake Low Level	Nadugala W.T.P.	Vertical Turbine Pump	1	1	400	112	15	45	1470	24	1994
2	Treatment Plant High Level	Uyanwatta G.R.	Centrifugal Split Casing	1	1	375	104	25	37	1470	24	1985
	<b>Malimbada W.T.P.</b>											
3	Balakawala Intake	Malimbada W.T.P.	Vertical Turbine Pump	2	1	335	93	96	132	1450	24	1997
4	Kadduwa Intake	Malimbada W.T.P.	Vertical Turbine Pump	2	2	335	93	55	75	1470	24	1985,1995 1997
	<b>Matara Group W.S.S.</b>											
5	Uyanwatta Pumping Station	Nupe Elevated Tank	Centrifugal Split Casing	1	0	250	70	33	30	1475	20	1985
		Gabadaweediya Elevated Tank	Centrifugal Split Casing	1	0	250	70	33	30	1475	20	1985
		Brownshill G.R. 1 & 2	Centrifugal Split Casing	2	1	525	146	60	125	1485	24	2002
6	Isadeen Pumping Station	Nupe Elevated Tank	Centrifugal Split Casing	1	1	135	37.5	60	37	1472	20	1995
		Kaburugamuwa E.T.	Centrifugal Split Casing	1	1	135	37.5	41	22	1472	20	1995
7	Kaburugamuwa Pumping Station	Mirissa Hill Top Ground Storage Tank	Centrifugal Split Casing	1	1	20	5.6	45	11	2900	16	1995
8	Gandara Pumping Station	Gandara Elevated Tank	Centrifugal Split Casing	1	1	126	35	31	18.5	1460	12	1985
9	Kottegoda Pumping Station	Kottegoda Elevated Tank	Centrifugal Split Casing	1	1				15	2910		2001
10	Dickwella Pumping Station	Dickwella Elevated Tank	Centrifugal Split Casing	1	1	135	37.5	36.1	22	1470	12	1985
		Naigala Elevated Tank	Centrifugal Split Casing	1	1	83	23	70.2	30	1450	12	1985
		Medagoda Elevated Tank	Centrifugal Split Casing	1	1	68.4	19	61	18.5	1450	12	1995
11	Kudawella Ground Reservoir	Yayawawtta Ground reservoir	Centrifugal Split Casing	1	1	36.4	10.1	80	11	2900	6	

Table . Maximum Capacity of Existing Pump and Required Pump Capacity

Case 1 PVC

No	Pump Station	Pump to	Unit		Capacity M <sup>3</sup> /Hr	Head m	Operation Time Hr.	Flow Rate (m3/d)		Pump Flow Rate and Pump Head								
			Duty	Stand by				Existing M <sup>3</sup> /d	Maximum M <sup>3</sup> /d	2007		2009		2011		2021		
										m3/d	m	m3/d	m	m3/d	m	m3/d	m	
1	Uyanwatta Pumping Station	Nupe Elevated Tank	Existing	1	0	250	33	20	5000	6000	2,957 OK	33 OK	3,187 OK	33 OK	3,464 OK	36 NO	4,874 OK	36 NO
		Gabadaweediya Elevated Tank		1	0	250	33	20	5000	6000	3,966 OK	33 OK	4,274 OK	33 OK	4,646 OK	33 OK	6,536 NO	36 NO
		Brownshill G.R. 1 & 2		2	1	525	60	24	25200	25200	13,622 OK	60 OK	14,728 OK	60 OK	18,158 OK	60 OK	26,492 NO	60 OK
2	Gandara Pumping Station	Gandara Elevated Tank	Existing	1	1	126	31	12	1512	3024	2,130 OK	31 OK	2,323 OK	31 OK	2,556 OK	31 OK	3,682 NO	35 NO
3	Dickwella Pumping Station	Dickwella Elevated Tank		1	1	135	36.1	12	1620	3240	2,157 OK	36 OK	2,325 OK	36 OK	2,526 OK	36 OK	3,555 NO	36 OK
	Dickwella Pumping Station	Medagoda Elevated Tank		1	1	68.4	61	12	821	1642	2,120 NO	78 NO	2,285 NO	78 NO	2,486 NO	78 NO	3,496 NO	78 NO
1	Uyanwatta Pumping Station	Nupe Elevated Tank	Proposed	1	1	250	36	24	-	6000					6,000 OK	36 OK	6,000 OK	36 OK
		Gabadaweediya Elevated Tank		1	1	350	36	24	-	8400							8,400 OK	36 OK
		Brownshill G.R. 1 & 2		2	1	650	60	24	-	31200							31,200 OK	60 OK
2	Gandara Pumping Station	Gandara Elevated Tank	Proposed	1	1	200	35	24	-	4800							4,800 OK	35 OK
3	Dickwella Pumping Station	Dickwella Elevated Tank		1	1	200	36	24	-	4800							4,800 OK	36 OK
	Dickwella Pumping Station	Medagoda Elevated Tank		1	1	140	78	24	-	3360	3,360 OK	78 OK	3,360 OK	78 OK	3,360 OK	78 OK	3,360 OK	78 OK
				1	1	70	78	24	-	1680							1,680	78

(Note)

1 Provided that pump loss is 3 m, pump head above was calculated deducting 3 m from their nominal pump head.

2 Capacity of the existing pumps were determined by pump flow and head. Therefore, timing of pump replacement was determined by their deficiency in pump flow and/or head.

3 Column with double line shows deficiency in pump capacity (pump flow and head) and needs pump replacement.

4 The specifications of proposed pumps are shown in "Proposed" column.

6. EXISTING TRANSMISSION PIPE SYSTEM - MATARA GROUP W.S.S.

No	Pipe Line	From	To	Diameter mm	Length M	Material	Water Flow Capacity (m <sup>3</sup> /d)
	<b>Nadugala W.T.P.</b>						
1	Raw water pumping transmission	Intake	W.T.P.	350	130	C.I.P.	-
2	Treated water pumping transmission	Nadugala G.R.	Uyanwatte G.R.	350	5,000	C.I.P.	9,000
	<b>Maimbada W.T.P.</b>						
3	Raw water pumping transmission	Balakawala Intake	Kadduwa Junction	400	6,630	D.I.P.	-
4	Raw water pumping transmission	Kadduwa Intake	Kadduwa Junction	400	20	D.I.P.	-
5	Raw water pumping transmission	Kadduwa Junction	Malimbada W.T.P.	600	2,960	D.I.P.	-
6	Treated water Gravity transmission	Malimbada Clear Water Tank	Uyanwatte G.R.	500	10,040	D.I.P.	21,000
7	Treated water Gravity transmission	Malimbada Clear Water Tank	Isadeen G.R.	350	8,800	D.I.P.	8,000
	<b>Uyanwatte W.S.S.</b>						
8	Treated water pumping transmission	Uyanwatte G.R.	Nupe E.T.	300	2,000	D.I.P.	2,200
9	Treated water pumping transmission	Uyanwatte G.R.	Gabadaweediya E.T.	300	500	D.I.P.	4,000
10	Treated water pumping transmission	Uyanwatte G.R.	Brownsill G.R. 1	500	2,000	D.I.P.	13,700
	Treated water pumping transmission	Uyanwatte G.R.	Brownsill G.R. 2	500	2,000	D.I.P.	13,700
11	Treated water pumping transmission	Isadeen G.R.	Nupe E.T.	200	2,820	D.I.P.	-
12	Treated water pumping transmission	Isadeen G.R.	Kaburugamuwa G.R.	200	4,270	D.I.P.	-
13	Treated water Gravity Transmission	Brownsill G.R. 2	Devinuwara Bulk Meter	500	3,320	D.I.P.	13,700
	<b>Devinuwara &amp; Gandara W.S.S.</b>						
14	Treated water Gravity Transmission	Devinuwara Bulk Meter	Devinuwara Junction	450	900	C.I.P.	13,700
15	Treated water Gravity Transmission	Devinuwara Junction	Devinuwara E.T.	150	400	C.I.P.	1,300
16	Treated water Gravity Transmission	Devinuwara Junction	Gandara Junction	450	4,090	A.C.P.	9,700
17	Treated water Gravity Transmission	Gandara Junction	Gandara B.P.T.(g.r.)	225	400	A.C.P.	800
18	Treated water pumping transmission	Gandara B.P.T.	Gandara E.T.	150	80	C.I.P.	500
	<b>Kottegoda W.S.S.</b>						
19	Treated water Gravity Transmission	Gandara Junction	Kottegoda G.R. Tee	400	4,960	A.C.P.	11,500
20	Treated water Gravity Transmission	Kottegoda G.R. Tee	Kottegoda G.R.	400	80	D.I.P.	11,500
21	Treated water pumping transmission	Kottegoda G.R.	Kottegoda E.T.	300	29	D.I.P.	5,000
	<b>Dicwella W.S.S.</b>						
22	Treated water Gravity Transmission	Kottegoda E.T.	Kottegoda Junction	300	121	A.C.P.	5,000
23	Treated water Gravity Transmission	Kottegoda Junction	Dickwella Junction	300	5,070	A.C.P.	4,200
24	Treated water Gravity Transmission	Dickwella Junction	Dickwella G.R.	300	120	A.C.P.	4,200
25	Treated water pumping transmission	Dickwella G.R.	Batheegama E.T.	200	80	A.C.P.	-
26	Treated water pumping transmission	Dickwella G.R.	Naigala E.T.	200	2,256	A.C.P.	1,800
27	Treated water pumping transmission	Dickwella G.R.	Medagoda E.T.	200	4,000	UPVC	900
	<b>Kudawella W.S.S.</b>						
28	Treated water Gravity Transmission	Naigala E.T.	Kudawella G.R.	160	6,000	UPVC	700
29	Treated water pumping transmission	Kudawella G.R.	Yayawatta G.R.	160	4,400	UPVC	600


## 参考資料 3.2

### ディヤガハ配水池及び送水管容量計算書





# Scenario: Scenario 1



## Appendix 2.2 Study of Reservoir Volume and Transmission pipe Capacity





# Scenario: Scenario 1





# Scenario: Scenario 1





## Scenario: Scenario 1





# Scenario: Scenario 1



# Scenario: Scenario 1



# Scenario: Scenario 1



## Scenario: Scenario 1

T-1

Scenario Summary			
Label	Scenario 1		
Physical Alternative	Base-Physical		
Demand Alternative	Base-Average Daily		
Initial Settings Alternative	Base-Initial Settings		
Operational Alternative	Base-Operational		
Age Alternative	Base-Age Alternative		
Constituent Alternative	Base-Constituent		
Trace Alternative	Base-Trace Alternative		
Fire Flow Alternative	Fire Flow-Scenario 2		
Cost Alternative	Base-Cost		
User Data Alternative	Base-User Data		
Calibration Summary			
Demand	<None>	Roughness	<None>
Geometric Summary			
X	3,047.034 m	Elevation	72.000 m
Y	3,064.817 m	Zone	Zone-1
Operating Range Summary			
Maximum Elevation	72.000 m	Maximum Level	4.200 m
Initial HGL	70.400 m	Initial Level	2.600 m
Minimum Elevation	68.000 m	Minimum Level	0.200 m
Base Elevation	67.800 m		
Storage Summary			
Section Type	Constant Area	Circular Tank Shape?	false
Diameter	N/A ft	Average Area	270.25 m <sup>2</sup>
Inactive Volume	0.0000 m <sup>3</sup>	Total Active Volume	1,080.9999 m <sup>3</sup>
User Data			
Date Installed		Date Retired	
Inspection Date		SCADA ID	
Observed Level	0.00 ft	Lining	
Condition		Metered	false
Clearwell Storage	false	Elevated Tank	false
Existing	false		




# Scenario: Scenario 1

History:

Location Description:

Calculated Results Summary								
Time	Calculated Hydraulic Grade (m)	Calculated Level (m)	Pressure (m H <sub>2</sub> O)	Calculated Percent Full (%)	Calculated Volume (m <sup>3</sup> )	Inflow (l/d)	Outflow (l/d)	Current Status
0.00 hr	70.400	2.600	2.5934	60.0	648.6001	1,505,280	-1,505,280	Filling
1.00 hr	70.632	2.832	2.8249	65.8	711.3207	1,612,800	-1,612,800	Filling
2.00 hr	70.881	3.081	3.0730	72.0	778.5208	1,720,320	-1,720,320	Filling
3.00 hr	71.146	3.346	3.3375	78.6	850.2006	1,854,720	-1,854,720	Filling
4.00 hr	71.432	3.632	3.6228	85.8	927.4811	1,962,240	-1,962,240	Filling
5.00 hr	71.734	3.934	3.9245	93.4	1,009.2412	1,612,800	-1,612,800	Filling
6.00 hr	71.983	4.183	4.1726	99.6	1,076.4413	107,520	-107,520	Filling
7.00 hr	72.000	4.200	4.1891	100.0	1,080.9209	-698,880	698,880	Draining
8.00 hr	71.892	4.092	4.0816	97.3	1,051.8011	-1,397,760	1,397,760	Draining
9.00 hr	71.676	3.876	3.8667	91.9	993.5613	-1,612,800	1,612,800	Draining
10.00 hr	71.428	3.628	3.6186	85.7	926.3612	-1,505,280	1,505,280	Draining
11.00 hr	71.196	3.396	3.3871	79.9	863.6406	-1,263,359	1,263,359	Draining
12.00 hr	71.001	3.201	3.1929	75.0	811.0004	-806,400	806,400	Draining
13.00 hr	70.877	3.077	3.0688	71.9	777.4009	-564,480	564,480	Draining
14.00 hr	70.790	2.990	2.9820	69.7	753.8806	-349,439	349,439	Draining
15.00 hr	70.736	2.936	2.9283	68.4	739.3206	-241,920	241,920	Draining
16.00 hr	70.698	2.898	2.8911	67.5	729.2403	-456,959	456,959	Draining
17.00 hr	70.628	2.828	2.8208	65.7	710.2008	-913,920	913,920	Draining
18.00 hr	70.487	2.687	2.6803	62.2	672.1205	-1,263,359	1,263,359	Draining
19.00 hr	70.292	2.492	2.4860	57.3	619.4803	-1,155,839	1,155,839	Draining
20.00 hr	70.114	2.314	2.3082	52.9	571.3209	-564,480	564,480	Draining
21.00 hr	70.027	2.227	2.2214	50.7	547.8005	241,920	-241,920	Filling
22.00 hr	70.064	2.264	2.2586	51.6	557.8808	913,920	-913,920	Filling
23.00 hr	70.205	2.405	2.3992	55.1	595.9611	1,263,361	-1,263,361	Filling
24.00 hr	70.400	2.600	2.5934	60.0	648.6014	1,505,280	-1,505,280	Filling



Title: Basic Design Study on the Project for the Improvement of Water Supply Scheme of Matara in Democratic Socialist of Sri Lanka  
Project Engineer: NJS

c:\...adopt only for pattern drwng jwwa 270m2.wcd  
03/05/09 14:50 © Haestad Methods, Inc.

Nippon Jogesuido Sekkei Co., Ltd.  
37 Brookside Road Waterbury, CT 06708 USA +1-203-755-1666

WaterCAD v4.1.1 [4.2014]  
Page 9

# Scenario: Scenario 1

=====  
Scenario: Scenario 1

=====  
0.0 hours - Hydraulic Summary

-----  
Iteration Summary

Balanced Trials = 2, Accuracy = 0.0

-----  
Flow Summary

Flow Supplied 14,069,013 l/d

Flow Demanded 12,563,721 l/d

Flow Stored 1,505,292 l/d

-----  
Boundary Summary

T-1 Tank: Filling, Tank Level = 2.600 m

=====  
1.0 hours - Hydraulic Summary

-----  
Iteration Summary

Balanced Trials = 2, Accuracy = 0.0

-----  
Flow Summary

Flow Supplied 14,069,013 l/d

Flow Demanded 12,456,173 l/d

Flow Stored 1,612,785 l/d

-----  
Boundary Summary

T-1 Tank: Filling, Tank Level = 2.832 m

=====  
2.0 hours - Hydraulic Summary

-----  
Iteration Summary

Balanced Trials = 2, Accuracy = 0.0

-----  
Flow Summary

Flow Supplied 14,069,013 l/d

Flow Demanded 12,348,680 l/d

Flow Stored 1,720,333 l/d

-----  
Boundary Summary

T-1 Tank: Filling, Tank Level = 3.082 m

=====  
3.0 hours - Hydraulic Summary

-----  
Iteration Summary

Balanced Trials = 2, Accuracy = 0.0

-----  
Flow Summary

Flow Supplied 14,069,013 l/d

Flow Demanded 12,214,258 l/d

Flow Stored 1,854,700 l/d

Title: Basic Design Study on the Project for the Improvement of Water Supply Scheme of Matara in Democratic Socialist of Sri Lanka

Project Engineer: NJS

c:\...adopt only for pattern drwng jwwa 270m2.wcd  
03/05/09 14:52

© Haestad Methods, Inc.

Nippon Jogesuido Sekkei Co., Ltd.

37 Brookside Road Waterbury, CT 06708 USA

+1-203-755-1666

WaterCAD v4.1.1 [4.2014]

Page 10

# Scenario: Scenario 1

-----  
Boundary Summary

T-1 Tank: Filling, Tank Level = 3.347 m

=====  
4.0 hours - Hydraulic Summary

-----  
Iteration Summary

Balanced Trials = 2, Accuracy = 0.0

-----  
Flow Summary

Flow Supplied 14,069,013 l/d

Flow Demanded 12,106,765 l/d

Flow Stored 1,962,248 l/d

-----  
Boundary Summary

T-1 Tank: Filling, Tank Level = 3.633 m

=====  
5.0 hours - Hydraulic Summary

-----  
Iteration Summary

Balanced Trials = 2, Accuracy = 0.0

-----  
Flow Summary

Flow Supplied 14,069,013 l/d

Flow Demanded 12,456,173 l/d

Flow Stored 1,612,785 l/d

-----  
Boundary Summary

T-1 Tank: Filling, Tank Level = 3.935 m

=====  
6.0 hours - Hydraulic Summary

-----  
Iteration Summary

Balanced Trials = 2, Accuracy = 0.0

-----  
Flow Summary

Flow Supplied 14,069,013 l/d

Flow Demanded 13,961,465 l/d

Flow Stored 107,494 l/d

-----  
Boundary Summary

T-1 Tank: Filling, Tank Level = 4.182 m

=====  
7.0 hours - Hydraulic Summary

-----  
Iteration Summary

Balanced Trials = 2, Accuracy = 0.0

-----  
Flow Summary

Flow Supplied 14,069,013 l/d

Flow Demanded 14,767,885 l/d

## Scenario: Scenario 1

Flow Stored -698,872 l/d

---

### Boundary Summary

T-1 Tank: Emptying, Tank Level = 4.200 m

---

### 8.0 hours - Hydraulic Summary

---

#### Iteration Summary

Balanced Trials = 2, Accuracy = 0.0

---

#### Flow Summary

Flow Supplied 14,069,013 l/d

Flow Demanded 15,466,757 l/d

Flow Stored -1,397,744 l/d

---

### Boundary Summary

T-1 Tank: Emptying, Tank Level = 4.093 m

---

### 9.0 hours - Hydraulic Summary

---

#### Iteration Summary

Balanced Trials = 2, Accuracy = 0.0

---

#### Flow Summary

Flow Supplied 14,069,013 l/d

Flow Demanded 15,681,798 l/d

Flow Stored -1,612,785 l/d

---

### Boundary Summary

T-1 Tank: Emptying, Tank Level = 3.877 m

---

### 10.0 hours - Hydraulic Summary

---

#### Iteration Summary

Balanced Trials = 2, Accuracy = 0.0

---

#### Flow Summary

Flow Supplied 14,069,013 l/d

Flow Demanded 15,574,305 l/d

Flow Stored -1,505,292 l/d

---

### Boundary Summary

T-1 Tank: Emptying, Tank Level = 3.627 m

---

### 11.0 hours - Hydraulic Summary

---

#### Iteration Summary

Balanced Trials = 2, Accuracy = 0.0

---

#### Flow Summary

Flow Supplied 14,069,013 l/d

Title: Basic Design Study on the Project for the Improvement of Water Supply Scheme of Matara in Democratic Socialist of Sri Lanka  
Project Engineer: NJS

c:\...adopt only for pattern drwg jwwa 270m2.wcd  
03/05/09 14:54 © Haestad Methods, Inc.

Nippon Jogesuido Sekkei Co., Ltd.  
37 Brookside Road Waterbury, CT 06708 USA +1-203-755-1666

WaterCAD v4.1.1 [4.2014]  
Page 12

## Scenario: Scenario 1

Flow Demanded 15,332,335 l/d  
Flow Stored -1,263,377 l/d

---

### Boundary Summary

T-1 Tank: Emptying, Tank Level = 3.395 m

---

### 12.0 hours - Hydraulic Summary

---

#### Iteration Summary

Balanced Trials = 2, Accuracy = 0.0

---

#### Flow Summary

Flow Supplied 14,069,013 l/d  
Flow Demanded 14,875,378 l/d  
Flow Stored -806,420 l/d

---

### Boundary Summary

T-1 Tank: Emptying, Tank Level = 3.200 m

---

### 13.0 hours - Hydraulic Summary

---

#### Iteration Summary

Balanced Trials = 2, Accuracy = 0.0

---

#### Flow Summary

Flow Supplied 14,069,013 l/d  
Flow Demanded 14,633,463 l/d  
Flow Stored -564,505 l/d

---

### Boundary Summary

T-1 Tank: Emptying, Tank Level = 3.075 m

---

### 14.0 hours - Hydraulic Summary

---

#### Iteration Summary

Balanced Trials = 2, Accuracy = 0.0

---

#### Flow Summary

Flow Supplied 14,069,013 l/d  
Flow Demanded 14,418,422 l/d  
Flow Stored -349,463 l/d

---

### Boundary Summary

T-1 Tank: Emptying, Tank Level = 2.990 m

---

### 15.0 hours - Hydraulic Summary

---

#### Iteration Summary

Balanced Trials = 2, Accuracy = 0.0

---

#### Flow Summary

Title: Basic Design Study on the Project for the Improvement of Water Supply Scheme of Matara in Democratic Socialist of Sri Lanka  
Project Engineer: NJS

c:\...adopt only for pattern drwng jwwa 270m2.wcd  
03/05/09 14:54 © Haestad Methods, Inc.

Nippon Jogesuido Sekkei Co., Ltd.  
37 Brookside Road Waterbury, CT 06708 USA

+1-203-755-1666

WaterCAD v4.1.1 [4.2014]  
Page 13

## Scenario: Scenario 1

Flow Supplied 14,069,013 l/d  
Flow Demanded 14,310,928 l/d  
Flow Stored -241,915 l/d

---

### Boundary Summary

T-1 Tank: Emptying, Tank Level = 2.935 m

---

## 16.0 hours - Hydraulic Summary

---

### Iteration Summary

Balanced Trials = 2, Accuracy = 0.0

---

### Flow Summary

Flow Supplied 14,069,013 l/d  
Flow Demanded 14,525,970 l/d  
Flow Stored -456,957 l/d

---

### Boundary Summary

T-1 Tank: Emptying, Tank Level = 2.899 m

---

## 17.0 hours - Hydraulic Summary

---

### Iteration Summary

Balanced Trials = 2, Accuracy = 0.0

---

### Flow Summary

Flow Supplied 14,069,013 l/d  
Flow Demanded 14,982,926 l/d  
Flow Stored -913,913 l/d

---

### Boundary Summary

T-1 Tank: Emptying, Tank Level = 2.829 m

---

## 18.0 hours - Hydraulic Summary

---

### Iteration Summary

Balanced Trials = 2, Accuracy = 0.0

---

### Flow Summary

Flow Supplied 14,069,013 l/d  
Flow Demanded 15,332,335 l/d  
Flow Stored -1,263,377 l/d

---

### Boundary Summary

T-1 Tank: Emptying, Tank Level = 2.688 m

---

## 19.0 hours - Hydraulic Summary

---

### Iteration Summary

Balanced Trials = 2, Accuracy = 0.0

---

# Scenario: Scenario 1

Flow Summary  
Flow Supplied 14,069,013 l/d  
Flow Demanded 15,224,842 l/d  
Flow Stored -1,155,829 l/d

-----  
Boundary Summary  
T-1 Tank: Emptying, Tank Level = 2.493 m

=====  
20.0 hours - Hydraulic Summary

-----  
Iteration Summary  
Balanced Trials = 2, Accuracy = 0.0

-----  
Flow Summary  
Flow Supplied 14,069,013 l/d  
Flow Demanded 14,633,463 l/d  
Flow Stored -564,505 l/d

-----  
Boundary Summary  
T-1 Tank: Emptying, Tank Level = 2.313 m

=====  
21.0 hours - Hydraulic Summary

-----  
Iteration Summary  
Balanced Trials = 2, Accuracy = 0.0

-----  
Flow Summary  
Flow Supplied 14,069,013 l/d  
Flow Demanded 13,827,098 l/d  
Flow Stored 241,915 l/d

-----  
Boundary Summary  
T-1 Tank: Filling, Tank Level = 2.228 m

=====  
22.0 hours - Hydraulic Summary

-----  
Iteration Summary  
Balanced Trials = 2, Accuracy = 0.0

-----  
Flow Summary  
Flow Supplied 14,069,013 l/d  
Flow Demanded 13,155,099 l/d  
Flow Stored 913,913 l/d

-----  
Boundary Summary  
T-1 Tank: Filling, Tank Level = 2.265 m

=====  
23.0 hours - Hydraulic Summary

-----  
Iteration Summary  
Balanced Trials = 2, Accuracy = 0.0

Title: Basic Design Study on the Project for the Improvement of Water Supply Scheme of Matara in Democratic Socialist of Sri Lanka  
Project Engineer: NJS

c:\...adopt only for pattern drwng jwwa 270m2.wcd  
03/05/09 15:29 © Haestad Methods, Inc.

Nippon Jogesuido Sekkei Co., Ltd.  
37 Brookside Road Waterbury, CT 06708 USA

+1-203-755-1666

WaterCAD v4.1.1 [4.2014]  
Page 15

# Scenario: Scenario 1

-----  
Flow Summary  
Flow Supplied 14,069,013 l/d  
Flow Demanded 12,805,636 l/d  
Flow Stored 1,263,377 l/d  
-----

Boundary Summary  
T-1 Tank: Filling, Tank Level = 2.405 m

=====  
24.0 hours - Hydraulic Summary  
-----

Iteration Summary  
Balanced Trials = 2, Accuracy = 0.0  
-----

Flow Summary  
Flow Supplied 14,069,013 l/d  
Flow Demanded 12,563,721 l/d  
Flow Stored 1,505,292 l/d  
-----

Boundary Summary  
T-1 Tank: Filling, Tank Level = 2.600 m

=====  
Message Summaries  
=====

(no messages)

=====  
Completed: 2003/01/09 18:50:21



# Scenario: Scenario 1

J-1

Scenario Summary	
Label	Scenario 1
Physical Alternative	Base-Physical
Demand Alternative	Base-Average Daily
Initial Settings Alternative	Base-Initial Settings
Operational Alternative	Base-Operational
Age Alternative	Base-Age Alternative
Constituent Alternative	Base-Constituent
Trace Alternative	Base-Trace Alternative
Fire Flow Alternative	Fire Flow-Scenario 2
Cost Alternative	Base-Cost
User Data Alternative	Base-User Data

Calibration Summary			
Demand	<None>	Roughness	<None>

Geometric Summary			
X	3,019.220 m	Elevation	120.000 m
Y	3,068.543 m	Zone	Zone-1

Demand Summary		
Type	Demand (l/d)	Pattern
Inflow	14,069,000	Fixed

User Data			
Observed Pressure	0.00 psi	Observed Concentration	0.00 mg/l
SCADA ID		Sampling Point	false
Hydrant Location	false	Existing	false

History:

Location Description:

Calculated Results Summary					
Time	Elevation (m)	Calculated Hydraulic Grade (m)	Pressure (m H2O)	Pressure Head (m)	Demand (Calculated) (l/d)
0.00 hr	120.000	106.314	-13.6515	-13.686	-14,069,000
1.00 hr	120.000	106.546	-13.4200	-13.454	-14,069,000
2.00 hr	120.000	106.795	-13.1720	-13.205	-14,069,000
3.00 hr	120.000	107.060	-12.9074	-12.940	-14,069,000
4.00 hr	120.000	107.346	-12.6222	-12.654	-14,069,000
5.00 hr	120.000	107.648	-12.3204	-12.352	-14,069,000
6.00 hr	120.000	107.897	-12.0724	-12.103	-14,069,000
7.00 hr	120.000	107.914	-12.0558	-12.086	-14,069,000
8.00 hr	120.000	107.806	-12.1633	-12.194	-14,069,000
9.00 hr	120.000	107.590	-12.3783	-12.410	-14,069,000
10.00 hr	120.000	107.342	-12.6263	-12.658	-14,069,000
11.00 hr	120.000	107.110	-12.8578	-12.890	-14,069,000
12.00 hr	120.000	106.915	-13.0521	-13.085	-14,069,000
13.00 hr	120.000	106.791	-13.1761	-13.209	-14,069,000
14.00 hr	120.000	106.704	-13.2629	-13.296	-14,069,000
15.00 hr	120.000	106.650	-13.3167	-13.350	-14,069,000
16.00 hr	120.000	106.612	-13.3539	-13.388	-14,069,000
17.00 hr	120.000	106.542	-13.4241	-13.458	-14,069,000
18.00 hr	120.000	106.401	-13.5647	-13.599	-14,069,000
19.00 hr	120.000	106.206	-13.7590	-13.794	-14,069,000
20.00 hr	120.000	106.028	-13.9367	-13.972	-14,069,000
21.00 hr	120.000	105.941	-14.0235	-14.059	-14,069,000
22.00 hr	120.000	105.978	-13.9863	-14.022	-14,069,000
23.00 hr	120.000	106.119	-13.8458	-13.881	-14,069,000
24.00 hr	120.000	106.314	-13.6515	-13.686	-14,069,000

Title: Basic Design Study on the Project for the Improvement of Water Supply Scheme of Matara in Democratic Socialist of Sri Lanka  
 Project Engineer: NJS

c:\...adopt only for pattern drwng jwwa 270m2.wcd  
 03/05/09 15:32 © Haestad Methods, Inc.

Nippon Jogesuido Sekkei Co., Ltd.  
 37 Brookside Road Waterbury, CT 06708 USA +1-203-755-1666

WaterCAD v4.1.1 [4.2014]  
 Page 17

# Scenario: Scenario 1

J-2

Scenario Summary	
Label	Scenario 1
Physical Alternative	Base-Physical
Demand Alternative	Base-Average Daily
Initial Settings Alternative	Base-Initial Settings
Operational Alternative	Base-Operational
Age Alternative	Base-Age Alternative
Constituent Alternative	Base-Constituent
Trace Alternative	Base-Trace Alternative
Fire Flow Alternative	Fire Flow-Scenario 2
Cost Alternative	Base-Cost
User Data Alternative	Base-User Data

Calibration Summary			
Demand	<None>	Roughness	<None>

Geometric Summary			
X	3,029.599 m	Elevation	20.000 m
Y	3,058.359 m	Zone	Zone-1

Demand Summary		
Type	Demand (l/d)	Pattern
Demand	0	Fixed

User Data			
Observed Pressure	0.00 psi	Observed Concentration	0.00 mg/l
SCADA ID		Sampling Point	false
Hydrant Location	false	Existing	false

History:

Location Description:

Calculated Results Summary					
Time	Elevation (m)	Calculated Hydraulic Grade (m)	Pressure (m H2O)	Pressure Head (m)	Demand (Calculated) (l/d)
0.00 hr	20.000	96.058	75.8662	76.058	0
1.00 hr	20.000	96.290	76.0977	76.290	0
2.00 hr	20.000	96.539	76.3457	76.539	0
3.00 hr	20.000	96.804	76.6103	76.804	0
4.00 hr	20.000	97.090	76.8955	77.090	0
5.00 hr	20.000	97.392	77.1973	77.392	0
6.00 hr	20.000	97.641	77.4453	77.641	0
7.00 hr	20.000	97.658	77.4618	77.658	0
8.00 hr	20.000	97.550	77.3544	77.550	0
9.00 hr	20.000	97.334	77.1394	77.334	0
10.00 hr	20.000	97.086	76.8914	77.086	0
11.00 hr	20.000	96.854	76.6599	76.854	0
12.00 hr	20.000	96.659	76.4656	76.659	0
13.00 hr	20.000	96.535	76.3416	76.535	0
14.00 hr	20.000	96.448	76.2547	76.448	0
15.00 hr	20.000	96.394	76.2010	76.394	0
16.00 hr	20.000	96.356	76.1638	76.356	0
17.00 hr	20.000	96.286	76.0935	76.286	0
18.00 hr	20.000	96.145	75.9530	76.145	0
19.00 hr	20.000	95.950	75.7587	75.950	0
20.00 hr	20.000	95.772	75.5809	75.772	0
21.00 hr	20.000	95.685	75.4941	75.685	0
22.00 hr	20.000	95.722	75.5313	75.722	0
23.00 hr	20.000	95.863	75.6719	75.863	0
24.00 hr	20.000	96.058	75.8662	76.058	0

Title: Basic Design Study on the Project for the Improvement of Water Supply Scheme of Matara in Democratic Socialist of Sri Lanka  
Project Engineer: NJS

c:\...adopt only for pattern drwng jwwa 270m2.wcd  
03/05/09 15:33

© Haestad Methods, Inc.

Nippon Jogesuido Sekkei Co., Ltd.

37 Brookside Road Waterbury, CT 06708 USA

+1-203-755-1666

WaterCAD v4.1.1 [4.2014]

Page 18

# Scenario: Scenario 1

J-3

Scenario Summary	
Label	Scenario 1
Physical Alternative	Base-Physical
Demand Alternative	Base-Average Daily
Initial Settings Alternative	Base-Initial Settings
Operational Alternative	Base-Operational
Age Alternative	Base-Age Alternative
Constituent Alternative	Base-Constituent
Trace Alternative	Base-Trace Alternative
Fire Flow Alternative	Fire Flow-Scenario 2
Cost Alternative	Base-Cost
User Data Alternative	Base-User Data

Calibration Summary			
Demand	<None>	Roughness	<None>

Geometric Summary			
X	3,056.681 m	Elevation	20.000 m
Y	3,058.290 m	Zone	Zone-1

Demand Summary		
Type	Demand (l/d)	Pattern
Demand	0	Fixed

User Data			
Observed Pressure	0.00 psi	Observed Concentration	0.00 mg/l
SCADA ID		Sampling Point	false
Hydrant Location	false	Existing	false

History:

Location Description:

Calculated Results Summary					
Time	Elevation (m)	Calculated Hydraulic Grade (m)	Pressure (m H2O)	Pressure Head (m)	Demand (l/d)
0.00 hr	20.000	61.179	41.0747	41.179	0
1.00 hr	20.000	61.411	41.3062	41.411	0
2.00 hr	20.000	61.659	41.5542	41.659	0
3.00 hr	20.000	61.925	41.8188	41.925	0
4.00 hr	20.000	62.210	42.1040	42.210	0
5.00 hr	20.000	62.513	42.4058	42.513	0
6.00 hr	20.000	62.762	42.6538	42.762	0
7.00 hr	20.000	62.778	42.6704	42.778	0
8.00 hr	20.000	62.671	42.5629	42.671	0
9.00 hr	20.000	62.455	42.3479	42.455	0
10.00 hr	20.000	62.206	42.0999	42.206	0
11.00 hr	20.000	61.974	41.8684	41.974	0
12.00 hr	20.000	61.779	41.6741	41.779	0
13.00 hr	20.000	61.655	41.5501	41.655	0
14.00 hr	20.000	61.568	41.4633	41.568	0
15.00 hr	20.000	61.514	41.4095	41.514	0
16.00 hr	20.000	61.477	41.3723	41.477	0
17.00 hr	20.000	61.406	41.3021	41.406	0
18.00 hr	20.000	61.266	41.1615	41.266	0
19.00 hr	20.000	61.071	40.9672	41.071	0
20.00 hr	20.000	60.893	40.7895	40.893	0
21.00 hr	20.000	60.806	40.7027	40.806	0
22.00 hr	20.000	60.843	40.7399	40.843	0
23.00 hr	20.000	60.984	40.8804	40.984	0
24.00 hr	20.000	61.179	41.0747	41.179	0

Title: Basic Design Study on the Project for the Improvement of Water Supply Scheme of Matara in Democratic Socialist of Sri Lanka  
Project Engineer: NJS

c:\...adopt only for pattern drwng jwwa 270m2.wcd  
03/05/09 15:34

© Haestad Methods, Inc.

Nippon Jogesuido Sekkei Co., Ltd.

37 Brookside Road Waterbury, CT 06708 USA

+1-203-755-1666

WaterCAD v4.1.1 [4.2014]

Page 19

# Scenario: Scenario 1

J-4

Scenario Summary	
Label	Scenario 1
Physical Alternative	Base-Physical
Demand Alternative	Base-Average Daily
Initial Settings Alternative	Base-Initial Settings
Operational Alternative	Base-Operational
Age Alternative	Base-Age Alternative
Constituent Alternative	Base-Constituent
Trace Alternative	Base-Trace Alternative
Fire Flow Alternative	Fire Flow-Scenario 2
Cost Alternative	Base-Cost
User Data Alternative	Base-User Data

Calibration Summary			
Demand	<None>	Roughness	<None>

Geometric Summary			
X	3,070.921 m	Elevation	31.500 m
Y	3,051.365 m	Zone	Zone-1

Demand Summary		
Type	Demand (l/d)	Pattern
Demand	11,381,000	Fixed

User Data			
Observed Pressure	0.00 psi	Observed Concentration	0.00 mg/l
SCADA ID		Sampling Point	false
Hydrant Location	false	Existing	false

History:

Location Description:

Calculated Results Summary					
Time	Elevation (m)	Calculated Hydraulic Grade (m)	Pressure (m H2O)	Pressure Head (m)	Demand (Calculated) (l/d)
0.00 hr	31.500	49.652	18.1060	18.152	11,381,000
1.00 hr	31.500	49.884	18.3375	18.384	11,381,000
2.00 hr	31.500	50.132	18.5855	18.632	11,381,000
3.00 hr	31.500	50.398	18.8501	18.898	11,381,000
4.00 hr	31.500	50.684	19.1353	19.184	11,381,000
5.00 hr	31.500	50.986	19.4371	19.486	11,381,000
6.00 hr	31.500	51.235	19.6851	19.735	11,381,000
7.00 hr	31.500	51.251	19.7016	19.751	11,381,000
8.00 hr	31.500	51.144	19.5942	19.644	11,381,000
9.00 hr	31.500	50.928	19.3792	19.428	11,381,000
10.00 hr	31.500	50.680	19.1312	19.180	11,381,000
11.00 hr	31.500	50.447	18.8997	18.947	11,381,000
12.00 hr	31.500	50.253	18.7054	18.753	11,381,000
13.00 hr	31.500	50.128	18.5814	18.628	11,381,000
14.00 hr	31.500	50.041	18.4945	18.541	11,381,000
15.00 hr	31.500	49.987	18.4408	18.487	11,381,000
16.00 hr	31.500	49.950	18.4036	18.450	11,381,000
17.00 hr	31.500	49.880	18.3333	18.380	11,381,000
18.00 hr	31.500	49.739	18.1928	18.239	11,381,000
19.00 hr	31.500	49.544	17.9985	18.044	11,381,000
20.00 hr	31.500	49.366	17.8207	17.866	11,381,000
21.00 hr	31.500	49.279	17.7339	17.779	11,381,000
22.00 hr	31.500	49.316	17.7711	17.816	11,381,000
23.00 hr	31.500	49.457	17.9117	17.957	11,381,000
24.00 hr	31.500	49.652	18.1060	18.152	11,381,000

Title: Basic Design Study on the Project for the Improvement of Water Supply Scheme of Matara in Democratic Socialist of Sri Lanka  
Project Engineer: NJS

c:\...adopt only for pattern drwng jwwa 270m2.wcd  
03/05/09 15:42 © Haestad Methods, Inc.

Nippon Jogesuido Sekkei Co., Ltd.  
37 Brookside Road Waterbury, CT 06708 USA

+1-203-755-1666

WaterCAD v4.1.1 [4.2014]  
Page 20

# Scenario: Scenario 1

J-5

Scenario Summary	
Label	Scenario 1
Physical Alternative	Base-Physical
Demand Alternative	Base-Average Daily
Initial Settings Alternative	Base-Initial Settings
Operational Alternative	Base-Operational
Age Alternative	Base-Age Alternative
Constituent Alternative	Base-Constituent
Trace Alternative	Base-Trace Alternative
Fire Flow Alternative	Fire Flow-Scenario 2
Cost Alternative	Base-Cost
User Data Alternative	Base-User Data

Calibration Summary			
Demand	<None>	Roughness	<None>

Geometric Summary			
X	3,048.975 m	Elevation	40.000 m
Y	3,053.218 m	Zone	Zone-1

Demand Summary		
Type	Demand (l/d)	Pattern
Demand	2,688,000	Residential

User Data			
Observed Pressure	0.00 psi	Observed Concentration	0.00 mg/l
SCADA ID		Sampling Point	false
Hydrant Location	false	Existing	false

History:

Location Description:

Calculated Results Summary					
Time	Elevation (m)	Calculated Hydraulic Grade (m)	Pressure (m H2O)	Pressure Head (m)	Demand (Calculated) (l/d)
0.00 hr	40.000	70.395	30.3187	30.395	1,182,720
1.00 hr	40.000	70.628	30.5509	30.628	1,075,200
2.00 hr	40.000	70.878	30.7997	30.878	967,680
3.00 hr	40.000	71.144	31.0650	31.144	833,280
4.00 hr	40.000	71.430	31.3508	31.430	725,760
5.00 hr	40.000	71.731	31.6505	31.731	1,075,200
6.00 hr	40.000	71.963	31.8828	31.963	2,580,480
7.00 hr	40.000	71.967	31.8864	31.967	3,386,880
8.00 hr	40.000	71.846	31.7654	31.846	4,085,760
9.00 hr	40.000	71.626	31.5459	31.626	4,300,800
10.00 hr	40.000	71.379	31.3002	31.379	4,193,280
11.00 hr	40.000	71.152	31.0737	31.152	3,951,360
12.00 hr	40.000	70.966	30.8882	30.966	3,494,400
13.00 hr	40.000	70.846	30.7685	30.846	3,252,480
14.00 hr	40.000	70.763	30.6853	30.763	3,037,440
15.00 hr	40.000	70.711	30.6333	30.711	2,929,920
16.00 hr	40.000	70.670	30.5926	30.670	3,144,960
17.00 hr	40.000	70.591	30.5142	30.591	3,601,920
18.00 hr	40.000	70.444	30.3668	30.444	3,951,360
19.00 hr	40.000	70.251	30.1747	30.251	3,843,840
20.00 hr	40.000	70.084	30.0079	30.084	3,252,480
21.00 hr	40.000	70.009	29.9335	30.009	2,446,080
22.00 hr	40.000	70.054	29.9786	30.054	1,774,080
23.00 hr	40.000	70.199	30.1225	30.199	1,424,640
24.00 hr	40.000	70.395	30.3187	30.395	1,182,720

Title: Basic Design Study on the Project for the Improvement of Water Supply Scheme of Matara in Democratic Socialist of Sri Lanka  
Project Engineer: NJS

c:\...adopt only for pattern drwng jwwa 270m2.wcd  
03/05/09 15:42

© Haestad Methods, Inc.

Nippon Jogesuido Sekkei Co., Ltd.

37 Brookside Road Waterbury, CT 06708 USA

+1-203-755-1666

WaterCAD v4.1.1 [4.2014]

Page 21

# Scenario: Scenario 1

## P-1

Scenario Summary			
Label	Scenario 1		
Physical Alternative	Base-Physical		
Demand Alternative	Base-Average Daily		
Initial Settings Alternative	Base-Initial Settings		
Operational Alternative	Base-Operational		
Age Alternative	Base-Age Alternative		
Constituent Alternative	Base-Constituent		
Trace Alternative	Base-Trace Alternative		
Fire Flow Alternative	Fire Flow-Scenario 2		
Cost Alternative	Base-Cost		
User Data Alternative	Base-User Data		
Calibration Summary			
Demand	<None>	Roughness	<None>
Pipe Characteristics			
Material	Ductile Iron	Hazen- Williams C	120.0
Diameter	450 mm	Minor Loss Coefficient	0.000
Check Valve?	false	Length	4,000.000 m
From Node	J-1	To Node	J-2
Elevations			
From Elevation	120.000 m	To Elevation	20.000 m
Initial Status			
Initial Status	Open		
User Data			
Date Installed		Date Retired	
Inspection Date		Observed Flow	0.00 gpm
Lining		Pipe Class	
Exterior Coating		Nominal Diameter	0.00 in
Condition		Skeletonized	false
Metered	false	Existing	false

# Scenario: Scenario 1

History:

Calculated Results Summary									
Time	Control Status	Discharge (l/d)	Velocity (m/s)	Upstream Structure Hydraulic Grade (m)	Downstream Structure Hydraulic Grade (m)	Calculated Friction Headloss (m)	Calculated Minor Headloss (m)	Pressure Pipe Headloss (m)	Headloss Gradient (m/m)
0.00 hr	Open	14,069,000	1.024	106.314	96.058	10.256	0.000	10.256	0.00256
1.00 hr	Open	14,069,000	1.024	106.546	96.290	10.256	0.000	10.256	0.00256
2.00 hr	Open	14,069,000	1.024	106.795	96.539	10.256	0.000	10.256	0.00256
3.00 hr	Open	14,069,000	1.024	107.060	96.804	10.256	0.000	10.256	0.00256
4.00 hr	Open	14,069,000	1.024	107.346	97.090	10.256	0.000	10.256	0.00256
5.00 hr	Open	14,069,000	1.024	107.648	97.392	10.256	0.000	10.256	0.00256
6.00 hr	Open	14,069,000	1.024	107.897	97.641	10.256	0.000	10.256	0.00256
7.00 hr	Open	14,069,000	1.024	107.914	97.658	10.256	0.000	10.256	0.00256
8.00 hr	Open	14,069,000	1.024	107.806	97.550	10.256	0.000	10.256	0.00256
9.00 hr	Open	14,069,000	1.024	107.590	97.334	10.256	0.000	10.256	0.00256
10.00 hr	Open	14,069,000	1.024	107.342	97.086	10.256	0.000	10.256	0.00256
11.00 hr	Open	14,069,000	1.024	107.110	96.854	10.256	0.000	10.256	0.00256
12.00 hr	Open	14,069,000	1.024	106.915	96.659	10.256	0.000	10.256	0.00256
13.00 hr	Open	14,069,000	1.024	106.791	96.535	10.256	0.000	10.256	0.00256
14.00 hr	Open	14,069,000	1.024	106.704	96.448	10.256	0.000	10.256	0.00256
15.00 hr	Open	14,069,000	1.024	106.650	96.394	10.256	0.000	10.256	0.00256
16.00 hr	Open	14,069,000	1.024	106.612	96.356	10.256	0.000	10.256	0.00256
17.00 hr	Open	14,069,000	1.024	106.542	96.286	10.256	0.000	10.256	0.00256
18.00 hr	Open	14,069,000	1.024	106.401	96.145	10.256	0.000	10.256	0.00256
19.00 hr	Open	14,069,000	1.024	106.206	95.950	10.256	0.000	10.256	0.00256
20.00 hr	Open	14,069,000	1.024	106.028	95.772	10.256	0.000	10.256	0.00256
21.00 hr	Open	14,069,000	1.024	105.941	95.685	10.256	0.000	10.256	0.00256
22.00 hr	Open	14,069,000	1.024	105.978	95.722	10.256	0.000	10.256	0.00256
23.00 hr	Open	14,069,000	1.024	106.119	95.863	10.256	0.000	10.256	0.00256
24.00 hr	Open	14,069,000	1.024	106.314	96.058	10.256	0.000	10.256	0.00256

## P-2

Scenario Summary			
Label	Scenario 1		
Physical Alternative	Base-Physical		
Demand Alternative	Base-Average Daily		
Initial Settings Alternative	Base-Initial Settings		
Operational Alternative	Base-Operational		
Age Alternative	Base-Age Alternative		
Constituent Alternative	Base-Constituent		
Trace Alternative	Base-Trace Alternative		
Fire Flow Alternative	Fire Flow-Scenario 2		
Cost Alternative	Base-Cost		
User Data Alternative	Base-User Data		
Calibration Summary			
Demand	<None>	Roughness	<None>
Pipe Characteristics			
Material	Ductile Iron	Hazen- Williams C	120.0
Diameter	450 mm	Minor Loss Coefficient	0.000
Check Valve?	false	Length	10,007.000 m
From Node	J-2	To Node	T-1
Elevations			
From Elevation	20.000 m	To Elevation	72.000 m
Initial Status			
Initial Status	Open		
User Data			
Date Installed	Date Retired		

Title: Basic Design Study on the Project for the Improvement of Water Supply Scheme of Matara in Democratic Socialist of Sri Lanka

Project Engineer: NJS

c:\...adopt only for pattern drwng jwwa 270m2.wcd  
03/05/09 15:47 © Haestad Methods, Inc.

Nippon Jogesuido Sekkei Co., Ltd.  
37 Brookside Road Waterbury, CT 06708 USA

+1-203-755-1666

WaterCAD v4.1.1 [4.2014]  
Page 23

# Scenario: Scenario 1

---

## User Data

Inspection Date	Observed Flow	0.00 gpm
Lining	Pipe Class	
Exterior Coating	Nominal Diameter	0.00 in
Condition	Skeletonized	false
Metered	Existing	false

## History:

---

### Calculated Results Summary

Time	Control Status	Discharge (l/d)	Velocity (m/s)	Upstream Structure Hydraulic Grade (m)	Downstream Structure Hydraulic Grade (m)	Calculated Friction Headloss (m)	Calculated Minor Headloss (m)	Pressure Pipe Headloss (m)	Headloss Gradient (m/m)
0.00 hr	Open	14,069,000	1.024	96.058	70.400	25.658	0.000	25.658	0.00256
1.00 hr	Open	14,069,000	1.024	96.290	70.632	25.658	0.000	25.658	0.00256
2.00 hr	Open	14,069,000	1.024	96.539	70.881	25.658	0.000	25.658	0.00256
3.00 hr	Open	14,069,000	1.024	96.804	71.146	25.658	0.000	25.658	0.00256
4.00 hr	Open	14,069,000	1.024	97.090	71.432	25.658	0.000	25.658	0.00256
5.00 hr	Open	14,069,000	1.024	97.392	71.734	25.658	0.000	25.658	0.00256
6.00 hr	Open	14,069,000	1.024	97.641	71.983	25.658	0.000	25.658	0.00256
7.00 hr	Open	14,069,000	1.024	97.658	72.000	25.658	0.000	25.658	0.00256
8.00 hr	Open	14,069,000	1.024	97.550	71.892	25.658	0.000	25.658	0.00256
9.00 hr	Open	14,069,000	1.024	97.334	71.676	25.658	0.000	25.658	0.00256
10.00 hr	Open	14,069,000	1.024	97.086	71.428	25.658	0.000	25.658	0.00256
11.00 hr	Open	14,069,000	1.024	96.854	71.196	25.658	0.000	25.658	0.00256
12.00 hr	Open	14,069,000	1.024	96.659	71.001	25.658	0.000	25.658	0.00256
13.00 hr	Open	14,069,000	1.024	96.535	70.877	25.658	0.000	25.658	0.00256
14.00 hr	Open	14,069,000	1.024	96.448	70.790	25.658	0.000	25.658	0.00256
15.00 hr	Open	14,069,000	1.024	96.394	70.736	25.658	0.000	25.658	0.00256
16.00 hr	Open	14,069,000	1.024	96.356	70.698	25.658	0.000	25.658	0.00256
17.00 hr	Open	14,069,000	1.024	96.286	70.628	25.658	0.000	25.658	0.00256
18.00 hr	Open	14,069,000	1.024	96.145	70.487	25.658	0.000	25.658	0.00256
19.00 hr	Open	14,069,000	1.024	95.950	70.292	25.658	0.000	25.658	0.00256
20.00 hr	Open	14,069,000	1.024	95.772	70.114	25.658	0.000	25.658	0.00256
21.00 hr	Open	14,069,000	1.024	95.685	70.027	25.658	0.000	25.658	0.00256
22.00 hr	Open	14,069,000	1.024	95.722	70.064	25.658	0.000	25.658	0.00256
23.00 hr	Open	14,069,000	1.024	95.863	70.205	25.658	0.000	25.658	0.00256
24.00 hr	Open	14,069,000	1.024	96.058	70.400	25.658	0.000	25.658	0.00256

## P-3

---

### Scenario Summary

Label	Scenario 1
Physical Alternative	Base-Physical
Demand Alternative	Base-Average Daily
Initial Settings Alternative	Base-Initial Settings
Operational Alternative	Base-Operational
Age Alternative	Base-Age Alternative
Constituent Alternative	Base-Constituent
Trace Alternative	Base-Trace Alternative
Fire Flow Alternative	Fire Flow-Scenario 2
Cost Alternative	Base-Cost
User Data Alternative	Base-User Data

---

### Calibration Summary

Demand	<None>	Roughness	<None>
--------	--------	-----------	--------

---

### Pipe Characteristics

Material	Ductile Iron	Hazen- Williams C	120.0
Diameter	400 mm	Minor Loss Coefficient	0.000
Check Valve?	false	Length	3,000.000 m
From Node	T-1	To Node	J-3

---

### Elevations

From Elevation	72.000 m	To Elevation	20.000 m
----------------	----------	--------------	----------

Title: Basic Design Study on the Project for the Improvement of Water Supply Scheme of Matara in Democratic Socialist of Sri Lanka

Project Engineer: NJS



# Scenario: Scenario 1

Initial Status			
Initial Status	Open		
User Data			
Date Installed	Date Retired		
Inspection Date	Observed Flow	0.00 gpm	
Lining	Pipe Class		
Exterior Coating	Nominal Diameter	0.00 in	
Condition	Skeletonized	false	
Metered	false	Existing	false

History:

Calculated Results Summary										
Time	Control Status	Discharge (l/d)	Velocity (m/s)	Upstream Structure Hydraulic Grade (m)	Downstream Structure Hydraulic Grade (m)	Calculated Friction Headloss (m)	Calculated Minor Headloss (m)	Pressure Pipe Headloss (m)	Headloss Gradient (m/m)	
0.00 hr	Open	11,381,000	1.048	70.400	61.179	9.221	0.000	9.221	0.00307	
1.00 hr	Open	11,381,000	1.048	70.632	61.411	9.221	0.000	9.221	0.00307	
2.00 hr	Open	11,381,000	1.048	70.881	61.659	9.221	0.000	9.221	0.00307	
3.00 hr	Open	11,381,000	1.048	71.146	61.925	9.221	0.000	9.221	0.00307	
4.00 hr	Open	11,381,000	1.048	71.432	62.210	9.221	0.000	9.221	0.00307	
5.00 hr	Open	11,381,000	1.048	71.734	62.513	9.221	0.000	9.221	0.00307	
6.00 hr	Open	11,381,000	1.048	71.983	62.762	9.221	0.000	9.221	0.00307	
7.00 hr	Open	11,381,000	1.048	72.000	62.778	9.221	0.000	9.221	0.00307	
8.00 hr	Open	11,381,000	1.048	71.892	62.671	9.221	0.000	9.221	0.00307	
9.00 hr	Open	11,381,000	1.048	71.676	62.455	9.221	0.000	9.221	0.00307	
10.00 hr	Open	11,381,000	1.048	71.428	62.206	9.221	0.000	9.221	0.00307	
11.00 hr	Open	11,381,000	1.048	71.196	61.974	9.221	0.000	9.221	0.00307	
12.00 hr	Open	11,381,000	1.048	71.001	61.779	9.221	0.000	9.221	0.00307	
13.00 hr	Open	11,381,000	1.048	70.877	61.655	9.221	0.000	9.221	0.00307	
14.00 hr	Open	11,381,000	1.048	70.790	61.568	9.221	0.000	9.221	0.00307	
15.00 hr	Open	11,381,000	1.048	70.736	61.514	9.221	0.000	9.221	0.00307	
16.00 hr	Open	11,381,000	1.048	70.698	61.477	9.221	0.000	9.221	0.00307	
17.00 hr	Open	11,381,000	1.048	70.628	61.406	9.221	0.000	9.221	0.00307	
18.00 hr	Open	11,381,000	1.048	70.487	61.266	9.221	0.000	9.221	0.00307	
19.00 hr	Open	11,381,000	1.048	70.292	61.071	9.221	0.000	9.221	0.00307	
20.00 hr	Open	11,381,000	1.048	70.114	60.893	9.221	0.000	9.221	0.00307	
21.00 hr	Open	11,381,000	1.048	70.027	60.806	9.221	0.000	9.221	0.00307	
22.00 hr	Open	11,381,000	1.048	70.064	60.843	9.221	0.000	9.221	0.00307	
23.00 hr	Open	11,381,000	1.048	70.205	60.984	9.221	0.000	9.221	0.00307	
24.00 hr	Open	11,381,000	1.048	70.400	61.179	9.221	0.000	9.221	0.00307	

## P-4

Scenario Summary	
Label	Scenario 1
Physical Alternative	Base-Physical
Demand Alternative	Base-Average Daily
Initial Settings Alternative	Base-Initial Settings
Operational Alternative	Base-Operational
Age Alternative	Base-Age Alternative
Constituent Alternative	Base-Constituent
Trace Alternative	Base-Trace Alternative
Fire Flow Alternative	Fire Flow-Scenario 2
Cost Alternative	Base-Cost
User Data Alternative	Base-User Data

Calibration Summary	
Demand	<None>
Roughness	<None>

Pipe Characteristics	
Material	Ductile Iron
Hazen-Williams C	120.0

Title: Basic Design Study on the Project for the Improvement of Water Supply Scheme of Matara in Democratic Socialist of Sri Lanka

Project Engineer: NJS

c:\...adopt only for pattern drwg jwwa 270m2.wcd  
03/05/09 15:48 © Haestad Methods, Inc.

Nippon Jogesuido Sekkei Co., Ltd.  
37 Brookside Road Waterbury, CT 06708 USA

+1-203-755-1666

WaterCAD v4.1.1 [4.2014]  
Page 25

# Scenario: Scenario 1

Pipe Characteristics			
Diameter	400 mm	Minor Loss Coefficient	0.000
Check Valve?	false	Length	3,750.000 m
From Node	J-3	To Node	J-4

Elevations			
From Elevation	20.000 m	To Elevation	31.500 m

Initial Status	
Initial Status	Open

User Data			
Date Installed		Date Retired	
Inspection Date		Observed Flow	0.00 gpm
Lining		Pipe Class	
Exterior Coating		Nominal Diameter	0.00 in
Condition		Skeletonized	false
Metered	false	Existing	false

History:

Calculated Results Summary										
Time	Control Status	Discharge (l/d)	Velocity (m/s)	Upstream Structure Hydraulic Grade (m)	Downstream Structure Hydraulic Grade (m)	Calculated Friction Headloss (m)	Calculated Minor Headloss (m)	Pressure Pipe Headloss (m)	Headloss Gradient (m/m)	
0.00 hr	Open	11,381,000	1.048	61.179	49.652	11.527	0.000	11.527	0.00307	
1.00 hr	Open	11,381,000	1.048	61.411	49.884	11.527	0.000	11.527	0.00307	
2.00 hr	Open	11,381,000	1.048	61.659	50.132	11.527	0.000	11.527	0.00307	
3.00 hr	Open	11,381,000	1.048	61.925	50.398	11.527	0.000	11.527	0.00307	
4.00 hr	Open	11,381,000	1.048	62.210	50.684	11.527	0.000	11.527	0.00307	
5.00 hr	Open	11,381,000	1.048	62.513	50.986	11.527	0.000	11.527	0.00307	
6.00 hr	Open	11,381,000	1.048	62.762	51.235	11.527	0.000	11.527	0.00307	
7.00 hr	Open	11,381,000	1.048	62.778	51.251	11.527	0.000	11.527	0.00307	
8.00 hr	Open	11,381,000	1.048	62.671	51.144	11.527	0.000	11.527	0.00307	
9.00 hr	Open	11,381,000	1.048	62.455	50.928	11.527	0.000	11.527	0.00307	
10.00 hr	Open	11,381,000	1.048	62.206	50.680	11.527	0.000	11.527	0.00307	
11.00 hr	Open	11,381,000	1.048	61.974	50.447	11.527	0.000	11.527	0.00307	
12.00 hr	Open	11,381,000	1.048	61.779	50.253	11.527	0.000	11.527	0.00307	
13.00 hr	Open	11,381,000	1.048	61.655	50.128	11.527	0.000	11.527	0.00307	
14.00 hr	Open	11,381,000	1.048	61.568	50.041	11.527	0.000	11.527	0.00307	
15.00 hr	Open	11,381,000	1.048	61.514	49.987	11.527	0.000	11.527	0.00307	
16.00 hr	Open	11,381,000	1.048	61.477	49.950	11.527	0.000	11.527	0.00307	
17.00 hr	Open	11,381,000	1.048	61.406	49.880	11.527	0.000	11.527	0.00307	
18.00 hr	Open	11,381,000	1.048	61.266	49.739	11.527	0.000	11.527	0.00307	
19.00 hr	Open	11,381,000	1.048	61.071	49.544	11.527	0.000	11.527	0.00307	
20.00 hr	Open	11,381,000	1.048	60.893	49.366	11.527	0.000	11.527	0.00307	
21.00 hr	Open	11,381,000	1.048	60.806	49.279	11.527	0.000	11.527	0.00307	
22.00 hr	Open	11,381,000	1.048	60.843	49.316	11.527	0.000	11.527	0.00307	
23.00 hr	Open	11,381,000	1.048	60.984	49.457	11.527	0.000	11.527	0.00307	
24.00 hr	Open	11,381,000	1.048	61.179	49.652	11.527	0.000	11.527	0.00307	

## P-5

Scenario Summary	
Label	Scenario 1
Physical Alternative	Base-Physical
Demand Alternative	Base-Average Daily
Initial Settings Alternative	Base-Initial Settings
Operational Alternative	Base-Operational
Age Alternative	Base-Age Alternative
Constituent Alternative	Base-Constituent
Trace Alternative	Base-Trace Alternative
Fire Flow Alternative	Fire Flow-Scenario 2
Cost Alternative	Base-Cost
User Data Alternative	Base-User Data

Title: Basic Design Study on the Project for the Improvement of Water Supply Scheme of Matara in Democratic Socialist of Sri Lanka  
 Project Engineer: NJS

# Scenario: Scenario 1

<b>Calibration Summary</b>			
Demand	<None>	Roughness	<None>
<b>Pipe Characteristics</b>			
Material	Ductile Iron	Hazen- Williams C	120.0
Diameter	400 mm	Minor Loss Coefficient	0.000
Check Valve?	false	Length	100.000 m
From Node	T-1	To Node	J-5
<b>Elevations</b>			
From Elevation	72.000 m	To Elevation	40.000 m
<b>Initial Status</b>			
Initial Status	Open		
<b>User Data</b>			
Date Installed		Date Retired	
Inspection Date		Observed Flow	0.00 gpm
Lining		Pipe Class	
Exterior Coating		Nominal Diameter	0.00 in
Condition		Skeletonized	false
Metered	false	Existing	false

History:

<b>Calculated Results Summary</b>										
Time	Control Status	Discharge (l/d)	Velocity (m/s)	Upstream Structure Hydraulic Grade (m)	Downstream Structure Hydraulic Grade (m)	Calculated Friction Headloss (m)	Calculated Minor Headloss (m)	Pressure Pipe Headloss (m)	Headloss Gradient (m/m)	
0.00 hr	Open	1,182,720	0.109	70.400	70.395	0.005	0.000	0.005	0.00005	
1.00 hr	Open	1,075,200	0.099	70.632	70.628	0.004	0.000	0.004	0.00004	
2.00 hr	Open	967,680	0.089	70.881	70.878	0.003	0.000	0.003	0.00003	
3.00 hr	Open	833,280	0.077	71.146	71.144	0.002	0.000	0.002	0.00002	
4.00 hr	Open	725,760	0.067	71.432	71.430	0.002	0.000	0.002	0.00002	
5.00 hr	Open	1,075,200	0.099	71.734	71.731	0.004	0.000	0.004	0.00004	
6.00 hr	Open	2,580,480	0.238	71.983	71.963	0.020	0.000	0.020	0.00020	
7.00 hr	Open	3,386,880	0.312	72.000	71.967	0.033	0.000	0.033	0.00033	
8.00 hr	Open	4,085,760	0.376	71.892	71.846	0.046	0.000	0.046	0.00046	
9.00 hr	Open	4,300,800	0.396	71.676	71.626	0.051	0.000	0.051	0.00051	
10.00 hr	Open	4,193,280	0.386	71.428	71.379	0.048	0.000	0.048	0.00048	
11.00 hr	Open	3,951,360	0.364	71.196	71.152	0.043	0.000	0.043	0.00043	
12.00 hr	Open	3,494,400	0.322	71.001	70.966	0.035	0.000	0.035	0.00035	
13.00 hr	Open	3,252,480	0.300	70.877	70.846	0.030	0.000	0.030	0.00030	
14.00 hr	Open	3,037,440	0.280	70.790	70.763	0.027	0.000	0.027	0.00027	
15.00 hr	Open	2,929,920	0.270	70.736	70.711	0.025	0.000	0.025	0.00025	
16.00 hr	Open	3,144,960	0.290	70.698	70.670	0.028	0.000	0.028	0.00028	
17.00 hr	Open	3,601,920	0.332	70.628	70.591	0.037	0.000	0.037	0.00037	
18.00 hr	Open	3,951,360	0.364	70.487	70.444	0.043	0.000	0.043	0.00043	
19.00 hr	Open	3,843,840	0.354	70.292	70.251	0.041	0.000	0.041	0.00041	
20.00 hr	Open	3,252,480	0.300	70.114	70.084	0.030	0.000	0.030	0.00030	
21.00 hr	Open	2,446,080	0.225	70.027	70.009	0.018	0.000	0.018	0.00018	
22.00 hr	Open	1,774,080	0.163	70.064	70.054	0.010	0.000	0.010	0.00010	
23.00 hr	Open	1,424,640	0.131	70.205	70.199	0.007	0.000	0.007	0.00007	
24.00 hr	Open	1,182,720	0.109	70.400	70.395	0.005	0.000	0.005	0.00005	


# Scenario: Scenario 1

P-5

Pattern Summary

Pattern	Residential	Format	Stepwise
Start Time	0.00 hr	Starting Multiplier	0.400
Duration	24.00 hr		


Pattern	
Time from Start (hr)	Multiplier
1.00	0.350
2.00	0.300
3.00	0.260
4.00	0.210
5.00	0.350
6.00	0.950
7.00	1.280
8.00	1.570
9.00	1.650
10.00	1.600
11.00	1.510
12.00	1.320
13.00	1.230
14.00	1.140
15.00	1.090
16.00	1.190
17.00	1.370
18.00	1.510
19.00	1.460
20.00	1.230
21.00	0.910
22.00	0.630
23.00	0.490
24.00	0.400



## 参考資料 3.3

### ディヤガハ配水区管網計算書

Scenario: Base



**Scenario: Base**  
**Steady State Analysis**  
**Junction Report**

Label	Elevation (m)	Zone	Type	Demand (l/d)	Pattern	Demand (Calculated) (l/d)	Calculated Hydraulic Grade (m)	Pressure (m H2O)
J-1	42.92	Zone-1	Demand	194,000	Fixed	194,000	67.84	24.86
J-2	1.72	Zone-1	Demand	372,000	Fixed	372,000	65.40	63.52
J-3	1.40	Zone-1	Demand	399,000	Fixed	399,000	34.12	32.64
J-4	5.08	Zone-1	Demand	137,000	Fixed	137,000	62.75	57.52
J-5	10.86	Zone-1	Demand	62,000	Fixed	62,000	61.05	50.06
J-6	11.79	Zone-1	Demand	130,000	Fixed	130,000	61.50	49.59
J-7	28.20	Zone-1	Demand	130,000	Fixed	130,000	56.81	28.53
J-8	54.29	Zone-1	Demand	253,000	Fixed	253,000	60.87	6.56
J-9	31.83	Zone-1	Demand	253,000	Fixed	253,000	60.87	28.97
J-10	16.19	Zone-1	Demand	28,000	Fixed	28,000	61.38	45.08
J-11	13.31	Zone-1	Demand	28,000	Fixed	28,000	61.45	48.02
J-12	12.97	Zone-1	Demand	28,000	Fixed	28,000	61.24	48.15
J-13	14.48	Zone-1	Demand	28,000	Fixed	28,000	60.50	45.91
J-14	10.68	Zone-1	Demand	28,000	Fixed	28,000	60.33	49.53
J-15	26.57	Zone-1	Demand	28,000	Fixed	28,000	60.15	33.50
J-16	17.23	Zone-1	Demand	28,000	Fixed	28,000	62.71	45.37
J-17	9.49	Zone-1	Demand	28,000	Fixed	28,000	61.51	51.89
J-18	24.88	Zone-1	Demand	125,000	Fixed	125,000	63.19	38.21
J-19	19.68	Zone-1	Demand	1,092,000	Fixed	1,092,000	58.50	38.72
J-20	30.09	Zone-1	Demand	391,000	Fixed	391,000	44.29	14.16
J-21	10.11	Zone-1	Demand	514,000	Fixed	514,000	33.79	23.62
J-22	8.80	Zone-1	Demand	280,000	Fixed	280,000	26.25	17.40
J-23	17.54	Zone-1	Demand	48,000	Fixed	48,000	56.06	38.43
J-24	18.11	Zone-1	Demand	48,000	Fixed	48,000	55.89	37.68
J-25	39.35	Zone-1	Demand	1,050,000	Fixed	1,050,000	54.81	15.42
J-27	19.96	Zone-1	Demand	621,000	Fixed	621,000	46.67	26.64
J-28	11.90	Zone-1	Demand	383,000	Fixed	383,000	39.98	28.01
J-29	31.74	Zone-1	Demand	349,000	Fixed	349,000	63.77	31.95
J-30	4.48	Zone-1	Demand	850,000	Fixed	850,000	42.00	37.43

**Scenario: Base  
Steady State Analysis  
Pipe Report**

Label	Length (m)	Diameter (mm)	Material	Hazen-Williams C	Check Valve?	Minor Loss Coefficient	Control Status	Discharge (l/d)	Upstream Structure Hydraulic Grade (m)	Downstream Structure Hydraulic Grade (m)	Pressure Pipe Headloss (m)	Headloss Gradient (m/km)
P-1	100	400	Ductile Iron	120.0	false	0.00	Open	7,905,000	68.00	67.84	0.16	1.57
P-2	1,500	250	Ductile Iron	120.0	false	0.00	Open	2,341,794	67.84	65.40	2.44	1.63
P-3	2,155	79	PVC	130.0	false	0.00	Open	399,000	65.40	34.12	31.28	14.52
P-4	1,271	198	PVC	130.0	false	0.00	Open	1,570,794	65.40	62.75	2.65	2.09
P-5	69	97	PVC	130.0	false	0.00	Open	912,000	62.75	61.05	1.70	24.65
P-6	452	123	PVC	130.0	false	0.00	Open	521,794	62.75	61.50	1.25	2.76
P-7	996	65	PVC	130.0	false	0.00	Open	130,000	61.50	56.81	4.69	4.71
P-8	819	123	PVC	130.0	false	0.00	Open	261,794	61.50	60.87	0.63	0.77
P-9	887	123	PVC	130.0	false	0.00	Open	8,794	60.87	60.87	1.28e-3	1.45e-3
P-10	758	123	PVC	130.0	false	0.00	Open	-244,206	60.87	61.38	0.51	0.68
P-11	85	123	PVC	130.0	false	0.00	Open	-272,206	61.38	61.45	0.07	0.83
P-12	9	44	PVC	130.0	false	0.00	Open	112,000	61.45	61.24	0.22	23.93
P-13	111	44	PVC	130.0	false	0.00	Open	56,000	61.24	60.50	0.74	6.64
P-14	92	44	PVC	130.0	false	0.00	Open	28,000	60.50	60.33	0.17	1.84
P-15	591	44	PVC	130.0	false	0.00	Open	28,000	61.24	60.15	1.09	1.84
P-16	704	123	PVC	130.0	false	0.00	Open	-412,206	61.45	62.71	1.26	1.78
P-17	650	44	PVC	130.0	false	0.00	Open	28,000	62.71	61.51	1.20	1.84
P-18	211	123	PVC	130.0	false	0.00	Open	-466,206	62.71	63.19	0.48	2.26
P-19	887	250	Ductile Iron	120.0	false	0.00	Open	4,427,000	63.19	58.50	4.69	5.29
P-20	720	97	PVC	130.0	false	0.00	Open	808,641	58.50	44.29	14.21	19.73
P-21	665	79	PVC	130.0	false	0.00	Open	417,641	44.29	33.79	10.50	15.79
P-22	1,000	79	PVC	130.0	false	0.00	Open	280,000	33.79	26.25	7.54	7.54
P-23	1,710	79	PVC	130.0	false	0.00	Open	-376,359	33.79	56.08	22.26	19.03
P-24	1,300	250	Ductile Iron	120.0	false	0.00	Open	2,526,359	56.50	56.08	2.43	1.87
P-25	50	198	PVC	130.0	false	0.00	Open	2,102,000	56.06	55.89	0.18	3.58
P-26	1,090	198	PVC	130.0	false	0.00	Open	1,050,000	55.89	54.81	1.08	0.89
P-28	995	123	PVC	130.0	false	0.00	Open	1,004,000	55.89	46.67	9.22	9.26
P-29	1,350	97	PVC	130.0	false	0.00	Open	383,000	46.67	39.98	6.69	4.95
P-30	213	300	Ductile Iron	120.0	false	0.00	Open	-5,020,206	63.19	63.77	0.58	2.74
P-31	1,310	300	Ductile Iron	120.0	false	0.00	Open	-5,369,206	63.77	67.84	4.07	3.11
P-32	880	97	PVC	130.0	false	0.00	Open	850,000	61.05	42.00	19.05	21.64