



5 . 建築・設備関連図面（フエ中央病院）

- (1) 現況配置図 dw-1
- (2) 関連施設 1 階平面図 dw-2
- (3) 関連施設 2 階平面図 dw-3
- (4) 新小児病棟 1 - 4 階平面図 kt-02 ~ 05
- (5) 新循環器センター 1 - 6 階平面図 kt-01 ~ 06
- (6) 電気設備 既存病院系統図 資料-1 ~ 2
- (7) 電気設備 地下ケーブル系統図 資料-3 ~ 8
- (8) 給水設備 系統図 資料-9
- (9) 排水設備 主放流経路 資料-10
- (10) 放流水質 フエ人民委員会環境部によるフエ
病院放流水質検査 資料-11



<p>Existing site plan</p>	<p>LOCATION : Hue City - Vietnam 0000-1-10 Architect Y. HIRAKAWA</p>	<p>Hue central hospital</p>
<p>scale : 1 = 2500</p>		<p>dw-01</p>



1F

I. C. U. Dept. 444.000m²


Project for the improvement of Hue central hospital

Location: Hue City - Vietnam

Existing Target Building plan

1F scale: 1:600

dw-02



2F

Project for the improvement of Hue central hospital

Existing Target Building plan

dw-03

Location: Hue City - Vietnam
 Architect: I. G. U. Dept.

Scale: 1 - 600

EAST MEETS WEST

SANITARY ROOM

PHÒNG TẮM VÀ PHÒNG CHUYỂN MÀU

HUE
MAT BANG TANG 1

CÔNG TRÌNH TIẾP
XÂY DỰNG TIẾP


NGUYỄN VĂN KHANH



TRUNG TÂM THIẾT KẾ VÀ XÂY DỰNG
10/...
ĐIỆN THOẠI: ...
...
...
...

BAN VE KI THIẾT
... 1/2000

KT-02



MAT BANG TANG 1
KHOA NỘI BỆNH VIỆN TƯ HUE

BAO MỸ VIỆT
 10A DƯƠNG THƯỜNG KIỆT
 QUẬN HOÀNG PHƯƠNG
 HUE

MAT BANG TANG 2
 B. LE (SCALE) 1/100
 HOC DAY 1:24


CÔNG TY KIẾN TRÚC XÂY DỰNG VÀ NỘI
 P. DUY BOC

NGUYỄN VĂN THINH
 30-TRẦN THẠCH
 100-NGUYỄN VĂN THINH
 100-TRẦN THẠCH


U. U. U.
 KTS - VU HOANG HUC
 THUC AT

KEA SUAT
 G. PHUAT

BAN VE KI THUAT
 THANG 5-2000
KT-08



MAT BANG TANG 2



MAT BANG TANG 8

EAST-MEERI WEST 300 Đ. ĐINH QUÝ ĐANG QUẬN TÂY HỒ HUE MAT BANG TANG 8 P. LÊ (Đ. L. L.) (7/10) SỐ QUÂN 1.34	CÔNG TIÊN THẢO XÂY DỰNG HÀ NỘI P. QUANG HUY	NGUYỄN VĂN THƯỜNG SỐ QUÂN 1.34	KIS - VU HOANG HAC SỐ QUÂN 1.34	B. LÊ (Đ. L. L.) (7/10) SỐ QUÂN 1.34	BAN YẾP QUẢN LÝ THANG 8-2000 KT-04
--	---	-----------------------------------	------------------------------------	---	---

EAST MEETS WEST
 FOR BUILDING DESIGN
 BÊN NHÌN TÂY HẢI
 CHINH THẮNG FIELDS
 HƯNG HƯNG

HỒ
MAT BANG TANG 4
 T. LÊ (SCALE) 1:100
 2/10/2011


CÔNG TY KIẾN TRÚC
 XÂY DỰNG HÀ NỘI
 P. LÊ QUANG ĐỨC

NGUYỄN VĂN THÁNH
 ARCHITECTURE
 SERVICE OFFICE
 1/1 - 1/11
 7/10 - 2/11/2011
 E-MAIL: thanh@architect.vn

Nguyễn Văn Thành
 KTS - VU HOANG HUC
 2/1/11

ALPHABET
 2/1/11









BAN YE KI THIẾT
 THÁNG 5-2000
KT-05




MAT BANG TANG 4

CHẾ ĐỘ

- CAC MOC GIOI A-B-C-D-E-N SAC DANH VA TRI (KHU A) DIEN TICH DAT : 87.853 M²
- CAC MOC GIOI K-L-M-N SAC DANH VA TRI (KHU B) DIEN TICH DAT : 8.303 M²
- CAC MOC GIOI P-R-S-T SAC DANH VA TRI (KHU C) DIEN TICH DAT : 12.608 M²
- TONG DIEN TICH DAT (A)+(B)+(C) : 89.366 M²

-  - PHAN CONG TRINH XAY MOI VA MQ BONG
-  - NHÀ MÀM NƠI DÀ CÓ NƠI HẠNH SỬ DỤNG TỰ BÒ ĐẾN 100 KM (KHEN TRƯỚC CỬ CỦA PHÁP ĐƯỢC XÂY DỰNG TỰ BẢO THỂ KỶ) CÔNG TRÌNH DƯ KIỆN CẤU TẠO
-  - NHÀ MÀM BANG CHONG HONG BANG / BROCKMEN
-  ĐƯỢC XÂY DỰNG TRƯỚC NĂM 1975
-  - PHAN CONG TRINH PHA DO DOT 1
-  - PHAN CONG TRINH ANANG TANG
-  - CÔNG TRÌNH BANG CẤ TẠO VÀ MQ BONG
-  - CỬ NHÀM SỬ DỤNG DAT CỦA NHÀ CHUA




VI TRI XAY DUNG
TRUNG TAM TIM MACH 6 TANG


MAT BANG VI TRI PHUONG AN CHON

KT-01




MAT BANG TANG 1 TIEU 1/200
CAP CUNG BANH DON TIEP






MAT BANG TANG 2 TIEP 1/200
ARCHITECT NGUYEN THU & HANH CHINH



MAT BANG TANG 64 TILL 1200
CHU THIN



MAT BANG TANG 5 TILE 1000
CHAU PHAU AHAU PHAU

HUE CENTRAL HOSPITAL


UNDERGROUND CABLES SYSTEM

1. High Voltage from Hue Electricity Department to Hospital:
 - Underground cables from Hue Electricity Department to Electricity Pole at the corner of Nguyen Hue - Hai Ba Trung Street
 - High voltage go along 4 electricity poles of 14 meter high
2. Underground cables bring electricity from high voltage pole at the end of power line to low voltage station.
3. Underground cables system bring electricity from the low voltage station to Buildings A,B,C,D.
4. There are electricity boxes in each Buildings with automatic control panels.

The whole electricity system of Hue Central Hospital is over 1 billion VND and need to be periodically maintained.


ĐƯỜNG DÂY ĐIỆN CAO THẾ VÀO CABIN → High voltage power line to cabin


PLAN OF UNDERGROUND CABLE



HÔPITAL HNHÉ

EMPLACEMENT DU NOUVEAU POSTE DE TRANSFORMATION





Underground cable system → HỆ THỐNG ĐIỆN CÁP NGẦM
(power)

Tuyll

Ngày 9-8-79
 Tham khảo báo về công tác
 1. Đường cable phải tuân thủ có khu vực
 phát hiện, sửa chữa.
 2. Giám phân phối khu vực D cần có 1 Ad không
 Song song phải có số có kỹ thuật viên chịu
 trách nhiệm.

GIÁM ĐỐC
 (Seal)
 T. Nguyễn Văn...

BỆNH VIỆN TRUNG ƯƠNG HUẾ
HUẾ CENTRAL HOSPITAL


資料-4

MẶT BẰNG

HỆ THỐNG ĐIỆN

VÀ ĐIỆN THOẠI

↓
Electricity and Telephone System



1. MỘT SỐ THÔNG TIN CHUNG:
 □ HỒ THẪM CÁP NGẦM CỦA HỆ THỐNG CABLE NGẦM.
 ○ TRỤ ĐIỆN CỦA HỆ THỐNG DÂY TRỜI

* TỔNG ĐÀI ĐIỆN THOẠI
 5 máy 100 cửa.
 → → → CÁP NGẦM

- 1. Hệ thống điện: Hệ thống điện bệnh viện gồm có hai phần
- 1.1. Chương dây cao thế từ Sở điện lực về bệnh viện
- 1.2. Chương dây trung thế từ trạm của bệnh viện Trung Ương Huế
- 2. Hệ thống điện trong bệnh viện:
 - Trạm biến thế: 1 trạm 10 công suất
 - Các tủ 500 KVA đang sử dụng (bệnh viện Trung Ương Huế)
 - Các tủ 120 KVA dự phòng với 1 máy dự phòng
 - Các tủ 65 KVA và
 - Các tủ 65 KVA
- 3. Hệ thống điện thoại:
 - Máy phát điện: 2 máy 65 KVA
 - Máy phát điện: 2 máy 65 KVA

Wuylle TRỤ phân phối...
 Trời đi khắp B.V.
 cho tất cả cơ sở
 có máy điện thoại
 - 5 máy điện thoại


trang hai

Lã - Văn - Vinh

INGENIEUR ELECTRONICIEN EFREN
INGENIEUR CONCRET,
242/14, Truong-Minh-Ky GIA-DINH
Binh Phuoc 2427 SAIGON

BẢNG PHÂN PHỐI ĐIỆN NHÀ A & B

Electric Circuit Board - Block A & B



Signatures and date: *Lã Văn Vinh*
Sign: *Lã Văn Vinh*
Date: *Sign 29-11-72*

LIÊN VIÊN TRƯỜNG UÔNG HUE

TO : MR. SHIMADA
資-50
(ORIGINAL)


From: SATO / HA
(10 pages)

Điện

BỆNH VIỆN TRUNG ƯƠNG
HUE
(Pue Central Hospital)

BẢNG PHÂN PHỐI ĐIỆN NHÀ C
Electric Circuit Board - Block C

Lê-Vinh-Vinh
INSTITUTE OF ELECTRONIC ENGINEERING
INSTITUTE GENERAL
269/14, Trưng-Khắc-Ky Q1A-BHVN
Delta Pacific 7417 SAIGON



KHU C1 (Block C1)

KHU C2 (Block C2)

Lê-Vinh

Saigon 29-11-72


Caravanish

Lê-Vinh

Li - Van - Vinh
INGENIEUR ELECTRONIQUE ESPR
INNOVATION CENTER
257/14, Truong Minh Ky Street
Binh Phuoc 7427 SAIGON

BẢNG PHÂN PHỐI ĐIỆN NHÀ D
Electric Circuit Board - Block D

TRUNG VIỆN KỸ THUẬT
HUE




Saigon 29-11-72
Li Van Vinh

Li Van Vinh

BỆNH VIỆN TRUNG ƯƠNG
 HUE
 BẢNG PHÂN PHỐI ĐIỆN NHÀ E

Electric Circuit Board - Block E

LA - Uẩn - Vĩnh
 207/14, Trưng-Hà-Hệ-Dương
 HỒI-VIS (176-242) SAIGON



Saigon 29-11-72
Lozawank
Tuyet



Water consumption
800 m³/day

資料-9


BỘ Y TẾ
BỆNH VIỆN TRUNG ƯƠNG HUẾ
16 LÊ LỢI, HUẾ, VIỆT NAM
Số 54.822325 : Fax 84.54.823324
E-mail: bvlwhue@dong.vnn.vn

Main gate

- φ 300: Lê Lợi Street
- φ 100: Ng. Huy Tụ Street
- 2 ☐ water tank 50 m³

SCALE: 1/2000
SURFACE OF LAND:

- Zonè A: 67,955m²
- Zonè B : 8,803m²
- Zonè C: 12,608m²
- total : 89,366m²




Nguồn vào: → INLET

- Đường Lê Lợi φ 300 vào φ 200 vào φ 100
- Đường N.H.Tụ φ 100 vào
- Đường Ngô Quyền φ 100 vào

TE WATER TREATMENT SYSTEM

資料-10

WASTE
TREAT
THE R.



ANALYSIS RESULTS OF WASTEWATER SAMPLE AND HUONG RIVER

Location: Hue Central Hospital

Date: June 22, 1999

Weather status: Sunny, temperature 35°C, speed = 0.22 m/s, w = 74%

Measuring equipment:

+ Spectrometer DR 2000 (USA)

+ Meter DO (USA)

+ Meter pH (Germany)

+ Analysis balance (China)

+ Meter BOD (Germany)

No.	Location to take sample	t° H ₂ O °C	pH	DO mg/l	SS mg/l	BOD ₅ mg/l	COD mg/l	NH ₄ ⁺ mg/l	Total P mg/l	Total coliform MPN/100ml	Remarks
1	Hospital's wastewater sample before treatment, taken at tank	28.6	6.8	2.1	56	124	186	3.8	7.8	7.6, 10 ⁵	*
2	Hospital's wastewater sample after treatment, taken at culvert outlet	28.5	7.2	3.8	25	22	54	1.4	7.2	0	*
3	Hospital's wastewater sample after treatment, taken inside culvert pipe	28.5	7.1	3.8	30	28	58	1.4	7.2	150	*
4	Water sample of Huong river taken at Phu Xuan bridge, approx. 7m from the river bank	30.2	7.1	5.7	15	4.6	12.5	0.2	0.14	6.8, 10 ³	**
	* TCVN 5945 - 1995 (column B)		5.5-9	-	100	50	100	1	6	10,000	
	** TCVN 5942 - 1995 (column B)		5.5-9	> or = 2	80	< 25	< 35	1	-	10,000	

Analysis maker

Director

KẾT QUẢ PHÂN TÍCH MẪU NƯỚC THẢI VÀ SÔNG HƯƠNG

Tòa Bệnh viện Trung ương Huế

Ngày: 22/6/1999

Điều kiện thời tiết: Trời nắng, $t^{\circ}k = 35, ^{\circ}C$, $v = 0,22$ m/s, $w = 74\%$

Thiết bị đo: + Máy quang phổ kế DR 2000, USA

+ Máy đo DO, USA

+ Máy đo pH, Germany

+ Cân phân tích, China

+ Máy đo BOD, Đức

資-57

TT	Địa điểm lấy mẫu	$t^{\circ}H_2O$ $^{\circ}C$	pH	DO mg/l	SS mg/l	BOD ₅ mg/l	COD mg/l	NH ₄ ⁺ mg/l	Tổng P mg/l	Total coliform MPN/100ml	Ghi chú
1	Mẫu nước thải bệnh viện trước xử lý, lấy ngay bể chứa	28,6	6,8	2,1	56	124	186	3,8	7,8	$7,6 \cdot 10^5$	*
2	Mẫu nước thải bệnh viện sau khi xử lý, lấy ngay miệng cống thải	28,5	7,2	3,8	25	22	54	1,4	7,2	0	*
3	Mẫu nước thải bệnh viện sau khi xử lý, lấy ngay trên đường cống dẫn thải	28,5	7,1	3,8	30	28	58	1,4	7,2	150	*
4	Mẫu nước sông Hương, lấy ngay khu vực cầu Phú Xuân, cách bờ khoảng 7m	30,2	7,1	5,7	15	4,6	12,5	0,2	0,14	$6,8 \cdot 10^3$	**
	* TCVN 5945 - 1995 (cột B)		5,5-9		100	50	100	1	6	10.000	
	** TCVN 5942 - 1995 (cột B)		5,5-9	≥ 2	80	<25	<35	1	-	10.000	

Giám đốc

Cán bộ phân tích

**CIVIL ENGINEERING AND FOUNDATION TECHNIQUE
JOINT VENTURE (COFEC)**

**REPORT ON
GEOLOGICAL SURVEY**

Location: Hue Central Hospital
Hue City

Surveyor: Engineer Luong Van Sau
Inspector: Engineer Phan Manh Hung
Approved by: Le Duc Phuc
Deputy Director of COFEC

Hanoi, July 1999

A – Explanation

Page

1. **Outlines**
2. **Survey methods**
 - 2.1. Boring and samples taking
 - 2.2. Standard penetration test (SPT)
 - 2.3. Static penetration test (SPT)
 - 2.4. Laboratory test
 - 2.5. Underground water
3. **Survey results**
 - 3.1. Layer
 - 3.2. Geological character
 - 3.3. Underground water results
4. **Conclusions and proposals**

B – Annexes

- Annex 1: Location map of survey points
- Annex 2: Cross section map of geological layer
- Annex 3: Bore log
- Annex 4: Testing results at laboratory and at site

EXPLANATION

GEOLOGICAL SURVEY

PROPOSED CONSTRUCTION SITE

HUE CENTRAL HOSPITAL

1. OUTLINES

The geological survey at Hue Central Hospital has been conducted based on the technical functions and Economic Contract No. 12/99/HDKT signed on 14 April 1999 between Hue Central Hospital and Civil Engineering & Foundation Technique Joint Venture (COFEC).

Having performed the Economic Contract No. 12/99/HDKT, COFEC already mobilised a driller GX-1T and SPT machine GOUDA to the site from 20/6/1999 to 11/7/1999 under instruction of Engineer Phan Manh Hung.

Laboratory tests are carried out by Engineer Khuat Thi Van.

Revision and making up of reports are made by Engineer Luong Van Sau under inspection of Engineer Phan Manh Hung.

All the survey, testing and report-making works are in accordance with the relevant regulations of Vietnam with reference of foreign technique ASTM.

The quantity for surveying work has been implemented in Table 1:

Table 1

No.	Items of works	Unit	Quantity
1	Boring – 14 holes	m	310
2	Testing at site		
	- Standard penetration test	times	146
	- Static penetration test – 5 holes	m	81
3	Testing at laboratory	samples	62

2. SURVEY METHODS

2.1. Boring and samples taking

Use pipe drilling method with single sample taken, diameter $\phi 110$, pump with bentonite in combination with driving pipe $\phi 130$, which are used on the top soil layer to prevent collapse of boring hole.

Undisturbed sample is put in sample tube.

Disturbed sample is put in tube for standard penetration test.

2.2. Standard Penetration Test

This test is conducted in all the boring holes. The instrument set for this standard penetration test has the following basic specification:

Sample tube:

- Inner diameter: $\phi 35$ mm
- Outer diameter: $\phi 50.8$ mm
- Length: 800 mm

(Sorry, the next page is lacking, so we cannot translate item "2.3. Static Penetration Test". We will contact Hue Hospital later for getting this page)

2.4. Laboratory test

According to technical functions, the undisturbed samples which are tested, have the following criteria:

- Soil grade
- Moisture
- Density
- Gravity
- ATTERBERG limit
- Accelerated compression test
- Shearing test

2.5. Underground water survey

The underground water survey is conducted during boring process with specifying stable water depth in the boring hole 24 hours after finishing boring hole.

3. SURVEY RESULTS

3.1. Layer

According to boring results of 14 boring holes within 32m scale in combination with other survey methods such as standard penetration test, static penetration test (5 holes) and laboratory test, we can divide structure of natural ground into 6 layers.

Layer 1: Filling

This is the top layer, located on the whole surveying area. The thickness changes from 1.2m to 2.8m, average 1.55m. This layer is a mixture of clay, sand, broken tile and brick.

Layer 2: Mixed clay

This is a strongly changeable layer, located uncontinuously on the surveying area. At cross section of geological layer III – III, there has not been found layer 2. At cross sections of geological layers IV – IV, VI – VI, layer 2 strongly changes, becomes weaker at boring hole K9, K11 to boring hole K7 and disappears at boring holes K5, K13. The depth of inner layers at some boring holes changes from 1.3m to 1.8m, the thickness changes from 1.5m to 2.7m, average 2.2m. The major component of layer is mixed clay of grey – yellow color, grey – green color, soft and plastic status.

Layer 3: Mixed clay

Layer 3 is located on the whole surveying area. The depth changes from 1.3m to 4.2m, the thickness changes from 3.0m to 11.2m, average 4.9m. The main component of this layer is mixed clay of grey – brown color, when it gets deeper, it changes to grey –black color, soft and plastic status. This is the weak soil layer, the thickness strongly changes.

Layer 4: Mixed clay with tiny grit

This layer is also located on the whole surveying area. The depth changes from 7.5m to 16.0m. The boring holes finish at depth 12.0m but have not found bottom layer. The major component of this layer is mixed clay with tiny grit of grey – yellow color, brown – red color, soft and plastic status. Tiny grit has main component of quartz of grey – white color and grey – green color, $\phi = 2 - 10\text{mm}$, unevenly located but concentrates mainly in groups. This is a layer with average bearing capacity.

Layer 5: Mixed clay with gravel

All the boring holes when reaching the depth 20m, have found layer 5. The depth changes from 13.0m to 16.0m, the boring holes finish at depth 20m but have not found bottom layer. The main component of this layer is mixed clay of red – brown color, grey – white color, consisting of gravel in hard and plastic status to semi-hard. The

deeper it gets, the volume of gravel reduces, at some place, gravel have size of $\phi = 2\text{cm} - 3\text{cm}$. This is a soil layer located at average depth, with considerable bearing capacity.

Layer 6: Clay

Layer 6 has been found at boring holes at depth 30m. The depth changes from 24.0m to 26.0m, the boring holes finish at depth 30 – 32m but have not found bottom layer. The main component of this clay is clay of brown – violet color mixed with grey – yellow color, semi-hard to hard status. This is a soil layer deeply located but has the best bearing capacity on the surveying area.

The above-divided layers have been met at survey points at the depths as mentioned in the following tables:

A. At location proposed to build 3-storey building

Table 2-1

Boring holes		K1, X1	K2	K3	K4, X2
Layer 1	From (m)	0.0	0.0	0.0	0.0
	To (m)	1.6	1.4	1.5	1.4
Layer 2	From (m)	1.6	1.4	1.5	1.4
	To (m)	4.2	3.8	3.0	3.0
Layer 3	From (m)	4.2	3.8	3.0	3.0
	To (m)	8.2	6.8	6.4	6.0
Layer 4	From (m)	8.2	6.8	6.4	6.0
	To (m)	14.0	14.0	16.0	15.0
Layer 5	From (m)	14.0	14.0	16.0	15.0
	To (m)	-	-	-	-

Location of the layers at this area is clear in cross sections I-I and II – II.

B. At location proposed to build 6-storey building

Table 2-2

Boring holes		K5, X3	K6	K7	K8	K9, X4	K10, X5
Layer 1	From (m)	0.0	0.0	0.0	0.0	0.0	0.0
	To (m)	2.8	1.8	1.5	1.2	1.8	1.8
Layer 2	From (m)	2.8	1.8	1.5	1.2	1.8	1.8
	To (m)	-	-	3.2	-	4.2	-
Layer 3	From (m)	2.8	1.8	3.2	1.2	4.2	1.8
	To (m)	6.4	6.4	6.3	6.5	13	13
Layer 4	From (m)	6.4	6.4	6.3	6.5	13	13
	To (m)	13	14	15.3	14.0	15.5	15.5
Layer 5	From (m)	13	14	15.3	14.0	15.5	15.5
	To (m)	24	25.5	25.0	24.0	26.0	26.0
Layer 6	From (m)	24	25.5	25.0	24.0	26.0	26.0
	To (m)	-	-	-	-	-	-

Location of the layers at this area is clear in cross sections III - III and IV - IV.

C. At location proposed to build 2-storey building

Table 2-3

Boring holes		K11	K12	K13	K14
Layer 1	From (m)	0.0	0.0	0.0	0.0
	To (m)	1.4	1.3	1.3	1.3
Layer 2	From (m)	1.4	1.3	1.3	1.3
	To (m)	4.0	4.0	-	3.8
Layer 3	From (m)	4.0	4.0	1.3	3.8
	To (m)	7.4	9.0	7.5	8.0
Layer 4	From (m)	7.4	9.0	7.5	8.0
	To (m)	-	-	-	-

Location of the layers at this area is clear in cross sections V - V and VI - VI.

3.2. Geological character

3.2.1. Physical and mechanical character

The physical and mechanical character of layers are specified by testing at laboratory and at site. Details of results are mentioned in Annex 4. Summary of testing results is mentioned in Annex 3 as below:

Table 3

Criteria	Mark	Unit	Average value of layers				
			2	3	4	5	6
Particle graduation	P	%					
>2			4.1	1.1	14.2	2.5	
2.0-0.5			3.3	3.3	12.7	6.0	0.4
0.5-0.25			3.8	5.2	10.5	21.5	0.8
0.1-0.025			37.9	20.3	16.2	14.5	5.8
0.1-0.05			23.5	20.8	13.6	20.5	11.9
0.05-0.005			19.4	40.6	18.7	15.0	40.8
<0.005			7.9	8.7	14.2	20.0	40.5
Natural moisture	W	%	32	41.9	22.3	16.4	30.1
Liquid limit	W _c	%	36.3	43.8	27.2	30.4	55.9
Plastic limit	W _d	%	26.5	32.6	16.4	16.0	30.2
Plasticity index	I _s		9.84	11.2	10.8	14.4	25.8
Consistency	B		0.55	0.83	0.54	0.03	0.0
Natural weight	γ	g/cm ³	1.84	1.73	2.0	1.97	1.93
Dry weight	γ_c	g/cm ³	1.40	1.22	1.65	1.69	1.48
Gravity	Δ	g/cm ³	2.69	2.68	2.70	2.75	2.71
Void coefficient	e _o		0.928	1.20	0.655	0.625	0.830
Void	n	%	48.1	54.3	39.1	38.5	45.3
Saturation	G	%	92.6	93.8	91.9	72.2	98.0
Inner friction	ϕ	degree	16°02'	7°49'	17°39'	22°29'	20°01'
Cohesion	c	kg/cm ²	0.125	0.089	0.181	0.187	0.368
Compression coefficient	a ₁₋₂	cm ² /kg	0.044	0.046	0.027	0.024	0.021
Standard resistance	N	hammer	4.7	3.2	14	33.4	39
Cone head resistance	q _c	kg/cm ²	11.33	6.9	48.8	171.7	
Friction	f _s	kg/cm ²	0.311	0.17	2.54	4.0	
Deformed module	E _o	kg/cm ²	71	30	171	189	207
Nominal bearing capacity	R _o	kg/cm ²	1.1	0.62	1.5	1.9	2.8

Note:

1. The soil layers with mark layer 4 and layer 5 are mixed clay with tiny grit, gravel, soft and plastic status (layer 4), plastic and hard up to semi-hard (layer 5). As there is a sample choice, the testing results at laboratory show that tiny grit and gravel volume in these layers are <15%. According to site description documents, the tiny grit and gravel volume in layers 4 and 5 are >25%, unevenly located but concentrate in groups. Therefore, the values q_c and f_s in layers 4 and 5 are rather high.
2. Total deformed module of clay E_o is calculated in the following formula:

$$E_o = \frac{\beta * m_k * (1 + e_o)}{a}$$

of which:

m_k : conversion coefficient from testing result at laboratory based on regulation 20TCVN-74-87
 β : deforming coefficient subject to soil type, mixed clay $\beta=0.62$, clay $\beta=0.4$

3. Nominal bearing capacity R_o of ground is calculated in the following formula:

$$R_o = m(A_b + B_h) \gamma_w + DC$$

of which

m : operative coefficient of ground (=1)
 $b = h = 1$ (width and depth of foundation)
 A, B, D : coefficients subject to inner friction of ground
 C : cohesion

3.3. Survey results of underground water:

Underground water is surveyed in boring holes 24 hours after finishing drilling hole in Table 4:

Table 4

Boring hole	K1	K2	K3	K4	K5	K6	K7
Depth (m)	1.2	1.4	1.2	1.2	0.6	1.2	1.1
Boring hole	K8	K9	K10	K11	K12	K13	K14
Depth (m)	1.3	1.6	1.5	1.1	1.05	1.2	1.1

The above results show that water in boring hole is upper layer water, mainly exists in filling layer which closely relates to surface water.

4. CONCLUSION AND PROPOSALS

4.1. Conclusion

In consideration of testing results of 14 boring holes and 5 static penetration testing holes at location proposed to build Hue Central Hospital, we can evaluate geological conditions of foundation up to depth 32m as follows:

From surface to depth 32m, it is divided into 6 layers:

- Layer I: Filling layer. This layer has thin thickness, mixed component, no meaning when building the Works.

- Layer 2: Mixed clay in soft and plastic status. This layer has thin thickness, unevenly located on the surveying area.
- Layer 3: Mixed clay in plastic and liquid status. This is a weak layer with considerable thickness and strongly changeable.
- Layer 4: Mixed layer with tiny grit in soft and plastic status. This is a soil layer with average bearing capacity, layer surface is strongly changeable.
- Layer 5: Mixed clay with gravel in soft – hard to semi-hard status. This is a soil layer with considerable bearing capacity, located at average depth.
- Layer 6: Clay in semi-hard to hard status. This is a soil layer with the best bearing capacity on the surveying area, deeply located.
- Underground water is not deep, thus when opening foundation of the Works, the underground water works may affect construction conditions.

4.2. Proposals

From the evaluation results on geological conditions within the proposed location for building Hue Central Hospital, we have some proposals for the items of the works as follows:

For the items of the works in 2-storey and 3-storey buildings:

These are the items with small bearing capacity, therefore we can use the shallow foundation option to be located on layers 2, 3 after foundation reinforcement.

In case of 3-storey building, if costs are affordable, it's better to use the shallow pile foundation to be located on layer 4.

For the items of the works in 6-storey building:

In case of this item, we should use pile driving option, pile on layer 5.

Hanoi, 31 July 1999

BORE HOLE LOG K1

PROJECT: HUE CENTRAL HOSPITAL

Station: Hue City	Depth(m): 20.0
	Elevation(m): 3.5
Date Commenced: 26/6/1999	Coordinates(m): X
Date Completed: 26/6/1999	Y
Logged by: Tran Van Hung	Boring type: GX-IT
Checked by: Phan Manh Hung	Underground water level(m): 1.2

Layer	Elevation	Depth	Thickness(m)	Log	SOIL AND ROCK DESCRIPTION	Scale(m)	Sample	Depth (m)				Standard Penetration Test (SPT)				SPT Chart N (Blows/30cm)			
								from	to	15	15	15	30	15	15		15	30	
1	1.9	1.6	1.6		Backfill soil: Yellowish brown grey sand, mixed with rubble	0													
2	-0.7	4.2	2.6		Yellowish grey, greenish grey clay, plastic state.	2													
							U1	3.2	3.5										
							D1	3.5	3.95	2	2	3	5						
3	-4.7	8.2	4		Brownish grey clay, changing to blackish grey according to the depth, plastic to liquid state.	5													
							U2	5.8	6.0										
							D2	6.0	6.45	2	2	2	4						
4	-10.5	14	5.8		Sandy clay with yellowish grey gravel, red brown, plastic state. The main content of gravel is quartz, D = 2-10mm, reach 30-40%, irregular disposition.	8	D3	8.0	8.45	1	2	3	5						
							U3	9.8	10										
							D4	10	10.5	7	10	11	21						
							D5	12	12.45	5	7	8	15						
5	-16.5	20.0			Sandy clay with reddish brown gravel, white grey, hard state. The content of gravel is > 25%, irregular disposition, the content of gravel decrease according to the depth, with gravel size is 2-3cm somewhere.	14	D6	14	14.45	15	17	16	33						
							D7	16	16.45	5	7	8	15						
							D8	18	18.5	6	7	8	15						
							D9	20	20.05	50			>50						
					Finished at depth of 20m	20													

Note: U: Undisturbed sample - D: Disturbed sample - C: Rock sample
N: Standard Penetration Value (Blows/30cm)