

APPENDIX – C

*NAM LAN
MINI HYDRO*

Table C-1-1 Estimated Unit Consumption Demand (1/2)

Object	Accessibility ratio, %	Step		Watt	Simultaneous use, %	Watt		Watt	Simultaneous use, %	Watt
1. Household		1-1	a. 3 Lights	90	100		a. 3 Lights	90	15	
Shan South	87		b. Radio	10	30		b. Radio	10	15	
Shan North	84		c. TV (60w)	30	85		c. TV (60w)	30	15	
Kachin	93		Ownership ratio				Ownership ratio			
Total (Un-Electrified)	87		50%				50%			
Total (Electrified)	92		Total	130	90%	118	Total	130	15%	20
Total	88	1-2	1-1	130	90		1-1	130	15	
			d. Rice Cooker	90	50		d. Rice Cooker	90	30	
			Ownership ratio				Ownership ratio			
			15%				15%			
			Total	220	70%	163	Total	220	20%	44
2. Public										
2.1 Street Light	100		1. 40w Tube 10/Place	50	100	2,000				0
2.2 Temple	100		1. Light 20wTubex30	600	67		1. Light 20wTubex30	600	0	
			2. TV 1x60w	60	50		2. TV 1x60w	60	0	
			3. Fan 4 x 60w	240	20		3. Fan 4 x 60w	240	50	
			4. Refrigerator(100w)	100	50		4. Refrigerator(100w)	100	100	
			5. A/C:1x1KW	1,000	0		5. A/C:1x1KW	1,000	50	
			Total	2,000	30%	528	Total	2,000	40%	720
2.3 Hospital	100		1. Outer light 20w Tube x 1	20	100		1.Outer light 20w Tube x 1	20	0	
			2. Inner light 40w Tube x 5rooms	200	50		2. Inner light Night demand x 50%	200	25	
			3. Refrigerator 130w x 1	130	100		3. Refrigerator 130w x 1	130	100	
			Total	350	70%	250	Total	350	50%	180
2.4 Clinic	100		1. Outer light 20w Tube x 1	20	100		1.Outer light	20	0	
			2. Inner light 40w Tube x 4rooms	160	50		2. Inner light Night demand x 50%	160	25	
			3. Refrigerator 130w x 1	130	100		3. Refrigerator 130w x 1	130	100	
			Total	310	70%	230	Total	310	50%	170
2.5 High School	100		1. Outer light 20w Tube x 1	20			1.Outer light	20	0	
			2. Inner light Class room (36) 40w Tube x 4 x 36	5,760			2. Inner light For cloudy, rainy day use: 5,760x20% use (50days/250days/year)	5,760	20	
			3. Head Master room 40w Tube x 1	40			3. Head Master room	40	20	
			4.Copy machine 300w x 10%	300			4. Copy machine 300w x 10%	300	10	
			5. Computer room 40w x 2	80			5. Computer room 40w x 2	80	100	
			Total	6,200	0%	0	Total	6,200	20%	1,270
2.6 Middle School	100		1. Outer light 20w Tube x 1	20			1.Outer light	20	0	
			2. Inner light Class room (8) 40w Tube x 4 x 8	1,280			2. Inner light For cloudy, rainy day 1.280x20% (50days/250days/year)	1,280	20	
			3 Head Master room 40w Tube x 1	40			3. Head Master room	40	20	
			4 Copy machine 300w x 10%	300			4. Copy machine 300w x 10%	300	10	
			Total	1,640	0%	0	Total	1,640	20%	290

Source: The Study Team

Table C-1-2 Estimated Unit Consumption Demand (2/2)

Object	Accessibility ratio, %	Step	Watt	Simultaneous use, %	Watt	Watt	Simultaneous use, %	Watt	
2.7 Primary School	100	1. Outer light 20w Tube x 1	20			1.Outer light	20	0	
		2. Inner light Class room (8) 40w Tube x 8	320			2. Inner light For cloudy, rainy day use: (50days/250days/year)	320	20	
		3 Head master room 40w Tube x 1	40			3. Head Master room	40	0	
		Total	380	0%	0	Total	380	20%	65
		3. Business							
3.1 Restaurant		1. Inner light 40w Tube x 4	160	100		1. Inner light	160	0	
		2. 21" CTV (95w)	95	100		2. 21" CTV (95w)	95	100	
		3. Refrigerator 130w x 1	130	100		3. Refrigerator 130w x 1	130	100	
		4. Rice Cooker 600w x 2	1,200	30		4. Rice Cooker 600w x 2	1,200	30	
		5. Hot plate 800w x 2	1,600	20		5. Hot plate 800w x 2	1,600	20	
		Total	3,185	30%	1,070	Total	3,185	30%	905
3.2 Guest House	100	1 Tube 20w x 22 room	4,400	50		1 Tube 20w x 22 room	4,400	20	
		2. 20w x 2 Toilet	40	20		2. 20w x 2 Toilet	40	20	
		3. Refrigerator 130 w x 1	130	100		3. Refrigerator 130 w x 1	130	100	
		4 Fan 60w x 4	240	50		4 Fan 60w x 4	240	50	
		5 21"TV 95w x 1	95	100		5 21"TV 95w x 1	95	100	
		Total	4,905	50%	2,550	Total	4,905	30%	1,230
3.3 Hotel	100	All facilities for 22 rooms/Hotel	7,000	80%	5,600	All facilities for 22 rooms/Hotel	7,000	70%	4,900
4. Cottage or Household Industry									
4.1 Rice Mill			5,000	0%	0	1. Motor	5,000	80%	5,000
4.2 Oil Mill			7,000	0%	0	1. Motor	7,000	80%	7,000
4.3 Powder Mill			5,000	0%	0	1. Motor	5,000	80%	5,000
4.4 Sugarcane Processing			5,000	0%	0	1. Motor	5,000	80%	5,000
4.5 Saw Mill			5,000	0%	0	1. Motor	5,000	80%	5,000
4.6 Paper Mill			5,000	0%	0	1. Motor	5,000	80%	5,000
4.7 Tofu Manufacturing			4,000	0%	0	1. Motor	4,000	80%	4,000
4.8 Noodle Mill			7,000	0%	0	1. Motor	7,000	80%	7,000
4.9 Furniture Manufacturing			5,000	0%	0	1. Motor	5,000	80%	5,000
4.10 Iron Work (including car, Trawlergyi, boat etc.repair shop)			4,000	0%	0	1. Motor	4,000	80%	4,000
4.11 Battery Charge Station (BCS)			1,500	0%	0	1. Motor	1,500	80%	1,500
4.12 Weaving			5,000	0%	0	1. Motor	5,000	80%	5,000
4.13 Water Pump			200	0%	0	1. Motor	200	80%	200

Note: It is assumed 15% of household will have 600 W Rice Cooker certain years after electrification.

For Namlan Village, 2 Saw Mills have total 4 machines at 20kW

Source: The Study Team

Table C-1-3 Power Demand Forecast in Nam Lan Village

Customer	Number of Customer	Step	Night						Daytime						
			Unit Consumption	Simultaneous %	Unit Consumption	Accessibility %	Estimated Power Demand	Sub-total	Unit Consumption	Simultaneous %	Unit Consumption	Accessibility %	Estimated Power Demand	Sub-total	
			Watt		Watt		kW	kW	Watt		Watt		kW	kW	
1. Household	2,082	1-1 1-2	130 220	90% 70%	120 160	93 93	232.4 309.8	232.4 309.8	130 220	15% 20%	20 50	93 93	38.7 96.8	38.7 96.8	
2. Public															
2.1 Street Light	16		400	50%	200	100	3.2		400	0	0	100	0.0		
2.2 Temple & Pagoda	11		2,000	30%	600	100	6.6		2,000	40%	800	100	8.8		
2.3 Hospital	1		230	70%	160	100	0.2		230	50%	120	100	0.1		
2.4 Clinic	1		310	70%	220	100	0.2		310	50%	160	100	0.2		
2.5.1 H.School	1		6,200	0	0	100	0.0		6,200	20%	1,240	100	1.2		
2.5.2 M.School	0		1,640	0	0	100	0.0		1,640	20%	330	100	0.0		
2.5.3 P.School	9		380	0	0	100	0.0		380	20%	80	100	0.7		
Sub-total								10.2						11.0	
3. Business															
3.1 Restaurant	3		3,185	30%	960	100	2.9		3,185	30%	960	100	2.9		
3.2 Guest House	2		4,905	50%	2,450	100	4.9		4,905	30%	1,470	100	2.9		
Sub-total								7.8						5.8	
4. Industry															
4.1 Rice Mill	18		5,000	0	0	100	0.0		5,000	80%	4,000	100	72.0		
4.2 Oil Mill	6		5,000	0	0	100	0.0		5,000	80%	4,000	100	24.0		
4.3 Powder Mill	0		5,000	0	0	100	0.0		5,000	80%	4,000	100	0.0		
4.4 Sugarcane Processing	0		5,000	0	0	100	0.0		5,000	80%	4,000	100	0.0		
4.5 Saw Mill	2		10,000	0	0	100	0.0		10,000	80%	8,000	100	16.0		
4.6 Paper Mill	0		5,000	0	0	100	0.0		5,000	80%	4,000	100	0.0		
4.7 Tofu Mfg	3		4,000	0	0	100	0.0		4,000	80%	3,200	100	9.6		
4.8 Noodle Mfg	3		7,000	0	0	100	0.0		7,000	80%	5,600	100	16.8		
4.9 Furniture	5		5,000	0	0	100	0.0		5,000	80%	4,000	100	20.0		
4.10 Iron Work	5		4,000	0	0	100	0.0		4,000	80%	3,200	100	16.0		
4.11 BCS	2		1,500	0	0	100	0.0		1,500	80%	1,200	100	2.4		
4.12 Weaving	0		5,000	0	0	100	0.0		5,000	80%	4,000	100	0.0		
4.13 Water Pump	25		200	0	0	100	0.0		200	80%	160	100	4.0		
Sub-total								0.0						180.8	
5. Total															
5.1 1-1+2,3,4								250.3						236.4	
5.2 1-2+2,3,4								327.8						294.5	
6. Gross Total															
6.1 1-1+2,3,4		Including 5% of transfer loss						270	Incl. 5% transfer loss						250
6.2 1-2+2,3,4		Including 5% of transfer loss						350	Incl. 5% transfer loss						310

Probable Flood

According to the absence of any flood data, maximum daily rainfall data at Hsipaw station were used as the main parameter in calculating the probable flood. Rational formula is used for the calculation.

Probable Rainfall

It was calculated rainfall data at Hsipaw station (1990 to 2001) as follows :

176 mm (Return Period : 100 year)

Probable Flood

The following parameters of the basins were used for the calculation of the probable flood.

	Hosant Chaung at Intake	Hosant Chaung at Power House
Catchment Area (km ²)	1.1	2.5
Average length of slopes (m)	317	485
Length of Stream (m)	1,500	3,100
Difference in elevation (m)	91	137

Finally probable floods at the proposed intake site and the proposed power house site were calculated as follows.

	Hosant Chaung at Intake	Hosant Chaung at Power House
Probable flood (m ³ /s)	8.6	19.2

Flow Chart for Operation of Power Generation




Table C-3-1 Calculation of Yearly Power Generation in Nam Lan Micro Hydro (1/3)

(1) Case - 1 : Hosang Chaung only (Phase-1)

Max. Discharge(m3/sec)	0.65	Installed capacity for 2 units (kW)	320
FSWL. at Pond (m)	688.00	Installed capacity for 1unit (kW)	160
TWL (m)	618.50	Loss coefficient for 2-unit	1.6177
Gross Head (m)	69.500	Loss coefficient for 1-unit	3.1570
Effective Head (m)	68.817		

Month	River flow (m ³ /sec)				Irrigation require. (m ³ /sec)	Available discharge (m ³ /sec)	Case - 1 : without regulation				Case - 2 : regulation with unrestricted pond				Case - 3 : regulation by rpond 5,000 m ³			
	Hosang	Nam Pankan	Kyutaw	Total			Q _{power} (m ³ /sec)	Output (kW)	Operation (hr)	Energy (MWh)	Q _{power} (m ³ /sec)	Output (kW)	Operation (hr)	Energy (MWh)	Pond (m ³)	Operation pattern	Output (kW)	Energy (MWh)
1	0.250	0.000	0.000	0.250	0.000	0.250	0.000	0	0.0	0.0	0.650	320	9.2	43.4	13,320	4	320/160	42.8
	0.250	0.000	0.000	0.250	0.000	0.250	0.000	0	0.0	0.0	0.650	320	9.2	43.4	13,320	4	320/160	42.8
2	0.250	0.000	0.000	0.250	0.000	0.250	0.000	0	0.0	0.0	0.650	320	9.2	39.2	13,320	4	320/160	38.6
	0.250	0.000	0.000	0.250	0.000	0.250	0.000	0	0.0	0.0	0.650	320	9.2	39.2	13,320	4	320/160	38.6
3	0.250	0.000	0.000	0.250	0.000	0.250	0.000	0	0.0	0.0	0.650	320	9.2	43.4	13,320	4	320/160	42.8
	0.250	0.000	0.000	0.250	0.000	0.250	0.000	0	0.0	0.0	0.650	320	9.2	43.4	13,320	4	320/160	42.8
4	0.250	0.000	0.000	0.250	0.000	0.250	0.000	0	0.0	0.0	0.650	320	9.2	42.0	13,320	4	320/160	41.4
	0.250	0.000	0.000	0.250	0.000	0.250	0.000	0	0.0	0.0	0.650	320	9.2	42.0	13,320	4	320/160	41.4
5	0.250	0.000	0.000	0.250	0.100	0.150	0.000	0	0.0	0.0	0.650	320	5.5	25.9	9,990	5	320/160	25.7
	0.300	0.000	0.000	0.300	0.100	0.200	0.000	0	0.0	0.0	0.650	320	7.4	34.9	11,952	4	320/160	34.2
6	0.350	0.000	0.000	0.350	0.100	0.250	0.000	0	0.0	0.0	0.650	320	9.2	42.0	13,320	4	320/160	41.4
	0.400	0.000	0.000	0.400	0.100	0.300	0.000	0	0.0	0.0	0.650	320	11.1	50.6	13,932	3	320/160	49.6
7	0.450	0.000	0.000	0.450	0.100	0.350	0.325	160	24.0	56.5	0.650	320	12.9	60.8	13,986	3	320/160	59.9
	0.500	0.000	0.000	0.500	0.100	0.400	0.325	160	24.0	56.5	0.650	320	14.8	69.7	13,248	2	320/160	68.4
8	0.500	0.000	0.000	0.500	0.075	0.425	0.325	160	24.0	56.5	0.650	320	15.7	74.0	12,699	2	320/160	72.7
	0.500	0.000	0.000	0.500	0.050	0.450	0.325	160	24.0	56.5	0.650	320	16.6	78.2	11,988	2	320/160	77.0
9	0.500	0.000	0.000	0.500	0.050	0.450	0.325	160	24.0	54.7	0.650	320	16.6	75.7	11,988	2	320/160	74.5
	0.450	0.000	0.000	0.450	0.050	0.400	0.325	160	24.0	54.7	0.650	320	14.8	67.5	13,248	2	320/160	66.2
10	0.450	0.000	0.000	0.450	0.050	0.400	0.325	160	24.0	56.5	0.650	320	14.8	69.7	13,248	2	320/160	68.4
	0.450	0.000	0.000	0.450	0.050	0.400	0.325	160	24.0	56.5	0.650	320	14.8	69.7	13,248	2	320/160	68.4
11	0.400	0.000	0.000	0.400	0.025	0.375	0.325	160	24.0	54.7	0.650	320	13.8	62.9	13,770	3	320/160	62.1
	0.350	0.000	0.000	0.350	0.000	0.350	0.325	160	24.0	54.7	0.650	320	12.9	58.8	13,986	3	320/160	57.9
12	0.300	0.000	0.000	0.300	0.000	0.300	0.000	0	0.0	0.0	0.650	320	11.1	52.3	13,932	3	320/160	51.3
	0.250	0.000	0.000	0.250	0.000	0.250	0.000	0	0.0	0.0	0.650	320	9.2	43.4	13,320	4	320/160	42.8
Total										558			1,272					1,251

Operation Patterns

- 1 Q > 0.65 2-unit operation (320 kW) for 24 hours
- 2 0.65 > Q > 0.40 Peak load operation with 2-unit (320 kW) in night and/or daytime + Base load operation with 1-unit (160 kW) for 24 hours
- 3 0.40 > Q > 0.30 Peak load operation with 2-unit (320 kW) in nighttime + Base load operation with 1-unit (160 kW) from 5:00 to 24:00
- 4 0.30 > Q > 0.20 Peak load operation with 2-unit (320 kW) for 2 ~ 3 hours in nighttime + 1-unit operation (160 kW) for several hours in daytime
- 5 0.20 > Q > 0.10 Peak load operation with 2-unit (320 kW) for 2 ~ 3 hours in nighttime
- 6 Q < 0.1 1-unit operation (160 kW) for several hours in nighttime




Table C-3-2 Calculation of Yearly Power Generation in Nam Lan Micro Hydro (2/3)

(2) Case - 2 : Hosang Chaung + Nam Pankan Chaung

Max. Discharge(m ³ /sec)	0.65	Installed capacity for 2 units (kW)	320
FSWL. at Pond (m)	688.00	Installed capacity for 1unit (kW)	160
TWL (m)	618.50	Loss coefficient for 2-unit	1.6177
Gross Head (m)	69.500	Loss coefficient for 1-unit	3.1570
Effective Head (m)	68.817		

Month	River flow (m ³ /sec)				Irrigation require. (m ³ /sec)	Available discharge (m ³ /sec)	Case - 1 : without regulation				Case - 2 : regulation with unrestricted pond				Case - 3 : regulation by rpond 5,000 m ³			
	Hosang	Nam Pankan	Kyutaw	Total			Q _{power} (m ³ /sec)	Output (kW)	Operation (hr)	Energy (MWh)	Q _{power} (m ³ /sec)	Output (kW)	Operation (hr)	Energy (MWh)	Pond (m ³)	Operation pattern	Output (kW)	Energy (MWh)
1	0.250	0.200	0.000	0.450	0.000	0.450	0.325	160	24.0	56.5	0.650	320	16.6	78.2	11,988	2	320/160	77.0
	0.250	0.200	0.000	0.450	0.000	0.450	0.325	160	24.0	56.5	0.650	320	16.6	78.2	11,988	2	320/160	77.0
2	0.250	0.200	0.000	0.450	0.000	0.450	0.325	160	24.0	51.1	0.650	320	16.6	70.6	11,988	2	320/160	69.5
	0.250	0.200	0.000	0.450	0.000	0.450	0.325	160	24.0	51.1	0.650	320	16.6	70.6	11,988	2	320/160	69.5
3	0.250	0.200	0.000	0.450	0.000	0.450	0.325	160	24.0	56.5	0.650	320	16.6	78.2	11,988	2	320/160	77.0
	0.250	0.200	0.000	0.450	0.000	0.450	0.325	160	24.0	56.5	0.650	320	16.6	78.2	11,988	2	320/160	77.0
4	0.250	0.200	0.000	0.450	0.000	0.450	0.325	160	24.0	54.7	0.650	320	16.6	75.7	11,988	2	320/160	74.5
	0.250	0.200	0.000	0.450	0.000	0.450	0.325	160	24.0	54.7	0.650	320	16.6	75.7	11,988	2	320/160	74.5
5	0.250	0.250	0.000	0.500	0.200	0.300	0.000	0	0.0	0.0	0.650	320	11.1	52.3	13,932	3	320/160	51.3
	0.300	0.300	0.000	0.600	0.200	0.400	0.325	160	24.0	56.5	0.650	320	14.8	69.7	13,248	2	320/160	68.4
6	0.350	0.350	0.000	0.700	0.200	0.500	0.325	160	24.0	54.7	0.650	320	18.5	84.4	9,900	2	320/160	82.7
	0.400	0.400	0.000	0.800	0.200	0.600	0.325	160	24.0	54.7	0.650	320	22.2	101.2	3,888	2	320/160	99.3
7	0.450	0.450	0.000	0.900	0.200	0.700	0.650	320	24.0	113.1	0.650	320	24.0	113.1	00	1	320	113.1
	0.500	0.500	0.000	1.000	0.200	0.800	0.650	320	24.0	113.1	0.650	320	24.0	113.1	00	1	320	113.1
8	0.500	0.500	0.000	1.000	0.150	0.850	0.650	320	24.0	113.1	0.650	320	24.0	113.1	00	1	320	113.1
	0.500	0.500	0.000	1.000	0.100	0.900	0.650	320	24.0	113.1	0.650	320	24.0	113.1	00	1	320	113.1
9	0.500	0.500	0.000	1.000	0.100	0.900	0.650	320	24.0	109.4	0.650	320	24.0	109.4	00	1	320	109.4
	0.450	0.450	0.000	0.900	0.100	0.800	0.650	320	24.0	109.4	0.650	320	24.0	109.4	00	1	320	109.4
10	0.450	0.450	0.000	0.900	0.100	0.800	0.650	320	24.0	113.1	0.650	320	24.0	113.1	00	1	320	113.1
	0.450	0.450	0.000	0.900	0.100	0.800	0.650	320	24.0	113.1	0.650	320	24.0	113.1	00	1	320	113.1
11	0.400	0.400	0.000	0.800	0.050	0.750	0.650	320	24.0	109.4	0.650	320	24.0	109.4	00	1	320	109.4
	0.350	0.350	0.000	0.700	0.000	0.700	0.650	320	24.0	109.4	0.650	320	24.0	109.4	00	1	320	109.4
12	0.300	0.300	0.000	0.600	0.000	0.600	0.325	160	24.0	56.5	0.650	320	22.2	104.6	3,888	2	320/160	102.6
	0.250	0.250	0.000	0.500	0.000	0.500	0.325	160	24.0	56.5	0.650	320	18.5	87.2	9,900	2	320/160	85.5
Total										1,833				2,221				2,202

Operation Patterns

- 1 Q > 0.65 2-unit operation (320 kW) for 24 hours
- 2 0.65 > Q > 0.40 Peak load operation with 2-unit (320 kW) in night and/or daytime + Base load operation with 1-unit (160 kW) for 24 hours
- 3 0.40 > Q > 0.30 Peak load operation with 2-unit (320 kW) in nighttime + Base load operation with 1-unit (160 kW) from 5:00 to 24:00
- 4 0.30 > Q > 0.20 Peak load operation with 2-unit (320 kW) for 2 ~ 3 hours in nighttime + 1-unit operation (160 kW) for several hours in daytime
- 5 0.20 > Q > 0.10 Peak load operation with 2-unit (320 kW) for 2 ~ 3 hours in nighttime
- 6 Q < 0.1 1-unit operation (160 kW) for several hours in nighttime




Table C-3-3 Calculation of Yearly Power Generation in Nam Lan Micro Hydro (3/3)

(3) Case - 3 : Hosang Chaung + Nam Pankan Chaung + Kyutaw Chaung

Max. Discharge(m3/sec)	0.65	Installed capacity for 2 units (kW)	320
FSWL. at Pond (m)	688.00	Installed capacity for 1unit (kW)	160
TWL (m)	618.50	Loss coefficient for 2-unit	1.6177
Gross Head (m)	69.500	Loss coefficient for 1-unit	3.1570
Effective Head (m)	68.817		

Month	River flow (m ³ /sec)				Irrigation require. (m ³ /sec)	Available discharge (m ³ /sec)	Case - 1 : without regulation				Case - 2 : regulation with unrestricted pond				Case - 3 : regulation by rpond 5,000 m ³			
	Hosang	Nam Pankan	Kyutaw	Total			Q _{power} (m ³ /sec)	Output (kW)	Operation (hr)	Energy (MWh)	Q _{power} (m ³ /sec)	Output (kW)	Operation (hr)	Energy (MWh)	Pond (m ³)	Operation pattern	Output (kW)	Energy (MWh)
1	0.250	0.200	0.200	0.650	0.000	0.650	0.650	320	24.0	113.1	0.650	320	24.0	113.1	00	1	320	113.1
	0.250	0.200	0.200	0.650	0.000	0.650	0.650	320	24.0	113.1	0.650	320	24.0	113.1	00	1	320	113.1
2	0.250	0.200	0.200	0.650	0.000	0.650	0.650	320	24.0	102.1	0.650	320	24.0	102.1	00	1	320	102.1
	0.250	0.200	0.200	0.650	0.000	0.650	0.650	320	24.0	102.1	0.650	320	24.0	102.1	00	1	320	102.1
3	0.250	0.200	0.200	0.650	0.000	0.650	0.650	320	24.0	113.1	0.650	320	24.0	113.1	00	1	320	113.1
	0.250	0.200	0.200	0.650	0.000	0.650	0.650	320	24.0	113.1	0.650	320	24.0	113.1	00	1	320	113.1
4	0.250	0.200	0.200	0.650	0.000	0.650	0.650	320	24.0	109.4	0.650	320	24.0	109.4	00	1	320	109.4
	0.250	0.200	0.200	0.650	0.000	0.650	0.650	320	24.0	109.4	0.650	320	24.0	109.4	00	1	320	109.4
5	0.250	0.250	0.250	0.750	0.300	0.450	0.325	160	24.0	56.5	0.650	320	16.6	78.2	11,988	2	320/160	77.0
	0.300	0.300	0.300	0.900	0.300	0.600	0.325	160	24.0	56.5	0.650	320	22.2	104.6	3,888	2	320/160	102.6
6	0.350	0.350	0.350	1.050	0.300	0.750	0.650	320	24.0	109.4	0.650	320	24.0	109.4	00	1	320	109.4
	0.400	0.400	0.400	1.200	0.300	0.900	0.650	320	24.0	109.4	0.650	320	24.0	109.4	00	1	320	109.4
7	0.450	0.450	0.450	1.350	0.300	1.050	0.650	320	24.0	113.1	0.650	320	24.0	113.1	00	1	320	113.1
	0.500	0.500	0.500	1.500	0.300	1.200	0.650	320	24.0	113.1	0.650	320	24.0	113.1	00	1	320	113.1
8	0.500	0.500	0.500	1.500	0.225	1.275	0.650	320	24.0	113.1	0.650	320	24.0	113.1	00	1	320	113.1
	0.500	0.500	0.500	1.500	0.150	1.350	0.650	320	24.0	113.1	0.650	320	24.0	113.1	00	1	320	113.1
9	0.500	0.500	0.500	1.500	0.150	1.350	0.650	320	24.0	109.4	0.650	320	24.0	109.4	00	1	320	109.4
	0.450	0.450	0.450	1.350	0.150	1.200	0.650	320	24.0	109.4	0.650	320	24.0	109.4	00	1	320	109.4
10	0.450	0.450	0.450	1.350	0.150	1.200	0.650	320	24.0	113.1	0.650	320	24.0	113.1	00	1	320	113.1
	0.450	0.450	0.450	1.350	0.150	1.200	0.650	320	24.0	113.1	0.650	320	24.0	113.1	00	1	320	113.1
11	0.400	0.400	0.400	1.200	0.075	1.125	0.650	320	24.0	109.4	0.650	320	24.0	109.4	00	1	320	109.4
	0.350	0.350	0.350	1.050	0.000	1.050	0.650	320	24.0	109.4	0.650	320	24.0	109.4	00	1	320	109.4
12	0.300	0.300	0.300	0.900	0.000	0.900	0.650	320	24.0	113.1	0.650	320	24.0	113.1	00	1	320	113.1
	0.250	0.250	0.250	0.750	0.000	0.750	0.650	320	24.0	113.1	0.650	320	24.0	113.1	00	1	320	113.1
Total										2,550				2,620				2,616

Operation Patterns

- 1 Q > 0.65 2-unit operation (320 kW) for 24 hours
- 2 0.65 > Q > 0.40 Peak load operation with 2-unit (320 kW) in night and/or daytime + Base load operation with 1-unit (160 kW) for 24 hours
- 3 0.40 > Q > 0.30 Peak load operation with 2-unit (320 kW) in nighttime + Base load operation with 1-unit (160 kW) from 5:00 to 24:00
- 4 0.30 > Q > 0.20 Peak load operation with 2-unit (320 kW) for 2 ~ 3 hours in nighttime + 1-unit operation (160 kW) for several hours in daytime
- 5 0.20 > Q > 0.10 Peak load operation with 2-unit (320 kW) for 2 ~ 3 hours in nighttime
- 6 Q < 0.1 1-unit operation (160 kW) for several hours in nighttime




Table C-3-4 Calculation of Daily Power Generation in Nam Lan Micro Hydro (1/2)















Table C-3-5 Calculation of Daily Power Generation in Nam Lan Micro Hydro (2/2)




Hydraulic Calculations for Nam Lan Mini Hydro Scheme

1. Diversion Weir

(1) Overflow capacity during a flood

Excessive discharge during a flood will be released from the spillway of the diversion weir



The overflow discharge can be calculated by the following formula:

$$Q = 1.84 \cdot (B - 0.2 \cdot H) \cdot H^{1.5}$$

Where, Q : overflow discharge (m³/s)

B : width of weir (= 4.0 m)


H : overflow depth (m)

Design Flood Discharge (100-year probable flood) = 8.6 m³/sec

Flood Water Level $8.6 = 1.84 \times (4.0 - 0.2 \times 1.15) \times 1.15^{1.5}$

$$\text{FWL} = 691.800 + 1.15 = 692.950$$

Overflow Capacity $Q = 1.84 \times (4.0 - 0.2 \times 1.2) \times 1.2^{1.5} = 9.1 \text{ m}^3/\text{sec}$



(2) River Outlet


River Outlet 1.0 m x 1.0 m, Center Elevation EL. 690.500

Discharge capacity at WL. 691.800

$$\text{Discharge } Q = \{2 \times 9.8 \times (691.800 - 690.500) / (1.0 + 0.2)\} \times (1.0 \times 1.0) = 4.6 \text{ m}^3/\text{s}$$

$$\text{Velocity } V = \{2 \times 9.8 \times (691.800 - 690.500) / (1.0 + 0.5)\} = 4.6 \text{ m/s}$$

2. Diversion Channel



(1) Inflow into Diversion Channel

Critical depth occurs at BP. of the slope of the inlet, and the flow in the channel become supercritical, since the slope of the channel is 1/72 that is steeper than critical slope.

The inflow discharge can be calculated by the following formula:

$$Q = 1.84 \cdot (B - 0.2 \cdot H) \cdot H^{1.5}$$

Where, Q : overflow discharge (m³/s)

B : width of inlet (= 1.4 m)

H : overflow depth (m)


WL. < EL. 691.800 : whole river flow enters the diversion channel.

WL. > EL. 691.800 : river flow is divided into the weir and the channel

$$\text{Flow into the channel } Q_{in} = 1.84 \times \{ 1.40 - (WL - 691.300) \} \times (WL - 691.300)^{1.5}$$

$$\text{Flow over the spillway } Q_{spill} = 1.84 \times \{ 4.00 - (WL - 691.800) \} \times (WL - 691.800)^{1.5}$$

WL. 691.72	$Q_{in} = 0.65 \text{ m}^3/\text{s}$	$Q_{spill} = 0.00 \text{ m}^3/\text{s}$	$Q_{river} = 0.65 \text{ m}^3/\text{s}$
WL. 691.80	$Q_{in} = 0.85 \text{ m}^3/\text{s}$	$Q_{spill} = 0.00 \text{ m}^3/\text{s}$	$Q_{river} = 0.85 \text{ m}^3/\text{s}$
WL. 691.84	$Q_{in} = 0.94 \text{ m}^3/\text{s}$	$Q_{spill} = 0.06 \text{ m}^3/\text{s}$	$Q_{river} = 1.00 \text{ m}^3/\text{s}$
WL. 692.12	$Q_{in} = 1.69 \text{ m}^3/\text{s}$	$Q_{spill} = 1.31 \text{ m}^3/\text{s}$	$Q_{river} = 3.00 \text{ m}^3/\text{s}$
WL. 692.32	$Q_{in} = 2.28 \text{ m}^3/\text{s}$	$Q_{spill} = 2.72 \text{ m}^3/\text{s}$	$Q_{river} = 5.00 \text{ m}^3/\text{s}$
WL. 692.64	$Q_{in} = 3.22 \text{ m}^3/\text{s}$	$Q_{spill} = 5.38 \text{ m}^3/\text{s}$	$Q_{river} = 8.60 \text{ m}^3/\text{s}$ (100-year flood)



From the above analysis, the followings are summarized:


- 1) River flow < 0.85 m³/s the whole flow enters the diversion channel
- 2) River flow > 0.85 m³/s the flow is divided into the weir and the channel
- 3) 100-year probable flood FWL = 692.68 Q_{in} = 3.2 m³/s Q_{spill} = 5.4 m³/s

(2) Uniform flow depth

Uniform flow depth in the diversion channel is calculated by the following formula:

$$Q = \frac{b \cdot h}{n} R^{2/3} I^{1/2}$$

Where, Q : discharge (m³/s) n : roughness (= 0.015)
 b : width (= 1.0 m) R : hydraulic radius (m)
 h : depth of flow (m) I : slope (= 1 / 72)



Q (m ³ /s)	Uniform depth (m)	Velocity (m/s)	Note
0.65	0.27	2.44	Max. design discharge
1.00	0.36	2.77	
2.00	0.60	3.31	100-year probable flood
3.20	0.87	3.66	

3. Head Pond

(1) Inflow Monitoring System

The inflow into the pond shall be monitored during the power generation by reading the water level in the pond through the pressure gauge equipped in the powerhouse.

$$\frac{dV}{dt} = \frac{dV}{dH} \cdot \frac{dH}{dt} = S(H) \cdot \frac{dH}{dt} = (Q_{in} - Q_{out})$$

$$\frac{dH}{dt} = \frac{(Q_{in} - Q_{out}) \cdot 3,600}{S(H)} = \frac{(Q_{in} - Q_{out}) \cdot 3,600}{\{25 + (H - 686)\} \cdot \{100 + (H - 686)\}} = \frac{(Q_{in} - Q_{out}) \cdot 3,600}{(H - 661) \cdot (H - 586)}$$


$$Q_{in} = \frac{dH}{dt} \cdot S(H) / 3,600 + Q_{out} = \frac{dH}{dt} \cdot (H - 661) \cdot (H - 586) / 3,600 + Q_{out}$$

where, dH/dt : fluctuation of water level in the pond during (dt) hours

H : water level in the pond (m)

Q_{in} : inflow into the pond (m³/s)

Q_{out} : power discharge (2-unit operation=0.65 m³/s, 1-unit operation=0.325 m³/s)



Procedures:

- 1) Power operation with 2-unit (320 kW, Q_{out}=0.65 m³/s)
- 2) Reading of water level in the pond by pressure gauge
- 3) When fluctuation of water level during 1.0 hour is -0.35m , and average water level is 687.000m under 2-unit operation

$$Q_{in} = -0.35 \times (687.000 - 661.000) \times (687.000 - 586.000) / 3,600 + 0.65 = 0.395 \text{ m}^3/\text{s}$$

(2) Spillway of Head Pond

Spillway Crest EL. 688.000, Width = 2.0 m


$$Q = 1.84 \cdot (B - 0.2 \cdot H) \cdot H^{1.5}$$

Where, Q : overflow discharge (m³/s)

B : width of weir (= 2.0 m)

H : overflow depth (m)

WL. 688.50	Qspill = 1.24 m ³ /s
WL. 688.60	Qspill = 1.61 m ³ /s
WL. 688.70	Qspill = 2.00 m ³ /s
WL. 688.80	Qspill = 2.42 m ³ /s
WL. 688.90	Qspill = 2.86 m ³ /s
WL. 688.90	Qspill = 2.86 m ³ /s
WL. 688.98	Qspill = 3.20 m ³ /s
WL. 689.00	Qspill = 3.31 m ³ /s



(3) Sand Drain of Head Pond

Outflow discharge through the sand drain gate can be calculated by the following formula:

$$Q = A \cdot \sqrt{\frac{2 \cdot g \cdot H}{1 + f_e + f_b + f}}$$

Where, Q : discharge (m³/s)

H : head (= WL - 683.600 m)

f_b : loss coefficient of bend = {0.131 + 0.1632 (0.6/3.0)^{3.5}} (60/90)^{0.5} = 0.11

f : loss coefficient of friction = 12.7 x 9.8 x 0.012² x 11.2 / 0.6^(4/3) = 0.40

EL. of pipe outlet = EL. 683.60 m,

A : area of gate (= 0.6 m x 0.6 m = 0.36 m²)

f_e : loss coefficient of inlet (= 0.2)

Pipe length = 11.2 m,


Pipe dia. = 0.60 m

Bend angle = 60 ° ,

Bend radius = 3.0 m

The relation between the water level in the pond and the outflow discharge under full opening of the sand drain gate is calculated as follows:

WL. 688.000	$Q_{out} = 2.28 \text{ m}^3/\text{s}$
WL. 687.500	$Q_{out} = 2.11 \text{ m}^3/\text{s}$
WL. 687.000	$Q_{out} = 1.93 \text{ m}^3/\text{s}$
WL. 686.500	$Q_{out} = 1.72 \text{ m}^3/\text{s}$
WL. 686.000	$Q_{out} = 1.49 \text{ m}^3/\text{s}$
WL. 685.500	$Q_{out} = 1.22 \text{ m}^3/\text{s}$
WL. 685.000	$Q_{out} = 0.86 \text{ m}^3/\text{s}$
WL. 684.500	$Q_{out} = 0.00 \text{ m}^3/\text{s}$



4. Penstock

For head loss calculations, refer to the following section.

5. Tailrace

Critical depth occurs at BP of tailrace channel, which can be calculated by the following formula.

$$H_c = \sqrt[3]{\frac{1.1 \cdot Q^2}{9.8 \cdot b^2}}$$

Where, Q : discharge (m³/s)

H_c : Critical depth for rectangular section

b : width of channel (=1.5 m)

Critical depth H_c = 0.276 m, Velocity v = 1.569 m/s, Velocity head v²/2g = 0.126 m

Elevation of tailrace channel at BP

$$TWL - H_c - v^2/2g = 618.500 - 0.276 - 0.126 = EL. 618.098 \text{ m} \quad EL. 618.100 \text{ m}$$

Uniform flow depth for trapezoidal channel


Depth = 0.16 m (Q = 0.65 m³/s, n = 0.020, slope = 1 / 27, bottom width = 1.5 m, side slope 1 : 0.5)

Velocity = 2.55 m/s

Formation of the tailrace channel

STA. + 186.5 (BP. of tailrace channel)	FH = 618.100
STA. + 283.5 (BP. + 97.0 m)	FH = 614.500
Total length of tailrace channel	L = 97.0 m
Slope	1 / 26.944
Flood water level of the stream	EL. 615.900 (EL. 614.200 + 1.700 m)
Tail water level	EL. 618.500

HYDRAULIC FEATURES OF WATERWAY



Head Loss Calculation in Nam Lan Mini Hydro Scheme for 2 units Operation

FSWL at Regulating Pond

TWL at Tailrace

Discharge (m³/sec)

Combined Efficiency of Turbine & Generator

Units of Turbine & Generator

688.000
618.500
0.650
0.733
2

PENSTOCK

(1) Screen

$$h_{11} = f_r \cdot \frac{v_1^2}{2g} \quad f_r = 2.34(\sin \theta) \left(\frac{t}{b}\right)^{4/3}$$

B(m)	H(m)	f _r	Velocity (m/s)	Head Loss (m)	Coefficient x 10 ⁻⁶ Q ²
3.00	0.30	0.97	0.722	0.0258	61,098.51

(2) Inlet

$$h_{12} = f_e \cdot \frac{v^2}{2g}$$

fe = 0.5 fe = 0.25 fe = 0.2

D (m)	f _e	Velocity (m/s)	Head Loss (m)	Coefficient x 10 ⁻⁶ Q ²
0.80	0.20	1.293	0.0171	40,386.31

(3) Friction

$$h_{13} = \frac{124.5n^2}{D^{4/3}} L \frac{v^2}{2g}$$

Q(m ³ /s)	n	D (m)	L (m)	Velocity (m/s)	Head Loss (m)	Coefficient x 10 ⁻⁶ Q ²
0.65	0.0120	0.80	178.49	1.293	0.3676	870,063.87
0.33	0.0120	0.40	3.55	2.586	0.0738	174,573.35

(4) Bend

$$h_{14} = \left\{0.131 + 0.1632 \left(\frac{D}{R}\right)^{3.5}\right\} \cdot \left(\frac{\theta}{90}\right)^{0.5} \cdot \frac{v^2}{2g}$$

Q(m ³ /s)	R	D(m)	θ (°)	Velocity (m/s)	Head Loss (m)	Coefficient x 10 ⁻⁶ Q ²
0.65	2.400	0.80	23.77	1.293	0.0059	13,956.83
0.65	2.400	0.80	2.06	1.293	0.0017	4,108.71
0.65	2.400	0.80	9.04	1.293	0.0036	8,607.09
0.65	2.400	0.80	17.24	1.293	0.0050	11,886.14
0.33	1.200	0.40	30.00	2.586	0.0265	62,718.09

(5) Transition

$$h_{15} = f_{gc} \cdot \frac{v_2^2}{2g}$$

D ₁ (m)	D ₂ (m)	L(m)	f _{transition}	Velocity (m/s)	Head Loss (m)	Coefficient x 10 ⁻⁶ Q ²

(6) Branch

$$h_{16} = f_b \cdot \frac{v_0^2}{2g}$$

D ₀ (m)	f _b	Velocity (m/s)	Head Loss (m)	Coefficient x 10 ⁻⁶ Q ²
0.80	0.500	1.293	0.0427	100,965.78

(7) Inlet valve

$$h_{17} = f_v \cdot \frac{v^2}{2g}$$

Q(m ³ /s)	D(m)	f _{valve}	Velocity (m/s)	Head Loss (m)	Coefficient x 10 ⁻⁶ Q ²
0.33	0.40	0.250	2.586	0.0853	201,931.57

(8) Others

Round-up

0.0050	11,833.92
--------	-----------

Sub-total (1) - (8)

0.6600	1,562,130.18
--------	--------------

TAILRACE

Discharge

(1) Friction in transition

$$h_{21} = \frac{2.37 \cdot n^2 Q^2 L}{D_2 - D_1} \cdot \left(\frac{1}{D_1^{13/3}} - \frac{1}{D_2^{13/3}}\right)$$

n	D ₁ (m)	D ₂ (m)	L(m)	Q(m ³ /s)	Velocity (m/s)	Head Loss (m)	Coefficient x 10 ⁻⁶ Q ²
				0.33			

(2) Enlargement

$$h_{21} = f_{ge} \left\{1 - \left(\frac{A_1}{A_2}\right)\right\}^2 \cdot \frac{v_1^2}{2g}$$

D ₁ (m)	D ₂ (m)	f _{ge}	Velocity (m/s)	Head Loss (m)	Coefficient x 10 ⁻⁶ Q ²

(3) Exit

$$h_{23} = f_{exit} \cdot \frac{v^2}{2g}$$

D(m)	f _{exit}	Velocity (m/s)	Head Loss (m)	Coefficient x 10 ⁻⁶ Q ²
0.80	1.000	0.647	0.0213	50,482.89

(4) Others

10%

0.0021	5,048.29
--------	----------

Sub-total

0.0235	55,531.18
--------	-----------

Total of Head Loss

0.6835	1,617,661.36
---------------	---------------------

Gross Head (m)

69.500

Effective Head (m)

68.817

Power Output (kW)

320

Head Loss Calculation in Nam Lan Mini Hydro Scheme for 1 unit Operation

FSWL at Regulating Pond

TWL at Tailrace

Discharge (m³/sec)

Combined Efficiency of Turbine & Generator

Units of Turbine & Generator

688.000
618.500
0.325
0.733
1

PENSTOCK

(1) Screen

$$h_{11} = f_r \cdot \frac{v_1^2}{2g} \quad f_r = 2.34 (\sin \theta) \left(\frac{t}{b}\right)^{1/5}$$

B(m)	H(m)	f _r	Velocity (m/s)	Head Loss (m)	Coefficient x 10 ⁻⁶ Q ²
3.00	0.30	0.97	0.361	0.0065	61,098.51

(2) Inlet

$$h_{12} = f_e \cdot \frac{v_2^2}{2g}$$

$f_e = 0.5$ $f_e = 0.25$ $f_e = 0.2$

D (m)	f _e	Velocity (m/s)	Head Loss (m)	Coefficient x 10 ⁻⁶ Q ²
0.80	0.20	0.647	0.0043	40,386.31

(3) Friction

$$h_{13} = \frac{124.5 n^2}{D^{4/3}} L \frac{v^2}{2g}$$

Q(m ³ /s)	n	D (m)	L (m)	Velocity (m/s)	Head Loss (m)	Coefficient x 10 ⁻⁶ Q ²
0.33	0.0120	0.80	178.49	0.647	0.0919	870,063.87
0.33	0.0120	0.40	3.55	2.586	0.0738	698,293.39

(4) Bend

$$h_{14} = \left\{0.131 + 0.1632 \left(\frac{D}{R}\right)^{3.5}\right\} \cdot \left(\frac{\theta}{90}\right)^{0.5} \cdot \frac{v^2}{2g}$$

Q(m ³ /s)	R	D(m)	θ (°)	Velocity (m/s)	Head Loss (m)	Coefficient x 10 ⁻⁶ Q ²
0.33	2.400	0.80	23.77	0.647	0.0015	13,956.83
0.33	2.400	0.80	2.06	0.647	0.0004	4,108.71
0.33	2.400	0.80	9.04	0.647	0.0009	8,607.09
0.33	2.400	0.80	17.24	0.647	0.0013	11,886.14
0.33	1.200	0.40	30.00	2.586	0.0265	250,872.35

(5) Transition

$$h_{15} = f_{gc} \frac{v_2^2}{2g}$$

D ₁ (m)	D ₂ (m)	L(m)	f _{transition}	Velocity (m/s)	Head Loss (m)	Coefficient x 10 ⁻⁶ Q ²

(6) Branch

$$h_{16} = f_b \cdot \frac{v_0^2}{2g}$$

D ₀ (m)	f _b	Velocity (m/s)	Head Loss (m)	Coefficient x 10 ⁻⁶ Q ²
0.80	0.500	0.647	0.0107	100,965.78

(7) Inlet valve

$$h_{17} = f_v \cdot \frac{v^2}{2g}$$

Q(m ³ /s)	D(m)	f _{valve}	Velocity (m/s)	Head Loss (m)	Coefficient x 10 ⁻⁶ Q ²
0.33	0.40	0.250	2.586	0.0853	807,726.27

(8) Others

Round-up

0.0071	66,945.98
--------	-----------

Sub-total (1) - (8)

0.3100	2,934,911.24
--------	--------------

TAILRACE

Discharge

(1) Friction in transition

$$h_{21} = \frac{2.37 \cdot n^2 Q^2 L}{D_2 - D_1} \cdot \left(\frac{1}{D_1^{1/3}} - \frac{1}{D_2^{1/3}}\right)$$

n	D ₁ (m)	D ₂ (m)	L(m)	Q(m ³ /s)	Velocity (m/s)	Head Loss (m)	Coefficient x 10 ⁻⁶ Q ²
				0.33			

(2) Enlargement

$$h_{21} = f_{ge} \left\{1 - \left(\frac{A_1}{A_2}\right)\right\}^2 \cdot \frac{v_1^2}{2g}$$

D ₁ (m)	D ₂ (m)	f _{ge}	Velocity (m/s)	Head Loss (m)	Coefficient x 10 ⁻⁶ Q ²

(3) Exit

$$h_{23} = f_{exit} \cdot \frac{v^2}{2g}$$

D(m)	f _{exit}	Velocity (m/s)	Head Loss (m)	Coefficient x 10 ⁻⁶ Q ²
0.80	1.000	0.647	0.0213	201,931.57

(4) Others

10%

0.0021	20,193.16
--------	-----------

Sub-total

0.0235	222,124.72
--------	------------

Total of Head Loss

0.3335	3,157,035.97
---------------	---------------------

Gross Head (m)

69.500

Effective Head (m)

69.167

Power Output (kW)

160

Project: Namlan (REV3)

Anchor Block No. 1


Item	unit	Input
Discharge	Q	m ³ /s 0.65
Head	H	m 4.00
Dia. of Pipe (u/s)	ϕ_1	m 0.80
Dia. of Pipe (d/s)	ϕ_2	m 0.80
Thickness of pipe (u/s)	t_1	mm 6.00
Thickness of pipe (d/s)	t_2	mm 6.00
Distance to exp. jt. (u/s)	L_1	m 15.00
Distance to exp. jt. (d/s)	L_2	m 0.00
Distance to saddle (u/s)	l_1	m 6.00
Distance to saddle (d/s)	l_2	m 6.00
Pipe slope (u/s)	α_1	° 4.57
Pipe slope (d/s)	α_2	° 28.34
Center angle of bend	ψ	° 23.77
Width of Anchor	w	m 2.00
Fillet of anchor	b	m 0.30
Seismic coefficient	k_h	- 0.00
Unit weight of concrete	γ_c	t/m ³ 2.30
Cohesion (concrete-foundation)	c	t/m ² 0.00
Friction coeff. (saddle)	f	- 0.50
Safety factor for sliding	F_s	- 1.50
Bearing stress of foundation	σ	t/m ² 100.00
滑動係数	ff	- 0.50

1. Anchor Block		
No.	x(m)	y(m)
1	0.000	0.000
2	2.000	0.000
3	2.500	1.000
4	4.000	1.000
5	4.000	2.157
6	3.848	4.051
7	1.739	3.882
8	0.000	2.994
9	0.000	0.000
10		
11		
12		
13		
14		
15		

2. Fillet		
No.	x(m)	y(m)
1	3.848	4.051
2	1.739	3.882
3	0.000	2.994
4	0.000	2.603
5	1.826	3.588
6	3.872	3.752
7	3.848	4.051
8		
9		
10		
11		
12		
13		
14		
15		

Max	4.000
Min	0.000
L	4.000

Pipe Location		
O ₁	x(m)	y(m)
O ₁	0.000	0.000
O ₂	3.920	3.154
O ₃	2.000	3.000
O ₄	0.000	1.921



Force	Magnitude (ton)	V (ton)	H (ton)	x (m)	y (m)	Mr (t·m)	Mo (t·m)
(1) Penstock Pipe (u/s)	1.857	1.851	-0.148	2.000	3.000	4.146	
(2) Penstock Pipe (d/s)	1.640	1.443	-0.778	2.000	3.000	5.222	
(3) Axial Force of Penstock Pipe (u/s)	3.856	0.307	3.844	2.000	3.000	0.614	11.531
(4) Axial Force of Penstock Pipe (d/s)	0.000	0.000	0.000	2.000	3.000	0.000	0.000
(5) Friction (u/s)	0.016	0.001	0.016	2.000	3.000	0.003	0.048
(6) Friction (d/s)	0.000	0.000	0.000	2.000	3.000	0.000	0.000
(7) Centrifugal Force	0.035	-0.035	0.007	2.000	3.000		0.091
(8) Water Pressure at Bend	0.828	-0.810	0.171	2.000	3.000		2.132
(9) Reducer Bend	0.000	0.000	0.000	2.000	3.000	0.000	0.000
(10) Anchor Block	54.368	54.368	0.000	1.937	0.000	105.290	
(11) Seismic	0.000	0.000	0.000	0.000	1.959		0.000
Total		57.126	3.111			115.276	13.802
							101.473

Stability

unit	unit	Result	Allowable Range	Judge
Safety factor for over turning	m	0.224	< 0.667	OK
Safety factor for sliding		11.017	> 1.200	OK
Bearing stress σ_1 (f=0.5)	t/m ²	9.537	< 100.000	OK
Bearing stress σ_2 (f=0.5)	t/m ²	4.745	< 100.000	OK

Stability Analysis of Anchor Block No.1

Project: Namlan (REV3)

Anchor Block No. 2


Item	unit	Input
Discharge	Q	m ³ /s 0.65
Head	H	m 28.00
Dia. of Pipe (u/s)	ϕ_1	m 0.80
Dia. of Pipe (d/s)	ϕ_2	m 0.80
Thickness of pipe (u/s)	t_1	mm 6.00
Thickness of pipe (d/s)	t_2	mm 6.00
Distance to exp. jt. (u/s)	L_1	m 50.00
Distance to exp. jt. (d/s)	L_2	m 0.00
Distance to saddle (u/s)	l_1	m 6.00
Distance to saddle (d/s)	l_2	m 6.00
Pipe slope (u/s)	α_1	° 28.34
Pipe slope (d/s)	α_2	° 26.28
Center angle of bend	ψ	° 2.06
Width of Anchor	w	m 2.00
Fillet of anchor	b	m 0.03
Seismic coefficient	k_h	- 0.00
Unit weight of concrete	γ_c	t/m ³ 2.30
Cohesion (concrete-foundation)	c	t/m ² 0.00
Friction coeff. (saddle)	f	- 0.50
Safety factor for sliding	F_s	- 1.50
Bearing stress of foundation	σ	t/m ² 100.00
滑動係数	ff	- 0.50

1. Anchor Block		
No.	x(m)	y(m)
1	0.000	0.000
2	1.500	0.000
3	2.000	1.000
4	4.000	1.000
5	4.000	2.942
6	3.098	4.615
7	1.587	3.800
8	0.000	3.016
9	0.000	0.000
10		
11		
12		
13		
14		
15		

2. Fillet		
No.	x(m)	y(m)
1	3.098	4.615
2	1.587	3.800
3	0.000	3.016
4	0.000	2.682
5	1.725	3.533
6	3.240	4.351
7	3.098	4.615
8		
9		
10		
11		
12		
13		
14		
15		

Max	4.000
Min	0.000
L	4.000

Pipe Location		
O ₁	x(m)	y(m)
O ₁	0.000	0.000
O ₂	3.525	3.823
O ₃	2.000	3.000
O ₄	0.000	2.012



Force	Magnitude (ton)	V (ton)	H (ton)	x (m)	y (m)	Mr (t·m)	Mo (t·m)
(1) Penstock Pipe (u/s)	1.640	1.443	-0.778	2.000	3.000	5.222	
(2) Penstock Pipe (d/s)	1.671	1.498	-0.740	2.000	3.000	5.215	
(3) Axial Force of Penstock Pipe (u/s)	15.655	7.431	13.779	2.000	3.000	14.862	41.336
(4) Axial Force of Penstock Pipe (d/s)	0.000	0.000	0.000	2.000	3.000	0.000	0.000
(5) Friction (u/s)	0.054	0.025	0.047	2.000	3.000	0.051	0.142
(6) Friction (d/s)	0.000	0.000	0.000	2.000	3.000	0.000	0.000
(7) Centrifugal Force	0.003	0.003	-0.000	2.000	3.000	0.006	
(8) Water Pressure at Bend	0.506	0.505	-0.009	2.000	3.000	1.038	
(9) Reducer Bend	0.000	0.000	0.000	2.000	3.000	0.000	0.000
(10) Anchor Block	54.795	54.795	0.000	1.951	0.000	106.897	
(11) Seismic	0.000	0.000	0.000	0.000	2.113		0.000
Total		65.701	12.299			133.290	41.477
							91.813

Stability

unit	unit	Result	Allowable Range	Judge
Safety factor for over turning	m	0.603	< 0.667	OK
Safety factor for sliding		3.205	> 1.200	OK
Bearing stress σ_1 (f=0.5)	t/m ²	15.636	< 100.000	OK
Bearing stress σ_2 (f=0.5)	t/m ²	0.790	< 100.000	OK

Stability Analysis of Anchor Block No.2

Project: Namlan (REV3)

Anchor Block No. 3


Item	unit	Input
Discharge	Q	m ³ /s 0.65
Head	H	m 48.00
Dia. of Pipe (u/s)	ϕ_1	m 0.80
Dia. of Pipe (d/s)	ϕ_2	m 0.80
Thickness of pipe (u/s)	t_1	mm 6.00
Thickness of pipe (d/s)	t_2	mm 6.00
Distance to exp. jt. (u/s)	L_1	m 45.00
Distance to exp. jt. (d/s)	L_2	m 0.00
Distance to saddle (u/s)	l_1	m 6.00
Distance to saddle (d/s)	l_2	m 6.00
Pipe slope (u/s)	α_1	° 26.28
Pipe slope (d/s)	α_2	° 17.24
Center angle of bend	ψ	° 9.04
Width of Anchor	w	m 2.00
Fillet of anchor	b	m 0.30
Seismic coefficient	k_h	- 0.00
Unit weight of concrete	γ_c	t/m ³ 2.30
Cohesion (concrete-foundation)	c	t/m ² 0.00
Friction coeff. (saddle)	f	- 0.50
Safety factor for sliding	F_s	- 1.50
Bearing stress of foundation	σ	t/m ² 100.00
滑動係数	ff	- 0.50

1. Anchor Block		
No.	x(m)	y(m)
1	0.000	0.000
2	1.500	0.000
3	2.000	1.000
4	3.500	1.000
5	3.500	2.625
6	2.659	4.329
7	1.665	3.838
8	0.000	3.300
9	0.000	0.000
10		
11		
12		
13		
14		
15		

2. Fillet		
No.	x(m)	y(m)
1	2.659	4.329
2	1.665	3.838
3	0.000	3.300
4	0.000	3.008
5	1.777	3.559
6	2.792	4.060
7		
8		
9		
10		
11		
12		
13		
14		
15		

Max	3.500
Min	0.000
L	3.500

Pipe Location		
O ₁	x(m)	y(m)
O ₁	0.000	0.000
O ₂	3.057	3.523
O ₃	2.000	3.000
O ₄	0.000	2.379



Force	Magnitude (ton)	V (ton)	H (ton)	x (m)	y (m)	Mr (t·m)	Mo (t·m)
(1) Penstock Pipe (u/s)	1.671	1.498	-0.740	2.000	3.000	5.215	
(2) Penstock Pipe (d/s)	1.779	1.699	-0.527	2.000	3.000	4.981	
(3) Axial Force of Penstock Pipe (u/s)	14.052	6.222	12.600	2.000	3.000	12.443	37.799
(4) Axial Force of Penstock Pipe (d/s)	0.000	0.000	0.000	2.000	3.000	0.000	0.000
(5) Friction (u/s)	0.048	0.021	0.043	2.000	3.000	0.043	0.130
(6) Friction (d/s)	0.000	0.000	0.000	2.000	3.000	0.000	0.000
(7) Centrifugal Force	0.014	0.013	-0.001	2.000	3.000	0.030	
(8) Water Pressure at Bend	3.803	3.791	-0.300	2.000	3.000	8.481	
(9) Reducer Bend	0.000	0.000	0.000	2.000	3.000	0.000	0.000
(10) Anchor Block	43.798	43.798	0.000	1.698	0.000	74.391	
(11) Seismic	0.000	0.000	0.000	0.000	2.283		0.000
Total		57.043	11.075			105.584	37.929
							67.655

Stability

unit	unit	Result	Allowable Range	Judge
Safety factor for over turning	m	0.564	< 0.583	OK
Safety factor for sliding		3.090	> 1.200	OK
Bearing stress σ_1 (f=0.5)	t/m ²	16.028	< 100.000	OK
Bearing stress σ_2 (f=0.5)	t/m ²	0.270	< 100.000	OK

Stability Analysis of Anchor Block No.3

Project: Namlan (REV3)

Anchor Block No. 4


Item	unit	Input
Discharge	Q	m ³ /s 0.65
Head	H	m 66.00
Dia. of Pipe (u/s)	ϕ_1	m 0.80
Dia. of Pipe (d/s)	ϕ_2	m 0.80
Thickness of pipe (u/s)	t_1	mm 6.00
Thickness of pipe (d/s)	t_2	mm 6.00
Distance to exp. jt. (u/s)	L_1	m 60.00
Distance to exp. jt. (d/s)	L_2	m 0.00
Distance to saddle (u/s)	l_1	m 6.00
Distance to saddle (d/s)	l_2	m 6.00
Pipe slope (u/s)	α_1	° 17.24
Pipe slope (d/s)	α_2	° 0.00
Center angle of bend	ψ	° 17.24
Width of Anchor	w	m 2.00
Fillet of anchor	b	m 0.30
Seismic coefficient	k_h	- 0.00
Unit weight of concrete	γ_c	t/m ³ 2.30
Cohesion (concrete-foundation)	c	t/m ² 0.00
Friction coeff. (saddle)	f	- 0.50
Safety factor for sliding	F_s	- 1.50
Bearing stress of foundation	σ	t/m ² 100.00
滑動係数	ff	- 0.50

1. Anchor Block		
No.	x(m)	y(m)
1	0.000	0.000
2	1.750	0.000
3	2.000	0.500
4	3.500	0.500
5	3.500	1.418
6	2.937	3.233
7	1.864	2.900
8	0.000	2.900
9	0.000	0.000
10		
11		
12		
13		
14		
15		

2. Fillet		
No.	x(m)	y(m)
1	2.937	3.233
2	1.864	2.900
3	0.000	2.900
4	0.000	2.600
5	1.909	2.600
6	3.026	2.947
7	2.937	3.233
8		
9		
10		
11		
12		
13		
14		
15		

Max	3.500
Min	0.000
L	3.500

Pipe Location		
O ₁	x(m)	y(m)
O ₁	0.000	0.000
O ₂	3.204	2.374
O ₃	2.000	2.000
O ₄	0.000	2.000



Force	Magnitude (ton)	V (ton)	H (ton)	x (m)	y (m)	Mr (t·m)	Mo (t·m)
(1) Penstock Pipe (u/s)	1.779	1.699	-0.527	2.000	2.000	4.454	
(2) Penstock Pipe (d/s)	1.863	1.863	0.000	2.000	2.000	3.726	
(3) Axial Force of Penstock Pipe (u/s)	19.009	5.634	18.155	2.000	2.000	11.268	36.310
(4) Axial Force of Penstock Pipe (d/s)	0.000	0.000	0.000	2.000	2.000	0.000	0.000
(5) Friction (u/s)	0.064	0.019	0.061	2.000	2.000	0.038	0.123
(6) Friction (d/s)	0.000	0.000	0.000	2.000	2.000	0.000	0.000
(7) Centrifugal Force	0.026	0.025	-0.004	2.000	2.000	0.059	
(8) Water Pressure at Bend	9.945	9.833	-1.491	2.000	2.000	22.647	
(9) Reducer Bend	0.000	0.000	0.000	2.000	2.000	0.000	0.000
(10) Anchor Block	37.889	37.889	0.000	1.629	0.000	61.729	
(11) Seismic	0.000	0.000	0.000	0.000	1.473		0.000
Total		56.963	16.195			103.921	36.433
							67.488

Stability

unit	unit	Result	Allowable Range	Judge
Safety factor for over turning	m	0.565	< 0.583	OK
Safety factor for sliding		2.110	> 1.200	OK
Bearing stress σ_1 (f=0.5)	t/m ²	16.023	< 100.000	OK
Bearing stress σ_2 (f=0.5)	t/m ²	0.253	< 100.000	OK

Stability Analysis of Anchor Block No.4

APPENDIX C-5 Structural Analysis (6/22)

Project: Namlan (REV5)

Section A



Item	unit	Input
Discharge	Q	m ³ /s 0.65
Dia. of pipe	φ	m 0.80
Thickness of pipe	t	mm 6.00
Distance between saddles	l	m 6.00
Pipe slope	α	° 4.57
Width of saddle	w	m 1.20
Fillet of saddle	b	m 0.60
Seismic coefficient	k _h	- 0.12
Unit weight of concrete	γ _c	t/m ³ 2.30
Cohesion (concrete-foundation)	c	t/m ² 0.00
Friction coeff. (saddle)	f	- 0.50
Safety factor for sliding	F _s	- 1.50
Bearing stress of foundation	σ	t/m ² 100.00
滑動係数	ff	- 0.50

1. Anchor Block		
No.	x(m)	y(m)
1	0.000	0.000
2	0.622	0.000
3	0.495	1.586
4	0.000	1.546
5	0.000	0.000
6		
7		
8		
9		
10		

2. Fillet		
No.	x(m)	y(m)
1	0.495	1.586
2	0.000	1.546
3	0.000	1.200
4	0.522	1.242
5	0.495	1.586
6		
7		
8		
9		
10		

Max	0.622
Min	0.000
L	0.622

Pipe Location		
O _i	x(m)	y(m)
O ₁	0.000	0.000
O ₂	0.495	1.586
O ₃	0.000	1.546



Force	Magnitude (ton)	V (ton)	H (ton)	x (m)	y (m)	Mr (t·m)	Mo (t·m)
(1) Penstock Pipe	3.714	3.703	-0.296	0.248	1.566	1.380	
(2) Axial Force due to Friction	0.000	0.000	0.000	0.000	0.000	0.000	0.000
(3) Axial Force due to Penstock Pipe	0.057	0.005	0.056	0.248	1.566	0.001	0.088
(4) Friction of Water	0.006	0.001	0.006	0.248	1.566	0.000	0.010
(5) Saddle	1.983	1.983	0.000	0.288	0.000	0.572	
(6) Seismic	0.238	0.000	0.238	0.000	0.565		0.134
Total		5.691	0.005			1.953	0.233
							1.720

Stability

unit	unit	Result	Allowable Range	Judge
Safety factor for over turning	m	0.009	< 0.104	OK
Safety factor for sliding		2.845	> 0.005	OK
Bearing stress σ ₁ (f=0.5)	t/m ²	8.265	< 100.000	OK
Bearing stress σ ₂ (f=0.5)	t/m ²	6.984	< 100.000	OK

Stability Analysis of Saddle Type A (Penstock B.P. ~ Anchor Block No.1)

APPENDIX C-5 Structural Analysis (7/22)

Project: Namlan (REV5)

Section B



Item	unit	Input
Discharge	Q	m ³ /s 0.65
Dia. of pipe	φ	m 0.80
Thickness of pipe	t	mm 6.00
Distance between saddles	l	m 6.00
Pipe slope	α	° 28.34
Width of saddle	w	m 1.20
Fillet of saddle	b	m 0.60
Seismic coefficient	k _h	- 0.12
Unit weight of concrete	γ _c	t/m ³ 2.30
Cohesion (concrete-foundation)	c	t/m ² 0.00
Friction coeff. (saddle)	f	- 0.50
Safety factor for sliding	F _s	- 1.50
Bearing stress of foundation	σ	t/m ² 100.00
滑動係数	ff	- 0.50

1. Anchor Block		
No.	x(m)	y(m)
1	0.000	0.000
2	1.000	0.000
3	1.000	0.699
4	0.421	1.773
5	0.000	1.546
6	0.000	0.000
7		
8		
9		
10		

2. Fillet		
No.	x(m)	y(m)
1	0.421	1.773
2	0.000	1.546
3	0.000	1.200
4	0.565	1.505
5	0.421	1.773
6		
7		
8		
9		
10		

Max	1.000
Min	0.000
L	1.000

Pipe Location		
O ₁	x(m)	y(m)
O ₁	0.000	0.000
O ₂	0.421	1.773
O ₃	0.000	1.546



Force	Magnitude (ton)	V (ton)	H (ton)	x (m)	y (m)	Mr (t·m)	Mo (t·m)
(1) Penstock Pipe	3.280	2.887	-1.557	0.211	1.660	3.191	
(2) Axial Force due to Friction	0.000	0.000	0.000	0.000	0.000	0.000	0.000
(3) Axial Force due to Penstock Pipe	0.337	0.160	0.297	0.211	1.660	0.034	0.492
(4) Friction of Water	0.006	0.003	0.006	0.211	1.660	0.001	0.009
(5) Saddle	3.484	3.484	0.000	0.470	0.000	1.639	
(6) Seismic	0.418	0.000	0.418	0.000	0.623		0.261
Total		6.533	-0.836			4.864	0.762
							4.102

Stability

unit	unit	Result	Allowable Range	Judge
Safety factor for over turning	m	-0.128	< 0.167	OK
Safety factor for sliding		3.267	> 0.836	OK
Bearing stress σ ₁ (f=0.5)	t/m ²	1.271	< 100.000	OK
Bearing stress σ ₂ (f=0.5)	t/m ²	9.619	< 100.000	OK

Stability Analysis of Saddle Type B (Anchor Block No.1 ~ No.2)

Project: Namlan (REV5)

Section C



Item	unit	Input
Discharge	Q	m ³ /s 0.65
Dia. of pipe	φ	m 0.80
Thickness of pipe	t	mm 6.00
Distance between saddles	l	m 6.00
Pipe slope	α	° 26.28
Width of saddle	w	m 1.20
Fillet of saddle	b	m 0.60
Seismic coefficient	k _h	- 0.12
Unit weight of concrete	γ _c	t/m ³ 2.30
Cohesion (concrete-foundation)	c	t/m ² 0.00
Friction coeff. (saddle)	f	- 0.50
Safety factor for sliding	F _s	- 1.50
Bearing stress of foundation	σ	t/m ² 100.00
滑動係数	ff	- 0.50

No.	x(m)	y(m)
1	0.000	0.000
2	1.000	0.000
3	1.000	0.804
4	0.509	1.798
5	0.000	1.546
6	0.000	0.000
7		
8		
9		
10		

No.	x(m)	y(m)
1	0.509	1.798
2	0.000	1.546
3	0.000	1.200
4	0.647	1.519
5	0.509	1.798
6		
7		
8		
9		
10		

Max	1.000
Min	0.000
L	1.000

O ₁	O ₂	O ₃
0.000	0.000	0.000
0.509	1.798	1.798
0.000	1.546	1.546



Force	Magnitude (ton)	V (ton)	H (ton)	x (m)	y (m)	Mr (t·m)	Mo (t·m)
(1) Penstock Pipe	3.341	2.996	-1.479	0.255	1.672	3.236	
(2) Axial Force due to Friction	0.000	0.000	0.000	0.000	0.000	0.000	0.000
(3) Axial Force due to Penstock Pipe	0.314	0.139	0.282	0.255	1.672	0.035	0.471
(4) Friction of Water	0.006	0.003	0.006	0.255	1.672	0.001	0.010
(5) Saddle	3.617	3.617	0.000	0.484	0.000	1.752	
(6) Seismic	0.434	0.000	0.434	0.000	0.637		0.276
Total		6.754	-0.758			5.024	0.758
							4.266

Stability

unit	unit	Result	Allowable Range	Judge
Safety factor for over turning	m	-0.132	< 0.167	OK
Safety factor for sliding		3.377	> 0.758	OK
Bearing stress σ ₁ (f=0.5)	t/m ²	1.183	< 100.000	OK
Bearing stress σ ₂ (f=0.5)	t/m ²	10.074	< 100.000	OK

Stability Analysis of Saddle Type C (Anchor Block No.2 ~ No.3)

Project: Namlan (REV5)

Section D



Item	unit	Input
Discharge	Q	m ³ /s 0.65
Dia. of pipe	φ	m 0.80
Thickness of pipe	t	mm 6.00
Distance between saddles	l	m 6.00
Pipe slope	α	° 17.24
Width of saddle	w	m 1.20
Fillet of saddle	b	m 0.60
Seismic coefficient	k _h	- 0.12
Unit weight of concrete	γ _c	t/m ³ 2.30
Cohesion (concrete-foundation)	c	t/m ² 0.00
Friction coeff. (saddle)	f	- 0.50
Safety factor for sliding	F _s	- 1.50
Bearing stress of foundation	σ	t/m ² 100.00
滑動係数	ff	- 0.50

No.	x(m)	y(m)
1	0.000	0.000
2	0.900	0.000
3	0.900	0.287
4	0.464	1.691
5	0.000	1.500
6	0.000	0.000
7		
8		
9		
10		

No.	x(m)	y(m)
1	0.464	1.691
2	0.000	1.500
3	0.000	1.200
4	0.562	1.375
5	0.464	1.691
6		
7		
8		
9		
10		

Max	0.900
Min	0.000
L	0.900

O ₁	O ₂	O ₃
0.000	0.000	
0.464	1.691	
0.000	1.500	



Force	Magnitude (ton)	V (ton)	H (ton)	x (m)	y (m)	Mr (t·m)	Mo (t·m)
(1) Penstock Pipe	3.559	3.399	-1.055	0.232	1.596	2.471	
(2) Axial Force due to Friction	0.000	0.000	0.000	0.000	0.000	0.000	0.000
(3) Axial Force due to Penstock Pipe	0.211	0.062	0.201	0.232	1.596	0.014	0.321
(4) Friction of Water	0.006	0.002	0.006	0.232	1.596	0.000	0.010
(5) Saddle	2.810	2.810	0.000	0.402	0.000	1.128	
(6) Seismic	0.337	0.000	0.337	0.000	0.575		0.194
Total		6.273	-0.510			3.614	0.524
							3.090

Stability


unit	unit	Result	Allowable Range	Judge
Safety factor for over turning	m	-0.043	< 0.150	OK
Safety factor for sliding		3.136	> 0.510	OK
Bearing stress σ ₁ (f=0.5)	t/m ²	4.158	< 100.000	OK
Bearing stress σ ₂ (f=0.5)	t/m ²	7.459	< 100.000	OK

Stability Analysis of Saddle Type D (Anchor Block No.3 ~ No.4)

Project: Namlan

Input			
Height	H	5.50	m
Margin Height	h ₀	1.00	m
Water depth (U/S)	h ₂	4.50	m
Water depth (D/S)	h ₁	0.00	m
Sediment depth	h _s	1.30	m
Slope (U/S)	1:n	0.00	
Slope (D/S)	1:m	0.00	
Unit weight of water	w _o	1.00	t/m ³
Unit weight of concrete	w _c	2.30	t/m ³
Unit weight of earth (below water)	w _s	1.13	t/m ³
Uplift coefficient	ζ	1.00	
Coefficient of earth pressure	C _e	0.50	
Seismic coefficient (Full)	κ ₁	0.10	
Seismic coefficient (Empty)	κ ₂	0.05	

Concrete			Water		
No.	x (m)	y (m)	No.	x (m)	y (m)
1	0.000	0.000	1	0.000	2.200
2	0.000	2.200	2	0.800	2.200
3	0.800	2.200	3	1.400	1.000
4	1.400	1.000	4	2.500	1.000
5	2.500	1.000	5	2.500	4.500
6	2.500	5.000	6	0.000	4.500
7	1.491	5.000	7	0.000	2.200
8	1.491	5.500	8		
9	4.000	5.500	9		
10	4.000	0.000	10		
11	0.000	0.000	11		
12			12		
13			13		
14			14		
15			15		



Max	4.000
Min	0.000
L	4.000

	Weir Full + Seismic D/S Direction		Magnitude (ton)	V (ton)	H (ton)	x (m)	y (m)	Mr (tm)	Mo (tm)
(1)	Self Weight	W ₁	28.921	28.921	0.000	1.480	0.000	42.802	
(2)	Seismic	F ₁	2.892	0.000	2.892	0.000	2.277		6.584
(3)	Static Water Pressure (U/S)	Pw1	10.125	0.000	10.125	0.000	1.500		15.188
(4)	Static Water Pressure (D/S)	Pw2	n.a	n.a	n.a	n.a	n.a		
(5)	Earth Pressure due to Sediment	Ps	0.479	0.000	0.479	0.000	0.433		0.207
(6)	Active Water Pressure (U/S)	Pd	0.131	0.000	0.131	0.000	1.800		0.236
(7)	Uplift	Wu	-9.000	-9.000	0.000	2.667	0.000		24.000
(8)	Water (U/S)	Ww	7.430	7.430	0.000	2.628	0.000	19.527	0.000
(9)	Water (D/S)	Ws	n.a	n.a	n.a	n.a	n.a		
Total				27.351	13.627			62.329	46.215
								ΣM=	16.114


Stability (Weir Full +Seismic D/S Direction)

	unit	Result		Allowable Range	Judge
Safety factor for over turning	m	1.411	<	0.667	NG
Safety factor for sliding		1.204	>	1.200	OK
Bearing stress s1 (f=0.5)	t/m ²	21.309	<	100.000	OK
Bearing stress s2 (f=0.5)	t/m ²	-7.633	<	100.000	NG

neglect overturning

$$\frac{\Sigma M_r}{\Sigma M_o} = 1.35$$


Stability Analysis of Power Intake



Project: Namlan (FSWL)

Input			Weir Coordinates			Water Upstream Coordinates		
Weir Height	H	2.30 m	No.	x (m)	y (m)	No.	x (m)	y (m)
Margin Height	h ₀	0.00 m	1	0.000	0.000	1	0.000	0.500
Water depth (U/S)	h ₂	2.30 m	2	0.000	0.500	2	0.000	2.300
Water depth (D/S)	h ₁	0.00 m	3	0.500	0.500	3	0.500	2.300
Sediment depth	h _s	1.50 m	4	0.500	2.300	4	0.500	0.500
Slope (U/S)	1:n	0.00	5	1.500	2.300	5	0.000	0.500
Slope (D/S)	1:m	0.70	6	2.760	0.500	6		
Unit weight of water	w _o	1.00 t/m ³	7	3.500	0.500	7		
Unit weight of concrete	w _c	2.30 t/m ³	8	3.500	0.000	8		
Unit weight of earth (submerged)	w _s	1.10 t/m ³	9	0.000	0.000	9		
Uplift coefficient	ζ	1.00	10			10		
Coefficient of earth pressure	C _e	0.50	11			11		
Seismic coefficient (Full)	κ ₁	0.00	12			12		
Seismic coefficient (Empty)	κ ₂	0.00	13			13		
			14			14		
			15			15		

Max	3.500
Min	0.000
L	3.500




	Weir Full		Magnitude (ton)	V (ton)	H (ton)	x (m)	y (m)	Mr (tm)	Mo (tm)
(1)	Self Weight	W ₁	10.773	10.773		1.997		21.515	
(2)	Seismic	F ₁	0.000		0.000		0.898		0.000
(3)	Static Water Pressure (U/S)	Pw1	2.645		2.645		0.767		2.028
(4)	Static Water Pressure (D/S)	Pw2	0.000		0.000		0.000	0.000	
(5)	Earth Pressure due to Sediment	Ps	0.619		0.619		0.500		0.309
(6)	Active Water Pressure (U/S)	Pd	0.000		0.000		0.920		0.000
(7)	Uplift	Wu	-4.025	-4.025		2.333			9.392
(8)	Water (U/S)	Ww1	0.900	0.900		3.250		2.925	
(9)	Water (D/S)	Ww2	0.000	0.000		3.500		0.000	
(10)	Concentrated Load of Bridge	Wb	2.300	2.300		2.5		5.750	
(11)	Sediment(U/S)	Ws	0.550	0.550		3.250		1.788	
	Total			10.498	3.264			31.977	11.729
								ΣM=	20.248

Stability (Weir Full)

	unit	Result		Allowable Range	Judge
Safety factor for over turning	m	0.179	<	0.583	OK
Safety factor for sliding		1.930	>	1.5	OK
Bearing stress s1 (f=0.5)	t/m ²	3.919	<	100.000	OK
Bearing stress s2 (f=0.5)	t/m ²	2.080	<	100.000	OK

f=0.6

Stability Analysis of Intake Weir (Full Supply Water Level)




Project: Namlan (FSWL + Seismic Downstream)

Input			
Weir Height	H	2.30	m
Margin Height	h ₀	0.00	m
Water depth (U/S)	h ₂	2.30	m
Water depth (D/S)	h ₁	0.00	m
Sediment depth	h _s	1.50	m
Slope (U/S)	1:n	0.00	
Slope (D/S)	1:m	0.70	
Unit weight of water	w _o	1.00	t/m ³
Unit weight of concrete	w _c	2.30	t/m ³
Unit weight of earth (below water)	w _s	1.10	t/m ³
Uplift coefficient	ζ	1.00	
Coefficient of earth pressure	C _e	0.50	
Seismic coefficient (Full)	κ ₁	0.10	
Seismic coefficient (Empty)	κ ₂	0.05	

Weir Coordinates			Water Upstream Coordinates		
No.	x (m)	y (m)	No.	x (m)	y (m)
1	0.000	0.000	1	0.000	0.500
2	0.000	0.500	2	0.000	2.300
3	0.500	0.500	3	0.500	2.300
4	0.500	2.300	4	0.500	0.500
5	1.500	2.300	5	0.000	0.500
6	2.760	0.500	6		
7	3.500	0.500	7		
8	3.500	0.000	8		
9	0.000	0.000	9		
10			10		
11			11		
12			12		
13			13		
14			14		
15			15		

Max	3.500
Min	0.000
L	3.500



	Weir Full + Seismic D/S Direction		Magnitude (ton)	V (ton)	H (ton)	x (m)	y (m)	Mr (tm)	Mo (tm)
(1)	Self Weight	W ₁	10.773	10.773		1.997		21.515	
(2)	Seismic	F ₁	1.077		1.077		0.898		0.967
(3)	Static Water Pressure (U/S)	Pw1	2.645		2.645		0.767		2.028
(4)	Static Water Pressure (D/S)	Pw2	0.000		0.000		0.000	0.000	
(5)	Earth Pressure due to Sediment	Ps	0.619		0.619		0.500		0.309
(6)	Active Water Pressure (U/S)	Pd	0.067		0.067		0.920		0.062
(7)	Uplift	Wu	-4.025	-4.025		2.333			9.392
(8)	Water (U/S)	Ww1	0.900	0.900		3.250		2.925	
(9)	Water (D/S)	Ww2	0.000	0.000		3.500		0.000	
(10)	Concentrated Load of Bridge	Wb	2.300	2.300		2.5		5.750	
(11)	Sediment(U/S)	Ws	0.550	0.550		3.250		1.788	
Total				10.498	4.408			31.977	12.758
								ΣM=	19.219

Stability (Weir Full +Seismic D/S Direction)

	unit	Result		Allowable Range	Judge
Safety factor for over turning	m	-0.081	<	0.583	OK
Safety factor for sliding		1.429	>	1.2	OK
Bearing stress s1 (f=0.5)	t/m ²	2.584	<	100.000	OK
Bearing stress s2 (f=0.5)	t/m ²	3.415	<	100.000	OK

f=0.6


Stability of Intake Weir (Full Supply Water Level; Seismic)

Project: Namlan (Flood Condition)

Input			
Weir Height	H	2.30	m
Margin Height	h ₀	0.00	m
Water depth (U/S)	h ₂	3.16	m
Water depth (D/S)	h ₁	1.00	m
Sediment depth	h _s	1.50	m
Slope (U/S)	1:n	0.00	
Slope (D/S)	1:m	0.70	
Unit weight of water	w _o	1.00	t/m ³
Unit weight of concrete	w _c	2.30	t/m ³
Unit weight of earth (below water)	w _s	1.10	t/m ³
Uplift coefficient	ζ	1.00	
Coefficient of earth pressure	C _e	0.50	
Seismic coefficient (Full)	κ ₁	0.00	
Seismic coefficient (Empty)	κ ₂	0.00	

Weir Coordinates			Water Upstream Coordinates		
No.	x (m)	y (m)	No.	x (m)	y (m)
1	0.000	0.000	1	0.000	0.500
2	0.000	0.500	2	0.000	3.160
3	0.500	0.500	3	1.500	3.160
4	0.500	2.300	4	1.500	2.300
5	1.500	2.300	5	0.500	2.300
6	2.760	0.500	6	0.500	0.500
7	3.500	0.500	7	0.000	0.500
8	3.500	0.000	8		
9	0.000	0.000	9		
10			10		
11			11		
12					
			Water Downstream Coordinates		
No.	x (m)	y (m)	No.	x (m)	y (m)
13			1	1.500	2.300
14			2	1.500	3.160
15			3	1.988	3.160
			4	3.500	1.000
			5	3.500	0.500
			6	2.760	0.500
			7	1.500	2.300
			8		
			9		
			10		

Max	3.500
Min	0.000
L	3.500




	Flood Condition		Magnitude (ton)	V (ton)	H (ton)	x (m)	y (m)	Mr (tm)	Mo (tm)
(1)	Self Weight	W ₁	10.773	10.773		1.997		21.515	
(2)	Seismic	F ₁	0.000		0.000		0.898		
(3)	Static Water Pressure (U/S)	Pw1	4.993		4.993		1.053		5.259
(4)	Static Water Pressure (D/S)	Pw2	-0.500		-0.500		0.333	0.167	
(5)	Earth Pressure due to Sediment	Ps	0.619		0.619		0.500		0.309
(6)	Active Water Pressure (U/S)	Pd	0.000		0.000		0.920		
(7)	Uplift	Wu	-7.280	-7.280		2.053			14.945
(8)	Water (U/S)	Ww1	2.190	2.190		2.955		6.473	
(9)	Water (D/S)	Ww2	2.553	2.553		1.060		2.705	
(10)	Concentrated Load of Bridge	Wb	2.300	2.300		2.5		5.750	
(11)	Sediment(U/S)	Ws	0.550	0.550		3.250		1.788	
	Total			11.086	5.112			38.397	20.513
								ΣM=	17.883

Stability (Flood Condition)

	unit	Result		Allowable Range	Judge
Safety factor for over turning	m	0.137	<	0.583	OK
Safety factor for sliding		1.301	>	1.2	OK
Bearing stress s1 (f=0.5)	t/m ²	3.911	<	100.000	OK
Bearing stress s2 (f=0.5)	t/m ²	2.424	<	100.000	OK

f=0.6

Stability Analysis of Weir (Flood Water Level)



EL. 617.500 Draft Tube Pit Bottom Slab <Uniform Load / 4 Fixed Edges (v=0)>


Short span	l_x	3.50 m
Long span	l_y	3.60 m
Span ratio	l_y/l_x	1.03

Unit weight of concrete	w_c	2.3 t/m ³
Unit weight of water	w_w	1.0 t/m ³

Dead Load	W_c	-0.9 t/m ²
Reaction	P_1	7.6 t/m ²
Uplift	P_u	3.5 t/m ²

Load Combination	$W = W_c + P_1 + P_u$	10.2 t/m ²
------------------	-----------------------	-----------------------

Moment	M_{x1}	$-0.052 \times W \times l_x^2$	-6.47 t·m
	M_{x2}	$0.018 \times W \times l_x^2$	2.24 t·m
	M_{y1}	$-0.052 \times W \times l_x^2$	-6.47 t·m
	M_{y2}	$0.018 \times W \times l_x^2$	2.24 t·m
Shear	Q_x	$0.44 \times W \times l_x$	15.63 t
	Q_y	$0.44 \times W \times l_x$	15.63 t



Moment and Shear of Draft Tube Pit Bottom Slab (EL 617.500)

**EL. 621.150 Draft Tube Pit Top Slab
<Uniform Load / 3 Fixed Edges (v=0) / Long Span Free>**


Short span	l_x	3.40 m
Long span	l_y	3.50 m
Span ratio	l_y/l_x	1.03

Unit weight of concrete	w_c	2.3 t/m ³
Unit weight of water	w_w	1.0 t/m ³

Dead load	W_c	1.3 t/m ²
Live load	P_1	1.0 t/m ²

Load Combination	$W = W_c + P_1$	2.3 t/m ²
------------------	-----------------	----------------------

Moment	M_{x1}	$-0.058 \times W \times l_x^2$	-1.52 t·m
	M_{x2}	$0.012 \times W \times l_x^2$	0.31 t·m
	M_{y1}	$-0.085 \times W \times l_x^2$	-2.23 t·m
	M_{y2}	$0.040 \times W \times l_x^2$	1.05 t·m
Shear	Q_x	$0.40 \times W \times l_x$	3.08 t
	Q_y	$0.58 \times W \times l_x$	4.47 t



Moment and Shear of Draft Tube Pit Upper Slab (EL 621.150)

Draft Tube Pit Wall <Trapezoid Load on Short Span / 4 Fixed Edges (v=0)>


Short span	l_x	3.10 m
Long span	l_y	3.50 m
Span ratio	l_y/l_x	1.13

Unit weight of concrete	w_c	2.3 t/m ³
Unit weight of water	w_w	1.0 t/m ³

Water pressure	P_w	3.1 t/m ²
Horizontal earth pressure	P_H	1.7 t/m ²
Horiz earth pressure due to live load	P_{Hq}	0.5 t/m ²

Load Combination	$W = P_w + P_H + P_{Hq}$	5.3 t/m ²
------------------	--------------------------	----------------------

Moment	M_{x1}	$-0.038 \times W \times l_x^2$	-1.94 t·m
	M_{x2}	$0.013 \times W \times l_x^2$	0.66 t·m
	M_{x3}	$-0.022 \times W \times l_x^2$	-1.12 t·m
	M_{y1}	$-0.028 \times W \times l_x^2$	-1.43 t·m
	M_{y2}	$0.008 \times W \times l_x^2$	0.41 t·m
Shear	Q_{x1}	$0.34 \times W \times l_x$	5.60 t
	Q_{x3}	$0.14 \times W \times l_x$	2.30 t
	Q_{y1}	$0.24 \times W \times l_x$	3.95 t



Moment and Shear of Draft Tube Pit Wall

EL. 621.150 Generator Floor Slab <Uniform Load / 4 Edges Pin (v=0)>


Short span	l_x	5.85 m
Long span	l_y	6.00 m
Span ratio	l_y/l_x	1.03

Unit weight of concrete	w_c	2.3 t/m ³
Unit weight of water	w_w	1.0 t/m ³

Dead load	W_c	1.3 t/m ²
Live load	P_1	1.0 t/m ²




Load Combination	$W = W_c + P_1$	2.3 t/m ²
------------------	-----------------	----------------------

Moment	M_{x1}	$0.000 \times W \times l_x^2$	0.00 t·m
	M_{x2}	$0.038 \times W \times l_x^2$	2.95 t·m
	M_{y1}	$0.000 \times W \times l_x^2$	0.00 t·m
	M_{y2}	$0.038 \times W \times l_x^2$	2.95 t·m
Shear	Q_x	$0.46 \times W \times l_x$	6.10 t
	Q_y	$0.46 \times W \times l_x$	6.10 t



Moment and Shear of Generator Floor Slab (L) (EL 621.150)

Moment and Shear of Generator Floor Slab (S) (EL 621.150)




APPENDIX C-5 Structural Analysis (18/22)


STRESS CALCULATION FOR REINFORCED CONCRETE

Powerhouse Slab and Draft Tube Pit Slab and Wall


Structure			1	2a	2b	3a	3b	4	5
			Draft Tube Pit Bottom Slab	Draft Tube Pit Top Slab	Draft Tube Pit Top Slab (Trench)	Generator Floor Slab (L)	Generator Floor Slab (L) (Trench)	Generator Floor Slab (S)	Draft Tube Pit Wall
Member									
Moment	M	(t.m)	6.47	2.23	2.23	2.95	2.95	2.15	1.94
Shear	S	(t)	15.63	4.47	4.47	6.10	6.10	6.12	5.60
Axial Force	N	(t)	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Width	B	(cm)	100.00	100.00	100.00	100.00	100.00	100.00	100.00
Height	H	(cm)	40.00	50.00	30.00	50.00	30.00	50.00	40.00
Effective Height	d	(cm)	30.00	40.00	25.00	40.00	25.00	40.00	30.00
Cover for comp.	d'	(cm)							
Re-bar (tension)	As	(cm ²)	19.40	19.40	19.40	19.40	19.40	19.40	19.40
Re-bar arrange			D22@200	D22@200	D22@200	D22@200	D22@200	D22@200	D22@200
Re-bar (comp.)	As'	(cm ²)							
Re-bar arrange									
Compression	σ_c	(kg/cm ²)	46.05	9.87	21.51	13.06	28.45	9.52	13.81
Tension	σ_s	(kg/cm ²)	1,260.42	321.15	526.47	424.84	696.45	309.63	377.93
Shear	τ	(kg/cm ²)	5.91	1.25	2.05	1.70	2.79	1.71	2.12
Allowable stress	σ_{ca}	(kg/cm ²)	60.00	60.00	60.00	60.00	60.00	60.00	60.00
	σ_{sa}	(kg/cm ²)	1,600.00	1,600.00	1,600.00	1,600.00	1,600.00	1,600.00	1,600.00
	τ_a	(kg/cm ²)	8.00	8.00	8.00	8.00	8.00	8.00	8.00
Note									




Draft Tube Pit Bottom Slab



Generator Floor Slab (L) and Draft Tube Pit Upper Slab



Generator Floor Slab (S)




Draft Tube Pit Wall

Re-bar Arrangement of Powerhouse Slab and Draft Tube Pit Slab and Wall

STRESS CALCULATION FOR REINFORCED CONCRETE
Namlan Tailrace Culvert (Large Section)

Structure Member			1 Top Slab	2 Side Wall	3 Side Wall	4 Bottom Slab
Moment	M	(t.m)	3.07	5.16	5.16	3.70
Shear	S	(t)	4.19	9.60	9.60	5.69
Axial Force	N	(t)	4.56	7.46	7.46	0.00
Width	B	(cm)	100.00	100.00	100.00	100.00
Height	H	(cm)	40.00	40.00	40.00	40.00
Effective Height	d	(cm)	30.00	30.00	30.00	30.00
Cover for comp.	d'	(cm)				
Re-bar (tension)	As	(cm ²)	14.30	14.30	14.30	14.30
Re-bar arrange			D19@200	D19@200	D19@200	D19@200
Re-bar (comp.)	As'	(cm ²)				
Re-bar arrange						
Compression	σ_c	(kg/cm ²)	24.18	40.65	40.65	29.30
Tension	σ_s	(kg/cm ²)	618.52	1,047.47	1,047.47	963.06
Shear	τ	(kg/cm ²)	1.59	3.65	3.65	2.12
Allowable stress	σ_{ca}	(kg/cm ²)	60.00	60.00	60.00	60.00
	σ_{sa}	(kg/cm ²)	1,600.00	1,600.00	1,600.00	1,600.00
	τ_a	(kg/cm ²)	8.00	8.00	8.00	8.00
Note						


Re-bar Arrangement of Tailrace Culvert (Large Section)




STRESS CALCULATION FOR REINFORCED CONCRETE
Namlan Tailrace Culvert (Small Section)


Structure Member			1 Top Slab	2 Side Wall	3 Side Wall	4 Bottom Slab
Moment	M	(t.m)	1.08	2.76	2.76	2.05
Shear	S	(t)	1.82	6.01	6.01	6.48
Axial Force	N	(t)	2.57	4.49	4.49	0.00
Width	B	(cm)	100.00	100.00	100.00	100.00
Height	H	(cm)	40.00	40.00	40.00	40.00
Effective Height	d	(cm)	30.00	30.00	30.00	30.00
Cover for comp.	d'	(cm)				
Re-bar (tension)	As	(cm ²)	14.30	14.30	14.30	14.30
Re-bar arrange			D19@200	D19@200	D19@200	D19@200
Re-bar (comp.)	As'	(cm ²)				
Re-bar arrange						
Compression	σ_c	(kg/cm ²)	8.39	21.70	21.70	16.23
Tension	σ_s	(kg/cm ²)	181.26	541.10	541.10	533.59
Shear	τ	(kg/cm ²)	0.70	2.29	2.29	2.41
Allowable stress	σ_{ca}	(kg/cm ²)	60.00	60.00	60.00	60.00
	σ_{sa}	(kg/cm ²)	1,600.00	1,600.00	1,600.00	1,600.00
	τ_a	(kg/cm ²)	8.00	8.00	8.00	8.00
Note						

Re-bar Arrangement of Tailrace Culvert (Small Section)







Typical Section



Skeleton Diagram




Normal Condition




With Groundwater


Loading Diagram



Shear (with groundwater)




Moment (with groundwater)




Reinforcement Bar Arrangement @200


Tailrace Culvert (Large Section) Section, Skeleton Diagram, Loading Diagram, Shear, Moment and Re-bar Arrangement



Typical Section




Normal Condition




With Groundwater


Loading Diagram




Skeleton Diagram



Shear (with groundwater)



Moment (with groundwater)



Reinforcement Bar Arrangement @200

Tailrace Culvert (Small Section) Section, Skeleton Diagram, Loading Diagram, Shear, Moment and Re-bar Arrangement

Figure C-5-1 Log of Test Pit No.1

GEODYNAMICS CO.,LTD. Geotechnical Engineering LOG OF TEST PIT OR AUGER HOLE FOR BORROW AND FOUNDATION INVESTIGATIONS											
Feature		SURGE TANK SITE		Project		NAMLAN HYDROPOWER PROJECT		Hole No.		TP-1	
Area Designation		-----		Coordinates		-----		Depth to Ground Water Level		NIL	
Method of Excavation		Manual		Approx. Dimension of Hole		4' x 6' x 15'		Dates of Excavation		24/25-May-01	
Hole Logged By		S.Lwin									
CLASSIFICATION SYMBOL		DEPTH (FEET)	SIZE AND TYPE OF SAMPLE TAKEN	CLASSIFICATION AND DESCRIPTION OF MATERIAL (SEE CHART UNIFIED SOIL CLASSIFICATION GIVE GEOLOGIC AND IN-PLACE DESCRIPTION FOR FOUNDATION INVESTIGATION)	PERCENTAGE OF COBBLES AND BOULDERS**						
					VOLUME OF PILES SAMPLED (CUBIC FEET)	WEIGHT OF 3 TO 5 INCH SAMPLES (LBS)	PERCENTAGE BY VOLUME OF 3 TO 5 INCH	WEIGHT OF PILES 5 INCH SAMPLED (LBS)	PERCENTAGE BY VOLUME OF PILES TO 5 INCH		
L	G	0-2 2-3 3-5 5-15	S S S S	0-2 ft. Top soil, black silty clay with scattered shell and rocks 2-3ft Tufa mixed with soil 2.25 loose yellowish yellowish grey tufa and from 2.5 to 3ft is black soil layer. 3-5ft Tufa yellowish grey poorly consolidated tufa with some hollows from which solid tufa pieces fall out or solution holes. Easy in excavation. 5-15ft tufa yellowish brown with iron staining, medium dense, with bedding like layers dipping towards the cliff side indicating the water flow direction.							
REMARKS											
NOTES Record water test and density test data, if applicable, under remarks *Record after water has reached its natural level, give date of reading adjacent to graphic symbol or in remarks **Applicable only to borrow pits and to foundations which are potential sources of construction materials *** (lbs of rock sampled /100) (bulk specific gravity of rock 924 (Cubic feet hole sampled) Record bulk specific gravity in remarks unless here obtained (measured or estimated)											

NAM LAN SCHEME

TEST PIT No. 1
PONDAGE



AUNG PYI TUN CONSTRUCTION LTD.

Figure C-5-2 Photograph of Test Pit No.1 (1/2)




Figure C-5-3 Photograph of Test Pit No.1 (2/2)

Figure C-5-4 Log of Test Pit No.2

GEODYNAMICS CO.,LTD.
Geotechnical Engineering

LOG OF TEST PIT OR AUGER HOLE FOR BORROW AND FOUNDATION INVESTIGATIONS

Feature **ANCHOR BLOCK** Project **NAMLAN HYDROPOWER PROJECT** Hole No. **TP-2**
 Area Designation----- Coordinates----- Ground Elevation-----
 Method of Excavation **Manual** Approx.Dimension of Hole **4'X 6'X15'** Dates of Excavation **24/25-May-01** Depth to Ground Water Level **NIL**
 Hole Logged By **S.Lwin**

CLASSIFICATION SYSTEM		DEPTH (FEET)	SEAL AND TYPE OF SAMPLE TAKEN	CLASSIFICATION AND DESCRIPTION OF MATERIAL (SEE CHART UNIFIED SOIL CLASSIFICATION GIVE GEOLOGIC AND IN-PLACE DESCRIPTION FOR FOUNDATION INVESTIGATION)	PERCENTAGE OF COBBLES AND BOULDERS**				
					VOLUME OF HOLES SAMPLED (CUBIC FEET)	WEIGHT OF 3 TO 3 INCH SAMPLES (LBS)	PERCENTAGE BY VOLUME OF 3 TO 3 INCH	WEIGHT OF PLUS 3 INCH SAMPLED (LBS)	PERCENTAGE BY VOLUME OF PLUS TO 3 INCH
CL	•••••	5		0-1.5ft. Top soil. Black silty clay with pieces of tufa and roots					
	•••••			1.5-2.5ft Tufa Whitish grey loose tufa					
	•••••			2.5-5.5ft Clay, Yellowish brown and purplish stiff clay; developed from completely weathered shale.					
	•••••			5.5-7.0ft Shale, highly weathered purplish shale, thinly bedded and highly jointed,can crushed between fingers.Easy in excavation. Foundation class C_k					
H-W	/ / / / /	10		7.5-15 Shale.Highly to moderately weathered purple shale. Hard in excavation. Broken into flat pieces;closely jointed. Foundation class C_{M-L}					
H-W	/ / / / /								
		15							
REMARKS shale do not break down after soaking in water. Some are sandy.									
NOTES Flooded water test and density test data, if applicable, under remarks					*** (lbs of rock sampled /100)				
*Record after water has reached its natural level, give date of reading adjacent to graphic symbol or in remarks					(bulk specific gravity of rock) ρ_{24} (Cubic feet hole sampled)				
**Applicable only to borrow pits and to foundations which are potential sources of construction materials					Record bulk specific gravity in remarks, stating how obtained (measured or estimated)				




Figure C-5-5 Photograph of Test Pit No.2

Figure C-5-6 Log of Test Pit No.3

GEODYNAMICS CO.,LTD. Geotechnical Engineering. LOG OF TEST PIT OR AUGER HOLE FOR BORROW AND FOUNDATION INVESTIGATIONS									
Feature		POWER STATION SITE		Project		NAMLAN HYDROPOWER PROJECT			
Area Designation		Coordinates		Ground Elevation		Hole No. TP-3			
Method of Excavation		Manual		Approx. Dimension of Hole		4' X6'X15'			
				Dates of Excavation		25/26-May-01			
						Depth to Ground Water Level 9.3ft			
						Hole Logged By S.Lwin			
CLASSIFICATION SYMBOL		DEPTH (FEET)	SIZE AND TYPE OF SAMPLE TAKEN	CLASSIFICATION AND DESCRIPTION OF MATERIAL (SEE CHART UNIFIED SOIL CLASSIFICATION GIVE GEOLOGIC AND IN-PLACE DESCRIPTION FOR FOUNDATION INVESTIGATION)	PERCENTAGE OF COBBLES AND BOULDERS**				
					VOLUME OF HOLES SAMPLED (CUBIC FEET)	WEIGHT OF 3 TO 3/8 INCH SAMPLED (LB)	PERCENTAGE BY VOLUME OF 3 TO 5 INCH	WEIGHT OF PLUS 3/8 INCH SAMPLED (LB)	PERCENTAGE BY VOLUME OF PLUS TO 3/8 INCH
A	5		0-1.3ft Top soil. Black silty clay with vegetable roots.					
	* * * *			1.3-3.5ft Shale. Completely weathered yellowish brown with patches of purple spots, stiff. Easy in excavation.					
	* * * *			3.5-7.0ft Boulders in weathered shales; boulders are hard sandstone.					
	* * * *			7.0-15ft Shale. Moderately weathered purple shale, thin bedded, interbedded with thin sandy shale layers. Hard in excavation. Foundation class C _M ground water at 9.3ft.					
	/ / / /	10							
	/ / / /	15							
REMARKS									
NOTES: Record water test and density test data, if applicable, under remarks * Record after water has reached its natural level, give date of reading adjacent to graphic symbol or in remarks ** Applicable only to borrow pits and to foundations which are potential sources of construction materials					*** (lbs of rock sampled /100 (bulk specific gravity of rock) x 24 (Cubic feet hole sampled) Record bulk specific gravity in remarks, stating how obtained (measured or estimated)				




Figure C-5-7 Photograph of Test Pit No.3