Appendix-5.3

Natural Condition Survey

# 5.3 Natural Condition Survey

# Water Source Survey (including Water Quality Survey)

The basic design study investigated the present conditions of water sources identified mainly by the development study (2002) and the preparatory study (2003), both precedents to the Basic Design Study. The results of the survey of the water sources is summarized in Table A1-1 and described below.

# (1) Water Sources

Tarus:

Water supply for Tarus village will be from Tarus spring. As the water from the Tarus spring is presently utilized not only for the Regional Drinking Water Enterprise (PDAM), but also for irrigation purposes, confirmation on the water rights was necessary.

The Study Team confirmed that about 30 L/sec of water is currently not being utilized by the PDAM at the spring and flows out downstream. On the other hand additional water use for the new water supply system will be 10 L/sec at the maximum. As a result the rest, about 20 L/sec of water, will still be available to the area downstream. That is sufficient for the irrigated area downstream.

It was confirmed that the head of the sub-district who is the owner of the spring, agreed on the additional use of water for the water supply scheme.

# Duman (Upper)

The upper most hamlet, Kuban Baru, is not supplied with water from the existing water source. A new spring was identified by the development study (May 2002) at a higher location than the existing broncaptering.

The basic design study confirmed through topographic survey that the new water source is located at a position high enough to supply water to Kuban Baru. The basic design study also confirmed the spring yield of 3 L/sec.

## Bagik Papan:

The existing water supply system was constructed in 1989 and provided sufficient water from the existing water source (spring). The water yield from the existing water source has declined to 1.3 L/sec (measured by the basic design study team) due to deforestation by re-settlers settled on the area above the spring. As the existing water source is no longer sufficient for the water supply scheme, the recent Development Study (2002) has already identified the new water source (M.A. Balas-I).

It was re-confirmed by this study that the new water source is available for the scheme (no water rights issues exist), and that it has adequate volume and is of good quality.

# Labuhan Mapin:

It was reported that the water supply to Labhan Mapin was not sufficient and therefore, development of new water sources would be required.

The observations and conclusions by the basic design study are as follows;

The development study reported that:

Water flow from the spring (M.A. Remas) to the broncaptering was reduced to 6 L/sec (measured in the rainy season by the development study) because a fallen tree damaged the flow path and disturbed the water flow.

PDAM Sumbawa repaired the damage in 2001, resulting in a water flow of 11 L/sec to the broncaptering even in the dry season (measured by the development study).

The basic design study confirmed that:

- Water volume collected by the broncaptering is 9.5 L/sec, and the water flow at the lowest BPT (Break Pressure Tank) was also 9.5 L/sec, indicating no major leakage from the transmission pipe.
- There was about 9.5 L/sec of leakage from a damaged part of the broncaptering. As the damaged part was repairable with simple concrete patch works, PDAM Sumbawa explained that they will repair it during the coming dry season.
- Total of 19 L/sec will be available for the existing water supply system if the damaged part is repaired to restore the water flow to the system to the original level of 20 L/sec.
- It was also confirmed by the Basic Design Study that the present water supply to Labuhan Mapin is 7.9 L/sec. That exceeds the required water flow to the designed scheme by the Development Study (2002).
- On the other hand, the Team observed leakage from distribution pipes, illegal connections by-passing flow meters, unclosed water taps wasting water, and other forms of wastage.

From the above observations the basic design study concludes that development of new water sources is not justifiable. Rather than that, proper operation and maintenance of the water supply system, including repairing the leaking pipes, banning illegal connections and, accepting adequate metering regulations will solve the impending problem of insufficient water.

Spring water discharge has been smaller than before due to illegal forest cutting. To preserve spring water as a resource, it is necessary to stop such an illegal act.

# (2) Water Quality

Out of the nine (9) water supply schemes, water quality analysis was carried out for the following three systems, for which the preceding preparatory study pointed out the necessity for further investigation on water sources.

- Duman (Upper)
- Bagik Papan
- Labuhan Mapin

Water samples taken from the water sources by the team were sent to a laboratory immediately after the sampling. The result of the water quality analysis is shown in Table A1-2 together with the results of the other six (6) systems for which water quality analysis had already been carried out by the development study (2002). The reports from the laboratory for the water samples analyzed for the Basic Design Study are also attached.

# a. Water quality evaluation as drinking water

The Indonesian guidelines for drinking water quality are also shown in the Table A1-2.

The table shows that all the analyzed samples are within the Indonesian guidelines for drinking water quality except for bacteria and coliform.

# b. Hydrogeological interpretation

In addition to the water quality analysis for drinking water, hydro-geological interpretation was carried out using the following items.

• Cation: Na, K, Ca, Mg

• Anion : Cl, HCO<sub>3</sub>, CO<sub>3</sub>, SO<sub>4</sub>

Analyzed results were converted from milligram per liter (mg/L) to milli-equivalent per liter, thereafter plotted on a 'Trilinear diagram' and 'Stiff diagram' as shown in Figure A1-1 and Figure A1-2 respectively.

- 1) Figure A1-1 Trilinear diagram shows all the water plots within the domain-I that represents water circulating near the ground surface, including surface water.
- 2) Figure A1-2 Stiff diagram shows two typical patterns; (1) water from Labuhan Mapin and Tarus show a similar pattern (pattern-A), (2) the others show the a second similar pattern (pattern-B). Pattern-A, which is strongly affected by the carbonated aquifer, is grouped in the Ca-HCO<sub>3</sub> type.
  - It is considered that the springs of Labuhan Mapin and Tarus originate from limestone aquifers, and the aquifers are being relatively quickly recharged by surface water.
  - The other water sources originate from very shallow aquifers, which are directly recharged by surface water. Water flow of those water sources may be strongly affected by rainfall.

System (Village)	Kabpaten (District)	Water Sources	Volume (Measurement method)	Remarks
Kuranji		Existing PDAM transmission pipe	-	Residual Chlorine,(0.2 mg/L), Pressure (0.15MPa)
Bajur		Existing PDAM transmission pipe	-	Residual Chlorine,(0.3 mg/L), Pressure (0.32MPa, 0.40 MPa)
Sunbung	Lombok	Existing PDAM transmission pipe	-	Residual Chlorine,(0.4 mg/L), Pressure (0.48MPa)
	Barat	M.A. Kohoh Bukit Trawasan (U)	3.0 L/sec (weight)	200m upstream from the existing broncaptering
Duman (U)		M.A. for Keban Baru	1.4 L/sec (weight)	On a brook of the right flank 150 m upstream of Kohoh Bukit Trawasan (Upper)
Duman (D)		Existing PDAM transmission pipe	-	Residual Chlorine,(0.1 mg/L), Pressure (> 0.32MPa)
Bagik Papan	Lombok	M.A. Balas-I	7 L/sec (current meter)	About 800m upstream of the existing broncaptering
Selaparang	Timur	M.A. Lenon	Over 50 L/sec (Development Study)	-
			9.5 L/sec (weigh)	Measured at no.6 BPT
Labuhan Mapin	Sumbawa	M.A. Remas	19 L/sec (weight)	Measured at broncaptering 9.5L/sec is used, the rest 9.5 L/sec is leaking from a broken part <sub>o</sub>
Tarus	Kupan	M.A.Tarus	About 33 L/sec after pumped by PDAM (current meter, overflowing height)	Measured at the spring It is said that total spring ranges from 40 to 75 L/sec, out of which PDAM uses $15\sim20$ L/sec

# Table A1-1 Summary of Survey on Water Sources

Table A1-2 Results of Water quality Analysis	
--	--

				Meas	ured in s	ite			Health-related Ite <b>m</b>									Hydro	ogeology	-related	Item								
Village	T( <b>°C)</b>	рН	EC	NH4	NO3	NO2	Bacteria	T.Coliform	Cr	Fl	As	РЬ	Se	Hg	CN	Fe	Cd	Mn	Cu	Na	К	Ca	Mg	а	нсоз	<b>SO4</b>	SiO4	Total Hardness as CaCO3	Note
			(mS/m)	(mg/L)	(mg/L)	(mg/L)	colony		(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	
Labuhan Mapin (No.6BPT)	24.2	7.7	34.1	0.0	0.0	0.0	30.0	D	<0.01	0.1	<0.005	< 0.005	<0.005	<0.001	<0.01	< 0.01	< 0.001	<0.01	< 0.02	11.7	<0.02	45.1	11.2	3.9	202.0	6.8	26.7	158.7	Analys
Labuhan Mapin (MA Remas)	22.0	7.4	34.7	0.0	0.0	0.0	30.0	D	<0.01	0.0	<0.005	<0.005	<0.005	<0.001	<0.01	< 0.01	<0.001	<0.01	< 0.02	10.5	<0.02	43.0	10.2	3.7	205.1	6.8	79.7	149.6	is by Bas
Duman (Upper)	22.0	7.8	6.7	0.0	0.0	0.0	30.0	D	<0.01	0.2	<0.005	<0.005	<0.005	<0.001	<0.01	0.1	<0.001	<0.01	< 0.02	5.9	<0.02	4.1	1.3	3.3	29.0	0.9	13.2	15.5	sic Design
Bagik Papan	21.0	7.4	29.0	0.0	0.0	0.0	30.0	D	<0.01	0.5	<0.005	<0.005	<0.005	<0.001	<0.01	< 0.01	< 0.001	<0.01	<0.02	19.1	<0.02	22.7	11.9	5.1	156.0	5.0	49.4	105.6	ר Study
Kuranji	28.2	7.1	11.6	25	2.5	0.1	0.0	ND	<0.006	0.1	<0.001	<0.01	<0.007	<0.001	<0.01	<0.04	<0.005	<0.02	<0.02	0.0	4.2	5.5	2.4	0.0	94.6	<0.04	51.0	27.0	
Bajur	20.2	/.1	11.0	2.3	2.3	0.1	0.0	ND	<0.000	0.1	~0.001	~0.01	<0.007	<0.001	<0.01	~0.04	~0.005	~0.02	<0.05	0.9	4.3		5.4	0.0	84.0	~0.94	54.0	21.9	Analysi
Sunbung	28.3	7.0	11.8	0.0	2.5	0.0	0.0	ND	<0.006	0.1	<0.001	<0.01	<0.007	<0.001	<0.01	<0.04	< 0.005	<0.02	< 0.03	8.4	4.0	5.6	3.5	0.0	75.6	2.3	55.5	28.6	s by Dev
Selaparan	22.1	6.6	16.0	<0.1	2.0	<0.02	25.0	ND	<0.006	0.2	<0.001	< 0.01	<0.007	<0.001	<0.01	<0.04	< 0.005	<0.02	<0.03	8.7	3.4	9.7	4.9	4.8	56.4	2.8	29.0	44.6	/elopmen
Duman(Lower)	25.2	6.7	14.8	0.0	4.0	0.0	0.0	ND	<0.006	0.4	<0.001	<0.01	<0.007	<0.001	<0.01	<0.04	< 0.005	<0.02	< 0.03	10.2	6.1	6.9	4.7	2.3	96.1	<0.94	58.0	36.6	t Study
Tarus	27.9	6.9	53.1	<0.1	5.0	<0.02	>100	D	<0.006	0.1	<0.001	<0.01	<0.007	<0.001	<0.01	<0.04	< 0.005	<0.02	<0.03	20.5	1.3	79.9	2.8	7.2	335.4	4.3	9.0	210.9	
Potable Water Guideline Indonesia	-	-	-	-	10.0	1.0	-	ND	0.05	1.40	0.05	0.05	0.01	0.00	0.10	0.30	0.005	0.10	1.00	200	-	-	-	250	-	400	-	-	

\* ND:Non Detected D:Detected



Figure A1-1 Trilinear Diagram



Appendix-5.4

Social Condition Survey

# 5.4 Social Condition Survey

# (1) Summary of the Interview Survey

# 1) General description of interview survey

An interview survey was conducted to verify the willingness to pay (WTP) for water fees on the improved water supply in three villages (Duman Upper, Bagik Papan, and Selaparang) that were pointed out in preparatory study report. The interview survey was contracted to a local consultant firm. The survey was carried out through interview style based on the Contingent Valuation Method (CVM). The collections of data were done using a structured questionnaire. The householder was asked how much he or she was willing to pay for a given level of service on the improved water supply. The collected data were analyzed statistically. The questionnaire differs from the usual household survey greatly in that an evaluation scenario was explained. Thus, interviewees were informed about all important aspects, such as the present situation of water supply in a village, the hypothetical situation of the improved water system, and operation and maintenance (O&M) methods of the system. The interviewees were given special impetus to answer honestly by careful explanation to consider whether they would truly be able to pay, or whether there was a possibility that it might become impossible for them to buy necessary items.

# 2) Sample collection and analysis

The interview survey was conducted in Duman Upper and Bagik Papan where there will be a Type C system (village/water user's association management), and in Selaparang where there will be a Type A system (PDAM management).

Province	District	Village	Туре	House Connection	Public Tap	Total
		Duman Upper		126	126	
	Lombok Barat					252
NTB						
	Lombolt Timur	Bagik Papan	С	126	126	252
	Lombok Timur	Selaparang	Α	125	125	250
		Total				754

Table B1-1 Sample Size (CVM)

①Duman Upper and Bagik Papan:

In Duman Upper and Bagik Papan, the interview survey was conducted on 252 households

in each village. Half of the interviewees (126 households) were asked the amount of WTP in case of public taps and the other half of interviewees (126 households) were asked the same question about house connections. The double-bound model was used to collect data and it offered 5 types of amount (400, 1,000, 1,900, 3,100, 4,600 rupiah). The double-bound approach adds one follow up question to the single bound question. The amount of WTP was estimated using a Weibull distribution model (The Weibull model is said to have a wide applicability and it makes it easy to obtain a reliable statistical result. The presumed result was estimated by having assumed the Weibull function in the distribution of an amount of WTP.) The result obtained was a very reliable statistic.

The result shows that most people of the village want the improved sanitary water supply system (95%). The amount of WTP is 4,023 rupiah for a house connection system and 2,354 rupiah for public taps in Duman Upper. In Bagik Papan, it is about 1,900 rupiah in each case. Although the amount of O&M fees from each household is not yet estimated, both villages will be able to pay sufficient O&M fees when using the results generated at the time of the development study.



**Duman Upper-House Connections** 

 Table B1-2 Water Demand Curve by CVM Method (Duman-upper)

**Duman Upper: Public Taps** Median WTP : **2,354 Rupiah** p(significance level) : 0.000\*\*\*



# Table B1-3 Water Demand Curve by CVM Method (Bagik Papan)



In Bagik Papan, although many households are willing to pay more O&M fees for house connections than public taps, the medium WTP is almost the same at 1,900 rupiah. The following three reasons are mentioned for the cheaper amount of the WTP; 1) Except for one hamlet, there is access to water such as using shallow wells, irrigation channels or springs, despite unsanitary conditions. 2) A common reason that it cannot be paid is that he or she could not afford to pay, even though they understood the importance of O&M. 3) Most of the households are poor and daily seasonal labor. Moreover, because of poverty, there is also a high number of migrant male workers in Bagik Papan.

# ② Selaparang :

The interview survey was conducted to 250 households in Selaparang. Half of the interviewees (125 households) were asked their WTP for public taps system, and the remaining 125 households were asked the same question for house connections.

In Selaparang, all households want the improved water supply system. First of all, the WTP for house connections was asked on four prepared amounts (4,200, 4,800, 5,400, 6,000 rupiah) that was set up in consideration of the PDAM tariff. Most of the households (99%) answered that they were able to pay. According to the interviewers, households answered that they were able to pay a water charge of more than 10,000 rupiah. At present, households have paid an average 513 rupiah per day for purchasing water, which if converted to a monthly charge is 15,390 rupiah. Therefore, there is no doubt about WTP for house

connections in Selaparang. This is because piped water has been supplied only after midnight, although an existing PDAM system is connected. Therefore, households feel very strong stress under the present service, and if there is an improved water supply system, they will pay as much as they can for the water charge.

On the other hand, the WTP for public taps was asked for four prepared amounts (1,580, 1,800, 2,000, 2,200 rupiah). In the results, a number of households (78%) answered that they did not want to pay the water fees for public taps. This is because Care International once installed a public tap system for water supply in the community. However, the amount of water was limited and it caused scrambling for water between households. In order to prevent the same problem, many households want to pay for a house connection system rather than a public tap system.





The result of the estimation was calculated using a logit model. The CVM result for house connections (see left box) shows that the coefficient on this variable is not statistically significant (p-value is larger than 0.1). However, it showed that 124 households out of 125 households would pay and there is no doubt about WTP for house connections. On the other hand, the WTP for public taps was cheaper as 1,000 rupiah, and 97 households out of 125 households did not want to pay because of the above-mentioned reasons.

# (2) Baseline Survey of the Community

# 1) General description of the baseline survey

The baseline survey was conducted to collect baseline data on the socio-economic conditions in the project site. The baseline survey was contracted by a local consultant firm. The survey was conducted at nine (9) systems in eight (8) project villages in the entire project site. Only a baseline survey was carried out this time, since the more detailed socio-economic survey was conducted during the development study. The survey was to randomly cover at lease 20 households at each site as listed below.

Province	District	village	Number of Household in area to be served (2001)	No. of Samples
		Kuranji	441	20
		Bajur	1,230	30
	Lombok Barat	Sumbung	449	25
NTTD		Duman (upper)	809	25
NID		Duman (lower)	147	20
	Lombok Timur	Bagik Papan	647	25
	Lonio X Timur	Selaparang	663	25
	Sumbawa	Labuhan Mapin	634	25
NTT	Kupang	Tarus	603	20
	Total		5 622	215

Table B2-1 Number of Survey Samples (Baseline Survey)

Survey area : 9 systems in 8 project villages

# 2) Results of the baseline survey

A brief summary of the results of the baseline survey is shown in Table B2-2. The detailed results of the baseline survey were prepared for each village. In the targeted villages, households use different water sources for drinking and washing purposes. Therefore, in many cases, they do not see the quality of drinking water as a problem, but washing water is felt to be dirty. Most of the households are dissatisfied with water quantity. Especially in the dry season, many people have to walk a long distance to fetch water from a spring or river. It makes women, who have the primary responsibility for water collection, become overworked. According to the incidence rate at the health center, the incidence of water born disease is higher in the dry season. There are not sufficient amounts of water during the dry season. Many people do not like the present facilities and would prefer an improved sanitary water supply system. Most of the households (100% in Kupang, Sumbawa and Lombok Barat, and more than 80% in Lombok Timur) are willing to pay for water fees for an improved water supply system. However, the amount of the WTP was slightly lower than the result of CVM method. This is because the households were asked directly about WTP, "how

much can you pay?" without informing them about all the important aspects such as the plan of the water supply system, detailed explanations of the O&M fees and usages of expenses, and importance of health and hygiene. Therefore households will be more willing to pay water fees through a deepening understanding of the new water supply system, water fees, importance of O&M activities and hygiene. According to the World Bank's 'rule of thumb', the cost of water should not exceed 3% of total household income or expenditure. The 3% of household income and expenditure was estimated and shown in the table. Accordingly, the PDAM tariffs and the O&M costs will be financially affordable by the households.

# Table B2-2 Baseline Survey Data

Item	Unit	Kuranji	Bajur	Sumbung	Duman Upper	Duman Lower	Bagik Papan	Selaparang	Labuhan Manin	Tarus
No. of household	Person	4.05	4.7	4.68	4.92	5.05	4.6	4.84	4.92	5.35
Children : Adult		48:52	39:61	35:65	45:55	39:61	47:53	45:55	47:53	51:49
Occupation		Trading Wage la b.	Trading Agri.rice	Wage lab Agri rice	Agricultur e	Agri rice Trading	Agri lab Agri rice	Agriculture Rice	Fishery	Trading Wage lab
Cattle	% household	0	0	0	0	0	4	0	24	0
Goats / sheep	% household	0	0	0	0	0	8	12	16	0
Poetry	% household	50	30	88	64	50	56	32	32	55
Ave. hhd. Income	Rupiah/month/hhd	320,855	$537,\!628$	358,640	410,105	381,679	813,536	1,019,669	440,896	410,150
Ave. hhd. Expenditure	Rupiah/month/hhd	611,743	846,932	626,982	938,856	648,503	1,113,383	1,429,521	491,186	598,050
Water purchase	% household	5%(1/20)	3%(1/30)	4%(1/25)	28%(7/25)	5%(1/20)	28%(7/25)	52%(13/25)	44%(11/25)	20%(4/20)
Water fees	Rupiah/month/hhd	10,000	15,000	13,333	3,214	20,000	7,714	31,038	37,568	80,000
Tobacco payment	Rupiah/month/hhd	44,867	103,889	71,289	19,813	77,597	45,083	77,433	75,357	62,222
Possession rate of TV	%	35	70	60	44	40	56	56	40	100
Ave no of collection	times/day	6	5	6	6	5	4	5	11	9
Water source for Drinking		Well 65% HC 30%	Well 97% Parch. 3%	Well 76% Spring 20% PT 4%	PT 100% River user	Well 70% Spring 25% Purch 5%	PT 100%	HC 56% PT 44%	PT 48% HC 35% Well 17%	Well 65% Purch 20% River 10% HC 5%
Water source for washing		Well 10 0%	Well 10 0%	Spring 5 6% PT 24% Well 20%	PT 56% River 44%	Well45% Spring40% River15%	River 100%	River 76% HC 12% PT 12%	PT 45% HC 41% Well 9% River 5%	Well 42% River 37%
Ave. distance to water (rainy season)	meter	14m	$5 \mathrm{m}$	$5 \mathrm{m}$	68m	68m	109m	2m	172m	$195 \mathrm{m}$
Ave. distance to water (dry season)	meter	18m	6m	195m	706m	243m	116m	24m	172m	195m
Quantity of Water	Satisfaction %	0%	0%	0%	36%	0%	0%	0%	37%	100%
Quality of Water	Satisfaction %	95%	100%	100%	64%	83%	PT 100% River 0%	PT 100% River 0%	PT 0% Well 0%	82%
Needs of improved facility	Necessity %	90%	90%	88%	80%	80%	100%	100%	100%	100%
Willingness to Pay	%	80%	90%	84%	80%	78%	88%	96%	100%	100%
Amount of WTP	Rupiah/month/hhd	2,167	2,688	2,381	1,690	4,321	1,909	3,333	7,190	11,225
3% of estimated Income	Rupiah/month/hhd	9,626	16,129	10,759	12,303	11,450	24,406	30,590	13,227	12,305
3% of estimated Expenditure	Rupiah/month/hhd	18,352	25,408	18,809	28,166	19,455	33,401	42,886	14,736	17,942
Boil water before drinking	Yes %	20%	60%	52%	35%	35%	72%	84%	56%	100%

PT:Public Tap

HC:House Connection

Appendix-5.5

Distribution Network Analysis



Site: NTB 1 Kuranji

Route: Distribution Pipeline Case: Hourly Maximum HYDRAULIC CALCULATION

Hazen-Williams' formula

Node No.	d (mm)	С	q (L/s)	Q (L/s)	L (m)	V (m∕s)	I(‰)	⊿h(m)	H (m)	h(m)	he (m)	Note
PDAM Distri	bution Pipe								20.0			GL(5.0+1.5kg/cm <sup>2</sup> )
1 - 2	100	120	0.21	2.71	300	0.345	2.0	0.6	19.4	4.0	15.4	
2 - 3	100	120	0.00	2.50	45	0.318	1.7	0.1	19.3	4.0	15.3	
3 - 4	75	120	0.30	1.74	150	0.394	3.6	0.5	18.8	4.0	14.8	
4 - 5	75	120	0.03	1.37	120	0.310	2.3	0.3	18.5	5.0	13.5	
5 - 6	75	120	0.11	1.34	230	0.303	2.2	0.5	18.0	5.0	13.0	
6 - 7	75	120	0.07	1.10	190	0.249	1.5	0.3	17.7	5.5	12.2	
7 - 8	75	120	0.00	1.03	80	0.233	1.4	0.1	17.6	5.5	12.1	
8 - 9	50	120	0.20	0.63	120	0.321	3.9	0.5	17.1	5.5	11.6	
9 - 10	40	120	0.20	0.43	100	0.342	5.8	0.6	16.5	5.0	11.5	
10 11	40	120	0.23	0.23	70	0.183	1.8	0.1	16.4	5.0	11.4	
8 - 12	40	120	0.14	0.40	50	0.318	5.1	0.3	17.3	6.0	11.3	
12 - 13	30	120	0.09	0.26	70	0.368	9.2	0.6	16.7	5.5	11.2	
13 - 14	30	120	0.17	0.17	90	0.241	4.2	0.4	16.3	5.0	11.3	
6 - 15	25	120	0.13	0.13	80	0.265	6.2	0.5	17.5	5.0	12.5	
4 - 16	25	120	0.07	0.07	80	0.143	2.0	0.2	18.6	3.5	15.1	
3 - 17	40	120	0.00	0.76	75	0.605	16.6	1.2	18.1	4.0	14.1	
17 - 18	30	120	0.00	0.32	75	0.453	13.6	1.0	17.1	4.0	13.1	
18 19	25	120	0.17	0.17	40	0.346	10.2	0.4	16.7	4.0	12.7	
18 - 20	25	120	0.15	0.15	250	0.306	8.1	2.0	15.1	4.0	11.1	
17 - 21	30	120	0.12	0.44	40	0.622	24.5	1.0	17.1	4.0	13.1	
21 - 22	25	120	0.15	0.15	80	0.306	8.1	0.6	16.5	4.0	12.5	
21 - 23	25	120	0.17	0.17	140	0.346	10.2	1.4	15.7	4.0	11.7	

### Remarks:

d : Pipe diameter

- C : Flow velocity coefficient
- q : Discharge
- Q : Flow rate
- L : Length of pipeline
- V : Velocity

I : Hydraulic gradient

⊿h : Loss head

- H : Dynamic water level
- h : Ground elevation
- he : Effective head



Hazen-Williams' formula

Node No. d (mm) С a (L/s) Q (L/s) L (m) V (m/s) I(‰) /h(m)H (m) h(m) he (m) Note PDAM Distribution Pipe 55.0  $GL..15m+4.0kg/cm^2$ 0 -120 0.20 7.64 580 0.973 13.7 7.9 47.1 15.0 1 100 32.1 1 -2 100 120 0.00 7.12 90 0.907 12.0 1.1 46.0 14.0 32.0 3 2 -100 120 0.32 6.98 30 0.889 11.6 0.3 45.7 14.0 31.7 3 -100 120 0.00 6.66 50 0.848 10.6 0.5 45.2 14.5 30.7 4 5 100 120 0.22 5.34 45 0.680 0.3 44.9 15.0 29.9 4 – 7.0 75 5 -6 75 120 0.18 3.47 0.785 12.9 1.0 43.9 15.0 28.9 28.7 6 -7 75 120 0.32 2.75 20 0.622 8.4 0.2 43.7 15.0 50 7 -8 120 0.00 1.46 90 0.744 18.7 42.0 13.5 28.5 1.7 8 -9 40 120 0.09 0.61 45 0.485 11.0 0.5 41.5 13.5 28.0 10 30 0.52 50 9 – 120 0.52 0.736 33.3 1.7 39.8 13.5 26.3 2 11 25 120 0.14 0.14 60 0.285 7.1 0.4 45.6 13.0 32.6 4 – 12 40 120 0.00 1.32 45 1.050 46.0 2.1 43.1 14.5 28.6 12 -13 40 120 0.60 0.92 60 0.732 23.6 1.4 41.7 14.0 27.7 25 13 - 14 120 0.32 0.32 60 0.652 33.0 2.0 39.7 13.0 26.7 12 - 15 25 120 0.40 0.40 50 0.815 49.8 2.5 40.6 15.0 25.6 40 0.97 0.97 0.772 7 - 16 120 75 26.0 2.0 41.7 15.0 26.7 1 - 17 25 120 0.32 0.32 245 0.652 33.0 8.1 39.0 13.0 26.0 250 5 -18 50 120 0.29 1.65 55 0.840 23.4 1.3 43.6 16.0 27.6 18 -19 30 120 0.35 0.52 55 0.736 33.3 41.8 15.0 26.8 1.8 19 -20 25 41.4 27.4 120 0.17 0.17 40 0.346 10.2 0.4 14.0 18 -21 40 120 0.46 0.84 65 0.668 19.9 1.3 42.3 14.0 28.3 21 -22 25 120 0.38 0.38 60 0.774 45.3 2.7 39.6 14.0 25.6 30 120 0.54 50 42.1 6 -23 0.54 0.764 35.7 1.8 16.0 26.1 40 120 45 0.9 13.5 27.6 8 -24 0.45 0.85 0.676 20.4 41.1 25 30 24 -120 0.40 0.40 90 0.566 20.5 1.8 39.3 13.5 25.8

#### Remarks:

d : Pipe diameter

C : Flow velocity coefficient

q : Discharge

Q : Flow rate

- L : Length of pipeline
- V : Velocity

I : Hydraulic gradient

⊿h : Loss head

H : Dynamic water level

h : Ground elevation

he : Effective head

Hazen-Williams' formula

Case: Hourly Maximum

### HYDRAULIC CALCULATION

Node N	lo.	d (mm)	С	q (L/s)	Q (L/s)	L (m)	V (m/s)	I(‰)	⊿h(m)	H (m)	h(m)	he (m)	Note
PDAM D	istrik	oution Pipe								32.0			$GL+3.2 kg/cm^2$
26 -	27	40	120	0.00	1.80	3	1.432	81.6	0.2	31.8	0.0	31.8	<b>–</b>
27 -	28	25	120	0.43	0.43	50	0.876	56.9	2.8	29.0	0.0	29.0	
27 -	29	40	120	1.37	1.37	100	1.090	49.3	4.9	26.9	0.0	26.9	
					-			-					

### Remarks:

- Pipe diameter d :
- Flow velocity coefficient C :
- Discharge : q
- : Flow rate Q
- Length of pipeline : L
- V : Velocity

- I : Hydraulic gradient
- ⊿h : Loss head
- H : Dynamic water level
- h : Ground elevation
- he : Effective head

# **KUBUN BARU**

(Hourly Maximum)

DUMAN UPPER (1/6)



## Project: RURAL WATER SUPPLY IN NUSA TENGGARA BARAT AND NUSA TENGGARA TIMUR

Site: NTB 4.1 Kubun Baru

Route: Distribution Pipeline

HYDRAULIC CALCULATION

Hazen-Williams' formula

Case:	Hourly	Maximum	

Node No.	d (mm)	С	q (L/s)	Q (L/s)	L (m)	V (m∕s)	I(‰)	⊿h(m)	H (m)	h(m)	he (m)	Note
									400.0	398.0		
1 - 2	50	120	0.19	0.58	50	0.295	3.4	0.2	399.8	395.0	4.8	
2 - 3	40	120	0.19	0.39	80	0.310	4.8	0.4	399.4	385.0	14.4	
3 - 4	30	120	0.20	0.20	110	0.283	5.7	0.6	398.8	390.0	8.8	

### Remarks:

- d : Pipe diameter
- C : Flow velocity coefficient
- q : Discharge
- Q : Flow rate
- L : Length of pipeline
- V : Velocity

I : Hydraulic gradient

⊿h : Loss head

- H : Dynamic water level
- h : Ground elevation
- he : 250



### Project: RURAL WATER SUPPLY IN NUSA TENGGARA BARAT AND NUSA TENGGARA TIMUR

Site: NTB 4.2 Awang Madya

Route: Distribution Pipeline

Case: Hourly Maximum

### HYDRAULIC CALCULATION

Hazen-Williams' formula

Node No.	d (mm)	С	q (L/s)	Q (L/s)	L (m)	V (m∕s)	I(‰)	⊿h(m)	H (m)	h(m)	he (m)	Note
									363.0	398.0		
1 - 2	40	120	0.076	0.840	50	0.668	19.9	1.0	362.0	355.0	7.0	
2 - 3	40	120	0.076	0.764	120	0.608	16.7	2.0	360.0	341.0	19.0	
3 - 4	30	120	0.076	0.688	200	0.973	55.9	11.2	348.8	330.0	18.8	
4 - 5	25	120	0.000	0.612	120	1.247	109.4	13.1	335.7	320.0	15.7	BPT
									320.0			BPT
5 - 6	40	120	0.076	0.612	110	0.487	11.1	1.2	318.8	310.0	8.8	
6 - 7	25	120	0.152	0.536	210	1.092	85.6	18.0	300.8	290.0	10.8	
7 - 8	25	120	0.076	0.384	90	0.782	46.2	4.2	296.6	277.0	19.6	
8 - 9	25	120	0.076	0.308	45	0.627	30.7	1.4	295.2	282.0	13.2	
9 - 10	25	120	0.076	0.232	80	0.473	18.2	1.5	293.7	278.0	15.7	
10 - 11	25	120	0.076	0.156	140	0.318	8.7	1.2	292.5	270.0	22.5	
11 - 12	25	120	0.080	0.080	130	0.163	2.5	0.3	292.2	265.0	27.2	

### Remarks:

d : Pipe diameter

- C : Flow velocity coefficient
- q : Discharge
- Q : Flow rate
- L : Length of pipeline
- V : Velocity

- I : Hydraulic gradient
- ⊿h : Loss head
  - H : Dynamic water level
  - h : Ground elevation
- he : Effective head

# MONTONG (Hourly Maximum)

DUMAN UPPER (4/6)



### Project: RURAL WATER SUPPLY IN NUSA TENGGARA BARAT AND NUSA TENGGARA TIMUR

Site: NTB 4.3 Montong

Route: Distribution Pipeline

Case: Hourly Maximum

### HYDRAULIC CALCULATION

Hazen-Williams' formula

Node No.	d (mm)	С	q (L/s)	Q (L/s)	L (m)	V (m∕s)	I(‰)	⊿h(m)	H (m)	h(m)	he (m)	Note
									245.0	245.0		
1 - 2	40	120	0.090	1.000	50	0.796	27.5	1.4	243.6	235.0	8.6	
2 - 3	40	120	0.090	0.910	100	0.724	23.1	2.3	241.3	226.0	15.3	
3 - 4	30	120	0.090	0.820	125	1.160	77.4	9.7	231.6	220.0	11.6	
4 - 5	30	120	0.090	0.730	145	1.033	62.4	9.0	222.6	201.0	21.6	BPT
									201.0	201.0		BPT
5 - 6	40	120	0.090	0.640	120	0.509	12.0	1.4	199.6	197.0	2.6	
6 - 7	40	120	0.090	0.550	100	0.438	9.1	0.9	198.7	190.0	8.7	
7 - 8	30	120	0.090	0.460	100	0.651	26.5	2.7	196.0	183.0	13.0	
8 - 9	25	120	0.090	0.370	100	0.754	43.1	4.3	191.7	176.0	15.7	
9 - 10	25	120	0.090	0.280	100	0.570	25.8	2.6	189.1	169.0	20.1	
10 - 11	25	120	0.090	0.190	100	0.387	12.6	1.3	187.8	162.0	25.8	
11 - 12	25	120	0.100	0.100	100	0.204	3.8	0.4	187.4	155.0	32.4	

### Remarks:

- d : Pipe diameter
- C : Flow velocity coefficient
- q : Discharge
- Q : Flow rate
- L : Length of pipeline
- V : Velocity

- I : Hydraulic gradient
- ⊿h : Loss head
  - H : Dynamic water level
  - h : Ground elevation
  - he : Effective head



DUMAN UPPER (3/6)



# Project: RURAL WATER SUPPLY IN NUSA TENGGARA BARAT AND NUSA TENGGARA TIMUR

Site: NTB 4.4 Leong

Route: Distribution Pipeline Case: Hourly Maximum

### HYDRAULIC CALCULATION

Hazen-Williams' formula

Node No. d (mm) С a (L/s) Q (L/s) L (m) V (m/s) I(‰) /h(m)H (m) h(m) he (m) Note 254.0 254.0 1 -2 50 120 0.060 0.840 230 0.428 6.7 1.5 252.5 245.0 7.5 40 2 -3 120 0.070 0.780 150 0.621 17.4 2.6 249.9 236.0 13.9 30 18.0 BPT 3 -120 4 0.070 0.710 150 1.004 59.3 8.9 241.0 223.0 223.0 4 – 5 40 120 0.080 0.640 70 0.509 12.0 0.8 222.2 217.0 5.2 BPT 30 120 0.080 0.400 220.4 203.0 5 -6 0.566 20.5 90 1.8 17.4 25 6 -7 120 0.080 0.320 110 0.652 33.0 3.6 216.8 198.0 18.8 8 25 0.080 7 – 120 0.160 120 0.326 9.1 215.7 198.0 17.7 1.1 25 0.163 2.5 215.4 8 -9 120 0.080 0.080 100 0.3 196.0 19.4 5 -10 30 120 0.080 0.160 50 0.226 3.8 0.2 222.0 217.0 5.0 10 -11 25 120 0.080 0.080 130 0.163 2.5 0.3 221.7 204.0 17.7 7 - 12 25 120 0.080 0.080 130 0.163 2.5 0.3 216.5 197.0 19.5

### Remarks:

d : Pipe diameter

- C : Flow velocity coefficient
- q : Discharge
- Q : Flow rate
- L : Length of pipeline
- V : Velocity

- I : Hydraulic gradient
- ⊿h : Loss head
- H : Dynamic water level
- h : Ground elevation
- he : Effective head

# DUMAN UTARA

(Hourly Maximum)

DUMAN UPPER (5/6)



# Project: RURAL WATER SUPPLY IN NUSA TENGGARA BARAT AND NUSA TENGGARA TIMUR

Site: NTB 4.5 Duman Utara

Route: Distribution Pipeline

Case: Hourly Maximum

### HYDRAULIC CALCULATION

Hazen-Williams' formula

Node No.	d (mm)	С	q (L/s)	Q (L/s)	L (m)	V (m∕s)	I(‰)	⊿h(m)	H (m)	h(m)	he (m)	Note
									215.0	215.0		
1 - 2	40	120	0.080	0.780	180	0.621	17.4	3.1	211.9	204.0	7.9	
2 - 3	40	120	0.100	0.700	125	0.557	14.2	1.8	210.1	200.0	10.1	
3 - 4	30	120	0.100	0.600	175	0.849	43.4	7.6	202.5	180.0	22.5	
4 - 5	25	120	0.100	0.500	115	1.019	75.3	8.7	193.8	180.0	13.8	
5 - 6	25	120	0.000	0.400	60	0.815	49.8	3.0	190.8	175.0	15.8	BPT
									175.0	175.0	0.0	BPT
6 - 7	40	120	0.100	0.400	45	0.318	5.1	0.2	174.8	170.0	4.8	
7 - 8	40	120	0.100	0.300	100	0.239	3.0	0.3	174.5	165.0	9.5	
8 - 9	25	120	0.100	0.200	350	0.407	13.8	4.8	169.7	134.0	35.7	
5 - 10	25	120	0.100	0.100	100	0.204	3.8	0.4	169.3	133.0	36.3	

### Remarks:

- d : Pipe diameter
- C : Flow velocity coefficient
- q : Discharge
- Q : Flow rate
- L : Length of pipeline
- V : Velocity

- I : Hydraulic gradient
- ⊿h : Loss head
  - H : Dynamic water level
  - h : Ground elevation
- he : Effective head



# Project: RURAL WATER SUPPLY IN NUSA TENGGARA BARAT AND NUSA TENGGARA TIMUR

Site: NTB 4.6Duman Dasan & Seraya Duman

Route: Distribution Pipeline

Case: Hourly Maximum

### HYDRAULIC CALCULATION

Hazen-Williams' formula

Node No.	d (mm)	С	q (L/s)	Q (L/s)	L (m)	V (m∕s)	I(‰)	⊿h(m)	H (m)	h(m)	he (m)	Note
									120.0	120.0		
1 - 2	50	120	0.160	1.220	330	0.621	13.4	4.4	115.6	100.0	15.6	
2 - 3	30	120	0.180	0.500	40	0.707	31.0	1.2	114.4	97.0	17.4	
3 - 4	25	120	0.160	0.320	75	0.652	33.0	2.5	111.9	92.0	19.9	
4 - 5	25	120	0.080	0.160	190	0.326	9.1	1.7	110.2	81.0	29.2	
5 - 6	25	120	0.080	0.080	100	0.163	2.5	0.3	109.9	74.0	35.9	
2 - 7	50	120	0.160	0.560	40	0.285	3.2	0.1	115.5	108.0	7.5	
7 - 8	40	120	0.080	0.400	300	0.318	5.1	1.5	114.0	101.0	13.0	
8 - 9	25	120	0.080	0.320	80	0.652	33.0	2.6	111.4	95.0	16.4	
9 - 10	25	120	0.000	0.240	145	0.489	19.4	2.8	108.6	86.0	22.6	
10 - 11	25	120	0.080	0.080	90	0.163	2.5	0.2	108.4	84.0	24.4	
10 - 12	25	120	0.080	0.160	20	0.326	9.1	0.2	108.4	86.0	22.4	
12 - 13	25	120	0.080	0.080	100	0.163	2.5	0.3	108.1	86.0	22.1	

### Remarks:

- d : Pipe diameter
- C : Flow velocity coefficient
- q : Discharge
- Q : Flow rate
- L : Length of pipeline
- V : Velocity

- I : Hydraulic gradient
- ⊿h : Loss head
  - H : Dynamic water level
  - h : Ground elevation
  - he : Effective head

# **DUMAN LOWER**

(Hourly Maximum)



Site: NTB 5 Duman Lower

Route: Distribution Pipeline

Case: Hourly Maximum

### HYDRAULIC CALCULATION

Hazen-Williams' formula

Node No.	d (mm)	С	q (L/s)	Q (L/s)	L (m)	V (m/s)	I(‰)	⊿h(m)	H (m)	h(m)	he (m)	Note
Bug-Bug Re	servoir Pres	sure Release	e Tank						77.0	74.0	3.0	H.W.L
2 - 3	75	120	0.06	1.46	1800	0.330	2.6	4.7	72.3	60.0	12.3	
3 - 4	75	120	0.05	0.70	60	0.158	0.7	0.0	72.3	60.0	12.3	
4 - 5	50	120	0.00	0.48	170	0.244	2.4	0.4	71.9	59.0	12.9	
5 - 6	50	120	0.05	0.45	100	0.229	2.1	0.2	71.7	59.0	12.7	
6 - 7	40	120	0.05	0.27	50	0.215	2.4	0.1	71.6	58.5	13.1	
7 - 8	30	120	0.08	0.22	40	0.311	6.8	0.3	71.3	58.0	13.3	
8 - 9	25	120	0.08	0.11	90	0.224	4.6	0.4	70.9	57.0	13.9	
9 - 10	25	120	0.03	0.03	40	0.061	0.4	0.0	70.9	57.0	13.9	
3 - 11	50	120	0.06	0.65	50	0.331	4.2	0.2	72.1	59.0	13.1	
11 - 12	40	120	0.14	0.54	80	0.430	8.8	0.7	71.4	57.0	14.4	
12 - 13	30	120	0.29	0.29	90	0.410	11.3	1.0	70.4	57.0	13.4	
3 - 16	25	120	0.05	0.05	100	0.102	1.1	0.1	72.2	61.0	11.2	
4 - 17	30	120	0.07	0.17	80	0.241	4.2	0.3	72.0	54.0	18.0	
17 - 18	25	120	0.10	0.10	90	0.204	3.8	0.3	71.7	54.0	17.7	
5 - 19	25	120	0.03	0.03	220	0.061	0.4	0.1	71.8	61.0	10.8	
6 - 20	25	120	0.03	0.03	40	0.061	0.4	0.0	71.7	58.5	13.2	
6 - 21	25	120	0.07	0.10	250	0.204	3.8	1.0	70.7	59.0	11.7	
21 - 22	25	120	0.03	0.03	50	0.061	0.4	0.0	70.7	58.0	12.7	
8 - 23	25	120	0.03	0.03	40	0.061	0.4	0.0	71.3	58.0	13.3	
11 - 14	25	120	0.05	0.05	80	0.102	1.1	0.1	72.0	57.0	15.0	
12 - 15	25	120	0.11	0.11	70	0.224	4.6	0.3	71.1	57.0	14.1	

### Remarks:

d : Pipe diameter

C : Flow velocity coefficient

q : Discharge

Q : Flow rate

- L : Length of pipeline
- V : Velocity

- I : Hydraulic gradient
- ⊿h : Loss head
  - H : Dynamic water level
  - h : Ground elevation
  - he : Effective head

# BAGIKPAPAN (1/2)

(Hourly Maximum)



# BAGIKPAPAN (2/2)

(Hourly Maximum)



Site: NTB 6 Bagikpapan

Route: Distribution Pipeline

Case: Hourly Maximum

### HYDRAULIC CALCULATION

Hazen-Williams' formula

Node No.	d (mm)	С	q (L/s)	Q (L/s)	L (m)	V (m/s)	I(‰)	⊿h(m)	H (m)	h(m)	he (m)	Note
Reservoir									159.5			LW.L
1 - 2	75	120	0.06	4.10	20	0.928	17.5	0.4	159.1	154.0	5.1	5.5
2 - 3	75	120	0.24	4.04	60	0.914	17.1	1.0	158.1	151.0	7.1	8.5
3 - 4	75	120	0.18	3.80	90	0.860	15.2	1.4	156.7	148.0	8.7	11.5
4 - 5	75	120	0.00	3.62	330	0.819	13.9	4.6	152.1	132.0	20.1	27.5
5 - 6	75	120	0.22	2.26	65	0.512	5.8	0.4	151.7	129.0	22.7	30.5
6 - 7	75	120	0.00	2.04	25	0.462	4.8	0.1	151.6	128.0	23.6	31.5
7 - 8	75	120	0.26	1.87	60	0.423	4.1	0.2	151.4	126.0	25.4	33.5
8 - 9	75	120	0.05	1.61	390	0.364	3.1	1.2	150.2	112.0	38.2	47.5
9 - 10	75	120	0.29	1.56	460	0.353	2.9	1.3	148.9	124.0	24.9	35.5
10 - 11	50	120	0.14	1.13	100	0.576	11.6	1.2	147.7	125.0	22.7	34.5
11 - 12	50	120	0.21	0.85	25	0.433	6.9	0.2	147.5	126.0	21.5	33.5
12 - 13	40	120	0.11	0.52	150	0.414	8.2	1.2	146.3	121.0	25.3	38.5
13 - 14	30	120	0.09	0.31	60	0.439	12.8	0.8	145.5	124.0	21.5	35.5
14 - 15	25	120	0.08	0.08	120	0.163	2.5	0.3	145.2	123.0	22.2	36.5
5 - 16	75	120	0.26	1.36	650	0.308	2.3	1.5	150.6	132.0	18.6	27.5
16 - 17	50	120	0.37	1.10	110	0.560	11.1	1.2	149.4	124.0	25.4	35.5
17 - 18	40	120	0.26	0.73	50	0.581	15.4	0.8	148.6	123.0	25.6	36.5
18 19	30	120	0.47	0.47	110	0.665	27.6	3.0	145.6	121.0	24.6	38.5
7 - 20	25	120	0.17	0.17	140	0.346	10.2	1.4	150.2	125.0	25.2	34.5
10 - 21	25	120	0.14	0.14	250	0.285	7.1	1.8	147.1	121.0	26.1	38.5
11 - 22	25	120	0.14	0.14	100	0.285	7.1	0.7	147.0	121.0	26.0	38.5
12 - 23	25	120	0.12	0.12	130	0.244	5.4	0.7	146.8	125.0	21.8	34.5
13 24	25	120	0.10	0.10	50	0.204	3.8	0.2	146.1	119.0	27.1	40.5
14 - 25	25	120	0.14	0.14	80	0.285	7.1	0.6	144.9	124.5	20.4	35

## Remarks:

d : Pipe diameter

C : Flow velocity coefficient

q : Discharge

Q : Flow rate

L : Length of pipeline

V : Velocity

- I : Hydraulic gradient
- ⊿h : Loss head

H : Dynamic water level

h : Ground elevation

he : Effective head

SELAPARANG (Hourly Maximum)



Site: NTB 7 Slaparang

Route: Distribution Pipeline

Case: Hourly Maximum

### HYDRAULIC CALCULATION

Hazen-Williams' formula

Node No.	d (mm)	С	q (L/s)	Q (L/s)	L (m)	V (m/s)	I(‰)	⊿h(m)	H (m)	h(m)	he (m)	Note
Reservoir L.	W.L								165.0			Static head (m)
0 1	100	120	0.00	6.80	230	0.866	11.0	2.5	162.5	152.0	10.5	13.0
1 - 2	75	120	0.36	6.80	200	1.539	44.7	8.9	153.6	142.0	11.6	23.0
2 - 3	75	120	0.25	6.44	80	1.458	40.4	3.2	150.4	139.0	11.4	26.0
3 - 4	. 75	120	0.40	6.19	90	1.401	37.5	3.4	147.0	135.0	12.0	30.0
4 - 5	75	120	0.67	5.79	65	1.311	33.2	2.2	144.8	131.0	13.8	34.0
5 - 6	75	120	1.03	5.12	55	1.159	26.4	1.5	143.3	129.0	14.3	36.0
6 - 7	75	120	1.01	4.09	80	0.926	17.4	1.4	141.9	127.0	14.9	38.0
7 - 8	50	120	0.96	3.08	50	1.569	74.4	3.7	138.2	123.0	15.2	42.0
8 - 9	50	120	0.36	2.12	50	1.080	37.3	1.9	136.3	120.0	16.3	45.0
9 - 10	50	120	1.18	1.76	45	0.896	26.4	1.2	135.1	118.0	17.1	47.0
10 11	40	120	0.18	0.58	110	0.462	10.0	1.1	134.0	113.0	21.0	52.0
11 - 12	30	120	0.40	0.40	60	0.566	20.5	1.2	132.8	112.0	20.8	53.0

# Remarks:

- d : Pipe diameter
- C : Flow velocity coefficient
- q : Discharge
- Q : Flow rate
- L : Length of pipeline
- V : Velocity

- I : Hydraulic gradient
- ⊿h : Loss head
  - H : Dynamic water level
  - h : Ground elevation
- he : Effective head



Site: NTT 9 Tarus

Route: Distribution Pipeline

Case: Hourly Maximum

# HYDRAULIC CALCULATION

Hazen-Williams' formula

Node No.	d (mm)	С	q (L/s)	Q (L/s)	L (m)	V (m/s)	I(‰)	⊿h(m)	H (m)	h(m)	he (m)	Note
Reservoir wa	ater level								47.0			Low Water Level
0 - 1	125	120	0.25	7.87	70	0.641	4.9	0.3	46.7	40.0	6.7	
1 - 2	125	120	0.15	6.68	170	0.544	3.6	0.6	46.1	35.0	11.1	
2 - 3	125	120	0.19	6.53	70	0.532	3.4	0.2	45.9	34.0	11.9	
3 - 4	100	120	0.35	4.14	350	0.527	4.4	1.5	44.4	17.0	27.4	
4 - 5	100	120	0.32	3.79	400	0.483	3.7	1.5	42.9	13.0	29.9	
5 - 6	100	120	0.43	3.47	190	0.442	3.2	0.6	42.3	29.0	13.3	
6 - 7	100	120	0.64	3.04	180	0.387	2.5	0.5	41.8	28.0	13.8	
7 - 8	40	120	0.15	0.64	80	0.509	12.0	1.0	40.8	25.0	15.8	
8 - 9	30	120	0.13	0.49	150	0.693	29.8	4.5	36.3	20.0	16.3	
9 - 10	25	120	0.36	0.36	170	0.733	41.0	7.0	29.3	9.0	20.3	
7 - 11	100	120	0.35	1.76	220	0.224	0.9	0.2	41.6	27.0	14.6	
11 - 12	75	120	0.39	1.01	240	0.229	1.3	0.3	41.3	19.0	22.3	
12 - 13	50	120	0.42	0.42	350	0.214	1.9	0.7	40.6	30.0	10.6	
11 - 14	40	120	0.40	0.40	100	0.318	5.1	0.5	41.1	30.0	11.1	
12 - 15	40	120	0.20	0.20	350	0.159	1.4	0.5	40.8	20.0	20.8	
1 - 16	100	120	0.19	0.94	350	0.120	0.3	0.1	46.6	28.0	18.6	
16 - 17	50	120	0.19	0.19	450	0.097	0.4	0.2	46.4	36.0	10.4	
16 - 22	75	120	0.56	0.56	250	0.127	0.4	0.1	46.5	36.0	10.5	
3 - 18	75	120	0.44	2.20	170	0.498	5.5	0.9	45.0	31.0	14.0	
18 - 19	50	120	0.42	1.12	190	0.570	11.4	2.2	42.8	27.0	15.8	
19 - 20	40	120	0.70	0.70	220	0.557	14.2	3.1	39.7	19.0	20.7	
18 - 21	30	120	0.64	0.64	200	0.905	48.9	9.8	35.2	19.0	16.2	

### Remarks:

d : Pipe diameter

C : Flow velocity coefficient

q : Discharge

Q : Flow rate

L : Length of pipeline

V : Velocity

I : Hydraulic gradient

⊿h : Loss head

H : Dynamic water level

h : Ground elevation

he : Effective head