

APPENDIX B
SEWERAGE FACILITIES

Appendix B-1

Design Calculations for Sewage Treatment Plant

Appendix. B.1 CAPACITY CALCULATION OF SEWAGE TREATMENT PLANT

1 BASIC CONDITIONS

1.1 BASIC ITEMS

- (1) Name : Astana Sewage Treatment Plant
- (2) Land Area : Approximately 43 ha
- (3) Ground Level : +345.0~ +351.3 m
- (4) Inlet Pipe Invert Level : +338.2 m
- (5) Inlet Pipe Diameter : Dia 1400mm x 2
- (6) Land Use : Exiting STP
- (7) Collection System : Separate Sewer System
- (8) Treatment Method : [Sewage Treatment] Conventional Activated Sludge
[Sludge Treatment] Thickening + Digestion + Dehydration
- (9) Effluent Discharge Point : Taldy Kol Reservoir
- (10) Discharge Point Water Level : +346.8 m
- (11) Design Target Year : 2010

1.2 Design Population

Design Population : Proposed Project: 490,000 (2010)
Ultimate: 800,000 (2030)

1.3 Sewage

1.3.1 Design Sewage Flow

ITEM		m ³ /day	m ³ /hr	m ³ /min	m ³ /sec
Proposed Project	Daily Average Flow (Q ₁)	114,000 (Q _{1-D})	4,750.0 (Q _{1-H})	79.17 (Q _{1-M})	1.319 (Q _{1-S})
	Design Daily Flow (Q ₂)	136,000 (Q _{2-D})	5,666.7 (Q _{2-H})	94.44 (Q _{2-M})	1.574 (Q _{2-S})
	Design Maximum Flow (Q ₃)	200,000 (Q _{3-D})	8,333.3 (Q _{3-H})	138.89 (Q _{3-M})	2.315 (Q _{3-S})
Ultimate	Daily Average Flow (Q' ₁)	181,000	7,541.7	125.69	2.095
	Design Average Daily Flow (Q' ₂)	217,000	9,041.7	150.69	2.512
	Maximum Flow (Q' ₃)	319,000	13,291.7	221.53	3.692

[Sewage Flow Calculation]

(1) Proposed Project Flow

$$Q_{1-D} = Q_2 / 1.2^{*1)} = 113,333 \text{ m}^3/\text{day} \quad \text{adopt} \quad 114,000 \text{ m}^3/\text{day}$$

$$Q_{2-D} : \text{Design Capacity for 2010} = 136,000 \text{ m}^3/\text{day} \quad \text{adopt} \quad 136,000 \text{ m}^3/\text{day}$$

$$Q_{3-D} = Q_2 \times 1.47^{*2)} = 199,920 \text{ m}^3/\text{day} \quad \text{adopt} \quad 200,000 \text{ m}^3/\text{day}$$

*1) : Peak Factor for Drinking Water Supply System (F/S p4-4)

*2) : SNiP 2.04.03-85, p4

(2) Ultimate Flow

$$Q'_{1-D} = Q_2 / 1.2^{*1)} = 180,702 \text{ m}^3/\text{day} \quad \text{adopt} \quad 181,000 \text{ m}^3/\text{day}$$

$$Q'_{2-D} : \text{Design Capacity for 2030}^{*3)} = 216,842 \text{ m}^3/\text{day} \quad \text{adopt} \quad 217,000 \text{ m}^3/\text{day}$$


$$Q'_{3-D} = Q_2 \times 1.47^{*2)} = 318,758 \text{ m}^3/\text{day} \quad \text{adopt} \quad 319,000 \text{ m}^3/\text{day}$$

*3) : Projected Peak Day Wastewater Flow for 2030 (F/S p6-3)

1.3.2 Design Sewage Quality

ITEM	Influent (mg/L)	Primary Treatment		Secondary Treatment		Total Removal Ratio
		Removal Ratio	Effluent (mg/L)	Removal Ratio	Effluent (mg/L)	
BOD	170	30%	119	83.2%	20	88%
SS	210	40%	126	84.1%	20	90%

1.4 System Flow Chart



1.5 Design Criteria

ITEMS	UNIT	Design Criteria	Application
1.5.1 Influent Pump Station <i>calculated by Design Maximum Flow</i>			
(1) Effluent Velocity	m/sec		1.5 to 3.0
(2) Retention Time	min		5
1.5.2 Grit Chamber <i>calculated by Design Maximum Flow</i>			
(1) Hydraulic Load	m ³ /m ² /day	-	2,640
(2) Retention Time	sec	-	25
1.5.3 Primary Sedimentation Tank <i>calculated by Design Daily Flow</i>			
(1) Hydraulic Load	m ³ /m ² /day		30.0
(2) Minimum Settling Time	hour	1.5	1.5
(3) Water Depth	m	2.5 - 4.0	3.5
(4) Liquid Temperature	°C		15
(5) Weir Loading	m ³ /m/day		250
(6) Solids Recovery	%		40
(7) Sludge Water Content	%		98.0
1.5.4 Aeration Tank <i>calculated by Design Daily Flow</i>			
(1) BOD-SS Load	kg/kg/day	0.1 - 0.25	0.1 - 0.25
(2) MLSS Concentration	mg/l	1,500 - 2,000	2,000
(3) Return Sludge Ratio	%		100
(4) Water Depth	m		4.0
(5) Hydraulic Retention Time (HRT)	hour	6.0 - 8.0	8.0
1.5.5 Secondary Sedimentation Tank <i>calculated by Design Daily Flow</i>			
(1) Hydraulic Load	m ³ /m ² /day		25.0
(2) Minimum Settling Time	hour		2.0
(3) Water Depth	m		4.0
(4) Sludge Quality	mg/l		5,000
(5) Influent Sewage Temperature	degree		15
(6) Weir Loading	m ³ /m/day	691 - 864	700
(7) Sludge Water Content	%		99.5
1.5.6 Discharge Pump Station <i>calculated by Maximum Flow</i>			
(1) Effluent Velocity	m/sec		1.5 to 3.0
(2) Retention Time	min		5

ITEMS	UNIT	Design Criteria	Application
1.5.7 Gravity Thickener <i>calculated by Design Daily Flow</i>			
(1) Retention Time	hr	12 to 15	15
(2) Water Depth	m		3.5
(3) Solids Recovery	%		90
(4) Water Content	%		95.0
1.5.8 Sludge Holding Tank <i>calculated by Design Daily Flow</i>			
(1) Retention Time	hr		3
1.5.9 Mechanical Thickener <i>calculated by Design Daily Flow</i>			
(1) Solids Loading (Screw Press Type)	m ³ /hr		75
(2) Solids Recovery	%		95
(3) Water Content	%		95.0
1.5.10 Thickened Sludge Holding Tank			
(1) Retention Time	hr		3
1.5.11 Digester <i>calculated by Design Daily Flow</i>			
(1) Digestion Time	day		6
(2) Digestion Ratio	%		50
(3) Organic Ratio	%		80.0
(4) Water Content	%		97.0
1.5.12 Digested Sludge Holding Tank <i>calculated by Design Daily Flow</i>			
(1) Retention Time	hr		3
1.5.13 Sludge Dewatering Unit <i>calculated by Design Daily Flow</i>			
(1) Solids Loading (Screw Press Type)	kg/hr		450
(2) Water Content	%		80.0
(3) Sludge Recovery	%		90
1.5.14 Waste Water Tank <i>calculated by Design Daily Flow</i>			
(1) Retention Time	hr		1
1.5.15 Hopper <i>calculated by Design Daily Flow</i>			
(1) Retention Time	day		0.5
1.5.16 Treated Water Tank <i>calculated by Utility Water Flow</i>			
(1) Retention Time	min		1
1.5.17 Utility Water Tank <i>calculated by Utility Water Flow</i>			
(1) Retention Time	hr		2
1.5.18 Potable Water Tank <i>calculated by Utility Water Flow</i>			
(1) Retention Time	hr		2

1.6 Material Balance Calculation

1.6.1 Design Condition

Incoming Sewage Flow	m ³ /d	136,000
Inlet SS	mg/l	210
Outlet SS	mg/l	20
Solids Removal Efficiency of Primary Sedimentation Tank	%	40
Solids Content of Primary Sludge	%	2.0
Solids Yield Coefficient (Gross)	%	100.0
Solids Content of Waste Sludge	%	0.5
Recovery Ratio of Gravity Thickener	%	90.0
Solids Content of Gravity Thickened Sludge	%	95.0
Solids Recovery of Mechanical Thickener	%	95.0
Solids Content of Mechanically Thickened Sludge	%	5.0
Sludge Digestion Ratio	%	50.0
Feed Sludge Organic Content	%	80.0
Digestion Gas Generation per Organic Load	m ³ /kg	0.5
Solids Recovery of Sludge Dewatering	%	90.0
Water Content of Sludge Cake	%	80.0

1.6.2 Result

(1) Primary Sedimentation Tank

Primary Sludge Solids Content	%	2.0
Primary Sludge Generation (dry solid)	kg/d	12,932
Primary Sludge Volume	m ³ /d	647

(2) Secondary Sedimentation Tank

Secondary Sludge Concentration	%	0.5
Waste Sludge Generation (dry solid)	kg/d	16,612
Waste Sludge Volume	m ³ /d	3,322

(3) Gravity Thickener

Thickened Sludge Generation (dry solid)	kg/d	11,638
Thickened Sludge Volume	m ³ /d	233
Supernatant SS	kg/d	1,293
Supernatant Flow	m ³ /d	414

(4) Mechanical Thickener

Thickened Sludge Generation (dry solid)	kg/d	15,781
Thickened Sludge Quantity	m ³ /d	316
Supernatant SS	kg/d	831
Supernatant Flow	m ³ /d	3,007

(5) THICKENED MIXED SLUDGE TANK

Thickened Mixed Sludge Solids Content	%	5.0
Thickened Mixed Sludge Generation (dry solid)	kg/d	27,420
Thickened Mixed Sludge Volume	m ³ /d	548

(6) Digester

Digested Sludge Solids Content	%	3.0
Digested Sludge Generation (dry solid)	kg/d	16,452
Digested Sludge Volume	m ³ /d	548
Digestion Gas Generation	m ³ /d	10,968

(7) Dewatering Unit

Water Content of Cake	%	80.0
Sludge Cake Generation (dry solid)	kg/d	14,807
Sludge Cake Volume	m ³ /d	74
Supernatant SS	kg/d	1,645
Supernatant Flow	m ³ /d	474

(8) Inlet Condition to Primary Sedimentation Tank

Sewage Flow	m ³ /d	139,895
SS Loading	kg/d	32,329

(9) Inlet Condition to Aeration Tank


Sewage Flow	m ³ /d	139,248
SS Loading	kg/d	19,397

(10) Return from Thickener & Dewatering Units

Return Flow	m ³ /d	3,895
SS Loading	kg/d	3,769

1.7 Material Balance Flowsheet

B.1-8



2. CAPACITY CALCULATION

2.1 Influent Pump Station

2.1.1 Design Condition

(1) Design Flow

$$Q_{3-D} = 200,000 \text{ m}^3/\text{day}$$

$$Q_{3-M} = 138.9 \text{ m}^3/\text{min}$$

(2) Inlet Pipe Diameter

Dia 1,400 mm x 2

2.1.2 Design Criteria

(1) Effluent Velocity

$$v = 1.5 \text{ m/sec to } 3.0 \text{ m/sec}$$

(2) Retention Time

$$T \geq 5 \text{ min}$$

2.1.3 Capacity Calculation

ITEM	SYMBOL	DESIGN
(1) Pump		See mechanical equipment calculation
(2) Effluent Pipe		
Pipe Number	PN	3 pipes
Diameter		$146 \times \{Q_{3-M} / PN \times (1/v)\}^{1/2}$
		D = 811 mm to 574 mm
		adopt 800 mm
(3) Pump Pit		
Unit Number	UN	1 units
Required Pit Volume	V	$Q_{3-M} \times T \geq 694 \text{ m}^3$
Diameter	D	24.0 m
Depth	H	3.9 m
		(Half of volume is used for pump pit.)
<u>Check</u>		
Retention Time	T'	$(D^2 \times 3.14 / 4 \times H) / 2 / Q_{3-M} = 6.3 \text{ min}$
		More than 5 ...OK

2.2 Grit Chamber

2.2.1 Design Condition

(1) Design Flow	$Q_{3-D} =$	200,000 m ³ /day
	$Q_{3-S} =$	2.315 m ³ /sec

2.2.2 Design Criteria

(1) Hydraulic Load	$HL \leq$	2,640 m ³ /m ² /day
(2) Retention Time	$T \geq$	25 sec

2.2.3 Capacity Calculation

ITEM	SYMBOL	DESIGN
Structure		
Type		Vortex Circle Radiation-Flow Type
Required Surface Area	A	$Q_{3-D} / HL \geq$ 75.8 m ²
Channel Number	CN	2
Diameter	D	$(A / CN \times 4 / 3.14)^{1/2} =$ 6.95 m adopt 7.3 m
Depth	H	$Q_{3-S} \times T / (D^2 \times 3.14 / 4) =$ 1.38 m adopt 1.8 m
<u>Check</u>		
Hydraulic Load	HL'	$Q_{3-D} / (D^2 \times 3.14 / 4) / CN =$ 2,390 m ³ /m ² /day Less than 2,640 ...OK
Retention Time	T'	$(D^2 \times 3.14 / 4 \times H) \times CN / Q_{3-S}$ 33 sec More than 25 ...OK

2.2.4 Result

Dimension **Diameter 7.3m x Depth 1.8m x 2 chambers**

2.3 Primary Sedimentation Tank

2.3.1 Design Condition

(1) Design Flow $Q_{2-D} = 136,000 \text{ m}^3/\text{day}$

2.3.2 Design Criteria

(1) Hydraulic Load $HL \leq 30 \text{ m}^3/\text{m}^2/\text{day}$

(2) Settling Time $T \geq 1.5 \text{ hr}$

(3) Water Depth $H = 3.5 \text{ m}$

(4) Influent Sewage Temperature $TT = 15 \text{ }^\circ\text{C}$

(5) Weir Loading $WL \leq 250 \text{ m}^3/\text{m}/\text{day}$

2.3.3 Capacity Calculation

ITEM	SYMBOL	DESIGN
Structure		
Type	-	Circular Radiation-Flow Type
Tank number	TN	8 tanks
Required Surface Area	A	$Q_{2-D} / HL \geq 4,533 \text{ m}^2$
Diameter	D	$(A / TN \times 4 / 3.14)^{1/2} = 26.9 \text{ m}$ adopt 28.0 m
Water Depth	H	3.5 m
Weir Length	L	$(D - 0.6 \times 2) \times 3.14 \times TN$ $= 673.2 \text{ m}$

ITEM	SYMBOL	DESIGN
<u>Check</u>		
Hydraulic Load	HL'	$Q_{2-D} / (D^2 \times 3.14 / 4) / TN =$ <div style="float: right;">27.6 m³/m²/day</div> <div style="text-align: right;">Less than 30.0 ...OK</div>
Settling Time	T'	$TN \times D^2 \times 3.14 / 4 \times H \times 24 / Q_{2-D} =$ <div style="float: right;">3.04 hr</div> <div style="text-align: right;">More than 1.5 ...OK</div>
Weir Loading	WL'	$Q_{2-D} / L =$ <div style="float: right;">202.0 m³/m/day</div> <div style="text-align: right;">Less than 250 ...OK</div>

2.3.4 Result

Dimension

Diameter 28m x Depth 3.5m x 8 tanks

Weir Length for 1 tank : 84.2m

2.4 Aeration Tank

2.4.1 Design Condition

(1) Design Flow	$Q_{2-D} =$	136,000 m ³ /day
(2) Tank Inlet BOD	$Sc =$	119 mg/L

2.4.2 Design Criteria

(1) BOD-SS Load	$BSL =$	0.1 - 0.25 kg/kg/day
(2) MLSS Concentration	$Ca =$	2,000 mg/l
(3) Return Sludge Ratio	$R =$	100 %
(4) Water Depth	$H =$	4.0 m
(5) Hydraulic Retention Time	$HRT \geq$	8 hours

2.4.3 Capacity Calculation

ITEM	SYMBOL	DESIGN
Structure		
Treatment Method	-	Conventional Activated Sludge Process
Tank Number	TN	4 tanks
Tank Inlet Soluble BOD Quality	Scs	$Sc \times 0.67 =$ 80 mg/L
Return Sludge Concentration	Cr	5,000 mg/L
Required Volume	Vol	$Q_{2-D} \times HRT / 24 \geq$ 45,333 m ³
Water Depth	H	4.0 m
Width	W	32.0 m
Length	L	119.0 m
<u>Check</u>		
Tank Volume	V'	$W \times L \times H =$ 15,232 m ³
Return Sludge Ratio	R'	$Ca / (Cr - Ca) =$ 67 % less than 100 ...OK
Retention Time	HRT'	$(V \times TN) / Q_{2-D} \times 24 \text{ hr} =$ 10.75 hr more than 8 ...OK
BOD-SS loading	BSL'	$(Q_{2-D} \times Sc) / (V \times TN \times Ca) =$ 0.13 kg/kg/day 0.1 - 0.25 ...OK

2.4.4 Result

Dimension

Width 32m x Length 119m x Depth 4m (15232m³) x 4 tanks

2.5 Secondary Sedimentation Tank

2.5.1 Design Condition

(1) Design Flow $Q_{2-D} = 136,000 \text{ m}^3/\text{day}$

2.5.2 Design Criteria

(1) Hydraulic Load $HL \leq 25.0 \text{ m}^3/\text{m}^2/\text{day}$

(2) Settling Time $T \geq 2.0 \text{ hr}$

(3) Water Depth $H = 4.0 \text{ m}$

(4) Influent Sewage Temperature $TT = 15 \text{ }^\circ\text{C}$

(5) Weir Loading $WL \leq 700 \text{ m}^3/\text{m}/\text{day}$

2.5.3 Capacity Calculation

ITEM	SYMBOL	DESIGN
Structure		
Type	-	Circular Radiation-Flow Type
Tank number	TN	12 tanks
Required Surface Area	A	$Q_{2-D} / HL \geq 5,440 \text{ m}^2$
Diameter	D	$(A / TN \times 4 / 3.14)^{1/2} = 24.0 \text{ m}$ adopt 28.0 m
Water Depth	H	4.0 m
Weir Length	L	$(D - 0.6 \times 2) \times 3.14 \times TN$ $= 1,009.8 \text{ m}$

ITEM	SYMBOL	DESIGN
<u>Check</u>		
Hydraulic Load	HL'	$Q'_{2-D} / (D^2 \times 3.14 / 4) / TN =$ <div style="float: right;">18.4 m³/m²/day</div> <div style="text-align: right;">Less than 25.0 ...OK</div>
Settling Time	T'	$TN \times D^2 \times 3.14 / 4 \times H \times 24 / Q_{2-D} =$ <div style="float: right;">5.21 hr</div> <div style="text-align: right;">More than 2.0 ...OK</div>
Weir Loading	WL'	$Q_{2-D} / L =$ <div style="float: right;">134.7 m³/m/day</div> <div style="text-align: right;">Less than 700 ...OK</div>

2.5.4 Result

Dimension

Diameter 28m x Depth 4m x 12 tanks

Weir Length for 1 tank : 84.2m

2.6 Discharge Pump Station

2.6.1 Design Condition

(1) Design Flow

$$Q_{3-D} = 200,000 \text{ m}^3/\text{day}$$

$$Q_{3-M} = 138.9 \text{ m}^3/\text{min}$$

(2) Inlet Pipe Diameter

Dia 1,500 mm x 1

2.6.2 Design Criteria

(1) Effluent Velocity

$$v = 1.5 \text{ m/sec to } 3.0 \text{ m/sec}$$

(2) Retention Time

$$T \geq 5 \text{ min}$$

2.6.3 Capacity Calculation

ITEM	SYMBOL	DESIGN
(1) Pump		See mechanical equipment calculation
(2) Effluent Pipe Pipe Number Diameter	PN	3 pipes $146 \times \{Q_{3-M} / \text{PN} \times (1/v)\}^{1/2}$ D = 811 mm to 574 mm adopt 800 mm
(3) Pump Pit Unit Number Required Pit Volume Diameter Depth	UN V D H	1 unit $Q_{3-M} \times T \geq 694 \text{ m}^3$ 24.0 m 3.65 m (Half of volume is used for pump pit.)
<u>Check</u> Retention Time	T'	$(D^2 \times 3.14 / 4 \times H) / 2 / Q_{2-M} = 5.9 \text{ min}$ More than 5 ...OK

2.7 Sludge Thickener

2.7.1 Gravity Thickener

2.7.1.1 Design Condition

Primary Sludge

(1) Solid	S1 =	12,932 kg/day	} (From Balance Sheet)
(2) Sludge	V1 =	647 m ³ /day	
(3) Water Content	Swc =	98.0 %	

2.7.1.2 Design Criteria

(1) Retention Time	T ≥	15 hours
(2) Water Depth	H =	3.5 m
(3) Sludge Recovery	Sr =	90 %
(4) Thickened Sludge Water Content	TSwc =	95.0 %

2.7.1.3 Capacity Calculation

ITEM	SYMBOL	DESIGN
1. Primary Sludge Thickener		
Structure		
Type	-	Circular Radiation-Flow Type
Tank Number	TN	2 tanks
Required Tank Volume	Vol	$V1 / 24 \times T / TN =$ 202 m ²
Diameter	D	20.0 m
Depth	H	3.5 m
<u>Check</u>		
Retention Time	T'	$(D^2 \times 3.14 / 4 \times H \times TN) / (V1 / 24) =$ 81.6 hr More than 15 ...OK

2.7.1.4 Result

Dimension

Diameter 20m x Depth 3.5m (1099m³) x 2 tanks

2.7.2 Sludge Holding Tank

2.7.2.1 Design Condition

Waste Sludge

(1) Solid	S2 =	16,612 kg/day =	16.612 t/day
(2) Sludge	V2 =	3,322 m ³ /day	

(From Balance Sheet)

2.7.2.2 Design Criteria

(1) Retention Time	T ≥	3 hr/day
--------------------	-----	----------

2.7.2.3 Capacity Calculation

ITEM	SYMBOL	DESIGN
Waste Sludge Holding Tank		
Type	-	RC Rectangular Tank (A-Tank & B-Tank)
Required Tank Volume	Vol	$V2 \times T / 24 \geq 415.3 \text{ m}^3$
<A-Tank>		
Unit Number	UN1	1 unit
Width	W1	6.7 m
Length	L1	8.95 m
Depth	H1	4.2 m
<B-Tank>		
Unit Number	UN2	1 unit
Width	W2	6.7 m
Length	L2	9.1 m
Depth	H2	4.2 m
<u>Check</u>		
Retention Time	T'	$\{(W1 \times L1 \times H1 \times UN1) + (W2 \times L2 \times H2 \times UN2)\} / V2$ <p style="text-align: right;">= 3.7 hr</p> <p style="text-align: right;">More than 3 ...OK</p>

2.7.2.4 Result

Dimension	A-Tank	Width 6.7m x Length 8.95m x Depth 4.2m (252m ³) x 1 unit
	B-Tank	Width 6.7m x Length 9.1m x Depth 4.2m (256m ³) x 1 unit

2.7.3 Mechanical Thickener

2.7.3.1 Design Condition

Waste Sludge

(1) Solid	S2 =	16,612 kg/day =	16.612 t/day
(2) Sludge	V2 =	3,322 m ³ /day	
(3) Water Content	Swc =	99.5 %	(From Balance Sheet)

2.7.3.2 Design Criteria

(1) Solid Recovery	Sr =	95%
(2) Thickened Sludge Water Content	TSwc =	95.0 %

2.7.3.3 Capacity Calculation

ITEM	SYMBOL	DESIGN
Mechanical Thickener		
Type	-	Screw Press Thickener
Solid Loading per Unit	SL	75 m ³ /hr/unit (25m ³ /m ² /hr x 3 m ²)
Operation Time	T1	7 days/week
	T2	24 hours/day
Thickened Sludge Volume	Vol	$V2 \times (7 / T1) / T2 \geq$ 138 m ³ /hr
Unit Number	UN	$Vol / SL =$ 1.85 units therefore 2 + 1 stand-by

2.7.3.4 Result

Screw Press Thickener 75m³/hr x 3 units (including 1 stand-by)

2.8 Digester

2.8.1 Design Condition

Thickened Sludge

(1) Solid	$S5 =$	$27,420 \text{ kg/day} = 27.420 \text{ t/day}$
(2) Sludge	$V5 =$	$548 \text{ m}^3/\text{day}$
(3) Water Content	$Swc =$	95.0% (From Balance Sheet)

2.8.2 Design Criteria

(1) Digestion Time	$T1 \geq$	6.0 days
(2) Digestion Ratio for Organic Matter	$Dr =$	50%
(3) Organic Ratio	$Or =$	80%
(4) Digested Sludge Water Content	$Swc =$	97.0%

2.8.3 Capacity Calculation

ITEM	SYMBOL	DESIGN
Structure		
Type	-	Anaerobic Unheated Digestion with gas agitation
Tank Number	TN1	2 tanks
Depth	H1	8 m
Required Volume	Vol	$V5 \times T1 = 3288 \text{ m}^3$
Diameter	D1	$\{V * 4 / (TN1 \times 3.14 \times H1)\}^{1/2} = 16.18 \text{ m}$ therefore 17.0 m
<u>Check</u>		
Digestion Time	T1'	$(D1^2 \times 3.14 / 4 \times H1 \times TN1) / V5 = 6.6 \text{ days}$ More than 6 ...OK
(2) Digested Sludge Volume		
Sludge Volume (Solid)	S6	$S5 \times (100 + 100 - Or) \times Dr \times 10^{-4} = 16.452 \text{ t/day}$
Sludge Volume (Sludge)	V6	$S4 \times \{100 / (100 - Swc)\} = 548 \text{ m}^3/\text{day}$
Digestion Gas	Gv	$S5 \times Or \times Gr = 10,968 \text{ m}^3/\text{day}$ Digestion Gas Volume per Organics kg Gr = $0.5 \text{ m}^3/\text{kg}$

ITEM	SYMBOL	DESIGN
(3) Gas Holder		
Type	-	Dry Seal Type
Tank Number	TN2	2 tanks
Storage Time	T2	2 - 4 hr/day
Depth	H2	6 m
Diameter	D2	13.0 m
<hr/>		
<u>Check</u>		
Storage Time	T2'	$(D2^2 \times 3.14 / 4 \times H2 \times TN2) / GV =$ 3.5 hr Between 2 - 4 ...OK

2.8.4 Result

2.8.4.1 Digester

Dimension

Diameter 17m x Depth 8m (1815m³) x 2 tanks

2.8.4.2 Gas Holder

Dimension

Diameter 13m x Depth 6m (796m³) x 2 tanks

2.9 Sludge Dewatering Unit

2.9.1 Digested Sludge Holding Tank

2.9.1.1 Design Condition

Digester Sludge

(1) Solid $S_6 = 16,452 \text{ kg/day} = 16.452 \text{ t/day}$

(2) Sludge $V_6 = 548 \text{ m}^3/\text{day}$

(From Balance Sheet)

2.9.1.2 Design Criteria

(1) Retention Time $T_1 = 3 \text{ hr/day}$

2.9.1.3 Capacity Calculation

ITEM	SYMBOL	DESIGN
Sludge Storage Tank		
Type		RC Rectangular Tank
Operation Time	T2	7 days/week
Unit Number	UN1	2 unit
Required Tank Volume	Vol	$V_6 \times (T_1 / 24) \times (7 / T_2) = 68.5 \text{ m}^3$
Width	W	7.7 m
Length	L	3.5 m
Depth	H	2.5 m
<hr/>		
<u>Check</u>		
Retention Time	T1'	$(W \times H \times L \times UN) / (7 / T_2 \times V_6) = 5.9 \text{ hr}$ more than 3 ...OK

2.9.1.4 Result

Dimension

Width 7.7m x Length 3.5m x Depth 2.5m (67m³) x 2 unit

2.9.2 Sludge Dewatering Units

2.9.2.1 Design Condition

Digester Sludge

(1) Solid $S_6 = 16,452 \text{ kg/day} = 16.452 \text{ t/day}$

(2) Sludge $V_6 = 548 \text{ m}^3/\text{day}$

(From Balance Sheet)

2.9.2.2 Design Criteria

(1) Sludge Recovery 90 %

(2) Dewatered Sludge Water Content 20.0 %

2.9.2.3 Capacity Calculation

ITEM	SYMBOL	DESIGN
Sludge Dehydrator		
Type		Screw Press Type
Solid Loading per Unit	SL	450 kg/hr/unit
Operation Time	T1	7 days/week
	T2	24 hours/day
Sludge Dewatering Volume	Vol	$S_6 \times (7 / T1) / T2 \geq 685 \text{ kg/hr}$
Unit Number	UN	$Vol / SL = 1.52 \text{ units}$
		therefore 2 + 1 stand-by

2.9.2.4 Result

Screw Press Type 450 kg/hr x 3 units (including 1 stand-by)

2.9.3 Waste Water Tank

2.9.3.1 Design Condition

(1) Design Flow	Supernatant from Mechanical Thickener		3,007 m ³ /day
	Supernatant from Dewatering Unit		474 m ³ /day
	Chemical Dissolved Water		200 m ³ /day
	Total	V_{total} =	3,681 m³/day
(2) Operation Time	Mechanical Thickener (for V4)	T2 =	7 days/week
		T3 =	24 hours/day
	Sludge Dewatering Units (for V6)	T4 =	7 days/week
		T5 =	24 hours/day

2.9.3.2 Design Criteria

(1) Retention Time	T1 =	1 hr
--------------------	------	------

2.9.3.3 Capacity Calculation

ITEM	SYMBOL	DESIGN
Waste Water Tank		
Type		RC Rectangular Tank
Unit Number	UN	1 unit
Sludge Volume	V	3681 m ³ /day
Required Tank Volume	V _{o1}	V-total x T7 / 24 = 153 m ³
Width	W	7.7 m
Length	L	8.0 m
Depth	H	2.5 m
<hr/>		
<u>Check</u>		
Retention Time	T'	(W x L x H x UN) / V x 24 = 1.004 hr
		More than 1 ...OK

2.9.3.4 Result

Dimension **Width 7.7m x Length 8m x Depth 2.5m (154m³) x 1 unit**

2.9.4 Hopper House

2.9.4.1 Design Condition

(1) Sludge Cake Volume $V_7 = 74 \text{ m}^3/\text{day}$ (From Balance Sheet)

2.9.4.2 Design Criteria

(1) Retention Time $T = 0.5 \text{ days}$

2.9.4.3 Capacity Calculation

ITEM	SYMBOL	DESIGN
Sludge Hopper		
Type		RC Rectangular Yard
Unit Number	UN	4 unit s + 2 stand-by
Required Tank Volume	Vol	$V_7 \times T / UN$ 9.25 m ³
Width	W	3.0 m
Length	L	3.0 m
Height	H	1.7 m
Hopper Volume	V	$W \times L \times H = 15.3 \text{ adopt } 15 \text{ m}^3$
<u>Check</u>		
Retention Time	T'	$V \times UN / V_7 = 0.8 \text{ days}$ More than 0.5 ...OK

2.9.4.4 Result

Dimension

Hopper Volume 15m³ x 6units (including 2 stand-by)

2.10 Utility Water

2.10.1 Treated Water Tank

2.10.1.1 Design Condition

(1) Automatic Strainer Capacity $q = 6.2 \text{ m}^3/\text{min}$
(See Mechanical Equipment Calculation)

2.10.1.2 Design Criteria

(1) Retention Time $T \geq 1 \text{ min}$

2.10.1.3 Capacity Calculation

ITEM	SYMBOL	DESIGN
Treated Water Tank		
Type		RC Rectangular Tank
Unit Number	UN	1 unit
Required Tank Volume	Vol	$q \times T = 6.2 \text{ m}^3$
Width	W	3.6 m
Length	L	1.1 m
Depth	H	1.8 m
<u>Check</u>		
Retention Time	T'	$(W \times H \times L \times UN) / q = 1.1 \text{ min}$ More than 1 ...OK

2.10.1.4 Result

Dimension **Width 3.6m x Length 1.1m x Depth 1.8m (7m³) x 1 unit**

2.10.2 Utility Water Tank

2.10.2.1 Design Condition

(1) Filtered Water Consumption	Wash for Mechanical Thickener	0.04 x 3 units =	0.12 m ³ /min
	Wash for Dewatering Unit	0.11 x 3 units =	0.33 m ³ /min
	Total	q =	0.450 m ³ /min

2.10.2.2 Design Criteria

(1) Retention Time	T ≥	2 hr
(2) Washing Time	t ≥	8 times x 1 hr/time

2.10.2.3 Capacity Calculation

ITEM	SYMBOL	DESIGN
Filtered Water Tank		
Type		RC Rectangular Tank
Unit Number	UN	1 unit
Required Tank Volume	Vol	$q \times t \times 60 \times T / 24 =$ 18.0 m ³
Width	W	4.7 m
Length	L	3.3 m
Depth	H	4.2 m
<hr/>		
<u>Check</u>		
Retention Time	T'	$(W \times H \times L \times UN) / (q \times t \times 60) \times 24 =$ 7.2 hr
		More than 2 ...OK

2.10.2.4 Result

Dimension **Width 4.7m x Length 3.3m x Depth 4.2m (65m³) x 1 unit**

2.10.3 Potable Water Tank

2.10.3.1 Design Condition

(1) Potable Water Consumption $q = 200 \text{ m}^3/\text{day}$ (See Mechanical Equipment Calculation)

2.10.3.2 Design Criteria

(1) Retention Time $T \geq 2 \text{ hr}$

2.10.3.3 Capacity Calculation

ITEM	SYMBOL	DESIGN
Utility Water Tank		
Type		RC Rectangular Tank
Unit Number	UN	1 unit
Required Tank Volume	Vol	$q \times T / 24 = 16.7 \text{ m}^3$
Width	W	4.7 m
Length	L	3.3 m
Depth	H	4.2 m
<hr/>		
<u>Check</u>		
Retention Time	T'	$(W \times H \times L \times UN) / q \times 24 = 7.8 \text{ hr}$
		More than 2 ...OK

2.10.3.4 Result

Dimension **Width 4.7m x Length 3.3m x Depth 4.2m (65m³) x 1 unit**