




**Figure 22 Total P and phosphate at 3 stations making a gradient from Rio S.J.Meriti north of Ilha do Governador**



**Figure 23 Total P and phosphate N at 3 stations making a gradient south of Ilha do Governador**



**Figure 24** Total P and phosphate at 3 at the entrance to the Bay



**Figure 25** Simulated average total P concentrations in February 2000

## References

1. MIKE 21 Coastal Hydraulics and Oceanography, User Guide, 2001
2. MIKE 21 Environmental Hydraulics, User Guide, 2001
3. Maria Louredes San Diego-Mclone, Stephen V. Smith, Vivian F. Nicolas. Stoichiometric Interpretations of C:N:P ratios in organic waste materials. Marine Pollution Bulletin Vol. No. 4 pp 325-330, 2000.
4. Ferenc Szilagyi, Hydrobiological investigations on Guanabara Bay, RJ, Brasil. Final report (Project: BRA/90/010)
5. Henning S. Jensen, Peer B. Mortensen, Frede Ø. Andersen, Erik K. Rasmussen, Anders Jensen. Phosphorus cycling in a coastal marine sediment, Aarhus Bay, Denmark. Limnol. Oceanogr. 40(5), 1995, pp. 908-917.
6. Carbon and nutrient cycles in seabed. Report from Danish Environmental Investigations no. 42. April 2002. (in Danish)

**SUPPORTING 7**

**PLANNING BASIS**

## TABLE OF CONTENTS

	<u>Page</u>
<b>SUPPORTING 7 PLANNING BASIS</b>	
1. Population in Sewer Systems.....	7 - 1
2. Wastewater Flow Rates in Sewer District.....	7 -17

## LIST OF TABLES

Table 1	Population Forecast for Municipalities.....	7 - 2
Table 2	Population Distribution Ratio to Sewer Systems.....	7 - 3
Table 3	Population Distribution (2000).....	7 - 4
Table 4	Population Distribution (2005).....	7 - 5
Table 5	Population Distribution (2010).....	7 - 6
Table 6	Population Distribution (2015).....	7 - 7
Table 7	Population Distribution (2020).....	7 - 8
Table 8	Population Distribution Ratio to Sewer Systems of Rio de Janeiro .....	7 - 9
Table 9	Population Distribution of Rio de Janeiro in 2000 .....	7 -10
Table 10	Population of Acari Sewer District in Pavuna-Meriti Sewer System.....	7 -10
Table 11 (1/7)	Census 2000-IBGE .....	7 -11
Table 11 (2/7)	Census 2000-IBGE .....	7 -12
Table 11 (3/7)	Census 2000-IBGE .....	7 -13
Table 11 (4/7)	Census 2000-IBGE .....	7 -14
Table 11 (5/7)	Census 2000-IBGE .....	7 -15
Table 11 (6/7)	Census 2000-IBGE .....	7 -16
Table 11 (7/7)	Census 2000-IBGE .....	7 -17
Table 12	Wastewater Flow Rates (2000).....	7 -18
Table 13	Wastewater Flow Rates (2005).....	7 -19
Table 14	Wastewater Flow Rates (2010).....	7 -20
Table 15	Wastewater Flow Rates (2015).....	7 -21
Table 16	Wastewater Flow Rates (2020).....	7 -22

## **SUPPORTING 7 PLANNING BASIS**

### **(2000, 2005, 2010, 2015 AND 2020)**

The population distribution to each of the sewer systems has been estimated for the years 2000, 2005, 2010 and 2020 based upon the 2000 population census data. This appendix describes the procedures to estimate the sewer service population for sewer systems, and attaches tables for the calculation bases of population estimates.

#### **1. POPULATION IN SEWER SYSTEMS**

The 2000 population census has been conducted for the administrative units of municipality, district, sub-district and bairro in the Study Area. Out of the units, the boundaries of the units that can be identified from the available digital maps are to the district levels of municipalities and Rio de Janeiro, whereas such smaller units as sub-districts or bairros are hardly recognizable.

The sewer system area is determined in principle by topographic conditions to effectively collect and transport the wastewater to WWTP(s), thus may include two or more municipalities

In view of these, the service population of sewer system is estimated by the following procedures:

- Estimate the ratios of each administrative boundary area that topographically located within the watershed to sewer system is estimated;
- Each municipality population is distributed to sewer systems by the distribution ratios;
- The service population of a sewer system can be calculated by adding the population distributed to the sewer system; and
- The future population distribution can also be estimated by the same method.

The results of the above calculations are shown in the following tables:

Table 1	Population forecast for municipalities
Table 2	Population distribution ratio to sewer systems
Tables 3 to 7	Population distributions (2000, 2005, 2010, 2015, 2020)
Table 8	Population distribution ratio to sewer systems of Rio de Janeiro
Table 9	Population distribution of Rio de Janeiro in 2000
Table 10	Population of Acari Sewer District in Pavuna-Meriti Sewer System
Table 11(1/7) to (7/7)	Census 2000 IBGE

The small differences in the estimated population figures for municipalities between *Table 1* and *Table 10* are that *Table 1* is calculated based on those by the provisional result of the census while *Table 10* is the final census result.

The population predictions for Brazil, Rio de Janeiro, etc. are made based on the provisional results in *Table 1*. The differences between the provisional and the final results are minor and negligible for sewer population estimates, and that these are adopted in the sewer systems plan.

Tables 12 through 16 show wastewater flow rates in each sewer system in 2000, 2005, 2010, 2015 and 2020, respectively.

**Table 1 Population Forecast for Municipalities**

Municipalities	1980	1991	2000	2005	2010	2015	2020
Brazil	119,002,706	146,825,475	170,143,121	181,341,499	192,040,996	201,517,470	209,705,328
RJ State	11,291,520	12,807,706	14,367,083	15,058,809	15,716,858	16,290,907	16,785,058
Rio de Janeiro	5,090,700	5,480,768	5,851,914	5,951,178	6,057,637	6,159,998	6,247,174
Belford Roxo	282,428	360,714	433,120	472,084	510,595	539,061	563,739
Duque de Caxias	575,814	667,821	770,865	826,136	885,994	944,541	1,001,288
Guapimirim	23,188	28,001	37,940	42,748	48,983	54,156	58,107
Itaborai	95,723	139,493	187,127	216,657	242,144	261,936	278,985
Magé	143,414	163,733	205,699	233,706	262,149	282,588	300,205
Nilópolis	151,588	158,092	153,572	153,874	156,146	157,600	159,479
Niterói	397,123	436,155	458,465	467,108	479,926	493,038	505,381
Nova Iguaçu	536,550	630,384	750,487	810,564	860,565	902,732	936,191
Mesquita	125,239	142,058	164,879	173,438	182,238	190,520	198,224
São Gonçalo	615,352	779,832	889,828	951,897	1,012,976	1,069,642	1,122,453
São João de Meriti	398,826	425,772	449,229	451,929	453,746	455,240	456,704
Tanguá	18,817	23,249	26,001	26,998	28,007	30,109	30,938
Cachoeiras de Macacu	35,867	40,208	48,460	50,319	54,518	58,673	62,748
Rio Bonito	40,036	45,161	49,599	52,619	54,585	57,546	59,130
Petrópolis			286,348	295,095	303,804	311,226	317,334
Total	8,530,665	9,521,441	10,763,533	11,176,350	11,594,013	11,968,606	12,298,080

(Unit: person)

**Table 2 Population Distribution Ratio to Sewer Systems**

Sewer System	Rio de Janeiro	Belford Roxo	Duque de Caxias	Guapimirim	Itaborai	Magé	Nitópolis	Niterói	Nova Iguaçu	Mesquita	São João de Meriti	Tanguá	Cachoeiras de Macacu	Rio Bonito
To Alegria From Ipanema	0.019													
Alegria	0.213													
Penha	0.103													
Pavuna-Meriti	0.181		0.2					0.4					0.4	
Sarapuí		0.4	0.2					0.6				1.0		0.6
Bangu	0.065													
Bota		0.6									1.0			
Ignaçu			0.3											
Estreia			0.3				0.5							
Rancador					0.9		0.5							
Macacu					0.1	0.9							0.1	1.0
Guaxindiba					0.1									0.2
Alcântara									0.1				0.4	
Imboassu													0.3	
Norte-Niterói											0.4			
Sul-Niterói											0.4			
Ilha do Governador	0.036													
Paquetá	0.001													
Others (Non Sewerage)														
Out of Study Area	0.382										0.1			

**Table 3 Population Distribution (2000)**

<b>Sewer System</b>	<b>Rio de Janeiro</b>	<b>Belford Roxo</b>	<b>Duque de Caxias</b>	<b>Guapimirim</b>	<b>Itaborai</b>	<b>Magé</b>	<b>Nilópolis</b>	<b>Niterói</b>	<b>Nova Iguaçu</b>	<b>Mesquita</b>	<b>São Gonçalo</b>	<b>São João de Meriti</b>	<b>Tanguá</b>	<b>Cachoeiras de Macacu</b>	<b>Rio Bonito</b>	<b>Total</b>
To Alegria From Ipanema	109,176															109,200
Alegria	1,250,306															1,250,300
Penha	605,314															605,300
Pavuna-Meriti	1,060,353		154,173													1,455,600
Sarapuí	173,248	154,173														854,000
Bangu	378,453															378,500
Bota		259,872														1,010,400
Iguatá			231,260													231,300
Estrela			231,260					102,850								334,100
Rancador				34,146				102,850								137,000
Macacu				3,794				168,414								287,200
Guaxindiba								18,713								196,700
Alcântara										45,847						401,800
Imbóassu																266,948
Norte-Niterói																266,900
Sul-Niterói																183,400
Ilha do Governador	211,469															183,400
Paquetá	3,421															3,400
Others																98,100
Out of Study Area	2,239,412															2,285,300
Study Area	3,618,492	433,120	770,865	37,940	187,127	205,699	153,572	412,618	750,487	164,879	889,828	449,229	26,001	48,460	49,599	8,198,100
Total	5,857,904	433,120	770,865	37,940	187,127	205,699	153,572	458,465	750,487	164,879	889,828	449,229	26,001	48,460	49,599	10,483,400

(Unit: person)

**Table 4 Population Distribution (2005)**

Sewer System	Rio de Janeiro	Belford Roxo	Duque de Caxias	Guapimirim	Itaborai	Magé	Nilópolis	Niterói	Nova Iguaçu	Mesquita	São Gonçalo	São João de Meriti	Tanguá	Cachoeiras de Macacu	Rio Bonito	Total
To Alegria From Ipanema				21,700						190,400						212,100
Alegria								46,700								427,500
Penha										380,800						285,600
Pavuna-Meriti									186,800							186,800
Sarapuí									186,800							186,800
Bangu	214,800															214,800
Botá	3,600															3,600
Iguaçu																
Estrela	2,275,100							46,700								50,300
Rançador	3,675,500	472,100	826,000	42,800	216,700	233,800	153,800	420,300	810,600	173,400	952,000	452,000	27,000	50,300	52,600	102,900
Macacu	5,951,178	472,084	826,136	42,748	216,657	233,706	153,874	467,108	810,564	173,438	951,897	451,929	26,998	50,319	52,619	10881,255
Guaxindiba								21,700								212,100
Alcântara										46,700						427,500
Imbocassu																285,600
Norte-Niterói										186,800						186,800
Sul-Niterói										186,800						186,800
Ilha do Governador	214,800															214,800
Paquetá	3,600															3,600
Others																2,321,800
Out of Study Area	2,275,100									46,700						
Study Area	3,675,500	472,100	826,000	42,800	216,700	233,800	153,800	420,300	810,600	173,400	952,000	452,000	27,000	50,300	52,600	8,558,900
Total	5,951,178	472,084	826,136	42,748	216,657	233,706	153,874	467,108	810,564	173,438	951,897	451,929	26,998	50,319	52,619	10,881,255

(Unit: person)

**Table 5 Population Distribution (2010)**

<b>Sewer System</b>	<b>Rio de Janeiro</b>	<b>Belford Roxo</b>	<b>Duque de Caxias</b>	<b>Guapimirim</b>	<b>Itaborai</b>	<b>Magé</b>	<b>Nilópolis</b>	<b>Niterói</b>	<b>Nova Iguaçu</b>	<b>Mesquita</b>	<b>São Gonçalo</b>	<b>São João de Meriti</b>	<b>Tanguá</b>	<b>Cachoeiras de Macacu</b>	<b>Rio Bonito</b>	<b>Total</b>	
To Alegria From Ipanema	112,700															112,700	
Alegria	1,292,700															1,292,700	
Penha	625,800															625,800	
Pavuna-Meriti	1,096,400		177,200				62,500									1,517,600	
Sarapuí		204,200	177,200				93,700									929,500	
Bangu	391,300															391,300	
Botá		306,400							860,600							1,167,000	
Iguatá			265,800													265,800	
Estrela			265,800				131,100									396,900	
Rançador			44,100			131,100										175,200	
Macacu				4,900	217,900							101,300				352,100	
Guaxindiba						24,200						202,600				226,800	
Alcântara										48,000		405,200				453,200	
Imbocassu												303,900				303,900	
Norte-Niterói											192,000					192,000	
Sul-Niterói											192,000						192,000
Ilha do Governador	218,700																218,700
Paquetá	3,600																3,600
Others																	2,363,800
Out of Study Area	2,315,800									48,000							2,363,800
Study Area	3,741,200	510,600	886,000	49,000	242,100	262,200	156,200	432,000	860,600	182,200	1,013,000	453,700	28,000	54,500	54,600	8,925,900	
Total	6,057,637	510,595	885,994	48,983	242,144	262,149	156,146	479,926	860,565	182,238	1,012,976	453,746	28,007	54,518	54,585	11,290,209	

(Unit: person)

**Table 6 Population Distribution (2015)**

Sewer System	Rio de Janeiro	Belford Roxo	Duque de Caxias	Guapimirim	Itaborai	Magé	Nilópolis	Niterói	Nova Iguaçu	Mesquita	São Gonçalo	São João de Meriti	Tanguá	Cachoeiras de Macacu	Rio Bonito	Total
To Alegria From Ipanema	114,600															114,600
Alegria	1,314,500															1,314,500
Penha	636,300															636,300
Pavuna-Meriti	1,115,000		188,900				63,000									1,549,000
Sarapuí		215,600	188,900			94,600			190,500							962,700
Bangu	397,900															397,900
Botá		323,400						902,700								1,226,100
Iguatá			283,400													283,400
Estrela			283,400			141,300										424,700
Rançador			48,700		141,300											190,000
Macacu				5,400	235,700						107,000					378,200
Guaxindiba						26,200					213,900					240,100
Alcântara										49,300		427,900				477,200
Imbocassu												320,900				320,900
Norte-Niterói									197,200							197,200
Sul-Niterói									197,200							197,200
Ilha do Governador	222,400															222,400
Paquetá	3,700															3,700
Others																116,200
Out of Study Area	2,355,000								49,300							2,404,300
Study Area	3,804,400	539,000	944,600	54,100	261,900	282,600	157,600	443,700	902,700	190,500	1,069,700	455,200	30,100	58,700	57,500	9,252,300
Total	6,159,998	539,061	944,541	54,156	261,936	282,588	157,600	493,038	902,732	190,520	1,069,642	455,240	30,109	58,673	57,546	11,657,380

(Unit: person)

**Table 7 Population Distribution (2020)**

Sewer System	Rio de Janeiro	Belford Roxo	Duque de Caxias	Guapimirim	Itaboraí	Magé	Nilópolis	Niterói	Nova Iguaçu	Mesquita	São Gonçalo	São João de Meriti	Tanguá	Cachoeiras de Macacu	Rio Bonito	Total
To Alegria From Ipanema	109,176															109,200
Alegria	1,250,306															1,250,300
Penha	605,314															605,300
Pavuna-Meriti	1,060,353		154,173				61,429									1,455,600
Sarapuí		173,248	154,173			92,143				164,879						854,000
Bangu	378,453															378,500
Bota	259,872							750,487								1,010,400
Iguacu		231,260														231,300
Estrela		231,260				102,850										334,100
Ranecador			34,146		102,850											137,000
Macacu			3,794	168,414						88,983						287,200
Guaxindiba				18,713						177,966						196,700
Alcântara								45,847		355,931						401,800
Imbóassu										266,948						266,900
Norte-Niterói									183,386							183,400
Sul-Niterói									183,386							183,400
Ilha do Governador	211,469															211,500
Paquetá	3,421															3,400
Others																98,100
Out of Study Area	2,239,412									45,847						2,285,300
Study Area	3,618,492	433,120	770,865	37,940	187,127	205,699	153,572	412,618	750,487	164,879	889,828	449,229	26,001	48,460	49,599	8,198,100
Total	5,857,904	433,120	770,865	37,940	187,127	205,699	153,572	458,465	750,487	164,879	889,828	449,229	26,001	48,460	49,599	10,483,400

(Unit: person)

**Table 8 Population Distribution Ratio to Sewer Systems of Rio de Janeiro**

Sub-District	Alegria	Penha	Pavuna -Meriti	Bangú	To Alegria From Ipanema	Ilha do Governador	Ilha de Paquetá	Others
Anchieta			1.0					
Bangu			0.1	0.9				
Barra da Tijuca								1.0
Botafogo								1.0
Campo Grande								1.0
Centro					0.7			0.3
Cidade de Deus								1.0
Complexo do Alemão	0.9	0.1						
Copacabana								1.0
Guaratiba								1.0
Ilha de Paquetá							1.0	
Ilha do Governador						1.0		
Inhaúma	1.0							
Irajá		0.6	0.4					
Jacarepaguá			0.1					0.9
Jacarezinho								1.0
Lagoa								1.0
Madureira	0.2		0.8					
Maré	0.4	0.6						
Méier	1.0							
Pavuna			1.0					
Penha		1.0						
Portuária					1.0			
Ramos	0.4	0.6						
Realengo			1.0					
Rio Comprido	0.6				0.4			
Rocinha								1.0
Santa Cruz								1.0
Santa Teresa					0.3			0.7
São Cristovão	1.0							
Tijuca	1.0							
Vila Isabel	1.0							

**Table 9 Population Distribution of Rio de Janeiro in 2000**

Sub-District	Alegria	Penha	Pavuna -Meriti	Bangú	To Alegria From Ipanema	Ilha do Governador	Ilha de Paquetá	Others	Total
Anchieta			154,608						154,608
Bangu			42,050	378,453					420,503
Barra da Tijuca								174,353	174,353
Botafogo								238,895	238,895
Campo Grande								484,362	484,362
Centro					27,395			11,741	39,135
Cidade de Deus								38,016	38,016
Complexo do Alemão	58,523	6,503							65,026
Copacabana								161,178	161,178
Guaratiba								101,205	101,205
Ilha de Paquetá							3,421		3,421
Ilha do Governador						211,469			211,469
Inhaúma	130,635								130,635
Irajá		121,780	81,187						202,967
Jacarepaguá			46,968					422,714	469,682
Jacarezinho								36,459	36,459
Lagoa								174,062	174,062
Madureira	74,831		299,326						374,157
Maré	45,523	68,284							113,807
Méier	398,486								398,486
Pavuna			197,068						197,068
Penha		318,505							318,505
Portuária					39,973				39,973
Ramos	60,161	90,242							150,403
Realengo			239,146						239,146
Rio Comprido	44,197				29,464				73,661
Rocinha								56,338	56,338
Santa Cruz								311,289	311,289
Santa Teresia					12,344			28,802	41,145
São Cristovão	70,945								70,945
Tijuca	180,992								180,992
Vila Isabel	186,013								186,013
Total	1,250,306	605,314	1,060,353	378,453	109,176	211,469	3,421	2,239,414	5,857,904
Study Area									3,618,490

**Table 10 Population of Acari Sewer District in Pavuna-Meriti Sewer System**

Sub-District	All Population	Ratio	Population of Acari
Bangu	420,503	0.1	42,100
Madureira	374,157	0.3	112,200
Realengo	239,146	1.0	239,100
Total	1,033,806		393,400

**Table 11(1/7)      Census 2000-IBGE**

Mesorregiões, Microrregiões, Municípios, Distritos, Subdistritos e Bairros	Total	Urbana	Rural
<b>Total</b>	<b>14 391 282</b>	<b>13 821 466</b>	<b>569 816</b>
Belford Roxo	434 474	434 474	-
Belford Roxo	434 474	434 474	-
Areia Branca	112 441	112 441	-
Jardim Redentor	83 242	83 242	-
Lote XV	89 747	89 747	-
Nova Aurora	81 032	81 032	-
Parque São José	68 012	68 012	-
Bairros			
Andrade Araujo	11 678	11 678	-
Areia Branca	16 725	16 725	-
Barro Vermelho	4 283	4 283	-
Bom Pastor	18 941	18 941	-
Centro	20 368	20 368	-
Das Graças	8 600	8 600	-
Glaucia	12 648	12 648	-
Heliópolis	24 467	24 467	-
Itaipu	6 514	6 514	-
Lote XV	12 217	12 217	-
Maringá	16 486	16 486	-
Nova Aurora	14 393	14 393	-
Nova Piam	10 383	10 383	-
Parque dos Ferreiras	13 896	13 896	-
Pauline	29 307	29 307	-
Piam	13 624	13 624	-
Recantus	7 128	7 128	-
Redentor	9 247	9 247	-
Santa Amélia	12 864	12 864	-
Santa Maria	7 661	7 661	-
Santa Tereza	22 128	22 128	-
Santo Antônio da Prata	15 196	15 196	-
São Bernardo	3 195	3 195	-
São Francisco de Assis	16 612	16 612	-
São José	19 340	19 340	-
São Vicente	17 152	17 152	-
Shangri-lá	20 119	20 119	-
Vale do Ipê	20 653	20 653	-
Wona	12 383	12 383	-
Xavantes	16 266	16 266	-
Sem especificação	-	-	-
Cachoeiras de Macacu	48 543	41 117	7 426
Cachoeiras de Macacu	19 183	18 384	799
Japuiba	22 883	20 443	2 440
Subaio	6 477	2 290	4 187
Duque de Caxias	775 456	772 327	3 129
Campos Elyseos	243 767	243 767	-
Duque de Caxias	338 542	338 542	-
Imbariê	140 246	139 908	338
Xerém	52 901	50 110	2 791
Bairros			
Amapá	4 586	4 586	-
Bar dos Cavalheiros	41 636	41 636	-
Barro Branco	13 736	13 736	-
Campos Elíseos	18 558	18 558	-
Cângulo	6 263	6 263	-
Capivari	1 443	1 443	-
Centenário	21 735	21 735	-
Centro	25 025	25 025	-
Chácaras Arcampo	10 432	10 432	-
Chacaras Rio-Petrópolis	11 983	11 983	-
Cidade dos Meninos	1 464	1 464	-
Cidade Parque Paulista	27 991	27 991	-
Doutor Laureano	45 148	45 148	-
Figueira	14 436	14 436	-
Gramacho	55 460	55 460	-
Imbariê	30 482	30 482	-
Jardim Anhangá	9 061	9 061	-

**Table 11(2/7) Census 2000-IBGE**

<b>Subdistritos e Bairros</b>	<b>Total</b>	<b>Urbana</b>	<b>Rural</b>
Jardim Primavera	35 935	35 935	-
Lamarão	180	180	-
Mantiqueira	8 281	8 281	-
Meio da Serra	2 525	2 525	-
Olavo Bilac	33 951	33 951	-
Parada Angélica	14 445	14 445	-
Parada Morabi	2 497	2 497	-
Parque Duque	44 449	44 449	-
Parque Eldorado	7 180	7 180	-
Parque Fluminense	33 001	33 001	-
Parque Sarapuí	463	463	-
Periquitos	23 674	23 674	-
Pilar	24 934	24 934	-
Santa Cruz da Serra	18 704	18 704	-
Santa Lúcia	16 070	16 070	-
Santo Antônio	9 904	9 904	-
São Bento	16 550	16 550	-
Saracuruna	38 523	38 523	-
Taquara	9 568	9 568	-
Vila São José	25 786	25 786	-
Vila São Luís	31 257	31 257	-
Vinte e Cinco de Agosto	15 744	15 744	-
Xerém	19 267	19 267	-
Sem especificação	3 129	-	3 129
Guapimirim	37 952	25 593	12 359
Guapimirim	37 952	25 593	12 359
Iguaba Grande	15 089	15 089	-
Iguaba Grande	15 089	15 089	-
Itaboraí	187 479	177 260	10 219
Cabuçu	7 732	903	6 829
Itaboraí	97 960	96 454	1 506
Itambi	71 294	71 294	-
Porto das Caixas	5 553	5 244	309
Sambaetiba	4 940	3 365	1 575
Magé	205 830	193 851	11 979
Guia de Pacobaíba	19 859	19 405	454
Inhomirim	101 574	96 254	5 320
Magé	54 843	52 580	2 263
Santo Aleixo	12 109	11 801	308
Suruí	17 445	13 811	3 634
Nilópolis	153 712	153 712	-
Nilópolis	99 705	99 705	-
Olinda	54 007	54 007	-
Niterói	459 451	459 451	-
Itaipu	57 778	57 778	-
Niterói	401 673	401 673	-
Bairros			
Badu	5 289	5 289	-
Baldeador	5 107	5 107	-
Barreto	15 953	15 953	-
Boa Viagem	2 104	2 104	-
Cachoeira	3 149	3 149	-
Cafubá	3 593	3 593	-
Cambokinhas	2 863	2 863	-
Cantagalo	7 829	7 829	-
Caramujo	13 186	13 186	-
Centro	18 487	18 487	-
Charitas	6 353	6 353	-
Cubango	10 643	10 643	-
Engenho do Mato	12 219	12 219	-
Engenhoca	22 193	22 193	-
Fátima	3 767	3 767	-
Fonseca	54 984	54 984	-
Gragoatá	220	220	-
Icaraí	75 127	75 127	-
Ilha da Conceição	6 438	6 438	-
Ingá	16 592	16 592	-
Itacoatiara	1 334	1 334	-
Itaipu	17 330	17 330	-

**Table 11(3/7) Census 2000-IBGE**

<b>Subdistritos e Bairros</b>	<b>Total</b>	<b>Urbana</b>	<b>Rural</b>
Ititoca	7 642	7 642	-
Jacaré	4 154	4 154	-
Jurujuba	2 960	2 960	-
Largo da Batalha	9 043	9 043	-
Maceió	4 142	4 142	-
Maria Paula	6 049	6 049	-
Matapaca	834	834	-
Morro do Estado	3 811	3 811	-
Muriqui	989	989	-
Pé Pequeno	3 841	3 841	-
Piratininga	14 297	14 297	-
Ponta D'Areia	7 162	7 162	-
Rio do Ouro	3 579	3 579	-
Santa Bárbara	5 891	5 891	-
Santa Rosa	27 038	27 038	-
Santana	8 813	8 813	-
São Domingos	4 619	4 619	-
São Francisco	9 654	9 654	-
São Lourenço	8 209	8 209	-
Sapê	4 861	4 861	-
Tenente Jardim	2 208	2 208	-
Várzea das Moças	2 002	2 002	-
Viçoso Jardim	3 371	3 371	-
Vila Progresso	2 942	2 942	-
Viradouro	3 516	3 516	-
Vital Brasil	3 064	3 064	-
Sem especificação	-	-	-
<b>Nova Iguaçu</b>	<b>920 599</b>	<b>920 599</b>	<b>-</b>
Nova Iguaçu	920 599	920 599	-
U.R.G. de Tinguá,Adrianópolis,Rio D'Ouro e Jaceruba-URG			
XII	13 328	13 328	-
Unidade Regional de Governo Centro - URG I	175 562	175 562	-
Unidade Regional de Governo da Chatuba - URG VI	34 988	34 988	-
Unidade Regional de Governo da Posse - URG II	117 834	117 834	-
Unidade Regional de Governo de Austim - URG IX	96 199	96 199	-
Unidade Regional de Governo de Banco de Areia - URG V	45 360	45 360	-
Unidade Regional de Governo de Cabuçu - URG VII	76 350	76 350	-
Unidade Regional de Governo de Comendador Soares - URG			
III	108 614	108 614	-
Unidade Regional de Governo de Km 32 - URG VIII	57 467	57 467	-
Unidade Regional de Governo de Mesquita - URG IV	80 990	80 990	-
Unidade Regional de Governo de Miguel Couto - URG XI	50 872	50 872	-
Unidade Regional de Governo de Vila de Cava - URG X	63 035	63 035	-
<b>Bairros</b>			
Adrianópolis	3 893	3 893	-
Ambaí	5 824	5 824	-
Austin	25 445	25 445	-
Banco de Areia	15 788	15 788	-
Boa Esperança	5 207	5 207	-
Botafogo	3 984	3 984	-
Cabuçu	21 476	21 476	-
Cacuia	7 670	7 670	-
Califórnia	6 692	6 692	-
Campo Alegre	6 422	6 422	-
Caonze	6 151	6 151	-
Carlos Sampaio	5 935	5 935	-
Carmary	17 888	17 888	-
Centro	28 867	28 867	-
Chacrinha	5 017	5 017	-
Chatuba	34 944	34 944	-

**Table 11(4/7) Census 2000-IBGE**

<b>Subdistritos e Bairros</b>	<b>Total</b>	<b>Urbana</b>	<b>Rural</b>
Comendador Soares	29 428	29 428	-
Corumbá	12 902	12 902	-
Cosmorama	9 564	9 564	-
Da Cerâmica	21 664	21 664	-
Da Luz	23 005	23 005	-
Da Palhada	11 684	11 684	-
Da Posse	12 900	12 900	-
Da Prata	6 801	6 801	-
Da Viga	11 158	11 158	-
Danon	6 157	6 157	-
Edson Passos	4 787	4 787	-
Engenho Pequeno	13 114	13 114	-
Figueiras	2 397	2 397	-
Geneciano	7 423	7 423	-
Grama	9 299	9 299	-
Iguacu Velho	5 988	5 988	-
Inconfidênci	4 978	4 978	-
Ipiranga	8 132	8 132	-
Jaceruba	860	860	-
Jacutinga	11 605	11 605	-
Jardim Alvorada	12 185	12 185	-
Jardim Guandu	16 135	16 135	-
Jardim Iguacu	9 500	9 500	-
Jardim Nova Era	12 132	12 132	-
Jardim Palmares	14 311	14 311	-
Jardim Pernambuco	9 178	9 178	-
Jardim Tropical	9 604	9 604	-
Juscelino	7 848	7 848	-
Kennedy	15 371	15 371	-
Km - 32	15 316	15 316	-
Lagoinha	7 546	7 546	-
Marapicu	12 026	12 026	-
Mesquita	37 372	37 372	-
Miguel Couto	18 626	18 626	-
Montevidéu	3 876	3 876	-
Moquetá	8 318	8 318	-
Nova América	14 941	14 941	-
Ouro Verde	9 875	9 875	-
Paraíso	16 349	16 349	-
Parque Ambaí	10 317	10 317	-
Parque Flora	7 772	7 772	-
Ponto Chic	14 473	14 473	-
Prados Verdes	9 666	9 666	-
Rancho Fundo	6 003	6 003	-
Rancho Novo	6 962	6 962	-
Riachão	11 204	11 204	-
Rio D'Ouro	845	845	-
Rocha Sobrinho	8 746	8 746	-
Rodilândia	14 098	14 098	-
Rosa dos Ventos	15 348	15 348	-
Santa Eugênia	13 447	13 447	-
Santa Rita	22 587	22 587	-
Santa Terezinha	20 942	20 942	-
Santo Elias	9 221	9 221	-
Tinguá	3 803	3 803	-
Tinguazinho	10 336	10 336	-
Três Corações	3 017	3 017	-
Valverde	9 055	9 055	-
Vila de Cava	13 158	13 158	-
Vila Emil	8 229	8 229	-
Vila Guimarães	16 533	16 533	-
Vila Nova	8 091	8 091	-
Vila Operária	10 966	10 966	-
Sem especificação	222	222	-
Rio Bonito	49 691	32 450	17 241
Boa Esperança	8 576	3 550	5 026
Rio Bonito	41 115	28 900	12 215
Rio de Janeiro	5 857 904	5 857 904	-
Rio de Janeiro	5 857 904	5 857 904	-
Anchieta	154 608	154 608	-

**Table 11(5/7) Census 2000-IBGE**

<b>Subdistritos e Bairros</b>	<b>Total</b>	<b>Urbana</b>	<b>Rural</b>
Bangu	420 503	420 503	-
Barra da Tijuca	174 353	174 353	-
Botafogo	238 895	238 895	-
Campo Grande	484 362	484 362	-
Centro	39 135	39 135	-
Cidade de Deus	38 016	38 016	-
Complexo do Alemão	65 026	65 026	-
Copacabana	161 178	161 178	-
Guaratiba	101 205	101 205	-
Ilha de Paquetá	3 421	3 421	-
Ilha do Governador	211 469	211 469	-
Inhaúma	130 635	130 635	-
Irajá	202 967	202 967	-
Jacarepaguá	469 682	469 682	-
Jacarezinho	36 459	36 459	-
Lagoa	174 062	174 062	-
Madureira	374 157	374 157	-
Maré	113 807	113 807	-
Méier	398 486	398 486	-
Pavuna	197 068	197 068	-
Penha	318 505	318 505	-
Portuária	39 973	39 973	-
Ramos	150 403	150 403	-
Realengo	239 146	239 146	-
Rio Comprido	73 661	73 661	-
Rocinha	56 338	56 338	-
Santa Cruz	311 289	311 289	-
Santa Teresa	41 145	41 145	-
São Cristovão	70 945	70 945	-
Tijuca	180 992	180 992	-
Vila Isabel	186 013	186 013	-
<b>Bairros</b>			
Abolição	12 346	12 346	-
Acarí	24 650	24 650	-
Águia Santa	7 243	7 243	-
Alto da Boa Vista	8 254	8 254	-
Anchieta	53 808	53 808	-
Andaraí	38 540	38 540	-
Anil	21 551	21 551	-
Bancários	12 126	12 126	-
Bangu	244 518	244 518	-
Barra da Tijuca	92 233	92 233	-
Barra de Guaratiba	4 380	4 380	-
Barros Filho	15 223	15 223	-
Benfica	19 017	19 017	-
Bento Ribeiro	46 507	46 507	-
Bonsucesso	19 298	19 298	-
Botafogo	78 259	78 259	-
Brás de Pina	59 389	59 389	-
Cachambi	41 334	41 334	-
Cacuia	9 952	9 952	-
Caju	17 679	17 679	-
Camorim	786	786	-
Campinho	9 407	9 407	-
Campo dos Afonsos	1 515	1 515	-
Campo Grande	297 494	297 494	-
Cascadura	33 526	33 526	-
Catete	21 724	21 724	-
Catumbi	12 914	12 914	-
Cavalcanti	15 773	15 773	-
Centro	39 135	39 135	-
Cidade de Deus	38 016	38 016	-
Cidade Nova	5 282	5 282	-
Cidade Universitária	1 736	1 736	-
Cocotá	4 910	4 910	-
Coelho Neto	32 052	32 052	-
Colégio	26 488	26 488	-
Complexo do Alemão	65 026	65 026	-
Copacabana	147 021	147 021	-
Cordovil	46 533	46 533	-

**Table 11(6/7)      Census 2000-IBGE**

<b>Subdistritos e Bairros</b>	<b>Total</b>	<b>Urbana</b>	<b>Rural</b>
Cosme Velho	7 229	7 229	-
Cosmos	65 961	65 961	-
Costa Barros	25 922	25 922	-
Curicica	24 839	24 839	-
Del Castilho	14 246	14 246	-
Deodoro	11 593	11 593	-
Encantado	15 412	15 412	-
Engenheiro Leal	6 196	6 196	-
Engenho da Rainha	27 311	27 311	-
Engenho de Dentro	46 834	46 834	-
Engenho Novo	44 472	44 472	-
Estácio	20 632	20 632	-
Flamengo	53 268	53 268	-
Freguesia (Ilha do Governador)	18 371	18 371	-
Freguesia (Jacarepaguá)	54 010	54 010	-
Galeão	21 633	21 633	-
Gamboa	10 490	10 490	-
Gardênia Azul	19 268	19 268	-
Gávea	17 475	17 475	-
Glória	10 098	10 098	-
Grajaú	38 296	38 296	-
Grumari	136	136	-
Guadalupe	46 325	46 325	-
Guaratiba	87 132	87 132	-
Higienópolis	16 587	16 587	-
Honório Gurgel	22 010	22 010	-
Humaitá	15 186	15 186	-
Inhaúma	42 722	42 722	-
Inhoaíba	59 536	59 536	-
Ipanema	46 808	46 808	-
Irajá	101 859	101 859	-
Itanhangá	21 813	21 813	-
Jacaré	7 392	7 392	-
Jacarepaguá	100 822	100 822	-
Jacarezinho	36 459	36 459	-
Jardim América	25 946	25 946	-
Jardim Botânico	19 560	19 560	-
Jardim Carioca	25 202	25 202	-
Jardim Guanabara	29 886	29 886	-
Jardim Sulacap	11 221	11 221	-
Joá	971	971	-
Lagoa	18 675	18 675	-
Laranjeiras	46 381	46 381	-
Leblon	46 670	46 670	-
Leme	14 157	14 157	-
Lins de Vasconcelos	35 171	35 171	-
Madureira	51 410	51 410	-
Magalhães Bastos	24 849	24 849	-
Mangueira	13 594	13 594	-
Manguinhos	31 059	31 059	-
Maracanã	27 319	27 319	-
Maré	113 807	113 807	-
Marechal Hermes	49 186	49 186	-
Maria da Graça	8 189	8 189	-
Méier	51 344	51 344	-
Moneró	6 180	6 180	-
Olaria	62 509	62 509	-
Oswaldo Cruz	35 901	35 901	-
Paciência	83 561	83 561	-
Padre Miguel	64 754	64 754	-
Paquetá	3 421	3 421	-
Parada de Lucas	23 269	23 269	-
Parque Anchieta	27 092	27 092	-
Parque Columbia	9 194	9 194	-
Pavuna	90 027	90 027	-
Pechincha	31 615	31 615	-
Pedra de Guaratiba	9 693	9 693	-
Penha	72 692	72 692	-
Penha Circular	51 113	51 113	-
Piedade	44 111	44 111	-

**Table 11(7/7) Census 2000-IBGE**

<b>Subdistritos e Bairros</b>	<b>Total</b>	<b>Urbana</b>	<b>Rural</b>
Pilares	28 956	28 956	-
Pitangueiras	11 605	11 605	-
Portuguesa	24 733	24 733	-
Praça da Bandeira	9 102	9 102	-
Praça Seca	59 657	59 657	-
Praia da Bandeira	6 587	6 587	-
Quintino Bocaiúva	34 757	34 757	-
Ramos	37 537	37 537	-
Realengo	176 277	176 277	-
Recreio dos Bandeirantes	37 572	37 572	-
Riachuelo	13 107	13 107	-
Ribeira	3 323	3 323	-
Ricardo de Albuquerque	27 383	27 383	-
Rio Comprido	34 833	34 833	-
Rocha	9 542	9 542	-
Rocha Miranda	41 253	41 253	-
Rocinha	56 338	56 338	-
Sampaio	10 508	10 508	-
Santa Cruz	191 836	191 836	-
Santa Teresa	41 145	41 145	-
Santíssimo	34 086	34 086	-
Santo Cristo	9 618	9 618	-
São Conrado	11 155	11 155	-
São Cristóvão	38 334	38 334	-
São Francisco Xavier	7 787	7 787	-
Saúde	2 186	2 186	-
Senador Camará	111 231	111 231	-
Senador Vasconcelos	27 285	27 285	-
Sepetiba	35 892	35 892	-
Tanque	32 462	32 462	-
Taquara	93 741	93 741	-
Tauá	33 184	33 184	-
Tijuca	163 636	163 636	-
Todos os Santos	22 927	22 927	-
Tomás Coelho	21 580	21 580	-
Turiaçu	16 054	16 054	-
Urca	6 750	6 750	-
Vargem Grande	9 306	9 306	-
Vargem Pequena	11 536	11 536	-
Vaz Lobo	12 177	12 177	-
Vicente de Carvalho	24 310	24 310	-
Vidigal	13 719	13 719	-
Vigário Geral	39 563	39 563	-
Vila da Penha	24 290	24 290	-
Vila Isabel	81 858	81 858	-
Vila Kosmos	17 673	17 673	-
Vila Militar	13 691	13 691	-
Vila Valqueire	31 717	31 717	-
Vista Alegre	8 347	8 347	-
Zumbi	2 041	2 041	-
Sem especificação	-	-	-
São Gonçalo	891 119	891 119	-
Ipiuba	159 812	159 812	-
Monjolo	176 716	176 716	-
Neves	156 751	156 751	-
São Gonçalo	320 754	320 754	-
Sete Pontes	77 086	77 086	-
São João de Meriti	449 476	449 476	-
Coelho da Rocha	162 418	162 418	-
São João de Meriti	230 518	230 518	-
São Mateus	56 540	56 540	-
Tanguá	26 057	22 448	3 609
Tanguá	26 057	22 448	3 609

## 2. WASTEWATER FLOW RATES IN SEWER DISTRICT

Wastewater flow rates in sewer districts are calculated by multiplying Population and Per Capita Flow in each sewer districts.

**Table 12 Wastewater Flow Rates (2000)**

Sewer System	WWTP	Population (person)	Sewerd Ratio	Sewered -Pop (person)	Average Daily Wastewater		Max.Daily Wastewater		Max.Hourly Wastewater	
					Per Capita Flow (Lcd)	Wastewater Flow Rate (L/s)	Per Capita Flow (Lcd)	Wastewater Flow Rate (L/s)	Per Capita Flow (Lcd)	Wastewater Flow Rate (L/s)
Alegria	Alegria	1,359,500	0.173	235,200	300	817	356	969	524	1,426
Penha	Penha	605,300	0.90	544,800	235	1,482	278	1,753	407	2,566
Pavuna -Meriti	Pavuna	1,055,600	0.40	422,200	240	1,173	284	1,388	416	2,033
	Acari	400,000	0.19	76,000	240	211	284	250	416	366
	Sub-Total	1,455,600		498,200		1,384		1,638		2,399
	Sarapuí	65,300	0.90	58,800	235	160	278	189	407	277
Sarapuí	Sarapuí	788,700	0.45	354,900	240	986	284	1,167	416	1,709
	Sub-Total	854,000		413,700		1,146		1,356		1,986
Bangu	Bangu	378,500	0.00	-	240	0	284	0	416	0
Bota	Iguacu 02	111,000	0.00	-	240	0	284	0	416	0
	Madame	10,100	0.00	-	240	0	284	0	416	0
	Velhos	31,400	0.00	-	250	0	296	0	434	0
	Bota	706,100	0.00	-	255	0	302	0	443	0
	Joinville	104,900	0.00	-	220	0	260	0	380	0
	Others	46,900	0.00	-						
Iguacu	Sub-Total	1,010,400		-		0		0		0
	Xerém	9,000	0.00	-	220	0	260	0	380	0
	Campos eliseos	203,000	0.00	-	220	0	260	0	380	0
	Others	19,300	0.00	-						
Estrela	Sub-Total	231,300		-		0		0		0
	1	73,000	0.00	-	245	0	290	0	425	0
	2	111,300	0.00	-	250	0	296	0	434	0
	3	89,300	0.00	-	250	0	296	0	434	0
	4	34,800	0.00	-	245	0	290	0	425	0
	Others	25,800	0.00	-						
Roncador	Sub-Total	334,100		-		0		0		0
	1	13,500	0.00	-	220	0	260	0	380	0
	2	54,700	0.00	-	225	0	266	0	389	0
	3	15,100	0.00	-	220	0	260	0	380	0
	Others	53,700	0.00	-						
Macacu	Sub-Total	137,000		-		0		0		0
	1	64,200	0.00	-	225	0	266	0	389	0
	2	48,700	0.00	-	225	0	266	0	389	0
	3	24,700	0.00	-	225	0	266	0	389	0
	4	20,900	0.00	-	225	0	266	0	389	0
	5	28,700	0.00	-	225	0	266	0	389	0
	6	35,200	0.00	-	225	0	266	0	389	0
	7	15,200	0.00	-	225	0	266	0	389	0
	8	21,200	0.00	-	225	0	266	0	389	0
Guaxindiba	Others	28,300	0.00	-						
	Sub-Total	287,200		-		0		0		0
	1	140,700	0.00	-	225	0	266	0	389	0
	2	32,900	0.00	-	225	0	266	0	389	0
	3	10,900	0.00	-	220	0	260	0	380	0
Alcântara	Others	12,100	0.00	-						
	Sub-Total	196,700		-		0		0		0
	Trindade	140,200	0.00	-	220	0	260	0	380	0
	Alcântara	81,600	0.00	-	220	0	260	0	380	0
	Jardim Nazaré	102,500	0.00	-	220	0	260	0	380	0
Imboassu	Others	77,500	0.00	-						
	Sub-Total	401,800		-		0		0		0
	Sao Gonçalo	207,000	0.18	37,300	280	121	332	143	488	211
	Bomba	35,400	0.00	-	230	0	272	0	398	0
	Others	24,500	0.00	-						
Niteroi	Sub-Total	266,900		37,300		121		143		211
	Toque Toque	183,400	0.00	-	250	0	296	0	434	0
	Icaráf	183,400	0.90	165,100	255	487	302	577	443	847
	Sub-Total	366,800		165,100		487		577		847
Ilha do Governador	Ilha do Governador	211,500	0.90	190,400	220	485	260	573	380	837
Paquetá	Paquetá	3,400	0.90	3,100	705	25	842	30	1,253	45
Others		98,100	0.00	-						
Total		8,198,100		2,087,800		5,947		7,039		10,317

**Table 13 Wastewater Flow Rates (2005)**

Sewer System	WWTP	Population (person)	Sewerd Ratio	Sewered Population (person)	Average Daily Wastewater		Max.Daily Wastewater		Max.Hourly Wastewater	
					Per Capita Flow (Lcd)	Wastewater Flow Rate (L/s)	Per Capita Flow (Lcd)	Wastewater Flow Rate (L/s)	Per Capita Flow (Lcd)	Wastewater Flow Rate (L/s)
Alegria	Alegria	1,380,700	0.90	1,242,600	300	4,315	356	5,120	524	7,536
Penha	Penha	614,800	0.90	553,300	235	1,505	278	1,780	407	2,606
Pavuna -Meriti	Pavuna	1,076,700	0.50	538,400	240	1,496	284	1,770	416	2,592
	Acari	408,000	0.19	77,500	240	215	284	255	416	373
	Sub-Total	1,484,700		615,900		1,711		2,025		2,965
Sarapuí	Gramacho	68,100	0.90	61,300	235	167	278	197	407	289
	Sarapuí	822,800	0.65	534,800	240	1,486	284	1,758	416	2,575
	Sub-Total	890,900		596,100		1,653		1,955		2,864
Bangu	Bangu	384,400	0.00	-	240	0	284	0	416	0
Bota	Iguacu 02	120,100	0.00	-	240	0	284	0	416	0
	Madame	10,900	0.00	-	240	0	284	0	416	0
	Velhos	34,000	0.00	-	250	0	296	0	434	0
	Bota	764,400	0.00	-	255	0	302	0	443	0
	Joinville	113,500	0.00	-	220	0	260	0	380	0
	Others	51,000	0.00	-						
Iguacu	Sub-Total	1,093,900		-		0		0		0
	Xerém	9,700	0.00	-	220	0	260	0	380	0
	Campos eliseos	217,400	0.00	-	220	0	260	0	380	0
	Others	20,700	0.00	-						
	Sub-Total	247,800		-		0		0		0
Estrela	1	79,600	0.00	-	245	0	290	0	425	0
	2	121,500	0.00	-	250	0	296	0	434	0
	3	97,500	0.00	-	250	0	296	0	434	0
	4	37,900	0.00	-	245	0	290	0	425	0
	Others	28,200	0.00	-						
Roncador	Sub-Total	364,700		-		0		0		0
	1	15,300	0.00	-	220	0	260	0	380	0
	2	62,100	0.00	-	225	0	266	0	389	0
	3	17,100	0.00	-	220	0	260	0	380	0
	Others	60,900	0.00	-						
Macacu	Sub-Total	155,400		-		0		0		0
	1	71,900	0.00	-	225	0	266	0	389	0
	2	54,500	0.00	-	225	0	266	0	389	0
	3	27,700	0.00	-	225	0	266	0	389	0
	4	23,400	0.00	-	225	0	266	0	389	0
	5	32,100	0.00	-	225	0	266	0	389	0
	6	39,400	0.00	-	225	0	266	0	389	0
	7	17,000	0.00	-	225	0	266	0	389	0
	8	23,700	0.00	-	225	0	266	0	389	0
Guaxindiba	Others	31,700	0.00	-						
	Sub-Total	321,500		-		0		0		0
	1	151,700	0.00	-	225	0	266	0	389	0
	2	35,500	0.00	-	225	0	266	0	389	0
	3	11,800	0.00	-	220	0	260	0	380	0
Alcântara	Others	13,100	0.00	-						
	Sub-Total	212,100		-		0		0		0
	Trindade	149,200	0.00	-	220	0	260	0	380	0
	Alcântara	86,900	0.00	-	220	0	260	0	380	0
	Jardim Nazaré	109,000	0.00	-	220	0	260	0	380	0
Imboassu	Others	82,400	0.00	-						
	Sub-Total	427,500		-		0		0		0
	Sao Gonçalo	221,500	0.90	199,400	280	646	332	766	488	1,126
	Bomba	37,900	0.00	-	230	0	272	0	398	0
Niteroi	Others	26,200	0.00	-						
	Sub-Total	285,600		199,400		646		766		1,126
	Toque Toque	186,800	0.00	-	250	0	296	0	434	0
Ilha do Governador	Icarai	186,800	0.90	168,100	255	496	302	588	443	862
	Sub-Total	373,600		168,100		496		588		862
Paquetá	Paquetá	3,600	0.90	3,200	705	26	842	31	1,253	46
Others		102,900	0.00	-						
Total		8,558,900		3,571,900		10,978		13,008		19,097

**Table 14 Wastewater Flow Rates (2010)**

Sewer System	WWTP	Population (person)	Sewerd Ratio	Sewered Population (person)	Average Daily Wastewater		Max.Daily Wastewater		Max.Hourly Wastewater	
					Per Capita Flow (Lcd)	Wastewater Flow Rate (L/s)	Per Capita Flow (Lcd)	Wastewater Flow Rate (L/s)	Per Capita Flow (Lcd)	Wastewater Flow Rate (L/s)
Alegria	Alegria	1,405,400	0.90	1,264,900	300	4,392	356	5,212	524	7,671
Penha	Penha	625,800	0.90	563,200	235	1,532	278	1,812	407	2,653
Pavuna -Meriti	Pavuna	1,100,600	0.90	990,500	240	2,751	284	3,256	416	4,769
	Acari	417,000	0.90	375,300	240	1,043	284	1,234	416	1,807
	Sub-Total	1,517,600		1,365,800		3,794		4,490		6,576
Sarapuí	Gramacho	71,100	0.90	64,000	235	174	278	206	407	301
	Sarapuí	858,400	0.90	772,600	240	2,146	284	2,540	416	3,720
	Sub-Total	929,500		836,600		2,320		2,746		4,021
Bangu	Bangu	391,300	0.90	352,200	240	978	284	1,158	416	1,696
Bota	Iguacu 02	128,200	0.00	-	240	0	284	0	416	0
	Madame	11,700	0.00	-	240	0	284	0	416	0
	Velhos	36,200	0.00	-	250	0	296	0	434	0
	Bota	815,500	0.00	-	255	0	302	0	443	0
	Joinville	121,100	0.30	36,300	220	92	260	109	380	160
	Others	54,300	0.00	-						
Iguacu	Sub-Total	1,167,000		36,300		92		109		160
	Xerém	10,400	0.00	-	220	0	260	0	380	0
	Campos eliseos	233,200	0.00	-	220	0	260	0	380	0
	Others	22,200	0.00	-						
	Sub-Total	265,800		-		0		0		0
Estrela	1	86,700	0.00	-	245	0	290	0	425	0
	2	132,200	0.00	-	250	0	296	0	434	0
	3	106,100	0.00	-	250	0	296	0	434	0
	4	41,300	0.00	-	245	0	290	0	425	0
	Others	30,700	0.00	-						
Roncador	Sub-Total	396,900		-		0		0		0
	1	17,300	0.00	-	220	0	260	0	380	0
	2	70,000	0.00	-	225	0	266	0	389	0
	3	19,300	0.00	-	220	0	260	0	380	0
	Others	68,600	0.00	-						
Macacu	Sub-Total	175,200		-		0		0		0
	1	78,800	0.00	-	225	0	266	0	389	0
	2	59,700	0.00	-	225	0	266	0	389	0
	3	30,300	0.00	-	225	0	266	0	389	0
	4	25,600	0.00	-	225	0	266	0	389	0
	5	35,200	0.00	-	225	0	266	0	389	0
	6	43,200	0.00	-	225	0	266	0	389	0
	7	18,600	0.00	-	225	0	266	0	389	0
	8	26,000	0.00	-	225	0	266	0	389	0
Guaxindiba	Others	34,700	0.00	-						
	Sub-Total	352,100		-		0		0		0
	1	162,300	0.00	-	225	0	266	0	389	0
	2	38,000	0.00	-	225	0	266	0	389	0
	3	12,600	0.00	-	220	0	260	0	380	0
Alcântara	Others	14,000	0.00	-						
	Sub-Total	226,800		-		0		0		0
	Trindade	158,100	0.00	-	220	0	260	0	380	0
	Alcântara	92,100	0.00	-	220	0	260	0	380	0
	Jardim Nazaré	115,600	0.00	-	220	0	260	0	380	0
Imboassu	Others	87,400	0.00	-						
	Sub-Total	453,200		-		0		0		0
	Sao Gonçalo	235,700	0.90	212,100	280	687	332	815	488	1,198
	Bomba	40,300	0.00	-	230	0	272	0	398	0
Niteroi	Others	27,900	0.00	-						
	Sub-Total	303,900		212,100		687		815		1,198
	Toque Toque	192,000	0.00	-	250	0	296	0	434	0
Ilha do Governador	Icarai	192,000	0.90	172,800	255	510	302	604	443	886
	Sub-Total	384,000		172,800		510		604		886
Ilha do Governador	Ilha do Governador	218,700	0.90	196,800	280	638	332	756	488	1,112
Paquetá	Paquetá	3,600	0.90	3,200	705	26	842	31	1,253	46
Others		109,100	0.00	-						
Total		8,925,900		5,003,900		14,969		17,733		26,019

**Table 15 Wastewater Flow Rates (2015)**

Sewer System	WWTP	Population (person)	Sewerd Ratio	Sewered Population (person)	Average Daily Wastewater		Max.Daily Wastewater		Max.Hourly Wastewater	
					Per Capita Flow (Lcd)	Wastewater Flow Rate (L/s)	Per Capita Flow (Lcd)	Wastewater Flow Rate (L/s)	Per Capita Flow (Lcd)	Wastewater Flow Rate (L/s)
Alegria	Alegria	1,429,100	0.90	1,286,200	300	4,466	356	5,300	524	7,801
Penha	Penha	636,300	0.90	572,700	235	1,558	278	1,843	407	2,698
Pavuna -Meriti	Pavuna	1,123,300	0.90	1,011,000	240	2,808	284	3,323	416	4,868
	Acari	425,700	0.90	383,100	240	1,064	284	1,259	416	1,845
	Sub-Total	1,549,000		1,394,100		3,872		4,582		6,713
Sarapuí	Gramacho	73,600	0.90	66,200	235	180	278	213	407	312
	Sarapuí	889,100	0.90	800,200	240	2,223	284	2,630	416	3,853
	Sub-Total	962,700		866,400		2,403		2,843		4,165
Bangu	Bangu	397,900	0.90	358,100	240	995	284	1,177	416	1,724
Bota	Iguacu 02	134,700	0.00	-	240	0	284	0	416	0
	Madame	12,300	0.00	-	240	0	284	0	416	0
	Velhos	38,100	0.00	-	250	0	296	0	434	0
	Bota	856,800	0.00	-	255	0	302	0	443	0
	Joinville	127,300	0.30	38,200	220	97	260	115	380	168
	Others	56,900	0.00	-						
Iguacu	Sub-Total	1,226,100		38,200		97		115		168
	Xerém	11,000	0.00	-	220	0	260	0	380	0
	Campos eliseos	248,700	0.00	-	220	0	260	0	380	0
	Others	23,700	0.00	-						
	Sub-Total	283,400		-		0		0		0
Estrela	1	92,700	0.00	-	245	0	290	0	425	0
	2	141,500	0.00	-	250	0	296	0	434	0
	3	113,500	0.00	-	250	0	296	0	434	0
	4	44,200	0.00	-	245	0	290	0	425	0
	Others	32,800	0.00	-						
	Sub-Total	424,700		-		0		0		0
Roncador	1	18,700	0.00	-	220	0	260	0	380	0
	2	75,900	0.00	-	225	0	266	0	389	0
	3	20,900	0.00	-	220	0	260	0	380	0
	Others	74,400	0.00	-						
	Sub-Total	190,000		-		0		0		0
Macacu	1	84,600	0.00	-	225	0	266	0	389	0
	2	64,200	0.00	-	225	0	266	0	389	0
	3	32,600	0.00	-	225	0	266	0	389	0
	4	27,500	0.00	-	225	0	266	0	389	0
	5	37,800	0.00	-	225	0	266	0	389	0
	6	46,300	0.00	-	225	0	266	0	389	0
	7	20,000	0.00	-	225	0	266	0	389	0
	8	27,900	0.00	-	225	0	266	0	389	0
	Others	37,300	0.00	-						
Guaxindiba	Sub-Total	378,200		-		0		0		0
	1	171,800	0.00	-	225	0	266	0	389	0
	2	40,200	0.00	-	225	0	266	0	389	0
	3	13,300	0.00	-	220	0	260	0	380	0
	Others	14,800	0.00	-						
Alcântara	Sub-Total	240,100		-		0		0		0
	Trindade	166,500	0.00	-	220	0	260	0	380	0
	Alcântara	97,000	0.00	-	220	0	260	0	380	0
	Jardim Nazaré	121,700	0.00	-	220	0	260	0	380	0
	Others	92,000	0.00	-						
	Sub-Total	477,200		-		0		0		0
Imboassu	Sao Gonçalo	248,800	0.90	223,900	280	726	332	860	488	1,265
	Bomba	42,600	0.00	-	230	0	272	0	398	0
	Others	29,500	0.00	-						
	Sub-Total	320,900		223,900		726		860		1,265
Niteroi	Toque Toque	197,200	0.00	-	250	0	296	0	434	0
	Icarai	197,200	0.90	177,500	255	524	302	620	443	910
	Sub-Total	394,400		177,500		524		620		910
Ilha do Governador	Ilha do Governador	222,400	0.90	200,200	280	649	332	769	488	1,131
Paquetá	Paquetá	3,700	0.90	3,300	705	27	842	32	1,253	48
Others		116,200	0.00	-						
Total		9,252,300		5,120,600		15,317		18,141		26,623

**Table 16 Wastewater Flow Rates (2020)**

Sewer System	WWTP	Population (person)	Sewerd Ratio	Sewered Population (person)	Average Daily Wastewater		Max.Daily Wastewater		Max.Hourly Wastewater	
					Per Capita Flow (Lcd)	Wastewater Flow Rate (L/s)	Per Capita Flow (Lcd)	Wastewater Flow Rate (L/s)	Per Capita Flow (Lcd)	Wastewater Flow Rate (L/s)
Alegria	Alegria	1,449,300	0.9	1,304,400	300	4,529	356	5,375	524	7,911
Penha	Penha	645,300	0.9	580,800	235	1,580	278	1,869	407	2,736
Pavuna-Meriti	Pavuna	1,144,000	0.9	1,029,600	240	2,860	284	3,384	416	4,957
	Acari	433,500	0.9	390,200	240	1,084	284	1,283	416	1,879
	Sub-Total	1,577,500		1,419,800		3,944		4,667		6,836
Sarapuí	Gramacho	76,000	0.9	68,400	235	186	278	220	407	322
	Sarapuí	917,700	0.9	825,900	240	2,294	284	2,715	416	3,977
	Sub-Total	993,700		894,300		2,480		2,935		4,299
Bangu	Bangu	403,600	0.9	363,200	240	1,009	284	1,194	416	1,749
Bota	Iguacu 02	140,000	0.9	126,000	240	350	284	414	416	607
	Madame	12,700	0.9	11,400	240	32	284	37	416	55
	Velhos	39,600	0.9	35,600	250	103	296	122	434	179
	Bota	890,600	0.9	801,500	255	2,366	302	2,802	443	4,110
	Joinville	132,300	0.9	119,100	220	303	260	358	380	524
	Others	59,200	0.0	-						
Iguaçu	Sub-Total	1,274,400		1,093,600		3,154		3,733		5,475
	Xerém	11,700	0.9	10,500	220	27	260	32	380	46
	Campos eliseos	263,600	0.9	237,200	220	604	260	714	380	1,043
	Others	25,100	0.0	-						
	Sub-Total	300,400		247,700		631		746		1,089
Estrela	1	98,400	0.0	-	245	0	290	0	425	0
	2	150,100	0.0	-	250	0	296	0	434	0
	3	120,400	0.0	-	250	0	296	0	434	0
	4	46,900	0.0	-	245	0	290	0	425	0
	Others	34,800	0.0	-						
Roncador	Sub-Total	450,500		-		0		0		0
	1	19,900	0.0	-	220	0	260	0	380	0
	2	80,900	0.0	-	225	0	266	0	389	0
	3	22,300	0.0	-	220	0	260	0	380	0
	Others	79,300	0.0	-						
Macacu	Sub-Total	202,400		-		0		0		0
	1	89,500	0.0	-	225	0	266	0	389	0
	2	67,900	0.0	-	225	0	266	0	389	0
	3	34,500	0.0	-	225	0	266	0	389	0
	4	29,100	0.0	-	225	0	266	0	389	0
	5	40,000	0.0	-	225	0	266	0	389	0
	6	49,000	0.0	-	225	0	266	0	389	0
	7	21,100	0.0	-	225	0	266	0	389	0
	8	29,500	0.0	-	225	0	266	0	389	0
Guaxindiba	Others	39,400	0.0	-						
	Sub-Total	400,000		-		0		0		0
	1	180,600	0.0	-	225	0	266	0	389	0
	2	42,200	0.0	-	225	0	266	0	389	0
	3	14,000	0.0	-	220	0	260	0	380	0
Alcântara	Others	15,500	0.0	-						
	Sub-Total	252,400		-		0		0		0
	Trindade	174,300	0.9	156,900	220	400	260	472	380	690
	Alcântara	101,500	0.9	91,400	220	233	260	275	380	402
	Jardim Nazaré	127,400	0.9	114,700	220	292	260	345	380	504
Imboassu	Others	96,300	0.0	-						
	Sub-Total	499,500		363,000		925		1,092		1,596
	Sao Gonçalo	261,100	0.9	235,000	280	762	332	903	488	1,327
	Bomba	44,700	0.9	40,200	230	107	272	127	398	185
Niteroi	Others	30,900	0.0	-						
	Sub-Total	336,700		275,200		869		1,030		1,512
	Toque Toque	202,200	0.0	-	250	0	296	0	434	0
Ilha do Governador	Icaraí	202,200	0.9	182,000	255	537	302	636	443	933
	Sub-Total	404,400		182,000		537		636		933
	Ilha do Governador	225,500	0.9	203,000	280	658	332	780	488	1,147
Paquetá	Paquetá	3,700	0.9	3,300	705	27	842	32	1,253	48
	Others	121,800	0.0	-						
Total		9,541,100		6,930,300		20,343		24,089		35,331

**SUPPORTING 8**

**FACILITY PLANNING AND DESIGN**

## TABLE OF CONTENTS

	<u>Page</u>
<b>SUPPORTING 8     FACILITY PLANNING AND DESIGN</b>	
1. Trunk Sewer Hydraulic Calculation .....	8 - 1
1.1 Pavuna Sewer District.....	8 - 1
1.2 Acari Sewer District.....	8 -17
1.3 Sarapui Sewer District .....	8 -36
1.4 Bangu Sewer District.....	8 -41
2. WWTP Design Calculation .....	8 -56
2.1 Pavuna WWTP .....	8 -56
2.2 Acari Sewer District.....	8 -64
2.3 Sarapui WWTP.....	8 -77
2.4 Bangu WWTP.....	8 -85

## LIST OF TABLE

Table 1	Trunk Sewer Hydraulic Calculation of Pavuna Sewer District .....	8 - 2
Table 2	Trunk Sewer Hydraulic Calculation of Acari Sewer District .....	8 -18
Table 3	Trunk Sewer Hydraulic Calculation of Sarapui Sewer District.....	8 -37
Table 4	Trunk Sewer Hydraulic Calculation of Bangu Sewer District.....	8 -42
Table 5	Specifications of Inlet Pumps .....	8 -56
Table 6	Specifications of Grit Chambers.....	8 -57
Table 7	Specifications of Chemical Feed System.....	8 -57
Table 8	Specifications of Sludge Pumps.....	8 -57
Table 9	List of Primary Treatment Equipment .....	8 -58
Table 10	Specifications of Intermediate Pumps.....	8 -58
Table 11	Specifications of Blowers .....	8 -59
Table 12	Specifications of Aeration Tanks .....	8 -59
Table 13	Specifications of Sludge Pumps.....	8 -60
Table 14	List of Secondary Treatment Equipment .....	8 -60
Table 15	List of Sludge Treatment Equipment .....	8 -62
Table 16	List of Primary Treatment Equipment .....	8 -65
Table 17	List of Secondary Treatment Equipment .....	8 -68
Table 18	List of Sludge Treatment Equipment .....	8 -71
Table 19	Specifications of Inlet Pumps .....	8 -77
Table 20	Specifications of Grit Chambers.....	8 -77
Table 21	Specifications of Chemical Feed System.....	8 -78
Table 22	Specifications of Primary Sludge Pumps.....	8 -78
Table 23	List of Primary Treatment Equipment .....	8 -79
Table 24	Specifications of Intermediate Pumps.....	8 -79
Table 25	Specifications of Blowers .....	8 -80
Table 26	Specifications of Aeration Tanks .....	8 -80
Table 27	Specifications of Sludge Pumps.....	8 -81
Table 28	List of Secondary Treatment Equipment .....	8 -81

Table 29	List of Sludge Treatment Equipment .....	8 -83
Table 30	List of Primary Treatment Equipment .....	8 -86
Table 31	List of Secondary Treatment Equipment .....	8 -89
Table 32	List of Sludge Treatment Equipment .....	8 -92

### **LIST OF FIGURE**

Figure 1	Mass Balance of Pavuna WWTP.....	8 -63
Figure 2	Solids - Concentration Curve .....	8 -73
Figure 3	Mass Balance of Acari WWTP.....	8 -76
Figure 4	Mass Balance of Sarapui WWTP .....	8 -84
Figure 5	Solids - Concentration Curve .....	8 -94
Figure 6	Mass Balance of Bangu WWTP .....	8 -97

## **SUPPORTING 8 FACILITY PLANNING AND DESIGN**

### **1. TRUNK SEWER HYDRAULIC CALCULATION**

#### **1.1 PAVUNA SEWER DISTRICT**

Trunk Sewer Hydraulic Calculation of Pavuna Sewer District is shown in *Table 1* (1/15 - 15/15).

**Table 1 (1/15) Trunk Sewer Hydraulic Calculation of Pavuna Sewer District**

PAVUNA SEWERAGE DISTRICT TRUNK SEWER HYDRAULIC CONCEPT DESIGN No. 1 TRUNK SEWER											
JICA manhole	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s) initial	downstream flow (l/s) final	diam. (mm)	slope (m/m)	ground level (m)	trunk sewer level (m)	trunk sewer depth (m)	cota NA final (m)
									upstream	upstream	initial
									downstream	downstream	final
1	o	82.506	110.00	37.09	37.09	400	0.0025	13.00	11.00	2.00	11.21
2	o	-	47.78	47.78	400	13.00	10.72	-	2.28	10.93	0.51
2	o	110.00	37.09	37.09	400	13.00	10.72	-	2.28	10.93	0.44
3	j	-	47.78	47.78	400	13.00	10.44	-	2.56	10.65	0.51
3	j	110.00	37.09	38.22	500	13.00	10.34	2.66	10.58	0.41	1.09
4	j	-	47.78	47.78	500	13.00	10.051	-	3.22	10.02	0.47
4	j	83.22	83.22	-	500	13.00	9.78	3.22	10.02	0.41	1.16
5	j	-	107.20	107.20	500	12.00	9.42	-	2.58	9.66	0.47
5	j	150.00	83.22	83.22	500	12.00	9.42	2.58	9.66	0.41	1.08
6	j	-	107.20	107.20	500	12.00	8.66	-	3.34	8.90	0.47
6	j	150.00	83.22	83.22	500	12.00	8.66	3.34	8.90	0.41	1.16
7	j	-	107.20	107.20	500	12.00	7.90	-	4.10	8.14	0.47
7	j	140.32	140.32	-	500	12.00	7.90	4.10	8.14	0.47	1.16
8	j	127.000	70.00	180.75	180.75	500	11.00	7.54	-	3.46	7.87
8	j	-	140.32	140.32	500	11.00	7.54	3.46	7.87	0.56	1.16
9	j	110.00	180.75	180.75	500	11.00	7.54	-	3.46	7.87	0.56
9	o	150.00	140.32	-	500	11.00	9.00	6.98	2.02	7.31	0.67
10	j	-	180.75	180.75	500	11.00	9.00	6.98	2.02	7.34	0.61
10	j	150.00	140.32	-	500	11.00	9.00	6.38	2.62	6.74	0.61
11	j	-	180.75	180.75	500	11.00	9.00	5.78	3.22	6.14	0.73
11	j	150.00	140.32	-	500	11.00	9.00	5.78	3.22	6.14	0.61
12	j	-	180.75	180.75	500	11.00	9.00	5.18	2.82	5.54	0.73
12	o	150.00	140.32	-	500	11.00	9.00	5.18	2.82	5.54	0.61
13	j	-	180.75	180.75	500	11.00	9.00	4.58	2.42	4.94	0.73
13	j	29.596	140.00	153.63	500	11.00	9.00	4.58	2.42	4.95	0.62
14	j	-	197.89	197.89	500	11.00	9.00	-	3.05	4.32	0.74
14	j	150.00	153.63	-	900	11.00	9.00	3.55	3.45	4.05	0.47
15	j	-	197.89	197.89	900	11.00	9.0005	-	3.48	3.52	0.55
15	j	150.00	153.63	-	900	11.00	9.0005	-	3.48	3.52	0.47
16	j	-	197.89	197.89	900	11.00	9.00	3.41	5.59	3.91	0.55

**Table 1 (2/15) Trunk Sewer Hydraulic Calculation of Pavuna Sewer District**

manhole no / j	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s)	downstream flow (l/s)	diam. (mm)	slope (m/m)	ground level (m)	trunk sewer depth (m)	cota NA final (m)	b/d (m/m)	initial V <sub>initial</sub> (m/s)	final V <sub>final</sub> (m/s)	velocity (m/s)	critical velocity V <sub>c</sub> (m/s)	Page Notes: entrance flow (l/s):
								initial	upstream	upstream	upstream					
								final	downstream	downstream	downstream					
16	j	80.331	150.00	189.75	189.75	1200	0.0005	9.00	3.11	5.89	3.59	0.35	0.54	-	1.06	9.52
17	j	150.00	244.41	244.41	189.75	189.75	-	8.00	3.04	4.96	3.52	0.40	0.57	-	-	36.117 46.522
17	j	-	244.41	-	1200	0.0005	-	8.00	3.04	4.96	3.52	0.35	0.54	-	-	9.52
18	j	150.00	244.41	244.41	189.75	189.75	-	8.00	2.98	5.02	3.46	0.40	0.57	-	-	9.52
18	j	-	244.41	-	1200	0.0005	-	8.00	2.98	5.02	3.46	0.35	0.54	-	-	9.52
19	j	150.00	244.41	244.41	189.75	189.75	-	8.00	2.91	5.09	3.39	0.40	0.57	-	-	9.52
19	j	80.00	-	-	1200	0.0005	8.00	2.91	5.09	3.39	0.35	0.54	-	-	-	9.52
20	j	130.00	244.41	244.41	189.75	189.75	-	8.00	2.87	5.13	3.35	0.40	0.57	-	-	9.52
20	j	-	244.41	-	1200	0.0005	-	8.00	2.87	5.13	3.35	0.35	0.54	-	-	9.52
21	j	150.00	244.41	244.41	189.75	189.75	-	8.00	2.81	5.19	3.29	0.40	0.57	-	-	9.52
21	j	-	244.41	-	1200	0.0005	8.00	2.81	5.19	3.29	0.35	0.54	-	-	-	9.52
22	j	150.00	244.41	244.41	189.75	189.75	-	8.00	2.75	5.26	3.22	0.40	0.57	-	-	9.52
22	j	-	244.41	-	1200	0.0005	-	8.00	2.75	5.26	3.22	0.35	0.54	-	-	9.52
23	j	110.00	244.41	244.41	189.75	189.75	-	9.00	2.68	6.32	3.16	0.40	0.57	-	-	9.52
23	j	-	244.41	-	1200	0.0005	-	9.00	2.68	6.32	3.16	0.35	0.54	-	-	9.52
24	j	50.00	244.41	244.41	189.75	268.74	-	9.00	2.63	6.37	3.11	0.40	0.57	-	-	9.52
24	j	-	244.41	-	1200	0.0004	9.00	2.63	6.37	3.25	0.45	0.54	-	-	-	9.52
25	j	100.00	268.74	268.74	346.16	346.16	-	9.00	2.61	6.39	3.24	0.52	0.58	-	-	10.43
25	j	-	268.74	-	1200	0.0004	-	9.00	2.61	6.39	3.24	0.45	0.54	-	-	10.43
26	j	100.00	346.16	346.16	268.74	268.74	-	9.00	2.57	6.43	3.20	0.52	0.58	-	-	10.43
26	j	-	346.16	-	1200	0.0004	-	9.00	2.57	6.43	3.20	0.45	0.54	-	-	10.43
27	j	150.00	346.16	346.16	268.74	268.74	-	9.00	2.54	6.46	3.16	0.52	0.58	-	-	10.43
27	j	-	346.16	-	1200	0.0004	-	9.00	2.54	6.46	3.16	0.45	0.54	-	-	10.43
28	j	150.00	346.16	346.16	268.74	268.74	-	9.00	2.48	6.52	3.11	0.52	0.58	-	-	10.43
28	j	-	346.16	-	1200	0.0004	-	9.00	2.48	6.52	3.11	0.45	0.54	-	-	10.43
29	j	150.00	346.16	346.16	268.74	268.74	-	9.00	2.44	6.56	3.07	0.52	0.58	-	-	10.43
29	j	-	346.16	-	1200	0.0004	-	9.00	2.44	6.56	3.06	0.45	0.54	-	-	10.43
30	j	150.00	303.53	303.53	390.98	390.98	-	9.00	2.38	6.62	3.01	0.52	0.58	-	-	10.44
30	j	-	303.53	-	1200	0.0004	-	9.00	2.33	6.67	3.01	0.48	0.55	-	-	10.44
31	j	150.00	303.53	303.53	390.98	390.98	-	9.00	2.28	5.72	2.96	0.57	0.59	-	-	10.70
31	j	-	303.53	-	1200	0.0004	-	8.00	2.28	5.72	2.96	0.57	0.59	-	-	10.70
32	j	150.00	390.98	390.98	-	-	-	-	-	-	-	-	-	-	-	34.798 44.823

**Table 1 (3/15) Trunk Sewer Hydraulic Calculation of Pavuna Sewer District**

manhole	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s)	downstream flow (l/s)	diam. (mm)	slope (m/m)	ground level (m)	trunk sewer level (m)	trunk sewer depth (m)	cota NA final (m)	h/d (m/m)	velocity (m/s)	critical velocity Vc (m/s)	Page Notes: entrance flow (l/s): 3
								initial	upstream	upstream	initial	V <sub>initial</sub>			
								final	downstream	downstream	final	V <sub>final</sub>			
32	j		150.00	303.53	303.53	1200	0.0004	8.00	-	2.28	5.72	2.96	0.48	0.55	
33	j		130.00	303.53	303.53	1200	0.0004	8.00	2.22	5.78	2.91	0.57	0.59	0.57	
34	j		150.00	390.98	390.98	1200	0.0004	8.00	2.22	5.78	2.89	0.47	-	-	10.63
34	j	114.261	150.00	354.90	354.90	1200	0.0004	8.00	2.18	5.83	2.84	0.56	0.61	-	
35	j		150.00	457.15	457.15	1200	0.0004	9.00	2.12	6.88	2.88	0.63	0.61	1.10	10.99
35	j		150.00	354.90	354.90	1200	0.0004	9.00	2.12	6.88	2.88	0.53	0.58	-	51.371 66.172
36	j		150.00	457.15	457.15	1200	0.0004	9.00	2.07	6.93	2.83	0.63	0.61	-	
36	j		150.00	354.90	354.90	1200	0.0004	9.00	2.07	6.93	2.83	0.53	0.58	-	
37	j		150.00	457.15	457.15	1200	0.0004	9.00	2.02	6.98	2.78	0.63	0.61	-	
37	j		150.00	354.90	354.90	1200	0.0004	9.00	2.02	6.98	2.78	0.53	0.58	-	
38	j		80.00	457.15	457.15	1200	0.0004	7.00	1.96	5.04	2.72	0.63	0.61	-	
38	j		80.00	354.90	354.90	1200	0.0004	7.00	1.96	5.04	2.72	0.54	0.57	-	
39	j		70.00	457.15	457.15	1200	0.0004	7.00	1.94	5.07	2.70	0.63	0.61	-	
39	j		70.00	354.90	354.90	1200	0.0004	7.00	1.94	5.07	2.69	0.53	0.58	-	
40	j		86.786	50.00	507.41	1200	0.0004	7.00	1.91	5.09	2.67	0.63	0.62	-	
40	j		86.786	50.00	507.41	1200	0.0004	7.00	1.91	5.09	2.72	0.57	0.60	-	
41	j		102.998	70.00	440.23	1200	0.0004	7.00	1.89	5.11	2.70	0.68	0.63	-	1.17 50.260
41	j		102.998	567.06	567.06	1200	0.0004	5.93	1.87	4.07	2.75	0.74	0.64	-	1.20 46.307
TC 116															59.649
TOTAL															

manhole	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s)	downstream flow (l/s)	diam. (mm)	slope (m/m)	ground level (m)	trunk sewer level (m)	trunk sewer depth (m)	cota NA final (m)	h/d (m/m)	velocity (m/s)	critical velocity Vc (m/s)	Page Notes: entrance flow (l/s): 3
								initial	upstream	upstream	initial	V <sub>initial</sub>			
								final	downstream	downstream	final	V <sub>final</sub>			
3.1	o	102.604	140.00	46.13	46.13	400	0.0020	13.00	-	2.00	11.26	-	0.66	0.70	6.37 46.130
3.2	o		140.00	46.13	46.13	400	0.0020	13.00	10.72	2.28	10.98	0.64	-	0.70	59.421
3 (No. 1 TS)				59.42	59.42			13.00	10.72	2.28	10.98	0.54	0.66	-	2.10 6.37
TOTAL			280.00										2.56		

**Table 1 (4/15) Trunk Sewer Hydraulic Calculation of Pavuna Sewer District**

PAVUNA SEWERAGE DISTRICT No. 1-2 TRUNK SEWER											
JICA manhole	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s) initial	downstream flow (l/s) final	diam. (mm)	slope (m/m)	ground level (m)	trunk sewer level (m)	cota NA final (m)	h/d (m/m)
									upstream	upstream	
									downstream	downstream	
24.1	o	91.690	150.00	41.22	41.22	400	0.0020	17.00	14.80	2.20	15.04
24.2	o	53.10	53.10	-	-	400	0.0020	18.00	14.50	-	-
24.2	o	100.00	41.22	41.22	400	0.0250	-	18.00	14.50	3.50	14.74
24.3	o	53.10	53.10	-	-	400	0.0020	14.00	12.00	-	-
24.3	o	150.00	53.10	41.22	400	0.0082	-	14.00	12.00	2.00	12.12
24.4	o	53.10	53.10	-	-	400	0.0082	13.00	10.77	-	-
24.4	o	100.00	41.22	41.22	400	0.0082	-	13.00	10.77	2.23	10.93
24.5	o	53.10	53.10	-	-	400	0.0082	12.00	9.95	-	-
24.5	o	130.00	53.10	41.22	400	0.0082	-	12.00	9.95	2.05	10.11
24.6	o	110.00	53.10	41.22	400	0.0082	-	11.00	8.89	-	-
24.6	o	84.000	150.00	78.99	78.99	400	0.0082	10.00	7.99	2.01	9.05
24.7	o	101.74	101.74	-	-	400	0.0082	10.00	7.99	-	-
24.8	o	70.00	101.74	78.99	78.99	400	0.0082	9.00	6.76	2.24	6.99
24.9	o	100.00	101.74	101.74	101.74	400	0.0082	9.00	6.76	2.24	6.99
24(No. 1 TS)	TOTAL			1,060.00							

PAVUNA SEWERAGE DISTRICT No. 2 TRUNK SEWER											
JICA manhole	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s) initial	downstream flow (l/s) final	diam. (mm)	slope (m/m)	ground level (m)	trunk sewer level (m)	cota NA final (m)	h/d (m/m)
									upstream	upstream	
									downstream	downstream	
1	j	136.071	80.00	61.18	61.18	500	0.0070	18.00	15.50	2.50	16.29
2	j	78.80	78.80	-	-	500	0.0070	20.00	15.44	4.56	16.17
2	j	150.00	61.18	61.18	500	0.0070	-	20.00	15.44	-	16.17
3	j	78.80	78.80	-	-	500	0.0070	18.00	15.34	2.66	15.95

## Table 1 (5/15) Trunk Sewer Hydraulic Calculation of Pavuna Sewer District

11	0	27,976	110,00	12,58	112,35	19,00	16,90	2,10	17,18	0,36	0,93	3,74	7,30	12,578
12		-	16,20	144,72	700	0,0027	-	2,40	16,88	0,40	0,99	-	-	16,202
12	0	90,00	-	112,35	112,35	19,00	16,60	2,40	16,88	0,36	0,92	-	-	
13	0	144,72	-	700	0,0027	-	-	-	-	-	-	3,67	7,31	
13	0	50,00	-	112,35	112,35	19,00	16,36	2,64	16,64	0,41	0,98	-	-	
14	0	144,72	-	700	0,0028	-	-	-	16,64	0,35	0,93	-	-	
14	0	120,00	-	112,35	112,35	19,00	16,22	2,78	16,50	0,40	1,00	-	-	
15	0	144,72	-	700	0,0027	-	-	2,78	16,50	0,36	0,92	-	-	
15	0	60,00	-	112,35	112,35	18,00	15,90	2,10	16,18	0,41	0,98	-	-	
16	0	144,72	-	700	0,0027	-	-	-	16,18	0,36	0,92	-	-	
16	0	60,00	-	112,35	112,35	18,00	15,74	2,26	16,02	0,41	0,98	-	-	
17	0	144,72	-	700	0,0027	-	-	-	16,02	0,36	0,92	-	-	
17	0	140,00	-	112,35	112,35	18,00	15,58	2,42	15,86	0,41	0,98	-	-	
18	0	144,72	-	700	0,0027	-	-	2,42	15,86	0,36	0,92	-	-	

**Table 1 (6/15) Trunk Sewer Hydraulic Calculation of Pavuna Sewer District**

manhole no / j	Construction Method o / j	Area (ha)	length (m)	upstream		downstream		slope (m/m)	diam. (mm)	ground level (m)		trunk sewer level (m)		cota NA final (m)	h/d (m/m)	velocity (m/s)	trative tension (Pa)	critical velocity $V_c$ (m/s)	Page Notes: entrance flow (l/s):		
				initial	final	initial	final			upstream	downstream	upstream	downstream								
18	0	52.606	150.00	136.00	136.00	700	700	0.0027	-	17.80	17.80	14.80	14.80	3.00	15.12	0.45	1.03	3.94	7.59	23.651	
19	0	150.00	175.19	136.00	136.00	-	700	0.0137	-	17.80	-	-	-	15.00	0.26	1.73	-	-	3.0465		
19	0	150.00	175.19	136.00	136.00	-	700	0.0137	-	15.00	12.75	2.25	12.75	2.25	12.95	0.29	1.86	-	-	14.32	6.40
20	0	150.00	175.19	136.00	136.00	-	700	0.0137	-	15.00	12.75	2.25	12.75	2.25	12.95	0.26	1.73	-	-	14.32	6.40
21	0	160.43	175.19	160.43	160.43	-	700	0.0013	-	12.80	12.80	10.70	10.70	2.10	10.90	0.29	1.86	-	-	11.14	5.53
21	0	54.333	150.00	206.65	206.65	-	700	0.0013	-	12.80	12.80	10.50	10.50	2.30	10.94	0.62	0.83	-	-	2.41	8.36
22	0	150.00	160.43	160.43	160.43	-	700	0.0013	-	12.80	12.80	10.50	10.50	2.30	10.94	0.54	0.76	-	-	10.54	24.428
22	0	150.00	206.65	206.65	206.65	-	700	0.0013	-	12.80	10.31	2.49	10.31	2.49	10.75	0.54	0.76	-	-	31.466	
23	0	150.00	206.65	160.43	160.43	-	700	0.0013	-	12.80	12.80	10.12	10.12	2.68	10.56	0.64	0.81	-	-	2.31	8.40
23	0	40.00	160.43	160.43	160.43	-	700	0.0013	-	12.80	12.80	10.07	10.07	2.68	10.57	0.54	0.76	-	-	10.54	24.428
24	0	40.00	206.65	206.65	206.65	-	700	0.0013	-	12.80	12.80	10.07	10.07	2.73	10.51	0.53	0.77	-	-	2.31	8.40
24	0	100.00	206.65	160.43	160.43	-	700	0.0013	-	12.80	12.80	9.94	9.94	2.86	10.38	0.63	0.82	-	-	2.29	8.41
25	0	74.818	150.00	249.98	249.98	-	700	0.0013	-	12.80	12.80	9.94	9.94	2.86	10.45	0.61	0.80	-	-	2.31	8.40
25	0	150.00	194.07	194.07	194.07	-	700	0.0084	-	11.00	8.49	2.51	8.49	2.51	8.77	0.35	1.62	-	-	11.45	7.27
26	0	140.00	249.98	249.98	249.98	-	700	0.0084	-	11.00	8.49	2.51	8.49	2.51	8.77	0.35	1.62	-	-	11.45	7.27
27	0	70.00	194.07	194.07	194.07	-	700	0.0084	-	11.00	8.49	2.51	8.49	2.51	8.77	0.35	1.62	-	-	11.48	7.27
27	0	100.00	249.98	249.98	249.98	-	900	0.0048	-	10.00	7.01	2.99	7.01	2.99	8.18	0.40	1.73	-	-	7.02	7.68
28	0	140.00	249.98	194.07	194.07	-	900	0.0048	-	10.00	7.01	2.99	7.01	2.99	8.18	0.40	1.73	-	-	7.02	7.68
28	0	70.00	249.98	249.98	249.98	-	900	0.0048	-	10.00	7.01	2.99	7.01	2.99	8.18	0.40	1.73	-	-	7.02	7.68
29	0	140.00	249.98	249.98	249.98	-	900	0.0048	-	9.50	6.53	2.97	6.53	2.97	6.83	0.28	1.28	-	-	7.04	7.68
30	0	100.00	194.07	194.07	194.07	-	900	0.0050	-	9.00	6.05	2.95	6.05	2.95	6.35	0.33	1.40	-	-	7.04	7.68
30	0	100.00	249.98	249.98	249.98	-	900	0.0048	-	8.00	5.30	2.70	5.30	2.70	5.60	0.33	1.42	-	-	7.04	7.68
31	0	80.00	194.07	194.07	194.07	-	900	0.0024	-	8.00	5.11	2.89	5.11	2.89	5.46	0.39	1.40	-	-	4.10	8.19
31	0	100.00	249.98	249.98	249.98	-	900	0.0048	-	9.00	6.05	2.95	6.05	2.95	6.35	0.33	1.40	-	-	7.04	7.68
32	0	150.00	194.07	194.07	194.07	-	900	0.0050	-	9.00	6.05	2.95	6.05	2.95	6.35	0.28	1.30	-	-	7.27	7.65
33	0	80.00	249.98	249.98	249.98	-	900	0.0024	-	8.00	5.30	2.70	5.30	2.70	5.65	0.35	1.01	-	-	4.10	8.19
34	0	80.00	249.98	249.98	249.98	-	900	0.0048	-	8.00	5.11	2.89	5.11	2.89	5.46	0.39	1.40	-	-	7.04	7.68

**Table 1 (7/15) Trunk Sewer Hydraulic Calculation of Pavuna Sewer District**

manhole no / j	Construction Method o / j	Area (ha)	length (m)	upstream		downstream		slope (m/m)	diam. (mm)	ground level (m)		trunk sewer level (m)		cota NA final (m)		h/d (m/m)		velocity		critical velocity $V_c$ (m/s)
				initial	final	upstream	downstream			upstream	downstream	upstream	downstream	initial	final	initial	final	trave tension (Pa)	trave tension (Pa)	
34	j	114.484	50.00	245.54	245.54	-	900	0.0024	900	8.00	-	4.99	3.01	5.39	0.44	1.15	-	4.51	8.56	51.471
35	j		90.00	245.54	245.54	-	900	0.0024	900	8.00	-	4.99	3.01	5.39	0.39	1.08	-	4.51	66.301	
36	j		90.00	245.54	245.54	-	900	0.0024	900	8.00	4.77	3.23	5.17	0.44	1.15	-	4.58	8.55		
36	j		90.00	245.54	245.54	-	900	0.0024	900	8.00	4.77	3.23	5.17	0.39	1.08	-	4.58	8.55		
37	j		90.00	316.28	316.28	-	900	0.0024	900	8.00	4.55	3.45	4.95	0.44	1.15	-	4.58	8.55		
37	j	66.555	90.00	275.46	275.46	-	900	0.0024	900	8.00	4.55	3.45	4.97	0.41	1.11	-	4.51	8.56	51.471	
38	j		100.00	354.83	354.83	-	900	0.0024	900	8.30	4.33	3.97	4.75	0.47	1.19	-	4.79	8.75	29.922	
38	j		100.00	275.46	275.46	-	900	0.0024	900	8.30	4.33	3.97	4.76	0.41	1.10	-	4.79	8.75	38.544	
39	j		100.00	354.83	354.83	-	900	0.0024	900	9.00	4.09	4.91	4.52	0.47	1.18	-	4.72	8.76		
39	j		100.00	275.46	275.46	-	900	0.0024	900	9.00	4.09	4.91	4.52	0.41	1.10	-	4.72	8.76		
40	j		150.00	354.83	354.83	-	900	0.0024	900	9.00	3.85	5.15	4.28	0.47	1.18	-	4.72	8.76		
40	j		150.00	275.46	275.46	-	900	0.0024	900	9.00	3.85	5.15	4.28	0.41	1.10	-	4.72	8.76		
41	j		150.00	354.83	354.83	-	900	0.0024	900	9.00	3.49	5.51	3.92	0.47	1.18	-	4.72	8.76		
41	j		150.00	275.46	275.46	-	900	0.0024	900	9.00	3.49	5.51	3.92	0.41	1.10	-	4.72	8.76		
42	j		150.00	354.83	354.83	-	900	0.0024	900	9.00	3.13	5.87	3.56	0.47	1.18	-	4.72	8.76		
42	j		150.00	275.46	275.46	-	900	0.0024	900	9.00	3.13	5.87	3.56	0.41	1.10	-	4.72	8.76		
43	j		150.00	354.83	354.83	-	900	0.0024	900	9.00	2.77	6.23	3.20	0.47	1.18	-	4.72	8.76		
43	j		150.00	275.46	275.46	-	900	0.0024	900	9.00	2.77	6.23	3.20	0.41	1.10	-	4.72	8.76		
44	j		150.00	354.83	354.83	-	900	0.0024	900	9.00	2.41	6.59	2.84	0.47	1.18	-	4.72	8.76		
44	j		150.00	275.46	275.46	-	900	0.0024	900	9.00	2.41	6.59	2.84	0.41	1.10	-	4.72	8.76		
45	j		50.00	354.83	354.83	-	900	0.0024	900	9.00	2.05	6.95	2.48	0.47	1.18	-	4.72	8.76		
45	j		50.00	275.46	275.46	-	900	0.0024	900	9.00	2.05	6.95	2.48	0.41	1.10	-	4.72	8.76		
46	j		60.971	100.00	354.83	-	900	0.0024	900	9.00	1.93	7.07	2.36	0.43	1.13	-	4.72	8.76		
46	j		60.971	100.00	302.87	-	900	0.0024	900	9.00	1.93	7.07	2.38	0.43	1.13	-	4.72	8.76		
47	j		390.14	390.14	390.14	-	900	0.0024	900	8.00	1.69	6.31	2.14	0.43	1.13	-	4.72	8.76		
47	j		100.00	302.87	302.87	-	900	0.0024	900	8.00	1.69	6.31	2.14	0.43	1.13	-	4.72	8.76		
48	j		390.14	390.14	390.14	-	900	0.0024	900	8.00	1.45	6.55	1.90	0.50	1.21	-	4.90	8.93		
48	j		101.954	100.00	348.71	-	900	0.0010	900	8.00	1.30	6.70	1.97	0.62	0.85	-	4.90	8.93	27.412	
50 (No.3 TS)	TOTAL			449.18	449.18	-				1.20	6.80	1.87	0.75	0.88	-	2.54	9.79	45.838		
				4,230.00															59.044	

Table 1 (8/15) Trunk Sewer Hydraulic Calculation of Pavuna Sewer District

PAVUNA SEWERAGE DISTRICT TRUNK SEWER HYDRAULIC CONCEPT DESIGN No. 3 TRUNK SEWER												
JICA manhole	Construction Method o / j	Area (ha)	length (m)	upstream	downstream	slope	ground level (m)	trunk sewer depth (m)	cota NA final (m)	b/d (m/m)	velocity	
				flow (l/s) initial	flow (l/s) final	(m/m)	upstream	upstream	initial	initial	trative tension (Pa)	
				initial	final		downstream	downstream	final	final	critical velocity $V_c$ (m/s)	
1	-	916.733	50.00	412.16	412.16	0.0026	17.50	11.00	6.50	11.50	0.43	1.26
2	-			530.91	530.91		16.80	10.87	5.93	11.37	0.50	-
2	-	120.00		412.16	412.16	0.0026	16.80	10.87	5.93	11.37	0.43	1.35
3	-			530.91	530.91		16.50	10.56	5.94	11.06	0.50	-
3	-	140.00		412.16	412.16	0.0026	16.50	10.56	5.94	11.06	0.43	1.34
4	-			530.91	530.91		16.20	10.20	6.00	10.70	0.50	-
4	-	30.00		412.16	412.16	0.0027	16.20	10.20	6.00	10.69	0.43	1.27
5	-			530.91	530.91		16.20	10.12	6.08	10.61	0.49	-
5	-	150.00		412.16	412.16	0.0026	16.20	10.12	6.08	10.62	0.43	1.34
6	-			530.91	530.91		16.00	9.73	6.27	10.23	0.50	-
6	-	150.00		412.16	412.16	0.0026	16.00	9.73	6.27	10.23	0.43	1.35
7	-			530.91	530.91		16.00	9.34	6.66	9.84	0.50	-
7	-	150.00		412.16	412.16	0.0026	16.00	9.34	6.66	9.84	0.43	1.27
8	-			530.91	530.91		15.80	8.95	6.85	9.45	0.50	-
8	-	150.00		412.16	412.16	0.0026	15.80	8.95	6.85	9.45	0.43	1.26
9	-			530.91	530.91		15.40	8.56	6.84	9.06	0.50	-
9	-	110.00		412.16	412.16	0.0026	15.40	8.56	6.84	9.06	0.43	1.27
10	-			530.91	530.91		14.70	8.27	6.43	8.77	0.50	-
10	-	40.00		412.16	412.16	0.0027	14.70	8.27	6.43	8.76	0.42	1.29
11	-			530.91	530.91		14.80	8.16	6.64	8.65	0.49	-
11	-	60.00		412.16	412.16	0.0020	14.80	8.16	6.64	8.70	0.46	1.35
12	j	150.00		530.91	530.91		14.40	8.04	6.36	8.58	0.54	-
12	j	40.106		482.56	482.56		14.40	7.84	6.56	8.66	0.57	-
13	j			621.59	621.59		13.20	7.76	5.44	8.58	0.68	-
13	j	80.00		482.56	482.56		13.20	7.76	5.44	8.60	0.58	0.71
14	j			621.59	621.59		12.00	0.0005	-	-	-	1.64
14	j	100.00		482.56	614.36		13.10	7.72	5.38	8.56	0.70	0.75
15	j			621.59	791.36		12.00	0.0018	-	-	-	1.21
15	j	80.00		614.36	614.36		13.10	7.54	5.56	8.18	0.53	1.30
16	j			791.36	791.36		12.80	7.40	5.40	8.04	0.53	1.28

**Table 1 (9/15) Trunk Sewer Hydraulic Calculation of Pavuna Sewer District**

manhole no / j	Construction Method o / j	Area (ha)	length (m)	upstream		downstream		ground level (m)		slope (m/m)		trunk sewer depth (m)		cota NA final (m)		h/d (m/m)		velocity (m/s)		Page 9 Notes: entrance flow (l/s):
				initial	final	initial	final	upstream	downstream	upstream	downstream	upstream	downstream	initial	final	initial	final	initial	final	
16	j	90.000	614.36	614.36	614.36	-	1200	0.0018	-	12.80	7.40	5.40	8.04	0.46	1.21	-	-	5.01	10.49	
17	j	130.000	791.36	632.39	632.39	-	1200	0.0018	13.40	7.24	6.16	7.88	0.53	1.29	-	-	-	-	-	
18	j	100.000	814.59	632.39	632.39	-	1200	0.0018	-	12.90	7.00	5.90	7.64	0.46	1.24	-	-	5.23	10.51	18.032 23.227
18	j	100.000	814.59	814.59	814.59	-	1200	0.0018	-	12.70	6.82	5.88	7.47	0.46	1.22	-	-	5.12	10.54	
19	j	100.000	632.39	632.39	632.39	-	1200	0.0018	-	12.70	6.82	5.88	7.47	0.46	1.22	-	-	5.12	10.54	
20	j	100.000	814.59	814.59	814.59	-	1200	0.0018	-	12.40	6.64	5.76	7.29	0.54	1.31	-	-	-	-	
20	j	100.000	632.39	632.39	632.39	-	1200	0.0018	-	12.40	6.64	5.76	7.29	0.46	1.22	-	-	5.12	10.54	
21	j	100.000	814.59	814.59	814.59	-	1200	0.0018	-	12.20	6.46	5.74	7.11	0.54	1.31	-	-	5.12	10.54	
21	j	60.000	632.39	632.39	632.39	-	1200	0.0018	-	12.20	6.46	5.74	7.10	0.46	1.23	-	-	5.20	10.52	
22	j	150.000	814.59	814.59	814.59	-	1200	0.0018	11.90	6.35	5.55	6.99	0.54	1.32	-	-	-	-	-	
22	j	150.000	632.39	632.39	632.39	-	1200	0.0018	-	11.70	6.08	5.55	7.00	0.46	1.22	-	-	-	-	
23	j	150.000	814.59	814.59	814.59	-	1200	0.0018	-	11.70	6.08	5.62	6.73	0.54	1.31	-	-	5.12	10.54	
23	j	150.000	632.39	632.39	632.39	-	1200	0.0018	-	11.70	6.08	5.62	6.73	0.46	1.22	-	-	5.12	10.54	
24	j	150.000	814.59	814.59	814.59	-	1200	0.0018	-	11.00	5.81	5.19	6.46	0.54	1.31	-	-	-	-	
24	j	49.851	654.81	654.81	654.81	-	1200	0.0018	-	11.00	5.81	5.19	6.47	0.47	1.24	-	-	5.20	10.61	22.413 28.870
25	j	60.000	843.46	843.46	843.46	-	1200	0.0018	-	10.50	5.54	4.96	6.20	0.55	1.32	-	-	-	-	
25	j	60.000	654.81	654.81	654.81	-	1200	0.0018	-	10.50	5.54	4.96	6.20	0.47	1.24	-	-	-	-	
26	j	120.000	843.46	843.46	843.46	-	1200	0.0018	-	10.10	5.43	4.67	6.09	0.55	1.33	-	-	5.27	10.59	
26	j	120.000	654.81	654.81	654.81	-	1200	0.0018	-	10.10	5.43	4.67	6.09	0.47	1.24	-	-	5.27	10.59	
27	j	120.000	843.46	843.46	843.46	-	1200	0.0018	-	10.50	5.21	5.29	5.87	0.55	1.33	-	-	-	-	
27	j	150.000	654.81	654.81	654.81	-	1200	0.0018	-	10.50	5.21	5.29	5.87	0.47	1.24	-	-	-	-	
28	j	130.000	843.46	843.46	843.46	-	1200	0.0018	-	11.00	4.94	6.06	5.60	0.55	1.32	-	-	5.20	10.61	
28	j	130.000	654.81	654.81	654.81	-	1200	0.0018	-	11.00	4.94	6.06	5.60	0.47	1.25	-	-	5.20	10.61	
29	j	150.000	843.46	843.46	843.46	-	1200	0.0018	-	9.80	4.70	5.10	5.36	0.55	1.33	-	-	-	-	
29	j	150.000	654.81	654.81	654.81	-	1200	0.0020	-	9.80	4.70	5.10	5.34	0.46	1.28	-	-	-	-	
30	j	150.000	843.46	843.46	843.46	-	1200	0.0010	-	8.00	4.40	3.60	5.04	0.53	1.37	-	-	5.65	10.50	
30	j	150.000	654.81	654.81	654.81	-	1200	0.0010	-	8.00	4.40	3.60	5.21	0.57	0.99	-	-	3.23	11.14	
31	j	150.000	843.46	843.46	843.46	-	1200	0.0010	-	8.00	4.25	3.75	5.06	0.68	1.05	-	-	3.23	11.14	
31	j	150.000	654.81	654.81	654.81	-	1200	0.0010	-	9.00	4.10	4.90	4.91	0.68	1.05	-	-	-	-	
32	j	150.000	843.46	843.46	843.46	-	1200	0.0010	-	9.00	4.10	4.90	4.91	0.68	1.05	-	-	-	-	

**Table 1 (10/15) Trunk Sewer Hydraulic Calculation of Pavuna Sewer District**

manhole no / j	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s)	downstream flow (l/s)	slope (m/m)	diam. (mm)	ground level (m)		trunk sewer depth (m)		cota NA final (m)		b/d (m/m)		velocity (m/s)		critical velocity Vc (m/s)		Page Notes: entrance flow (l/s);	
								initial	final	upstream	downstream	initial	final	V <sub>initial</sub>	V <sub>final</sub>	tractive tension (Pa)	velocity	critical velocity Vc (m/s)	Page 10		
32	j	39.311	80.00	672.48	672.48	-	1200	0.0010	9.00	-	4.10	4.90	4.93	0.58	0.99	-	3.23	11.18	17.674	22.766	
33	j	175.202	70.00	866.23	866.23	751.25	751.25	0.0010	9.00	4.02	4.98	4.85	4.92	0.63	1.02	0.69	1.05	-			
33	j	175.202	70.00	967.69	967.69	-	1200	0.0010	9.00	-	4.02	4.98	-	-	-	-	0.63	1.02	3.35	11.31	78.770
34	j	100.00	751.25	967.69	967.69	-	1200	0.0010	9.00	3.95	5.05	4.85	4.85	0.62	1.03	0.75	1.06	1.03	101.465		
34	j	100.00	751.25	967.69	967.69	-	1200	0.0010	9.00	-	3.85	5.15	4.75	4.75	0.62	1.03	-	-	3.39	11.30	
35	j	70.00	751.25	967.69	967.69	-	1200	0.0010	9.00	3.85	5.15	4.75	4.75	0.62	1.03	-	-	3.39	11.30		
36	j	100.00	751.25	967.69	967.69	-	1200	0.0010	9.00	3.78	5.22	4.68	4.69	0.63	1.02	0.75	1.07	-			
36	j	100.00	967.69	967.69	967.69	-	1200	0.0010	9.00	3.78	5.22	4.69	-	-	-	-	0.63	1.02			
37	j	100.00	751.25	967.69	967.69	-	1200	0.0010	9.00	3.68	5.32	4.59	4.59	0.75	1.06	-	-	3.34	11.31		
37	j	100.00	751.25	967.69	967.69	-	1200	0.0010	9.00	3.68	5.32	4.57	4.57	0.61	1.04	-	-	3.39	11.30		
38	j	100.00	967.69	967.69	967.69	-	1200	0.0010	9.00	3.58	5.42	4.46	4.46	0.74	1.09	-	-	3.51	11.28		
38	j	100.00	967.69	967.69	967.69	-	1200	0.0010	9.00	3.58	5.42	4.48	4.48	0.63	1.04	-	-	3.51	11.28		
39	j	35.123	100.00	988.03	988.03	-	1200	0.0010	9.00	3.48	5.52	4.38	4.38	0.75	1.08	-	-	3.47	11.31	15.791	
39	j	120.00	767.04	988.03	988.03	-	1200	0.0010	9.00	3.48	5.52	4.38	4.38	0.62	1.04	-	-	3.51	11.31	20.341	
40	j	100.00	767.04	988.03	988.03	-	1200	0.0010	9.00	3.35	5.65	4.25	4.25	0.75	1.09	-	-	3.47	11.31		
40	j	100.00	767.04	988.03	988.03	-	1200	0.0010	9.00	3.35	5.65	4.25	4.25	0.62	1.05	-	-	3.53	11.30		
41	j	70.00	767.04	988.03	988.03	-	1200	0.0010	9.00	3.25	5.75	4.15	4.15	0.75	1.09	-	-	3.53	11.30		
41	j	70.00	988.03	988.03	988.03	-	1200	0.0010	9.00	3.25	5.75	4.15	4.15	0.62	1.05	-	-	3.54	11.30		
42	j	120.00	767.04	988.03	988.03	-	1200	0.0010	9.00	3.18	5.82	4.07	4.07	0.75	1.09	-	-	3.46	11.31		
42	j	120.00	767.04	988.03	988.03	-	1200	0.0010	9.00	3.18	5.82	4.08	4.08	0.63	1.04	-	-	3.46	11.31		
43	j	50.00	767.04	988.03	988.03	-	1200	0.0010	9.00	3.06	5.95	3.96	3.96	0.63	1.04	-	-	3.47	11.31		
43	j	130.00	767.04	988.03	988.03	-	1200	0.0010	9.00	2.87	6.13	3.76	3.76	0.62	1.05	-	-	3.47	11.31		
44	j	40.00	767.04	988.03	988.03	-	1200	0.0011	9.00	2.87	6.13	3.76	-	-	-	-	0.62	1.08			
44	j	80.00	767.04	988.03	988.03	-	1200	0.0011	9.00	2.83	6.17	3.72	3.72	0.75	1.10	-	-	3.56	11.30		
45	j	150.00	767.04	988.03	988.03	-	1200	0.0011	9.00	2.74	5.26	3.62	3.62	0.73	1.07	-	-	3.50	11.31		
45	j	150.00	988.03	988.03	988.03	-	1200	0.0011	8.00	2.74	5.26	3.63	0.62	1.06	-	-	3.60	11.29			

**Table 1 (11/15) Trunk Sewer Hydraulic Calculation of Pavuna Sewer District**

manhole no / j	Construction Method o / j	Area (ha)	length (m)	upstream		downstream		ground level (m)		slope (m/m)		trunk sewer depth (m)		cota final (m)		h/d (m/m)		velocity (m/s)		Page Notes: entrance flow (l/s);	
				initial	final	initial	final	upstream	downstream	upstream	downstream	upstream	downstream	initial	final	initial	final	initial	final		
48	j		150.00	767.04	767.04	-	-	1200	0.0011	8.00	2.58	5.42	3.47	0.62	1.05	-	-	3.57	11.30		
49	j		150.00	988.03	988.03	767.04	767.04	-	-	2.42	5.58	3.32	0.74	1.10	1.06	1.06	1.06	1.06	1.13	11.45	
49	j		150.00	988.03	988.03	767.04	767.04	1500	0.0011	8.00	2.12	5.88	2.86	0.42	-	-	-	3.63	-		
50	j		60.00	1115.752	1115.752	-	-	1500	0.0017	8.00	1.96	6.04	2.70	0.49	1.13	1.37	1.37	1.46	1.46		
50	j		60.00	988.03	988.03	1437.21	1437.21	-	-	1.20	6.80	2.02	0.46	-	-	-	-	5.96	11.81		
51	j		50.00	1115.75	1115.75	1115.75	1115.75	1500	0.0008	8.00	1.10	6.90	2.15	0.59	1.04	1.04	1.04	1.04	1.04		
51	j		50.00	1437.21	1437.21	1437.21	1437.21	-	-	6.94	2.11	6.94	2.11	0.70	1.10	1.10	1.10	1.10	1.10		
52	j		130.00	1115.75	1115.75	1115.75	1115.75	1500	0.0008	8.00	1.06	6.94	2.13	0.59	1.03	1.03	1.03	1.03	1.03		
52	j		130.00	1437.21	1437.21	1437.21	1437.21	-	-	6.94	2.13	6.94	2.13	-	-	-	-	3.19	12.56		
53	j		57.951	130.00	1141.81	1141.81	1141.81	1141.81	1500	0.0008	7.00	0.96	6.04	2.03	0.71	1.08	1.08	1.08	1.08	1.08	
53	j		57.951	130.00	1470.77	1470.77	1470.77	1470.77	-	-	6.15	1.90	6.15	1.90	-	-	-	-	3.29	12.53	
54	j		90.00	1141.81	1141.81	1141.81	1141.81	1500	0.0008	7.00	0.85	6.15	1.93	0.60	1.04	1.04	1.04	1.04	1.04		
54	j		90.00	1470.77	1470.77	1470.77	1470.77	-	-	6.22	1.86	6.22	1.86	0.72	1.09	1.09	1.09	1.09	1.09		
55	j		60.00	1141.81	1141.81	1141.81	1141.81	1500	0.0008	7.00	0.78	6.22	1.83	0.59	1.07	1.07	1.07	1.07	1.07		
55	j		60.00	1470.77	1470.77	1470.77	1470.77	-	-	6.27	1.78	6.27	1.78	0.70	1.12	1.12	1.12	1.12	1.12		
56	j		100.00	1141.81	1141.81	1141.81	1141.81	1500	0.0008	7.00	0.73	6.27	1.80	0.60	1.05	1.05	1.05	1.05	1.05		
56	j		100.00	1470.77	1470.77	1470.77	1470.77	-	-	6.35	1.72	6.35	1.72	0.71	1.13	1.13	1.13	1.13	1.13		
57	j		70.00	1141.81	1141.81	1141.81	1141.81	1500	0.0008	7.00	0.65	6.35	1.73	0.60	1.03	1.03	1.03	1.03	1.03		
57	j		70.00	1470.77	1470.77	1470.77	1470.77	-	-	6.40	1.68	6.40	1.68	0.72	1.08	1.08	1.08	1.08	1.08		
58	j		60.00	1141.81	1141.81	1141.81	1141.81	1500	0.0008	7.00	0.60	6.40	1.68	0.60	1.03	1.03	1.03	1.03	1.03		
58	j		60.00	1470.77	1470.77	1470.77	1470.77	-	-	6.45	1.63	6.45	1.63	0.72	1.08	1.08	1.08	1.08	1.08		
59	j		70.00	1141.81	1141.81	1141.81	1141.81	1500	0.0008	7.00	0.55	6.45	1.63	0.60	1.04	1.04	1.04	1.04	1.04		
59	j		70.00	1470.77	1470.77	1470.77	1470.77	-	-	6.51	1.57	6.51	1.57	0.72	1.09	1.09	1.09	1.09	1.09		
60	j		50.00	1185.69	1185.69	1185.69	1185.69	1500	0.0008	7.00	0.50	6.51	1.60	0.62	1.05	1.05	1.05	1.05	1.05		
60	j		50.00	1527.30	1527.30	-	-	1500	0.0008	7.00	0.46	6.54	1.56	0.74	1.10	1.10	1.10	1.10	1.10		
61	j		20.562	1194.93	1194.93	-	-	1500	0.0008	7.00	0.46	6.54	1.58	0.63	1.04	1.04	1.04	1.04	1.04		
62	j		100.00	1539.21	1539.21	-	-	1500	0.0008	7.00	0.38	6.62	1.51	0.75	-	-	3.23	12.64			
62	j		100.00	1194.93	1194.93	-	-	1500	0.0008	7.00	0.38	6.62	1.48	0.61	1.06	1.06	1.06	1.06	1.06		
63	j		97.604	1194.93	1194.93	-	-	1500	0.0008	7.00	0.30	6.70	1.40	0.74	1.11	1.11	1.11	1.11	1.11		
63	j		150.00	1539.21	1539.21	-	-	1500	0.0008	7.00	0.30	6.70	1.40	0.61	1.06	1.06	1.06	1.06	1.06		
64	j		150.00	1194.93	1194.93	-	-	1500	0.0008	6.00	0.18	5.82	1.28	0.74	1.11	1.11	1.11	1.11	1.11		

**Table 1 (12/15) Trunk Sewer Hydraulic Calculation of Pavuna Sewer District**

manhole no / j	Construction Method o / j	Area (ha)	length (m)	upstream		downstream		slope (m/m)	ground level (m)	trunk sewer level (m)		cota final (m)	h/d (m/m)	velocity (m/s)	critical velocity $V_c$ (m/s)	Page 12 Notes: entrance flow (l/s);	
				initial	final	upstream	downstream			upstream	downstream						
				initial	final	upstream	downstream			upstream	downstream						
64	j		150.00	-	1194.93	1194.93	-	1500	0.0008	6.00	0.18	5.82	1.28	0.61	1.06		
65	j	23.031	150.00	1539.21	1539.21	1205.29	1205.29	-	1500	0.0008	6.00	0.06	5.94	1.16	-	-	3.37
65	j		150.00	-	1552.54	1552.54	-	1500	0.0008	6.00	-	5.94	1.17	0.62	1.06	1.11	
66	j		150.00	1552.54	1552.54	1205.29	1205.29	-	1500	0.0008	6.00	-0.06	6.06	1.05	0.74	1.11	
66	j		150.00	-	1552.54	1552.54	-	1500	0.0008	6.00	-	6.06	1.05	0.62	1.06	1.11	
67	j		150.00	1552.54	1552.54	1205.29	1205.29	-	1500	0.0008	6.00	-0.18	6.18	0.93	0.74	1.11	
67	j		150.00	-	1552.54	1552.54	-	1500	0.0008	6.00	-0.18	6.18	0.93	0.62	1.06	1.11	
68	j		150.00	1552.54	1552.54	1205.29	1205.29	-	1500	0.0008	6.00	-0.30	6.30	0.81	0.74	1.11	
68	j		140.00	-	1552.54	1552.54	-	1500	0.0008	6.00	-0.30	6.30	0.82	0.62	1.05	1.05	
69	j		150.00	1552.54	1552.54	1205.29	1205.29	-	1500	0.0008	7.00	-0.41	7.41	0.71	0.75	1.10	
70	j		150.00	-	1552.54	1552.54	-	1500	0.0008	7.00	-0.41	7.41	0.70	0.62	1.06	1.06	
70	j		150.00	1552.54	1552.54	1205.29	1205.29	-	1500	0.0008	4.00	-0.53	4.53	0.58	0.74	1.11	
71	j		150.00	-	1552.54	1552.54	-	1500	0.0008	4.00	-	4.53	0.58	0.62	1.06	1.11	
71	j		150.00	1552.54	1552.54	1205.29	1205.29	-	1500	0.0008	4.00	-0.65	4.65	0.46	0.74	1.11	
72	j		150.00	-	1552.54	1552.54	-	1500	0.0008	4.00	-	4.65	0.46	0.62	1.06	1.11	
72	j		150.00	1552.54	1552.54	1205.29	1205.29	-	1500	0.0008	4.00	-0.77	4.77	0.34	0.74	1.11	
73	j		150.00	-	1552.54	1552.54	-	1500	0.0008	4.00	-0.77	4.77	0.34	0.62	1.06	1.06	
73	j		150.00	1552.54	1552.54	1205.29	1205.29	-	1500	0.0008	4.00	-0.89	4.89	0.22	0.74	1.11	
74	j		150.00	-	1552.54	1552.54	-	1500	0.0008	4.00	-0.89	4.89	0.22	0.62	1.06	1.06	
74	j		150.00	1552.54	1552.54	1205.29	1205.29	-	1500	0.0008	4.00	-1.01	5.01	0.10	0.74	1.11	
75	j		150.00	-	1552.54	1552.54	-	1500	0.0008	4.00	-	5.13	-0.02	0.74	1.11		
75	j		150.00	1552.54	1552.54	1205.29	1205.29	-	1500	0.0008	4.00	-1.13	5.13	-0.03	0.61	1.07	
76	j		110.00	-	1552.54	1552.54	-	1500	0.0008	4.00	-	5.22	-0.12	0.73	1.12		
76	j		150.00	-	1552.54	1552.54	-	1500	0.0008	4.00	-1.22	5.22	-0.11	0.62	1.06		
77	j		120.00	-	1552.54	1552.54	-	1500	0.0008	4.00	-1.34	5.34	-0.23	0.62	1.06		
77	j		50.00	-	1552.54	1552.54	-	1500	0.0008	4.00	-1.34	5.34	-0.23	-	-		
78	j		80.00	-	1552.54	1552.54	-	1500	0.0008	4.00	-1.38	5.38	-0.27	0.74	1.11		
78	j		120.00	-	1552.54	1552.54	-	1500	0.0008	4.00	-1.38	5.38	-0.27	0.62	1.06		
79	j		120.00	-	1552.54	1552.54	-	1500	0.0008	4.00	-1.44	5.44	-0.33	0.74	1.11		
79	j		120.00	-	1552.54	1552.54	-	1500	0.0008	4.00	-1.44	5.44	-0.33	0.62	1.06		
80	j		120.00	-	1552.54	1552.54	-	1500	0.0008	4.00	-1.54	5.54	-0.43	0.74	1.11		

**Table 1 (13/15) Trunk Sewer Hydraulic Calculation of Pavuna Sewer District**

manhole	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s)	downstream flow (l/s)	diam. (mm)	slope (m/m)	ground level (m)	trunk sewer level (m)	trunk sewer depth (m)	cota NA final (m)	h/d (m/m)	tractive tension (Pa)	critical velocity Vc (m/s)	Notes: entrance flow (l/s):	Page 13
								initial	upstream	upstream	initial	initial	final	final		
								final	downstream	downstream	final	final	final	final	V <sub>initial</sub>	V <sub>final</sub>
80	j		60.00	-	1205.29	1552.54	0.0008	4.00	-1.54	5.54	-0.45	0.61	1.08	-		
81	j		70.00	-	1205.29	1552.54	0.0008	4.00	-1.59	5.59	-0.50	0.73	1.13	-	3.50	12.60
81	j		150.00	-	1205.29	1552.54	0.0008	4.00	-1.64	5.64	-0.52	0.75	1.05	-		
82	j		150.00	-	1205.29	1552.54	0.0008	4.00	-1.64	5.64	-0.55	0.61	1.08	-	3.28	12.64
82	j		150.00	-	1205.29	1552.54	0.0008	4.00	-1.77	5.77	-0.68	0.73	1.13	-		
83	j		150.00	-	1205.29	1552.54	0.0008	4.00	-1.77	5.77	-0.66	0.62	1.06	-		
84	j		150.00	-	1205.29	1552.54	0.0008	5.00	-1.89	6.89	-0.78	0.74	1.11	-	3.38	12.63
84	j		150.00	-	1205.29	1552.54	0.0008	5.00	-1.89	6.89	-0.78	0.62	1.06	-		
85	j		150.00	-	1205.29	1552.54	0.0008	4.00	-2.01	6.01	-0.90	0.74	1.11	-		
85	j		140.00	-	1205.29	1552.54	0.0008	4.00	-2.01	6.01	-0.90	0.62	1.06	-		
86	j		120.00	-	1205.29	1552.54	0.0008	4.00	-2.13	6.13	-1.02	0.74	1.11	-		
86	j		120.00	-	1205.29	1552.54	0.0008	4.00	-2.13	6.13	-1.01	0.62	1.05	-		
87	j		120.00	-	1205.29	1552.54	0.0008	4.00	-2.24	6.24	-1.12	0.75	1.10	-		
87	j		120.00	-	1205.29	1552.54	0.0008	4.00	-2.24	6.24	-1.15	0.61	1.08	-		
88	j		120.00	-	1205.29	1552.54	0.0008	4.00	-2.34	6.34	-1.25	0.73	1.13	-		
88	j		120.00	-	1205.29	1552.54	0.0008	4.00	-2.34	6.34	-1.25	0.61	1.08	-		
89	j		90.00	-	1205.29	1552.54	0.0008	4.00	-2.44	6.44	-1.35	0.73	1.13	-		
89	j		50.00	-	1205.29	1552.54	0.0008	4.00	-2.44	6.44	-1.33	0.62	1.06	-		
90	j		120.00	-	1205.29	1552.54	0.0008	4.00	-2.48	6.48	-1.37	0.74	1.11	-		
90	j		90.00	-	1205.29	1552.54	0.0008	4.00	-2.48	6.48	-1.36	0.62	1.05	-		
91	j		120.00	-	1205.29	1552.54	0.0008	4.00	-2.55	6.55	-1.43	0.75	1.10	-		
91	j		120.00	-	1205.29	1552.54	0.0008	4.00	-2.55	6.55	-1.46	0.61	1.08	-		
TC053 (PDBG1)	TOTAL															
					9,912.00											

**Table 1 (14/15) Trunk Sewer Hydraulic Calculation of Pavuna Sewer District**

PAVUNA SEWERAGE DISTRICT TRUNK SEWER HYDRAULIC CONCEPT DESIGN No. 3-1 TRUNK SEWER										
JICA manhole	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s) initial final	downstream flow (l/s) initial final	diam. (mm)	slope (m/m)	ground level (m)	trunk sewer level (m)	cota NA final (m)
									b/d (m/m)	velocity (m/s)
									V <sub>i</sub> initial V <sub>f</sub> final	
14.1	0	157.579	150.00	70.85	70.85	400	0.0113	29.90	27.90	2.00
14.2	0	150.00	91.26	91.26	91.26	400	0.0113	28.20	26.20	2.00
14.2	0	150.00	70.85	70.85	91.26	400	0.0113	28.20	26.20	2.00
14.3	0	150.00	91.26	91.26	91.26	400	0.0113	26.50	24.50	2.00
14.3	0	150.00	70.85	70.85	91.26	400	0.0113	24.80	22.80	2.00
14.4	0	150.00	91.26	91.26	91.26	400	0.0113	24.80	22.80	2.00
14.4	0	150.00	70.85	70.85	91.26	400	0.0113	23.10	21.10	2.00
14.5	0	150.00	91.26	91.26	91.26	400	0.0113	23.10	21.10	2.00
14.5	0	150.00	70.85	70.85	91.26	400	0.0113	21.50	19.40	2.00
14.6	0	150.00	91.26	91.26	91.26	400	0.0080	21.50	19.40	2.10
14.6	0	150.00	70.85	70.85	91.26	400	0.0080	20.60	18.20	2.40
14.7	0	150.00	91.26	91.26	91.26	400	0.0080	20.60	18.20	2.40
14.7	0	150.00	70.85	70.85	91.26	400	0.0080	19.00	17.00	2.00
14.8	0	150.00	91.26	91.26	91.26	400	0.0040	18.70	15.80	2.90
14.8	0	150.00	70.85	70.85	91.26	400	0.0040	18.80	15.28	3.52
14.9	0	150.00	91.26	91.26	91.26	400	0.0040	18.80	15.28	3.52
14.9	0	130.00	91.26	91.26	91.26	400	0.0040	17.30	15.20	2.10
14.10	0	70.084	130.00	-	131.85	500	0.0040	-	-	17.30
14.10	0	20.00	70.85	-	131.85	500	0.0040	-	-	16.80
14.11	0	130.00	91.26	-	131.85	500	0.0040	-	-	14.58
14.11	0	130.00	102.36	102.36	131.85	500	0.0040	-	-	14.58
14.12	0	70.00	102.36	102.36	131.85	500	0.0040	-	-	16.80
14.12	0	130.00	102.36	102.36	131.85	500	0.0040	-	-	14.58
14.13	0	140.00	131.85	-	131.85	500	0.0040	-	-	16.10
14.13	0	120.00	102.36	-	131.85	500	0.0040	-	-	16.10
14.14	0	130.00	102.36	102.36	131.85	500	0.0040	-	-	15.90
14.14	0	140.00	131.85	-	131.85	500	0.0040	-	-	14.06
14.15	0	120.00	102.36	-	131.85	500	0.0040	-	-	13.22
14.15	0	130.00	102.36	-	131.85	500	0.0040	-	-	13.22
14.16	0	120.00	131.85	-	131.85	500	0.0040	-	-	12.74

**Table 1 (15/15) Trunk Sewer Hydraulic Calculation of Pavuna Sewer District**

manhole no / j	Construction Method	Area (ha)	length (m)	upstream flow (l/s)	diam. (mm)	slope (m/m)	ground level (m)	trunk sewer level (m)	cota NA final (m)	h/d (m/m)	velocity (m/s)	critical velocity Vc (m/s)	trative tension (Pa)	Page Notes: entrance flow (l/s): 15	
14.16	o	65.488	150.00	131.80	500	0.0040	15.50	12.74	2.76	13.09	0.58	1.12	-	29.443	
14.17	o	150.00	169.77	169.77	500	0.0040	14.70	12.14	2.56	12.49	0.69	1.18	-	37.926	
14.17	o	150.00	131.80	131.80	500	0.0040	14.70	12.14	2.56	12.49	0.58	1.12	-	5.47	
14.18	o	150.00	169.77	169.77	500	0.0040	13.80	11.54	2.26	11.89	0.69	1.18	-	5.47	
14.18	o	150.00	131.80	131.80	500	0.0040	13.80	11.54	2.26	11.89	0.58	1.12	-	5.47	
14.19	o	150.00	169.77	169.77	500	0.0040	13.30	10.94	2.36	11.29	0.69	1.18	-	5.47	
14.19	o	90.00	131.80	131.80	500	0.0040	13.30	10.94	2.36	11.29	0.58	1.12	-	7.22	
14 (No. 3 TS)	TOTAL		2,480.00								2.52	10.93	0.69	1.18	5.47
															7.22

## 1.2 ACARI SEWER DISTRICT

Trunk Sewer Hydraulic Calculation of Acari Sewer District is shown in *Table 2 (1/18 - 18/18)*.

**Table 2 (1/18) Trunk Sewer Hydraulic Calculation of Acari Sewer District**

JICA No. 1 TRUNK SEWER		ACARI SEWERAGE DISTRICT TRUNK SEWER HYDRAULIC CONCEPT DESIGN														
manhole	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s)	downstream flow (l/s)	diam. (mm)	slope (m/m)	ground level (m)	trunk sewer level (m)	trunk sewer depth (m)	cota NA final (m)	h/d (m/m)	velocity (m/s)	trative tension (Pa)	critical velocity (m/s)	Page Notes: entrance flow (l/s):
		initial	initial	initial	final	initial	final	upstream	upstream	upstream	initial	initial	V <sub>initial</sub>	V <sub>final</sub>	V <sub>c</sub>	1
1	j	33.025	150.00	12.58	12.58	500	0.0015	34.00	30.00	4.00	30.12	0.21	0.41	-	0.94	5.02
2	j	150.00	12.58	12.58	16.20	500	0.0015	34.00	29.78	4.22	29.90	0.21	0.42	-	0.44	12.575
3	j	150.00	12.58	12.58	16.20	500	0.0015	34.00	29.55	4.45	29.67	0.21	0.45	-	0.97	16.198
4	j	150.00	12.58	12.58	16.20	500	0.0015	34.00	29.33	4.67	29.45	0.21	0.42	-	0.94	5.02
5	j	150.00	12.58	12.58	16.20	500	0.0015	34.00	29.33	4.67	29.45	0.21	0.42	-	0.97	5.00
6	j	150.00	12.58	12.58	16.20	500	0.0015	34.00	29.10	4.90	29.22	0.21	0.42	-	0.97	5.00
7	j	100.00	12.58	12.58	16.20	500	0.0015	34.00	29.10	4.90	29.22	0.21	0.42	-	0.97	5.00
8	j	64.070	100.00	12.58	16.20	500	0.0015	32.00	28.87	3.13	28.99	0.24	0.45	-	0.97	5.00
9	j	100.00	12.58	12.58	16.20	500	0.0015	32.00	28.72	3.28	28.84	0.24	0.44	-	0.96	5.01
10	j	150.00	36.97	36.97	47.62	500	0.0015	32.00	28.72	3.28	28.93	0.37	0.56	-	1.51	6.27
11	j	150.00	36.97	36.97	47.62	500	0.0015	32.00	28.57	3.43	28.78	0.42	0.60	-	1.49	6.28
12	j	150.00	36.97	36.97	47.62	500	0.0015	32.00	28.42	3.58	28.63	0.37	0.56	-	1.49	6.28
13	j	150.00	36.97	36.97	47.62	500	0.0015	32.00	28.20	3.80	28.41	0.37	0.56	-	1.49	6.28
14	j	100.00	36.97	36.97	47.62	500	0.0015	31.40	27.98	3.42	28.19	0.42	0.59	-	1.49	6.28
15	j	140.00	36.97	36.97	47.62	500	0.0015	31.40	27.98	3.42	28.19	0.37	0.56	-	1.54	6.26
16	j	150.00	36.97	36.97	47.62	500	0.0015	31.00	27.75	3.25	27.96	0.42	0.60	-	1.49	6.28
17	j	150.00	36.97	36.97	47.62	500	0.0015	31.00	27.53	3.47	27.74	0.37	0.56	-	1.51	6.27
18	j	100.00	36.97	36.97	47.62	500	0.0015	31.00	27.38	3.62	27.59	0.42	0.60	-	1.51	6.27
19	j	61.067	36.97	36.97	47.62	500	0.0015	31.00	27.38	3.62	27.66	0.48	0.64	-	1.83	6.90
20	j	77.57	36.97	36.97	47.62	500	0.0015	31.00	27.17	3.83	27.45	0.57	0.68	-	1.80	23.252
21	j	60.22	36.97	36.97	47.62	500	0.0015	31.00	27.17	3.83	27.46	0.49	0.63	-	1.80	29.951
22	j	77.57	36.97	36.97	47.62	500	0.0015	31.00	26.95	4.05	27.24	0.57	0.67	-	1.80	6.91

**Table 2 (2/18) Trunk Sewer Hydraulic Calculation of Acari Sewer District**

manhole o / j	Construction Method	Area (ha)	length (m)	upstream		downstream		trunk sewer		cota NA final (m)		tractive tension (Pa)		velocity critical velocity Vc (m/s)		Page Notes: entrance flow (l/s);	
				initial	final	initial	final	upstream	downstream	upstream	downstream	initial	final	initial	final	initial	final
16	j	150.00	60.22	60.22	500	0.0015	31.00	26.95	4.05	27.24	0.49	0.63	-	-	1.80	6.91	
17	j	150.00	77.57	77.57	500	0.0015	30.60	26.73	3.87	27.02	0.57	0.67	-	-	1.87	6.88	
17	j	150.00	60.22	60.22	500	0.0015	30.60	26.73	3.87	27.01	0.48	0.64	-	-	1.87	6.88	
18	j	100.00	77.57	77.57	500	0.0015	30.40	26.50	3.90	26.78	0.56	0.68	-	-	1.99	7.15	
18	j	100.00	74.45	74.45	500	0.0015	30.40	26.50	3.90	26.83	0.55	0.67	-	-	1.99	7.15	
19	j	37.355	95.89	95.89	500	0.0015	30.00	26.35	3.65	26.68	0.66	0.71	-	-	14.223	18.321	
19	j	100.00	74.45	74.45	500	0.0015	30.00	26.35	3.65	26.68	0.55	0.67	-	-	1.99	7.15	
20	j	100.00	95.89	95.89	500	0.0015	28.80	26.20	2.60	26.53	0.66	0.71	-	-	1.99	7.15	
20	j	110.00	74.45	74.45	500	0.0017	28.80	25.44	3.36	25.90	0.44	0.97	-	-	1.99	7.15	
21	j	42.954	95.89	95.89	337.13	0.0017	28.50	25.25	3.25	25.71	0.51	1.03	-	-	3.55	8.96	
21	j	130.00	262.05	262.05	900	0.0017	28.50	25.25	3.25	25.71	0.44	0.96	-	-	3.50	8.98	
22	j	130.00	337.13	337.13	900	0.0017	28.20	25.03	3.17	25.49	0.51	1.02	-	-	3.50	8.98	
22	j	130.00	262.05	262.05	900	0.0017	28.20	25.03	3.17	25.49	0.44	0.96	-	-	3.50	8.98	
23	j	130.00	337.13	337.13	900	0.0017	27.80	24.81	2.99	25.27	0.51	1.02	-	-	3.50	8.98	
23	o	130.00	262.05	262.05	900	0.0017	27.80	24.81	2.99	25.27	0.44	0.96	-	-	3.50	8.98	
24	o	130.00	337.13	337.13	900	0.0017	27.50	24.59	2.91	25.05	0.51	1.02	-	-	3.50	8.98	
24	o	100.00	278.40	278.40	900	0.0017	27.50	24.59	2.91	25.07	0.46	0.98	-	-	3.59	9.08	
25	o	100.00	358.19	358.19	900	0.0032	27.15	24.42	2.73	24.90	0.53	1.04	-	-	16.355	21.067	
25	o	100.00	278.40	278.40	900	0.0032	27.15	24.42	2.73	24.81	0.38	1.23	-	-	5.98	8.53	
26	o	100.00	358.19	358.19	900	0.0008	26.80	24.10	2.70	24.49	0.44	1.32	-	-	5.98	8.53	
26	o	15.473	284.29	284.29	900	0.0008	26.80	24.10	2.70	24.73	0.58	0.74	-	-	1.97	9.70	
27	o	100.00	365.78	365.78	900	0.0008	27.00	24.02	2.98	24.65	0.70	0.78	-	-	5.892	7.589	
27	o	100.00	284.29	284.29	900	0.0008	27.00	24.02	2.98	24.65	0.58	0.74	-	-	1.97	9.70	
28	-	104.00	365.78	365.78	900	0.0004	27.83	23.80	4.03	24.57	0.76	0.78	-	-	1.97	9.70	
28	-	104.00	284.29	284.29	1000	0.0004	27.83	23.80	4.03	24.60	0.63	0.55	-	-	1.97	9.70	
29	-	300.54	300.54	300.54	1000	0.0004	27.98	23.78	4.20	24.55	0.76	0.57	-	-	1.97	9.70	
29	-	42.676	53.00	386.71	386.71	1000	0.0004	27.98	23.78	4.20	24.55	0.77	0.60	-	-	1.97	9.70
30	-	100.00	300.54	300.54	1000	0.0004	27.98	23.78	4.20	24.52	0.61	0.60	-	-	1.97	9.70	
31	-	100.00	386.71	386.71	1000	0.0004	28.06	23.74	4.32	24.47	0.74	0.63	-	-	1.24	10.30	
31	-	85.00	300.54	300.54	1000	0.0009	28.06	23.74	4.32	24.32	0.49	0.78	-	-	2.15	9.81	
32	-	85.00	386.71	386.71	1000	0.0009	28.02	23.66	4.36	24.24	0.58	0.83	-	-	2.15	9.81	

**Table 2 (3/18) Trunk Sewer Hydraulic Calculation of Acari Sewer District**

manhole o / j	Construction Method	Area (ha)	length (m)	upstream		downstream		ground level (m)		trunk sewer level (m)		trunk sewer depth (m)		cota NA final (m)		tractive tension (Pa)		velocity critical velocity Vc (m/s)		Page 3 Notes: entrance flow (l/s);		
				initial	final	initial	final	upstream	downstream	upstream	downstream	initial	final	V <sub>initial</sub>	V <sub>final</sub>	h/d (m/m)	initial	final	initial	final		
32	-	100.00	300.54	300.54	1000	0.0004	28.02	23.66	-	24.46	0.67	0.55	-	-	0.56	0.66	0.66	0.66	0.66	0.66	EXISTING	
33	-	74.00	300.54	300.54	1000	0.0006	28.16	23.63	4.53	24.43	0.80	0.56	-	-	1.02	1.02	1.02	1.02	1.02	1.02	EXISTING	
33	-	10.00	300.54	300.54	1000	0.0110	28.02	23.59	4.43	24.26	0.67	0.70	-	-	1.52	1.52	1.52	1.52	1.52	1.52	EXISTING	
34	-	73.00	300.54	300.54	1000	0.0007	28.11	23.48	4.63	23.87	0.25	1.94	-	-	16.14	16.14	16.14	16.14	16.14	16.14	EXISTING	
35	-	31.500	85.00	312.54	312.54	1000	0.0004	27.93	23.43	4.51	23.76	0.28	2.08	-	-	1.52	1.52	1.52	1.52	1.52	1.52	EXISTING
36	-	95.00	402.16	312.54	312.54	1000	0.0009	27.66	23.39	4.27	24.17	0.63	0.75	-	-	1.75	1.75	1.75	1.75	1.75	1.75	EXISTING
37	-	79.00	402.16	312.54	312.54	1000	0.0011	27.51	23.30	4.21	23.97	0.65	0.59	-	-	1.18	1.18	1.18	1.18	1.18	1.18	EXISTING
38	-	85.00	402.16	312.54	312.54	1000	0.0007	27.14	23.21	4.21	23.88	0.58	0.86	-	-	2.32	2.32	2.32	2.32	2.32	2.32	EXISTING
39	-	67.00	312.54	324.54	324.54	1200	0.0010	26.89	23.16	4.21	23.85	0.47	0.86	-	-	2.69	2.69	2.69	2.69	2.69	2.69	EXISTING
40	-	31.512	417.62	312.54	324.54	1200	0.0005	26.89	23.16	4.73	23.76	0.54	0.92	-	-	9.81	9.81	9.81	9.81	9.81	9.81	EXISTING
41	-	59.00	417.62	324.54	324.54	1200	0.0003	26.89	23.16	4.73	23.76	0.55	0.71	-	-	1.77	1.77	1.77	1.77	1.77	1.77	EXISTING
41	-	67.00	417.62	324.54	324.54	1200	0.0010	26.80	23.13	3.67	23.98	0.84	0.55	-	-	0.99	0.99	0.99	0.99	0.99	0.99	EXISTING
42	-	43.00	417.62	324.54	324.54	1200	0.0004	26.14	21.65	4.54	22.38	0.38	0.83	-	-	2.46	2.46	2.46	2.46	2.46	2.46	EXISTING
42	-	79.00	417.62	324.54	324.54	1200	0.0005	26.86	21.80	5.06	22.31	0.43	0.88	-	-	9.79	9.79	9.79	9.79	9.79	9.79	EXISTING
43	-	59.00	417.62	324.54	324.54	1200	0.0002	26.95	21.77	5.18	22.42	0.54	0.67	-	-	1.35	1.35	1.35	1.35	1.35	1.35	EXISTING
43	-	59.00	417.62	324.54	324.54	1200	0.0021	26.19	21.65	4.54	22.08	0.36	1.16	-	-	4.48	4.48	4.48	4.48	4.48	4.48	EXISTING
44	-	43.00	417.62	324.54	324.54	1200	0.0004	26.14	21.65	4.54	22.33	0.49	0.59	-	-	1.17	1.17	1.17	1.17	1.17	1.17	EXISTING
45	-	79.00	417.62	324.54	324.54	1200	0.0004	25.63	21.60	4.51	22.32	0.57	0.63	-	-	#NUM!	#NUM!	#NUM!	#NUM!	#NUM!	#NUM!	EXISTING
46	-	79.00	417.62	324.54	324.54	1200	0.0005	25.47	21.56	3.91	22.83	1.06	#NUM!	-	-	1.88	1.88	1.88	1.88	1.88	1.88	EXISTING
47	-	79.00	417.62	324.54	324.54	1200	0.0019	25.47	21.56	3.91	22.33	0.54	1.35	-	-	6.05	6.05	6.05	6.05	6.05	6.05	EXISTING
47	-	79.00	417.62	324.54	324.54	1200	0.0019	24.81	21.41	3.40	22.18	0.64	1.43	-	-	#NUM!	#NUM!	#NUM!	#NUM!	#NUM!	#NUM!	EXISTING
48	-	1084.19	1084.19	1084.19	1084.19	1200	0.0019	24.81	21.41	3.40	22.18	0.64	1.43	-	-	#NUM!	#NUM!	#NUM!	#NUM!	#NUM!	#NUM!	EXISTING

**Table 2 (4/18) Trunk Sewer Hydraulic Calculation of Acari Sewer District**

manhole	Construction Method o /j	Area (ha)	length (m)	upstream flow (l/s) initial	diam. (mm) final	slope (m/m) initial	ground level (m) upstream	trunk sewer level (m) downstream	trunk sewer depth (m) upstream	cota NA final (m) initial	b/d (m/m) initial	tractive tension (Pa) final	critical velocity Vc (m/s)	Page 4 Notes: entrance flow (l/s):	
48	-	20.00	842.02	842.02	1200	0.0097	24.81	21.41	.40	21.88	0.35	2.46	-	EXISTING	
49	-	63.00	842.02	842.02	1500	0.0015	25.01	21.21	.80	21.68	0.39	2.62	-	EXISTING	
49	-	69.00	842.02	842.02	1500	0.0089	24.52	21.12	.40	21.83	0.41	1.21	-	4.79	11.32
50	-	123.00	842.02	842.02	1500	0.0018	24.52	21.12	.40	21.56	0.26	2.33	-	EXISTING	
52	-	74.00	842.02	842.02	1500	0.0035	23.97	20.28	.69	20.94	0.29	2.49	-	20.06	9.38
53	-	107.00	842.02	842.02	1500	0.0027	23.97	20.28	.69	20.84	0.33	1.68	-	EXISTING	
53	-	4.00	842.02	842.02	1500	0.0347	23.59	20.03	.56	20.59	0.38	1.78	-	9.71	10.40
54	-	48.00	842.02	842.02	1500	0.0016	22.93	19.74	.19	20.34	0.40	1.62	-	EXISTING	
55	-	78.00	842.02	842.02	1500	0.0048	22.49	19.60	.89	19.91	0.21	4.08	-	7.80	10.67
56	-	82.00	842.02	842.02	1500	0.0025	22.49	19.60	.89	20.29	0.40	1.27	-	58.61	8.15
56	-	1084.19	842.02	842.02	1500	0.0036	23.17	19.52	.65	20.21	0.46	1.35	-	EXISTING	
57	-	1084.19	842.02	842.02	1500	0.0017	23.17	19.52	.65	20.04	0.30	1.86	-	12.28	10.09
57	-	81.00	842.02	842.02	1500	0.0026	22.98	19.15	.83	19.67	0.35	2.02	-	EXISTING	
58	-	1084.19	842.02	842.02	1500	0.0033	22.72	18.94	.78	19.55	0.36	1.49	-	7.53	10.71
59	-	81.00	842.02	842.02	1500	0.0019	22.52	18.65	.87	19.20	0.33	1.70	-	9.99	10.37
59	-	75.00	842.02	842.02	1500	0.0017	22.52	18.65	.87	19.33	0.40	1.28	-	EXISTING	
60	-	81.00	842.02	842.02	1500	0.0026	22.16	18.31	.85	18.92	0.41	1.59	-	5.37	11.16
60	-	81.00	842.02	842.02	1500	0.0030	21.87	18.07	.80	18.65	0.39	1.70	-	7.54	10.71
61	-	1084.19	842.02	842.02	1500	0.0025	21.87	18.07	.80	18.64	0.34	1.65	-	EXISTING	
61	-	81.00	842.02	842.02	1500	0.0033	21.28	17.80	.48	18.37	0.38	1.76	-	9.39	10.44
62	-	93.00	842.02	842.02	1500	0.0025	21.28	17.39	.89	18.00	0.36	1.48	-	EXISTING	
63	-	1084.19	842.02	842.02	1500	0.0029	21.29	17.16	.13	17.77	0.41	1.58	-	7.37	10.74

**Table 2 (5/18) Trunk Sewer Hydraulic Calculation of Acari Sewer District**

manhole o / j	Construction Method	Area (ha)	length (m)	upstream		downstream		ground level		trunk sewer depth (m)		cota NA final (m)		tractive tension (Pa)		velocity critical velocity Vc (m/s)		Page Notes: entrance flow (l/s);	
				initial	final	initial	final	upstream	downstream	upstream	downstream	initial	final	V <sub>initial</sub>	V <sub>final</sub>	5			
64	-	76.00	842.02	842.02	1500	0.0025	-	21.29	17.16	4.13	17.77	0.36	1.48	-	7.38	10.74	EXISTING		
65	-	81.00	842.02	842.02	1500	0.0025	-	21.21	16.97	4.24	17.58	0.41	1.58	-	7.42	10.73	EXISTING		
66	-	81.00	842.02	842.02	1500	0.0025	-	21.03	16.77	4.26	17.38	0.41	1.58	-	7.42	10.73	EXISTING		
67	-	81.00	842.02	842.02	1500	0.0025	-	20.78	16.57	4.21	17.18	0.41	1.58	-	7.42	10.73	EXISTING		
68	-	81.00	842.02	842.02	1500	0.0025	-	20.78	16.57	4.21	17.18	0.36	1.48	-	7.39	10.73	EXISTING		
69	-	81.00	842.02	842.02	1500	0.0025	-	20.63	16.36	4.27	16.98	0.41	1.58	-	7.39	10.73	EXISTING		
70	-	76.00	842.02	842.02	1500	0.0025	-	20.44	16.16	4.28	16.77	0.36	1.48	-	7.38	10.74	EXISTING		
71	-	82.00	842.02	842.02	1500	0.0025	-	20.18	15.97	4.21	16.59	0.41	1.58	-	7.41	10.73	EXISTING		
72	-	80.00	842.02	842.02	1500	0.0025	-	20.18	15.97	4.21	16.58	0.36	1.48	-	7.38	10.74	EXISTING		
73	-	81.00	842.02	842.02	1500	0.0025	-	19.91	15.77	4.15	16.38	0.41	1.58	-	7.42	10.73	EXISTING		
74	-	81.00	842.02	842.02	1500	0.0025	-	19.91	15.77	4.15	16.38	0.36	1.48	-	7.38	10.74	EXISTING		
75	-	81.00	842.02	842.02	1500	0.0025	-	19.72	15.57	4.15	16.18	0.41	1.58	-	7.42	10.73	EXISTING		
76	-	72.00	842.02	842.02	1500	0.0025	-	19.72	15.57	4.15	16.18	0.36	1.48	-	7.42	10.73	EXISTING		
77	-	104.00	842.02	842.02	1500	0.0025	-	19.38	15.16	4.21	15.77	0.41	1.58	-	7.42	10.73	EXISTING		
78	-	81.00	842.02	842.02	1500	0.0025	-	19.02	14.96	4.07	15.57	0.41	1.58	-	7.42	10.73	EXISTING		
79	j	80.00	842.02	842.02	1500	0.0025	-	18.91	14.76	4.15	15.37	0.41	1.58	-	7.42	10.73	EXISTING		
79	j	412.922	150.00	1286.71	1286.71	0.0083	-	18.93	14.58	4.35	15.19	0.36	1.48	-	7.41	10.73	EXISTING		
80	-	999.25	1084.19	1084.19	1084.19	0.0083	-	18.15	13.65	4.50	14.09	0.28	2.38	-	18.98	9.45	EXISTING		
80	-	150.00	1286.71	1286.71	1286.71	0.0083	-	17.40	12.40	5.00	12.90	0.33	2.59	-	20.38	9.92	157.226	202.522	

**Table 2 (6/18) Trunk Sewer Hydraulic Calculation of Acari Sewer District**

manhole	Construction Method o /j	Area (ha)	length (m)	upstream		downstream		slope (m/m)	diam. (mm)	ground level (m)		trunk sewer depth (m)		NA final (m)	h/d (m/m)	initial V <sub>initial</sub> (m/s)	final V <sub>final</sub> (m/s)	velocity critical velocity V <sub>c</sub> (m/s)	Prage Notes: entrance flow (l/s):
				initial	final	initial	final			upstream	downstream	upstream	downstream						
80	j	90.00	99.25	99.25	1500	0.0083	17.40	-	-	11.65	-	5.35	12.15	0.33	2.59	-	20.38	9.92	
81	j	110.00	99.25	1286.71	1441.63	0.0015	17.00	10.92	-	0.08	11.92	-	0.56	1.42	-	6.19	12.41		
82	j	40.00	1441.63	1286.71	1856.55	0.0015	16.30	10.75	-	5.55	11.75	0.66	1.51	-	1.41	1.76	0.56	12.44	
83	j	30.00	1856.55	1458.62	1458.62	0.0010	16.10	10.69	-	5.41	11.70	0.67	1.49	-	6.04	11.87	0.65	1.21	
ETE																		4.33	
TOTAL																		12.69	
																		21.887	

ACARI SEWERAGE DISTRICT TRUNK SEWER HYDRAULIC CONCEPT DESIGN																			
No.1-1 TRUNK SEWER																			
manhole	Construction Method o /j	Area (ha)	length (m)	upstream		downstream		slope (m/m)	diam. (mm)	ground level (m)		trunk sewer depth (m)		NA final (m)	h/d (m/m)	initial V <sub>initial</sub> (m/s)	final V <sub>final</sub> (m/s)	velocity critical velocity V <sub>c</sub> (m/s)	Prage Notes: entrance flow (l/s):
				initial	final	initial	final			upstream	downstream	upstream	downstream						
20.1	j	102.984	135.00	-	50.44	50.44	50.44	0.0015	500	28.00	22.80	.520	23.02	0.44	0.60	-	1.53	39.212	
20.2	j	135.00	39.21	-	50.44	50.44	50.44	0.0015	500	28.00	22.80	.520	23.02	0.38	0.57	-	1.53	50.439	
20.3	j	38.350	5.00	-	53.81	53.81	53.81	0.0020	500	27.00	22.60	.440	22.82	0.44	0.60	-	1.53	6.35	
EE-1																		14.602	
TOTAL																		18.809	
RECALCULATE: L=480m e D=100mm																			
20.4	j	11.315	150.00	4.31	58.12	500	0.0100	-	32.00	30.00	-	2.00	30.17	0.28	1.25	-	8.13	4.308	
20.5	j	150.00	5.55	-	74.80	58.12	58.12	0.0100	500	33.00	28.50	.450	28.67	0.33	1.36	-	5.72	5.550	
20.6	j	150.00	74.80	-	127.69	99.18	99.18	0.0100	500	32.00	27.00	.500	27.17	0.33	1.36	-	8.13	5.72	
20.6	j	107.836	50.00	-	127.69	127.69	127.69	0.0047	500	29.00	26.50	.500	27.22	0.38	1.46	-	10.24	41.059	
20.7	j	150.00	99.18	-	127.69	99.18	99.18	0.0047	500	29.00	26.50	.500	26.77	0.46	1.10	-	12.32	52.889	
20.8	j	150.00	127.69	-	99.18	99.18	99.18	0.0047	500	29.00	25.80	.320	26.07	0.54	1.18	-	5.55	6.81	
20.8	j	150.00	127.69	-	127.69	127.69	127.69	0.0047	500	28.00	25.80	.320	26.07	0.46	1.11	-	5.61	6.80	
20.9																		25.36	

**Table 2 (7/18) Trunk Sewer Hydraulic Calculation of Acari Sewer District**

manhole	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s)	diam.	slope (m/m)	ground level (m)	trunk sewer level (m)	trunk sewer depth (m)	cota NA final (m)	h/d (m/m)	trative tension (Pa)	critical velocity Vc (m/s)	Page Notes:
				initial	initial	final	upstream	upstream	downstream	initial	initial	initial	initial	7
				initial	final	final	downstream	downstream	downstream	final	final	final	final	entrance flow (l/s):
20.9	j	100.00	-	99.18	99.18	500	0.0047	28.00	25.09	25.36	0.46	1.10	-	
20.10				127.69	127.69	-	-	28.00	24.62	24.89	-	5.58	6.80	
20.10	j	113.72	113.72	-	113.72	500	0.0050	28.00	24.62	3.38	0.54	1.18	-	
EE-2				-	-	146.42	-	-	-	24.91	0.49	1.17	-	
TOTAL				758.00				28.00	24.58	3.42	0.58	1.25	-	
<b>RECALCULATE: L=10m e D=50mm</b>														
20.11	o	119.00	0.00	113.72	-	700	0.0009	28.00	25.90	2.10	26.29	0.48	0.62	
20.12			0.00	146.42	-	-	-	28.00	25.80	2.20	26.19	0.56	0.66	
20.12	o	60.00	113.72	113.72	-	700	0.0009	28.00	25.80	2.20	26.20	0.49	0.61	
20.13				146.42	146.42	-	-	-	-	-	-	1.49	8.18	
20.13	o	14.190	150.00	119.13	119.13	700	0.0009	28.00	25.75	2.25	26.15	0.57	0.65	
20.14				-	-	153.38	-	29.40	25.62	3.78	0.59	0.65	-	
20.14	o	179.124	95.00	187.60	187.60	700	0.0009	29.40	25.62	3.78	26.16	0.50	0.61	
20.15				-	-	241.23	241.23	29.30	25.55	3.77	26.17	0.66	0.71	
20.15	o	95.00	187.60	187.60	-	700	0.0009	29.30	25.55	3.77	26.08	0.66	0.71	
20(No.1 TS)				-	-	241.23	241.23	-	-	25.44	3.36	25.99	0.79	0.73
TOTAL				510.00						3.36				

JICA	ACARI SEWERAGE DISTRICT TRUNK SEWER HYDRAULIC CONCEPT DESIGN No.2 TRUNK SEWER													
manhole	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s)	diam.	slope (m/m)	ground level (m)	trunk sewer level (m)	trunk sewer depth (m)	cota NA final (m)	h/d (m/m)	trative tension (Pa)	critical velocity Vc (m/s)	Page Notes:
				initial	initial	final	upstream	upstream	downstream	initial	initial	initial	initial	7
1	o	89.088	150.00	33.92	33.92	400	0.0020	36.40	34.40	2.00	34.61	0.45	0.61	
2	j	130.00	-	43.69	43.69	-	-	36.80	34.10	2.70	34.31	0.45	0.61	
3	j	43.69	58.73	58.73	58.73	500	0.0020	37.00	33.84	-	34.05	0.52	0.65	
3	j	58.73	-	75.65	75.65	-	-	37.00	33.74	3.26	33.99	0.44	0.70	
4	j	65.147	150.00	58.73	58.73	500	0.0020	37.30	33.44	-	33.69	0.51	0.75	
4	j	150.00	-	75.65	75.65	-	-	37.30	33.44	3.86	33.69	0.44	0.70	
5	j	58.73	58.73	58.73	58.73	500	0.0020	37.00	33.14	-	33.39	0.51	0.75	
5	j	120.00	-	75.65	75.65	-	-	37.80	33.14	3.86	33.39	0.44	0.70	
6	j	120.00	75.65	-	-	-	-	37.80	32.90	4.90	33.15	0.51	0.75	

**Table 2 (8/18) Trunk Sewer Hydraulic Calculation of Acari Sewer District**

manhole	Construction Method o /j	Area (ha)	length (m)	upstream flow (l/s)	diam.	slope (m/m)	ground level (m)	trunk sewer level (m)	trunk sewer depth (m)	NA final (m)	b/d (m/m)	tractive tension (Pa)	critical velocity (m/s)	Page Notes:
				initial	initial	final	upstream	upstream	upstream	initial	initial	V <sub>initial</sub>	V <sub>c</sub> (m/s)	entrance flow (l/s):
				initial	final		downstream	downstream	downstream	final	final	V <sub>final</sub>		
6	j	156.685	150.00	118.39	118.39	0.0030	37.80	32.90	4.90	33.26	0.60	0.98	4.15	7.25
7	j	152.49	152.49	-	500	0.0030	36.60	32.45	4.15	32.81	0.71	1.03	-	59.659
7	j	130.00	118.39	118.39	-	500	0.0030	36.60	32.45	4.15	32.81	0.60	0.98	76.847
8	j	152.49	152.49	152.49	-	500	-	-	-	-	-	-	-	4.15
8	j	20.00	118.39	118.39	-	500	0.0030	36.30	32.06	4.24	32.42	0.71	1.03	7.25
9	j	152.49	152.49	152.49	-	500	-	-	-	32.42	0.60	0.98	-	4.15
9	j	110.00	118.39	118.39	-	500	0.0030	36.30	32.00	4.30	32.36	0.71	1.03	7.25
10	j	152.49	152.49	152.49	-	500	0.0030	36.00	31.67	4.33	32.36	0.60	0.98	4.15
10	j	110.00	118.39	118.39	-	500	0.0030	36.00	31.67	4.33	32.03	0.71	1.03	7.25
11	j	152.49	152.49	152.49	-	500	0.0030	35.80	31.34	4.46	31.70	0.71	1.03	4.15
11	j	150.00	118.39	218.86	-	900	0.0013	35.80	30.94	4.86	31.39	0.43	0.82	7.25
12	j	152.49	281.91	281.91	-	900	0.0013	35.30	30.75	4.55	31.20	0.50	0.88	2.58
12	j	218.86	218.86	-	900	0.0013	35.30	30.75	4.55	31.20	0.43	0.83	-	8.92
13	j	281.91	281.91	-	900	0.0013	35.00	30.58	4.42	31.03	0.50	0.89	-	2.65
13	j	218.86	218.86	-	900	0.0013	35.00	30.58	4.42	31.03	0.43	0.83	-	8.89
14	j	281.91	281.91	-	900	0.0013	34.95	30.41	4.54	30.86	0.50	0.89	-	2.65
14	j	235.36	235.36	-	900	0.0013	34.95	30.41	4.54	30.88	0.45	0.84	-	8.89
15	j	303.16	303.16	-	900	0.0013	34.90	30.22	4.68	30.69	0.52	0.90	-	16.499
15	j	235.36	235.36	-	900	0.0013	34.90	30.22	4.68	30.69	0.45	0.84	-	21.252
16	j	303.16	303.16	-	900	0.0013	34.85	30.03	4.82	30.50	0.52	0.90	-	9.05
16	j	235.36	235.36	-	900	0.0013	34.85	30.03	4.82	30.50	0.45	0.84	-	9.05
17	j	303.16	303.16	-	900	0.0013	34.80	29.84	4.96	30.31	0.52	0.90	-	9.05
17	j	235.36	235.36	-	900	0.0013	34.80	29.84	4.96	30.31	0.45	0.84	-	9.05
18	j	303.16	303.16	-	900	0.0013	34.40	29.65	4.75	30.12	0.52	0.90	-	2.66
18	j	235.36	235.36	-	900	0.0013	34.40	29.65	4.75	30.11	0.44	0.85	-	9.05
19	j	303.16	303.16	-	900	0.0013	33.80	29.45	4.35	29.91	0.52	0.91	-	2.77
19	j	235.36	235.36	-	900	0.0013	33.80	29.45	4.35	29.91	0.44	0.85	-	9.05
20	j	303.16	303.16	-	900	0.0013	33.00	29.25	3.75	29.71	0.52	0.91	-	2.77
20	j	235.36	261.22	-	900	0.0025	33.00	27.30	5.70	27.71	0.40	1.11	-	9.05
21	j	336.48	336.48	-	900	0.0025	33.00	27.20	.80	27.61	0.45	1.18	-	4.78
21	j	401.55	261.22	-	1200	0.0008	33.00	26.90	6.10	27.53	0.45	0.81	-	8.63
22	j	336.48	517.24	-	1200	0.0008	32.90	26.86	6.04	27.49	0.52	0.86	-	25.860
22	j	50.00	336.48	-	1200	0.0008	32.90	26.86	6.04	27.49	0.52	0.86	-	33.311

**Table 2 (9/18) Trunk Sewer Hydraulic Calculation of Acari Sewer District**

manhole no / j	Construction Method o / j	Area (ha)	length (m)	upstream		downstream		ground level (m)		trunk sewer level (m)		trunk sewer depth (m)		NA final (m)		h/d (m/m)		traeive tension (Pa)		velocity critical velocity Notes: Vc (m/s)		Page 9 entrance flow (l/s);		
				initial		final		upstream		upstream		downstream		downstream		initial		initial		final		final		
				diam. (mm)	slope (m/m)	diam. (mm)	slope (m/m)	upstream	upstream	downstream	downstream	upstream	downstream	V <sub>initial</sub>	V <sub>final</sub>	V <sub>initial</sub>	V <sub>final</sub>	V <sub>initial</sub>	V <sub>final</sub>	V <sub>initial</sub>	V <sub>final</sub>	V <sub>initial</sub>	V <sub>final</sub>	
22	j	110.00	401.55	401.55	-	1200	0.0008	-	32.90	26.86	6.04	27.48	0.45	0.81	-	-	-	-	-	-	2.27	10.42		
23	j	110.00	517.24	517.24	401.55	1200	0.0008	-	32.80	26.77	6.03	27.39	0.45	0.81	27.39	0.45	0.81	0.87	0.87	-	-	-	-	
23	j	110.00	517.24	517.24	401.55	1200	0.0008	-	32.80	26.77	6.03	27.39	0.45	0.81	-	-	-	-	-	-	2.27	10.42		
24	j	150.00	408.94	408.94	-	1200	0.0008	-	32.70	26.68	6.02	27.30	0.45	0.81	27.32	0.45	0.81	0.87	0.87	-	-	-	-	
24	j	150.00	526.76	526.76	408.94	1200	0.0008	-	32.70	26.68	6.02	27.30	0.45	0.81	-	-	-	-	-	-	2.25	10.48	7.388	9.517
25	j	150.00	408.94	408.94	-	1200	0.0008	-	32.50	26.56	5.94	27.20	0.45	0.81	-	-	-	-	-	-	2.25	10.48		
25	j	150.00	526.76	526.76	408.94	1200	0.0008	-	31.00	26.44	4.56	27.08	0.53	0.87	-	-	-	-	-	-	2.25	10.48		
26	j	150.00	408.94	408.94	-	1200	0.0054	-	31.00	26.44	4.56	27.08	0.53	0.87	-	-	-	-	-	-	2.25	10.48		
26	j	150.00	526.76	526.76	408.94	1200	0.0054	-	30.00	25.63	4.37	26.02	0.27	1.62	-	-	-	-	-	-	10.22	8.75		
27	j	80.00	417.99	417.99	498.95	1200	0.0054	-	30.00	25.63	4.37	26.05	0.31	1.74	-	-	-	-	-	-	11.46	9.048	11.654	
27	j	80.00	-	-	538.41	642.70	0.0054	-	29.00	25.20	3.80	25.62	0.35	1.85	-	-	-	-	-	-	11.38	9.06		
28	j	150.00	498.95	498.95	-	1200	0.0053	-	29.00	25.20	3.80	25.62	0.31	1.74	-	-	-	-	-	-	11.44	9.06		
28	j	150.00	642.70	642.70	498.95	1200	0.0053	-	28.00	24.40	3.60	24.82	0.31	1.74	-	-	-	-	-	-	11.38	9.06		
29	j	110.00	498.95	498.95	-	1200	0.0054	-	28.00	24.40	3.60	24.82	0.31	1.74	-	-	-	-	-	-	11.44	9.06		
29	j	110.00	642.70	642.70	498.95	1200	0.0054	-	28.00	23.81	4.19	24.23	0.35	1.85	-	-	-	-	-	-	11.38	9.06		
30	j	32.030	70.00	-	511.15	1200	0.0054	-	28.00	23.81	4.19	24.23	0.32	1.76	-	-	-	-	-	-	11.64	9.09	12.196	15.709
31	j	100.00	658.41	658.41	511.15	1200	0.0053	-	28.00	23.43	4.57	23.85	0.35	1.86	-	-	-	-	-	-	11.41	9.11		
31	j	100.00	658.41	658.41	511.15	1200	0.0040	-	26.50	22.90	3.60	23.33	0.32	1.74	-	-	-	-	-	-	11.41	9.11		
32	j	150.00	517.49	517.49	-	1200	0.0040	-	26.30	22.30	4.00	22.76	0.34	1.57	-	-	-	-	-	-	9.07	9.37	6.336	8.162
33	j	120.00	517.49	517.49	-	1200	0.0040	-	26.30	22.30	4.00	22.76	0.34	1.57	-	-	-	-	-	-	9.07	9.37		
45 (No.1 TS)	TOTAL	4,070,000																						

**Table 2 (10/18) Trunk Sewer Hydraulic Calculation of Acari Sewer District**

JICA		ACARI SEWERAGE DISTRICT TRUNK SEWER HYDRAULIC CONCEPT DESIGN No. 2-1 TRUNK SEWER													
manhole	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s) initial	downstream flow (l/s) final	diam. (mm)	slope (m/m)	ground level (m)	trunk sewer level (m)	trunk sewer depth (m)	cota NA final (m)	h/d (m/m)	velocity (m/s)	critical velocity (m/s)	Page Notes:
				initial	final			upstream	upstream	upstream	initial	initial	V <sub>initial</sub>	V <sub>final</sub>	10
11.1	j	47.574	110.00	18.11	500	0.0015	45.00	40.50	4.50	40.64	0.25	0.46	-	1.14	5.38
11.2	j	43.206	130.00	34.57	500	0.0015	44.00	40.33	3.67	40.47	0.29	0.49	-	-	18.114
11.3	j	80.00	44.52	34.57	500	0.0015	42.80	40.14	2.66	40.34	0.41	0.58	-	1.45	6.20
11.4	j	150.00	44.52	44.52	500	0.0015	43.00	40.02	2.98	40.22	0.41	0.59	-	-	16.451
11.5	j	150.00	56.38	56.38	500	0.0020	42.30	38.50	4.50	38.71	0.37	0.65	-	-	21.191
11.6	j	150.00	56.38	56.38	500	0.0020	42.30	38.22	4.08	38.43	0.37	0.65	-	-	9.206
11.7	j	150.00	56.38	56.38	500	0.0020	42.30	38.22	4.08	38.43	0.37	0.65	-	-	11.859
11.8	j	150.00	56.38	56.38	500	0.0020	42.00	37.92	4.08	38.13	0.43	0.69	-	-	-
11.9	o	135.496	30.00	43.77	500	0.0020	41.50	37.62	3.88	37.83	0.43	0.69	-	-	-
11.10	o	13.427	150.00	56.38	500	0.0020	41.50	37.62	3.88	37.83	0.37	0.65	-	-	-
11.11	o	150.00	120.00	43.77	500	0.0020	41.00	37.32	3.68	37.53	0.43	0.69	-	-	-
11.12	o	150.00	122.84	56.38	700	0.0033	40.20	37.08	3.12	37.29	0.43	0.69	-	-	-
11.13	o	150.00	100.48	100.48	700	0.0036	40.00	36.78	3.22	37.03	0.35	1.02	-	-	4.17
11.14	o	150.00	129.42	129.42	700	0.0036	39.50	36.24	3.26	36.49	0.36	1.06	-	-	6.94
11.15	o	150.00	100.48	100.48	700	0.0036	39.50	36.24	3.26	36.49	0.32	1.00	-	-	6.96
11.16	o	90.00	100.48	100.48	700	0.0042	37.80	35.16	2.64	35.41	0.32	1.00	-	-	4.53
11 (No.2 TS)	TOTAL	1,900.00	129.42	129.42	129.42	0.0036	37.30	35.70	3.30	35.95	0.32	1.00	-	-	6.96
															6.580

**Table 2 (11/18) Trunk Sewer Hydraulic Calculation of Acari Sewer District**

JICA ACARI SEWERAGE DISTRICT TRUNK SEWER HYDRAULIC CONCEPT DESIGN No. 2-2 TRUNK SEWER		ACARI SEWERAGE DISTRICT TRUNK SEWER HYDRAULIC CONCEPT DESIGN No. 2-2 TRUNK SEWER										ACARI SEWERAGE DISTRICT TRUNK SEWER HYDRAULIC CONCEPT DESIGN No. 3 TRUNK SEWER									
manhole	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s)	diam. (mm)	slope (m/m)	ground level (m)	trunk sewer level (m)	trunk sewer depth (m)	cota NA final (m)	h/d (m/m)	velocity (m/s)	trative tension (Pa)	critical velocity Vc (m/s)	Page 11 Notes: entrance flow (l/s):						
manhole	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s)	diam. (mm)	slope (m/m)	ground level (m)	trunk sewer level (m)	trunk sewer depth (m)	cota NA final (m)	h/d (m/m)	velocity (m/s)	trative tension (Pa)	critical velocity Vc (m/s)	Page 11 Notes: entrance flow (l/s):						
27.1	0	112.947	110.00	43.01	43.01	0.0064	35.00	-	2.00	33.17	0.37	1.00	-	5.19	5.63	43.005					
27.2	0	-	55.40	55.40	400	0.0064	34.30	32.30	2.00	32.47	0.43	1.07	-	-	-	55.396					
27.2	0	35.810	90.00	56.64	56.64	0.0064	34.30	32.30	2.00	32.50	0.43	1.08	-	-	-	-					
27.3	-	-	72.96	72.96	400	0.0064	-	-	-	-	-	-	-	-	-	-					
27.3	0	10.164	150.00	60.51	60.51	0.0064	33.90	31.72	2.18	31.92	0.50	1.15	-	-	-	13.636					
27.4	0	-	77.95	77.95	400	0.0064	32.80	30.76	2.04	30.97	0.45	1.09	-	-	-	17.564					
27.4	0	150.00	-	60.51	60.51	0.0064	-	-	-	-	-	-	-	-	-	-					
27.5	-	-	77.95	77.95	400	0.0064	31.80	29.80	2.00	30.01	0.52	1.17	-	-	-	-					
27.5	0	53.715	150.00	80.97	80.97	0.0050	31.80	29.80	2.00	30.08	0.58	1.08	-	-	-	3.870					
27.6	-	-	104.29	104.29	400	0.0050	-	-	-	-	-	-	-	-	-	4.985					
27.6	0	-	80.97	80.97	400	0.0050	31.10	29.05	2.05	29.33	0.69	1.13	-	-	-	-					
27.7	0	120.00	104.29	104.29	400	0.0050	-	-	-	-	-	-	-	-	-	-					
27.7	0	-	80.97	80.97	400	0.0050	31.00	28.45	2.55	28.73	0.58	1.08	-	-	-	-					
27 (No.2 TS)	-	-	104.29	104.29	400	0.0050	-	-	-	-	-	-	-	-	-	-					
TOTAL	-	-	890.00	-	-	-	-	-	-	-	-	-	-	-	-	-					
JICA ACARI SEWERAGE DISTRICT TRUNK SEWER HYDRAULIC CONCEPT DESIGN No. 3 TRUNK SEWER		ACARI SEWERAGE DISTRICT TRUNK SEWER HYDRAULIC CONCEPT DESIGN No. 3 TRUNK SEWER										ACARI SEWERAGE DISTRICT TRUNK SEWER HYDRAULIC CONCEPT DESIGN No. 3 TRUNK SEWER									
manhole	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s)	diam. (mm)	slope (m/m)	ground level (m)	trunk sewer level (m)	trunk sewer depth (m)	cota NA final (m)	h/d (m/m)	velocity (m/s)	trative tension (Pa)	critical velocity Vc (m/s)	Page 11 Notes: entrance flow (l/s):						
manhole	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s)	diam. (mm)	slope (m/m)	ground level (m)	trunk sewer level (m)	trunk sewer depth (m)	cota NA final (m)	h/d (m/m)	velocity (m/s)	trative tension (Pa)	critical velocity Vc (m/s)	Page 11 Notes: entrance flow (l/s):						
1	0	45.641	100.00	17.38	17.38	0.0060	43.00	41.00	2.00	41.11	0.24	0.76	-	-	17.378						
2	0	-	22.39	22.39	400	0.0060	42.40	40.40	2.00	40.51	0.27	0.81	-	-	-	22.385					
2	0	80.00	22.39	22.39	400	0.0060	-	-	-	-	-	-	-	-	-	-					
3	-	-	17.38	17.38	400	0.0060	42.00	39.92	2.08	40.03	0.27	0.81	-	-	-	-					
3	0	150.00	-	22.39	22.39	0.0060	-	-	-	-	-	-	-	-	-	-					
4	-	-	17.38	17.38	400	0.0060	41.10	39.02	2.08	39.13	0.27	0.81	-	-	-	-					
4	0	150.00	-	22.39	22.39	0.0060	-	-	-	-	-	-	-	-	-	-					
5	-	-	17.38	17.38	400	0.0060	40.30	38.12	2.18	38.23	0.27	0.81	-	-	-	-					
5	0	80.00	-	22.39	22.39	0.0060	-	-	-	-	-	-	-	-	-	-					
6	-	-	22.39	22.39	400	0.0060	-	-	-	-	-	-	-	-	-	-					
6	0	-	80.00	22.39	22.39	0.0060	-	-	-	-	-	-	-	-	-	-					

**Table 2 (12/18) Trunk Sewer Hydraulic Calculation of Acari Sewer District**

manhole	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s) initial	downstream flow (l/s) final	diam. (mm)	slope (m/m)	ground level (m) upstream	trunk sewer level (m)	cota NA final (m)	h/d (m/m)	trative tension (Pa)	critical velocity Vc (m/s)	Page Notes: entrance flow (l/s):
				initial	final			upstream	upstream	initial	initial			12
6	o	32.360	60.00	-	29.70	29.70	0.0060	40.00	37.64	2.26	37.78	0.32	4.34	5.28
7	o	80.00	-	38.26	38.26	400	0.0125	39.30	37.28	2.02	37.42	0.36	0.95	12.322 15.871
8	o	150.00	-	38.26	38.26	400	0.0125	39.30	37.28	2.02	37.40	0.26	1.15	-
9	o	150.00	-	38.26	38.26	400	0.0125	38.30	36.28	2.02	36.40	0.29	1.23	-
10	j	150.00	-	38.26	38.26	400	0.0125	38.30	36.28	2.02	36.40	0.26	1.15	-
11	j	60.00	-	38.26	38.26	500	0.0046	35.50	32.43	2.02	34.52	0.29	1.23	-
12	j	130.00	-	38.26	38.26	500	0.0046	35.50	32.53	2.02	34.52	0.26	1.14	-
13	j	100.00	-	33.66	131.00	500	0.0047	34.50	31.74	2.02	32.57	0.25	1.23	-
14	j	10.401	-	43.36	168.74	500	0.0047	34.50	31.47	2.02	31.61	0.25	0.79	-
15	j	100.00	-	131.00	131.00	500	0.0047	33.60	29.39	2.02	29.72	0.65	1.26	-
15	j	140.33	-	168.74	168.74	500	0.0047	33.60	29.39	2.02	29.72	0.55	1.19	-
21 (No.2 TS)	j	24.509	90.00	140.33	140.33	500	0.0047	33.40	28.92	2.02	29.25	0.65	1.26	-
TOTAL			1,630.00	180.76	180.76			33.00	28.50	2.02	28.84	0.69	1.27	9.332 12.020

ACARI SEWERAGE DISTRICT TRUNK SEWER HYDRAULIC CONCEPT DESIGN														
No.3-1 TRUNK SEWER														
manhole	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s) initial	downstream flow (l/s) final	diam. (mm)	slope (m/m)	ground level (m) upstream	trunk sewer depth (m)	cota NA final (m)	h/d (m/m)	trative tension (Pa)	critical velocity Vc (m/s)	velocity Notes: entrance flow (l/s):
				initial	final			upstream	upstream	initial	initial			12
13.1	j	144.665	140.00	-	55.08	500	0.0047	38.00	-	4.00	35.39	0.34	0.95	-
13.2	j	140.00	-	70.95	70.95	500	0.0047	34.54	34.54	-	34.73	0.38	1.01	-
13.2	j	140.00	-	55.08	55.08	500	0.0047	38.00	34.54	-	34.73	0.34	0.95	-
13.3	j	50.00	-	70.95	70.95	500	0.0047	37.00	33.88	-	34.07	0.38	1.01	-
13.3	j	50.00	-	55.08	55.08	500	0.0047	37.00	33.88	-	34.07	0.34	0.95	-
13.4				70.95	70.95			36.50	33.65	-	33.84	0.39	1.01	-

**Table 2 (13/18) Trunk Sewer Hydraulic Calculation of Acari Sewer District**

manhole	Construction Method o /j	Area (ha)	length (m)	upstream		downstream		trunk sewer		cota		velocity critical velocity (m/s)	Prage Notes: entrance flow (l/s): (Pa)
				flow (l/s)		diam. (mm)	slope (m/m)	ground level (m)	depth (m)	NA final (m)	h/d (m/m)		
				initial	final	initial	final	upstream	downstream	initial	final		
13.4	0	110.00	-	55.08	55.08	500	0.0047	36.50	33.65	2.85	33.84	0.34	0.95
13.5	0	110.00	70.95	70.95	70.95	36.00	-	33.13	2.87	33.32	0.39	1.01	6.06
13.5	0	110.00	-	55.08	55.08	500	0.0047	36.00	33.13	2.87	33.32	0.34	0.95
13.6	0	110.00	70.95	70.95	70.95	35.10	-	32.61	2.49	32.80	0.38	1.01	6.06
13.6	0	41.193	40.00	-	70.77	500	0.0047	35.10	32.61	2.49	32.83	0.38	1.01
13.7	0	91.16	91.16	-	70.77	500	0.0047	35.10	32.42	2.68	32.64	0.44	1.08
13.7	j	150.00	-	70.77	70.77	500	0.0047	35.10	32.42	2.68	32.64	0.39	1.01
13.8	j	90.00	-	91.16	91.16	500	0.0047	35.00	31.72	3.28	31.94	0.44	1.08
13.8	j	90.00	70.77	-	91.16	500	0.0047	35.00	31.72	3.28	31.94	0.39	1.01
13.9	j	69.792	70.00	-	97.34	500	0.0047	34.50	31.30	3.20	31.52	0.44	1.08
13.9	j	69.792	70.00	-	125.39	500	0.0047	34.50	31.30	3.20	31.57	0.46	1.10
13.10	j	30.00	-	97.34	97.34	500	0.0047	34.00	30.97	3.03	31.24	0.53	1.18
13.10	j	30.00	125.39	-	125.39	500	0.0047	34.00	30.00	4.00	30.27	0.46	1.10
13 (No.3 TS)	TOTAL	930.00											
<b>JICA TRUNK SEWER HYDRAULIC CONCEPT DESIGN</b>													
<b>No.4 TRUNK SEWER</b>													
manhole	Construction Method o /j	Area (ha)	length (m)	upstream		downstream		trunk sewer		cota		velocity critical velocity (m/s)	Prage Notes: entrance flow (l/s): (Pa)
				flow (l/s)		diam. (mm)	slope (m/m)	ground level (m)	depth (m)	NA final (m)	h/d (m/m)		
				initial	final	initial	final	upstream	downstream	initial	final		
1	0	123.919	150.00	47.18	47.18	400	0.0020	43.00	41.00	2.00	41.26	0.55	0.67
2	0	150.00	-	60.78	60.78	43.00	-	40.70	2.30	40.96	0.65	0.71	6.39
2	0	150.00	-	47.18	47.18	400	0.0020	43.00	40.70	2.30	40.96	0.55	0.67
3	0	130.00	-	60.78	60.78	43.00	-	40.40	2.60	40.66	0.65	0.71	6.39
3	0	130.00	-	47.18	47.18	400	0.0020	43.00	40.40	2.60	40.66	0.55	0.67
4	0	130.00	-	60.78	60.78	400	0.0020	43.00	40.14	2.86	40.40	0.65	0.71
4	0	150.00	-	47.18	47.18	400	0.0048	43.00	40.14	2.86	40.34	0.42	0.92
5	0	150.00	-	60.78	60.78	42.00	-	39.52	2.48	39.72	0.49	0.98	4.26
5	0	150.00	-	47.18	47.18	400	0.0048	42.00	-	39.72	0.42	0.92	4.26
6	0	150.00	-	47.18	47.18	400	0.0048	41.20	38.80	2.40	39.00	0.49	0.99
6	0	150.00	-	60.78	60.78	400	0.0048	40.50	-	38.08	0.42	0.92	4.28
7	0	150.00	-	47.18	47.18	400	0.0048	40.50	-	38.28	0.49	0.99	4.28

**Table 2 (14/18) Trunk Sewer Hydraulic Calculation of Acari Sewer District**

manhole	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s)	diam.	slope (m/m)	ground level (m)	trunk sewer depth (m)	cota NA final (m)	b/d (m/m)	tractive tension (Pa)	critical velocity Vc (m/s)	Page Notes:
			initial	initial	final	initial	upstream	upstream	initial	initial			14 entrance flow (l/s):
			final	final		final	downstream	downstream	final	final			
7	o	150.00	47.18	47.18	40.50	0.0048	-	2.42	38.28	0.42	0.92	-	4.28 5.90
8	o	60.78	60.78	40.00	40.00	0.0048	37.36	2.64	37.56	0.49	0.99	-	
8	o	150.00	47.18	47.18	40.00	0.0048	-	-	37.56	0.42	0.92	-	4.28 5.90
9	o	60.78	60.78	40.00	39.00	0.0048	36.64	2.36	36.84	0.49	0.99	-	
9	o	100.00	47.18	47.18	40.00	0.0048	-	-	36.84	0.42	0.92	-	4.28 5.90
10	o	60.78	60.78	38.90	36.16	0.0048	36.16	2.74	36.36	0.49	0.99	-	
10	o	150.00	47.18	47.18	40.00	0.0048	38.90	2.74	36.36	0.42	0.92	-	
11	j	150.00	60.78	60.78	40.00	0.0048	-	-	35.56	0.49	0.99	-	4.28 5.90
11	j	150.00	47.18	47.18	500	0.0009	39.00	35.34	36.66	0.48	0.50	-	
12	j	150.00	60.78	60.78	500	0.0009	-	-	35.20	3.80	35.48	-	1.14 6.89
12	j	47.18	47.18	500	40.00	0.0009	39.00	35.20	3.80	35.49	0.49	0.49	-
13	j	60.78	60.78	40.00	40.00	0.0009	-	-	35.07	4.93	35.36	-	1.07 6.93
13	j	70.00	70.00	500	40.00	0.0009	39.00	35.01	3.99	35.30	0.58	0.52	-
14	j	65.800	150.00	93.05	93.05	0.0201	-	-	35.07	4.93	35.36	0.49	0.49
14	j	72.24	72.24	500	34.50	0.0201	32.00	32.00	2.50	32.15	0.30	1.83	-
15	o	150.00	72.24	72.24	500	0.0153	34.50	32.00	2.50	32.17	0.28	1.55	-
15	o	93.05	93.05	500	32.20	0.0153	-	-	29.70	2.50	29.87	-	12.49 5.72
16	o	150.00	72.24	72.24	500	0.0153	32.20	29.70	2.50	29.87	0.28	1.55	-
16	o	93.05	93.05	500	30.00	0.0153	-	-	27.41	2.59	27.58	-	12.44 5.72
17	o	150.00	72.24	72.24	500	0.0153	30.00	27.41	2.59	27.58	0.28	1.55	-
17	o	93.05	93.05	500	27.60	0.0153	-	-	25.11	2.49	25.28	-	12.49 5.72
18	o	100.00	72.24	72.24	500	0.0153	27.60	25.11	2.49	25.28	0.28	1.55	-
18	o	93.05	93.05	500	26.10	0.0153	-	-	23.58	2.52	23.75	-	12.47 5.72
19	o	137.925	130.00	124.76	500	0.0065	25.30	26.10	23.58	2.52	23.86	0.48	1.32
19	o	160.70	160.70	500	0.0065	-	-	-	22.74	2.56	23.02	-	1.41
20	o	124.76	124.76	500	25.30	0.0065	-	-	22.74	2.56	23.02	0.48	1.32
20	o	166.24	166.24	500	24.30	0.0065	-	-	21.77	2.53	22.05	0.57	1.41
21	o	124.76	124.76	500	24.30	0.0065	-	-	21.77	2.53	22.05	0.48	1.32
21	o	160.70	160.70	500	23.30	0.0065	-	-	20.80	2.50	21.08	0.57	1.41
22	o	166.24	166.24	500	23.30	0.0065	-	-	20.80	2.50	21.14	0.58	1.42
22	o	214.13	214.13	500	23.00	0.0065	-	-	20.28	2.72	20.62	0.69	1.50
23	o	108.939	80.00	-	-	-	-	-	-	-	-	-	41.481 53.432

**Table 2 (15/18) Trunk Sewer Hydraulic Calculation of Acatlán Sewer District**

manhole	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s)	diam.	slope (m/m)	ground level (m)	trunk sewer depth (m)	cota NA final (m)	h/d (m/m)	tractive tension (Pa)	critical velocity Vc (m/s)	Page Notes:
			initial	initial	final	initial	upstream	upstream	initial	initial			15 entrance flow (l/s):
			final	final		final	downstream	downstream	final	final			
23	o	0	100.00	-	166.24	166.24	23.00	20.28	20.62	0.58	1.42	-	
24	j	120.00	166.24	214.13	214.13	0.0065	22.50	19.63	2.87	19.97	0.69	1.50	
24	j	150.00	214.13	166.24	166.24	0.0065	22.50	19.63	2.87	19.97	0.58	1.42	
25	j	214.13	166.24	214.13	166.24	0.0065	22.00	18.85	3.15	19.19	0.69	1.50	
26	o	150.00	-	214.13	214.13	0.0065	22.00	18.85	3.15	19.20	0.58	1.42	
26	o	51.158	150.00	-	185.72	185.72	21.30	17.88	3.42	18.23	0.69	1.50	
27	o	100.00	185.72	239.22	239.22	0.0025	21.30	17.68	3.62	18.07	0.47	1.02	
27	o	150.00	-	239.22	239.22	0.0025	20.60	17.30	3.30	17.69	0.55	1.09	
28	j	150.00	239.22	-	700	0.0025	20.60	17.30	3.30	17.69	0.47	1.02	
28	j	17.120	130.00	239.22	239.22	0.0025	20.00	17.05	2.95	17.44	0.56	1.09	
29	j	110.00	-	192.24	192.24	0.0025	19.70	16.67	3.03	17.06	0.55	1.09	
29	j	140.00	140.00	-	247.62	247.62	700	0.0025	19.60	16.35	3.25	16.75	0.57
30	j	140.00	140.00	-	192.24	192.24	900	0.0011	19.60	16.15	3.45	16.59	0.42
31	j	140.00	140.00	-	247.62	247.62	900	0.0011	19.50	16.03	3.47	16.47	0.48
31	j	130.00	-	192.24	192.24	900	0.0011	19.50	16.03	3.47	16.47	0.42	0.75
32	j	140.00	140.00	-	247.62	247.62	900	0.0011	19.50	15.89	3.61	16.33	0.49
32	j	140.00	-	192.24	192.24	900	0.0011	19.50	15.89	3.61	16.33	0.42	0.75
33	j	140.00	140.00	-	247.62	247.62	900	0.0011	19.50	15.74	3.76	16.18	0.49
33	j	140.00	-	192.24	192.24	900	0.0011	19.50	15.74	3.76	16.17	0.42	0.76
34	j	140.00	-	247.62	247.62	900	0.0011	19.00	15.64	3.36	16.07	0.48	0.80
34	j	60.00	-	192.24	192.24	900	0.0012	19.00	15.64	3.36	16.07	0.41	0.77
35	j	140.00	140.00	-	247.62	247.62	900	0.0011	19.00	15.57	3.43	16.00	0.47
35	j	100.00	-	192.24	192.24	900	0.0011	19.00	15.57	3.43	16.00	0.42	0.75
36	j	140.00	140.00	-	247.62	247.62	900	0.0011	19.00	15.46	3.54	15.89	0.48
36	j	140.00	-	206.73	206.73	900	0.0011	19.00	15.46	3.54	15.91	0.43	0.78
37	j	140.00	-	266.30	266.30	900	0.0071	17.00	14.30	2.70	14.30	0.27	2.32
37	j	140.00	-	206.73	206.73	900	0.0071	17.00	14.30	2.70	14.30	0.30	2.21
37	j	140.00	-	266.30	266.30	900	0.0071	16.00	13.30	2.70	13.30	0.30	2.19
38	o	140.00	-	266.30	266.30	900	0.0071	17.00	14.30	2.70	14.30	0.30	2.29
38	o	140.00	-	206.73	206.73	900	0.0071	16.00	13.30	2.70	13.30	0.30	2.19
39	o	140.00	-	266.30	266.30	900	0.0071	16.00	13.30	2.70	13.30	0.30	2.19

**Table 2 (16/18) Trunk Sewer Hydraulic Calculation of Acatlán Sewer District**

manhole	Construction Method o /j	Area (ha)	length (m)	upstream flow (l/s)	diam.	slope (m/m)	ground level (m)	trunk sewer depth (m)	cota NA final (m)	h/d (m/m)	tractive tension (Pa)	critical velocity Vc (m/s)	Page Notes:
				initial	final		upstream	upstream	initial	initial			16 entrance flow (l/s):
				initial	final		downstream	downstream	final	final			
39	j	100.00	206.73	206.73	900	0.0071	16.00	13.30	2.70	13.58	0.27	1.51	
40	j	78.003	40.00	236.43	236.43	-	15.70	12.59	3.11	12.87	-	9.87	7.51
41	j	70.00	304.55	304.55	900	0.0019	15.70	12.59	3.11	13.01	0.41	0.96	29.700
41	j	110.00	304.55	304.55	900	0.0019	15.70	12.52	3.18	12.94	0.47	1.03	38.258
42	j	120.00	236.43	236.43	1200	0.0004	16.00	12.38	3.18	12.93	0.40	0.98	
42	j	120.00	304.55	304.55	900	0.0019	16.00	12.38	3.62	12.80	0.46	1.05	
43	j	120.00	236.43	371.71	371.71	-	16.20	12.17	4.03	12.80	0.40	0.98	
44	j	120.00	304.55	478.80	1200	0.0004	16.30	11.87	4.33	12.61	0.52	1.04	
44	j	120.00	371.71	371.71	1200	0.0004	16.30	11.82	4.48	12.56	0.52	0.62	
45	j	150.00	421.70	421.70	1200	0.0004	16.70	11.77	4.93	12.51	0.62	0.66	
45	j	150.00	543.20	543.20	1200	0.0004	16.70	11.77	4.93	12.59	0.57	0.63	
46	j	150.00	421.70	421.70	1200	0.0004	16.00	11.71	4.29	12.53	0.68	0.67	
46	j	150.00	543.20	543.20	1200	0.0004	16.00	11.71	4.29	12.53	0.57	0.63	
47	j	11.066	130.00	548.62	548.62	-	1200	0.0004	16.60	11.65	4.95	12.47	0.68
48	j	120.00	425.91	425.91	1200	0.0004	17.05	11.60	.45	12.49	0.59	0.62	
48	j	120.00	548.62	548.62	1200	0.0004	17.05	11.60	.45	12.44	0.70	0.66	
49	j	150.00	425.91	425.91	1200	0.0004	17.50	11.55	.95	12.37	0.68	0.68	
49	j	150.00	548.62	548.62	1200	0.0004	17.30	11.49	.81	12.38	0.58	0.63	
50	j	120.00	425.91	425.91	1200	0.0004	17.30	11.49	.81	12.32	-	-	
51	j	40.00	548.62	548.62	1200	0.0005	17.05	11.44	.61	12.26	-	-	
51	j	140.00	425.91	425.91	1200	0.0004	17.05	11.44	.61	12.20	0.54	0.69	
52	j	140.00	548.62	548.62	1200	0.0004	17.05	11.42	.63	12.18	0.64	0.73	
52	j	140.00	425.91	425.91	1200	0.0005	16.80	11.36	.44	12.17	0.67	0.69	
53	j	150.00	548.62	548.62	1200	0.0004	16.80	11.36	.44	12.19	0.58	0.63	
54	j	140.00	434.96	434.96	1200	0.0005	16.80	11.30	.50	12.13	-	-	
54	j	23.766	140.00	560.28	560.28	-	16.80	11.30	.50	12.08	0.54	0.69	
55	j	150.00	548.62	548.62	1200	0.0005	17.20	11.23	.97	12.01	0.65	0.73	9.049 11.656

**Table 2 (17/18) Trunk Sewer Hydraulic Calculation of Acari Sewer District**

manhole	Construction Method o / j	Area (ha)	length (m)	upstream		downstream		slope (m/m)	diam. (mm)	ground level (m)		trunk sewer depth (m)		cota NA final (m)	h/d (m/m)	initial V <sub>initial</sub> (m/s)	final V <sub>final</sub> (m/s)	velocity critical velocity V <sub>c</sub> (m/s)	Page Notes: 17 entrance flow (l/s):
				initial	final	initial	final			upstream	downstream	upstream	downstream						
55	j	110.00	434.96	-	1200	0.0005	-	17.20	11.23	-	5.97	11.98	0.53	0.71	-	1.70	10.96		
56	j	560.28	434.96	560.28	-	17.50	11.17	6.33	11.92	0.63	0.76	11.96	0.56	0.67	-	-			
56	j	434.96	434.96	-	1200	0.0005	-	17.50	11.17	6.33	11.96	0.56	0.67	-	-	1.49	11.09		
57	j	560.28	434.96	560.28	-	17.90	11.10	6.80	11.89	0.66	0.71	-	-	-	-	-			
57	j	434.96	434.96	-	1200	0.0005	-	17.90	11.10	6.80	11.89	0.56	0.67	-	-	1.49	11.09		
58	j	560.28	434.96	560.28	-	17.90	11.03	6.87	11.82	0.66	0.71	-	-	-	-	-			
58	j	434.96	434.96	-	1200	0.0005	-	17.90	11.03	6.87	11.79	0.53	0.71	-	-	-			
59	j	150.00	560.28	560.28	-	17.00	10.95	6.05	11.71	0.63	0.75	-	-	-	-	1.66	10.98		
59	j	442.38	442.38	-	1200	0.0006	-	17.00	10.95	6.05	11.69	0.52	0.74	-	-	1.84	10.91	7.417	
81 (No. 1 TS)	j	19.481	50.00	-	569.84	569.84	-	17.00	10.92	6.08	11.66	0.61	0.79	-	-	-	9.555		
TOTAL			7,400.00							0.08									

**JICA ACARI SEWERAGE DISTRICT TRUNK SEWER HYDRAULIC CONCEPT DESIGN**  
**No. 4-1 TRUNK SEWER**

manhole	Construction Method o / j	Area (ha)	length (m)	upstream		downstream		slope (m/m)	diam. (mm)	ground level (m)		trunk sewer depth (m)		cota NA final (m)	h/d (m/m)	initial V <sub>initial</sub> (m/s)	final V <sub>final</sub> (m/s)	velocity critical velocity V <sub>c</sub> (m/s)	Page Notes: 17 entrance flow (l/s):
				initial	final	initial	final			upstream	downstream	upstream	downstream						
43.1	j	156.332	60.00	-	500	0.0015	-	12.50	7.50	-	5.00	7.78	0.48	0.63	-	1.82	6.88	59.525	
43.2	j	59.53	76.68	76.68	-	12.50	7.41	-	5.09	7.69	0.56	-	-	-	-	-	6.675		
43.2	j	100.00	59.53	-	500	0.0011	-	12.50	7.41	-	5.09	7.72	0.53	0.57	-	-	-		
43.3	j	76.68	76.68	-	500	0.0011	-	12.50	7.30	-	5.20	7.61	0.62	0.60	-	-	1.42	7.07	
43.3	j	59.53	76.68	76.68	-	12.70	7.17	-	5.53	7.48	-	-	-	-	-	-			
43.4	j	75.51	97.27	97.27	-	12.70	6.77	-	5.93	7.07	-	5.95	7.05	0.29	0.48	-	-		
43.4	j	30.00	75.51	75.51	-	12.70	6.75	-	5.95	7.05	-	5.95	7.05	0.34	0.53	-	-		
43.5	j	40.00	97.27	97.27	-	12.90	6.72	-	6.18	7.02	-	6.18	7.02	0.33	0.55	-	-		
43.6	j	120.00	75.51	-	900	0.0007	-	12.90	6.72	-	6.18	7.02	0.29	0.48	-	-	1.00	7.74	
43.7	j	97.27	75.51	75.51	-	13.20	6.64	-	6.56	6.94	-	6.56	6.94	0.34	0.53	-	-		
43.7	j	150.00	97.27	97.27	-	13.20	6.64	-	6.56	6.94	-	6.56	6.94	0.29	0.48	-	-		
43.8	j	7,400.00	75.51	-	900	0.0007	-	13.60	6.54	-	6.84	7.06	0.34	0.53	-	-	1.00	7.74	

**Table 2 (18/18) Trunk Sewer Hydraulic Calculation of Acari Sewer District**

manhole	Construction Method o /j	Area (ha)	length (m)	upstream flow (l/s) initial	diam. (mm) final	slope (m/m) initial	ground level (m) upstream	trunk sewer level (m) downstream	cota NA final (m)	h/d (m/m) initial	tractive tension (Pa) initial	velocity critical Vc (m/s)	Page Notes: 18 entrance flow (l/s):
43.8	j		150.00	75.51	75.51	0.0007	13.60	6.54	7.06	6.84	0.29	0.48	
43.9				97.27	97.27	-	14.20	6.44	7.76	6.74	0.34	0.53	
43.9	j	120.364	110.00	121.34	121.34	0.0007	14.20	6.44	7.76	6.82	0.37	0.57	45.830 59.034
43.10				156.31	156.31	-	14.60	6.36	8.24	6.74	0.42	0.61	
43.10	j		110.00	121.34	121.34	0.0007	14.60	6.36	8.24	6.74	0.37	0.57	
43.11				156.31	156.31	-	15.05	6.28	8.77	6.66	0.42	0.61	
43.11	j		110.00	121.34	121.34	0.0007	15.05	6.28	8.77	6.66	0.37	0.57	
43.12				156.31	156.31	900	0.0007	15.50	6.20	9.30	6.58	0.42	0.61
43.12	j		120.00	121.34	121.34	900	0.0007	15.50	6.20	9.30	6.58	0.37	0.56
43.13				156.31	156.31	-	15.30	6.12	9.18	6.50	0.43	0.59	
43.13	j		100.00	121.34	121.34	900	0.0007	15.30	6.12	9.18	6.50	0.37	0.57
43.14				156.31	156.31	-	15.00	6.05	8.95	6.43	0.42	0.60	
43.14				135.27	135.27	-	15.00	6.05	8.95	6.45	0.38	0.60	
43.15	j	36.582	40.00	174.25	174.25	900	0.0008	15.00	6.02	8.98	6.42	0.44	0.64
43.15	j		5.00	135.27	135.27	-	15.00	6.02	8.98	6.33	0.29	0.85	13.929 17.942
EE-4				174.25	174.25	900	0.0020	15.00	6.01	8.99	6.32	0.34	0.92
TOTAL				1,365.00						8.99			

RECALQUE: L=120m e D=500mm

43.16	0		100.00	0.00	135.27	900	0.0010	15.00	12.90	2.10	13.27	0.36	0.67	
43.17				0.00	174.25			15.20	12.80	2.40	13.17	0.41	0.71	
43.17	j		70.00	135.27	135.27	-	900	0.0010	15.20	12.80	2.40	13.17	0.36	0.67
43 (No. 4 TS)				174.25	174.25	-	-	-	12.73	3.47	13.10	0.41	0.71	
TOTAL			170.00		12.76					3.47				
EE-3	0	33.501		16.43	16.43									

RECALQUE: L=400m e D=150mm

### 1.3 SARAPUI SEWER DISTRICT

Trunk Sewer Hydraulic Calculation of Sarapui Sewer District is shown in *Table 3 (1/4 - 4/4)*.

**Table 3 (1/4) Trunk Sewer Hydraulic Calculation of Sarapui Sewer District**

JICA manhole	SARAPUÍ SEWERAGE DISTRICT No. 1 TRUNK SEWER											critical velocity $V_c$ (m/s)	tractive tension (Pa)	velocity $V_f$ (m/s)	Page Notes: entrance flow (l/s):			
	Construction Method o /j	Area (ha)	length (m)	upstream flow (l/s)		downstream flow (l/s)		slope (m/m)	diam. (mm)	ground level (m)	trunk sewer level (m)	trunk sewer depth (m)	h/d (m/m)	initial Vinitial	final Vfinal			
				initial	final	initial	final											
1	o	90.275	150.00	32.71	32.71	-	400	0.0020	5.00	-	3.00	2.00	0.44	0.61	-	1.83	6.07	32.707
2	o	150.00	45.29	32.71	32.71	-	400	0.0020	5.00	2.70	2.70	2.30	0.54	0.66	-	-	0.61	45.288
3	o	100.00	45.29	32.71	32.71	-	400	0.0020	5.00	2.40	2.60	0.54	0.66	-	-	1.83	6.07	
4	o	100.00	45.29	32.71	32.71	-	400	0.0020	5.00	2.40	2.60	0.44	0.61	-	-	1.83	6.07	
5	j	27.860	110.00	42.80	42.80	-	500	0.0020	5.00	2.20	2.80	0.44	0.66	-	-	1.83	6.07	
6	j	150.00	59.25	42.80	42.80	-	500	0.0008	5.00	1.90	3.10	0.44	0.61	-	-	1.83	6.07	
7	j	70.00	59.25	42.80	42.80	-	500	0.0008	5.00	1.81	3.19	0.58	0.51	-	-	1.00	6.93	10.094
8	o	168.608	150.00	103.89	103.89	-	900	0.0006	4.00	1.62	3.19	0.47	0.47	-	-	1.00	6.93	13.958
9	o	150.00	143.72	103.89	103.89	-	900	0.0006	4.00	1.14	2.86	0.43	0.47	-	-	1.01	6.92	
10	j	150.00	143.72	103.89	103.89	-	900	0.0006	4.00	1.14	2.86	0.36	0.50	-	-	1.00	8.46	61.087
11	j	130.00	143.72	103.89	103.89	-	900	0.0006	4.00	1.06	2.94	0.43	0.54	-	-	1.00	8.46	84.472
12	j	140.00	143.72	103.89	103.89	-	900	0.0006	4.00	0.97	3.03	0.43	0.54	-	-	1.00	8.46	
13	o	120.00	103.89	143.72	143.72	-	900	0.0006	4.00	0.89	3.11	0.43	0.54	-	-	1.00	8.46	
14	j	80.677	150.00	184.14	184.14	-	900	0.0005	5.00	0.68	4.32	0.51	0.56	-	-	1.01	8.99	29.227
15	j	150.00	133.12	184.14	184.14	-	900	0.0005	5.00	0.68	4.32	0.42	0.51	-	-	1.01	8.99	40.420
16	j	150.00	184.14	184.14	184.14	-	900	0.0005	5.00	0.60	4.40	0.51	0.56	-	-	1.01	8.99	

**Table 3 (2/4) Trunk Sewer Hydraulic Calculation of Sarapui Sewer District**

manhole no / j	Construction Method o / j	Area (ha)	length (m)	upstream		downstream		slope (m/m)	diam. (mm)	ground level (m)		trunk sewer level (m)		h/d (m/in)	Vinitial	Vfinal	velocity (m/s)	critical velocity Vc (m/s)	Page Notes: entrance flow (l/s);	
				initial	final	initial	final			upstream	downstream	upstream	downstream							
				initial	final	initial	final			upstream	downstream	upstream	downstream							
16	j	80.331	130.00	-	900	0.0005	-	5.00	133.12	133.12	133.12	5.00	0.60	4.40	0.42	0.51	-	1.01	8.99	
17	j	130.00	184.14	184.14	184.14	-	900	0.0005	4.00	133.12	133.12	133.12	4.00	0.54	3.46	0.42	0.51	0.56	-	
18	j	62.078	70.00	155.60	215.24	-	900	0.0005	5.00	184.14	184.14	184.14	5.00	0.47	4.53	0.48	0.51	-	1.01	8.99
19	j	120.00	155.60	155.60	215.24	-	900	0.0005	5.00	215.24	215.24	215.24	5.00	0.44	4.56	0.48	0.52	-	1.00	9.33
20	j	150.00	215.24	215.24	215.24	-	900	0.0005	5.00	155.60	155.60	155.60	5.00	0.38	4.62	0.48	0.52	0.56	22.489	31.101
21	j	150.00	215.24	215.24	215.24	-	900	0.0005	5.00	155.60	155.60	155.60	5.00	0.33	4.67	0.47	0.52	-	1.00	9.32
22	j	150.00	215.24	215.24	215.24	-	900	0.0005	5.00	155.60	155.60	155.60	5.00	0.33	4.67	0.47	0.52	-	1.00	9.33
23	j	150.00	215.24	215.24	215.24	-	900	0.00064	4.00	155.60	155.60	155.60	4.00	0.26	3.74	0.38	0.56	0.56	-	
23	o	140.00	155.60	257.04	355.52	-	900	0.0007	2.00	215.24	215.24	215.24	2.00	-0.70	2.70	0.28	1.34	-	0.70	7.14
24	o	140.00	215.24	257.04	355.52	-	900	0.0007	2.00	155.60	155.60	155.60	2.00	-0.80	2.80	0.71	0.69	-	1.73	9.73
24	o	140.00	257.04	257.04	355.52	-	900	0.0007	2.00	155.60	155.60	155.60	2.00	-0.80	2.80	0.57	0.69	0.69	-	
25	j	59.172	150.00	385.16	385.16	-	900	0.0007	2.00	278.47	278.47	278.47	2.00	-0.90	2.90	0.71	0.74	-	1.73	9.73
25	j	150.00	385.16	385.16	385.16	-	900	0.0007	2.00	278.47	278.47	278.47	2.00	-0.90	2.90	0.59	0.71	-	1.73	9.73
26	j	150.00	385.16	385.16	385.16	-	900	0.0007	2.00	278.47	278.47	278.47	2.00	-1.01	3.01	0.75	0.76	-	1.82	21.436
26	j	150.00	385.16	385.16	385.16	-	900	0.0007	2.00	278.47	278.47	278.47	2.00	-1.01	3.01	0.59	0.71	-	1.82	29.645
27	j	60.00	385.16	278.47	278.47	-	900	0.0007	2.00	385.16	385.16	385.16	2.00	-1.12	3.12	0.75	0.76	0.59	0.71	
28	j	150.00	313.25	278.47	313.25	-	900	0.0007	2.00	385.16	385.16	385.16	2.00	-1.16	3.16	0.75	0.76	-	1.82	9.79
28	j	150.00	433.26	313.25	313.25	-	900	0.0007	2.00	313.25	313.25	313.25	2.00	-1.16	3.16	0.64	0.73	-	1.82	9.79
29	j	96.009	150.00	433.26	433.26	-	900	0.0007	2.00	433.26	433.26	433.26	2.00	-1.27	3.27	0.82	0.76	0.59	0.71	
29	j	150.00	433.26	313.25	313.25	-	900	0.0007	2.00	433.26	433.26	433.26	2.00	-1.38	3.38	0.64	0.73	0.76	0.71	
30	j	150.00	433.26	313.25	313.25	-	900	0.0007	2.00	433.26	433.26	433.26	2.00	-1.38	3.38	0.82	0.76	-	1.82	9.79
31	j	150.00	433.26	313.25	313.25	-	900	0.0007	2.00	433.26	433.26	433.26	2.00	-1.49	3.49	0.82	0.76	-	1.82	9.83
31	j	150.00	433.26	313.25	313.25	-	900	0.0007	2.00	433.26	433.26	433.26	2.00	-1.49	3.49	0.64	0.73	-	1.82	9.83
32	j	150.00	433.26	433.26	433.26	-	900	0.0007	2.00	-1.60	-1.60	-1.60	2.00	-1.60	3.60	0.82	0.76	0.71	0.76	48.100

**Table 3 (3/4) Trunk Sewer Hydraulic Calculation of Sarapui Sewer District**

manhole	Construction Method o /j	Area (ha)	length (m)	upstream		downstream		slope (m/m)	diam. (mm)	ground level (m)		trunk sewer level (m)		h/d (m/m)	initial V <sub>initial</sub>	final V <sub>final</sub>	velocity (m/s)	critical velocity V <sub>c</sub> (m/s)	Page Notes: entrance flow (l/s);
				initial	final	initial	final			upstream	downstream	upstream	downstream						
32	j		150.00	-	313.25	313.25	313.25	0.0007	900	0.0007	2.00	-1.60	3.60	0.64	0.73	-	1.89	9.83	
33	j		70.00	-	313.25	313.25	313.25	0.0007	900	0.0007	2.00	-1.71	3.71	0.64	0.74	0.76	-		
34	j		30.00	-	313.25	313.25	313.25	0.0007	900	0.0007	2.00	-1.77	3.77	0.64	0.73	0.77	-	1.91	9.83
35	j		150.00	-	313.25	313.25	313.25	0.0007	900	0.0007	2.00	-1.79	3.79	0.62	0.76	-	1.89	9.83	
36	j		150.00	-	433.26	433.26	433.26	0.0007	900	0.0007	2.00	-1.79	3.79	0.65	0.73	-	1.86	9.83	
36	j		150.00	-	313.25	313.25	313.25	0.0007	900	0.0007	2.00	-1.90	3.90	0.62	0.75	-	1.86	9.83	
37	j		150.00	-	433.26	433.26	433.26	0.0007	900	0.0007	2.00	-2.00	4.00	0.62	0.75	-	1.86	9.83	
37	j		150.00	-	313.25	313.25	313.25	0.0007	900	0.0007	2.00	-2.00	4.00	0.65	0.73	-	1.86	9.83	
38	j		60.00	-	313.25	313.25	313.25	0.0007	900	0.0007	2.00	-2.11	4.11	0.62	0.75	-	1.86	9.83	
38	j		110.00	-	433.26	433.26	433.26	0.0007	900	0.0007	2.00	-2.11	4.11	0.65	0.73	-	1.86	9.83	
39	j		110.00	-	313.25	313.25	313.25	0.0007	900	0.0007	2.00	-2.16	4.16	0.62	0.75	-	1.86	9.83	
40	j		120.00	-	433.26	433.26	433.26	0.0007	900	0.0007	2.00	-2.23	4.23	0.62	0.75	-	1.86	9.83	
41	j		30.00	-	349.07	349.07	349.07	0.0009	900	0.0009	1.00	-2.32	3.32	0.82	0.75	-	1.86	9.83	
41	j		150.00	-	484.53	484.53	484.53	0.0009	900	0.0009	1.00	-2.70	3.70	0.64	0.82	-	2.40	9.83	COLETOR CC 35.820 51.270
42	j		150.00	-	349.07	349.07	349.07	0.0009	900	0.0009	1.00	-2.73	3.73	0.64	0.82	-	2.40	9.83	
43	j		150.00	-	484.53	484.53	484.53	0.0009	900	0.0009	1.00	-2.87	3.87	0.81	0.86	-	2.43	9.83	
44	j		120.00	-	349.07	349.07	349.07	0.0009	900	0.0009	1.00	-3.01	4.01	0.81	0.87	-	2.43	9.83	WWTP effluent channel
46 (interceptor)	TOTAL		5,530.00		484.53	484.53	484.53	0.95	900	0.0009	1.00	-3.12	4.07	0.81	0.86	-	2.40	9.83	
46 (interceptor) PDBG ETE					61.00	1788.53	2137.60	0.95		0.00044	1.00	-6.206	7.16	0.61	0.98	-	2.59	14.80	3244.010

**Table 3 (4/4) Trunk Sewer Hydraulic Calculation of Sarapui Sewer District**

JICA manhole	SARAPUÍ SEWERAGE DISTRICT TRUNK SEWER HYDRAULIC CONCEPT DESIGN No. 1-I TRUNK SEWER											Page Notes: entrance flow (l/s): Vc (m/s)	
	Construction Method o /j	Area (ha)	length (m)	upstream flow (l/s)		downstream flow (l/s)		slope (m/m)	diam. (mm)	ground level (m)	trunk sewer level (m)		
				initial	final	initial	final						
23.1	0	227.211	150.00	82.31	82.31	-	-	0.0020	500	4.00	2.00	0.54	
23.2	0	113.83	113.83	113.83	113.83	-	-	-	4.00	4.00	1.70	2.30	
23.2	0	82.31	82.31	82.31	82.31	-	-	0.0020	500	4.00	1.70	2.30	
23.3	0	113.83	113.83	113.83	113.83	-	-	-	4.00	4.00	1.40	2.60	
23.3	0	82.31	82.31	82.31	82.31	-	-	0.0020	500	4.00	1.40	2.60	
23.4	0	120.00	113.83	113.83	113.83	-	-	-	4.00	4.00	1.16	2.84	
23.4	0	101.43	101.43	101.43	101.43	-	-	0.0006	700	4.00	0.96	3.04	
23.5	0	150.00	140.28	140.28	140.28	-	-	-	4.00	4.00	0.87	3.13	
23.5	0	101.43	101.43	101.43	101.43	-	-	0.0006	700	4.00	0.87	3.13	
23.6	0	150.00	140.28	140.28	140.28	-	-	-	4.00	4.00	0.78	3.22	
23.6	0	101.43	101.43	101.43	101.43	-	-	0.0006	700	4.00	0.78	3.22	
23.7	j	150.00	140.28	140.28	140.28	-	-	-	4.00	4.00	0.69	3.31	
23.7	0	101.43	101.43	101.43	101.43	-	-	0.0006	700	4.00	0.69	3.31	
23.8	0	40.00	40.00	40.00	40.00	-	-	-	4.00	4.00	0.67	3.33	
23.8	j	30.00	-	101.43	101.43	-	-	0.0007	900	4.00	0.17	3.83	
23.9	j	140.28	140.28	101.43	101.43	-	-	-	4.00	4.00	0.15	3.85	
23.9	j	90.00	-	90.00	90.00	-	-	0.0007	900	4.00	0.15	3.85	
23.10	j	101.43	101.43	101.43	101.43	-	-	-	4.00	4.00	0.09	3.91	
23.11	j	90.00	-	140.28	140.28	-	-	0.0007	900	4.00	0.09	3.91	
23.11	0	40.00	-	101.43	101.43	-	-	-	2.00	-0.60	2.60	0.22	
23.12	0	40.00	140.28	140.28	140.28	-	-	0.0007	900	2.00	-0.63	2.63	
23.12	0	101.43	101.43	101.43	101.43	-	-	-	2.00	-0.63	2.63	0.34	
23	0	60.00	-	140.28	140.28	-	-	0.0007	900	2.00	-0.67	2.67	
TOTAL									1,220.00			2.67	

## 1.4 BANGU SEWER DISTRICT

Trunk Sewer Hydraulic Calculation of Bangu Sewer District is shown in *Table 4 (1/14 - 14/14)*.

**Table 4 (1/14) Trunk Sewer Hydraulic Calculation of Bangu Sewer District**

JICA		BANGU SEWERAGE DISTRICT TRUNK SEWER HYDRAULIC CONCEPT DESIGN No. 1 TRUNK SEWER																					
manhole	Construction Method o / j	Area (ha)	length (m)	upstream flow (l/s)		downstream flow (l/s)		diam. (mm)	slope (m/m)	ground level (m)		trunk sewer level (m)		h/d (m/m)	velocity (m/s)	tractive tension (Pa)	critical velocity Vc (m/s)						
				initial		final				upstream		downstream											
				initial	final	initial	final			upstream	downstream	upstream	downstream										
1	o	163.950	150.00	121.34	121.34	-	-	500	0.0040	-	-	48.80	2.00	0.55	1.10	5.30	7.13						
2	o	153.79	153.79	153.79	153.79	121.34	121.34	-	-	50.40	50.40	48.20	2.20	0.65	1.16	-	121.339						
3	o	153.79	153.79	153.79	153.79	121.34	121.34	-	-	50.00	50.00	47.76	2.24	0.65	1.16	-	153.785						
4	j	150.00	150.00	153.79	153.79	121.34	121.34	-	-	500	0.0040	-	-	0.55	1.10	-							
4	j	150.00	150.00	153.79	153.79	121.34	121.34	-	-	500	0.0040	-	-	0.55	1.10	-							
5	j	150.00	150.00	153.79	153.79	121.34	121.34	-	-	500	0.0040	-	-	0.55	1.10	-							
5	j	150.00	150.00	153.79	153.79	121.34	121.34	-	-	500	0.0040	-	-	0.55	1.10	-							
6	j	130.00	130.00	153.79	153.79	163.29	163.29	-	-	500	0.0040	-	-	0.55	1.16	-							
6	j	130.00	130.00	153.79	153.79	121.34	121.34	-	-	500	0.0040	-	-	0.55	1.16	-							
7	j	140.00	140.00	153.79	153.79	163.29	163.29	-	-	900	0.0010	-	-	0.55	1.10	-							
8	j	24.480	150.00	181.41	181.41	229.92	229.92	-	-	900	0.0010	-	-	0.55	1.16	-							
9	j	150.00	150.00	181.41	181.41	229.92	229.92	-	-	900	0.0010	-	-	0.55	1.16	-							
9	j	150.00	150.00	181.41	181.41	181.41	181.41	-	-	900	0.0010	-	-	0.55	1.16	-							
10	j	100.00	100.00	229.92	229.92	229.92	229.92	-	-	900	0.0010	-	-	0.55	1.16	-							
10	j	100.00	100.00	229.92	229.92	181.41	181.41	-	-	900	0.0010	-	-	0.55	1.16	-							
11	j	26.913	130.00	201.33	201.33	255.17	255.17	-	-	900	0.0050	-	-	0.45	0.74	-							
12	j	130.00	201.33	201.33	201.33	255.17	255.17	-	-	900	0.0050	-	-	0.42	0.72	-							
12	j	130.00	201.33	201.33	201.33	255.17	255.17	-	-	900	0.0050	-	-	0.42	0.72	-							
13	j	130.00	201.33	201.33	201.33	255.17	255.17	-	-	900	0.0050	-	-	0.42	0.72	-							
13	j	130.00	201.33	201.33	201.33	255.17	255.17	-	-	900	0.0050	-	-	0.42	0.72	-							
14	j	130.00	201.33	201.33	201.33	255.17	255.17	-	-	900	0.0050	-	-	0.42	0.72	-							
14	j	130.00	201.33	201.33	201.33	255.17	255.17	-	-	900	0.0050	-	-	0.42	0.72	-							
15	j	120.00	201.33	201.33	201.33	255.17	255.17	-	-	900	0.0050	-	-	0.40	0.70	-							
15	j	120.00	201.33	201.33	201.33	255.17	255.17	-	-	900	0.0050	-	-	0.40	0.70	-							
16	j	120.00	201.33	201.33	201.33	255.17	255.17	-	-	900	0.0050	-	-	0.33	0.43	-							

**Table 4 (2/14) Trunk Sewer Hydraulic Calculation of Bangu Sewer District**

manhole	Construction Method o / j	Area (ha)	length (m)	upstream		downstream		trunk sewer level (m)		trunk sewer depth (m)		hydraulic tension (Pa)		critical velocity Vc (m/s)	Page Notes: entrance flow (l/s):
				initial	final	initial	final	upstream	downstream	upstream	downstream	initial	final		
				(mm)	(mm)	(mm)	(mm)					V <sub>initial</sub>	V <sub>final</sub>		
16	j	50.935	140.00	239.03	239.03	900	0.00050	45.70	41.30	4.40	0.32	1.41	-	8.17	7.92
17	j			-	302.94	302.94	-	44.00	40.60	3.40	0.36	1.49	-		37.697
17	j			239.03	262.29	900	0.0028	44.00	40.48	3.52	0.38	1.16	-		47.777
18				-	332.43	332.43	-	44.00	40.10	3.90	0.44	1.23	-		
18	j			302.94	262.29	900	0.0028	44.00	40.10	3.90	0.39	1.15	-		
19	j			-	332.43	332.43	-	43.00	39.74	3.26	0.44	1.22	-		
19	j			322.43	262.29	900	0.0028	43.00	39.74	3.26	0.39	1.15	-		
20	j			-	332.43	332.43	-	43.00	39.49	3.51	0.44	1.22	-		
20	j			90.00	262.29	900	0.0028	43.00	39.49	3.51	0.39	1.15	-		
21	j			-	332.43	332.43	-	43.00	39.24	3.76	0.44	1.22	-		
21	j			265.03	265.03	900	0.0028	43.00	39.24	3.76	0.39	1.16	-		
22				-	335.90	335.90	-	42.00	38.93	3.07	0.44	1.23	-		
22	j			278.76	278.76	900	0.0028	42.00	38.93	3.07	0.40	1.17	-		
23	j			-	353.30	353.30	-	42.00	38.51	3.49	0.45	1.25	-		
23	j			278.76	278.76	900	0.0028	42.00	38.51	3.49	0.40	1.17	-		
24	j			-	353.30	353.30	-	42.00	38.09	3.91	0.45	1.25	-		
24	j			283.88	283.88	900	0.0028	42.00	38.09	3.91	0.40	1.18	-		
25	j			-	359.78	359.78	-	42.00	37.67	4.33	0.46	1.25	-		
25	j			283.88	283.88	900	0.0027	42.00	37.67	4.33	0.40	1.16	-		
26	j			-	359.78	359.78	-	42.00	37.48	4.52	0.46	1.24	-		
26	j			289.52	289.52	900	0.0028	42.00	37.48	4.52	0.40	1.18	-		
27	j			-	366.93	366.93	-	41.00	37.34	3.66	0.46	1.26	-		
27	j			289.52	289.52	900	0.0028	41.00	37.34	3.66	0.40	1.19	-		
28	j			-	366.93	366.93	-	41.00	37.00	4.00	0.46	1.27	-		
28	j			298.94	298.94	900	0.0028	41.00	37.00	4.00	0.41	1.20	-		
29	j			-	378.88	378.88	-	40.00	36.69	3.31	0.47	1.27	-		
29	j			298.94	298.94	900	0.0045	40.00	36.69	3.31	0.37	1.69	-		
30	j			-	378.88	378.88	-	40.00	36.11	3.89	0.41	1.79	-		
30	j			298.94	298.94	900	0.0045	40.00	36.11	3.89	0.36	1.69	-		
31	j			-	378.88	378.88	-	39.00	35.52	3.48	0.41	1.79	-		
31	j			303.83	303.83	900	0.0044	39.00	35.52	3.48	0.37	1.71	-		
32	j			-	385.07	385.07	-	39.00	35.21	3.79	0.42	1.81	-		

**Table 4 (3/14) Trunk Sewer Hydraulic Calculation of Bangu Sewer District**

manhole	Construction Method o / j	Area (ha)	length (m)	upstream		downstream		trunk sewer level (m)		trunk sewer depth (m)		hydraulic tension (Pa)		critical velocity Vc (m/s)	Page Notes: entrance flow (l/s):
				initial	final	initial	final	upstream	downstream	upstream	downstream	initial	final		
				(mm)	(mm)	(mm)	(mm)	(m/m)	(m/m)	(m/m)	(m/m)	V <sub>initial</sub>	V <sub>final</sub>		
32	j	9.463	110.00	310.83	310.83	393.95	393.95	900	900	0.0045	0.0045	39.00	35.21	3.79	1.71
33	j		110.00	310.83	310.83	393.95	393.95	-	-	39.00	34.71	4.29	0.42	-	7.004 8.877
33	j		110.00	310.83	310.83	393.95	393.95	-	-	39.00	34.71	4.29	0.37	1.71	
34	j		110.00	310.83	310.83	393.95	393.95	-	-	39.00	34.22	4.78	0.42	1.81	
34	j		110.00	310.83	310.83	393.95	393.95	900	900	0.0045	0.0045	39.00	34.22	4.78	0.37
35	j		110.00	310.83	310.83	393.95	393.95	-	-	38.00	33.72	4.28	0.42	1.82	
35	j	64.082	120.00	358.26	581.32	736.77	736.77	1200	1200	0.0045	0.0045	38.00	31.93	6.07	0.35
36	j		100.00	581.32	581.32	584.81	584.81	-	-	37.40	37.40	31.39	31.39	-	1.37
36	j		100.00	581.32	581.32	584.81	584.81	1200	1200	0.0026	0.0026	37.40	31.39	6.01	0.39
37	j		100.00	736.77	736.77	584.81	584.81	-	-	37.00	37.00	31.13	31.13	5.87	0.40
37	j		30.00	741.18	741.18	741.18	741.18	1200	1200	0.0027	0.0027	37.00	31.05	5.95	0.45
38	j		50.00	741.18	741.18	818.96	818.96	-	-	37.00	37.00	31.05	31.05	5.95	0.40
38	j		50.00	597.22	1037.95	1037.95	1037.95	1200	1200	0.0026	0.0026	36.70	30.92	5.78	0.45
39	j		130.00	756.92	818.96	818.96	818.96	-	-	35.80	35.80	30.58	30.58	5.22	0.56
40	j		130.00	1037.95	1037.95	1037.95	1037.95	1200	1200	0.0026	0.0026	35.80	30.58	5.22	0.48
41	j		120.00	1037.95	1037.95	1037.95	1037.95	-	-	36.70	36.70	30.24	30.24	6.46	0.56
41	j		120.00	818.96	818.96	818.96	818.96	1200	1200	0.0026	0.0026	36.70	30.24	6.46	0.48
42	j		150.00	829.55	829.55	1051.37	1051.37	-	-	34.00	34.00	29.93	29.93	4.07	0.56
42	j		150.00	1051.37	1051.37	1051.37	1051.37	1200	1200	0.0026	0.0026	34.00	29.54	4.46	0.57
43	j		150.00	829.55	829.55	1051.37	1051.37	-	-	34.00	34.00	29.54	29.54	4.46	0.49
43	j		150.00	1051.37	1051.37	1051.37	1051.37	1200	1200	0.0026	0.0026	34.00	29.54	4.46	1.51
44	j		150.00	829.55	829.55	1051.37	1051.37	-	-	33.50	33.50	29.15	29.15	4.35	0.57
44	j		150.00	850.00	850.00	850.00	850.00	1200	1200	0.0026	0.0026	33.50	29.15	4.35	0.49
45	j		150.00	1077.28	1077.28	1077.28	1077.28	-	-	33.00	33.00	28.76	28.76	4.24	0.57
45	j		150.00	850.00	850.00	850.00	850.00	1200	1200	0.0026	0.0026	32.00	28.37	3.63	0.57
46	j		150.00	850.00	850.00	1077.28	1077.28	-	-	32.00	32.00	28.37	28.37	3.63	0.59
46	j		150.00	1077.28	1077.28	1077.28	1077.28	1200	1200	0.0015	0.0015	33.00	28.15	4.85	0.70
47	j		150.00	850.00	850.00	850.00	850.00	-	-	33.00	33.00	28.15	28.15	4.85	0.59
47	j		150.00	1077.28	1077.28	1077.28	1077.28	1200	1200	0.0015	0.0015	32.00	27.92	4.08	0.69
48	j		150.00	1077.28	1077.28	1077.28	1077.28	-	-	32.00	32.00	27.92	27.92	4.08	1.31

**Table 4 (4/14) Trunk Sewer Hydraulic Calculation of Bangu Sewer District**

manhole	Construction Method o / j	Area (ha)	length (m)	upstream		downstream		trunk sewer		velocity		Notes: entrance flow (l/s):	Page 4	
				flow (l/s) initial	diam. (mm)	slope (m/m)	ground level (m)	trunk sewer level (m)	hd (m/m)	tractive tension (Pa)	critical velocity V <sub>c</sub> (m/s)			
				final	initial	final	upstream	downstream	initial V <sub>initial</sub>	final V <sub>final</sub>	critical velocity V <sub>c</sub> (m/s)			
48	j	59.501	80.00	894.03	894.03	1200	0.0015	-	27.92	4.08	0.61	1.25	44.036 55.812	
49	j		1133.09	1133.09	894.03	-	32.00	27.80	4.20	0.72	-	5.04	11.26	
49	j		894.03	-	1200	0.0015	-	27.80	4.20	0.62	1.23	-	1.30	
50	j		1133.09	1133.09	-	1200	0.0015	34.00	27.64	6.36	0.73	1.29	-	
50	j		894.03	894.03	-	1200	0.0015	34.00	27.64	6.36	0.61	1.25	-	
51	j		1133.09	1133.09	894.03	-	32.00	27.46	4.54	0.72	1.30	-	5.04	
51	j		894.03	-	1200	0.0015	-	27.46	4.54	0.61	1.25	-	11.26	
52	j		1133.09	1133.09	894.03	-	31.00	27.28	3.72	0.72	1.30	-	5.04	
52	j		894.03	-	1200	0.0015	-	27.28	3.72	0.61	1.25	-	11.26	
53	j		1133.09	1133.09	-	1200	0.0015	31.00	27.13	3.87	0.72	1.30	-	
53	j		894.03	894.03	-	1200	0.0015	31.00	27.13	3.87	0.61	1.26	-	
54	j		1133.09	1133.09	-	1200	0.00060	31.00	26.90	4.10	0.72	1.32	-	
54	j		894.03	894.03	-	1200	0.00060	31.00	26.90	4.10	0.40	2.09	-	
55	j		1133.09	1133.09	-	1200	0.00060	31.00	26.00	5.00	0.46	2.22	-	
55	j		894.03	894.03	-	1200	0.00060	31.00	26.00	5.00	0.40	2.09	-	
56	j		1133.09	1133.09	-	1200	0.00060	29.00	25.10	3.90	0.46	2.22	-	
56	j		79.567	120.00	952.99	952.99	1200	0.00060	29.00	25.10	3.90	0.41	2.12	-
57	j		1207.82	1207.82	952.99	952.99	-	29.00	24.38	4.62	0.47	2.26	-	
57	j		130.00	1207.82	1207.82	-	1200	0.00060	29.00	24.38	4.62	0.41	2.12	-
58	j		1207.82	1207.82	952.99	952.99	-	28.00	23.60	4.40	0.47	2.26	-	
58	j		110.00	1207.82	1207.82	-	1200	0.00060	28.00	23.60	4.40	0.41	2.12	-
59	j		1207.82	1207.82	952.99	952.99	-	27.00	22.94	4.06	0.47	2.26	-	
59	j		100.00	1207.82	1207.82	-	1200	0.00060	27.00	22.94	4.06	0.41	2.12	-
60	j		980.48	980.48	1242.67	1242.67	-	26.00	22.34	3.66	0.47	2.26	-	
60	j		150.00	1242.67	1242.67	-	1200	0.00060	26.00	22.34	3.66	0.52	1.66	-
61	j		980.48	980.48	1242.67	1242.67	-	26.00	21.89	4.11	0.60	1.76	-	
61	j		125.00	1242.67	1242.67	-	1200	0.00060	26.00	21.89	4.11	0.52	1.65	-
62	j		1007.46	1007.46	1007.46	1007.46	-	26.00	21.52	4.48	0.61	1.75	-	
62	j		120.00	1276.86	1276.86	1276.86	-	1200	0.00060	26.00	21.52	4.48	0.53	1.67
63	j		1007.46	1007.46	1007.46	1007.46	-	26.00	21.16	4.84	0.61	1.77	-	
63	j		120.00	1276.86	1276.86	1276.86	-	1200	0.00060	26.00	21.16	4.84	0.53	1.67
64	j		120.00	1276.86	1276.86	1276.86	-	26.00	20.80	5.20	0.61	1.77	-	

**Table 4 (5/14) Trunk Sewer Hydraulic Calculation of Bangu Sewer District**

manhole	Construction Method o / j	Area (ha)	length (m)	upstream		downstream		slope (m/m)	diam. (mm)	ground level (m)	trunk sewer depth (m)		hd (m/m)	initial V <sub>initial</sub>	final V <sub>final</sub>	tractive tension (Pa)	critical velocity V <sub>c</sub> (m/s)	Notes: entrance flow (l/s);	Page 5
				initial	final	initial	final				upstream	downstream							
				initial	final	initial	final				upstream	downstream							
64	j		120.00	1007.46	1007.46	1200	0.00060	26.00	-	20.80	5.20	0.53	1.67	-	-	9.28	10.91		
65			1276.86	1276.86	-	26.00	20.44	5.56	0.61	18.40	7.60	0.53	1.67	-	-	1.77	1.77		
65	j		1007.46	1007.46	-	26.00	-	-	-	18.25	7.75	0.61	1.77	-	-	9.28	10.91		
66			1276.86	1276.86	-	26.00	18.25	7.75	0.53	1200	0.0030	-	-	-	-	1.67	1.67		
66	j		1007.46	1007.46	-	26.00	18.25	7.75	0.53	-	1200	-	-	-	-	1.77	1.77		
67			1276.86	1276.86	-	26.00	18.10	7.90	0.61	1379.93	0.0030	1200	-	-	-	1.80	1.80		
67	j		1007.46	1007.46	-	26.00	18.10	7.90	0.65	1276.86	0.0030	-	-	-	-	1.77	1.77		
ETE			1276.86	1276.86	-	26.00	18.07	7.93	0.77	1748.74	-	-	-	-	-	1.86	11.33		
TOTAL			7,940.00									7.93							

**BANGU SEWERAGE DISTRICT  
TRUNK SEWER HYDRAULIC CONCEPT DESIGN  
No. 1-1 TRUNK SEWER**

manhole	Construction Method o / j	Area (ha)	length (m)	upstream		downstream		slope (m/m)	diam. (mm)	ground level (m)	trunk sewer depth (m)		hd (m/m)	initial V <sub>initial</sub>	final V <sub>final</sub>	tractive tension (Pa)	critical velocity V <sub>c</sub> (m/s)	Notes: entrance flow (l/s);	Page 5	
				initial	final	initial	final				upstream	downstream								
				initial	final	initial	final				upstream	downstream								
17.1	j	31.437	80.00	23.27	23.27	500	0.0027	48.00	42.00	42.00	6.00	0.25	0.61	-	-	2.00	5.32	23,267		
17.2			29.49	29.49	-	47.00	41.78	5.22	0.28	23.27	41.78	5.22	0.25	0.60	0.65	0.64	29,488			
17.2	j		23.27	23.27	-	47.00	-	-	-	500	0.0027	-	-	-	-	-	1.95	1.95		
17.3			29.49	29.49	-	46.00	41.38	4.62	0.28	23.27	46.00	41.38	4.62	0.25	0.61	0.64	0.64	1.99	1.99	
17.3	j		23.27	23.27	-	46.00	-	-	-	500	0.0027	-	-	-	-	-	1.99	1.99		
17.4			29.49	29.49	-	45.00	40.97	4.03	0.28	23.27	45.00	40.97	4.03	0.25	0.61	0.65	0.65	1.99	1.99	
17.4	j		110.00	110.00	-	44.50	-	-	-	500	0.0027	-	-	-	-	-	-	5.33	5.33	
17.5			29.49	29.49	-	44.50	40.67	3.83	0.28	23.27	44.50	40.67	3.83	0.25	0.61	0.65	0.65	1.98	1.98	
17.5	j		70.00	70.00	-	44.00	-	-	-	500	0.0027	-	-	-	-	-	-	5.33	5.33	
17			29.49	29.49	-	40.48	-	-	-	560.00	-	-	-	-	-	-	-	-	-	
TOTAL			560.00									3.52								

**Table 4 (6/14) Trunk Sewer Hydraulic Calculation of Bangu Sewer District**

BANGU SEWERAGE DISTRICT No. 1-2 TRUNK SEWER										TRUNK SEWER HYDRAULIC CONCEPT DESIGN																							
JICA manhole o / j	Construction Method (ha)	Area (ha)	length (m)	upstream		downstream		slope (m/m)	diam. (mm)	ground level (m)		trunk sewer level (m)		h/d (m/m)	initial V <sub>initial</sub>	final V <sub>final</sub>	velocity (m/s)	tractive tension (Pa)	critical velocity V <sub>c</sub> (m/s)	Page Notes: entrance flow (l/s): 6 44.747 56.712													
				initial		final				upstream		downstream																					
				initial		final				upstream		downstream																					
39.1	o	60.460	150.00	44.75	44.75	-	400	0.0087	52.60	50.60	2.00	0.35	1.13	-	-	-	6.77	5.49	44.747	56.712													
39.2	o		65.00	44.75	44.75	56.71	56.71	0.0085	52.60	49.30	3.30	0.40	1.20	-	-	-	6.64	5.50															
39.3	o	5.794	95.00	56.71	56.71	-	400	0.0084	52.60	48.75	3.85	0.40	1.19	-	-	-	6.84	5.61	4.288	5.435													
39.4	o		95.00	49.04	49.04	49.04	-	400	0.0084	51.00	47.95	3.05	0.42	1.22	-	-	6.84	5.61															
39.5	o	6.883	95.00	54.13	54.13	-	400	0.0084	51.00	47.95	3.05	0.37	1.15	-	-	-	6.84	5.61															
39.6	j	37.412	95.00	62.15	62.15	62.15	-	500	0.0084	51.00	47.15	3.85	0.42	1.22	-	-	6.84	5.61															
39.7	j		95.00	103.70	103.70	103.70	-	500	0.0084	50.00	46.35	3.65	0.45	1.25	-	-	7.10	5.72	5.094	6.457													
39.8	j	43.375	25.00	113.92	113.92	113.92	500	0.0060	48.00	44.00	4.00	0.47	1.25	-	-	8.29	6.17	27.688	35.092														
39.9	j		85.00	144.38	144.38	144.38	-	500	0.0060	48.00	43.85	4.15	0.54	1.33	-	-	7.17	6.80	32.102	40.686													
39.10	j		85.00	144.38	144.38	144.38	-	500	0.0060	48.00	43.85	4.15	0.47	1.25	-	-	7.17	6.80															
39.10	j		90.00	145.39	145.39	145.39	-	500	0.0060	48.00	43.34	4.66	0.54	1.34	-	-	7.89	7.10	31.467	39.881													
39.11	j	42.518	90.00	184.26	184.26	184.26	-	500	0.0060	47.00	42.80	4.20	0.64	1.41	-	-	8.29	6.17															
39.11	j		90.00	145.39	145.39	145.39	-	500	0.0061	47.00	42.80	4.20	0.54	1.34	-	-	7.17	6.80															
39.12	j	39.486	140.00	184.26	184.26	174.61	-	500	0.0061	46.00	42.25	3.75	0.63	1.42	-	-	8.01	7.09															
39.13	j		140.00	221.30	221.30	221.30	-	500	0.0061	45.00	41.40	3.60	0.72	1.46	-	-	8.51	7.27	29.223	37.038													
39.14	j		140.00	174.61	174.61	174.61	-	500	0.0061	44.00	40.55	3.45	0.72	1.46	-	-	8.51	7.27															
39.14	o	23.392	140.00	191.92	191.92	191.92	-	700	0.0036	44.00	40.15	3.85	0.44	1.17	-	-	5.70	7.87	17.312	21.941													
39.15	o		191.92	243.24	243.24	243.24	-	700	0.0036	43.00	39.65	3.35	0.50	1.25	-	-	8.51	7.27															
39.15	o		140.00	-	243.24	243.24	-	700	0.0036	43.00	39.65	3.35	0.44	1.17	-	-	5.70	7.87															
39.16																																	

**Table 4 (7/14) Trunk Sewer Hydraulic Calculation of Bangu Sewer District**

manhole o / j	Construction Method	Area (ha)	length (m)	upstream		downstream		trunk sewer		velocity		Notes: entrance flow (l/s):	Page 7
				diam. (mm)	slope (m/m)	diam. (mm)	ground level (m)	trunk sewer depth (m)	hyd (mm)	tractive tension (Pa)	critical velocity V <sub>c</sub> (m/s)		
				initial	final	initial	upstream	upstream	initial	V <sub>initial</sub>	critical velocity V <sub>c</sub> (m/s)		
39.16	o	120.00	191.92	191.92	-	700	0.0037	42.00	39.15	2.85	0.43	1.19	
39.17	o	120.00	191.92	243.24	243.24	-	41.70	38.70	3.00	0.49	-	5.93	7.83
39.17	o	120.00	243.24	191.92	-	700	0.0038	41.70	38.70	3.00	0.43	1.19	1.27
39.18	o	243.24	243.24	243.24	-	-	-	38.25	2.75	0.49	-	5.93	7.83
39.18	o	215.66	215.66	215.66	-	700	0.0064	41.00	38.25	2.75	0.40	1.50	
39.19	o	273.33	273.33	273.33	-	-	-	41.00	37.80	3.20	0.45	1.60	23.741 30.089
39.19	j	215.66	215.66	215.66	-	900	0.0064	41.00	37.80	3.20	0.28	1.47	
39.20	j	273.33	273.33	273.33	-	-	-	41.00	37.55	3.46	0.32	1.60	
39.20	j	30.00	215.66	215.66	-	900	0.0064	41.00	37.55	3.46	0.32	1.60	
39.21	j	273.33	273.33	273.33	-	-	-	41.00	37.35	3.65	0.32	1.60	
39.21	j	215.66	215.66	215.66	-	900	0.0064	41.00	37.35	3.65	0.28	1.47	
39.22	j	273.33	273.33	273.33	-	-	-	41.00	36.39	4.61	0.32	1.60	
39.22	j	215.66	215.66	215.66	-	900	0.0064	41.00	36.39	4.61	0.28	1.46	
39.23	j	273.33	273.33	273.33	-	-	-	39.00	35.85	3.15	0.32	1.59	
39.23	j	215.66	215.66	215.66	-	900	0.0065	39.00	35.85	3.15	0.28	1.47	
39.24	j	85.00	273.33	273.33	-	-	-	38.00	35.30	2.70	0.32	1.60	
39.24	o	8.212	221.74	221.74	-	900	0.0046	38.00	35.30	2.70	0.32	1.34	
39.25	o	130.00	281.03	281.03	-	-	-	37.50	34.70	2.80	0.35	1.42	7.46 7.703
39.25	o	120.00	221.74	221.74	-	900	0.0046	37.50	34.70	2.80	0.32	1.34	
39.26	o	281.03	281.03	281.03	-	-	-	37.00	34.15	2.85	0.35	1.41	7.41 7.87
39	o	120.00	221.74	221.74	-	900	0.0046	37.00	34.15	2.85	0.32	1.34	
TOTAL			2,610.00					36.70	33.60	3.10	0.35	1.41	7.41 7.87
										3.10			

**Table 4 (8/14) Trunk Sewer Hydraulic Calculation of Bangu Sewer District**

JICA		BANGU SEWERAGE DISTRICT No. 2 TRUNK SEWER HYDRAULIC CONCEPT DESIGN																					
manhole	Construction Method o / j	TRUNK SEWER		upstream flow (l/s)		downstream flow (l/s)		diam.		ground level (m)		trunk sewer level (m)		h/d (m/m)		velocity (m/s)		tractive tension (Pa)		critical velocity Vc (m/s)		Page Notes: entrance flow (l/s):	
		initial		final		initial		final		upstream		downstream		upstream		downstream		initial		final			
		m	(ha)	m	(mm)	m	(mm)	m	(mm)	m	(m)	m	(m)	m	(m)	m	(m)	m	(m)	m	(m)	m	(m/s)
1	o	16.024	60.00	11.86	11.86	500	0.0042	42.00	-	39.75	2.25	0.18	-	0.16	0.58	-	2.08	4.42	11.859	15.031			
2	o	59.276	50.00	55.73	55.73	500	0.0020	42.00	-	39.75	2.25	0.42	-	0.69	-	2.24	6.59	4.3871	55.601				
3	j	14.968	80.00	70.63	70.63	500	0.0031	42.00	-	39.65	2.35	0.49	-	0.74	-	3.44	6.53	11.078	14.040				
4	o	110.00	-	66.81	66.81	500	0.0027	42.00	-	39.40	2.60	0.43	-	0.81	-	3.08	6.62						
5	o	150.00	-	66.81	66.81	500	0.0027	42.00	-	39.10	2.90	0.43	-	0.81	-	3.03	6.64						
6	j	122.15	122.15	122.15	122.15	500	0.0033	41.00	-	38.70	2.30	0.50	-	0.86	-	4.58	7.22	55.339	70.136				
7	j	150.00	154.81	154.81	154.81	500	0.0033	41.80	-	38.20	3.60	0.69	-	1.08	-	4.58	7.22	55.339	70.136				
8	j	140.00	-	154.81	154.81	500	0.0027	42.00	-	37.82	4.18	0.75	-	0.98	-	3.86	7.30						
9	j	150.00	-	158.26	158.26	500	0.0030	42.00	-	37.82	4.18	0.62	-	0.99	-	4.23	7.28	2.722	3.450				
9	j	150.00	-	124.87	124.87	500	0.0030	41.50	-	37.37	4.13	0.73	-	1.03	-	4.23	7.28						
10	j	150.00	-	158.26	158.26	500	0.0030	40.70	-	36.92	3.78	0.73	-	1.03	-	4.23	7.28						
10	j	100.00	-	124.87	124.87	500	0.0030	40.70	-	36.92	3.78	0.62	-	0.99	-	4.23	7.28						
11	j	100.00	-	158.26	158.26	500	0.0030	40.50	-	36.62	3.88	0.73	-	1.03	-	4.23	7.28						
11	j	155.53	155.53	155.53	155.53	900	0.0030	40.50	-	36.22	4.28	0.29	-	1.02	-	4.43	7.68	30.658	38.855				
12	j	197.11	197.11	155.53	155.53	900	0.0030	41.50	-	35.92	5.58	0.33	-	1.11	-	4.43	7.68						
12	j	100.00	-	197.11	197.11	900	0.0030	41.50	-	35.92	5.58	0.29	-	1.02	-	4.43	7.68						
13	j	155.53	155.53	155.53	155.53	900	0.0030	41.00	-	35.62	5.38	0.33	-	1.11	-	4.43	7.68						
13	j	197.11	197.11	197.11	197.11	900	0.0030	40.50	-	35.47	5.03	0.33	-	1.11	-	4.43	7.68						
14	j	41.424	100.00	155.53	155.53	900	0.0030	40.50	-	35.47	5.03	0.29	-	1.02	-	4.43	7.68						
15	j	197.11	-	155.53	155.53	900	0.0030	39.75	-	35.17	4.58	0.33	-	1.11	-	4.43	7.68						
15	j	100.00	-	197.11	197.11	900	0.0030	39.75	-	35.17	4.58	0.29	-	1.02	-	4.43	7.68						
16	j	197.11	-	197.11	197.11	900	0.0030	39.00	-	34.87	4.13	0.33	-	1.11	-	4.43	7.68						

**Table 4 (9/14) Trunk Sewer Hydraulic Calculation of Bangu Sewer District**

manhole o / j	Construction Method	Area (ha)	length (m)	upstream		downstream		trunk sewer		velocity		critical velocity $V_c$ (m/s)	Page Notes: entrance flow (l/s):	9
				flow (l/s) initial	diam. (mm)	slope (m/m)	ground level (m)	trunk sewer level (m)	hd (mm)	tractive tension (Pa)				
				final	initial	upstream	upstream	downstream	downstream	initial	final			
16	j		120.00	155.53	155.53	-	900	0.0030	39.00	34.87	4.13	0.29	1.02	
17	j		197.11	197.11	197.11	-	-	-	39.00	34.51	4.49	0.33	1.11	
17	j		155.53	155.53	155.53	-	900	0.0030	39.00	34.51	4.49	0.29	1.01	
18	j		197.11	197.11	197.11	-	-	-	39.00	34.17	4.83	0.33	1.10	
18	j		155.53	155.53	155.53	-	900	0.0030	39.00	34.17	4.83	0.28	1.02	
19	j		197.11	197.11	197.11	-	-	-	39.00	33.82	5.18	0.33	1.11	
19	j		155.53	155.53	155.53	-	900	0.0032	39.00	33.82	5.18	0.28	1.04	
20	j		30.00	197.11	197.11	-	-	-	39.00	33.73	5.28	0.33	1.13	
20	j		155.53	155.53	155.53	-	900	0.0032	39.00	33.73	5.28	0.28	1.04	
21	j		197.11	197.11	197.11	-	-	-	39.00	33.33	4.67	0.33	1.13	
21	j		155.53	155.53	155.53	-	900	0.0032	38.00	33.33	4.67	0.28	1.04	
22	j		197.11	197.11	197.11	-	-	-	37.00	32.93	4.07	0.33	1.13	
22	j		155.53	223.07	223.07	-	900	0.0033	37.00	32.93	4.07	0.34	1.18	
23	j		70.00	197.11	282.71	-	-	-	37.00	32.70	4.30	0.38	1.25	
23	j		223.07	223.07	223.07	-	900	0.0037	37.00	32.30	4.70	0.33	1.24	
24	j		40.00	282.71	282.71	-	-	-	37.00	32.15	4.85	0.37	1.31	
24	j		223.07	223.07	223.07	-	900	0.0037	37.00	32.15	4.85	0.33	1.24	
35 (N0.1.TS)			40.00	-	282.71	-	-	-	38.00	32.00	6.00	0.37	1.31	8.02
TOTAL			2,370.00							6.00				

**Table 4 (10/14) Trunk Sewer Hydraulic Calculation of Bangu Sewer District**

**Table 4 (11/14) Trunk Sewer Hydraulic Calculation of Bangu Sewer District**

JICA		BANGU SEWERAGE DISTRICT No. 3 TRUNK SEWER											TRUNK SEWER HYDRAULIC CONCEPT DESIGN													
manhole	Construction Method o / j	Area (ha)		length (m)		upstream flow (l/s)		downstream flow (l/s)		diam. (mm)		ground level (m)		trunk sewer level (m)		trunk sewer depth (m)		h/d (m/m)		tractive tension (Pa)		critical velocity Vc (m/s)		Page Notes: entrance flow (l/s):		
		initial		final		initial		final		upstream		downstream		upstream		downstream		initial		final		Vinitial		Vfinal		
		38.09	38.09	-	400	0.0067	48.07	400	0.0067	38.00	-	36.00	2.00	0.35	0.99	-	-	5.15	5.46	38.089	48.073	11	11	11	11	
1	o	51.464	150.00	-	48.07	48.07	-	400	0.0067	38.00	-	35.00	2.00	0.35	0.99	-	-	1.05	1.05	-	-	5.15	5.46	38.089	48.073	
2	o	150.00	150.00	-	38.09	38.09	-	400	0.0067	37.00	-	35.00	2.00	0.35	0.99	-	-	1.05	1.05	-	-	5.15	5.46	-	-	
3	o	29.627	150.00	-	48.07	48.07	-	400	0.0067	36.00	-	34.00	2.00	0.39	1.05	-	-	-	-	-	-	-	-	-	-	-
4	o	110.00	60.02	-	60.02	60.02	-	400	0.0067	36.00	-	34.00	2.00	0.44	1.11	-	-	1.11	1.11	-	-	6.13	5.97	21.927	27.791	
5	o	150.00	60.02	-	75.86	75.86	-	400	0.0067	35.00	-	33.00	2.00	0.51	1.18	-	-	1.18	1.18	-	-	6.13	5.97	-	-	
6	o	60.02	60.02	-	75.86	75.86	-	400	0.0067	34.50	-	32.26	2.24	0.44	1.11	-	-	1.11	1.11	-	-	6.17	5.96	-	-	
7	o	50.00	50.00	-	75.86	75.86	-	400	0.0067	34.50	-	32.26	2.24	0.44	1.11	-	-	1.11	1.11	-	-	6.17	5.96	-	-	
8	j	85.745	70.00	-	123.48	123.48	-	500	0.0165	34.00	-	30.92	3.08	0.51	1.18	-	-	1.18	1.18	-	-	6.17	5.96	-	-	
9	j	90.00	90.00	-	123.48	123.48	-	500	0.0165	34.00	-	30.92	3.08	0.44	1.11	-	-	1.11	1.11	-	-	6.17	5.96	-	-	
9	j	156.29	156.29	-	156.29	156.29	-	500	0.0165	34.00	-	30.92	3.08	0.44	1.11	-	-	1.11	1.11	-	-	6.17	5.96	-	-	
10	j	123.48	123.48	-	123.48	123.48	-	500	0.0165	32.00	-	28.87	3.13	0.49	1.62	-	-	1.62	1.62	-	-	10.85	6.60	-	-	
10	j	90.00	90.00	-	156.29	156.29	-	500	0.0165	32.00	-	28.87	3.13	0.43	1.52	-	-	1.52	1.52	-	-	10.85	6.60	-	-	
11	j	156.29	156.29	-	156.29	156.29	-	500	0.0165	31.00	-	28.00	3.00	0.49	1.62	-	-	1.62	1.62	-	-	10.85	6.60	-	-	
11	j	133.88	133.88	-	262.58	262.58	-	900	0.0067	31.00	-	26.60	4.40	0.32	1.61	-	-	1.61	1.61	-	-	10.85	6.60	63.459	80.428	
12	j	169.48	169.48	-	332.61	332.61	-	900	0.0027	31.00	-	25.60	5.40	0.35	1.70	-	-	1.70	1.70	-	-	10.85	6.60	-	-	
12	j	150.00	150.00	-	262.58	262.58	-	900	0.0027	31.00	-	25.60	5.40	0.39	1.13	-	-	1.13	1.13	-	-	5.04	5.04	-	-	
13	j	262.58	262.58	-	332.61	332.61	-	900	0.0020	28.00	-	25.20	2.80	0.42	1.02	-	-	1.02	1.02	-	-	4.00	4.00	8.56	8.56	
13	j	150.00	150.00	-	332.61	332.61	-	900	0.0020	28.00	-	24.90	3.10	0.48	1.09	-	-	1.09	1.09	-	-	4.00	4.00	8.81	8.81	
14	j	110.00	110.00	-	262.58	262.58	-	900	0.0020	28.00	-	24.90	3.10	0.42	1.02	-	-	1.02	1.02	-	-	4.00	4.00	8.81	8.81	
15	j	332.61	332.61	-	332.61	332.61	-	900	0.0020	28.00	-	24.68	3.32	0.48	1.09	-	-	1.09	1.09	-	-	4.00	4.00	8.81	8.81	
15	j	262.58	262.58	-	332.61	332.61	-	900	0.0020	28.00	-	24.68	3.32	0.42	1.02	-	-	1.02	1.02	-	-	4.00	4.00	8.81	8.81	
16	j	332.61	332.61	-	332.61	332.61	-	900	0.0020	28.00	-	24.38	3.62	0.48	1.09	-	-	1.09	1.09	-	-	4.00	4.00	8.81	8.81	

**Table 4 (12/14) Trunk Sewer Hydraulic Calculation of Bangu Sewer District**

manhole	Construction Method o / j	Area (ha)	length (m)	upstream		downstream		diam. (mm)	slope (m/m)	ground level (m)	trunk sewer depth (m)	hd (mm)	initial V <sub>initial</sub> (m/s)	final V <sub>final</sub> (m/s)	tractive tension (Pa)	critical velocity V <sub>c</sub> (m/s)	Notes: entrance flow (l/s):	Page 12
				initial	final	upstream	downstream											
				initial	final	upstream	downstream											
16	j	150.00	262.58	-	900	0.0020	28.00	262.58	-	24.38	3.62	0.42	1.02	-	4.00	8.81		
17	j	130.00	332.61	332.61	-	28.00	24.08	262.58	-	3.92	0.48	1.09	1.02	-	-			
17	j	130.00	262.58	-	900	0.0020	28.00	262.58	-	24.08	3.92	0.42	1.02	-	4.00	8.81		
18	j	332.61	332.61	-	900	0.0020	27.00	23.82	-	3.18	0.48	1.09	1.09	-	-			
18	j	310.70	310.70	-	900	0.0021	27.00	23.82	-	3.18	0.45	1.09	1.09	-	-			
19	j	393.60	393.60	-	900	0.0021	26.50	23.50	-	3.00	0.52	1.16	1.16	-	4.50	9.05	48.124	
19	o	150.00	310.70	-	900	0.0020	26.50	23.50	-	3.00	0.46	1.07	1.07	-	-		60.992	
20	o	100.00	393.60	393.60	-	26.00	23.20	310.70	-	2.80	0.54	1.13	1.13	-	-			
20	o	310.70	393.60	-	900	0.0020	26.00	310.70	-	23.20	2.80	0.46	1.07	-	-			
21	o	16.021	100.00	322.56	372.46	-	26.00	393.60	-	23.00	3.00	0.54	1.13	-	-			
21	ETE-manhole	0	408.63	-	900	0.0020	26.00	372.46	-	23.00	3.00	0.52	1.12	-	-			
TOTAL			2,560.00					471.88		22.80	3.20	0.60	1.19	-	-		11.857 15.028	

**JICA BANGU SEWERAGE DISTRICT TRUNK SEWER HYDRAULIC CONCEPT DESIGN No. 3-1 TRUNK SEWER**

manhole	Construction Method o / j	Area (ha)	length (m)	upstream		downstream		diam. (mm)	slope (m/m)	ground level (m)	trunk sewer depth (m)	hd (mm)	initial V <sub>initial</sub> (m/s)	final V <sub>final</sub> (m/s)	tractive tension (Pa)	critical velocity V <sub>c</sub> (m/s)	Notes: entrance flow (l/s):	Page 12
				initial	final	upstream	downstream											
				initial	final	upstream	downstream											
11.1	o	69.705	120.00	51.59	51.59	400	0.0104	38.00	-	35.50	2.50	0.36	1.26	-	8.29	5.54	51.589 65.383	
11.2	o	120.00	65.38	65.38	-	36.80	34.25	51.59	-	34.25	2.55	0.41	1.34	-	-			
11.2	o	120.00	65.38	-	400	0.0104	36.80	65.38	-	34.25	2.55	0.36	1.26	-	-			
11.3	o	120.00	65.38	65.38	-	35.00	33.00	51.59	-	33.00	2.00	0.41	1.34	-	-			
11.3	o	130.00	65.38	-	400	0.0104	35.00	51.59	-	33.00	2.00	0.36	1.26	-	-			
11.4	o	20.402	130.00	66.69	66.69	400	0.0104	34.00	-	31.65	2.35	0.41	1.34	-	-			
11.5	o	140.00	84.52	84.52	-	33.00	30.30	66.69	-	30.30	2.70	0.47	1.43	-	-			
11.5	o	90.00	84.52	84.52	-	31.80	28.85	66.69	-	28.85	2.95	0.47	1.43	-	-			
11.6	o	66.69	84.52	84.52	-	31.80	28.85	66.69	-	28.85	2.95	0.41	1.34	-	-			
11.6	o	90.00	84.52	84.52	-	31.00	27.92	66.69	-	27.92	3.08	0.47	1.43	-	-			
11.7	o	2,560.00	2,560.00	-	-	-	-	-	-	-	-	-	-	-	-	-		

**Table 4 (13/14) Trunk Sewer Hydraulic Calculation of Bangu Sewer District**

manhole	Construction Method o / j	Area (ha)	length (m)	upstream		downstream		slope (m/m)	diam. (mm)	ground level (m)	trunk sewer depth (m)	h/d (m/m)	initial V <sub>initial</sub>	final V <sub>final</sub>	tractive tension (Pa)	critical velocity V <sub>c</sub> (m/s)	Notes: entrance flow (l/s):	Page 13
				initial	flow (l/s)	initial	flow (l/s)											
				final	final	upstream	downstream											
11.7	o	45.532	90.00	100.39	100.39	-	400	0.0104	31.00	27.92	3.08	0.53	1.50	-	10.75	6.30	33.698 42.708	
11.8	-	127.23	127.23	128.70	128.70	-	-	-	31.00	26.98	4.02	0.61	1.59	-	-	-	-	
11.8	j	38.250	30.00	-	-	500	0.0104	-	-	-	-	0.43	1.59	-	-	-	-	
11	-	163.13	163.13	163.13	163.13	-	-	-	31.00	26.67	4.33	0.49	1.69	-	-	-	-	
TOTAL	-	850.00	850.00	-	-	-	-	-	-	-	-	4.33	-	-	-	-	-	

JICA No. 3-2 TRUNK SEWER	BANGU SEWERAGE HYDRAULIC CONCEPT DESIGN																		
	manhole	Construction Method o / j	Area (ha)	length (m)	upstream		downstream		slope (m/m)	diam. (mm)	ground level (m)	trunk sewer level (m)	h/d (m/m)	initial V <sub>initial</sub>	final V <sub>final</sub>	tractive tension (Pa)	critical velocity V <sub>c</sub> (m/s)	Notes: entrance flow (l/s):	Page 13
					initial	flow (l/s)	final	flow (l/s)											
21.1	o	27.530	100.00	20.38	-	25.82	25.82	-	400	0.0080	33.00	30.50	2.50	0.24	0.88	-	4.52	4.69	
21.2	-	100.00	20.38	20.38	-	25.82	25.82	-	400	0.0080	32.00	29.70	2.30	0.27	0.94	-	-	20.375 25.824	
21.2	o	100.00	25.82	25.82	-	25.82	25.82	-	400	0.0080	31.00	28.90	2.10	0.27	0.94	-	-	-	
21.3	-	150.00	20.38	20.38	-	25.82	25.82	-	400	0.0080	31.00	28.90	2.10	0.24	0.88	-	-	-	
21.3	o	40.00	20.38	20.38	-	25.82	25.82	-	400	0.0080	30.00	27.70	2.30	0.27	0.94	-	-	-	
21.4	-	43.92	43.92	43.92	-	55.66	55.66	-	400	0.0080	29.00	27.70	2.30	0.24	0.88	-	-	-	
21.4	o	31.811	100.00	43.92	-	55.66	55.66	-	400	0.0080	29.00	26.58	2.42	0.40	1.16	-	-	-	
21.5	-	100.00	55.66	43.92	-	55.66	43.92	-	400	0.0080	29.00	26.58	2.42	0.36	1.10	-	-	5.51	
21.5	o	3.428	100.00	55.66	-	55.66	55.66	-	400	0.0080	28.00	25.78	2.22	0.40	1.16	-	-	5.51	
21.6	-	46.46	46.46	46.46	-	58.88	58.88	-	400	0.0080	28.00	25.78	2.22	0.37	1.11	-	-	6.30	
21.6	o	4.659	50.00	46.46	-	58.88	58.88	-	400	0.0033	28.00	24.98	3.02	0.41	1.18	-	-	5.57	
21.7	-	63.25	63.25	49.90	-	63.25	49.90	-	400	0.0033	27.00	24.65	2.35	0.49	0.81	-	-	5.57 3.215	
21.7	o	49.90	49.90	49.90	-	63.25	63.25	-	400	0.0033	27.00	24.49	2.51	0.57	0.86	-	-	3.15 3.448	
21.8	-	60.00	60.00	63.25	-	63.25	63.25	-	400	0.0033	27.00	24.49	2.51	0.49	0.81	-	-	6.08 4.370	
21.8	o	60.00	60.00	63.25	-	63.25	63.25	-	400	0.0033	27.00	24.29	2.71	0.57	0.86	-	-	3.23 6.17	

**Table 4 (14/14) Trunk Sewer Hydraulic Calculation of Bangu Sewer District**

manhole o / j	Construction Method ha)	Area (ha)	length (m)	upstream		downstream		trunk sewer		trunk sewer depth (m)	h/d (m/m)	tractive tension (Pa)	critical velocity $V_c$ (m/s)	Page Notes: entrance flow (l/s):
				flow (l/s)	diam. (mm)	slope (m/m)	ground level (m)	trunk sewer level (m)						
				initial	final	upstream	upstream	downstream	downstream	initial	final	initial	final	
21.11	0	150.00	49.90	49.90	400	0.0033	27.00	24.29	27.1	0.49	0.81			14
21			-	-	-	-	-	-	-	-	-			
TOTAL		1,050.00	63.25	63.25			26.00	23.80	2.20	0.57	0.86	3.22	6.17	

## 2. WWTP DESIGN CALCULATION

### 2.1 PAVUNA WWTP

#### 2.1.1 LOCATION OF PAVUNA WWTP

Pavuna WWTP is located at;

Rua Bulhões Maciel, Vigário Geral, Rio de Janeiro, RJ

The treated effluent is discharged to;

Rio Pavuna

#### 2.1.2 PRELIMINARY AND PRIMARY TREATMENT UNITS

##### (1) General

Preliminary and primary treatment units are shown below.

Raw Sewage Pumping Station; Grit chamber; Chemical Feed System; Primary Clarifier; Primary Sludge Pumping Station.

##### (2) Raw Sewage Pumping Station

The sewage flowing into the WWTP is conveyed up to the screen channel where the material with dimension larger than 5 cm is removed. The pumping station has the following characteristics:

**Table 5 Specifications of Inlet Pumps**

Facilities	Type	Number	Spec.
Inlet pumps	vertical centrifugal	2	Head: 17.3 m
Gates	slide	2 units/ bar screen	1,400 x 1,400 mm
Coarse bar screen	rack	1	depth: 11.2 m, bar spacing: 50 mm

##### (3) Grit Chambers

The grit removal system is performed by 3 (three) aerated and rectangular chambers with width 6 m, length 15 m and total depth 5.75 m. The material removed shall be washed and after this operation it shall be taken to the sanitary backfill. The grit chambers has the hereunder main characteristics:

Aeration system

type: 15 diffusers / tank coarse bubble, number of pumps:1, air flow requirement:  
390 Nm<sup>3</sup>/h per tank, blower: 390 Nm<sup>3</sup>/h per tank, water depth: 4.81 m

**Table 6 Specifications of Grit Chambers**

Facilities	Type	Number	Spec.
Pump	Vortex pumps	1	flow: 0.96 m <sup>3</sup> /min
Pump	Screw pumps	1	flow: 0.96 m <sup>3</sup> /min
Grit concentrator and washer	inclined screw	number of screws: 1	flow: 0.96 m <sup>3</sup> /min
Gates	slide, number of gates	2 units/bar screen	2,000 x 1,500 mm
Fine bar screen	rack	number of screens: 1	depth: 2.05 m, bar spacing: 13 mm

**(4) Chemical Feed System**

Ferric chloride ( $\text{Fe Cl}_3$ ) will be used for the assisted chemical treatment. Application of ferric salts ( $\text{Fe- Cl}_3$ ) as coagulant agent of the raw sewage can be made at 2 spots of the WWTP. A first application at the sewage inlet box, upstream the coarse racks and a second application at the fine racks channel.

**Table 7 Specifications of Chemical Feed System**

Facilities	Type	Number	Spec.
Tanks	Volume: 150,000 L/tank	1	material: fiber glass
Pumps	diaphragm pump	1	0.06 m <sup>3</sup> /min

**(5) Primary Clarifier**

The settling system consists of 2 (two) circular primary clarifiers with 40 m diameter, 4m total depth and 3.5 m water depth next to the wall. The outflow distribution to the clarifiers shall be made from the distribution box.

Feeding of clarifiers is made from the center of the unit and the scrapers driving system is central type.

Sludge and scum scrapers

type: circular, water depth next to the wall (m): 3.5, driving gear: central

feeding: central, sludge withdrawal: scraper, bottom declivity (v:h)1:12

overflow rate (m<sup>3</sup>/m<sup>2</sup>/d): 52.0 for average daily

**(6) Primary Sludge Pumping Station**

The primary sludge pumping station consists of a building with the dimensions 16.8 m x 7.0 m in plan, with the scum chamber next to it, with 2.7 m x 2.7 m dimensions in plan.

**Table 8 Specifications of Sludge Pumps**

Facilities	Type	Number	Spec.
Pumps	piston pump	2	0.66 m <sup>3</sup> /min

**(7) Equipment**

The list of main equipment of preliminary and primary units is shown below.

**Table 9 List of Primary Treatment Equipment**

Facilities	Equipment	Quantity			Capacity (m³/min/unit)	Power (kw/unit)	National(N) Imported(I)
		Total	PDBG	F/S			
Pumping station	Inlet pump	6	4	2	59.00	320	N
	Coarse bar screen	4	3	1	96.00	2.2	N
	Slide gate	8	6	2	-	-	N
Grit chamber	Aeration system	3	2	1	-	-	N
	Vortex pump	3	2	1	0.96	10.5	N
	Screw pump	3	2	1	0.96	-	N
	Grit concentrator and washer	3	2	1	0.96	0.75	I
	Blower	3	2	1	-	11.2	I
	Fine bar screen	4	3	1	96.00	2.24	N
	Slide gate	8	6	2	-	-	N
Chemical feedingsystem(FeCl <sub>3</sub> )	Tank	3	2	1	-	-	N
	Diaphragm pump	3	2	1	-	-	I
Primary clarifier	Sludge and scum scraper	4	2	2	72.00	1.12	I
Primary sludge pumping station	Pistom pump	5	3	2	0.66	7.5	I

### 2.1.3 SECONDARY TREATMENT UNITS

#### (1) General

The biological treatment is done through the activated sludge process. The primary effluent is conveyed to the aeration units and then to secondary clarifier.

The secondary treatment consists of the following main units:

Intermediate Pumping Station, Aeration Tanks, Blowers Platform, Secondary Clarifier, Sludge Pumping Station

#### (2) Intermediate Pumping Station

The function of the intermediate pumping station is to lift the primary effluent up to the adequate elevation so the secondary treatment occurs through gravity up to the receiving river Pavuna.

**Table 10 Specifications of Intermediate Pumps**

Facilities	Type	Number	Spec.
Screw pumps	Screw	1	0.96 m³/min, head: 4.15 m screw diameter: 2,750 mm, inclination: 38°

#### (3) Blowers Platform

The blowers are installed adjacent to the aeration tanks, on concrete platforms, protected from bad weather. The platform has the dimensions of 49m x 10.5 m in plan. The blowers have the following features:

**Table 11 Specifications of Blowers**

Facilities	Type	Number	Spec.
Blowers	centrifuge	3	12,100 Nm³/h

#### (4) Aeration Tanks

Primary effluent is conveyed directly to the aeration tanks. At the inlet of each six tanks with 24 m width, 48 m length and 6.2 m total depth, there is a distribution box which has the function to equally divide the outflow to each group of six aeration tanks.

From the total of 6 tanks, 4 have been constructed, and equipment was installed in just 3 tanks (PDBG-1). In this stage (F/S) the other 2 aeration tanks will be constructed and 3 more tanks will be equipped.

Diffuser system

type: flexible membrane, number of diffusers: 2,340 units per tank, type of bubble: fine, depth of the diffuser (m): 5.2 m, oxygen standard requirement (kg/h per tank): 797 for average daily, air outflow (Nm<sup>3</sup>/h per tank): 10,000 for average daily

**Table 12 Specifications of Aeration Tanks**

Facilities	Type	Number	Spec.
Tanks	-	2 (3)	water depth: 5.5 m volume: 6,340 m <sup>3</sup> per tank

#### (5) Secondary Clarifiers

The mixed liquor is conveyed to the secondary clarifiers, where the biological solids will be separated. The settling system consists of 3 (three) circular secondary clarifiers with 46 m diameter, with circular concrete structures with central feed.

Sludge removal is done through a mechanical scraper system which will convey the sludge up to the clarifier center. The secondary sludge is withdrawn through centrifuge pumps located at the sludge pumping station.

Sludge and scum scrapers

type: circular, water depth next to the wall (m): 4.0, driving gear: central

feeding: central, sludge withdrawal: scraper, bottom declivity (v:h) 1:12

overflow rate (m<sup>3</sup>/m<sup>2</sup>/d): 27.0 for average daily

Excess sludge production (kg/d SST)

average daily: 15,800

#### (6) Sludge Pumping Station

Sludge pumps installed in sludge pumping station withdraw the sludges from the six secondary clarifiers. 2 pumping stations are installed for each set of 3 secondary clarifiers.

The withdrawn sludge is raised to an outfall box; from which it returns to aeration tanks by gravity through two ductile cast iron pipelines.

The excess sludge is withdrawn from the outfall box, located at the outflow of the reflux pumps of the sludge pumping station, through 2 progressive cavity pumps, conveying the sludge to the further the process.

Each pumping station consists of a 13 m x 5 m building in plan, with the scum well and the pumped sludge channel next to it.

**Table 13 Specifications of Sludge Pumps**

Facilities	Type	Number	Spec.
Return sludge pumps	vertical centrifuge	3	15 –30 m <sup>3</sup> /min head (m): 7.5, speed: variable
Excess sludge pumps	progressive cavity	2	1.08 m <sup>3</sup> /min, head (m): 26.0, speed: variable

## (7) Equipment

The list of main equipment of secondary treatment units is shown below.

**Table 14 List of Secondary Treatment Equipment**

Facilities	Equipment	Quantity			Capacity (m <sup>3</sup> /min/unit)	Power (kw/unit)	National(N) Imported(I)
		Total	PDBG	F/S			
Intermediate pumping station	Screw pump	4	3	1	96.00	112	N
Blower bldg.	Blowers	7	4	3	-	373	I
Aeration tank	Diffusers system	6	3	3	-	-	I
Secondary clarifier	Sludge and scum scraper	6	3	3	48.00	1.12	I
Return sludge pumping station	Vertical centrifuge pumps	7	4	3	30.00	37.3	N
Return sludge pumping station	Progressive cavity pumps	4	2	2	1.08	14.9	N

### 2.1.4 SLUDGE TREATMENT

#### (1) Sludge Treatment Building

The purpose of sludge treatment is to reduce and stabilize sludges by dewatering and chemical stabilization prior to the final disposal. The treatment is performed in the sludge treatment building, where sludge pumping equipment, sludge dewatering, polymer application pumps and the sludge alkaline stabilization equipment are located. The following units are used for sludge treatment.

Thickening, Dewatering, Lime stabilization, Thermal drying

The sludge treatment building consists of two floors with 37 m x 20 m dimensions in plan.

## (2) Sludge Thickening and Dewatering

### Thickening centrifuges

operation period: 7 days/week, 24h/d, number of centrifuges: 2	
solids loading (kg/h/unit):	330 for average daily,
hydraulic loading (m <sup>3</sup> /h/unit):	47.1 for average daily,
thickened sludge concentration (%):	5 to 7

### Dewatering centrifuges

operation type: 7 days/week, 24h/d, number of centrifuges: 2+1	
solids loading (kg/h/unit):	1,350 for average daily,
hydraulic loading (m <sup>3</sup> /h/unit):	32.4 for average daily
dewatered sludge concentration (%):	24 to 27

Polymer shall be applied as conditioner for the sludge dewatering processes. These units shall apply the polymer with pre-settled dosing.

## (3) Lime Stabilization of Sludge and Further Drying

The dewatered sludge will be chemically stabilized by mixing alkaline material. Stabilized sludge is then dried by thermal dryer using natural gas. The expected moisture contents of stabilized and dried sludges are 64% and 20%, respectively.

The alkaline material used is the calcium oxide (CaO). It is mixed with dewatered sludge to lift its pH higher than 12 at least two hours after the application.

The lime coming from the “lime silo” is dosed and mixed with dewatered sludge in screw mixers located at the second floor of the building.

The lime amended sludge is then dried by thermal dryer to the moisture content as low as 20%. The dried sludge is unloaded at the second floor, through a hopper, to trucks parked at the ground floor which will convey the dried sludge to final disposal at a sanitary landfill site.

### Lime silo

diameter (m): 3.66 m, height (m) 8.1, available capacity (m <sup>3</sup> ): 65	
lime: 92%, dosing (kg CaO/ton dry sludge):	200 on average
operation (7 days/week):	24 h/d

### Lime dosing

capacity (kg/h): 60 – 1,200, operation (7 days/week):	24 h/d
---	--------

### Sludge and lime mixer

capacity (kg/h – dry basis): 4,100, operation (kg/h):	3,070 for average daily
detention time (s):	120

#### (4) Equipment

The list of main equipment of sludge treatment units is shown below.

**Table 15 List of Sludge Treatment Equipment**

Facilities	Equipment	Quantity			Capacity (m <sup>3</sup> /min/unit)	Power (kw/unit)	National(N) Imported(I)
		Total	PDBG	F/S			
Sludge treatment bldg.	Thickening centrifuges	3	2	1	47.1	45	I
	Dewatering centrifuges	2	2	-	32.4	45	I
	Lime system	3	2	1	-	11.2	N
	Sludge and lime mixer	2	2	-	-	22	I
	Polymer system	2	1	1	-	-	N
Thermal dryer bldg.	Thermal dryer	2	1	1	-	215	I




Figure 1 Mass Balance of Pavuna WWTP

## **2.2 ACARI SEWER DISTRICT**

### **2.2.1 LOCATION OF ACARI WWTP**

Acari WWTP is located at;

Rua Nazaré, Acari, Rio de Janeiro, RJ

The treated effluent is discharged to;

Rio Sapopemba

### **2.2.2 PRELIMINARY AND PRIMARY TREATMENT UNITS**

#### **(1) General**

Major preliminary and primary treatment units are shown below.

Raw Sewerage Pumping Station;

Grit chambers;

Primary Clarifier;

#### **(2) Raw Sewage Pumping Station**

The sewage flowing into the WWTP is conveyed up to the coarse bar screen chute where the material with dimension larger than 8 cm is removed.

The coarse bar screen chute has 2 (two) parallel segments and insulated by upstream floodgates and downstream the screens, in order to allow its maintenance.

The pumping station has 4 motor-pump sets, one of them is spare. Each set discharges 660 l/s it being 3 (three) groups with variable speed. The estimated head is 10.5 mca.

The sewage is conveyed through a channel to the fine screen (1 cm) system, where the channel is subdivided into 3 (three) smaller channels directing the sewage to each screen. Each rack is insulated by a system of sliding floodgates, upstream and downstream. The racked material shall be cast on conveying mats and then taken to a compacter.

#### **(3) Grit Chambers**

The grit is removed by 2 (two) mechanized and square chambers with 10m side, which shall remove particles with diameter less than 0.2 mm. The material removed will be washed taken to the sanitary landfill.

Measuring of the flow to the WWTP is done through Parshall downstream the Grit Chamber.

#### **(4) Primary Clarifiers**

The settling system consists of 4 (four) circular primary clarifiers with 25 m diameter and 3.5m water depth. The flow distribution to the clarifiers shall be made from the distribution chamber.

Feeding of clarifiers is made from the center of the unit and the scrapers driving system is central type.

The sludge settled in the clarifiers is conveyed to the unit center from where it is withdrawn through helical pumps.

## (5) Equipment

The list of main equipment of the preliminary and primary treatment units is shown below.

**Table 16 List of Primary Treatment Equipment**

Place	Equipment	Capacity (m <sup>3</sup> /min/unit)	Quantity	Power (kw/unit)	National (N) Imported (I)
Raw Sewerage Pumping Station	Coarse bar screen	59.4	2	2.0	N
Raw Sewerage Pumping Station	Slide gates	59.4	8	-	N
Raw Sewerage Pumping Station	Vertical Centrifuge Pump	39.6	4	100	N
Raw Sewerage Pumping Station	Fine bar screen	39.6	3	2.0	N
Grit Chamber	Bottom scraper	59.4	2	-	N
Grit Chamber	Screw for sand removal	-	2	-	N
Primary Clarifier	Sludge and Scum Scrapers	29.7	4	1	I
Primary Sludge Pumping Station	Progressive Cavity Pumps	-	5	-	N
Thickeners	Bottom Scrapers	0.75	4	0.37	N

## 2.2.3 SECONDARY TREATMENT UNITS

### (1) General

The biological treatment is done through the activated sludge process. The primary effluent is conveyed to the aeration units and then to secondary clarifiers.

The secondary treatment consists of the following main units:

Aeration Tanks

Blowers

Secondary Clarifier

Sludge Return Pumping Station

### (2) Aeration Tanks

Primary effluent is conveyed directly to the aeration tanks. At the inlet of each four tanks there is a chamber which has the function to equally divide the outflow to each group of four aeration tanks.

The liquid effluent to the chamber goes through a spiller, unloading individually into the aeration tank.

Inlet of the return sludge and the primary effluent into the aeration tank is controlled by two electrically driven floodgates.

The effluent of each group of four aeration tanks shall flow through a pipeline to two secondary clarifiers.

The process parameters are as follows:

Sludge age (days)	8
Retention time (hours)	6.6
Substratum / micro-organisms ratio F/M	0.35
Mixed liquor concentration (mg/l)	2,411 for average daily
Production of excess sludge (kg/d TSS)	11,795 for average daily
Excess sludge concentration (mg/l)	6,400 – 8,000
Demand of Oxygen (kg/h)	1,650

Main features of the aeration tanks are as hereunder:

Number of tanks	8
Width (m)	13
Length	50
Water depth (m)	5.0
Total depth (m)	6.0
Volume (m <sup>3</sup> per tank)	3,250

Air to the diffusers shall be supplied by a blowers system and distribution pipes (stainless steel for pipes that are not in contact with the sewage and glass fiber for internal pipeline to the aeration tanks). The air diffusion system has the following features:

Type of diffuser	Flexible membrane
Material	EPDM
Type of bubble	fine
Depth of the diffuser (m)	4.8
Oxygen requirement (kg/h per tank)	206 for average daily
Air outflow (Nm <sup>3</sup> /h per tank)	4,980 for average daily

### (3) Blowers Platform

The blowers shall be installed adjacent to the aeration tanks, in concrete platforms, protected from bad weather. These blowers have the following features:

Type of blower	Centrifuge
Number of blowers	4 + 1 (one for standby)
Air (Nm <sup>3</sup> /h/unit)	9,960
Power (KW/unit)	192

### (4) Secondary Clarifiers

The mixed liquor will be conveyed to the secondary clarifiers, where the biological solids will be separated.

4 secondary clarifiers shall be implemented with 35m diameter, with circular concrete structures with central feed.

Sludge will be accumulated through a mechanical scraper system which will convey the sludge up to the clarifier center. The secondary sludge shall be withdrawn through centrifuge pumps located on the sludge pumping station.

This same equipment makes the superficial scum removal, which shall be conveyed to a well.

The plant effluent will be discharged into a reinforced concrete culvert to be conveyed to the receiving body (Sapopemba river).

The main features of the secondary clarifiers and the main design parameters are shown below:

Type of clarifier	Circular
Number of clarifiers	4
Sludge and scum withdrawal driving gear	central
Feeding	central
Sludge withdrawal	scraper
Diameter (m)	35
Water depth in the wall (m)	4.0
Bottom declivity (v:h)	1:12
Overflow rate ( $m^3/m^2/d$ )	24.5 for average daily
Superficial load of solids ( $kg/m^2/d$ )	122 for average daily
Excess sludge production ( $kg/d TSS$ )	11,793 for average daily

## (5) Sludge Pumping Station

Sludges from four secondary clarifiers are withdrawn by pumps installed in sludge pumping station.

The sludges are withdrawn and raised to an outfall box; from this box it will continue through gravity up to the aeration tanks through two ductile cast iron pipelines.

Its structure shall be of two floors, one being at the ground level and the other below where the centrifuge pumps and of progressive cavity will be sheltered. Besides these pumps, it is foreseen a well pump to drain the pumps well.

Each reflux pump will exclusively consider one clarifier; it is also foreseen 1 (one) spare pump which will remain at the storehouse.

The excess sludge is withdrawn from the outfall box, located at the outflow of the reflux pumps of the sludge return pumping station, through 2 progressive cavity pumps. This box shall have a "stop-log" separating the casting of each two reflux pumps. The third pump shall be normally used to pump the floating matter removed from the clarifiers, also being a spare unit.

Each reflux pump for withdrawal of excess sludge is equipped with a speed varying to adjust the upsetting outflow. Magnetic outflow meters are foreseen at the system outflow and sludges reflux and discard.

The main features of the sludge recirculation and discard system are shown below.

### 1) Return Sludge Pumps

Type of pump	Centrifuge
Speed	Variable
Number of pumps	4 + 1 (one for standby)
Capacity (m <sup>3</sup> /min/unit)	8.4 to 12.0
Power (KW/unit)	17.5

### 2) Excess Sludge Pumps

Type of pump	Progressive Cavity
Speed	Variable
Number of pumps	2 + 1 (one for standby)
Capacity (m <sup>3</sup> /min/unit)	0.90 - 1.80
AMT (bar)	4
Power (KW/unit)	20.0

### 3) Auxiliary Equipment

The sludge return pumping stations have the following facilities:

Overhead crane and Tackle;

Service water system to seal the pumps;

Draining system, with submerged motor pump for 6 l/s and 6 mca head.

## (6) EQUIPMENT

The following list shows main equipment of the secondary treatment units:

**Table 17 List of Secondary Treatment Equipment**

Place	Equipment	Capacity (m <sup>3</sup> /min/unit)	Quantity	Power (kw/unit)	National(N) Imported(I)
Aeration Tank	Diffusers system	-	8	-	I
Aeration Tank	Blowers	166	5 (4+1)	192	N
Secondary Clarifier	Sludge and Scum scrapers	-	4	1	I
Sludge Pumping Station	Centrifuge pumps	12.0	5 (4+1)	17.5	N
Sludge Pumping Station	Progressive Cavity Pumps	1.8	3 (2+1)	20	N

### 2.2.4 SLUDGE TREATMENT

#### (1) Sludge Thickening and Dewatering

The treatment is done in the Sludge Treatment Building, inside which are located the equipment necessary for performance of the centrifuge thickening, mechanical dewatering and drying stages.

## (2) Gravity Thickener

The primary sludge withdrawn from the primary clarifiers has 1.0 to 1.5% concentration of solids. It will be thickened to 4-5% by gravity thickeners. There are 4 (four) thickeners with 8.0 m diameter and 3.5 m water depth next to the wall.

Inlet of the primary sludge will be through the center of the thickener and drive of bottom scrapers is central type. The sludge settled in the bottom are withdrawn through gravity and conveyed up to the sludge raising well from where it is alternately pumped to each digester.

## (3) Thickening of Excess Sludge

The excess sludge and the floating material removed from the secondary clarifiers will be pumped to the sludge treatment building where they will be chemically conditioned with polymer for its thickening in the centrifuges.

The thickened excess sludge will be conveyed up to the thickened sludge pumping station to be mixed with the gravity thickened primary sludge.

The liquid withdrawn from the thickening process through draining (centered) returns to sewage treatment process.

The main features of the centrifugal thickening system are shown below.

### 1) Thickening Centrifuges

Number of units	2 + 1 (one for standby)
Operation	7 days/week, 20h/d
Solids loading (kg/h/unit)	295 for average daily
Hydraulic load ( $m^3/h/unit$ ) <sup>1</sup>	46 for average daily
Thickened sludge concentration (%)	5.0

(Assuming a minimum concentration of 6 400 mg/l of TSS in the sludge excess.)

### 2) Pumps of Thickened Excess Sludge

The centrifuges thickened sludge is conveyed to the collection well and then, pumped up to the thickened sludge pumping station.

Type	Progressive Cavity
Speed	variable
Number of pumps	1 + 1 (one for standby)
Capacity ( $m^3/min/unit$ )	0.72 - 1.44
AMT (bar)	2.0
Power (KW/unit)	10.0

### 3) Dosing and Dilution Unit

Polymer is applied as conditioner for the excess sludge thickening processes.

Number of Units	2
Polymer concentration applied (%)	0.05 - 0.5
Polymer consumption (kg of polymer/ton sludge)	2
Water outflow for dilution (l/min/unit)	3 - 20

#### 4) Mixer

Type	Submersible
Number of mixers	1
Motor power (kW per mixer)	1.9

#### (4) Anaerobic Digestion

3 primary digesters and 1 secondary digester with dimensions 16.5m diameter and 17.5m height are installed to digest both thickened primary and excess sludges.

Recirculation of the liquid inside the digesters are done with centrifuge pumps, that will operate 24 hours per day, pumping the sludge alternately from the upper to the lower part and vice-versa every 2 hours.

##### 1) Sludge Reflux Pumps in the Digester

Type of pump	Vertical centrifuge
Number of pumps	6
Capacity (m <sup>3</sup> /min/unit)	31.2
Power (KW/unit)	34

##### 2) Digested Sludge Pumps

The digested sludge is conveyed through pumps up to the dewatering process.

Type	Progressive cavity
Speed	variable
Number of pumps	1 + 1 (one for standby)
Capacity (m <sup>3</sup> /min/unit)	0.12 - 0.6
AMT (bar)	2.0
Power (KW/unit)	4.5

#### (5) Mechanical Sludge Dewatering

The digested sludge shall be mechanically dewatered by centrifuges. A total of two centrifuges (one operational and one standby) will dewater the sludge to solids concentration of 25%.

The sludge is chemically conditioned through addition of polymer before being supplied to the centrifuges. The sludge cake resulting from dewatering will be unloaded in a conveying screws system which will convey them up to the thermal drying system.

The conveying screws system will replace the existing mats and will consist of a set of horizontal and tilted screws. The liquid waste from the dewatering process will return to the plant inlet.

The main features of the sludge mechanical dewatering system are shown below:

### **1) Dewatering Centrifuges**

Number of units	1 + 1 (one for standby)
Operation (7days/week)	20 h/d
Solids loading (kg/h/unit)	729 for average daily
Hydraulic load (m <sup>3</sup> /h/unit)	208 for average daily
Dewatered sludge concentration (%)	25.0

### **2) Dosing and Diluting Unit**

Polymer is applied as conditioner for the sludge dewatering processes.

Number of Units	1
Concentration of polymer in the application (%)	0.05 - 0.5
Polymer consumption (kg of polymer/ton sludge)	10
Water outflow for dilution (l/min/unit)	55 - 240

### **3) DEWATERED Sludge Conveying System**

Dewatered sludge is conveyed through conveying screws to the thermal drying system. The conveying screws comply with the sludge volume produced by the dewatering centrifuges.

## **(6) Equipment**

The list of main equipment of the sludge treatment area is shown below:

**Table 18 List of Sludge Treatment Equipment**

Place	Equipment	Capacity (m <sup>3</sup> /min/unit)	Quantity	Power (kw/unit)	National (N) Imported (I)
Sludge Treatment	Thickening Centrifuges	46.0 (*)	3 (2+1)	45	I
Sludge Treatment	Dewatering Centrifuges	20.8 (*)	2 (1+1)	45	I
Sludge Treatment	Dosing and Diluting Units	-	3		I
Sludge Treatment	Thermal dryer	-	1	105	I
Pumping of thickened excess sludge	Progressive cavity Pumps	1.44	2 (1+1)	10	N
Pumping of digested sludge	Progressive cavity Pumps	0.6	2 (1+1)	4.5	N
Digester	Vertical centrifuge pumps	31.2	6	34	N

Note: (\*) Capacity in m<sup>3</sup>/h/unit

### **2.2.5 DESIGN CALCULATION**

Design Calculations of Acari WWTP are shown in bellow.

## ETE ACARI (WWTP ACARI)

### 1) Eficiências p/ Tratamento (Efficiency)

1) BOD <sub>5</sub> removed.....=	30%	(primary treatment)
2) TSS removed.....=	50%	(primary treatment)
3) BOD <sub>5</sub> .....=	91%	(secondary treatment)
4) TSS.....=	92%	(secondary treatment)
5) VSS/TSS.....=	0.75	
6) BOD influent.....=	230	mg/l
7) BOD effluent.....=	20	mg/l
8) TSS influent.....=	250	mg/l
9) TSS effluent.....=	20	mg/l

### 2) Caixa de Areia (Grit Chamber)

1) Qmáx.....=	1.98	m <sup>3</sup> /s
2) Number of units.....=	2	
3) Qunit.....=	0.99	m <sup>3</sup> /s
4) Surface-loading rate .....	1000	m <sup>3</sup> /m <sup>2</sup> .d (ranger 600-1300)
5) Width.....=	10	m
6) Water deptht.....=	0.65	m
7) Velocity .....	0.15	m/s

### 3) Decantador Primário (Primary Clarifier)

1) Qavg.....=	1.1	m <sup>3</sup> /s
2) Qmax.....=	1.98	m <sup>3</sup> /s
3) Number of units.....=	4	
4) Qunit.....=	0.50	m <sup>3</sup> /s
5) Diameter.....=	25	m
6) Water deptht.....=	3.5	m (> 2,0 m)
7) Unit Area .....	490.9	m <sup>2</sup>
8) Surface-loading rate .....	87.1 - 48.4	m <sup>3</sup> /m <sup>2</sup> .d max-avg (ranger 0 - 120)
9) Hydraulics detention time (max).....=	2.2	h
10) Hydraulics detention time (min).....=	1.0	h
11) Weir-loading rate.....=	302.5	m <sup>3</sup> /m.d (ranger 0 - 720)
12) Solids concentration (outflow).....=	1.2%	(ranger 1 - 2)
13) TSS.....=	12,889.0	kg SS/d
14) Total sludge flow.....=	44.8	m <sup>3</sup> /h
15) Slope.....=	1/12	m/m

### 4) Tanque de Aeração (Aeration Tank)

1) BOD influent (So).....=	161.00	mg/l
2) Soluble BODeffluent (S).....=	10.56	mg/l
3) Qavg.....=	1.10	m <sup>3</sup> /s
4) Maximum yield coef. (Y).....=	0.55	kgMLVSS/kgBOD
5) Endogenous decay coef. (Kd).....=	0.08	1/dia
6) Rate Biodegradable VSS (F'b ).....=	0.80	
7) Sludge age (θ).....=	8.00	dias
8) Rate recycle.....=	0.60	
9) Number of units.....=	8.00	
10) Rate Biodegrad. VSS after sludge age (Fb)....=	0.71	Fb = F'b / (1 + (1 - F'b) x Kd x θ)
11) MLSS (X).....=	2,411	mg/l
12) MLVSS (Xv).....=	1,664	mg/l
13) Water depth.....=	5.00	m
14) Length.....=	50.00	m
15) Width.....=	13.00	m
16) Unit Volume (V).....=	3250	m <sup>3</sup>
17) Total Volume .....=	26000	m <sup>3</sup> V = Yx θ x Qavg x (So - S)/(Xv x (1 + Kd x Fb x θ))
18) Hydraulics detention time .....	6.60	h
19) Concentration in return (Xr).....=	6,431	mg/l
20) Rate Food/Microorg (F/M).....=	0.35	kgBOD5/kgMLVSS.dia (ranger 0,07 - 1)
21) Rate Food/Microorg (F/M).....=	0.24	kgBOD5/kgMLSS.dia
22) Net specific growth rate (U).....=	0.33	kgBOD5/kgMLVSS.dia (ranger 0,06 - 1)
23) Flowrate Wasted (Qex).....=	1,834	m <sup>3</sup> /d
24) Solids removed (Px).....=	11,793	kg/d

## 5) Decantador Secundário (Secondary Clarifier)

1) Qavg.....	=	1.10	m3/s	$\begin{cases} \text{MLSS}<3000\text{mg/l} - R>=0.25 \text{ e } TH<=36 \\ \text{MLSS}>=3000\text{mg/l} \text{ e } \\ <4500\text{mg/l} - R>=0.50 \text{ e } TH<=24 \\ \text{MLSS}>=4500\text{mg/l} - R>=1 \text{ e } TH<=16 \end{cases}$
2) Rate recycle (R).....	=	0.60		
3) Recycle flowrate.....	=	0.66	m3/s	
4) Diameter.....	=	35	m	
5) Water depth.....	=	4	m	
6) Slope.....	=	1/12	m/m	
7) Number units.....	=	4		
8) Unit Volume .....	=	3,848	m3	
9) Unit Area .....	=	962	m2	
10) Hydraulics detention time .....	=	3.9	h	
11) Surface-loading rate (TH).....	=	24.7	m3/m2/d	
12) Solids loading rate.....	=	122	kg/m2/d	
			<	144 kg/m2/d




Figure 2 Solids - Concentration Curve

## 6) Adensador por Gravidade (Gravity Thickening)

1) Concentration in influent.....	=	12,000 mg/l	=	12 kg/m3
2) Concentration in effluent.....	=	4.0%	(ranger 0 - 10)	
3) TSS.....	=	12,889.0	kg SS/d	
4) Number of units.....	=	4		
5) TSS for unit.....	=	3,222.0	kg SS/d	
6) Diameter.....	=	8	m	
7) Unit Area .....	=	50.3	m²	
8) Solids loading rate.....	=	64.1	kg SS/m².d (ranger 0 - 150)	
9) TSS effluent.....	=	11,600	kg SS/d	
10) Sludge flow effluent.....	=	12.1	m³/h	
11) TSS in supernatant.....	=	1,289	kg SS/d	
12) Supernatant flow.....	=	32.7	m³/h	
13) Water depth.....	=	3.50	m (>=3,0m)	
14) Unit Volume .....	=	175.6	m³	
15) Hydraulics detention time .....	=	12.58	h (<= 24 h)	
16) Surface-loading rate .....	=	5.3	m³/m².d	
17) Solids recovery.....	=	90.0%		
18) Declividade do fundo.....	=	1/12	m/m	

## 7) Centrífugas de Adensamento (Centrifuge Thickening)

1) TSS influent.....	=	11,794.0	kg SS/d
2) Concentration influent in centrifuge.....	=	0.64%	
3) Concentration effluent in centrifuge.....	=	5.0%	
4) Flowrate to Centrifuge .....	=	18.8	l/s
5) Solids recovery.....	=	95.0%	
6) TSS effluent.....	=	11,204.0	kg SS/d
7) Blended sludge.....	=	2.6	l/s
8) Thinckener effluent.....	=	18.6	l/s
9) Number operation centrifuge .....	=	2.0	
10) Operation time.....	=	20	h/d
11) Hydraulics flow .....	=	45.8	m³/h/unit

**Polymers application**

12) Dosage.....=	2	kg Pol / t SS
13) Polymers Concentration.....=	30.0%	
14) Concentration application polymers.....=	0.20% - 0.05%	
15) Total polymers.....=	23.6	kg/d de pol

**8) Digestores (Digesters)****7.1) Primary Digester**

1) Type.....=	High rate	
2) TSS influent.....=	22,804.0	kg SS/d
3) VSS/TSS.....=	0.721	
4) Concentration Solids.....=	3.5%	
5) High rate digestion.....=	1.2 - 6.0	kg VSS/m3
6) Sludge Volume influent (Vf).....=	502.1	m3/d
7) Sludge Volume effluent (Vd).....=	408.6	m3/d
8) Digestion time(t).....=	25	dias
9) Sludge Volume in digesters (V).....=	10,994.2	m3
10) Number digester.....=	3	
11) Diameter.....=	16.5	m
12) Height.....=	17.5	m
13) Volume Unit.....=	3,741.9	m3

**7.2) Digestor Secundário**

1) Number.....=	1	
2) Diameter.....=	16.5	m
3) Height.....=	17.5	m
4) Volume Unit.....=	3,741.9	m3

**9) Centrífugas de Desidratação (Centrifuge Dewatering)**

1) TSS influent.....=	14,588.0	kg SS/d
2) Concentration influent in centrifuge.....=	3.5%	
3) Concentration effluent in centrifuge.....=	25.0%	
4) Flowrate to Centrifuge .....	4.8	l/s
5) Solids recovery.....=	95.0%	
6) TSS effluent.....=	13,858.0	kg SS/d
7) Sludge Flow dewatering .....	0.6	l/s
8) Filtrate .....	4.2	l/s
9) Number operation centrifuge .....	1.0	
10) Operation time.....=	20	h/d
11) Hydraulics flow .....	20.8	m3/h/unit

**Polymers application**

12) Dosage.....=	10	kg Pol / t SS
13) Polymers Concentration.....=	30.0%	
14) Concentration application polymers.....=	0.20% - 0.05%	
15) Total polymers.....=	145.9	kg/d de pol

**10) Consumo de Oxigênio (Oxygen-Transfer)****10.1) Oxygen Requirements from removal of Carbonaceous organic matter (DOC)**

1) DOC.....=	13,195.0 kg O2/d	DOC = Qavg x (So-S) x (1,46 - (1,42 x Y)/(1+ Kd x Fb x θ))
--------------	------------------	--

**10.2) Oxygen Requirement from Nitrification (DON)**

1) Population.....=	390,000 hab	
2) Nitrogen.....=	8 g NTK/dia/p	
3) Total Nitrogen.....=	3,120.0 kg/dia	
4) Concentration (CN).....=	32.8 mg/l	
5) Efficiency from Primary treatment (effn).....=	20.0%	
6) DON.....=	11,406.7 kg O2/d	DON = (4,57 x Qavg x CN /1000) x (1-effn)

**10.3) SOTE (standardized oxygen-transfer)**

1) SOTE = DOC + DON.....=	24,601.3 kg O2/d	
---------------------------	------------------	--

**10.4) Oxygen Transferred under field conditions (OTR)**

1)	$\alpha$ (oxygen-transfer correction factor for water). =	0.85
2)	$\beta$ (saturação de O <sub>2</sub> no esgoto/na água). =	0.95
3)	CL (operation oxygen concentration)..... =	2.0 mg/l
4)	CS summer(O <sub>2</sub> saturation in water)..... =	8.4 g/m <sup>3</sup>
5)	CS 20 °(O <sub>2</sub> saturation in water)..... =	9.2 g/m <sup>3</sup>
6)	$\delta$ (coeff. temperature)..... =	1.024
7)	Summer temperature..... =	25 °C
8)	OTR (summer)..... =	39,548.0 kg O <sub>2</sub> /d

$$OTR = SOTE / (((\beta \times CS - CL) / CS(20^\circ C)) \times \alpha \times \delta^{(T-20)})$$

**10.5) Air Requirement**

1)	Efficiency..... =	15.0%
2)	Specific weight of air..... =	1.2 kg/m <sup>3</sup>
3)	O <sub>2</sub> in air..... =	0.23 g O <sub>2</sub> / g ar
4)	Air..... =	663.0 m <sup>3</sup> /min de ar

**10.6) Power**

1)	Specific weight of water..... =	1000 kg/m <sup>3</sup>
2)	Diffuser depth..... =	4.8 m
3)	Headloss..... =	0.87 m
4)	Efficiency..... =	80.0%
5)	Power..... =	192 kW/unit
6)	Number of blowers..... =	4 + 1




Figure 3 Mass Balance of Acari WWTP

## 2.3 SARAPUI WWTP

### 2.3.1 LOCATION OF SARAPUI WWTP

Sarapui WWTP is located at:

Rua Demóstenes, Jardim Ideal, Belford Roxo, RJ

The treated effluent is discharged to:

Rio Sarapuí

### 2.3.2 PRELIMINARY AND PRIMARY TREATMENT UNITS

#### (1) General

Preliminary and primary treatment units are shown below.

Raw Sewage Pumping Station; Grit chamber; Chemical Feed System; Primary Clarifier; Primary Sludge Pumping Station.

#### (2) Raw Sewage Pumping Station

The sewage flowing into the WWTP is conveyed up to the screen channel where the material with dimension larger than 5 cm is removed. The pumping station has the following characteristics:

**Table 19 Specifications of Inlet Pumps**

Facilities	Type	Number	Spec.
Inlet pumps	vertical centrifugal	2	Head: 14.3 m
Gates	slide	2 units/ bar screen	1,400 x 1,400 mm
Coarse bar screen	rack	1	depth: 11.2 m, bar spacing: 50 mm

#### (3) Grit Chambers

The grit removal system is performed by 3 (three) aerated and rectangular chambers with width 6 m, length 15 m and total depth 5.75 m. The material removed shall be washed and after this operation it shall be taken to the sanitary backfill. The grit chambers has the hereunder main characteristics:

Aeration system

type: 15 diffusers / tank coarse bubble, number of pumps: 1, air flow requirement: 390 Nm<sup>3</sup>/h per tank, blower: 390 Nm<sup>3</sup>/h per tank, water depth: 4.81 m

**Table 20 Specifications of Grit Chambers**

Facilities	Type	Number	Spec.
Pump	Vortex pumps	1	0.96 m <sup>3</sup> /min
	Screw pumps	1	0.96 m <sup>3</sup> /min
Grit concentrator and washer	inclined screw	1	0.96 m <sup>3</sup> /min
Gates	slide	2 units/bar screen	2,000 x 1,500 mm
Fine bar screen	rack	1	depth: 2.05 m, bar spacing: 13 mm

#### (4) Chemical Feed System

Ferric chloride ( $\text{Fe Cl}_3$ ) will be used for the assisted chemical treatment. Application of ferric salts ( $\text{Fe-Cl}_3$ ) as coagulant agent of the raw sewage can be made at 2 spots of the WWTP. A first application at the sewage inlet box, upstream the coarse racks and a second application at the fine racks channel.

**Table 21 Specifications of Chemical Feed System**

Facilities	Type	Number	Spec.
Tanks	-	1	150,000 L/tank material: fiber glass
Pumps	diaphragm pump	1	0.06 m <sup>3</sup> /min

#### (5) Primary Clarifier

The settling system consists of 1 (one) circular primary clarifier with 40 m diameter, 4m total depth and 3.5 m water depth next to the wall. The outflow distribution to the clarifiers shall be made from the distribution box.

Feeding of clarifiers is made from the center of the unit and the scrapers driving system is central type.

Sludge and scum scrapers

type: circular, water depth next to the wall (m): 3.5, driving gear: central

feeding: central, sludge withdrawal: scraper, bottom declivity (v:h)1:12

overflow rate (m<sup>3</sup>/m<sup>2</sup>/d): 57.3 for average daily

#### (6) Primary Sludge Pumping Station

The primary sludge pumping station consists of a building with the dimensions 16.8 m x 7.0 m in plan, with the scum chamber next to it, with 2.7 m x 2.7 m dimensions in plan.

**Table 22 Specifications of Primary Sludge Pumps**

Facilities	Type	Number	Spec.
Pumps	piston pump	2	0.66 m <sup>3</sup> /min

#### (7) Equipment

The list of main equipment of preliminary and primary units is shown below.

**Table 23 List of Primary Treatment Equipment**

Facilities	Equipment	Quantity			Capacity (m <sup>3</sup> /min/unit)	Power (kw/unit)	National(N) Imported(I)
		Total	PDBG	F/S			
Pumping station	Inlet pump	4	3	1	84.00	280	N
	Coarse bar screen	3	2	1	126.00	2.2	N
	Slide gate	6	4	2	-	-	N
Grit chamber	Aeration system	3	2	1	-	-	N
	Voltex pump	3	2	1	0.96	10.5	N
	Screw pump	3	2	1	0.96	-	N
	Grit concentrator and washer	3	2	1	0.96	0.75	I
	Blower	3	2	1	-	11.2	I
	Fine bar screen	4	3	1	96.00	2.24	N
	Slide gate	8	6	2	-	-	N
Chemical Feedingsystem (FeCl <sub>3</sub> )	Tank	3	2	1	-	-	N
	Diaphram pump	3	2	1	-	-	I
Primary clarifier	Sludge and scum scraaper	3	2	1	72.00	1.12	I
Primary sludge pumping station	Pistom pump	4	3	1	0.66	7.5	I

### 2.3.3 SECONDARY TREATMENT UNITS

#### (1) General

The biological treatment is done through the activated sludge process. The primary effluent is conveyed to the aeration units and then to secondary clarifier.

The secondary treatment consists of the following main units:

Intermediate Pumping Station, Aeration Tanks, Blowers Platform, Secondary Clarifier, Sludge Pumping Station

#### (2) Intermediate Pumping Station

The function of the intermediate pumping station is to lift the primary effluent up to the adequate elevation so the secondary treatment occurs through gravity up to the receiving river Sarapui.

**Table 24 Specifications of Intermediate Pumps**

Facilities	Type	Number	Spec.
Screw pumps	screw	1	0.96 m <sup>3</sup> /min, head: 4.15 m screw diameter: 2,750 mm, inclination: 38°

#### (3) Blowers Platform

The blowers are installed adjacent to the aeration tanks, on concrete platforms, protected from bad weather. The platform has the dimensions of 49m x 10.5 m in plan. The blowers have the following features:

**Table 25 Specifications of Blowers**

Facilities	Type	Number	Spec.
Blowers	centrifuge	2	12,100 Nm <sup>3</sup> /h

**(4) Aeration Tanks**

Primary effluent is conveyed directly to the aeration tanks. At the inlet of each six tanks with 24 m width, 48 m length and 6.2 m total depth, there is a distribution box which has the function to equally divide the outflow to each group of six aeration tanks .

From the total of 6 tanks, 4 have been constructed , and equipment was installed in just 3 tanks (PDBG-1). In this stage (F/S) the other 2 aeration tanks will be constructed and 2 more tanks will be equipped. In total, six tanks will be constructed out of which five tanks are equipped with diffusers.

## Diffuser system

type: flexible membrane, number of diffusers: 2,340 units per tank, type of bubble: fine, depth of the diffuser (m): 5.2 m, oxygen standard requirement (kg/h per tank):797 for average daily, air outflow (Nm<sup>3</sup>/h per tank): 10,000 for average daily

**Table 26 Specifications of Aeration Tanks**

Facilities	Type	Number	Spec.
Tanks	-	2	water depth: 5.5 m, volume: 6,340 m <sup>3</sup> per tank

**(5) Secondary Clarifiers**

The mixed liquor is conveyed to the secondary clarifiers, where the biological solids will be separated. The settling system will consist of 2 (two) circular secondary clarifiers with 46 m diameter, with circular concrete structures with central feed. Three out of five clarifiers are already constructed and two others will be constructed.

Sludge removal is done through a mechanical scraper system which will convey the sludge up to the clarifier center. The secondary sludge is withdrawn through centrifuge pumps located at the sludge pumping station.

## Sludge and scum scrapers

type: circular, water depth next to the wall (m): 4.0, driving gear: central

feeding: central, sludge withdrawal: scraper, bottom declivity (v:h)1:12

overflow rate (m<sup>3</sup>/m<sup>2</sup>/d): 26.0 for average daily

## Excess sludge production (kg/d SST)

average daily: 15,800

## (6) Sludge Pumping Station

Sludge pumps installed in sludge pumping station withdraw the sludges from the six secondary clarifiers. 2 pumping stations are installed for each set of 3 secondary clarifiers.

The withdrawn sludge is raised to an outfall box; from which it returns to aeration tanks by gravity through two ductile cast iron pipelines.

The excess sludge is withdrawn from the outfall box, located at the outflow of the reflux pumps of the sludge pumping station, through 2 progressive cavity pumps, conveying the sludge to the further the process.

Each pumping station consists of a 13 m x 5 m building in plan, with the scum well and the pumped sludge channel next to it.

**Table 27 Specifications of Sludge Pumps**

Facilities	Type	Number	Spec.
Return sludge pumps	vertical centrifuge	2	15 –30 m <sup>3</sup> /min head: 7.5 m, speed: variable
Excess sludge pumps	progressive cavity	2	1.08 m <sup>3</sup> /min, head: 26.0 m, speed: variable

## (7) Equipment

The list of main equipment of secondary treatment units is shown below.

**Table 28 List of Secondary Treatment Equipment**

Facilities	Equipment	Quantity			Capacity (m <sup>3</sup> /min/unit)	Power (kw/unit)	National(N) Imported(I)
		Total	PDBG	F/S			
Intermediate pumping station	Screw pump	4	3	1	96.00	112	N
Blower bldg.	Blowers	6	4	2	-	373	I
Aeration tank	Diffusers system	5	3	2	-	-	I
Secondary clarifier	Sludge and scum scraaper	5	3	2	48.00	1.12	I
Return sludge pumping station	Vertical centrifuge pumps	6	4	2	30.00	37.3	N
Return sludge pumping station	Progressive cavity pumps	4	2	2	1.08	14.9	N

### 2.3.4 SLUDGE TREATMENT

#### (1) Sludge Treatment Building

The purpose of sludge treatment is to reduce and stabilize sludges by dewatering and chemical stabilization prior to the final disposal. The treatment is performed in the sludge treatment building, where sludge pumping equipment, sludge dewatering, polymer application pumps and the sludge alkaline stabilization equipment are located. The following units are used for sludge treatment.

Thickening, Dewatering, Lime stabilization, Thermal drying

The sludge treatment building consists of two floors with 37 m x 20 m dimensions in plan.

## **(2) Sludge Thickening and Dewatering**

Thickening centrifuges

operation period: 7 days/week, 24h/d, number of centrifuges: 2  
 solids loading (kg/h/unit):330 for average daily,  
 hydraulic loading ( $m^3/h/unit$ ):47.1 for average daily,  
 thickened sludge concentration (%): 5 to 7

Dewatering centrifuges

operation type: 7 days/week, 24h/d, number of centrifuges: 2+1  
 solids loading (kg/h/unit):1,350 for average daily,  
 hydraulic loading ( $m^3/h/unit$ ):32.4 for average daily  
 dewatered sludge concentration (%): 24 to 27

Polymer will be applied as conditioner for the sludge dewatering processes. These units will apply the polymer with pre-settled dosing.

## **(3) Lime Stabilization of Sludge and Further Drying**

The dewatered sludge will be chemically stabilized by mixing alkaline material. Stabilized sludge is then dried by thermal dryer using natural gas. The expected moisture contents of stabilized and dried sludges are 64% and 20%, respectively.

The alkaline material used is the calcium oxide (CaO). It is mixed with dewatered sludge to lift its pH higher than 12 at least two hours after the application.

The lime coming from the “lime silo” is dosed and mixed with dewatered sludge in screw mixers located at the second floor of the building.

The lime amended sludge is then dried by thermal dryer to the moisture content as low as 20%. The dried sludge is unloaded at the second floor, through a hopper, to trucks parked at the ground floor which will convey the dried sludge to final disposal at a sanitary landfill site.

Lime silo

diameter (m): 3.66 m, height (m) 8.1, available capacity ( $m^3$ ): 65  
 lime: 92%, dosing (kg CaO/ton dry sludge): 200 on average  
 operation (7 days/week): 24 h/d

Lime dosing

capacity (kg/h): 60 – 1,200, operation (7 days/week): 24 h/d

Sludge and lime mixer

capacity (kg/h – dry basis): 4,100, operation (kg/h):3,070 for average daily  
detention time (s): 120

#### (4) Equipment

The list of main equipment of sludge treatment units is shown below.

**Table 29 List of Sludge Treatment Equipment**

Facilities	Equipment	Quantity			Capacity (m <sup>3</sup> /min/unit)	Power (kw/unit)	National(N) Imported(I)
		Total	PDBG	F/S			
Sludge treatment bldg.	Thickening centrifuges	3	2	1	47.1	45	I
	Dewatering centrifuges	2	2	-	32.4	45	I
	Lime system	3	2	1	-	11.2	N
	Sludge and lime mixer	2	2	-	-	22	I
	Polimer system	2	1	1	-	-	N
Thermal dryer bldg.	Thermal dryer	2	1	1	-	215	I




Figure 4 Mass Balance of Sarapui WWTP

## 2.4 BANGU WWTP

### 2.4.1 LOCATION OF BANGU WWTP

Bangu WWTP is located at;

Rua Três Marius, Bangu (Vila Catiri), Rio de Janeiro, RJ

The treated effluent is discharged to;

Rio das Tintas

### 2.4.2 PRELIMINARY AND PRIMARY TREATMENT UNITS

#### (1) General

Major preliminary and primary treatment units are shown below.

Raw Sewerage Pumping Station;

Grit chambers;

Primary Clarifier;

#### (2) Raw Sewage Pumping Station

The sewage flowing into the WWTP is conveyed up to the coarse bar screen chute where the material with dimension larger than 8 cm is removed.

The coarse bar screen chute has 2 (two) parallel segments and insulated by upstream floodgates and downstream the screens, in order to allow its maintenance.

The pumping station has 4 motor-pump sets, one of them is spare. Each set discharges 600 l/s it being 3 (three) groups with variable speed. The estimated head is 11.5 mca.

The sewage is conveyed through a channel to the fine screen (1 cm) system, where the channel is subdivided into 3 (three) smaller channels directing the sewage to each screen. Each rack is insulated by a system of sliding floodgates, upstream and downstream. The racked material shall be cast on conveying mats and then taken to a compacter.

#### (3) Grit Chambers

The grit is removed by 2 (two) mechanized and square chambers with 10m side, which shall remove particles with diameter less than 0.2 mm. The material removed will be washed taken to the sanitary landfill.

Measuring of the flow to the WWTP is done through Parshall downstream the Grit Chamber.

#### (4) Primary Clarifiers

The settling system consists of 4 (four) circular primary clarifiers with 25 m diameter and 3.5m water depth. The flow distribution to the clarifiers shall be made from the distribution chamber.

Feeding of clarifiers is made from the center of the unit and the scrapers driving system is central type.

The sludge settled in the clarifiers is conveyed to the unit center from where it is withdrawn through helical pumps.

## (5) Equipment

The list of preliminary and primary treatment units is shown below.:

**Table 30 List of Primary Treatment Equipment**

Place	Equipment	Capacity (m <sup>3</sup> /min/unit)	Quantity	Power (KW/unit)	National (N) Imported (I)
Raw Sewerage Pumping Station	Coarse bar screen	54	2	2.0	N
	Slide gates	54	8	-	N
	Vertical Centrifuge Pump	36	4	100	N
	Fine bar screen	36	3	2.0	N
Grit Chamber	Bottom scraper	54	2	-	N
Grit Chamber	Screw for sand removal	-	2	-	N
Primary Clarifier	Sludge and Scum Scrapers	27	4	1	I
Primary Sludge Pumping Station	Progressive Cavity Pumps	-	5	-	N
Thickeners	Bottom Scrapers	0.68	4	0.37	N

## 2.4.3 SECONDARY TREATMENT UNITS

### (1) General

The biological treatment is done through the activated sludge process. The primary effluent is conveyed to the aeration units and then to secondary clarifiers.

The secondary treatment consists of the following main units:

Aeration Tanks

Blowers

Secondary Clarifier

Sludge Return Pumping Station

### (2) Aeration Tanks

Primary effluent is conveyed directly to the aeration tanks. At the inlet of each four tanks there is a chamber which has the function to equally divide the outflow to each group of four aeration tanks.

The liquid effluent to the chamber goes through a spiller, unloading individually into the aeration tank.

Inlet of the return sludge and the primary effluent into the aeration tank is controlled by two electrically driven floodgates.

The effluent of each group of four aeration tanks shall flow through a pipeline to two secondary clarifiers.

The process parameters are as hereunder:

Sludge age (days)	8
Retention time (hours)	6.4
Substratum / micro-organisms ratio F/M	0.35
Mixed liquor concentration (mg/l)	2,474 for average daily
Production of excess sludge (kg/d TSS)	10,720 for average daily
Excess sludge concentration (mg/l)	6,600 - 8,000
Demand of Oxygen (kg/h)	1,507

Main features of the aeration tanks are as hereunder:

Number of tanks	8
Width (m)	12
Length	48
Water depth (m)	5.0
Total depth (m)	6.0
Volume (m <sup>3</sup> per tank)	2,880

Air to the diffusers shall be supplied by a blowers system and distribution pipes (stainless steel for pipes that are not in contact with the sewage and glass fiber for internal pipeline to the aeration tanks). The air diffusion system has the following features:

Type of diffuser	Flexible membrane
Material	EPDM
Type of bubble	fine
Depth of the diffuser (m)	4.8
Oxygen standard requirement (kg/h per tank)	188 for average daily
Air outflow (Nm <sup>3</sup> /h per tank)	4,550 for average daily

### (3) Blowers Platform

The blowers shall be installed adjacent to the aeration tanks, in concrete platforms, protected from bad weather. These blowers have the following features:

Type of blower	Centrifuge
Number of blowers	4 + 1 (one for standby)
Air (Nm <sup>3</sup> /h/unit)	9,100
Power (KW/unit)	175

#### **(4) Secondary Clarifiers**

The mixed liquor will be conveyed to the secondary clarifiers, where the biological solids will be separated.

4 secondary clarifiers shall be implemented with 33m diameter, with circular concrete structures with central feed.

Sludge will be accumulated through a mechanical scraper system which will convey the sludge up to the clarifier center. The secondary sludge shall be withdrawn through centrifuge pumps located on the sludge pumping station.

This same equipment makes the superficial scum removal, which shall be conveyed to a well.

The plant effluent will be discharged into a reinforced concrete culvert to be conveyed to the receiving body (Sapopemba river).

The main features of the secondary clarifiers and the main design parameters are shown below:

Type of clarifier	Circular
Number of clarifiers	4
Sludge and scum withdrawal driving gear	central
Feeding	central
Sludge withdrawal	scraper
Diameter (m)	33
Water depth in the wall (m)	4.0
Bottom declivity (v:h)	1:12
Overflow rate ( $m^3/m^2/d$ )	25.3 for average daily
Solids loading ( $kg/m^2/d$ )	125 for average daily
Production of excess sludge ( $kg/d TSS$ )	10,720 for average daily

#### **(5) Sludge Pumping Station**

Sludges from four secondary clarifiers are withdrawn by pumps installed in sludge pumping station.

The sludge are withdrawn and raised to an outfall box; from this box it will continue through gravity up to the aeration tanks through two ductile cast iron pipelines.

Its structure shall be of two floors, one being at the ground level and the other below where the centrifuge pumps and of progressive cavity will be sheltered. Besides these pumps, it is foreseen a well pump to drain the pumps well.

Each reflux pump will exclusively consider one clarifier; it is also foreseen 1 (one) spare pump which will remain at the storehouse.

The excess sludge is withdrawn from the outfall box, located at the outflow of the reflux pumps of the sludge return pumping station, through 2 progressive cavity pumps. This box shall have a

"stop-log" separating the casting of each two reflux pumps. The third pump shall be normally used to pump the floating matter removed from the clarifiers, also being a spare unit.

Each reflux pump for withdrawal of excess sludge is equipped with a speed varying to adjust the upsetting outflow. Magnetic outflow meters are foreseen at the system outflow and sludges reflux and discard.

The main features of the sludge recirculation and discard system are shown below.

### **1) Return Sludge Pumps**

Type of pump	Centrifuge
Speed	Variable
Number of pumps	4 + 1 (one for standby)
Capacity (m <sup>3</sup> /min/unit)	7.2 to 10.8
Power (KW/unit)	16.0

### **2) Excess Sludge Pumps**

Type of pump	Progressive Cavity
Speed	Variable
Number of pumps	2 + 1 (one for standby)
Capacity (m <sup>3</sup> /min/unit)	0.6 - 1.5
AMT (bar)	4
Power (KW/unit)	18.0

### **3) Auxiliary Equipment**

The sludge return pumping stations have the following facilities:

Overhead crane and Tackle;

Service water system to seal the pumps;

Draining system, with submerged motor pump for 6 l/s and 6 mca head.

## **(6) Equipment**

The following list shows main equipment of the secondary treatment units:

**Table 31 List of Secondary Treatment Equipment**

Place	Equipment	Capacity (m <sup>3</sup> /min/unit)	Quantity	Power (KW/unit)	National(N) Imported(I)
Aeration Tank	Diffusers system	-	8	-	I
Aeration Tank	Blowers	152	5 (4+1)	175	N
Secondary Clarifier	Sludge and Scum scrapers	-	4	1	I
Sludge Pumping Station	Centrifuge pumps	10.8	5 (4+1)	16	N
Sludge Pumping Station	Progressive Cavity Pumps (excess)	1.5	3 (2+1)	18	N

## 2.4.4 SLUDGE TREATMENT

### (1) Sludge Thickening and Dewatering

The treatment is done in the Sludge Treatment Building, inside which are located the equipment necessary for performance of the centrifuge thickening, mechanical dewatering and drying stages.

### (2) Gravity Thickeners

The primary sludge withdrawn from the primary clarifiers has 1.0 to 1.5% concentration of solids. It will be thickened to 4-5% by gravity thickeners. There are 4 (four) thickeners with 8.0 m diameter and 3.5 m water depth next to the wall.

Inlet of the primary sludge will be through the center of the thickener and drive of bottom scrapers is central type. The sludge settled in the bottom are withdrawn through gravity and conveyed up to the sludge raising well from where it is alternately pumped to each digester.

### (3) Thickening of Excess Sludge

The excess sludge and the floating material removed from the secondary clarifiers will be pumped to the sludge treatment building where they will be chemically conditioned with polymer for its thickening in the centrifuges.

The thickened excess sludge will be conveyed up to the thickened sludge pumping station to be mixed with the gravity thickened primary sludge.

The liquid withdrawn from the thickening process through draining (centered) returns to sewage treatment process.

The main features of the centrifugal thickening system are shown below.

#### 1) Thickening Centrifuges

Number of units	2 + 1 (one for standby)
Operation	7 days/week, 20h/d
Solids loading (kg/h/unit)	223 for average daily
Hydraulic loading ( $m^3/h/unit^1$ )	41 for average daily
Thickened sludge concentration (%)	5.0

(Assuming a minimum concentration of 6600 mg/l of TSS in the excess sludge)

#### 2) Pumps of Thickened Excess Sludge

The centrifuges thickened sludge is conveyed to the collection well and then, pumped up to the thickened sludge pumping station.

Type	Progressive Cavity
Speed	variable
Number of pumps	1 + 1 (one for standby)
Capacity ( $m^3/min/unit$ )	0.72 - 1.44
AMT (bar)	2.0
Power (KW/unit)	10.0

### 3) Dosing and Dilution Unit

Polymer is applied as conditioner for the excess sludge thickening processes.

Number of Units	2
Polymer concentration in application (%)	0.05 - 0.5
Polymer consumption (kg of polymer/ton sludge)	2
Water outflow for dilution (l/min/unit)	3 - 20

### 4) Mixer

Type	Submersible
Number of mixers	1
Motor power (kW per mixer)	1.9

## (4) Anaerobic Digestion

3 primary digesters and 1 secondary digester with dimensions 16.5m diameter and 17.5m height are installed to digest both thickened primary and excess sludges.

Recirculation of the liquid inside the digesters are done with centrifuge pumps, that will operate 24 hours per day, pumping the sludge alternately from the upper to the lower part and vice-versa every 2 hours.

### 1) Sludge Reflux Pumps in the Digester

Type of pump	Vertical centrifuge
Number of pumps	6
Capacity (m <sup>3</sup> /min/unit)	28.5
Power (KW/unit)	31

### 2) Digested Sludge Pumps

The digested sludge is conveyed through pumps up to the dewatering process.

Type	Progressive cavity
Speed	variable
Number of pumps	1 + 1 (one for standby)
Capacity (m <sup>3</sup> /min/unit)	0.12 - 0.6
AMT (bar)	2.0
Power (KW/unit)	4.5

## (5) Mechanical Sludge Dewatering

The digested sludge shall be mechanically dewatered by centrifuges. A total of two centrifuges (one operational and one standby) will dewater the sludge to solids concentration of 25%.

The sludge is chemically conditioned through addition of polymer before being supplied to the centrifuges. The sludge cake resulting from dewatering will be unloaded in a conveying screws system which will convey them up to the thermal drying system.

The conveying screws system will replace the existing mats and will consist of a set of horizontal and tilted screws. The liquid waste from the dewatering process will return to the plant inlet.

The main features of the sludge mechanical dewatering system are shown below:

### 1) Dewatering Centrifuges

Number of units	1 + 1 (one for standby)
Operation (7days/week)	20 h/d
Solids loading (kg/h/unit)	663 for average daily
Hydraulic load (m <sup>3</sup> /h/unit)	189 for average daily
Dewatered sludge concentration (%)	25.0

### 2) Dosing and Diluting Unit

Polymer is applied as conditioner for the sludge dewatering processes.

Number of Units	1
Concentration of polymer in the application (%)	0.05 - 0.5
Polymer consumption (kg of polymer/ton sludge)	10
Water outflow for dilution (l/min/unit)	50 - 220

### 3) DEWATERED Sludge Conveying System

Dewatered sludge is conveyed through conveying screws to the thermal drying system. The conveying screws comply with the sludge volume produced by the dewatering centrifuges.

## (6) Equipment

The list of main equipment of the sludge treatment area is shown below:

**Table 32 List of Sludge Treatment Equipment**

Place	Equipment	Capacity (m <sup>3</sup> /min/unit)	Quantity	Power (kw/unit)	National (N) Imported (I)
Sludge Treatment	Thickening Centrifuges	41 (*)	3 (2+1)	45	I
Sludge Treatment	Dewatering Centrifuges	18.9 (*)	2 (1+1)	45	I
Sludge Treatment	Dosing and Diluting Units	-	3		I
Sludge Treatment	Thermal dryer	-	1	105	I
Pumping of thickened excess sludge	Progressive cavity pumps	1.44	2 (1+1)	10	N
Pumping of digested sludge	Progressive cavity pumps	0.6	2 (1+1)	4.5	N
Digester	Vertical centrifuge pumps	31.2	6	34	N

Note: (\*) Capacity in m<sup>3</sup>/h/unit

### 2.4.5 DESIGN CALCULATION

Design calculation of Bangu WWTP is shown bellow.

## ETE BANGU (WWTP BANGU)

### 1) Eficiências p/ Tratamento (Efficiency)

1)	BOD <sub>5</sub> removed.....	=	30%	(primary treatment)
2)	TSS removed.....	=	50%	(primary treatment)
3)	BOD <sub>5</sub> .....	=	91%	(secondary treatment)
4)	TSS.....	=	92%	(secondary treatment)
5)	VSS/TSS.....	=	0.75	
6)	BOD influent.....	=	230	mg/l
7)	BOD effluent.....	=	20	mg/l
8)	TSS influent.....	=	250	mg/l
9)	TSS effluent.....	=	20	mg/l

### 2) Caixa de Areia (Grit Chamber)

1)	Qmáx.....	=	1.8	m <sup>3</sup> /s
2)	Number units.....	=	2	
3)	Qunit.....	=	0.90	m <sup>3</sup> /s
4)	Surface-loading rate .....	=	1000	m <sup>3</sup> /m <sup>2</sup> .d (ranger 600-1300)
5)	Width.....	=	9	m
6)	Water depth.....	=	0.65	m
7)	Velocity .....	=	0.15	m/s

### 3) Decantador Primário (Primary Clarifier)

1)	Qavg.....	=	1	m <sup>3</sup> /s
2)	Qmax.....	=	1.8	m <sup>3</sup> /s
3)	Number units.....	=	4	
4)	Qunit.....	=	0.45	m <sup>3</sup> /s
5)	Diameter.....	=	24	m
6)	Water deptht.....	=	3.5	m (> 2,0 m)
7)	Unit Area .....	=	452.4	m <sup>2</sup>
8)	Surface-loading rate .....	=	85.9 - 47.7	m <sup>3</sup> /m <sup>2</sup> .d max-avg (ranger 0 - 120)
9)	Hydraulics detention time (max).....	=	2.2	h
10)	Hydraulics detention time (min).....	=	1.0	h
11)	Weir-loading rate.....	=	286.5	m <sup>3</sup> /m.d (ranger 0 - 720)
12)	Solids concentration (outflow).....	=	1.2%	(ranger 1 - 2)
13)	TSS.....	=	11,717.0	kg SS/d
14)	Total sludge flow.....	=	40.7	m <sup>3</sup> /h
15)	Slope.....	=	1/12	m/m

### 4) Tanque de Aeração (Aeration Tank)

1)	BOD influent (So).....	=	161.00	mg/l
2)	Soluble BODeffluent (S).....	=	10.56	mg/l
3)	Qavg.....	=	1.00	m <sup>3</sup> /s
4)	Maximum yield coef. (Y).....	=	0.55	kgMLVSSV/kgBOD
5)	Endogenous decay coef. (Kd).....	=	0.08	1/dia
6)	Rate Biodegradable VSS (F'b ) .....	=	0.80	
7)	Sludge age (θ).....	=	8.00	dias
8)	Rate recycle.....	=	0.60	
9)	Number units.....	=	8.00	
10)	Rate Biodegrad. VSS after sludge age (Fb)....	=	0.71	Fb = F'b / (1 + (1 - F'b) x Kd x θ)
11)	MLSS (X).....	=	<b>2,474</b>	mg/l
12)	MLVSS (Xv).....	=	<b>1,707</b>	mg/l
13)	Water depth.....	=	5.00	m
14)	Length.....	=	48.00	m
15)	Width.....	=	12.00	m
16)	Unit Volume (V).....	=	<b>2880</b>	m <sup>3</sup>
17)	Total Volume .....	=	<b>23040</b>	m <sup>3</sup> V = Yx θ x Qavg x (So - S)/(Xv x (1 + Kd x Fb x θ))
18)	Hydraulics detention time .....	=	6.40	h
19)	Concentration in return (Xr).....	=	6,597	mg/l
20)	Rate Food/Microorg (F/M).....	=	0.35	kgBOD5/kgMLVSS.dia (ranger 0,07 - 1)
21)	Rate Food/Microorg (F/M).....	=	0.24	kgBOD5/kgMLSS.dia
22)	Net specific growth rate (U).....	=	0.33	kgBOD5/kgMLVSS.dia (ranger 0,06 - 1)
23)	Flowrate Wasted (Qex).....	=	1,625	m <sup>3</sup> /d
24)	Solids removed (Px).....	=	10,720	kg/d

## 5) Decantador Secundário (Secondary Clarifier)

1) Qavg.....	=	1.00	m <sup>3</sup> /s	{	MLSS<3000mg/l - R>=0.25 e TH<=36
2) Rate recycle (R).....	=	0.60			MLSS>=3000mg/l e
3) Recycle flowrate.....	=	0.60	m <sup>3</sup> /s		<4500mg/l - R>=0.50 e TH<=24
4) Diameter.....	=	33	m		MLSS>=4500mg/l - R>=1 e TH<=16
5) Water depth.....	=	4	m		
6) Slope.....	=	1/200	m/m		
7) Number units.....	=	4			
8) Unit Volume .....	=	3,421	m <sup>3</sup>		
9) Unit Area .....	=	855	m <sup>2</sup>		
10) Hydraulics detention time .....	=	3.8	h >		1.5 h
11) Surface-loading rate (TH).....	=	25.3	m <sup>3</sup> /m <sup>2</sup> /d		
12) Solids loading rate.....	=	125	kg/m <sup>2</sup> /d <		144 kg/m <sup>2</sup> /d




Figure 5 Solids - Concentration Curve

## 6) Adensador por Gravidade (Gravity Thickening)

1) Concentration in effluent.....	=	4.0%	(ranger 0 - 10)
2) TSS.....	=	11,717.0	kg SS/d
3) Number units.....	=	4	
4) TSS for unit.....	=	2,929.3	kg SS/d
5) Diameter.....	=	8	m
6) Unit Area .....	=	50.3	m <sup>2</sup>
7) Solids loading rate.....	=	58.3	kg SS/m <sup>2</sup> .d (ranger 0 - 150)
8) Concentration in influent.....	=	12,000	mg/l = 12 kg/m <sup>3</sup>
9) TSS effluent.....	=	10,545	kg SS/d
10) Sludge flow effluent.....	=	11.0	m <sup>3</sup> /h
11) TSS in supernatant.....	=	1,172	kg SS/d
12) Supernatant flow.....	=	29.7	m <sup>3</sup> /h
13) Water depth.....	=	3.00	m (>=3,0m)
14) Unit Volume .....	=	156.4	m <sup>3</sup>
15) Hydraulics detention time .....	=	12.30	h (<= 24 h)
16) Surface-loading rate .....	=	4.9	m <sup>3</sup> /m <sup>2</sup> .d
17) Solids recovery.....	=	90.0%	
18) Declividade do fundo.....	=	1/12	m/m

## 7) Centrífugas de Adensamento (Centrifuge Thickening)

1) TSS influent.....	=	10,720.5	kg SS/d
2) Concentration influent in centrifuge.....	=	0.66%	
3) Concentration effluent in centrifuge.....	=	5.0%	
4) Flowrate to Centrifuge .....	=	18.8	l/s
5) Solids recovery.....	=	95.0%	
6) TSS effluent.....	=	10,184.4	kg SS/d
7) Blended sludge.....	=	2.4	l/s
8) Thinckener effluent.....	=	16.5	l/s
9) Number operation centrifuge .....	=	2.0	
10) Operation time.....	=	20	h/d
11) Hydraulics flow .....	=	40.6	m <sup>3</sup> /h/unit

**Polymers application**

12)	Dosage.....	=	2	kg Pol / t SS
13)	Polymers Concentration.....	=	30.0%	
14)	Concentration application polymers.....	=	0.20% - 0.05%	
15)	Total polymers.....	=	21.4	kg/d de pol

**8) Digestores (Digesters)****8.1) Primary Digester**

1)	Type.....	=	High rate	
2)	TSS influent.....	=	20,729.7	kg SS/d
3)	VSS/TSS.....	=	0.721	
4)	Concentration Solids.....	=	3.5%	
5)	High rate digestion.....	=	1.2 - 6.0	kg VSS/m3
6)	Sludge Volume influent (Vf).....	=	456.4	m3/d
7)	Sludge Volume effluent (Vd).....	=	371.5	m3/d
8)	Digestion time(t).....	=	25	dias
9)	Sludge Volume in digesters (V).....	=	9,994.1	m3
10)	Number digester.....	=	3	
11)	Diameter.....	=	16.5	m
12)	Heigth.....	=	16.0	m
13)	Volume Unit.....	=	3,421.2	m3

**8.2) Digestor Secundário**

1)	Number.....	=	1	
2)	Diameter.....	=	16.5	m
3)	Heigth.....	=	16.0	m
4)	Volume Unit.....	=	3,421.2	m3

**9) Centrífugas de Desidratação (Centrifuge Dewatering)**

1)	TSS influent.....	=	13,260.8	kg SS/d
2)	Concentration influent in centrifuge.....	=	3.5%	
3)	Concentration effluent in centrifuge.....	=	25.0%	
4)	Flowrate to Centrifuge .....	=	4.4	l/s
5)	Solids recovery.....	=	95.0%	
6)	TSS effluent.....	=	12,597.8	kg SS/d
7)	Sludge Flow dewatering .....	=	0.6	l/s
8)	Filtrate .....	=	3.8	l/s
9)	Number operation centrifuge .....	=	1.0	
10)	Operation time.....	=	20	h/d
11)	Hydraulics flow .....	=	18.9	m3/h/unit

**Polymers application**

12)	Dosage.....	=	10	kg Pol / t SS
13)	Polymers Concentration.....	=	30.0%	
14)	Concentration application polymers.....	=	0.20% - 0.05%	
15)	Total polymers.....	=	132.6	kg/d de pol

**10) Consumo de Oxigênio (Oxygen-Transfer)****10.1) Oxygen Requirements from removal of Carbonaceous organic matter (DOC)**

1)	DOC.....	=	11,995.1 kg O2/d	DOC = Qavg x (So-S) x (1,46 - (1,42 x Y)/(1+ Kd x Fb x θ))
----	----------	---	------------------	--

**10.2) Oxygen Requirement from Nitrification (DON)**

1)	Population.....	=	360,000 hab	
2)	Nitrogen.....	=	8 g NTK/dia/p	
3)	Total Nitrogen.....	=	2,880.0 kg/dia	
4)	Concentration (CN).....	=	33.3 mg/l	
5)	Efficiency from Primary treatment (effn).....	=	20.0%	
6)	DON.....	=	10,529.3 kg O2/d	DON = (4,57 x Qavg x CN /1000) x (1-effn)

**10.3) SOTE (standardized oxygen-transfer)**

1)	SOTE = DOC + DON.....	=	22,524.4 kg O2/d	
----	-----------------------	---	------------------	--

**10.4) Oxygen Transferred under field conditions (OTR)**

1)	$\alpha$ (oxygen-transfer correction factor for water). =	0.85
2)	$\beta$ (saturação de O <sub>2</sub> no esgoto/na água). =	0.95
3)	CL( operation oxygen concentration ). =	2.0 mg/l
4)	CS summer(O <sub>2</sub> saturation in water). =	8.4 g/m <sup>3</sup>
5)	CS 20 °(O <sub>2</sub> saturation in water). =	9.2 g/m <sup>3</sup>
6)	$\delta$ (coeff. temperature) =	1.024
7)	Summer temperature..... =	25 °C
8)	OTR (summer). =	36,209.4 kg O <sub>2</sub> /d      OTR = SOTE / ((( $\beta$ x CS - CL) / CS(20° C)) x $\alpha$ x $\delta^{(T-20)}$ )

**10.5) Air Requirement**

1)	Efficiency..... =	15.0%
2)	Specific weight of air..... =	1.2 kg/m <sup>3</sup>
3)	O <sub>2</sub> in air..... =	0.23 g O <sub>2</sub> / g ar
4)	Air..... =	607.4 m <sup>3</sup> /min de ar

**10.6) Power**

1)	Specific weight of water..... =	1000 kg/m <sup>3</sup>
2)	Difuser depth..... =	4.8 m
3)	Headloss..... =	0.87 m
4)	Efficiency..... =	80.0%
5)	Power..... =	175 kW/unit
6)	Number of blower..... =	4 + 1




Figure 6 Mass Balance of Bangu WWTP