

3.7 Identified Problems and Solutions

3.7.1 Frequency

As described in the previous chapter, the Andhra Pradesh system operated in severe low frequency conditions in May 2002, but this cannot be solved only using APTRANSCO because the Southern India Grid including the system operates at the same frequency. Low frequency problems in the Southern India Grid were considered problems by the Central Electricity Regulatory Commission in March 2002. Since the ABT was enforced in January 2003, the frequency has been maintained by 49.0 Hz or more.

Sustained low frequency operation or wide frequency variation causes damage to the electrical equipment of power plants as well as that of consumers. In power plants, this kind of operation may damage not only auxiliary equipment such as motors and pumps, but also turbines and generators. Low frequency also decreases the security level of power system operation.

The quality of products of a number of process industries such as rolling mills is heavily dependent on the quality of supply. Poor quality power supply not only results in reduced life of equipment, but also in poor quality products. In case of irrigation pumps, the total operating hours of the pumps increases for pumping the same amount of water if the frequency of operation is low.

To advance the industry with advanced technology in the area, it is necessary to supply electricity with a stabilized frequency. For this, APTRANSCO/APCPDCL are required to establish an organization to supply a stable electricity supply by strengthening power generating facilities and promoting Demand Side Management (DSM) with the cooperation of customers.

3.7.2 Voltage

The voltage of the distribution system is decided by the voltage of the upper stream transmission system. The voltages of domestic and industry feeders remain within the specified level and no problem is observed at this moment. For agriculture feeder, it is considered that distance is comparatively long and load is fluctuated so a large voltage variation is occurred. APCPDCL is recommended to make efforts continuously to maintain the voltages and reduce the distribution losses with suitable distribution of the loads and the reactive power sources. (Also please refer to Chapter 5)

3.7.3 Number of Outages

Analysis results show that some feeders stopped 100 times or more in 2002/03 and proper countermeasures have to be taken.

Table 3.8 shows the major causes of outages and considerable countermeasures for reducing the number of outages which were obtained through the analysis of outage records and discussions with APCPDCL.

Table 3.8 Major causes of outages and considerable countermeasures

Causes	Description	Temporary measures	Permanent measures
Tree contact to the conductors		Reexamination of range and opportunity of trees cutting.	Adoption of insulated conductors for the span where there is a probability of tree contact to the conductor.
Bird contact to the charging parts			Adoption of insulated conductors
Loose conductors	Short circuit at the mid-span due to excess of sag.	(1) Adjustment of sag of a conductor. (2) Adoption of spacer.	(1) Insert the pole at the mid-span for reducing sag. (2) Increase the phase clearance. (3) Adoption of insulated conductors.
Bad connection of joint parts	Poor contact of twist type jointing.		Adoption of compression type clamp.
Inferiority of insulators		Exchange with excellent one	
Contamination of insulators	Due to salt or dust of factories.	Cleaning of insulators.	Adoption of longer leakage path insulators.

An insulated conductor is considered an effective means for reducing the number of outages. They should be used in locations where contact between trees and conductors is unavoidable by cutting trees or contact of conductors at the mid span is not solved by adjustment of their sagging.

Troubles of joints of conductors/jumpers frequently occur, but they can be solved by the adoption of compression type clamps instead of the twist type joint used at the moment. The average number and duration of a customer per year in Japan where insulated conductor and compressed type clamp are used are 0.2 times and 25 minutes, respectively.

As pointed out in 3.6.3(4), Details of Unknown Causes and Equipment, approximately 51 % of outages are classified as OTH/OTH that is equipment and cause of outages is not identified. However, the number of outages cannot be reduced if their cause is not known. Therefore, APCPDCL should take actions such as making an accurate record of the outage and perform a patrol of distribution facilities as much as possible to identify the condition of equipment and cause of fault and make a preventive plan for recurrence of the same troubles. If the number of outages is reduced the duration of outages will also decrease as a result, the burden on the maintenance crew will also decrease, and therefore, it can be utilized for preventive maintenance and can result in improvement in the quality of maintenance.

3.7.4 Duration of Outages

Approximately 98 % of outages are restored within 120 minutes in the RBAN case (See 3.6.3(3)) and the cases in which duration of outages was prolonged are not particularly significant large. However, APCPDCL has to try hard in the future to reduce the duration of outages.

3.7.5 Overload

The monitoring of the overload of the transformers is carried out by the section office continuously and the same procedures are necessary to maintain carefully. (Refer to 5.7 Recommendations of Chapter 5)

3.7.6 Correspondence to DISTRIBUTION CODE

Since the DISTRIBUTION CODE will be enforced in 2004, APCPDCL must establish a system corresponding to it as soon as possible. Figure 3.25 shows the flow of required quality control work for it.




Figure3.25 Quality control flow for DISTRIBUTION CODE

When output from the distribution system (frequency, voltage, number and duration of interruptions) is compared with the target (regulations of DISTRIBUTION CODE) and the former does not satisfy the latter, it is necessary to take action in pursuit of the cause.

For this reason, understanding the output of the distribution system and the setup of target are indispensable. Although the target of outages may not be specified in the DISTRIBUTION CODE for the time being such as the GRID CODE, APCPDCL should to setup an in-house target and try to supply better quality electricity to the consumers than at present.

The concrete step is;

- (a) Data collection and its analysis for understanding the output from the distribution system
- (b) Setup the target value, if any
- (c) Planning and execution of the countermeasures, if system output does not satisfy the specified level. (Target)

It is necessary to carry out systematic analysis of outage records especially.

(1) Category

Analysis of the outage records shows that the applied categories differ depending on the persons in charge. For example, the same outage is classified into the three categories, such as scheduled maintenance, emergency maintenance and others so it should be follow the common philosophy of the

office.

(2) Coding System for Remarks

Some times, the descriptions of remarks include very useful information for data analysis. Therefore, feeder name, equipment, cause of outage, pole no., etc which are included in description of remarks will be converted to a suitable codes and used as data of analysis.

(3) Format of Duration of Outages

APCPDCL uses the following format of “the hour” (xx h, xx m, xx s), for duration of outages, but this system is not suitable for more than 24 hours. The study team suggests applying “minutes” for analysis. GRID CODE also uses “minutes.”

(4) Review of CODE LIST

CODE LIST attached in Annex 3.2 should be reviewed/ revised as per the present situation.

(5) Application to other districts

Regarding the data analysis, the similar system is to be applied to other districts.

(6) Data Centers

For utilization of this system effectively, setup data centers in the corporate office and districts and these are linked with a communications channel, for example by Internet. It is necessary to train required personnel in parallel to the above.

In addition, out-sourcing should be considered if it takes some time for preparation of the required system and training of the personnel.

3.7.7 Others

(1) Operation and Maintenance Manual

An operation and maintenance manual in conformity with the DISTRIBUTION CODE that will be applied from 2004 should be arranged as soon as possible. The same will be distributed to all the offices concerning operation including substations and should be made so that the personnel in charge of the substation share common knowledge and a sense of thoroughness.

(2) Rearrangement of low voltage wiring

The present arrangement of a low voltage wiring, especially the branch part to customers, is very disorderly and management must be difficult. Rearrangement of the same wiring is suggested.

(3) Safety Measures to the Public

It is observed that a passer-by may often unconsciously touch the bare energized terminals/wires of a low -voltage distribution/switch box which its cover is kept opened and, in the rural area, some transformers are installed near the ground surface and charged parts are exposed without protective covers so that the general public may touch them easily.

Especially, in case the equipment is installed in or near a public road, it is recommended to take suitable measures urgently to prevent people approaching to the energized parts of the said equipment such as to install a fence surrounding the transformer or close the cover of the same box.

3.8 Recommendations

The study team found some problems through the study on the quality of electricity, frequency, voltage, number and duration of outages, in Range Reddy and Medak and presents suggestions to solve them.

Regarding the frequency, it is out of control for APCPDCL and no serious problems are observed for the voltage.

(1) Correspondence to the DISTRIBUTION CODE

Since the DISTRIBUTION CODE deliberated now by APERC is due to be enforced in 2004, it is necessary that to construct a system to collect and analyze the data efficiently and train the necessary personnel as soon as possible.

(2) Reduction of the Number of Outages

Analysis results show that some feeders stopped 100 times or more in 2002/03 and proper countermeasures have to be taken to reduce this number. It is recommended to use insulated conductors in locations where contact between trees and conductors cannot be preventing by cutting along or contact of conductors at the mid span that is not solved by adjustment of sagging.

Troubles of joints of conductors/jumpers occur frequently and they will be solved by an adoption of a compression type clamp instead of the twist type joint used at the moment.

In the RBAN system, approximately 51 % of outages are classified as OTH/OTH which is equipment and the cause of outages is not identified. However, the number of outages cannot be reduced if their cause remains unknown. Therefore, APCPDCL should take actions such as making an accurate record of outages and perform a patrol of distribution facilities as much as possible to identify the equipment and cause of faults and make a preventive plan for recurrence of the same problems.

(3) Operation and Maintenance Manual

An operation and maintenance manual that in conformity with the DISTRIBUTION CODE that will be applied from 2004 should be arranged as soon as possible. The same will be distributed to all offices concerning operation including substations and should be made even so that the personnel in charge of the substation attain common knowledge and a sense of thoroughness.

(4) Rearrangement of Low Voltage Wiring

The present arrangement of a low voltage wiring, especially the branch part to the customers, is very disorderly and management must be difficult. Rearrangement of the same wiring is suggested.

(5) Safety Measures for the Public

It is often observed that the low-voltage energized parts are exposed without protective covers so that the general public may touch them easily, therefore, it is recommended to take suitable measures urgently to prevent people from being injured.

Note:

One CD-R is separately attached for reference;

JICA O & M Data (Data used for preparation of the report)

Text (How to analyze the data)

Annextures

- Annex 3.1 Form of Data Collection of Outage Records
- Annex 3.2 Code List of Substations and Feeders
- Annex 3.3 Frequency Records in May and November 2002 and 2003
- Annex 3.4 Records of Voltage Measurement at the End-customers of
Model Feeders
- Annex 3.5 Summary of Outage Records Collected

Annex 3.1 Form of Data Collection of Outage Records


How to fill in Outage Form

Important note to fill in the form;

- (1) For sorting, each outage should be filled in one(1) row.
- (2) Same column should be filled in a same format. (Mixed use of digits and characters is not allowed)
- (3) At least, same code system should be applied in a circle.

Note on each column

- Column No (1) Code name of 132/33 kV substation. District name R or M + Code name .Common for all the circles.
 (2) Serial no. Each outage is given specified number and no change will be allowed after fixed the number..
 (3),(4) Blank
 (5) Voltage class of substation (Digit)
 (6) Code name of substation .
 (7) Voltage class equipment/feeder troubled. (Digit)
 (8) Code name of equipment/feeder troubled. (Refer to note)
 (9) Category of feeder
 (10) Year 20022, 20033 (Digit)
 (11) Month (Digit)
 (12) Day (Digit)
 (13) Time of an outage started. Time of 24 hour system (Digit): Minute (Digit)
 (14) No. of trips in a event (Digit). One(1) is preferable.
 (15) Duration of an outage (Digit)
 (16) Unsupplied energy during the outage, if available. (Digit)
 (17),(18),(19) Protective device operated in code name. (Refer to note)
 (20) Recloser has operated. (Y or N)
 (21) Distance from substation (Digit)
 (22) Cause of outage (Refer to note)
 (23) Equipment damaged or maintained. (Refer to note)
 (24) Supplementary information, if any
 (25) Memorandum, if any



NOTE on Columns:

Code name of equipment (8)

For easy sorting of kind of equipment, first character indicates major Equipment, for example, F: feeder, TR: Transformer, CB: Circuit breaker, etc. () shows information to identify the equipment, code name of feeder, if any

Relay (17)(18)(19)

- DIR : Power direction relay
- OC : Over-current relay
- OCG : Over-current ground relay
- DF : Differential relay
- UV : Under-voltage relay
- F : Power fuse
- UK : Un-known

Cause of interruption (22)

- BW : Bad weather, heavy rain/ strong wind
- LTG : Lightning
- CNT : Contamination of insulator
- INS : Deterioration of insulator
- ERE : Improper erection/maintenance
- OBS : Contact of obstacles
- PUB : Mistake of 3rd party
- WOK : Mistake of worker
- ZSM : Scheduled maintenance
- ZEM : Emergency (extraordinary) inspection
- OTH : Others

Equipment (23)

- SYS : 132 kV and above system
- POL : Supporting structure
- INS : Insulator
- COND : Conductor
- JNT : Joint of conductors
- BUS : Substation bus
- TR : Transformers
- CB : Circuit breaker
- SWG : Switchgear (L,A,PT,CT,DS, etc.
- RLY : Protective relay
- AUX : Auxiliary circuit
- DC : Battery, charger, DC circuit
- OTH : Others

L/R(LR) : Load relief

L/C : Line clear = ZEM

Annex 3.2 Code List of Substations and Feeders

Annex 3.2 Code List of Substations and Feeders

Ranga Reddy (1/18)

220/132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder			0.4 kV Line						
Name	Code	Name	Code	Name	Code	Name	Code	Category	Name	Code					
1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28	Dharmasagar (S)	Chevella	F(CHE)	Chevella	CHE	Chevella	SHE								
						Starchik	STA								
						Kothapally	KOT								
						Alur	ALU								
						Gundala	GUN								
						Mudumyal	MUD								
		Moinabad	F(MOI)	Moinabad	MOI	Moinabad	MOI								
						S.P.Steels	SPS								
						Peddamangalaram	PED								
						Kankamamdi	KAN								
						Himayathnagar	HIM								
						Surangal	SUR								
		Pargi	F(PAR)	Manneguda	MAN	Super Dairy	SUP								
						Chenggamul	OHN								
						Pudur	PUD								
				Pargi	PAR	Pargi	PAR	Merzapur	MER						
								Pargi Town	PAR						
								Rakamcherla	RAK						
		Shabad	F(SHA)	Shabad	SHA	Shabad	SHA								
						Nagarkunta	NAG								
						Polaram	POL								
						Sardarnagar	SAR								
						Tallapally	TAL	Tallapally	TAL	R.Dosado	RDO				
										Rudraram	RUD				
						Tallapally	TAL								

Ranga Reddy (2/18)

220/132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder			0.4 kV Line							
Name	Code	Name	Code	Name	Code	Name	Code	Category	Name	Code						
1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36	Ibrahimpatnam (S)	Ibrahimpatnam	F(IBR)	Ibrahimpatnam	IBR	Ibrahimpatnam	IBA									
						Sheriguda	SHE									
						Elmnedu										
						Raipole										
						Kandukur	F(KAN)	Kandukur	KAN	Kandukur	KAN					
										Gudur	GUD					
										Pulimamudi	PUL					
										Bachepally	BAC					
										Nednoor	NED					
										Mucherla	MUC					
						Rachaloor	RAC	Rachaloor	RAC	Rachaloor	BAC					
										Gundavally	GUN					
										Thummmmarpur	THI					
						Lemur	LEM	Lemur	LEM	Lemur	LEM					
						Mall	F(MAL)	Mall	MAL	Bodakonda(Unmanned)	BOD					
										Bodakonda	BOD					
						Yellamma Tanda	YEL	Yellamma Tanda	YEL	Yellamma Tanda	YEL					
						Mall	MAL	Mall	MAL	Mall	MAL					
										Nallavally	NAL					
										Kothapally	KOT					
						Manchal	F(MAN)	Manchal	MAN	Dandumailaram	DAN					
										Nerapally	NER					
										Mukkunoor	MUK					
						Manchal	MAN	Manchal	MAN	Manchal	MAN					
										Nomula	NOM					
										Japal	JAP					
										Arutla	ARU					
						Tallapallyguda	TAL	Tallapallyguda	TAL	Tallapallyguda	TAL					
						Turkayamzal	F(TUK)	Turkayamzal	TUR	Turkayamzal	TUR					
										Manneguda	MAN					
						Yacharam	F(YAC)	Yacharam	YAC	Yacharam	YAC					
Medipally	MED															
Gungal	GUN															
Chintapalla	CHI															
Chowderpally	CHO															
Nandivanaparthi	NAN															

Annex 3.2 Code List of Substations and Feeders

Ranga Reddy (3/18)

220/132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder			0.4 kV Line	
Name	Code	Name	Code	Name	Code	Name	Code	Category	Name	Code
1 Medehal	RMED	Alhabad	F(ALI)	Alhabad	ALI	Bavileela	BAV			
2 (N)						S.V S Milla	SVS			
3						Turkapally	TUR			
4						Alhabad	ALI			
5						Tumkunta	TUM			
6						Jaganguda	JAG			
7				Medicity	MED	Medicity	MED			
8						Pudur	PUD			
9						Rajblaram	RAJ			
10				ICICI	ICI	ICICI	ICI			
11						Bharath Bio-Tech	BHA			
12		Bandamadaram	F(BAN)	Bandamadaram	BAN	Srirangavaram	SRI			
13						Nutankal	NUT			
14						Railapur	RAI			
15		G.P.Pally	F(GPP)	G.P.Pally	GPP	IDA	IDA			
16						G P Pally	GPP			
17						Maisammaguda	MAI			
18						Doolapally	DOO			
19				Kompally	KOM	Kompally	KOM			
20						Jeedimelta	JEE			
21						Jayabhen	JAY			
22		Keshavaram	F(KES)	Keshavaram	KES	Uddamarri	UDD			
23						Anantharam	ANA			
24						Laxmapur	LAX			
25				Koltur	KOL	Koltur	KOL			
26				Thumukunta	THU	Nalsar	NOL			
27						Shameerpet	SHA			
28						Thumukunta	THU			
29		Medehal	F(MED)	Medehal	MED	IDA I	ID1			
30						IDA II	ID2			
31						Medcal Town	MED			
32						Kandlakoya	KAN			
33						Medchal Rural	MER			
34						Yellampet	YEL			
35						Ravalkole	RAV			
36		Shapur Nagar	F(SHA)	Aleap	ALE	Pragathinagar	PRA			
37						Aleap	ALE			

Ranga Reddy (4/18 - 1)

220/132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder			0.4 kV Line	
Name	Code	Name	Code	Name	Code	Name	Code	Category	Name	Code
1 Moulali	RMOU	L.G.Mint	F(LGM)	Cherlapally	CHE	Nagaram	NAG			
2 (N)						Rampally	RAM			
3						Kurppa	KUR			
4						IDA Phse-I	ID1			
5						IDA Phase-II	ID2			
6						ECIL	ECI			
7				Keesara	KEE	Keesara	KEE			
8						Cheryal	CHE			
9		Moulali	F(MOU)	Malkajgiri	MAL	Suryanagar	SUR			
10						Anandbagh	ANA			
11						Durganagar	DUR			
12						Mahinkarjunanagar	MAL			
13				Moulali	MOU	HMT	HMT			
14						HCL	HCL			
15						Meerpet	MEE			
16						Mirzalaguda	MIR			
17						Spectra	SPE			
18						Malkajgiri	MAL			
19						Moulali	MOU			
20						Flash Butt	FLA			
21		Nacharam	F(NAC)	Mallapur	MLL	A.P.Foods	APF			
22						Bell	BEL			
23						IDA Mallapur Phase-I	IDA			
24						Mallapur(V)	MAL			
25				Nacharam	NAC	NILE	MIL			
26						Laxmi starch	LAX			
27						Telephone Exchange	TEL			
28						Indan Extrusion	IND			
29						Multi Steel	MUL			
30						Sanjay Re-Roll	SAN			
31						Tunggabhadra	TUN			

Annex 3.2 Code List of Substations and Feeders

Ranga Reddy (4/18 - 2)

220/132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder			0.4 kV Line			
Name	Code	Name	Code	Name	Code	Name	Code	Category	Name	Code		
32 Moulali 33 (N) 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53	RMOU	NGRI	F(NGR)	NGRI	NGR	Kalyanpuri	KAL					
						S O I	SOI					
						Penguntentiles	PEN					
						H M T	HMT					
						Habsigunda	HAB					
						NGRI	NGR					
				Mohan Nagar	MOH	Laxmi Nagar	LAX					
						Kothapet	KOT					
				Samikpuri	F(SAI)	Samikpuri	SAI	Kushaiguda	KUS			
			Kamalanagar					KAM				
			A S Rao nagar					ASR				
			Neredmet					NAR				
			Sainikpuri					SAI				
			Kapra					KAP				
				Uppal	F(UPP)	Uppal	UPP	Boduppal	BOD			
			Indl Ghatkesar					IND				
			Door Darshan					DOO				
			Navabharath					NAV				
	Uppal	UPP										
	Gangappa	GAN										
	Ramanthpur	RAM										

Ranga Reddy (5/18)

220/132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder			0.4 kV Line					
Name	Code	Name	Code	Name	Code	Name	Code	Category	Name	Code				
1 Puttapahad 2 (S) 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17	RPUT	Doma	F(DOM)	Domsampally	DIR	Mallepally	MAL							
						Brahamapally	BRA							
						Badempally	BAD							
						Domsampally	DIR							
								Doma	DOM	Doma	DOM			
										Baspally	BAS			
						Palepally	PAL							
				Puttapahad	F(PUT)	Chowdapur	CHO	Chowdapur	OHO					
										Majdipur	MAJ			
										Marikal	MAR			
										Puttapahad	PUT	Puttapahad	PUT	
								Rusumpally	PUS					
								Nancherla	NAN					
								Kulkacherla	PUL					
				Salkarpet	F(SAL)	Salkarpet	SAL	Pagidiyal	PAG					
										Gandeed	GAN			
										Salkarpet	SAL			

Ranga Reddy (6/18)

220/132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder			0.4 kV Line					
Name	Code	Name	Code	Name	Code	Name	Code	Category	Name	Code				
1 Rama 2 Chandrapuram 3 (Medak) 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19	MRAM	Chandanagar (N)	F(CHA)	Chandanagar	CHA	Taranagar	TAR							
						Chandanagar	CHA							
						Hafeezpet	HAF							
						Miyapur	MIY							
				Gachibowli (N)	F(CAC)	Gachibowli	GAC	Lingampally	LIN					
										Gachibowli	GAC			
										Kothaguda	KOT			
										University	UNI			
						Alind	ALI							
				Gridhar Ispot (S)	F(GRI)	Garge Steels	GAR	Garge Steels	GAR					
										Vanasthalpuram	VAN			
				Shankarpally (S)	F(SHA)	Donthanpally	DON	Maharajpet	MAH					
										Janwada	JAN			
										Shankarpally	SHA			
								Parwada	PAR					
								Kondekal	KON					
								Dhobipet	DHO					
						SJB TUBES	SJB	Indl feeder	IND					
								Mokila	MOK					

Annex 3.2 Code List of Substations and Feeders

Ranga Reddy (7/18)

220/132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder			0.4 kV Line	
Name	Code	Name	Code	Name	Code	Name	Code	Category	Name	Code
1 Shapurunagar (N)	RSHA	AFA-I (N)	F(AF1)	D.P.PALLY	DPP	Gagilapur Dundigal Bowrampet Satyamcomputers	GAG DUN BOW SAT			
		Jeedimetla-I (N)	F(JE1)	Jeedimetla-I	JE1	Phase-I Phase-II Phase-V Subbhashnagar Agarwal Foundry Virco Sudarshan Drugs *****	PH1 PH2 PH5 SUB AGA VIR SUD			
		Jeedimetla-II (N)	F(JE2)	Jeedimetla-II	JE2	Gajuralaramaram Kompally Suraram Phase-III Phase-IV Phase-V	GAJ KOM SUR Ph2 PH4 PH5			
		Shapurunagar (N)	F(SHA)	Ushamullapudi	USH	Ushamullapudi Shapurunagar Gajuralaramaram Chandragiricolony	USH SHA GAJ CHA			

Ranga Reddy (8/18)

220/132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder			0.4 kV Line	
Name	Code	Name	Code	Name	Code	Name	Code	Category	Name	Code
1 Shivarampally (S)	RSHI	Gaganpahad	F(GAG)	Gaganpahad	GAG	Manage Shivashakthi Jai Bhavan Rajendranagar Gaganpahad NPA	MAN SHI JAI RAJ GAG NPA			
		Ibrahimbagh	F(IBR)	Ibrahimbagh	IBR	Osmanagar Military-I Military-II Peddamangalram	OSM MI1 MI2 PED			
				APPA	APP	Himayathsagar Police Academy Aziznagar	HIM POL AZI			
		N.P.A	F(NPA)	N.P.A	NPA	Kattedan Sivarampally N.P.A Shastripuram Uppanpally	KAT SIV NPA SHA UPP			

Annex 3.2 Code List of Substations and Feeders

Ranga Reddy (9/18)

220/132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder			0.4 kV Line					
Name	Code	Name	Code	Name	Code	Name	Code	Category	Name	Code				
1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31	RTAN	Basheerabad	F(BAS)	Basheerabad	BAS	Basheerabad	BAS							
								Yallal	YAL	Yallal	YAL			
										Bennur	BEN			
										Devnoor				
								Laxminarayanpur	LAX	Chennaram	CHE			
										Laxminarayanpur	LAX			
										Dennur	DEN			
						Karankote	F(KAR)	Karankote	KAR	Karankote	KAR			
										Ogipur	OGI			
						Tandur	F(TAN)	Tandur	TAN	Kodungal	KOD			
										Water Works	WAT			
										Adikcherla	ADI			
										Antaram	ANT			
										Chengole	CHE			
										Tandur Old	TAN			
						Turimamidi	F(TUR)	Peddumul	PED	Peddumul	PED			
										Kandavally	KAN			
										Jangaon	JAN			
										Kotepally	KOT			
								Turimamidi	TUR	Turimamidi	TUR			
										Tatepally	TAT			
										Bentaram	BEN			
						Vikarabad	F(VIK)	Dharur	DHA	Dharur	DHA			
										Kukkunda	KUK			
										Gutkepally	GUT			
								Vikarabad	VIK	Vikarabad+P Press	VIK			
										AnanthGiri Gutta	ANA			
										Sivareddypet	SKA			
										Ekamamidi	EKA			

Ranga Reddy (10/18)

220/132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder			0.4 kV Line					
Name	Code	Name	Code	Name	Code	Name	Code	Category	Name	Code				
1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26	RBAN	Abdullapurmet (S)	F(ABD)	Abdullapur	ABD	Abdullapurmet	ABD							
								Film City	FLM	Film City	FLM			
								Peddamberpet	PED	Peddamberpet	PED			
										Taramathipet	TAR			
						Ghatkesar (N)	F(GHA)	Narapally	NAR	Medipally	MED			
										Prathapapsingram	PRA			
						Hayathnagar (S)	F(HAY)	Hayathnagar	HAY	Mansurabad	MAN			
										Mother dairy	MOT			
										High Court Colony	HCC			
										Autonagar	AUT			
										L.B.Nagar	LBN			
										AIR	AIR			
										Sirs	SIR			
										Hayathnagar	HAY			
						Vanasthalipuram (S)	F(VAN)	Vanasthalipuram	VAN	Vanasthalipuram	VAN			
										Bairamalguda	BAL			
										Injapur	INJ			
								Bandlaguda	BAN	A;kapuri	AKA			
										Nagole	NAG			
										GSI	GSI			
										Huda	NUD			
										Kothapet	KOT			
										Saroornagar	SAM			
										Kamalanagar	KAM			

Annex 3.2 Code List of Substations and Feeders

Ranga Reddy (11/18)

220/132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder			0.4 kV Line		
Name	Code	Name	Code	Name	Code	Name	Code	Category	Name	Code	
1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28	RCHA	Champapet	F(CHA)	Champapet	CHA	Sulthanvala	SIU				
						Champapet	CHA				
						Karmangbat	KAR				
						Balapur	BAL				
						Meerpet	MEE				
		Kattendan	F(KAT)	Kattendan	KAT	Kattendan-I	KT1				
						Kattendan-II	KT2				
						Kattendan-III	KT3				
		Maheswaram	F(MAH)	Maheswaram	MAH	Maheswaram	MAH				
						Lemur	LEM				
						Ghatpally	GHA				
						Timmalur	TIM				
						Nagaram	NAG				
		Mamudipally			MAM	Pahadisharif	PAH				
						Thukkunguda	THU				
Mankal			MAN	Mankal	MAN						
				IDA	IDA						
Shamshabad	F(SHA)	Shamshabad	SHA	Om Jatbhavani	OMJ						
				Shamshabad	SHA						
				Narkoda	NAR						
				Habeebullnagar	HAB						
Shapurkalan			SHP	Indi feeder	IND						
				Palmakunta	PAL						
				Gandiguda	GAN						
				Shapurkalan	SHA						

Ranga Reddy (12/18)

220/132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder			0.4 kV Line	
Name	Code	Name	Code	Name	Code	Name	Code	Category	Name	Code
1 2 3 4 5 6 7	CERR	Kukatpally	F(KUK)	Kukatpally	KUK	Kukatpally	KUK			
						Hydernagar	HYD			
						Air force	AIR			
						Venkatechwarannagar	VEN			
						Bhagyanagar	BHA			
						JNTU	JNT			
						KPHB	KPH			

Ranga Reddy (13/18)

220/132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder			0.4 kV Line	
Name	Code	Name	Code	Name	Code	Name	Code	Category	Name	Code
1 2 3 4 5 6 7	RGHA	Ghatkesar	F(GHA)	Ghatkesar	GHA	NTPC	NTP			
						Medipally	MED			
						Syndicate	SYN			
						Ghatkesar	GHA			
						Keesara	KEE			
						Edulabad	EDU			
						Aushapur	AUS			

Ranga Reddy (14/18)

220/132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder			0.4 kV Line	
Name	Code	Name	Code	Name	Code	Name	Code	Category	Name	Code
1 2 3 4	CJUB	CMC	F(OMC)	ESCI	ESO	Guchibowli	GUC			
						Nanakramguda	NAN			
						ESCI	FSC			
							III			

Ranga Reddy (15/18)

220/132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder			0.4 kV Line	
Name	Code	Name	Code	Name	Code	Name	Code	Category	Name	Code
1 2 3	HKOT	Kothur	F(KOT)	Ameerpet	AME	Ameerpet	AME			
						Collur	COL			
						Dubbacherla	DUB			

Annex 3.2 Code List of Substations and Feeders

Ranga Reddy (16/18)

220/132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder			0.4 kV Line	
Name	Code	Name	Code	Name	Code	Name	Code	Category	Name	Code
1 Mehaboobnagar	HMEH	Salkarpet	F(SAL)	Mohammadabad	MOH	Noncherla	NON			
2 (Mabhubnagar)						Mohammadabad	MOH			

Ranga Reddy (17/18)

220/132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder			0.4 kV Line	
Name	Code	Name	Code	Name	Code	Name	Code	Category	Name	Code
1 Sadasivpet	MSAD	Mominpet	F(MOM)	Marpally	MAR	Patlur	PAT			
2 (Medak)						Marpally	MAR			
3						Sripuram	SRI			
4				Mominpet	MOM	Mominpet	MOM			
5						Barwada	BAR			
6						Enkatala	ENK			
7				Nawabpet	NAW	Havabpet	HAV			
8						Arkatala	ARK			
9						Dulmamudi	DUL			

Ranga Reddy (18/18)

220/132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder			0.4 kV Line	
Name	Code	Name	Code	Name	Code	Name	Code	Category	Name	Code
1 Bollaram	MBOL	*****	F(**)	Reddy Labs	RL1	(HT)				
4 (Medak)				Reddy Diagnostic	RED	(HT)				
5				Reddy Labs	RL2	(HT)				
7				Kukatpally	LUK	***				
8						***				
9						***				

Annex 3.2 Code List of Substations and Feeders

Medak (1/7)

132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder		
Name	Code	Name	Code	Name	Code	Name	Code	Category
1	Siddipet	MSID	Rampur	F(RAM)	Rampur(Nangnoor)	RAM	Paiamakulu	PAI
2							Narmeta	NAR
3							Badojpadga	BAD
4					Mittapally	MIT	Bakrichepyal	BAK
5							Watsol (I)	WAT
6							Velkatoor	VEL
7					Kondamrajapally	KON	Kodarajampally	KOD
8							Katha	KAT
9					Narmetta	NAM	Narmetta	NAR
10					Ponnal	PON	Ponal	PON
11							Rangampally	RAM
12			Duddeda	F(DUD)	Duddeda	DUD	Bandram	DAN
13							Deddeda	DED
14							Velkatta	VEL
15					Medinipur	MED	Mangote	MAN
16							Kukunurpally	KUK
17							Lakdarama	LAK
18					Kondapak	KON	Kondapak	KON
19							Nacharam	NAC
20					Marpadaga	NAR		
21			Tornal	F(TOM)	Tornal	TOM		
22					Irkode	IRK	Irkode	IRK
23					Chiiapur	CHI		
24					Pothareddypet	POT	Pothareddypet	POT
25							Thalapally	THA
26			Dubbak	F(DBB)	Pedda Gundavally	PED	Peddagundavelly	PED
27							Dumpalapally	DUM
28					Dubbak	DUB	Dubbaka	DUB
29							Lachapet	LAC
30							Habsipur	HAB
31							Chellapur	CHE
32					Ragothampally	RAG	Raghqthampally	RAG
33							Ramakkapet	RAM
34							Gosanpally	GOS
35							Akaram	AKA
36					PeddaChikode	RED	Chekode	CHE
37							Potharam	POT
38							Achmaipally	ACH
39					Challapur	CHA		
40					Dharmajipet	DHA	Dharmajipet	BHA
41							Lachapet	LAC
42			Raghavapur	F(RAG)	Raghavapur	RAG	Narayanraopet	NAR
43							Chintamadaka	CHI
44							Pulkur	PUL
45					Laxmidivpally	LAX	Laxmidivpally	LAX
46							Machapur	MAC
47					Gurrale Gondi	GUR	Gurralagondi	GUR
48							Jakkapur	JAK
49					Kammarlapally	KAM	Allipur	ALL
50							Waterworks	WAT
51							Kammarlapally	KAM
52					Machapur	MAC	Machapur	MAC
53			Pedda Kodur	F(RED)	Narsapur(Shiddipet)	NAR	Lingareddypally (I)	LIN
54							Market Yard (U)	MAR
55							Narsapur (I)	NAR
56							Karim Nagar Road	KAR
57					Peddakodur	PED		
58					Meddipally	MED	Ibrahimnagar	IBR
59							Medipally	MED
60							Ananthasagar	ANA

Medak (2/7)

	132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder		Category
	Name	Code	Name	Code	Name	Code	Name	Code	
61					Thornal	THO	Tornal	TOR	
62							Timmapur	TIM	
63					Nedipally	NED			
64					Condipally	CON			
65	Thukkapur	MTHU	Dommat	F(DOM)	Dommat	DOM	Dommat	DOM	
66							Suranpally	SUR	
67					Doulthabad	DOU	Inddupriyal	IND	
68							Konnaipally	KON	
69							Doulthabad	DOU	
70					Chittapur	CHI	Dharmajipet	DHA	
71							Chittapur	CHI	
72							Mothey	MOT	
73					Peddachpyal	PED			
74			Thukkapur	F(THU)	Thukkapur	THU	Togita	TOG	
75							Yellareddypet	YEL	
76							Y. G. Kistapur	YGK	
77							Pouce Station	POU	
78			Mirdoddi	F(MIR)	Mirdoddy	MIR	Mirdoddy	MIR	
79							Mallepally	MAL	
80							Andha	AND	
81					Mettu(Bandarappally)	MET			
82					Gudikandula	GUD	Gudikandula	GUD	
83					Jangampally	JAN	Jangapally	JAN	
84							Veerareddypally	VEE	
85					Peddachepyal	PED			
86					Khajipur	KHA	Khajipur	KHA	
87			Ligapur	F(LIG)	Lingapur	LIN	Lingapur	LIN	
88							Venkatraopet	VEN	
89					Raipole	RAI	Raipole	RAI	
90							Thirmalapur	THI	
91							Thmmakpally	THM	
92							Anajpur	ANA	
93							Kothapally	KOT	
94					Pallepahad	PAL	Pallepahad	PAL	
95							Vemulghat	VEM	
96	Gajwel	MGAJ	Gajwel	F(GAJ)	Gajwel	GAJ	Dharmareddypall	DHA	
97			Jagadevapur	F(JAG)	Jagadevapur	JAG	Jagadevapur	JAG	
98							Itikyal	ITI	
99							Allirajpet	ALL	
100					Kodakandla	KOD	Kodakandla	KOD	
101							Mohank K/S(I)	MOH	
102							Kuknoor Pally	KUK	
103							Burugpally	BUR	
104					Munigadapa	MUN	Munigadapoa	MUN	
105							Basvapur	BAS	
106					Ganeshpally	GAN	Ganeshpally	GAN	
107					Pregnapur	PRE	Pregnapur	PRE	
108							Serigurpally	SER	
109			Ahmedipur	F(AHM)	Ahmedipur	AHM	Ahmedipur	AHM	
110							Pidched	PID	
111					Bejgoam	BEJ	Bejgoan	BEJ	
112							Plungareddypally	PLI	
113					Gurralasofa	GUR	Waddepally	WAD	
114							Ramaram	RAM	
115							Machaipally	MAC	
116					Banglla Venkatapur	BAN	B. Venkatapur	BE	
117							Yelkal	YEL	
118							Muktmamasanpally	MUK	

Annex 3.2 Code List of Substations and Feeders

Medak (3/7)

132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder		
Name	Code	Name	Code	Name	Code	Name	Code	Category
119		Mulugu	F(MUL)	Mulugu	MUL			
120				Vntimamidi	ONT			
121				Thunkikalsa	THU	Tunkkalsa	TUN	
122						Narsapur	NAR	
123				Kokkonda	KOK			
124		Gowraram	F(GOW)	Gowraram	GOW	Paamulaparthu	PAA	
125						Pathur	PA1	
126						Pathur	PA2	
127						Navodaya	NAV	
128						Wargal	WAR	
129						Express	EXP	
130				Markook	MAR			
131	Chegunta	MCHE	Chegunta	F(CHE)	Chegunta	CHE	Chegunta	CHE
132						Karnalpally	KAR	
133						Reddypally	RED	
134						Volluru	VOL	
135		Yeldurthy	F(YEL)	Yeldurthy	YEL	Yeldurthy	YEL	
136						Uppulingapur	UPP	
137						Shetpally	SHE	
138				Suraram	SUR	Chandampet	CHA	
139						Suram	SUR	
140				Konapur	KON	Konapur	KON	
141				Nizampet	NIZ	Nizampet	NIZ	
142						Chelmada	CHE	
143						Maskal	MAS	
144						Kalwakunta	KAL	
145				Mangalparthy	MAN			
146								
147		Bonale	F(BON)	Bonala	BON	Bonala	BON	
148						B Kondapur	BKO	
149				Narlapur	NAR	Narlapur	NAR	
150						Venkatapur (K)	VEN	
151				Nizampur	NIZ			
152	Minpur	MMIN	Minpur	F(MIN)	Minpur	MIN	Minpur	MIN
153						Kodpak	KOD	
154		(NPDCL)	Nizampet					
155			Podochanpal	F(POD)	Podochanpally	POD	Podchanpally	POD
156						Gandharpally	GAN	
157			Narsingi	F(NAR)	Narsingi	NAR	Narsingi	NAR
158						Narsampally	NAP	
159						Sankapur	SAN	
160						Vallebapur	VAL	
161				Tekmal	TEK	Ellapally	ELL	
162						Tekmal	TEK	
163				Kodapak	KOD			
164	Kowdipally	MKOW	Ch.Ghanpur	F(CHG)	Ch.Ghanpur	CHG		
165					Engandia	ENG		
166								
167			Kowdipally	F(KOW)	Kowdipally	KOW	Kowdipally	KOW
168						Devaipally	DEV	
169						Mohobad	MOH	
170			Venktraopec	F(VEN)	Venktraopec	VEN		
171			Amsanpally	F(AMS)	Amsanpally	AMS	Amsanpally	AMS
172						Kongode	KON	
173	Medak	MMDK	Medak	F(MDK)	Medak	MDK	Medak T-I(U)	MD1
174							Medak T-II(U)	MD2
175							Komtur	KM
176							Ausalapally	AUS
177							Balanagar	BAL
178							Kuchanpally	KUC
179							Nagapur	NAG
180							H Ghanapur	HGH

Annex 3.2 Code List of Substations and Feeders

Medak (4/7)

132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder		
Name	Code	Name	Code	Name	Code	Name	Code	Category
181		NSF	F(NSF)	NSF(Mombojipally	NSF			
182				Pillikottala	PIL			
183		Shankarampe	F(SHA)	Shankarampet	SHA	Shankrampet	SHA	
184						Jangarai	JAN	
185						Maadoor	MAA	
186				Shalipet	SHL	Shalipet	SHL	
187		B.B.Pur	F(BBP)	B.B.Pur	BBP	B. Boopathipally	BBP	
188						Burugupally	BUR	
189						Sardana	SAR	
190				Wadi	WAD	Wadi	WAD	
191						Dhupsinghthanda	DHU	
192		Ramayampet	F(RAM)	Ramayampet	RAM	Ramayampet	RAM	
193						Konapur	KON	
194						D. Dharmaram	DDH	
195						Akkannapet	AKK	
196				Laxmapur	LAX	Laxmapur	LAX	
197						Tunigandla	TUN	
198						Indust (I)	IND	
199						Katryal	KAT	
200				Pathur	PAT	Pathur	PAT	
201						Shamnapur	SHA	
202	Narayankhed	MNAR	F(NAR)	Narayankhed	NAR	Abbenoa	ABB	
203						Rayalamadgu	RAY	
204						Regode	REG	
205						Pipri	PIP	
206						Narayankhed	NAR	
207		Shankarampe	F(SHA)	Shankarampet	SHA	Shankrampet	SHA	
208						Mizampet	MIZ	
209						Velur	VEU	
210						Alladurg	ALL	
211						Regode	REG	
212				Bodagattu	BOD			
213		Kalher	F(KAL)	Kalher	KAL	Kalher	KAL	
214						Kanapoor	KAN	
215						Mardi	MAR	
216				Sanjeevaraopet	SAN	Sanjeevaraopet	SAN	
217						Kadpal	KAD	
218				Bachepally	BAC	Bachepally	BAC	
219						Ramreddypet	RAM	
220		Poosalpahad	F(POO)	Poosalpahad	POO	Mandoor	MAN	
221						Shapur	SHA	
222				Borancha	BOR	Dhanwar	DHA	
223						Nap	NAP	
224		Waser		Waser	WAS			
225				Tadakal	TAD			
226	Manoharabad	MMAN	F(MAS)	Masaipet	MAS	Masaipet	MAS	
227			er			Lingareddypally	LIN	
228						PD Shivanur	PDS	
229				Islampur	ISL	Islampur	ISL	
230				Nacharam	NAC	Nacharam	NAC	
231						Vailur	VAL	
232				Chandaipet	CHA	Chandaipet	CHA	
233						Makkarajpet	MAK	
234		Toopran	F(TOO)	Toopran	TOO	Toopran	TOO	
235						Ravelly	RAV	
236						Padalpally	PAD	
237						Asian Coffee (I)	ASI	
238				Gonepally	GON	Gonepally	GON	
239						Ramunipatla	RAM	

Annex 3.2 Code List of Substations and Feeders

Medak (5/7)

132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder		
Name	Code	Name	Code	Name	Code	Name	Code	Category
240		Manoharabad	F(MAN)	Manoharabad	MAN	Kucharam	KUC	
241						Mulugu	MUL	
242		Kallakal	F(KAL)	Kallakal	KAL	Kallakal	KAL	
243						K. P Steel (I)	KPS	
244						Karan Textile (I)	TEX	
245		Shivampet	F(SHI)	Shivampet	SHI	Shivampet- I	SH1	
246						Shivampet-II	SH2	
247						Donthy	CDN	
248						Indl Feeder	IND	
249						Pambanda	PAM	
250				Sikundlapur	SIK			
251	Gummadidala	MGUM	Gummadidala	F(GUM)	Gummadidala	GUM	Kanukunta	KAN
252						Abgrobel (I)	ABG	
253						Bell Remedies (I)	BEL	
254		Narsapur	F(NAR)	Narsapur	NAR	Narsapur	NAR	
255						K. Maddor	KMA	
256						Narayanpur	NAR	
257						Avancha	AVA	
258						Reddypally	RED	
259				Kothapet	KOT	Kothapet	KOT	
260						Lingojigda	LIN	
261	220/132 kv		Jinnaram		Jinnaram	JIN		
262	(RRS)				Dundigal	DUN		
263					Gaddapotaram	GAD		
264			(RRS)					
265	Bollaram	MBOL	Kukatpally	F(KUK)				
266			Bachepally	F(BAC)				
267			Shathavachana	F(SHA)				
268			Bollaram		Bollaram-I	BO1	Soubhagya	SOU
269							Pavan	PAV
270					Bollaram-II	BO2	Charminar	CHA
271							Vipla	VIP
272							Kottam	KOT
273							Rupa	RUP
274	132/11kV Bollaram							
275	Zaheerabad	MZAH	Zaheerabad	F(ZAH)	Zaheerabad	ZAH	Zaheerabad - I	ZA1
276							Zaheerabad - II	ZA2
277							Ranjole	RAN
278							Aligole .	ALI
279			Mannapur	F(MAN)	Mannapur	MAN	Hottab	HOT
280							Manapur	MAN
281							Gopanpally	GOP
282							Magdoompally	MAG
283					Malchelma	MAL	Malchelma	MAL
284							J. Malkapur	JMA
285							Parsapally	PAR
286					Satwar	SAT	Satwar	SAT
287			Jarasangam	F(JAL)	Jarasangam	JAL	Kuppanagar	KUP
288							Jeerlapally	JEE
289							Raikode	RAI
290			Hadnoor	F(HAD)	Hadnoor	HAD	Rejintal	REJ
291							Hadnoor	HAD
292							Nyalkal	NYA
293							Mamidiga	MAM
294					Chalki	CHA	Raghavapur	RAG
295							Chalki	CHA
296							Nap W.W.	NAP
297					Raikode	RAI	Raikode	RAI
298							Pampad	RAM
299							Pipalpally	PIP
300					Metalkunta	MET	Metalkunta	MET
301							Rajol	RAJ

Annex 3.2 Code List of Substations and Feeders

Medak (6/7)

	132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder				
	Name	Code	Name	Code	Name	Code	Name	Code	Category		
302	Jogipet	MJOG	Jogipet	F(JOG)	Jogipet	JOG	Jogipet	JOG			
303			Dakoor	DAK							
304			Dhanura	DHA							
305			Posanpet	POS							
306			Shankarmpet	SHA							
307			Chitkul	F(CHI)	Chitkul	CHI	Chitkul	CHI	Chitkul	CHI	
308			Seelampally	SEE	Seelampally	SEE	Seelampally	SEE	Seelampally	SEE	
309			Faizabad	FAI					Faizabad	FAI	
310			Gadipeddapur	F(GAD)	Gadipeddapur	GAD	Gadipeddapur	GAD	Gadipeddapur	GAD	
311			Muslapur	MUS					Muslapur	MUS	
312			Alladurg	ALL	Alladurg	ALL	Alladurg	ALL	Alladurg	ALL	
313			Chilvera	CHI					Chilvera	CHI	
314			Medikonda	MED	Medikonda	MED	Alladurg	DRG	Alladurg	DRG	
315			Devanoor	DEV					Devanoor	DEV	
316			Khadiraad	KHA					Khadiraad	KHA	
317			Laximisagar	F(LAX)	Laximisagar	LAX	Laximisagar	LAX	Laximisagar	LAX	
318			Pothrepdyally	POT					Pothrepdyally	POT	
319			Talelma	TAL					Talelma	TAL	
320			Pashamailaram	MPAS	Isnapur	F(ISN)	Isnapur	ISN	Patodia	PAT	
321	Muthangi	MUT						Muthangi	MUT		
322	Ida - I	ID1							Ida - I	ID1	
323	Ida - II	ID2							Ida - II	ID2	
324	Rudraram	PUD							Rudraram	PUD	
325	Widia	WID							Widia	WID	
326	SOL	F(SQL)			SOL	SQL	SOL	SQL	Sol Town	SQL	
327	Dexo	DEX							Dexo	DEX	
328	Inole	INO			Inole	INO	P. Kanjarla	PKA	P. Kanjarla	PKA	
329	Indresham	IND							Indresham	IND	
330								EPI			
331	Manjeera Water	F(WAT)			E P IP(Pashamailaram)	EPI					
332	INOX	F(INO)									
333	R.C.Puram		Gachibowli								
334			Patancheru								
335			Ambuja								
336			Manjeera W.W.								
337			NSL								
338			Annapurna Foils		Annapurna Foils	ANN					
339						MIG					
340						Kollur	KOL				
341			Chandanagar		Chandanagar	CHA					
342					Ashoknagar	ASH					
343			Giridhar Ispat	GIR							
344	Sadasivpet	MSAD	Jogipet	F(JOG)	Nizampur	NIZ	Nizampur	NIZ			
345			Venkatapur	VEN					Venkatapur	VEN	
346			Mudaipet	MUD					Singoor	SIN	
347			Mudimaniyam	MUD					Mudimaniyam	MUD	
348			Pulkal	PUL					Pulkal	PUL	
349			Sultanpur	SUL					Sultanpur	SUL	
350			Korpole	KOR					Korpole	KOR	
351			Manjeera	F(MAN)							
352			MRF	F(MRF)							
353			Vikarabad	F(VIK)							
354			(RRS)		Kohir	F(KOH)	Kohir	KOH	Kohir	KOH	
355	Nagreddypally	NAG						Nagreddypally	NAG		
356	Sajapur	SAJ							Sajapur	SAJ	
357	Digwal	DIG			Digwal	DIG	Chintalghat	CHI	Chintalghat	CHI	
358	Digwal	DIG							Digwal	DIG	
359							Global Bluk Drugs	GLO			

Annex 3.2 Code List of Substations and Feeders

Medak (7/7)

132/33 kV Substation		33 kV Feeder		33/11kV Substation		11 kV Feeder		
Name	Code	Name	Code	Name	Code	Name	Code	Category
360		Munipally	F(MUN)	Munipally	MUN	Budhera	BUD	
361						Khammampally	KHA	
362						Jackwell	JAC	
363				Athmakur	ATH	Athemakur	ATH	
364						Yellaram	YEL	
365		Priyadarshini	F(PRI)					
366	132/11kV Sadasivpet							
367	Kandi	MKAN	F(SR1)	Sangareddy-I	SR1	Sangareddy - I	SR1	
368						Sangareddy - II	SR2	
369						Sangareddy - III	SR3	
370							KAL	
371						Kandi	KAN	
372						Kolsa	KOS	
373						Water Works	WAT	
374				Rajampet	RAJ	Kalabcur (Filter bed)		
375				Sangareddy-II	SR2	Sangareddy - I	SA1	
376						Sangareddy - II	SA2	
377						Sangareddy - III	SA3	
378				Kondapur	KON	Kondapur	KON	
379						Marepally	MAR	
380						Gangaram	GAN	
381				Malkapur	MAL	Malkapur	MAL	
382						Mundevunipally	MUN	
383						Pepsi	PPS	
384				Ismailkanpet	ISM	Ismailkhanpet	ISM	
385						Arutla	ARU	
386						Erdanoor	ERD	
387		HFC-I	F(HF1)	Cheriyal	CHE	Kandi	KAN	
388						Kalvemula	KAL	
389						Indrakaram	IND	
390						Cheriyal	CHE	
391		HFC-II	F(HF2)	TurakalaKhanapur	TUR	Borpatra	BOR	
392						Doultabad	DOU	
393						Indl	INL	
394				Hathnoora	HAT	Hathnoora	HAT	
395						Gondarapally	GON	
396						Sikindlapur	SIK	
397				Nasthipur	NAS			
398		BharathStrips	F(BHA)					
399		Isnapur	F(ISN)					
400		BDL	F(BDL)	BDL	BDL			
401				Nangigama	NAN			
402		Alkabir	F(ALK)					

Annex 3.3 Frequency Records in May and November 2002 and 2003

(Hz)

Day	May-02-2002		Nov-02-2002		May-02-2003		Nov-03-2003	
	Max	Min	Max	Min	Max	Min	Max	Min
1	47.78	47.75	49.71	49.44	50.65	49.42	49.85	49.10
2	47.92	47.87	50.84	49.29	50.38	49.62	50.25	49.70
3	47.96	47.88	50.25	50.00	50.40	49.73	50.15	49.60
4	47.95	47.86	50.75	48.58	50.62	49.48	50.10	49.30
5	47.86	47.84	50.00	49.96	50.75	49.64	50.15	49.50
6	47.86	47.81	50.44	50.17	50.34	49.25	50.25	49.20
7	48.01	47.82	50.41	49.13	50.14	49.14	50.50	49.50
8	48.50	47.87	49.67	49.59	50.32	49.64	49.85	49.40
9	48.53	47.88	50.72	49.75	50.26	49.50	50.50	49.55
10	47.86	47.86	50.25	49.77	49.95	49.15	50.25	49.40
11	50.01	47.86	50.86	48.65	50.50	49.85	50.20	49.55
12	47.96	47.83	50.77	48.69	50.21	49.60	50.32	49.50
13	47.90	47.80	49.05	48.61	50.25	49.75	50.20	49.45
14	47.90	47.81	49.06	48.88	50.70	49.65	50.15	49.50
15	47.99	47.78	49.40	49.31	50.42	49.12	50.20	49.65
16	48.24	47.95	49.09	48.84	50.35	49.32	50.10	49.75
17	49.70	48.10	49.87	49.37	50.24	49.30	50.25	49.34
18	49.76	47.77	49.95	49.42	50.18	49.22	49.85	49.42
19	47.88	47.84	49.54	49.38	50.15	48.65	50.00	49.50
20	47.90	47.87	49.36	49.16	50.23	49.43	49.85	49.42
21	47.88	47.86	49.83	48.95	50.56	49.50	49.95	49.25
22	47.86	47.83	49.25	49.16	50.10	49.26	50.12	49.32
23	47.84	47.84	49.71	49.35	50.35	49.15	50.15	49.52
24	48.02	47.95	49.15	48.95	49.82	49.32	50.12	49.62
25	47.96	47.77	49.97	49.79	50.28	49.45	49.85	49.42
26			49.42	48.90	50.50	49.48	50.05	49.52
27	48.82	47.89	49.35	49.07	50.25	49.50	50.20	49.30
28	50.00	47.90	49.39	49.09	50.22	49.45	50.15	49.35
29	48.85	48.16	49.54	49.25	49.85	49.00	50.05	49.40
30	48.55	47.86	49.62	49.33	49.80	49.10	50.25	49.60
31	49.05	47.88	-	-	49.78	49.21	-	-
Max.	50.01	48.16	50.86	50.17	50.75	49.85	50.90	50.17
Min.	47.78	47.75	49.05	48.58	49.78	48.65	49.10	48.58
Ave.	48.34	47.87	49.84	49.26	50.28	49.38	49.84	49.26
SD	0.680	0.080	0.560	0.420	0.256	0.255	0.560	0.420
%Max	49.69	48.03	50.95	50.51	50.78	49.88	51.00	50.50
%Min	47.00	47.70	48.74	48.45	49.77	48.88	48.70	48.50

Source : LDC, APTRANSCO

Note: SD stands for Standard Deviation

Annex 3.4 Records of Voltage Measurement at the End-customers of Model Feeders

Annex 3.4 Records of Voltage Measurement at the End-customers of Model Feeders

Low Voltage Distribution

Nov. 2003

33/11 kV Kothapet Substation
11 kV Kamalanagar feeder

Transformer TN14 (315 kVA)

Customer : Mr. Vijetra Shelters
(#1)

(Volt)

Day	Off peak (3 o'clock)									Day peak (11 o'clock)									Night peak (20 o'clock)								
	Transformer			Customer			Transformer			Customer			Transformer			Customer			Transformer			Customer					
	A	B	C	A	B	C	A	B	C	A	B	C	A	B	C	A	B	C	A	B	C	A	B	C			
1	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
2	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
3	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
4	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
5	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
6	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
7	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
8	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
9	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
10	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
11	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
12	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
13	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
14	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
15	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
16	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
17	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
18	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
19	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
20	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
21	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
22	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
23	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
24	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
25	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
26	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
27	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
28	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
29	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
30	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
31																											
Max.	240	240	240	235	235	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
Min.	240	240	240	235	233	235	235	236	235	228	228	227	230	230	230	220	220	220	230	230	230	220	220	220			
Ave.	240.0	240.0	240.0	235.0	233.1	235.0	235.0	236.0	235.0	228.0	228.0	227.0	230.0	230.0	230.0	220.0	220.0	220.0	230.0	230.0	230.0	220.0	220.0	220.0			
SD	0.0002	0.0002	0.0002	0.0002	0.3653	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002			
%Max	240.0	240.0	240.0	235.0	233.8	235.0	235.0	236.0	235.0	228.0	228.0	227.0	230.0	230.0	230.0	220.0	220.0	220.0	230.0	230.0	230.0	220.0	220.0	220.0			
%Min	240.0	240.0	240.0	235.0	232.4	235.0	235.0	236.0	235.0	228.0	228.0	227.0	230.0	230.0	230.0	220.0	220.0	220.0	230.0	230.0	230.0	220.0	220.0	220.0			

(Note) SD: Standard deviation

Annex 3.4 Records of Voltage Measurement at the End-customers of Model Feeders

Low Voltage Distribution
Nov. 2003
33/11 kV Kothapet Substation
11 kV Kamalanagar feeder
Transformer TN11 (250 kVA)
Customer : Sanscript College
(#2)

(Volt)

Day	Off peak (3 o'clock)									Day peak (11 o'clock)									Night peak (20 o'clock)								
	Transformer			Customer			Transformer			Customer			Transformer			Customer			Transformer			Customer					
	A	B	C	A	B	C	A	B	C	A	B	C	A	B	C	A	B	C	A	B	C	A	B	C			
1	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
2	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
3	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
4	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
5	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
6	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
7	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
8	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
9	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
10	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
11	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
12	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
13	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
14	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
15	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
16	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
17	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
18	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
19	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
20	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
21	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
22	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
23	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
24	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
25	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
26	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
27	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
28	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
29	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
30	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
31																											
Max.	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
Min.	238	238	239	234	233	234	235	234	235	230	229	230	230	230	229	219	220	220	230	230	229	219	220	220			
Ave.	238.0	238.0	239.0	234.0	233.0	234.0	235.0	234.0	235.0	230.0	229.0	230.0	230.0	230.0	229.0	219.0	220.0	220.0	230.0	230.0	229.0	219.0	220.0	220.0			
SD	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002			
%Max	238.0	238.0	239.0	234.0	233.0	234.0	235.0	234.0	235.0	230.0	229.0	230.0	230.0	230.0	229.0	219.0	220.0	220.0	230.0	230.0	229.0	219.0	220.0	220.0			
%Min	238.0	238.0	239.0	234.0	233.0	234.0	235.0	234.0	235.0	230.0	229.0	230.0	230.0	230.0	229.0	219.0	220.0	220.0	230.0	230.0	229.0	219.0	220.0	220.0			

Note) SD: Standard deviation

Annex 3.4 Records of Voltage Measurement at the End-customers of Model Feeders

Low Voltage Distribution
Nov. 2003
33/11 kV Kothapet Substation
11 kV Kamalanagar feeder
Transformer TN23 (315 kVA)
Customer : Mr. K. Ramulu
(#3)

Day	Off peak (3 o'clock)									Day peak (11 o'clock)									Night peak (20 o'clock)								
	Transformer			Customer			Transformer			Customer			Transformer			Customer			Transformer			Customer					
	A	B	C	A	B	C	A	B	C	A	B	C	A	B	C	A	B	C	A	B	C	A	B	C			
1	240	239	240	230	230	230	240	233	235	235	220	220	220	230	232	230	218	220	218								
2	240	241	240	230	230	230	240	230	233	230	220	220	220	230	232	230	218	220	218								
3	240	241	240	230	228	228	235	233	235	235	220	220	220	230	232	230	218	220	218								
4	241	240	240	230	229	228	234	230	233	230	220	220	220	228	229	228	218	220	218								
5	241	240	240	228	229	229	234	230	233	230	220	220	220	228	229	228	218	220	218								
6	240	240	240	230	230	230	235	233	235	230	220	220	220	228	229	228	218	220	218								
7	240	240	240	230	230	230	230	230	231	220	220	220	220	230	232	230	220	222	220								
8	240	240	240	230	230	230	233	232	230	220	220	220	220	230	232	230	220	222	220								
9	240	240	240	230	230	230	234	230	233	220	220	220	220	230	232	230	220	222	220								
10	240	240	240	230	230	230	234	230	233	220	220	220	220	230	232	230	220	222	220								
11	240	240	240	230	230	230	234	230	233	220	220	220	220	230	232	230	220	222	220								
12	240	240	240	230	230	230	234	230	233	220	220	220	220	230	232	230	220	222	220								
13	238	238	238	230	230	230	230	230	229	220	220	220	220	230	232	230	220	222	220								
14	240	240	240	228	230	230	230	230	229	220	220	220	220	230	232	230	220	222	220								
15	240	240	240	230	230	230	233	232	230	220	220	220	220	230	232	230	220	222	220								
16	240	240	240	230	230	230	233	232	230	220	220	220	220	230	232	230	220	222	220								
17	240	240	239	230	230	228	230	230	229	220	220	220	220	230	232	230	220	222	220								
18	240	240	240	230	230	230	230	230	229	220	220	220	220	230	232	230	220	222	220								
19	240	241	241	230	230	230	235	233	235	220	220	220	220	230	232	230	220	222	220								
20	240	240	240	230	230	230	235	233	235	220	220	220	220	230	232	230	220	222	220								
21	240	240	240	230	230	230	234	230	233	219	220	220	220	230	232	230	220	222	220								
22	240	240	240	230	230	230	234	230	233	220	220	220	220	230	232	230	220	222	220								
23	240	240	240	230	230	230	234	230	233	220	220	220	220	230	232	230	220	222	220								
24	241	241	242	230	230	230	234	230	233	220	220	220	220	230	232	230	220	222	220								
25	241	241	241	230	230	230	234	230	233	220	220	220	220	230	232	230	220	222	220								
26	240	240	240	230	230	230	234	230	233	220	220	220	220	230	232	230	220	222	220								
27	240	240	240	230	230	230	234	230	233	220	220	220	220	230	232	230	220	222	220								
28	240	240	240	230	230	230	234	230	233	220	220	220	220	230	232	230	220	222	220								
29	240	240	240	230	230	230	234	230	233	220	220	220	220	230	232	230	220	222	220								
30	240	240	240	230	230	230	234	230	233	220	220	220	220	230	232	230	220	222	220								
31	240	240	240	230	230	230	234	230	233	220	220	220	220	230	232	230	220	222	220								
Max.	241	241	242	231	230	230	240	233	235	220	220	220	220	230	232	230	220	224	220								
Min.	238	238	238	228	228	228	230	230	229	219	220	220	220	228	229	228	218	220	218								
Ave.	240.1	240.1	240.0	229.9	229.8	229.8	233.7	230.8	232.3	219.9	220.0	220.0	229.8	231.6	229.8	219.6	221.7	219.6									
SD	0.521	0.5833	0.615	0.548	0.551	0.531	2.333	1.223	1.953	0.254	2E-04	2E-04	0.61	0.964	0.61	0.814	0.922	0.814									
%Max	241.1	241.2	241.2	231.0	230.9	230.9	238.3	233.2	236.2	220.4	220.0	220.0	231.0	233.5	231.0	221.2	223.5	221.2									
%Min	239.0	238.9	238.8	228.8	228.7	228.8	229.2	228.4	228.5	219.4	220.0	220.0	228.6	229.7	228.6	218.0	219.9	218.0									

Note) SD: Standard deviation

Annex 3.4 Records of Voltage Measurement at the End-customers of Model Feeders

Low Voltage Distribution
Nov. 2003
11kV Kattedan #2 Line
Customer #6 (3 phase)
Chocolate Factory
Customer #8(3 phase)
Jaya & Company

Day	Off peak (3 o'clock)									Day peak (11 o'clock)									Night peak (20 o'clock)								
	Customer #6			Customer #8			Customer #6			Customer #8			Customer #6			Customer #8			Customer #6			Customer #8					
	A	B	C	A	B	C	A	B	C	A	B	C	A	B	C	A	B	C	A	B	C	A	B	C			
1	265	266	265	265	264	267	249	250	250	248	249	250	246	247	247	246	247	247	247	246	247	248	248				
2	265	266	265	265	264	267	249	250	249	249	249	249	249	249	249	249	249	249	249	249	249	248	248				
3	263	267	265	265	265	268	249	250	249	249	249	249	249	249	249	249	249	249	249	249	248	248	248				
4	263	267	265	263	265	268	250	250	249	250	249	250	248	248	247	246	248	248	248	246	248	248	249				
5	263	268	266	263	265	268	250	250	250	250	249	250	248	248	247	246	248	248	248	246	248	248	249				
6	263	268	266	263	266	267	250	250	250	250	249	250	248	248	247	246	248	248	248	246	248	249	250				
7	265	268	266	264	266	267	249	251	249	251	249	250	248	248	247	246	248	248	248	246	248	249	250				
8	265	266	267	264	265	267	249	251	250	251	249	250	248	248	247	246	248	248	248	246	249	249	250				
9	265	266	266	264	265	266	249	251	250	251	249	250	248	248	247	246	248	248	248	246	249	249	250				
10	263	266	266	265	266	266	250	251	250	251	249	250	248	248	247	246	248	248	248	246	248	249	249				
11	263	265	265	265	266	265	250	250	250	250	249	249	250	247	247	246	248	248	248	246	248	249	249				
12	264	265	265	265	265	264	250	250	249	248	250	249	248	248	247	246	248	248	248	246	249	249	250				
13	264	266	266	265	265	264	250	250	249	248	250	249	248	248	247	246	248	248	248	246	249	249	250				
14	265	266	265	266	266	264	249	250	249	248	250	249	248	248	247	246	248	248	248	246	249	249	250				
15	265	265	265	266	266	265	249	250	249	249	250	249	248	248	247	246	248	248	248	246	249	249	250				
16	265	265	266	265	265	265	249	250	249	249	250	249	248	248	247	246	248	248	248	246	249	249	250				
17	266	264	266	265	265	264	249	250	250	249	250	249	248	248	247	246	248	248	248	246	249	249	251				
18	266	263	264	265	265	265	249	250	250	249	250	249	248	248	247	246	248	248	248	246	249	249	251				
19	266	263	264	264	265	264	250	249	250	250	250	249	248	248	247	246	248	248	248	246	249	249	250				
20	265	263	263	264	264	264	250	249	251	250	250	251	248	248	247	246	248	248	248	246	249	249	250				
21	265	262	263	264	264	264	250	249	251	250	250	251	248	248	247	246	248	248	248	246	249	249	250				
22	265	263	263	263	264	265	249	251	251	251	250	249	248	248	247	246	248	248	248	246	249	249	251				
23	265	264	262	263	263	264	249	251	251	251	250	249	248	248	247	246	248	248	248	246	249	249	251				
24	266	265	262	263	263	263	250	251	251	251	250	249	248	248	247	246	248	248	248	246	249	249	250				
25	266	262	262	263	263	263	249	249	249	250	249	249	248	248	247	246	248	248	248	246	249	249	250				
26	266	263	262	264	263	263	249	250	249	250	249	249	248	248	247	246	248	248	248	246	249	249	250				
27	267	263	262	263	263	263	248	250	249	250	249	249	248	248	247	246	248	248	248	246	249	249	250				
28	267	265	266	263	263	263	248	248	248	248	249	249	248	248	247	246	248	248	248	246	249	249	250				
29	267	265	265	263	263	263	248	248	249	250	249	249	248	248	247	246	248	248	248	246	249	249	250				
30	267	265	265	264	263	263	248	248	249	250	250	249	248	248	247	246	248	248	248	246	249	249	250				
31																											
Max.	267	268	267	266	266	268	250	251	251	251	250	251	250	251	255	255	255	255	255	255	255	256	255				
Min.	263	262	262	263	263	263	248	248	248	248	248	249	249	249	246	246	245	247	247	245	247	245	248				
Ave.	265.0	265.0	264.6	264.1	264.5	265.0	249.3	249.9	249.6	249.6	249.4	250.0	249.0	249.0	249.0	247.9	247.0	248.7	249.4	249.4	249.9	249.9	249.9				
SD	1.287	1.722	1.564	0.973	1.106	1.712	0.691	0.8847	0.814	0.89	0.498	0.695	1.93	1.999	2.414	1.863	1.942	1.668	1.668	1.668	1.668	1.668	1.668				
%Max	267.5	268.4	267.7	266.0	266.7	268.3	250.6	251.6	251.2	251.4	250.4	251.4	252.8	251.9	251.8	252.3	253.2	253.2	253.2	253.2	253.2	253.2	253.2				
%Min	262.5	261.6	261.6	262.2	262.3	261.6	247.9	248.2	248.0	247.9	248.4	248.6	245.2	244.0	242.3	245.0	245.6	245.6	245.6	245.6	245.6	245.6	245.6				

(Note) SD: Standard deviation

Annex 3.4 Records of Voltage Measurement at the End-customers of Model Feeders

Meter Serial No.: APE13611

Measuring Item:

Transformer Sub Station:

Place of Measuring: Malkapur Sub Station, Malkapur Feeder

Measuring item: Voltage (V)

(Note) shows data adopted cells.

-1.0 indicates ALL POTENTIALS MISSING

DATE	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00
2003/5/9	190.9	190.9	193.2	186.3	184	179.4	-1	-1	-1	-1	257.6	246.1	243.8	246.1	246.1	-1	-1	255.3	253	195.5	195.5	190.9	193.2	197.8
2003/6/9	195.5	197.8	193.2	188.6	188.6	184	-1	-1	-1	-1	246.1	246.1	232.3	239.2	243.8	248.4	248.4	248.4	184	188.6	188.6	190.9	188.6	190.9
2003/7/9	190.9	190.9	190.9	248.4	248.4	257.6	248.4	248.4	250.7	239.2	239.2	-1	-1	-1	-1	-1	-1	-1	197.8	190.9	190.9	190.9	193.2	193.2
2003/8/9	193.2	193.2	193.2	250.7	250.7	246.1	253.3	250.7	243.8	230	-1	-1	-1	-1	-1	-1	-1	-1	-1	190.9	190.9	188.6	190.9	193.2
2003/9/9	193.2	193.2	190.9	243.8	241.5	236.9	239.2	241.5	234.6	220.8	-1	-1	-1	-1	-1	-1	-1	-1	186.3	188.6	188.6	190.9	193.2	193.2
2003/10/9	190.9	188.6	188.6	184	243.8	239.2	248.4	239.2	225.4	220.8	179.4	174.8	-1	-1	-1	-1	-1	-1	184	188.6	188.6	190.9	193.2	193.2
2003/11/9	190.9	190.9	188.6	250.7	243.8	234.6	243.8	241.5	225.4	220.8	-1	-1	-1	-1	-1	-1	-1	-1	186.3	186.3	188.6	190.9	193.2	188.6
2003/12/9	190.9	190.9	190.9	241.5	239.2	230	239.2	239.2	255.3	234.6	243.8	-1	-1	-1	-1	-1	-1	-1	184	186.3	188.6	190.9	190.9	193.2
13/09/2003	190.9	190.9	188.6	250.7	253	248.4	243.8	243.8	230	223.1	232.3	-1	-1	-1	-1	-1	-1	-1	248.4	184	186.3	188.6	190.9	193.2
14/09/2003	193.2	193.2	193.2	186.3	186.3	184	-1	-1	-1	-1	255.3	232.3	234.6	243.8	241.5	239.2	243.8	248.4	184	190.9	190.9	188.6	190.9	190.9
15/09/2003	190.9	190.9	188.6	181.7	181.7	177.1	-1	-1	-1	-1	241.5	225.4	236.9	239.2	234.6	236.9	241.5	241.5	184	188.6	188.6	190.9	190.9	193.2
16/09/2003	193.2	190.9	190.9	186.3	184	-1	-1	-1	-1	-1	234.6	227.7	227.7	241.5	234.6	234.6	239.2	243.8	181.7	188.6	186.3	188.6	188.6	188.6
17/09/2003	190.9	188.6	188.6	181.7	179.4	-1	-1	-1	-1	-1	239.2	223.1	220.8	234.6	234.6	236.9	243.8	250.7	188.6	188.6	186.3	188.6	188.6	190.9
18/09/2003	190.9	180.9	188.6	184	181.7	-1	-1	-1	-1	-1	234.6	232.3	232.3	241.5	241.5	243.8	246.1	248.4	184	186.3	186.3	188.6	188.6	190.9
19/09/2003	188.6	193.2	197.8	188.6	-1	156.4	-1	-1	-1	-1	234.6	241.5	239.2	246.1	246.1	248.4	253	250.7	190.9	195.2	197.8	200.1	190.9	193.2
20/09/2003	190.9	195.5	202.4	190.9	193.2	188.6	-1	-1	-1	-1	248.4	236.9	234.6	241.5	234.6	236.9	241.5	246.1	188.6	190.9	195.5	195.5	195.5	197.8
21/09/2003	200.1	195.5	246.1	250.7	250.7	250.7	253	246.1	248.4	253	259.9	-1	-1	-1	-1	-1	-1	-1	193.2	197.8	197.8	193.2	197.8	197.8
22/09/2003	197.8	202.4	202.4	255.3	257.6	257.6	259.9	266.8	273.7	271.4	246.1	-1	-1	-1	-1	-1	-1	-1	190.9	184	193.2	190.9	193.2	197.8
23/09/2003	197.8	195.5	195.5	269.1	271.4	262.2	262.2	259.9	262.2	253	259.9	-1	-1	-1	-1	-1	-1	-1	193.2	193.2	190.9	193.2	193.2	190.9
24/09/2003	190.9	190.9	190.9	266.8	271.4	264.5	259.9	255.3	239.2	236.9	241.5	-1	-1	-1	-1	-1	-1	-1	181.7	193.2	195.5	195.5	197.8	200.1
25/09/2003	193.2	200.1	195.5	248.4	248.4	250.7	253	255.3	246.1	241.5	246.1	-1	-1	-1	-1	-1	-1	-1	184	188.6	195.5	195.5	195.5	195.5
26/09/2003	193.2	193.2	193.2	257.6	262.2	259.9	259.9	259.9	259.9	253	236.9	-1	-1	-1	-1	-1	-1	-1	190.9	186.3	186.3	190.9	193.2	188.6
27/09/2003	190.9	193.2	190.9	271.4	273.7	271.4	271.4	271.4	264.5	241.5	236.9	-1	-1	-1	-1	-1	-1	-1	184	186.3	188.6	188.6	190.9	188.6
28/09/2003	186.3	188.6	188.6	186.3	184	184	-1	-1	-1	-1	255.3	253	248.4	248.4	246.1	248.4	255.3	264.5	193.2	188.6	188.6	190.9	193.2	193.2
29/09/2003	193.2	190.9	190.9	184	184	181.7	-1	-1	-1	-1	243.8	243.8	239.2	241.5	248.4	243.8	253	257.6	188.6	190.9	188.6	186.3	193.2	193.2
30/09/2003	190.9	188.6	186.3	181.7	181.7	179.4	-1	-1	-1	-1	262.2	246.1	248.4	246.1	230	253	250.7	253	188.6	262.2	218.5	190.9	190.9	190.9
2003/1/10	188.6	188.6	186.3	181.7	179.4	174.8	-1	-1	-1	-1	239.2	220.8	234.6	234.6	232.3	232.3	-1	-1	255.3	257.6	184	188.6	184	190.9
2003/2/10	190.9	188.6	188.6	179.4	181.7	181.7	-1	-1	-1	-1	241.5	225.4	223.1	236.9	234.6	230	239.2	241.5	188.6	188.6	188.6	190.9	193.2	197.8
2003/3/10	195.5	193.2	193.2	188.6	184	179.4	-1	-1	-1	-1	236.9	239.2	241.5	243.8	243.8	248.4	255.3	257.6	179.4	186.3	186.3	188.6	190.9	193.2
2003/4/10	190.9	193.2	190.9	186.3	184	181.7	-1	-1	-1	-1	246.1	239.2	243.8	239.2	243.8	243.8	246.1	-1	181.7	184	186.3	188.6	188.6	190.9
									6	10	3	10	7	1	1	38								

Load survey data from 05-09-03 to 04-10-03 30 days

Annex 3.5 Summary of Outage Records Collected

Annex 3.5 Summary of Outage Records Collected

Summary of Outage Records Collected for 2002/03 (1/4)

132 kV System (Mother substation)	33 kV feeder	33 kV substation	11 kV feeder	Cause recorded		Number of outages			Duration of outages (Min)			Remarks		
				Cause	Equipment	33 kV	11 kV	Total	33 kV	11 kV	Total			
1 HKOT (Kothur)		AME	AME	x			14	14		3,158	3,158			
			COL	x			30	30		4,645	4,645			
			DUB	x			21	21		6,330	6,330			
2 HRAM		SHA	DHO	x			25	25		3,135	3,135			
			KON	x			15	15		1,720	1,720			
			PAR	x			48	48		4,176	4,176			
			SHA	x			40	40		2,305	2,305			
3 MRAM (R.ama Chandrapuram)		GAR	VAN	x			50	50		-	-			
			SHA	DHO	x			25	25		3,135	3,135		
		SJB	KON	x			15	15		1,720	1,720			
			PAR	x			48	48		4,176	4,176			
			SHA	x			40	40		2,305	2,305			
			IND	x			2	2		295	295			
			MOK	x			130	130		12,816	12,816			
		SHAM	HAB	x			45	45		3,582	3,582			
			NAR	x			48	48		4,792	4,792			
			OMJ	x			25	25		2,082	2,082			
			SHA	x			69	69		4,633	4,633			
4 MSAD (Sadasivpet)	VKB	MAR	KAL	x		77	24	77	2,292	5,755	2,292			
			MAR	x			17	17		1,403	1,403			
			PAT	x			43	43		6,468	6,468			
		MOM	SRI	x			21	21		4,254	4,254			
			BAR	x			59	59		7,123	7,123			
			ENK	x			127	127		17,296	17,296			
			MOM	x			10	10		676	676			
			MPT	x			11	11		675	675			
			MRP	x			1	1		45	45			
		NAW	MVP	x			125	125		13,435	13,435			
			ARK	x			174	174		5,453	5,453			
			NAW	x			13	13		490	490			
			PUL	x			283	283		10,588	10,588			
			5 MKAN (Kandi)	MAL	MAL	x		444	524	968	51,854	101,618	153,472	
					MUN	x			675	675		103,335	103,335	
TWN	x					157	157		22,190	22,190				
KON	KOT	x			150	150		29,710	29,710					
	KON	x		279	356	635	47,240	5,767	53,007					
	TER	x			261	261		63,918	63,918					
	MAR	x			477	477		0	0					
6 MNAR (Narayankhed)		BOR	BPR	x		679	154	833	70,462	4,135	74,597			
			DHA	x			213	213		0	0			
			NAP	x			191	191		2,731	2,731			
		POO	MAN	x		599	518	1,117	68,575	33,829	102,404			
			SHA	x			373	373		33,168	33,168			
			GUD	x			21	21		3,239	3,239			
		KAL	MAR	x		422	368	790	52,640	89,540	142,180			
			KAL	x		422	348	770	52,640	88,895	141,535			
			KAN	x		422	360	782	52,640	88,466	141,106			
		7 MSAD (Sadasivepet)		JOG	KOH	x		169	169	169	16,797		16,797	
					MRT	x		156	156	156	15,779		15,779	
PSML	x					22	22	22	2,825		2,825			
MAN	x					24	24	24	1,220		1,220			
MUN	x					87	87	87	4,315		4,315			
MUN	x					119	119	119	9,173		9,173			
VIK	x					167	167	167	13,071		13,071			
SAD	SAD			x		72	395	467	4,739	26,987	31,726			
	BUD			x		63	169	232	4,876	5,690	10,566			
	TSM			x		63	192	255	4,876	6,849	11,725			
	MAN			x		71	789	860	5,068	119,433	124,501			
JOG	NIZ			x		113	156	269	11,840	5,245	17,085			
	VEN			x		143	197	340	16,740	12,295	29,035			
MUN	MUN			x		220	261	481	17,504	2,253	19,757			
	CHA			x		190	147	337	22,433	5,248	27,681			
8 RBAN (Bandlaguda)	F(VAN)	ABD	YEL	x		144	194	338	14,956	6,101	21,057			
			ABD	x	x	81		81	3,747		3,747			
			ANA	x	x		122	122		5,730	5,730			
			SAB	x	x		42	42		2,920	2,920			
			SAN	x	x		1	1		950	950			
						47	47		3,400	3,400				

Annex 3.5 Summary of Outage Records Collected

Summary of Outage Records Collected for 2002/03 (2/4)

132 kV System (Mother substation)	33 kV feeder	33 kV substation	11 kV feeder	Cause recorded		Number of outages			Duration of outages (Min)			Remarks
				Cause	Equipment	33 kV	11 kV	Total	33 kV	11 kV	Total	
		PED	PED	x	x		57	57		2,084	2,084	
		TAR	TAR	x	x		33	33		1,108	1,108	
		RFC	RFC	x	x		51	51		710	710	
		VAN	BAL	x	x		19	19		1,080	1,080	
			INJ	x	x		31	31		1,835	1,835	
			NGO	x	x		7	7		265	265	
			VAN	x	x		42	42		2,110	2,110	
		BAN	ALK	x	x		55	55		661	661	
			GSI	x	x		36	36		226	226	
			NAG	x	x		106	106		1,798	1,798	
		HAY	AIR	x	x		24	24		203	203	
			AUT	x	x		38	38		382	382	
			HAY	x	x		26	26		148	148	
			HCO	x	x		12	12		228	228	
			LBN	x	x		33	33		453	453	
			MAN	x	x		29	29		459	459	
			MOT	x	x		51	51		468	468	
			SIR	x	x		34	34		719	719	
		KOT	KAM	x	x		91	91		4,090	4,090	
			KOT	x	x		162	162		6,310	6,310	
			LNR	x	x		39	39		1,995	1,995	
			MAN	x	x		7	7		245	245	
			NOD	x	x		48	48		1,070	1,070	
			SAM	x	x		155	155		5,061	5,061	
9	RCHA (Chandrayanagutta)	33 F(KAT)		x			57	57	4,684	4,684		Bus 1, TR 2 are included
		CHA	ALK & othe	x			3	3		18	18	
			BAL	x			297	297		5,185	5,185	
			CHA	x			76	76		863	863	
			KAR	x			179	179		2,554	2,554	
			LBV-I	x			1	1		2	2	
			LV-I	x			21	21		134	134	
			LV-II	x			1	1		5	5	
			MEE	x			251	251		2,606	2,606	
			SLU	x			35	35		386	386	
		KAT	KT1	x			109	109		2,456	2,456	
			KT2	x			87	87		2,547	2,547	
			KT3	x			95	95		2,319	2,319	
			KT4	x			101	101		2,553	2,553	
			BAL	x			132	132		4,151	4,151	
		MAH	GHA	x			23	23		2,583	2,583	
			LEM	x			25	25		2,115	2,115	
			MAH	x			2	2		270	270	
			NAG	x			18	18		2,007	2,007	
			TIM	x			20	20		2,480	2,480	
		MAN	IDA	x			175	175		4,895	4,895	
			MAN	x			132	132		5,579	5,579	
		SHAM	HAB	x			45	45		5,582	5,582	
			NAR	x			48	48		4,192	4,192	
			OMJ	x			25	25		2,082	2,082	
			SHA	x			69	69		4,673	4,673	
		SHP	GAN	x			4	4		215	215	
			IND	x			5	5		468	468	
			PAL	x			6	6		800	800	
			SHA	x			7	7		2,155	2,155	
10	RDHA (Dharmasagar)	CHE		x			87	87	764		764	
		PAR		x			134	134	1,524		1,524	
		PRA		x			13	13	682		682	
		SHA		x			63	63	2,804		2,804	
		CHE	ALU	x			70	70		11,913	11,913	
			CHE	x			7	7		715	715	
			GUD	x			10	10		2,025	2,025	
			GUN	x			9	9		2,290	2,290	
			KOT	x			24	24		4,400	4,400	
			MUD	x			61	61		6,130	6,130	
			SHE	x			1	1		210	210	
			STA	x			4	4		300	300	
			(Bus)	x			1	1		120	120	
		MAN	MER	x			37	37		3,239	3,239	
			OHN	x			63	63		9,342	9,342	
			PUD	x			55	55		8,049	8,049	

Annex 3.5 Summary of Outage Records Collected

Summary of Outage Records Collected for 2002/03 (3/4)

132 kV System (Mother substation)	33 kV feeder	33 kV substation	11 kV feeder	Cause recorded		Number of outages			Duration of outages (Min)			Remarks		
				Cause	Equipment	33 kV	11 kV	Total	33 kV	11 kV	Total			
		MOI	SUP	x			68	68		2,652	2,652			
			HIM	x			264	264		35,243	35,243			
		KAN	KAN	x			250	250		34,233	34,233			
			MOI	x			33	33		3,191	3,191			
			PED	x			250	250		33,300	33,300			
			SPS	x			70	70		6,110	6,110			
			SUR	x			268	268		35,168	35,168			
			PAR	GAN	x			31	31		1,434	1,434		
		PAR	PAR	x			21	21		261	261			
			ROO	x			17	17		431	431			
			RAK	x			20	20		764	764			
			SHA	x			31	31		942	942			
		SHA	NAG	x			24	24		8,945	8,945			
			POL	x			9	9		3,575	3,575			
			SAR	x			16	16		3,955	3,955			
		TAL	RAO	x			19	19		284	284			
			RDO	x			23	23		399	399			
			RUD	x			31	31		574	574			
			TAL	x			42	42		568	568			
		11 RIBR (Ibrahimpatnam)		BOD	BOD	x	x		158	158		2,048	2,048	
					YEL	x	x		158	158		1,818	1,818	
				DAN	DAN	x	x		116	116		1,809	1,809	
					MUK	x	x		75	75		1,137	1,137	
					NER	x	x		133	133		1,624	1,624	
IBR	ELM			x	x		57	57		1,028	1,028			
	IBA			x	x		134	134		2,448	2,448			
	RAP			x	x		135	135		1,935	1,935			
	SHE			x	x		90	90		2,172	2,172			
KAN	BAC			x	x		106	106		1,159	1,159			
	GUD			x	x		60	60		868	868			
	KAN			x	x		69	69		814	814			
	MUC			x	x		90	90		1,611	1,611			
	NED			x	x		221	221		3,139	3,139			
MAL	PUL			x	x		64	64		1,005	1,005			
	KOT			x	x		156	156		2,762	2,762			
	MAL			x	x		95	95		1,497	1,497			
MAN	NAL			x	x		123	123		2,092	2,092			
	ARU			x	x		69	69		1,091	1,091			
	JAP			x	x		86	86		1,569	1,569			
	MOM			x	x		65	65		1,566	1,566			
	MOM			x	x		111	111		1,380	1,380			
	TAL			x	x		142	142		1,990	1,990			
	RAC			BAC	x	x		206	206		474	474		
RAC	GUD			x	x		54	54		921	921			
	GUN			x	x		170	170		3,106	3,106			
	LEM			x	x		167	167		2,258	2,258			
	RAC			x	x		155	155		1,850	1,850			
	THI			x	x		133	133		2,190	2,190			
	TUR			MAN	x	x		126	126		1,774	1,774		
YAC	TUR			x	x		151	151		2,621	2,621			
	CHI			x	x		91	91		1,452	1,452			
	CHO			x	x		123	123		1,861	1,861			
	CHU			x	x		26	26		395	395			
	GUN			x	x		173	173		2,583	2,583			
	MED			x	x		163	163		1,969	1,969			
	NAN			x	x		98	98		1,451	1,451			
	YAC			x	x		63	63		1,144	1,144			
12 (ROTH) ???				LNPOOR	BAN	x			215	215		6,267	6,267	
					CHR	x			268	268		10,801	10,801	
					LAX	x			176	176		1,609	1,609	
13 RPUT (Puttapahad)	CHW DOM PUT SAL			x			29	29		684	684			
				x			99	99		4,344	4,344			
				x			34	34		1,550	1,550			
				x			139	139		4,743	4,743			
	DMA	BSP DMA PLP	BSP	x			39	39		279	279			
			DMA	x			42	42		716	716			
			PLP	x			41	41		353	353			
			BRP	x			54	54		1,128	1,128			
			DSP	x			25	25		310	310			
			MLP	x			32	32		433	433			

Annex 3.5 Summary of Outage Records Collected

Summary of Outage Records Collected for 2002/03 (4/4)

132 kV System (Mother substation)	33 kV feeder	33 kV substation	11 kV feeder	Cause recorded		Number of outages			Duration of outages (Min)			Remarks
				Cause	Equipment	33 kV	11 kV	Total	33 kV	11 kV	Total	
		PUT	KUL	x			7	7		408	408	
			MAN	x			8	8		960	960	
			PUT	x			6	6		875	875	
			RUS	x			6	6		1,290	1,290	
		SKP	GAN	x			31	31		252	252	
			PGDL	x			42	42		659	659	
			SKP	x			39	39		977	977	
14 RSHI (Shivarampally)		APP	AZI	x			148	148		10,977	10,977	
			HIM	x			60	60		3,665	3,665	
			POL	x			1	1		30	30	
		GAG	GAG	x			31	31		150	150	
			JAI	x			35	35		1,033	1,033	
			MAN	x			29	29		636	636	
			NPA	x			17	17		419	419	
			RAJ	x			46	46		565	565	
			SHI	x			18	18		276	276	
		IBR	MI1	x			116	116		5,955	5,955	
			MI2	x			16	16		901	901	
			OSM	x			96	96		4,124	4,124	
			PED	x			77	77		2,236	2,236	
		NPA	KTD	x			109	109		2,456	2,456	
	SHA		x			47	47		-	-		
	SIV		x			102	102		2,429	2,429		
	UPP		x			132	132		4,151	4,151		
15 RTAN (Tandur)	BAS			x		206		206	8,822		8,822	
		KAR		x		107		107	6,137		6,137	
		TDR		x		1		1	10		10	
		TUR		x		101		101	3,084		3,084	
		VIK		x		58		58	3,850		3,850	
		BAS	AGN	x			114	114		8,005	8,005	
			BAS	x			74	74		2,758	2,758	
			NLP	x			127	127		14,051	14,051	
		DHA	DHA	x			7	7		58	58	
			GUT	x			77	77		15,863	15,863	
			KUK	x			63	63		14,531	14,531	
		KAR	KAR	x			68	68		4,111	4,111	
			MTK	x			70	70		7,381	7,381	
			OGI	x			101	101		7,840	7,840	
		PED	JAN	x			32	32		2,894	2,894	
			KAN	x			20	20		3,357	3,357	
			KOT	x			85	85		8,828	8,828	
			PED	x			6	6		430	430	
		TUR	BEN	x			12	12		1,865	1,865	
			TAT	x			48	48		6,700	6,700	
			TUR	x			1	1		50	50	
		VIK	ANA	x			52	52		4,451	4,451	
			EKA	x			103	103		7,761	7,761	
			SKA	x			178	178		11,899	11,899	
			VIK	x			165	165		6,034	6,034	
			BAM	x			1	1		110	110	
			BEN	x			151	151		9,797	9,797	
			DEN	x			217	217		30,970	30,970	
			SAN	x			100	100		11,155	11,155	
			VAL	x			2	2		15	15	
	YAL		x			133	133		8,709	8,709		
	YAL + ****		x			98	98		1,155	1,155		
		x			1	1		5	5			
TTL	16	61	244			6,376	23,522	29,898	611,984	1,760,718	2,372,702	

Chapter 4 SCADA System

Contents

Chapter 4 SCADA System.....	4 - 1
4.1 General.....	4 - 1
4.1.1 Assessment of the Existing SCADA System	4 - 1
4.1.2 Study of Distribution SCADA Introduction.....	4 - 2
4.1.3 Proposition of Distribution SCADA System	4 - 3
4.2 Assessment of Existing SCADA System	4 - 4
4.2.1 First Survey of Existing SCADA.....	4 - 4
4.2.2 Follow-up Survey Regarding SCADA Improvement	4 - 9
(1) Restoration Procedure for Feeder Fault	4 - 9
(2) Priority of Introduction of DMS Functions.....	4 - 10
(3) One Idea of Communication System Configuration for Distribution SCADA.....	4 - 10
(4) Feeder Fault Frequency and Feeder Specification Study	4 - 12
4.3 Introduction of Distribution SCADA System	4 - 13
4.3.1 Area to be covered	4 - 13
4.3.2 Assessment of the Existing System.....	4 - 14
(1) Substation Configuration and Monitoring Items.....	4 - 14
(2) Some Review Items for Existing SCADA	4 - 14
(3) Effectiveness of Distribution SCADA	4 - 16
4.3.3 Design	4 - 17
(1) Communication Method.....	4 - 17
(2) Faulty Zone Sectionalization.....	4 - 18
(3) Load Balancing by Back Up from a Neighboring Feeder.....	4 - 19
4.3.4 Cost Estimate	4 - 20
(1) Costs of Components	4 - 20
(2) Benefits of System Introduction.....	4 - 20
(3) Conditions for Estimate.....	4 - 20
4.3.5 Plan of Introduction	4 - 23
(1) Section Number and Number of Pole-mounted Automatic Switches (SWs)	4 - 23
(2) Number of SWs and Economical Estimate	4 - 24
(3) Policy for Introducing Distribution SCADA	4 - 24
4.4 Recommendation on Distribution SCADA System.....	4 - 28
4.4.1 Functions of Existing SCADA and of Distribution SCADA.....	4 - 28
(1) Call Center at SCADA Center.....	4 - 28
(2) Load Monitoring System at SCADA Center.....	4 - 29
4.4.2 System Design	4 - 29
(1) Communication System	4 - 29
(2) Equipped System Specification.....	4 - 30
4.4.3 Cost for Every System Configuration.....	4 - 34
4.4.4 Cost Estimate for Individual Substation	4 - 42
4.5 Recommendations.....	4 - 55

Chapter 4 SCADA System

The study was planned for the purpose of proposing an improvement plan of the existing SCADA to introduce distribution supervisory control and data acquisition functions (distribution SCADA) and achieve the following items.

- Improve electricity supply reliability through reduction of the interruption period and outage duration and improve availability of electric supply.
- Automatically change the transformer taps for maintaining desired voltages and switching on and off of capacitor banks for reducing reactive power, and optimally deliver loads to the feeders by monitoring and analyzing voltage and current on feeder, and in turn, improve the utilization rate of distribution feeder as well as reduce distribution losses.

To be more specific, the existing SCADA is covering as far as the 11kV feeder circuit breakers in the distribution substation, and the distribution SCADA functions should be introduced into the existing SCADA by the manners as shown below:

- Install remote-controlled switches with control device and voltage and current instrument devices on a feeder including voltage booster and capacitor banks.
- Connect the above-mentioned devices with the existing SCADA through a new communication system.

4.1 General

This study includes the following steps:

- Assessment of the existing SCADA System
- Study on introduction of distribution SCADA System
- Proposal of distribution SCADA System

4.1.1 Assessment of the Existing SCADA System

The existing SCADA system is covering up to 11kV feeder circuit breakers in substations. First, the system configuration and its functions were studied. Based on the findings, the additional hardware and software that are required to introduce the distribution SCADA functions were identified. They were reflected in the proposed distribution SCADA system design.

4.1.2 Study of Distribution SCADA Introduction

The system configuration and introduction cost were studied and feasibility of introducing the system was also assessed on the proposal of distribution SCADA.

- Study area
 - Conceptual design: As for the substations covered by the existing SCADA system, collect as many data as possible and summarize them.
 - Detail design study: Survey almost all the substations for study of amount of required distribution SCADA system equipments and information data etc.
- Follow up of the existing SCADA assessment

The follow up study was conducted with respect to the operation and reliability of equipments duly considering the findings of the 1st site survey.
- Design study
 - Study of total system configuration

The conceptual design was studied with respect to the installation of remote controlled switches with control device and voltage and current measuring instruments on feeders, computer system configuration and communication method between RTUs (control device) and computer system in distribution control center.
 - Study of additional functions

The study was conducted with respect to which DMS functions are to be introduced, such as feeder monitoring, control and data recording.
 - Study of communication system

As for the communication method between feeder devices, substation and DCC, the study of hardware and cost was assessed with respect to radio, wire cable and fiber optic cable.
 - Detail study of system configuration

The study was conducted with respect to the really installed functions, alteration of DCC computer system, alteration of distribution equipment and system configuration.
- Estimation of cost

Based on the studied design for typical substations, the cost was estimated with respect to the system alteration, distribution equipment alteration and newly installed equipment.
- Study of introduction of distribution SCADA to feeders

As for the introduction to the covered area, the priority of introduction to feeders was studied from the viewpoint of reducing the outage period and feeder importance, and the phases of introduction were considered. The cost for each introduction phase was estimated as well.

4.1.3 Proposition of Distribution SCADA System

The plan for improvement of SCADA was proposed with the following contents:

- Existing SCADA and introduction of distribution SCADA functions
The existing SCADA system configuration and its functions, communication system and the operation status were assessed and the necessity to introduce a distribution SCADA was proposed.
- Design of distribution SCADA system
Based on the following study results, the optimal system design was proposed.
 - Installation of remote-controlled switches and control devices on the feeders
 - Installation of voltage and current measuring instruments on the feeders
 - Linking n with DMS (including “DMS functions and its adopted functions”)
 - Installation of communication system (radio, control wire and optic fiber cable).

In this case, the optimal design may depend on the location of the corresponding substation and feeders.

- Introduction plan of distribution SCADA to feeders
Based on the study results and consideration of the reliability and importance of feeders, the introduction plan was proposed.
- Cost
The cost plan corresponding to the above-mentioned plan was proposed.

4.2 Assessment of Existing SCADA System

The existing SCADA system covers up to the distribution feeder circuit breakers in the distribution substation. First, the system configuration and its functions will be studied. Based on this result, the additional hardware and software required will be identified in order to introduce the distribution SCADA functions, which will be reflected in the distribution SCADA design.

4.2.1 First Survey of Existing SCADA

At the first survey, the general functioning of the existing SCADA was surveyed mainly based on the explanation document. The results are shown in Table 4.1.

Table 4.1 Functions of existing SCADA

Items	Outline
a. Monitor and control area	<p>The existing SCADA system covers Hyderabad, 10 municipals in Ranga Reddy. Hyderabad is separated into 3 circles, South, North and Central, and SEs (Superintending Engineers) are assigned to these circles including one block of 10 municipalities in Ranga Reddy.</p> <p>In this area, the SCADA is centrally monitoring and controlling 13 EHV substations (220/132kV) and 93 middle voltage substations (33/11kV) from the DCC (Distribution Control Center) at Erragadda.</p>
b. Communication system (Refer to Figure 4.1)	<p>The basic communication system for Hyderabad SCADA system is the state of the art Microwave Communication Network, comprising of two separate Networks.</p> <p>The primary backbone communication network on the Time Division Multi Access (TDMA) principle operating on 2.3 GHz frequency band connects the central station to all the nodal stations – 220/132kV stations. This will carry data of SCADA, voice communication etc.</p> <p>The Secondary Communication Network that is based on the Multiple Address Radio System (MARS) principle interlinks all the 33/11kV substations to the nearest nodal station (TDMA station).</p>
c. Outline of DCC Computer System (Refer to Figure 4.2)	<p>The Master Control Center has ABB's S.P.I.D.E.R. System with three high end servers, namely, a main standby redundant SCADA application server pair and one for the DMS (Distribution Management System) application functions.</p> <p>The programmer's office has one operator's programming workstation. This is an engineering console used for database generation, maintenance and modification of existing pictures and /or addition of new network pictures/data.</p> <p>Additionally, 2 remote communication servers are provided to control and acquire data from 33kV feeders emanating from EHV substations, incoming 33kV circuits and 33/11kV substations, through the substation RTUs.</p> <p>Furthermore, 4 monitoring dual workstations are also provided in the control room.</p> <p>Besides general SCADA functions like Calculation of hourly active and reactive power values, Event & alarm list, Report Generation and Display of status indications etc., this system envisages integration of both Critical Distribution System Control functions such as Emergency Load Shedding, Fault Localization and Restoration of Supply and also application functions such as Automated Meter Reading of the HV customers connected to the city distribution network.</p> <p>Pole-type RTUs (not installed in reality) are envisaged for Feeder SCADA and Automatic Meter Reading functions. It is an integral unit comprising of an</p>

Items	Outline
d. DMS Application functions	<p data-bbox="475 219 1375 253">RTU, Radio Transceiver, equipment power supplies & backup battery supplies.</p> <p data-bbox="201 253 435 286">(Table 4.1 Continue)</p> <p data-bbox="475 322 1375 383">The following additional DMS function modules have been integrated into the S.P.I.D.E.R. SCADA software.</p> <ul style="list-style-type: none"> <li data-bbox="475 416 1375 544">-Emergency load shedding (for HV customer) This facility enables operators to select a group of breakers with a single command and shed blocks of load. However, for protection against operator errors load shedding will be initiated through a two-step procedure. <li data-bbox="475 577 1375 734">-Load control (for HV customer) Load control of HV loads for single discrete loads or groups of loads brings out effective management of System peak load hours. Synthesis of load peak curves of the feeders to which the HV customers are attached is also done simultaneously for flattening the load curve. <li data-bbox="475 768 1375 1021">-Automatic meter reading (for HV customer) For the various HV bulk consumers that APTRANSCO caters to, such as Railways, heavy industries and others, ABB uses the output of electronic meters installed by APTRANSCO for retrieving and integrating the meter data into the SCADA system through RTUs. This arrangement vastly eases the traditional tasks of the utility company like procurement of billing information, monitoring of customer's load and voltage besides being an effective way of detecting any attempt to temper with meters. <li data-bbox="475 1055 1375 1149">-Fault location The operator, through SCADA, can perform identification and isolation of the faulty section through the Fault Localization application function module. <li data-bbox="475 1182 1375 1272">-Load balancing Automatic operation of transformer taps from the control center, in the event of actual or likely overloads, distributes the total load on the system. <li data-bbox="475 1305 1375 1435">-Automated mapping and facilities management (AM/FM) The latest geographical maps with the electrical network merged on it are a boon for both Troubleshooting and Routine field maintenance of devices such as relaying of under-ground cables etc. <li data-bbox="475 1469 1375 1624">-Trouble call management system In APTRANSCO project the information of outage of supply reported by the customers will be collected at fuse-off call centers. By connecting up all the fuse-off call centers to DCC, the operator at DCC can make an analysis and send rectification gangs for supply restoration.




Figure 4.1 Network connection for Hyderabad SCADA system




Figure 4.2 DCC computer system

As a conceptual design example, a design such as Figure 4.3 is expected. This design is based on the idea that the existing RF communication route should be most used.




Figure 4.3 Distribution SCADA configuration

4.2.2 Follow-up Survey Regarding SCADA Improvement

For the purpose of SCADA improvement, the following items were also studied through the persons in charge of Indian side.

- Restoration procedure for feeder fault
- Priority of functions for DMS (Distribution Management System)
- Communication system configuration for distribution SCADA
- Feeder fault frequency and feeder specification study
- Substation configuration and monitoring items
- Some review items for existing SCADA

(1) Restoration Procedure for Feeder Fault

With respect to the purpose of a distribution SCADA system, a reduction of outage time is expected through measures such as automatic separation of the fault section and remote restoration operation. Therefore, the possibility of improvement for this reduction was studied.

(a) Procedure

Figure 4.4 shows the procedure to be taken when a feeder fault occurs. Operators at substation learn a fault by alarms and customers call to the Call Center or FOC. The CBD does not receive a call but is put in charge of 11 kV feeder affairs.

After fault, re-closing of feeder circuit breaker is tried twice. If the fault remains, the fault section detection is executed with connection to inspectors. For separating the fault section, manual AB switches (Refer to Annex 4.1) are operated on the field side. In urban area, the Call Center connects with CBD operators. In rural area, the Call Center connects with FOC operators.




Figure 4.4 Feeder fault and restoration procedure

(b) Outage Time

A period of one outage is from 10 to 15 minutes for a small size feeder and generally, from 30 to 60 minutes. Two categories of interruption and break down exist; the period of the former is less than 30 minutes and that of the latter is more than 30 minutes.

(2) Priority of Introduction of DMS Functions

The existing SCADA has functions of DMS. Some of these functions should be put to use, and the priority of introduction is as shown in Table 4.2 that is based on a SCADA operator's opinion.

Fault location has the first priority and Load balancing the second. These contribute to improvement of reliability and reduction of loss, respectively.

Table 4.2 Priorities of DMS functions

Function	Priority
a. Emergency load shedding (for HV customer)	6
b. Load control (for HV customer)	4
c. Automatic meter reading (for HV customer)	3
d. Fault location	1
e. Load balancing	2
f. Automated mapping and facilities management (AM/FM)	7
g. Trouble call management system	5

(3) One Idea of Communication System Configuration for Distribution SCADA

The communication structure is already shown in Figure 4.1. In this section, one idea of extending the network for distribution SCADA communication is shown in Figure 4.5. In this case a polling master is newly installed at substation where a master MARS is equipped. In another case pole top RTUs can be directly connected with DCC.




Figure 4.5 Example of telecommunication method

(4) Feeder Fault Frequency and Feeder Specification Study

In order to study the introduction of distribution SCADA, the study was done with respect to feeder specifications such as length, maximum load and expanding form (Refer to Figure 4.6) and the outage period caused by interruption and break down faults. The results are shown in Annex 4.2.




Figure 4.6 Feeder data items

Table 4.3 shows the summary of results. As for the data per one feeder, maximum load is approximately identical in both Ranga Reddy and Hyderabad, but Ranga Reddy is a little longer than Hyderabad in length. The amount of outage in Ranga Reddy is also larger than that in Hyderabad.

Table 4.3 Results of feeder survey

Item	Ranga Reddy			Hyderabad				Total
	North	South	Total	North	Central	South	Total	
Number of substations	22	13	35	30	14	17	61	96
Number of feeders	121	58	179	178	87	102	367	546
Max load (A/F)	111	107	109	100	100	116	104	106
Length (km/F)	9.9	12.3	10.7	4.7	5.0	3.9	4.5	6.5
Sec. SW (Nos./F)	2.0	1.5	1.8	1.6	1.4	1.5	1.5	1.6
Spur line (Nos./F)	4.2	5.5	4.6	4.9	4.7	5.0	4.9	4.8
Alternate line (Nos./F)	0.5	0.9	0.6	1.7	1.3	1.8	1.6	1.3
Outage I+B(Nos./F/M)	5.7	9.1	6.9	4.2	3.7	4.6	4.1	5.0
Outage I+B (minutes/F/M)	56	171	93	78	62	82	75	81

I: interruption, B: breakdown, F: feeder, M: month

4.3 Introduction of Distribution SCADA System

In this section, the possibility for Distribution SCADA introduction is studied with respect to the mainly economical estimate for the substations covered by the existing SCADA. This estimate is conducted on the basis of the average data derived from "4.2.2(4) Feeder Fault Frequency and Feeder Specification Study".

4.3.1 Area to be covered

Among the substations (106) monitored and controlled by the existing system, the study was focused on 96 substations because the data of these 96 substations are available. The details of 106 substations are shown in Table 4.4.

The details of the survey are shown in The Annex 4.2 and summarized in Table 4.5. This table includes some outage energy data regarding the area substations. The amount of energy is nearly equal to the accumulating base value shown in the following section.

Table 4.4 Details of substation number

Total Area							
106							
North				South			
49				57			
Hyderabad City		Ranga Reddy		Hyderabad City		Ranga Reddy	
34		15		33		24	
EHV (132/33kV)	33/11kV	EHV (132/33kV)	33/11kV	EHV (132/33kV)	33/11kV	EHV (132/33kV)	33/11kV
4	30	3	12	2	31	4	20

Table 4.5 Nos. of substations and feeders with some outage energy data

Item		Ranga Kedy North	Ranga Kedy South	Ranga Kedy Gross (1)	Hyderabad North	Hyderabad Central	Hyderabad South	Hyderabad Gross (2)	Hydera.+R.R. (1) + (2)
Maximum load	Current(A/feeder) (a)	110.6	107.0	109.3	100.0	100.4	116.1	104.0	
	Apparent power (kVA/feeder) (1)	2,107.2	2,038.6	2,082.4	1,905.2	1,912.8	2,211.9	1,981.4	
Power factor (b)		0.85	0.85	0.85	0.85	0.85	0.85	0.85	
Load factor (c)		0.7	0.7	0.7	0.7	0.7	0.7	0.7	
Average load(kW) (2)		1,253.8	1,212.9	1,239.0	1,133.6	1,138.1	1,316.1	1,178.9	
Outage period	(m/feeder/M) (d)	55.6	170.7	93.3	78.1	62.2	81.5	74.7	
	(m/feeder/Y) (3)	667.2	2048.4	1119.6	937.2	746.4	978	896.4	
Outage energy (kWh/feeder/Y) (4)		13,942	41,410	23,120	17,707	14,158	21,452	17,613	
Substation Nos		22	13	35	30	14	17	61	96
Feeder Nos(e)		121	58	179	178	87	102	367	546
Outage energy (kWh/Area/Y) (5)		1,686,952	2,401,778	4,138,494	3,151,799	1,231,774	2,188,152	6,464,092	10,602,587
Tariff (f)	(Rs/kWh) Rs	46.5	4,000	4,000	4,000	4,000	4,000	4,000	
	(US\$/kWh) US\$	1	0.086	0.086	0.086	0.086	0.086	0.086	
	(Yen/kWh) Yen	120	10.323	10.323	10.323	10.323	10.323	10.323	
Tariff incom reduction (6)	(Rs/Y)	6,747,810	9,607,111	16,553,978	12,607,198	4,927,094	8,752,609	25,856,369	42,410,346
	(US\$/Y)	145,114	206,605	356,000	271,123	105,959	188,228	556,051	912,050
	(Yen/Y)	17,413,702	24,792,545	42,719,942	32,534,704	12,715,082	22,587,378	66,726,113	109,446,055

(1)=(a)×11kV×3^{0.5}

(b): JICA Information booklet

(c): O&M data

(2)=(1)×(b)×(c)

(3)=(d)×12

(4)=(2)×(3)/60

(5)=(4)×(e)

(6)=(5)×(f)

4.3.2 Assessment of the Existing System

(1) Substation Configuration and Monitoring Items

The basic substation structures and the monitoring items are shown in Figure 4.7. Circuit breakers in substations of DISCOM are also monitored and remotely operated from SCADA center as well.

(2) Some Review Items for Existing SCADA

Officers in charge pointed out some items to be improved as follows. Among these items, there are some points that will improve the existing SCADA and need the distribution SCADA functions.

(a) All outdoor substations

Problem:

Only one GC breaker on 33 kV is available; Transformer protection relays (Buchholz + Temperature) for all 3 phases transformers are connected to one GC breaker. If any fault happens on any transformer at an outdoor substation, the GC breaker will trip. In this case, 2 transformers cannot be charged from SCADA, since no independent breaker is available for each transformer.

Improvement:

Propose to install an independent 33 kV breaker for each transformer.

(b) All the isolators

Problem: All the isolators (AB switches) are now of manual operation type.

Improvement: They may be motorized.

(c) Transducer supply power

Problem: AC power is supplied. Even when the incoming supply fails, total remote operation will be lost.

Improvement: Change all transducers to DC power supply type.

(d) Bus Coupler Breaker

Provide instead of isolator (AB switch) for all outdoor substations.

(e) Operation of transformer and breaker

All transformers and breakers should be loaded up to 50 % of capacity, so that an alternate supply can be arranged from SCADA.

(f) Operation of 11 kV feeder

All 11 kV feeders should be loaded up to 100 amperes, since CT ratio of almost all 11 kV feeders is 200/5 amperes. In case of emergency, one feeder should be able to take alternate feeder load by choosing sectionalizer.




Figure 4.7 Substation configuration and monitoring items

(3) Effectiveness of Distribution SCADA

As mentioned above, the existing SCADA seems to monitor the system and control up to the distribution substations. The functions such as monitoring and controlling feeder current or transformer load, however, are expected to be present in the SCADA system. These functions indirectly realize load leveling of feeders in a substation and reduce feeder ohm loss.

In addition to these functions, the faulty zone sectionalization seems to be needed because the outage period is very long as shown in Annex 4.2.

Therefore, loss recovery energy by balancing of feeder load and lost energy by outage are estimated as follows.

(a) Outage Energy Estimate

Lost energy (kWh) by outage is calculated for every feeder based on its fault data. The equation is as follows.

$$E \text{ (kWh/year)} = MA \times V \times 3^{1/2} \times PF \times LF \times OPM/60 \times 12(\text{months})$$

MA : Maximum ampere for a month, V : 11 kV, PF: Power factor 0.85,

LF : Load factor 0.7, OPM : Outage period for a month (minutes)

The result is shown in Annex 4.3.

(b) Recovery Energy by Load Balancing of Feeders in a Substation

Loss energies at maximum amperes and at leveled amperes are calculated as follows and recovery energy is derived as the difference between the two calculated energy values.

$$E_m \text{ (kWh/year)} = 3 \times MA^2 \times R_u \times L \times 24(\text{h}) \times 365(\text{days}) \times LF \times DLF$$

MA: Maximum ampere, R_u : Ohm/km, L: Feeder length(km), LF: Loss factor= $aF+(1-a)F^2=0.553$ at $a=0.3$ $F(\text{load factor})=0.7$, DLF(Dispersal loss factor): 0.33 at flat load on feeder

$$E_l \text{ (kWh/year)} = 3 \times LA \times R_u \times L \times 24(\text{h}) \times 365(\text{days}) \times LF \times DLF$$

LA: Leveled ampere, others are same as above.

The result is shown in Annex 4.4.

4.3.3 Design

(1) Communication Method

The communication methods between pole top RTUs and DCC (Distribution control center) are shown in Table 4.6. Every method has merits and demerits, respectively. In this survey, Radio and Fiber Optic Cable methods seem to be available from the view point of cost as studied in the following section and because a lot of fiber optic cables have been laid in Hyderabad. The Power Line Carrier (PLC) method is not available here because the distribution network is directly earthed and PLC cannot be used.

Table 4.6 Comparison of communication methods

Method	Merit	Demerit
Radio Communication	<ul style="list-style-type: none"> - No selection for cable route and it's number. - Freedom for places, where RTUs are installed. - Easy for increase of facility. 	<ul style="list-style-type: none"> - Depending on transmission path. - Low reliability of transmission.
Control Cable	<ul style="list-style-type: none"> - Proper for the case where the number (par km) of switches is large. - Easy construction of cable. 	<ul style="list-style-type: none"> - Not proper for the case where the distance between switches is large because of expensive cost - Need an amplifier, in some case.
Power Line Carrier (VO Signal)	<ul style="list-style-type: none"> - Can be adopted everywhere the distribution lines exist. 	<ul style="list-style-type: none"> - Low reliability of transmission. - Some influence because of using distribution line. - Unusable for direct earth network.
Fiber Optic Cable	<ul style="list-style-type: none"> - High speed and large capacity for signal transmission. - Few number of cables because of large capacity par one cable. 	<ul style="list-style-type: none"> - Need the special technique for cable connecting etc. - Impossible to make a small radial curve. - Low efficiency for small scale transmission signals.

(2) Faulty Zone Sectionalization

Figure 4.8 shows a mechanism for detecting a faulty zone. This function is expected to be equipped first while introducing distribution SCADA.

- ◆ Step 1 : CB opens because of a fault on the section 2.
- ◆ Step 2 : CB closes and charges the section 1.
- ◆ Step 3 : The first SW tries to close.
- ◆ Step 4 : CB opens again because the fault remains in the section2. The first SW is locked not to close next.
- ◆ Step 5 : CB closes again and the first section is charged. The first SW, however, is not able to close because of lock mode.
- ◆ Step 6 : The SW tied to a neighboring feeder closes to charge a no-fault section.




Figure 4.8 Faulty zone sectionalization method

4.3.4 Cost Estimate

The NPV (Net Present Value) method is adopted in this cost estimation. This method is considered practical or theoretical when a social discount is difficult to decide.

(1) Costs of Components

At first, the costs of components used in distribution SCADA system were surveyed in India and Japan. The results are shown in Table 4.7. Based on this table, every component cost is decided for economical estimate of system introduction.

(2) Benefits of System Introduction

As for benefits of the distribution SCADA, three advantages are considered in this estimate as follows.

(a) Reduced outage period and recovery of supply energy and tariff income

The amount of outage energy is described in “4.3.2 (3) (a)”. But the amount of energy recovered depends on the number of sections on a feeder that are made by automatic switches. For example, if a feeder is separated into two sections by one automatic switch, the amount of power (kW) during outage period decreases by half and the outage period also decreases by half because the inspection zone is reduced by half. As a result, the outage energy (kWh) is reduced by quarter. This means that the energy is recovered by 3/4 by means of faulty zone sectionalization.

- ✓ Section Nos. = 2 : Recovered energy 3/4 (1-1/4) (mentioned above)
- ✓ Section Nos. = 3 : Recovered energy 8/9 (1-1/9)
- ✓ Section Nos. = 4 : Recovered energy 15/16 (1-1/16)

(b) Loss energy recovery by load balancing of distribution feeders

The amount of loss recovery energy is described in “4.3.2 (3) (a)”. The procedure for load balancing seems to be difficult but the calculated amount is applied to the estimate.

(c) Reduced personnel expense

Distribution SCADA enables reduction of the service crew because the fault section can be isolated by remote- control facilities installed at a distribution control center. The crew can be reduced by about one person in every substation.

(3) Conditions for Estimate

Conditions for approximate estimate are shown in Table 4.8 considering above (1) and (2). This table includes other values than cost and benefit such as social discount rate and price index increasing rate etc.

Table 4.7 Costs of components

		Exchange Rate				
		US\$	Rs	Yen	Yen/Rs	
		1	46.5	120	2.58	
■ Pole mounted device		Bold font: original value				
Item	unit	Rs		Yen		Remark
		Materials	Construction	Materials	Construction	
(Example in Japan)						
Controle cable method (metallic,optic fiber)	Automatic SW	device	142,360	26,956	367,380	69,564
	Power supply transformer		41,543	8,982	107,208	23,180
	Pole mounted RTU		209,360	36,659	540,284	94,604
	Sub total	set	393,263	72,597	1,014,872	187,348
Distribution PLC method	Automatic SW	device	142,360	26,956	367,380	69,564
	Power supply transformer		144,658	12,717	373,312	32,819
	Pole mounted RTU		193,860	30,661	500,284	79,124
	Sub total	set	480,878	70,334	1,240,976	181,507
Current sensor	device		24,800	11,548	64,000	29,800
(Example in India)						
Radio Frequency method	Automatic SW (with pole top RTUs cum tranceiver and 3 phase PTs)	set	362,500		935,484	1.25xbelow
			290,000		748,387	Value in 1996
(Old)	Pole mounted RTU cum tranceiver at DTR	device	221,250		570,968	1.25xbelow
			177,000		456,774	Value in 1996
(Latest)	Remote metering HV service with Pole mounted and 11kV breaker, metering sets.	set	412,500		1,064,516	1.25xbelow
			330,000		851,613	Value in 1996
(Read DTR or LV)	Remote metering HV service GSM Modem(12500Rs) SIM Card(1000),Labour(1500)	set	13,500	1,500	34,839	3,871
	LV,CT TVM with box(10000) Modem(12500),SIM Card(1000) Labour inc. wire cost(1500)	set	23,500	1,500	60,645	3,871

Data : Development of 'Distribution Automation' Project at 33/11 kV Gachibowli SS jointly with M/s CMC Limited.

■ Communication device						
Item	unit	Rs		Yen		Remark
		Materials	Construction	Materials	Construction	
(Example in Japan)						
Controle cable method(metallic)	Master RTU (DCC)	device	9,687,500	116,250	25,000,000	300,000
Distribution PLC method	Master RTU (DCC)	device	7,750,000	116,250	20,000,000	300,000
	Repeat RTU(SS)		3,875,000	38,750	10,000,000	100,000
	Sub total	set	11,625,000	155,000	30,000,000	400,000
	Metallic cable(20c(10p))	km	212,738	400,094	549,000	1,032,500
	Fiber optic cable(16c(16p))	km	116,250	581,250	300,000	1,500,000
	Radio communication tanceiver	device	27,125		70,000	
(Example in India)						
Radio Frequency method	Communication equipment(SS) (MARS Master,radio Tower,Antennas, Cables Comppication I/F and Testing equipment)	set	5,775,000		14,903,226	1.25xbelow
			4,620,000		11,922,581	Value in 1996
(Old)	Substation RTU with tranceiver, transducer/TVM, Tele signal and tele comand, charger etc.	device	955,000		2,464,516	1.25xbelow
			764,000		1,971,613	Value in 1996
Data : Development of 'Distribution Automation' Project at 33/11 kV Gachibowli SS jointly with M/s CMC Limited.						
Radio Frequency method	MAR System (Master or Repeater Station)		300,390		775,200	1.2xbelow
			250,325		646,000	Value in 1998
	MAR System (Remote Station at 33/11kV SS)		61,572		158,895	1.2xbelow
			51,310		132,413	Value in 1998
	RTU(96staus inputs, 72 Analog inputs, 48 control outputs for 33/11kV SS)		490,987		1,267,064	1.2xbelow
		409,156		1,055,886	Value in 1998	
	RTU(96staus inputs, 72 Analog inputs, 48 control outputs for 33/11kV SS)		855,360		2,207,381	1.2xbelow
			712,800		1,839,484	Value in 1998

Data : Contract Agreement of SCADA System (April 1998)

Fiber optic cable(12 to 20 c)	km	25,000		64,516	minimum
		50,000		129,032	maximum

(Remarks) Fiber optic cable has already been laid by M/S Reliance in Hyderabad city (65,000km in India) and can be leased for commun

■ DAS(Distribution Automation System) Master System**(Example in India)**

Radio Frequency method	Remote Communication Server (Reddudant RCS 300)	set	2,859,912		7,380,418	1.2xbelow
			2,383,260		6,150,348	Value in 1998

Data : Contract Agreement of SCADA System (April 1998)

Table 4.8 Conditions for estimate

Item		Value	Remark	
Social Discount		0.05		
Price Index Increasing		0.01		
Exchange Rate		Yen/US\$	120	
		Rupee/US\$	46.5	
		Yen/Rupee	2.58	
Facilities				
Feeder Number	Nos/SS (RR and Hyderabad)	6.00		
Feeder Length	km/Feeder(RR and Hyderabad)	6.50		
Construction Cost(Rs)				
Pole Mounted Device (per unit)	SW,RTU etc.	Materials(India) Construction(Japan)	362,500 72,597	435,097
	SW,RTU etc. (for PLC)	Materials(Japan) Construction(Japan)	480,878 70,334	551,212
	Radio Communication Device (GSM Mobile)	Materials(India) Construction(India)	13,500 1,500	15,000
Communication Line (per km)	Metaric Cable	Materials(Japan) Construction(Japan)	212,738 400,094	612,832
	Fiber Optic cable	Materials(India) Construction(Japan)	50,000 581,250	631,250
RTU etc. at SS, DCC per unit)	For RF at SS (RTU)	Materials(India) Construction(Japan)	490,987 49,099	540,086
	For PLC at SS	Materials(Japan) Construction(Japan)	3,875,000 38,750	3,913,750
	MAR for RF at SS (MAR Master)	Materials(India) Construction(Japan)	300,390 30,039	330,429
	MAR for RF at SS (MAR Remote)	Materials(India) Construction(Japan)	61,572 6,157	67,729
	For Metallic Cable, Fiber at DCC	Materials(Japan) Construction(Japan)	9,687,500 116,250	9,803,750
	For PLC at DCC	Materials(India) Construction(Japan)	7,750,000 116,250	7,866,250
	RCS for RF at DCC	Materials(India) Construction(Japan)	2,859,912 116,250	2,976,162
Maintenance(%)			3	
Benefit Estimate				
Tarrif(Rs/kWh)			5	
Outage Energy Reduction	kWh/Feeder/Y(RR and Hyderabad)	19,729		(*1)
Loss Energy Recovery	kWh/SS/Y(RR and Hyderabad)	97,096		(*1)
Woerkers' Number Reduction	Rs/SS/Y	120,000		One person

(*1): Refer to Annex 4.4

	Outage Energy (kWh/Y)	Loss Energy Recovery (kWh/Y)	Feder NO	SS NO
RR	4,772,941	6,287,610	179	35
Hyderabad	5,999,138	3,033,577	367	61
Total	10,772,079	9,321,187	546	96
Average	19,729 (kWh/Feeder/Y)	97,096 (kWh/SS/Y)		

4.3.5 Plan of Introduction

(1) Section Number and Number of Pole-mounted Automatic Switches (SWs)

At first, the relation of section number and SW number is considered as Figure 4.10. For example, in case of 2 sections per one feeder needs 1 SW for separation and 0.5+0.5 SW for 2 sections to be connected with neighboring feeders. Here, 0.5 SW means that 1 SW is connected with 2 feeders. As a result, isolation of 2 sections needs 2 SWs per one feeder. The relation is concluded on the basis of Table 4.9 as follows. The relation between section number and recovery energy is also shown in Figure 4.11 and Table 4.9.




Figure 4.10 Section number and SW number

Outage Zone = 1, Outage Period = 1
 Outage Energy(kWh) = Zone(kW) · Period(h)=1

Outage Zone = 1/2, Outage Period = 1/2
 Outage Energy(kWh) = Zone(kW) · Period(h)=1/4

Outage Zone = 1/3, Outage Period = 1/3
 Outage Energy(kWh) = Zone(kW) · Period(h)=1/9




Figure 4.11 Section number and energy recovery rate

Table 4.9 Relation between section number ,and SW number and energy recovery rate

Section Number/feeder	SW Number/Feeder	Energy Recovery Rate
2	2	3/4
3	3.5	8/9
4	5	15/16

(2) Number of SWs and Economical Estimate

Based on Tables 4.8 and 4.9, cost and benefit were estimated by changing the number of SWs. Table 4.11 shows the result of a case of 2 to 5 per feeder SWs.

The estimate conditions are as follows:

- ◆ Cost only includes pole-mounted automated switches and its attached devices.
- ◆ Substation Nos and Feeder Nos are 96 and 546, respectively.
- ◆ Construction period is 5 years.

From this result shown in Table 4.10, feeders of 2 or 3 sections seem to be available with Fiber Optic Cable or RF method of communication.

Table 4.10 Number of section switch and economical estimate

Number of sections	No. of switches /feeder	Equipment Cost	NPV (20 Year)	(Million Rs)
				Recovery Period
2	2	511	528	8 years
3	3.5	894	137	16 years
4	5	1,277	▲313	Over 20 years

(3) Policy for Introducing Distribution SCADA

(a) Section number

2 or 3 (Number of switches is 2 or 3.5 per feeder) .

(b) Communication method

Fiber Optic Cable or RF depending on the site condition.

(c) Priority for introduction

Economical aspects are considerably different from substation to substation. Hence priority should be given to introducing the system to substations.

Table 4.11 Example of estimate

Section SW No.: 2/Feeder

Cash Flow Analysis (Money unit: 10 ⁶ Rs)		0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	Total
Relative Year		2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	Total
Calendar Year(n)		2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	Total
Discount=1/(1+i) ⁿ		1.000	0.952	0.907	0.864	0.823	0.784	0.746	0.711	0.677	0.645	0.614	0.585	0.557	0.530	0.505	0.481	0.458	0.436	0.416	0.396	0.377	
Price=(1+i) ⁿ		1.000	1.010	1.020	1.030	1.041	1.051	1.062	1.072	1.083	1.094	1.105	1.116	1.127	1.138	1.149	1.161	1.173	1.184	1.196	1.208	1.220	
rate i= 0.05																							
rate r= 0.01																							
Amount of Construction Facilities																							
Substation Number		20	20	20	20	16	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	96
Feeder Number		120	120	120	120	96	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	576
Feeder Length(km)		780	780	780	780	624	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	3,744
Cost																							
Pole Mounted Device		104.42	105.47	106.52	107.59	86.93	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	511
a.SW,RTU etc.		3.13	6.30	9.49	12.72	15.33	15.33	15.33	15.33	15.33	15.33	15.33	15.33	15.33	15.33	15.33	15.33	15.33	15.33	15.33	15.33	15.33	292
Maintenance Factor (%)																							
Total Cost		107.6	111.8	116.0	120.3	102.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	15.3	803.1
Present Value		107.6	106.4	105.2	103.9	84.1	12.0	11.4	10.9	10.4	9.9	9.4	9.0	8.5	8.1	7.7	7.4	7.0	6.7	6.4	6.1	5.8	292.2
Benefit																							
Outage		8.9	17.8	26.6	35.5	42.6	42.6	42.6	42.6	42.6	42.6	42.6	42.6	42.6	42.6	42.6	42.6	42.6	42.6	42.6	42.6	42.6	813
Loss		9.7	19.4	29.1	38.8	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	889
Worker		2.4	4.8	7.2	9.6	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	220
Tariff Rate																							
Outage Reduction Rate																							
Return																							
Total		21.0	42.0	63.0	84.0	100.7	100.7	100.7	100.7	100.7	100.7	100.7	100.7	100.7	100.7	100.7	100.7	100.7	100.7	100.7	100.7	100.7	1,922
Benefit		21.0	40.0	57.1	72.5	82.9	78.9	75.2	71.6	68.2	64.9	61.8	58.9	56.1	53.4	50.9	48.5	46.2	44.0	41.9	39.9	38.0	1,172
Return																							
Benefit - Total Cost		-86.6	-69.8	-53.1	-36.4	-1.5	85.4	85.4	85.4	85.4	85.4	85.4	85.4	85.4	85.4	85.4	85.4	85.4	85.4	85.4	85.4	85.4	1,119
Present Value		-86.6	-66.5	-48.1	-31.4	-1.2	66.9	63.7	60.7	57.8	55.1	52.4	49.9	47.6	45.3	43.1	41.1	39.1	37.3	35.5	33.8	32.2	528
Return Accumulation																							
Benefit - Total Cost		-86.6	-156.4	-209.4	-245.8	-247.3	-161.9	-76.5	9.0	94.4	179.8	265.2	350.6	436.0	521.4	606.8	692.3	777.7	863.1	948.5	1033.9	1119.3	
Present Value		-86.6	-153.0	-201.2	-232.6	-233.8	-166.9	-103.1	-42.4	15.4	70.4	122.9	172.8	220.4	265.7	308.8	349.9	389.0	426.3	461.8	495.6	527.8	

(Table 4.11 Continue)
Section SW No.: 3.5/Feeder

Cash Flow Analysis (Money unit: 10 ⁶ Rs)		0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	Total Equip.
Relative Year		2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	
Calendar Year(n)		1.000	0.952	0.907	0.864	0.823	0.784	0.746	0.711	0.677	0.645	0.614	0.585	0.557	0.530	0.505	0.481	0.458	0.436	0.416	0.396	0.377	
Discount=1/(1+i) ⁿ	rate i= 0.05	1.000	1.010	1.020	1.030	1.041	1.051	1.062	1.072	1.083	1.094	1.105	1.116	1.127	1.138	1.149	1.161	1.173	1.184	1.196	1.208	1.220	
Price=(1+i) ⁿ	rate r= 0.01	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	
Amount of Construction Facilities																							
Substation Number		120	120	120	120	96	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	96
Feeder Number	6 (Nos/SS)	780	780	780	780	624	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	576
Feeder Length(km)	6.5 (km/Feeder)	780	780	780	780	624	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	3,744
Cost																							
Pole	a.SW,RTU	182.74	184.57	186.41	188.28	152.13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	894
Mounted	etc.	5.48	11.02	16.61	22.26	26.82	26.82	26.82	26.82	26.82	26.82	26.82	26.82	26.82	26.82	26.82	26.82	26.82	26.82	26.82	26.82	26.82	511
Device	Maintenance Factor																						
	3 (%)	188.2	195.6	203.0	210.5	179.0	26.8	26.8	26.8	26.8	26.8	26.8	26.8	26.8	26.8	26.8	26.8	26.8	26.8	26.8	26.8	26.8	894
	Total Cost	188.2	186.3	184.2	181.9	147.2	21.0	20.0	19.1	18.2	17.3	16.5	15.7	14.9	14.2	13.5	12.9	12.3	11.7	11.1	10.6	10.1	511.4
Benefit																							
Outage	19,729 (kWh/Feeder/Y)	10.5	21.1	31.6	42.1	50.6	50.6	50.6	50.6	50.6	50.6	50.6	50.6	50.6	50.6	50.6	50.6	50.6	50.6	50.6	50.6	50.6	965
Loss	97,096 (kW/h/SS/Y)	9.7	19.4	29.1	38.8	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	889
Worker	0.12 (10 ⁶ Rs/SS/Y)	2.4	4.8	7.2	9.6	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	220
Tariff Rate	5 (Rs/kWh)																						
Outage Reduction Rate	0.89																						
Total		22.6	45.3	67.9	90.6	108.7	108.7	108.7	108.7	108.7	108.7	108.7	108.7	108.7	108.7	108.7	108.7	108.7	108.7	108.7	108.7	108.7	2,074
Benefit		22.6	43.1	61.6	78.2	89.4	85.2	81.1	77.2	73.6	70.1	66.7	63.6	60.5	57.6	54.9	52.3	49.8	47.4	45.2	43.0	41.0	1,264
Return																							
Benefit - Total Cost																							
Current Value		-165.6	-150.3	-135.1	-120.0	-70.3	81.9	81.9	81.9	81.9	81.9	81.9	81.9	81.9	81.9	81.9	81.9	81.9	81.9	81.9	81.9	81.9	669
Present Value		-165.6	-143.1	-122.5	-103.6	-57.8	64.1	61.1	58.2	55.4	52.8	50.3	47.9	45.6	43.4	41.4	39.4	37.5	35.7	34.0	32.4	30.9	137
Return Accumulation																							
Current Value		-165.6	-315.9	-451.0	-570.9	-641.2	-559.3	-477.4	-395.6	-313.7	-231.8	-150.0	-68.1	13.8	95.7	177.5	259.4	341.3	423.1	505.0	586.9	668.8	
Present Value		-165.6	-308.7	-431.3	-534.9	-592.7	-528.5	-467.4	-409.2	-353.8	-301.1	-250.8	-202.9	-157.3	-113.9	-72.6	-33.2	4.3	40.0	74.1	106.5	137.3	

(Table 4.11 Continue)
Section SW No.: 5/Feeder

Cash Flow Analysis (Money unit: 10⁶ Rs)

Relative Year	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	Total Equip.		
Calendar Year(n)	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	Total		
Discount=1/(1+i) ⁿ	1.000	0.952	0.907	0.864	0.823	0.784	0.746	0.711	0.677	0.645	0.614	0.585	0.557	0.530	0.505	0.481	0.458	0.436	0.416	0.396	0.377			
Price=(1+i) ⁿ	1.000	1.010	1.020	1.030	1.041	1.051	1.062	1.072	1.083	1.094	1.105	1.116	1.127	1.138	1.149	1.161	1.173	1.184	1.196	1.208	1.220			
Amount of Construction Facilities																								
Substation Number	20	20	20	20	16	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	96	
Feeder Number	120	120	120	120	96	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	576	
Feeder Length(km)	780	780	780	780	624	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	3,744	
Cost																								
Pole Mounted	0.4351	10 ⁶ Rs/Unit	261.06	263.67	266.31	268.97	271.33	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1,277	
etc.	5	(Nos/Feeder)	7.83	15.74	23.73	31.80	38.32	38.32	38.32	38.32	38.32	38.32	38.32	38.32	38.32	38.32	38.32	38.32	38.32	38.32	38.32	38.32	731	
Device		Maintenance Factor																						
Total Cost		(%)																					1,277	
Current Value	268.9	279.4	290.0	300.8	255.6	38.3	38.3	38.3	38.3	38.3	38.3	38.3	38.3	38.3	38.3	38.3	38.3	38.3	38.3	38.3	38.3	38.3	2,007.9	
Present Value	268.9	266.1	263.1	259.8	210.3	30.0	28.6	27.2	25.9	24.7	23.5	22.4	21.3	20.3	19.4	18.4	17.6	16.7	15.9	15.2	14.4	14.4	730.5	
Benefit																								
Outage	19,729	(kWh/Feeder/Y)	11.1	22.3	33.4	44.5	53.4	53.4	53.4	53.4	53.4	53.4	53.4	53.4	53.4	53.4	53.4	53.4	53.4	53.4	53.4	53.4	1,019	
Loss	97,096	(kWh/SS/Y)	9.7	19.4	29.1	38.8	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	46.6	889
Worker	0.12	(10 ⁶ Rs/SS/Y)	2.4	4.8	7.2	9.6	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	11.5	220	
Tariff Rate		(Rs/kWh)																						
Outage Reduction Rate	0.94																							
Total			23.2	46.5	69.7	92.9	111.5	111.5	111.5	111.5	111.5	111.5	111.5	111.5	111.5	111.5	111.5	111.5	111.5	111.5	111.5	111.5	2,128	
Benefit			23.2	44.3	63.2	80.3	91.8	87.4	83.2	79.3	75.5	71.9	68.5	65.2	62.1	59.2	56.3	53.7	51.1	48.7	46.3	44.1	42.0	1,297
Return																								
Current Value																								
Present Value																								
Return Accumulation																								
Benefit - Total Cost			-232.9	-220.3	-207.8	-144.1	73.2	73.2	73.2	73.2	73.2	73.2	73.2	73.2	73.2	73.2	73.2	73.2	73.2	73.2	73.2	73.2	121	
Present Value			-245.7	-221.8	-199.8	-179.5	-118.6	57.4	54.6	52.0	49.6	47.2	44.9	42.8	40.8	38.8	37.0	35.2	33.5	31.9	30.4	29.0	27.6	-313
Benefit - Total Cost																								
Current Value	-245.7	-478.6	-698.9	-906.7	-1050.8	-977.6	-904.4	-831.2	-758.0	-684.8	-611.5	-538.3	-465.1	-391.9	-318.7	-245.5	-172.2	-99.0	-25.8	47.4	120.6			
Present Value	-245.7	-467.5	-667.3	-846.9	-965.4	-908.1	-853.4	-801.4	-751.8	-704.6	-659.7	-616.9	-576.1	-537.3	-500.3	-465.1	-431.5	-399.6	-369.2	-340.2	-312.6			

4.4 Recommendation on Distribution SCADA System

In this section, the more concrete ideas for distribution SCADA are studied. The previous section treated average data of substations and feeders in Ranga Reddy district and Hyderabad. This section treats more specific data of individual substations.

4.4.1 Functions of Existing SCADA and of Distribution SCADA

The existing SCADA mainly monitors and controls the facilities inside the distribution substations. But the existing SCADA software includes the distribution SCADA functions such as DMS (Distribution Management System). This indicates an intention to introduce the concrete hardware for distribution SCADA in the future.

In addition to these software functions, the communication facility of RF also has some marginal capacity to add distribution SCADA function, and fiber optic cables have been already laid in urban area of Hyderabad. This also means that some infrastructure is already available for introducing distribution SCADA functions.

Table 4.12 shows DMS software functions and recommendable addressing policy.

Table 4.12 DMS functions and priority

Function	Priority	Situation and Recommendable Policy for Addressing
a. Emergency load shedding (for HV customer)	6	Priority is low, so consider introduction after the primary functions.
b. Load control (for HV customer)	4	This is concerning load leveling, so also consider introduction after the primary functions.
c. Automatic meter reading (for HV customer)	3	Priority is middle and if distribution SCADA is introduced, this function is easy to introduce. Hence consider introduction in the middle future.
d. Fault location	1	Priority is the highest and this is the most basic function, so consider introduction from the start.
e. Load balancing	2	Priority is the second highest and this is an important function, so consider introduction from the start.
f. Automated mapping and facilities management (AM/FM)	7	Priority is low but GIS is prevailing and is studied in this project, so better consider connecting GIS with distribution SCADA system.
g. Trouble call management system	5	This function is already installed independent of the existing SCADA as the following Call Center, so better consider interconnecting them with each other.

(1) Call Center at SCADA Center

- ◆ Telephone no: 1912, 24 independent lines connected to this Call Center
- ◆ 16 only incoming, 4 only outgoing
- ◆ Headed by ADE+AE + system engineers, Operators are outsourced, 24 hours basis.
- ◆ LAN network, Data is available for 1,040,624 (Hyderabad), to be added for Ranga Reddy circle 797,732.
- ◆ Data: Address, Telephone No, Customer ID, Name of the feeding substation, feeder, fuse off call office, electric and revenue office
- ◆ The customer can call 1912 for registering a complaint. A call can be registered, either by customer No or telephone No or by house No.

- ◆ Software : ORACLE data base
- ◆ This Center is proposed to be linked to SCADA DCC. Upon any feeder trip, the save will appear on every screen in Call Center

(2) Load Monitoring System at SCADA Center

- ◆ Districts
6 Districts of Ranga Redy, Medak, Nalgonda, Mahaboob Nagar, Kurnool, Anatzapur.
- ◆ Numbers of substations and feeders
363 substations and 667 feeders (urban;800, rural;1,700) among 827 substations and 2,500 feeders.
- ◆ Monitoring items
V, I, P, kVA, PF at feeder outlet and 2nd side of 4 DTRs for sample.
- ◆ Communication method
Public telephone network, and GSM mobile network recently.
- ◆ Point
Monitoring for change 3F supply (9 hours) and 1F supply (15 hours) on agricultural feeder.
- ◆ Operator
2 shifts (6 persons per 1 shift).
- ◆ Meter specification
Meter protocol: SEM by SECURE,
36 days data available
Optional port: use for remote metering
SECURE meter;RS-232C in Hyderabad SCADA project
- ◆ Finance
World Bank: APL-1 (Adaptable Program of Lending 1)
Meter Number: 1000 (for 4 DISCOMs)
Material and erection: M/S SECURE
Loan amount: US\$ 1 billion (Rs 4,000 crore)

4.4.2 System Design

(1) Communication System

Figure 4.12, Figure 4.13 and Figure 4.14 show the ideas of communication system configuration.

- ◆ Idea 1 (Figure 4.12): DCC directly communicates with the field device (pole top SW, RTU).
- ◆ Idea 2 (Figure 4.13): DCC communicates through TDMA Repeater Station and /or TDMA Out Station.
- ◆ Idea 3 (Figure 4.14): DCC communicates through TDMA Repeater Station, TDMA Out Station and MARS Remote Station.

Table 4.13 shows the devices to be considered for every idea.

RF MARS has a security problem and is not able to be used for non line of sight communication.

Fiber optic cables are already laid to total length of 200 km in Hyderabad and its surrounding area.

As for cost, the following section treats. If that result is also considered here, the

following methods are expected to be promising ones.

- ◆ Fiber Optic Cable (Case 1)
- ◆ RF Mobile System

(2) Equipped System Specification

As for the field equipment and the software functions, the following items are recommended.

- ◆ Isolated section number on a feeder should be 2 or 3.
- ◆ The software functions to be introduced in the first stage should be for, at least, Fault location and Load balancing.

Table 4.13 Communication methods and system configuration

Method	Pole-top Device	Installation of Com. Line	RTU etc. at SS, DCC
--------	-----------------	---------------------------	---------------------

Idea1

Fiber Optic Cable	Case 1 (Much infrastructure of fiber optic cable)	- Automated switch with RTU	- 1% of feeder length	- 10% improvement of RCS(Remote communication System) at DCC
	Case 2 (A little infrastructure)		- 10% of feeder length	
	Case 3 (Little infrastructure)		- 50% of feeder length	
Metallic Wire		- Same as above	- 100% of feeder length	
RF Mobile System		- Automated switch with RTU and RF communication device	(Not need)	- 50% of improvement of RCS at DCC

Idea2

RF MARS		- Automated switch with RTU and RF communication device	(Not need)	- 50% of new MARS Master at SS and improvement of RCS at DCC
---------	--	---	------------	--

Idea3

PLC (Vo Carrier)		- Automated switch with RTU	(Not need)	- New RTU at SS and DCC
------------------	--	-----------------------------	------------	-------------------------




Figure 4.12 Communication configuration (Idea 1)




Figure 4.13 Communication configuration (Idea 2)




Figure 4.14 Communication configuration (Idea 3)