

[2] Master Plan on Optimization for Peaking Power Supply

Japan International Cooperation Agency (JICA)

1

Contents

- Part1: Outline of Study
- Part2: Scenarios
- Part3: Results of Simulations
- Part4: Optimal Power Development Plan


2

Part1 : Outline of Study

- Study Flow
- Methodology
 - System Reliability Analysis
 - Quantification of Annual Costs

3

Study Flow



4

Power system analysis

- To identify
- Constraints among North, Center and South through 500 kV T/L
- Due to :
- Spec. of Transmission systems
 - Stability
 - Power supply reliability

Reflecting to Supply-and-Demand Simulation

5


Methodology

- (Simulation Tools)
- System Reliability
 - Annual Costs
 - Balance between Demand and Supply
- RETICS
- PDPAT II

6

System Reliability Analysis by RETICS

- To simulate how Reserve Capacity Required changes along with Interconnection Capacity on the Same Reliability



7

Simulation of Supply & Demand Balance by PDPAT II (1)

- Computation of Annual Cost
 - Fixed Cost
 - Depreciation, Interest
 - O&M
 - Energy Cost
 - Fuel
 - Power Exchange

8

Simulation of Supply & Demand Balance by PDPAT II (2)

- Computation of Balance between Demand and Supply (Economic Dispatch)
 - Most Economical Energy Balance (Fuel Balance)
 - Optimal Power Balance
 - Reserve Margin
 - Fuel Consumption
- Computation of Power Exchange
 - Quantity & Frequency of Exchange
 - Economical Power Exchange

9

Contents

- Part1: Outline of Study
- Part2: Scenarios
- Part3: Results of Simulations
- Part4: Optimal Power Development Plan

10

Part2 : Establishment of Scenarios


- Situations & Conditions
 - Load Curve, Limitation of Interconnection
- Screening Analysis
 - Selection of Economical Peak Suppliers
- System reliability analysis
 - Necessary Reserve margin

To establish Scenarios for Quantification of annual costs by PDPAT II Simulation for divided systems


11

Load Curve Forecast

- Peak shift affects the duration of peak demand




Limitation of Interconnection



13

PDPAT II Input; Multi-system Model



14

Screening analysis

- Which peaking power supply should be selected from economic aspect?


15

Screening Analysis (conditions)

	Construction Cost	Life time	Annual O&M Cost Rate	Fuel Cost in 2020	
PSPP	650 US\$/kW	40	1.0%	Hydro 0 ¢ /kWh	Coal 2.4 ¢ /kWh
GT	400 US\$/kW	20	5.0%	3.9 ¢ /kWh	
CC	600 US\$/kW	25	4.5%	2.4 ¢ /kWh	
Coal	938 US\$/kW	30	3.5%	1.5 ¢ /kWh	
Diesel	800 US\$/kW	15	3.0%	9.0 ¢ /kWh	


16

Screening Analysis (1)



17


Screening Analysis (2)



18

Reliability analysis by RETICS (1)


■ Divided systems



19

Reliability analysis by RETICS (2)

■ Reduction of Reserve Capacity



20

Reserve Margin of Revised 5th M/P

	Installed capacity (MW)	Reserve margin	LOLE	Annual costs mil. US\$/yr
Whole system	42,162	19.3%	0.08	9,515
North	16,290	10.9%	86.46	2,925
C&S	25,872	20.2%	0.03	6,699
Total	42,162			9,624

21

Required Reserve Margin (MP load profile)

	Installed capacity (MW)	Reserve margin	LOLE (hrs)	Annual costs (mil.US\$/yr)
①Whole system	39,793 -2,369	9.7%	24.6	9,400 -115
②Divided system				
(North)	16,225 -65	14.2%	23.4	3,083 +158
(C&S)	24,538 -1,334	7.9%	23.3	6,555 -144
Total	40,763 -1,399			9,638 +14

22

Establishment of scenarios

	PSPP	GT
Target years	2015, 2020	2015, 2020
Power system	Whole, North, C&S	Whole, South
Installed capacity	0 - 10%	0 - 10%
Capacity of interconnection	800, 1300, 2200MW	800, 1300, 2200MW
Son La construction	2,400 or 0	2,400 or 0
Demand forecast	MP load curve, Peak Shift	MP load curve, Peak Shift
Power Purchase from Neighbor Countries	Laos, None, All	Laos, None, All
Soaring fuel prices	Base×2	Base×2

23

Contents

- Part1: Outline of Study
- Part2: Scenarios
- Part3: Results of Simulations
- Part4: Optimal Power Development Plan

24


Part3 : Simulation of Supply & Demand Balance by PDPAT II

- Results in 2015 for optimal peak supply
 - Effects of Son La
- Results in 2020 for optimal peak supply
 - Effects of peak shift
 - Effects of interconnection
 - Effects of system limitations
- Optimal composition
 - Effects of limitations of fuel consumption
- Optimal operating hours for PSPP

25

Effects of Son La

- Effects peak supply installation



26

Results in 2020


- PSPP in N system shows benefits

Demand	Scenario	PSPP in N		PSPP in S		GT in S	
		Interconnection %	US\$ mil/Yr	%	US\$ mil/Yr	%	US\$ mil/Yr
Peak shift	Whole system	0	9,621	0	9,621	0	9,621
	0MW	3.5	9,875	0	9,956	0	9,973
	800MW	3.5	9,650	0	9,727	0	9,729
	1,300MW	3.5	9,618	0.6	9,663	0	9,667
	2,200MW	2.4	9,598	1.8	9,588	0	9,622
IE	Whole system	0	9,400	0	9,400	1.2	9,397
	0MW	1.2	9,546	0	9,592	0	9,592
	800MW	1.2	9,307	0	9,341	0	9,341
	1,300MW	1.2	9,260	0	9,276	0	9,276
	2,200MW	0	9,233	0	9,233	0	9,233

27

PSPP in N system PS demand (1)


- N system has benefits.



28

Simulation results (1)

- Before PSPP installation, N system




Dec. 2020 N system

29

Simulation results (2)

- Before PSPP installation, C&S system




Dec. 2020 C&S system

30

Simulation results (3)


- After PSPP installation, N system



31

Effects of PSPP in 2020


- Utilization of off-peak surplus supply



32

Simulation results (4)


- After PSPP installation, C&S system



33

PSPP in N system PS demand (1)


- N system has benefits.



34

PSPP in S system PS demand (1)


- No benefit



35

PSPP in C&S system PS demand (2)

- Increasing Oil consumption




PSPP in C&S 250MW in Dec. 2020 PSPP in C&S 2000MW in Dec. 2020

36

PSPP in N system, MP load profile


- Benefits from PSPP installation with IC 1300MW



37

Optimal Peak Duration Time of PSPP


- 7-hour is appropriate in Vietnam system.



38

Effects of Interconnection


- Around 1300MW, benefits decelerate



39

Effects of Coal TPP installation in the South


- PS demand, 2020 case



40

Consideration of Fuel limitation


- Coal limits at 25%, Gas not to constrain



41

Optimal Composition

- Peak shift case, 2020 case



42

Contents

- Part1: Outline of Study
- Part2: Scenarios
- Part3: Results of Simulations
- Part4: Optimal Power Development Plan

Part 4 : Optimal power development plan in 2020 (Composition)




Image of power development pattern from 2010 to 2020 (Peak shift case)

Year	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Peak Demand	18,000	18,500	19,000	19,500	20,000	20,500	21,000	21,500	22,000	22,500	23,000
Hydro	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000
Coal	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000
Nuclear	5,000	5,000	5,000	5,000	5,000	5,000	5,000	5,000	5,000	5,000	5,000
Gas	2,000	2,500	3,000	3,500	4,000	4,500	5,000	5,500	6,000	6,500	7,000
Other	0	0	0	0	0	0	0	0	0	0	0

Thank you