

APPENDIX 10-3-2

Handout of the second workshop

THE 2nd WORKSHOP
ON THE MASTER PLAN STUDY
ON PUMPED STORAGE POWER
PROJECT
AND OPTIMIZATION FOR PEAKING
POWER GENERATION

Venue: Fuji A, 2nd floor, Hotel NIKKO HANOI
7 August, Thursday


1

POWER DEVELOPMENT
& POWER NETWORK

- Outlines of power development plan focusing on peaking power supply
 - Optimization for peaking power generation
 - Power system analysis


2

Study Flow



3

Outline of the study on Optimization for Peaking power generation



4

Power system analysis

- To identify
- Constraints among North, Center and South through 500 kV T/L
Due to :
 - Spec. of Transmission systems
 - Stability
 - Power supply reliability



Reflecting Demand-and-supply simulation

5

Optimization for Peaking power generation

- Quantification of annual cost saving
- System reliability analysis

6

Quantification of annual cost saving

Step1:

Screening curve analysis

- Which peaking power supply should be selected from economic aspect?


7

Conditions of screening

	Construction Cost	Life time	Annual O&M Cost Rate	Fuel cost	
				Hydro	Coal
PSPP	650 US\$/kW	40	1.0%	0 ¢ /kWh	2.4 ¢ /kWh
GT	400 US\$/kW	20	5.0%	3.9 ¢ /kWh	
CC	600 US\$/kW	25	4.5%	2.4 ¢ /kWh	
Coal	938 US\$/kW	30	3.5%	1.5 ¢ /kWh	
Diesel	800 US\$/kW	15	3.0%	9.0 ¢ /kWh	


8

Screening curve analysis (1)



9

Screening curve analysis (2)



10

System reliability analysis


Step2: Relation between LOLE and reserve margin

- How much power supply does it need to meet the reliability criteria?
 - Reliability analysis (RETICS)

11

Relations between Reserve Capacity and LOLE


$$LOLE = \sum (P_i \times H_i)$$



12

Reliability analysis (1)


■ Whole system



13

Reliability analysis (2)


■ Divided systems



14


Reduction in reserve capacity

■ To maintain a desired LOLE value for each system and ascertain how the reserve capacity changes with or without an interconnection



15

Reduction in Reserve Capacity



16

Quantification of annual cost saving

■ Step3: Annual costs analysis

- How much annual cost does it need to operation?
 - Simulation concerning with daily operation (PDPAT II)

17

Function of PDPAT II

■ Computation of Annual Cost

- Capacity Cost
 - Depreciation
 - Maintenance
- Energy Cost
 - Fuel
 - Power Exchange

18

Function of PDPAT II

- Computation of Balance between Demand and Supply (Economic Dispatch)
 - Most Economical Energy Balance (Fuel Balance)
 - Optimal Power Balance
 - Reserve Margin
 - Fuel Consumption
- Computation of Power Exchange
 - Quantity & Frequency of Exchange
 - Economical Power Exchange

19


Input Data for PDPAT II

- Demand Data
 - Every Hour Data throughout a Year
- Power Development Plan
- Facility Data
 - Capacity
 - Generation Cost and its Breakdown (Construction, Fuel, O&M Cost *etc.*)
 - Forced & Scheduled Outage Rate
 - Operation Condition

20

Demand-and-Supply Simulation (1)


- Weekly operation N system



21

Demand-and-Supply Simulation (2)


- Weekly operation of C&S system



22

Demand-and-Supply Simulation (3)


- Power exchange



23

Optimal Composition

- Analysis of optimal PSPP install capacity



24

Power network of Vietnam in year 2020

- Outline of power network
- Series capacitors
- Impacts on power network by PSPP


25

Outline of power network

26

Existing 500 kV system

- Single circuit from north to south
- Series capacitors and shunt reactors installed




27

500 kV system Y2020

- Doubled with north-south 500 kV circuits
- Constructed in a net-shaped structure of north and south
- Extended to the power station areas in Laos and Cambodia


28

Sample power flow at peak in 2020



29

Sample power flow at off peak in 2020



30

Power flow at off peak in 2020

- Fully output Coal P/S in north
- Less output Gas P/S in south




- More power exchange from north to south than peak

31

1,000 MW PSPP to network

- Example of TEPCO




- 500 kV
 - Stable and more cost effective than 220 kV
- One circuit
 - Tokyo and Tohoku system : 50,000 MW (planning stage)
 - 8 % power/Hz
 - Dropping out of 1 circuit makes allowable frequency changes.

32

Example of PSPP operation at peak


- Full outputting at peak demand



33

Example of PSPP operation at off peak

- Pumping up at off peak demand



34

Series capacitors

35


Series capacitors and SSR

- Series capacitors compensate large line reactance.
- However, there is a possibility of causing SSR (subsynchronous resonance).

36

SSR

- Zero reactance of transmission lines and series capacitors for a lower frequency than 50 Hz.




- Series resonance or negative damping torque
- Possibility of causing **shaft torsional vibration** of turbine generators with long shafts.

37

Example of SSR


- Simple model with generator 3 mass system



38

Example of SSR


- Divergence of generator speed



39

Countermeasures against SSR

- Not installing series capacitors
- Reinforcing transmission lines without series capacitors
- Series capacitor with some filters



- Relays for generator tripping
- Auto network switching in case of SSR
- Applying shafts avoiding resonance
- Applying thyristor controlled devices
- Precise and cautious studies will be required on applying series capacitor.**

40

Impacts on power network by PSPP

41

Study flow

- PDP scenarios with PSPP
 - Economical operation
 - Largest power flow case
 - PSPP development scenarios
- Studies of impacts on power network by PSPP
 - Checking system performance
 - Giving information for comparison between scenarios

42



Checking system performance

- Power flow
 - Power flow analysis and loss comparison
 - Loss ratio to total demand will be about 2-3% in Y2020.
- Stability
 - In case of a fault at each 500 kV circuit
- Voltage
 - Differences in required reactive power in network
- Fault current
 - Confirmation of fault current at respective buses
 - Some 220 kV buses in south areas will exceeds 45 kA

43



Thank you

44