

APPENDIX-11

WASTEWATER TREATMENT PLANTS AND PUMPING STATIONS

Contents

A11.1	INTRODUCTION	A11-1
A11.2	PUMPING STATIONS AND SCREENS	A11-1
A11.2.1	MATADERO PUMPING STATION	A11-1
A11.2.2	CABALLERIA SCREEN FACILITY	A11-7
A11.2.3	CASABLANCA PUMPING STATION	A11-7
A11.2.4	REPUMPING STATION	A11-8
A11.3	NEW WASTEWATER TREATMENT PLANTS.....	A11-10
A11.3.1	LUYANÓ WWTP	A11-10
A11.3.2	TADEO WWTP	A11-27
A11.3.3	GUANABACOA WWTP	A11-28
A11.3.4	LA CUMBRE WWTP	A11-29

Figures:

FIGURE A11.1	Layout of Matadero Pumping Station	A11-30
FIGURE A11.2	Rehabilitation of Caballeria Screen Facility.....	A11-31
FIGURE A11.3	Rehabilitation of Casablanca Pumping Station (1/2)	A11-32
FIGURE A11.4	Rehabilitation of Casablanca Pumping Station (2/2)	A11-33
FIGURE A11.5	Repumping Station, Sedimentation and Sludge Treatment Facilities	A11-34
FIGURE A11.6	Layout of Luyano WWTP.....	A11-35
FIGURE A11.7	Hydraulic Profile of Luyano WWTP.....	A11-36
FIGURE A11.8	Primary Sedimentation Tank in Luyanó WWTP	A11-37
FIGURE A11.9	Aeration Tank in Luyano WWTP.....	A11-38
FIGURE A11.10	Final Sedimentation Tank in Luyano WWTP	A11-39
FIGURE A11.11	Sludge Thickener in Luyano WWTP	A11-40
FIGURE A11.12	Digestion Tank in Luyano WWTP	A11-41
FIGURE A11.13	Layout of Tadeo WWTP	A11-42
FIGURE A11.14	Layout of Guanabacoa WWTP	A11-43
FIGURE A11.15	Layout of La Cumbre WWTP	A11-44

A11.1 INTRODUCTION

In this appendix, the design concepts and design calculations of the wastewater treatment facilities and pumping stations are shown. The designs of these facilities are separately explained in Section A11.2 Pumping Stations and Screens (Matadero Pumping Station, Caballeria Screen Facility, Casablanca Pumping Station, Repumping Station) and Section A11.3 New Waste Water Treatment System (Luyanó WWTP, Tadeo WWTP, Guanabacoa WWTP, La Cumbre WWTP). All the designs are outline designs, which aim at approximate calculations of the sizes, required areas and costs of the facilities. Therefore, when more detailed design work will be carried out in the next step of the project, the baseline data will need to be reaffirmed.

A11.2 PUMPING STATIONS AND SCREENS

A11.2.1 MATADERO PUMPING STATION

The layout and profile of Matadero Pumping Station are shown in Figure A11.1. The design calculation of Matadero Pumping Station and the list of its equipment are shown in the following.

Matadero Pumping Station will need to cope with three different inflow conditions which occur 1) during and 2) after the rehabilitation of Colector Sur, and 3) in case Luyanó Left Colector (Area A) is connected to Matadero Pumping Station (an alternative plan of the Master Plan that need to be reviewed after the first stage of the project implementation). Therefore this pumping station is designed to deal with these different flow rates. The maximum hourly flow and required numbers of screens, grit chambers and pumps for the operation in each condition are shown in the following table.

The number of pumps in Matadero Pumping Station will be up to five. During the rehabilitation of Colector Sur, three pumps will be installed as temporary ones. Therefore any standby pump will not be installed during the rehabilitation. The numbers of screens and grit chambers to be constructed are designed based on the flow rate in the third condition which includes the wastewater discharged from Area A. However, the numbers of screens and grit chambers to be operated vary depending on the flow in each condition.

Required Numbers of Screens, Grit Chambers and Pumps for Operation

	Unit	During the Rehabilitation	After the Rehabilitation	Including Area A
Q maximum hourly flow	m ³ /sec	2.283	0.676	1.271
	m ³ /min	137.0	40.6	76.3
Coarse Screen	number	3	2	3
Fine Screen	number	3	2	3
Grit Chamber	number	3	2	3
Pumping Equipment				
Pump No.1 (20m ³ /min)	number	3	3 (1)	2
Pump No.2 (40m ³ /min)	number	2	-	2 (1)

Note ; (1) means that one standby pump is included

(1) Design Calculations**1) Pump Capacities and the Numbers of Pump Units**

The operation of the pumps is planned in view of different flow rates of influent as shown in the following tables.

	Capacity m ³ /min	During the Rehabilitation Number	After the Rehabilitation Number	Including Area A Number
Pump No.1	20	3	3 (1)	2
Pump No.2	40	2	-	2 (1)
Total Capacity		140	40	80

Note; () standby

a. Pump Operation Plan during the Rehabilitation

	Design Flow		Capacity	Number of Pump Units	
	m ³ /sec	m ³ /min	m ³ /min	Pump No.1	Pump No.2
Q average daily flow	1.473	88.38	100	3	1
Q maximum daily flow	1.738	104.28	100	3	1
Q maximum hourly flow	2.283	136.98	140	3	2

b. Pump Operation Plan in the case including Area A

	Design Flow		Capacity	Number of Pump Units	
	m ³ /sec	m ³ /min	m ³ /min	Pump No.1	Pump No.2
Q average daily flow	0.797	47.82	40	2	0
Q maximum daily flow	0.949	56.94	60	1	1
Q maximum hourly flow	1.271	76.26	80	2	1

c. Pump Operation Plan after the Rehabilitation (not including Area A)

	Design Flow		Capacity	Number of Pump Units	
	m ³ /sec	m ³ /min	m ³ /min	Pump No.1	Pump No.2
Q average daily flow	0.346	20.76	20	1	0
Q maximum daily flow	0.408	24.48	40	2	0
Q maximum hourly flow	0.676	40.56	40	2	0

2) Conditions of the Incoming and Discharge Sewers

Size of the incoming sewer 1,500 mm
 Bottom level of the incoming sew -5.55 M
 Pressure Pipe Bottom level 1.65 M
 Diameter 1,350 mm
 Length 1,020 m

Gravity Flow Pipe

Bottom level -2.10 M
 Diameter 1,500 mm

3) Pump Diameter

Pump No.1

$$D = 146 \sqrt{Q / v}$$

$$= 146 \sqrt{(400 / 2.5)} = 413.0 \quad 400$$

$$0.4$$

where D : Diameter(mm)
 Q : Pump Capacity (m³/min)
 v : Velocity(m/sec) 2.5 m/sec

Pump No.2

$$D = 146 \sqrt{Q / v}$$

$$= 146 \sqrt{(600 / 2.5)} = 584.0 \quad 600$$

$$0.6$$

4) Water Head

a. Suction water level = -5.55 M
 b. Pressure Pipe Pipe Bottom level 1.650 M
 Discharge water level = Pipe Bottom level + Diamet
 $= 1.650 + 1.35$
 $= 3.000 \text{ M}$

c. Actual Head; H

$$H = 3.000 - (-5.550)$$

$$= 8.55 \text{ m}$$

d. Total head loss by pump equipment

Pump No.1

$$V = q / A / 60 = 2.654 \text{ m/sec}$$

$$A = 1/4 \times \pi \times D^2 = 0.126 \text{ m}^2$$

Loss coefficients H_l

Inlet	0.10
Sluice valve	0.15
Check valve	1.20
Outlet	1.00
Bend	0.28
Friction los: $0.047 \times L / D =$	1.18
Sum	3.91

$$H1 = 3.91 \times v^2 / 2g \quad \text{Assumed Pipe Length} = 10 \text{ m}$$

$$= 1.40 \text{ m} \quad D = 0.4 \text{ m}$$

Pump No.2

$$V = 2.359 \text{ m/sec}$$

$$A = 0.283 \text{ m}^2$$

Loss coefficients H1

Inlet	0.10
Sluice valve	0.15
Check valve	1.20
Outlet	1.00
Bend	0.28
Friction los: $0.047 \times L/D$	0.78
Sum	3.51

$$H1 = 3.51 \times v^2 / 2g \quad \text{Assumed Pipe Length} = 10 \text{ m}$$

$$= 1.00 \text{ m} \quad D = 0.6 \text{ m}$$

e. Pressure Water Head Loss

Length of the Pressure Pipe L = 1,020 m D = 1.35 m

	During the Rehabilitation	Including Area A	After the Rehabilitation
Q (m ³ /min)	140	80	40
V = Q / A / 60 (m/sec)	1.63	0.93	0.47
A = $1/4 \times \pi \times D^2$ (m ²)	1.431	1.431	1.431
H2 = $6.82 \times (L/D^{1.17}) \times (V/CS)^{1.85}$			
(m)	2.02	0.72	0.20

f. Total Water Head Required

> During the Rehabilitation

Unit: m

Pump	H	H1	H2	Total Head	
No.1	8.55	1.40	2.02	11.98	12.0
No.2	8.55	1.00	2.02	11.57	12.0

> Including Area A

Unit: m

Pump	H	H1	H2	Total Head	
No.1	8.55	1.40	0.72	10.67	12.0
No.2	8.55	1.00	0.72	10.27	12.0

> After the Rehabilitation (Except for Area A)

Unit: m

Pump	H	H1	H2	Total Head	
No.1	8.55	1.40	0.20	10.15	12.0

5) Pump Equipment

Pump specifications		No.1	No.2
		Submerged Pump	
Diameter (mm)		400	600
Capacity (m ³ /min)		20	40
Total Dynamic Head (m)		12.0	12.0
Motor Output (kw)		75	120
Number of Pump Units	During the Rehabilitation	3	2
	Including Area A	5(1)	0
	After Rehabilitation	3(1)	0

Pump No.1

Shaft power

Shaft power of mixed flow centrifugal pumps

$$L = \frac{k \cdot \gamma \cdot Q \cdot H}{\eta}$$

where

L : Shaft power of a pump

k : k w

0.163

Q : Discharge (m³/min)

20

H : Total dynamic head(m)

12.0

γ : Specific gravity of water

1

η : Pump efficiency

0.76

$$= 51.47 \text{ kw}$$

Outputs of pump drivers

$$P = L(1+\alpha)/\eta$$

where

P : Pump power (k w)

L : Pump shaft power (kw)

51.47

α : Allowance for motor

0.15 for electric

η : Transmission efficiency

1.0 for direct connection

$$= 59.2$$

75 kw

Pump No.2

Shaft power

Shaft power of mixed flow centrifugal pumps

$$L = \frac{k \cdot \gamma \cdot Q \cdot H}{\eta}$$

where

L : Shaft power of pump	
k : k w	0.163
Q : Pump discharge (m ³ /min)	40
H : Pump total dynamic head(m)	12.0
γ : Specific gravity of water	1
η : Pump efficiency	0.79

$$= 99.04 \text{ kw}$$

Outputs of pump drivers

$$P = L(1+\alpha)/\eta$$

where

P : Pump power (k w)	
L : Pump shaft power (kw)	99.04
α : Allowance for motor	0.15 for electric
η : Transmission efficiency	1.0 for direct connection

$$= 113.9 \quad 120 \text{ kw}$$

(2) List of Mechanical Equipment

1) Screen System Equipment

No.	Equipment	Type	Size and Specifications	Qty	Output kW/unit	Total output(kW)
1	Screen channel influent gates	Cast iron made, manually operated sluice gate	1,500W x 1,500H	3	—	—
2	Coarse screens	Manually screened (removable type)	Clear opening 100 mm 1.4mW x 1.0mH x 60°	3	—	—
3	Fine screens	Mechanically-cleaned, (intermittently operated)	Clear opening 20 mm 1.4mW x 1.0mH x 75°	3	0.75	2.25
4	Grit collector	with bucket conveyor	1.7mW x 12.0mL	3	1	3
5	Grit chamber effluent gates	Cast iron made, manually operated sluice gate	700W x 700H	3	—	—
6	Screenings conveyors	Trough belt conveyor		2	1.5	3
7	Screenings skip hoist	Wire rope operated		1	2.2	2.2
8	Screenings hopper	Steel made, motor operated		1	1.5	1.5
9	Screening hoist	Motor operated hoist with trolley		1	2.6	2.6
10	Gritting conveyors	Trough belt conveyor		3	1.5	4.5
11	Gritting skip hoist	Wire rope operated		1	2.2	2.2
12	Screenings hopper	Steel made, motor operated		1	1.5	1.5
13	Screening hoist	Motor operated hoist with trolley		1	2.6	2.6
Total motor outputs of (1)						25.4

2) Pumping Equipment

No.	Equipment	Type	Size and Specifications	Qt'y	Output kW/unit	Total output(kW)
1	No.1 Pumps	Submersible pump	400mmΦ x 20m ³ /min. x 12m	3	75	225
2	Check valves	Slow-closing check valve		3	—	—
3	Discharge valves	Motor-operated butterfly valve		3	0.2	0.6
4	No.2 Pumps	Submersible pump	600mmF x 40m ³ /min. x 12m	2	120	240
5	Check valves	Slow-closing check valve		2	—	—
6	Discharge valves	Motor-operated butterfly valve		2	0.2	0.4
7	Crane for pumps	Manually-operated crane with chain block		1	—	—
8	Flow measurement equipment	Electro-magnetic flow meter		1	—	—
9	Generator Equipment		700KVA	1	—	—
Total motor outputs of (2)						466.0
Grand Total of Motor Outputs						491.4

A11.2.2 CABALLERIA SCREEN FACILITY

The Layout of Caballeria Screen Facility is shown in Figure A11.2. The equipment list of Caballeria Screen Facility is shown in the following table.

No.	Equipment	Type	Size and Specifications	Quantity	Output kW/unit	Total output(kW)	Remarks
1	Coarse screen	Cleaned manually (removable type)	Clear opening 100 mm	1	—		Existing
2	Screen	Cleaned mechanically (intermittently operated)	Clear opening 50 mm	3	0.75	2.25	One unit Existing
3	Effluent gate of a grit chamber	Steel plate manually operated	1200W x 1200H	1	—		Existing
4	Bypass gate	Steel plate manually operated	1200W x 1200H	1	—		
5	Air lift pump		150F x 1.0m ³ /min	6	—		
6	Blower	Root type	65mm×3.2m ³ /min	2 (1)	5.5	5.5	Standby excluded
Ground Total of Motor Output						7.75 kw	

A11.2.3 CASABLANCA PUMPING STATION

Figure A11.3 and Figure A11.4 show the layout and profile of Casablanca Pumping Station that are designed for its rehabilitation. The equipment list of Casablanca Pumping Station is shown in the following table.

No.	Equipment	Type	Size and Specifications	Qt'y	Output kW/unit	Total out-put(kW)	Remarks
1	Influent gates	Cast iron made, manually operated sluice gate	1200W x 1200H	4	—	—	
2	Pump	Submersible pump	900mmF x 1.75m ³ /min. 200kw x 60Hz	4 (1)	200	600	Standby excluded
3	Check valves	Slow-closing check valve	900F	4 (1)	—	—	Standby excluded
4	Water level gage	Immersion type		2	—	—	
5	Flow measurement equipment	Ultra-sonic type		1	—	—	Settled in tunnel
6	Flower drain pumps	Submersible pump	65Φ x 0.3m ³ /min	2 (1)	1.5	1.5	Standby excluded
13	Generator	Diesel engine type	1500KVA	1			
Ground Total of Motor Output						601.5 kw	

A11.2.4 REPUMPING STATION

The water head loss occurred for the discharge of effluent into the open sea will increase after the renewal of the outfall sewer. Therefore a pumping station is necessary after the tunnel to pump up again and discharge the effluent into the open sea through the outfall sewer. This Repumping Station is planned along with sedimentation basins and sludge treatment facilities in case the sedimentation treatment of the effluent will be required in the future. Supposed that the sedimentation and sludge treatment facilities are constructed in the same site as the repumping station, the layout of those facilities are shown in Figure A11.5.

The outlines of the repumping station, sedimentation and sludge treatment facilities are shown in the following tables.

(1) Outline of the Repumping Station

1. Design Flow:

Q hourly maximum flow	5.2m ³ /sec	Same as Casablanca Pumping Station
-----------------------	------------------------	------------------------------------

2. Main Facilities

Facility	Quantity	Size, Capacity, Specification	Remark
1. Influent gate	3 Units	Cast iron made, manually Operated	
2. Fine screen	3 Units	Openings of 20mm Cleaned mechanically (Intermittently operated)	
3. Submersible pump	4 (1) Units	900mmF x 1.75m ³ /min. x 8m	Same as Casablanca Pumping Station
4. Generator	1 Unit	Diesel engine type 1500KVA	

(2) Outline of sedimentation and sludge treatment facilities**1) Design Flow**

Q daily maximum flow (Q d)	272,000 m ³ /day
Q hourly maximum flow (Q h)	329,000 m ³ /day

2) Wastewater Quality

Parameter	Raw Wastewater (mg/l)	Removal Efficiency (%)	Treated Wastewater (mg/l)	The Great Caribbean
BOD ₅	190	30-50	133-95	< 150
SS	190	40-60	114-76	< 150

3) Main Facilities

Facility	Quality	Size, Capacity, Specification	Remarks
1.Sedimentation tank	8 Units	12.0mWx 41.0mLx 3.0mH 69 m ³ /m ² /day (: Qd) 84 m ³ /m ² /day (: Qh)	Surface loading 70m ³ /m ² /day
2.Mechanical dewatering Belt filter press	12 Units	Filter width :3m	Filter loading rate 140kg/m/hour Daily operation time ;6hour/day Working days /week ;5day

$$\begin{aligned}\text{Solid Production} &= Q_d \times SS \times 10^{-6} \times 0.4 \text{ (Removal rate)} \\ &= 272,000 \text{ m}^3/\text{day} \times 190 \times 10^{-6} \times 0.4 = 20.7 \text{ t/day}\end{aligned}$$

A11.3 NEW WASTEWATER TREATMENT PLANTS

A11.3.1 LUYANÓ WWTP

The layout and hydraulic profile of Luyanó WWTP are shown in Figures A11.6 and A11.7. The designs of the main facilities in Luyanó WWTP are shown in Figures A11.6 to 12. The design calculation and equipment lists of Luyanó WWTP are shown in the following tables.

(1) Design Calculation

1) Design Basis

a. Design Wastewater Inflow

Unit :m³ /d

	Total		Collector	
	Design Inflow	Estimated Inflow	Luyano Martin Perez	Luyano Left Bank
Q average daily flow	60,000	59,650	26,423	33,227
Q maximum daily flow	71,000	70,924	31,419	39,505
Q maximum hourly flow	119,000	118,572	53,732	64,840

b. Design Wastewater Quality

	mg/l
BOD ₅	200
TSS	200

Parameter	Removal Efficiency (%)			Wastewater Quality (mg/l)		
	Primary Treatment	Secondary Treatment	Overall Removal Rate	Raw Wastewater	Primary Effluent	Secondary Effluent
BOD ₅	30	86	90.2	200	140	19.6
TSS	40	84	90.4	200	120	19.2

c.Flow Sheet

```

graph LR
    Influent --> Screen
    Screen --> IP[Influent Pump]
    IP --> GC[Grit Chamber]
    GC --> PST[Primary Sedimentation Tank]
    PST --> AT[Aeration Tank]
    AT --> FST[Final Sedimentation Tank]
    FST --> Effluent
    PST -.-> ST[Sludge Thickener]
    FST -.-> ST
    ST -.-> SD[Sludge Digester Non Heating]
    SD -.-> MD[Mechanical Dewatering]
    MD -.-> Disposal
  
```

————— Water Flow

- - - - - Sludge Flow

2) Sludge Volume

a. Raw Sludge

Raw sludge production volume is calculated by the following equation.

$$\begin{aligned} \text{Solid Production} &= Q_d \times \text{TSS} \times 10^{-6} \times 0.4 \\ &= 71,000 \times 200 \times 10^{-6} \times 0.4 = 5.68 \\ \text{Assumed sludge concentration is} &= 3 \% \\ \text{Sludge Volume} &= \frac{5.68}{3} \times 100 = 189 \text{ m}^3/\text{day} \end{aligned}$$

b. Excess Sludge

$$\begin{aligned} \text{Solid Production} &= Q_d \times (120 - 19.2) \times 10^{-6} = 7.16 \text{ t/day} \\ \text{Assumed sludge concentration is} &= 0.8 \% \\ \text{Sludge Volume} &= \frac{7.16}{0.8} \times 100 = 895 \text{ m}^3/\text{day} \end{aligned}$$

c. Thickened Sludge

Thickened sludge production volume is calculated by the following equation

$$\begin{aligned} \text{Sludge Solid} &= \text{Raw Sludge} + \text{Excess Sludge} \\ &= 5.68 + 7.16 = 12.84 \text{ t/day} \\ \text{Assumed sludge concentration is} &= 1 \% \\ \text{Sludge Volume} &= \frac{12.84}{1} \times 100 = 1,284 \text{ m}^3/\text{day} \\ \text{Assumed sludge concentration is} &= 3 \% \\ \text{Sludge Volume} &= \frac{12.84}{3} \times 100 = 428 \text{ m}^3/\text{day} \end{aligned}$$

d. Digested Sludge

$$\begin{aligned} \text{Input solids} &= 12.84 \text{ t/day} \\ \text{Input sludge volume} &= 428 \text{ m}^3/\text{day} \\ \text{Volatile solid contents of sludge} &= 70 \% \\ \text{Solid destruction rate} &= 50 \% \\ \text{Digested sludge solids} &= 12.84 \times (1 - 0.7 \times 0.5) \\ &= 8.34 \text{ t/day} \end{aligned}$$

e. Sludge Dewatered Mechanically

(Digested Sludge)

$$\begin{aligned} \text{Assumed sludge concentration is} &= 20 \% \\ &= \frac{8.34}{20} \times 100 = 41.7 \text{ t/day} \\ \text{Sludge Volume} &= \frac{41.7}{1} \times 100 = 4,170 \text{ m}^3/\text{day} \\ \text{Sludge Weight} &= 41.7 \times 1 \text{ t/m}^3 = 41.7 \text{ t/day} \\ \text{Polymer addition rate} &= 1 \% \\ &= \frac{41.7}{100} \times 0.01 = 0.00417 \text{ t/day} \end{aligned}$$

3) Coarse Screen

Design Flow

	Luyano Martin Perez Colector		Luyano Left Bank Colector	
	m/sec	m ³ /min	m/sec	m ³ /min
Qhour	0.622	37.3	0.751	45.1
Inlet Pipe Bottom Level (M)		-6.82		-1.00

Channel Width	1.2 m	
Screen Openings	100 mm	
No. of Screens	4 unit	
Slope of Screens	60 degrees from horizontal	
Screen Bottom Level	-7.00 M	Low stage (L,M,P,C)
	-1.20 M	Hight Stage (L,L,B,C)

Grit Pit

Grit pits are set up to subsidence gravel and sand of large size.

Grab buckets etc. are used to remove them from the grit pits.

Pit Width	1.2 m
Pit length	1.2 m
number	4 unit

4) Fine Screen

Channel Width	1.2 m
Depth	0.7 m
Bar Screen Clear Opening	20 mm
Thickness of Screen Bar	8 mm
Slope of Screens	75 degrees from horizontal
Out Put	1.5 kw
No. of Screen Bar	4 units

5) Influent Pumping Station

a. Design Flow

	Luyano Martin Perez Colector		Luyano Left Bank Colector	
	m/sec	m ³ /min	m/sec	m ³ /min
Q hour	0.622	37.3	0.751	45.1

b) Submerged Pump**Luyano Martin Perez Colector (Lower water level)**

> Design Flow

Q hour	37.3	m ³ /min
--------	------	---------------------

> Pump Capacity

No.1

Pump Capacity	19 m ³ /min	
Diameter	450 mm	$d=146(Q/v)^{0.5}$
Total Dynamic Head	17.0 m	$v = 2.0$
Motor Output	90 kw	
Number of Pumps	2 units	(1standby)

No.2

Pump Capacity	9.5 m ³ /min	
Diameter	300 mm	$d=146(Q/v)^{0.5}$
Total Dynamic Head	17.0 m	$v = 2.0$
Motor Output	45 kw	
Number of Pumps	2 units	

> Water Head

Suction water level: a) (Pipe Bottom level=)	-7.00 M
Discharge water level: b)	9.00 M
Actual Water Head; H1 = b) - a) =	16.00 m
Total water head loss at pump equipment:	

			Pump No.1	Pump No.2
Pump Velocity	$q/A/60=$	m/sec	1.992	2.241
Area	$1/4 \times \pi D^2=$	m ²	0.159	0.071
Diameter		m	0.450	0.300

Loss coefficients H1

		Pump No.1	Pump No.2	Remark
Inlet		0.10	0.10	
Sluice valve		0.15	0.15	
Check valve		1.2	1.2	
Outlet		1	1	
Bend		0.28	0.28	assumed
Friction loss	$0.047 \times L/D=$	1.044	1.567	L=10m
Sum	(S)	3.77	4.30	

H1 (S) $\times V^2/2g=$ 0.77 m 0.983 m

Total head required

	Pump No.1	Pump No.2
H1	16.00 m	16.00 m
H1	0.77 m	0.98 m
H1 + H1	16.77 m	16.98 m
use		17.0 m

Shaft power

Pump No.1

Shaft power of mixed flow centrifugal pumps

$$L = \frac{k \cdot \gamma \cdot Q \cdot H}{\eta}$$

where

L	: Shaft power of pump	
k	: kw	0.163
Q	: Pump discharge (m ³ /min)	19
H	: Pump total dynamic head(m)	17.0
γ	: Specific gravity of water	1
η	: Pump efficiency	0.76

$$= 69.28 \text{ kw}$$

Outputs of pump drivers

$$P = L(1+\alpha)/\eta$$

where

P	: Pump power (kw)	
L	: Pump shaft power (kw)	69.28
α	: Allowance for motor	0.15 for electric
η	: Transmission efficiency	1.0 for direct connection

$$= 79.67 \text{ kw}$$

Pump No.2

Shaft power of mixed flow centrifugal pumps

$$L = \frac{k \cdot \gamma \cdot Q \cdot H}{\eta}$$

where

L	: Shaft power of pump	
k	: kw	0.163
Q	: Pump discharge (m ³ /min)	9.5
H	: Pump total dynamic head(m)	17.0
γ	: Specific gravity of water	1
η	: Pump efficiency	0.76

$$= 34.64 \text{ kw}$$

Outputs of pump drivers

$$P = \frac{L(1+\alpha)}{\eta}$$

where

P : Pump power (k w)

L : Pump shaft power (kw) 34.64

α : Allowance for motor 0.15 for electric

η : Transmission efficiency 1.0 for direct connection

$$= \frac{39.83}{1.0} = 39.83 \text{ kw}$$

Luyano Left Bank Colector (Higher Water Level)

> Design Flow

Q hour	45.1	m ³ /min
--------	------	---------------------

> Pump Capacity

No.3

Pump Capacity 23 m³/min

Diameter 450 mm $d=146(Q/v)^{0.5}$

Total Dynamic Head 11.0 m $v = 2.5$

Motor Output 55 kw

Number of Pumps 2 units

> Head

Suction water level: a) (Pipe Bottom level=) -1.20 M

Discharge water level: b) 9.00 M

Actual Head; H1 = b) - a) = 10.20 m

Total head loss at pump equipment:

		unit	Pump No.3
Pump Velocity	$q/A/60=$	m/sec	2.411
Area	$1/4 \times \pi D^2=$	m ²	0.159
Diameter		m	0.450

Loss coefficients H1

		Pump No.3	Remark
Inlet		0.10	
Sluice valve		0.15	
Check valve		1.2	
Outlet		1	
Bend		0.28	assumed
Friction loss	$0.047 \times L/D=$	1.044	L=10m
Sum	(S)	3.77	

$$H1 = (S) \times V^2/2g = 0.93 \text{ m}$$

Total head required

Pump No.3			
H1		10.2	m
H1		0.93	m
H1+ H1		11.13	m
use		11.0 m	

6) Grit, Oil/Sand Removal Equipment

a. Design Flow

	m ³ /day	m ³ /hour	m ³ /sec
Qaverage	60,000	2,500	0.694
Qday (max)	71,000	2,958	0.822
Qhour (dry)	119,000	4,958	1.377

b. Tank Geometry

Grit Chamber

Surface Load	1,800 m ³ /m ² /day
sand specific gravity	2.65
Required Surface Area	66.1 m ²
Trains	4 Channels
Width	1.5 m
Height	0.7 m
Length	10 m
Velocity	0.33 m/sec
Detention Time	30.5 sec

Oil Separator (if necessary)

Required Retention Time	5 min (5-30min)Quib WWTP
Required Volume	413 m ³

Trains	4 Channels
Width	4.0 m
Height	2.0 m
Length	11.6 m

7) Flow Measurement

Select 3ft (91.44cm) flume, the range of measurable flow	0.0173-1.43 m ³ /s
No. of Flow Measurs	1 unit

8) Primary Sedimentation Tank

Design Flow

Q _{day} (max)	71,000	m ³ /day
------------------------	--------	---------------------

Overflow Rate	50 m ³ /m ² /day
Tanks	16 basins
Influent to Each Tank	4,438 m ³ /day/basin
Required Surface Area of Each Tank	89 m ²
Retention Time	1.5 hour

a. Tank Geometry

Width	5.0 m			
Tank Length	88.8	÷	5.0	= 17.75 m
Effective Depth	3.0 m		use	17.8 m
Number of Basins	16 basins			

Tank Geometry					
W	5.0 m	×	H 3.0 m	×	16 basins
L	17.8 m				(8 tanks)

Check

Basin Capacity	4,272 m ³
Retention Time	Q _{day} (max)= 1.44 hour
Overflow Rate	50 m ³ /m ² /day

b. Raw Sludge Pumping Equipment

Sludge Volume	1,284 m ³ /day = 0.891 m ³ /min
Pump Type	Centrifugal Screw Pump
Pump Bore Size	100 mm
Delivering Capacity	0.5 m ³ /min
Total Dynamic Head	10 m
Motor Output	3.7 kw
Number of Pumps	8 units (including 4 standby)

9) Aeration Tank

Design Flow

Q _{day} (max)	71,000	m ³ /day
------------------------	--------	---------------------

BOD-SS load	0.35 kg BOD/kgSS/day
MLSS	1,600 mg/l

$$\begin{aligned}
 &\text{Return Sludge Solid Concentration} && 8,000 \text{ mg/l} \\
 &\text{Sludge Return Ratio} && = \frac{1,600}{0.25} \div \left(\frac{8,000}{0.25} - 1,600 \right) \\
 &\text{Inflow BOD to Reactors} && 71,000 \times \frac{200}{(1-0.3)} \times 10^{-3} = 9,940 \text{ kgBOD/day} \\
 &\text{Reactor Tanks SS} && V \times 1,600 \times 10^{-3} \text{ kgMLSS} \\
 &\text{Required Tank Capacity} && 9,940 \div 1.6 \div 0.35 = 17,750 \text{ m}^3 \\
 &\text{Aeration Time} && 6.0 \text{ hour} \\
 &\text{Retention Time} && 6.0 \text{ hour} \\
 &\text{Required Volume} && 17,750 \text{ m}^3
 \end{aligned}$$

a. Tank Geometry

$$\begin{aligned}
 &\text{Width} && 5.0 \text{ m} \\
 &\text{Effective Depth} && 5.0 \text{ m} \\
 &\text{Cross Sectional Area} && 5.0 \times 5.0 - \frac{1}{2} \times 1.0^2 \times 2 - \frac{1}{2} \times 0.6^2 \times 2 \\
 &&& = 23.75 \text{ m}^2 \\
 &\text{Number of Tanks} && 16 \text{ tanks or} \\
 &\text{Capacity of One Tank} && 1,109 \text{ m}^3 \\
 &\text{Tank Length} && 46.71 \text{ use } 47.0 \text{ m}
 \end{aligned}$$

Tank Geometry				
W	5.0	m	×	L 47.0 m
H	5.0	m	×	16 tanks

Check

Volume	m ³	17,750
Retention Time	hour	6.00

b. Blower

$$\begin{aligned}
 &\text{Blower Volume} && 5 \text{ Q assuming} \\
 &&& 355,000 \text{ m}^3/\text{day} = 246.5 \text{ m}^3/\text{min} \\
 &&& \text{use } 250 \text{ m}^3/\text{min}
 \end{aligned}$$

$$\begin{aligned}
 &\text{Blowers} && \text{Multiple step blower manufactured by steel board} \\
 &\text{Size and Specification} && 300/250 \text{ mm } 63 \text{ m}^3/\text{min}/\text{unit} \\
 &\text{Output} && 90 \text{ kw} \\
 &\text{Unit} && 5 \text{ units (including 1 standby)}
 \end{aligned}$$

10) Secondary Sedimentation Tank

Design Flow

Q _{day} (max)	71,000	m ³ /day
------------------------	--------	---------------------

Overflow Rate	25 m ³ /m ² /day
Total tank number is	16 tanks
Influent to Each Tank	4,438 m ³ /day/tank
Required Surface Area of Each Tank	177.5 m ²

a. Tank Geometry

Width	5.0 m			
Tank Length	177.5	÷	5.0	= 35.50 m
Effective Depth	3.0 m		use	35.5 m
Number of Basins	16 basins			

Tank Geometry				
W	5.0 m	×	H 3.0 m	×
L	35.5 m			16 basins
				(8 tanks)

Check

Surface Area	m ²	2,840	
Surface Load Rate	m ³ /m ² /day	25.0 = 25	m ³ /m ² /day
Retention Time	hour	3.4	

b. Excess Sludge Pumping Equipment

Excess Sludge Volume	895 m ³ /day=	0.62 m ³ /min
Pump Type	Submersible pump	
Delivering Capacity	0.5 m ³ /min	
Total Dynamic Head	6.0 m	
Motor Output	3.7 kw	
Number of Pumps	4 units (including 2 standby)	

c. Return Sludge Pumping Equipment

Average Sludge Return	25 %			
Return Sludge Volume	71,000	×	0.25	= 17,750 m ³ /day
(Average)				= 12.33 m ³ /min
(Max)	50 %	71,000	×	0.5 = 24.65 m ³ /min

Pump Type	Submersible pump
Diameter	250 mm
Capacity	3 m ³ /min
Total Dynamic Head	6.0 m
Motor Output	11 kw
Number of Pumps	8 units

11) Sludge Thickeners

Hydraulic Capacity of Tanks

	units		
Solids Input	t/day	12.84	
Input Sludge Volume	m ³ /day	1284	
		1.0 %assume	
Output Sludge Volume	m ³ /day	428	
		3.0 %assume	

Floor Loading 60 kg/m²/day

Required Surface Area 213.9 m²

a. Tank Geometry

Pump Type Circular Flow Type
 Internal Diameter 12.0 m
 Effective Depth 3.0 m
 Number of Tanks 2 unit

Check

	units	
Water Surface Area	m ²	288.0
Floor Loading	kg/m ² /day	44.6

b. Sludge Digester


Hydraulic Capacity of Tanks

	units		
Solids Input	t/day	12.84	
Input Sludge Volume	m ³ /day	428	
		3.0 %assume	
Output Sludge Volume	m ³ /day	428	
		3.0 %assume	

Retention Time 20.0 day

Required Volume 8,558 m³

Pump Type Circular Radial Flow Type
 Internal Diameter 17.8 m
 Effective Depth 8.9 m
 Number of Tanks 4 units



$$\text{Volume of Tanks} \quad 3.14/4 \times D^2 \times H = 2,214 \text{ m}^3/\text{tank}$$

Check

	unit	
Volume of Tanks	m ³	8,854
Retention Time	day	20.7

13) Mechanical Sludge Dewatering

Filter Capacity Calculation

	unit	
Solids Input	t/day	8.43

Yield per Unit Length 110 kg/m/hr

Filter Width 3 m

Daily Operation Time 6 hr

Working Days/Week 5 day

Solid Load per Hour

$$= 8.43 \times 7 / 5 \times 10^3 / 6$$

$$= 1,966 \text{ kg/hour}$$

Required Number of Belt Press

$$= 1,966 / 110 / 3$$

$$= 6.0 \text{ use } 6 \text{ unit}$$

Type Belt Filter Press

Filter Loading Rate 110 kg/m/hr

Filter Width 3 m

Motor Output 2.2 kw

Number of Filters 6 units

(2)List of Mechanical Equipment**1) Screen System Equipment**

No.	Equipment	Type	Size and Specification	Qt'y	Output kW/unit	Total output(kW)	Remarks
1	Screen channel influent gates	Cast iron made, manually operated sluice gate	700W x 700H	4	—	—	
2	Coarse screens	Manually screened (removable type)	Clear opening 100 mm 1.4mW x 1.0mH x 60°	4	—	—	
3	Fine screens	Mechanically-cleaned, (intermittently operated)	Clear opening 20 mm, 1.4mW x 1.0mH x 75°	4	0.75	3	
4	Grab bucket			2	—	—	
5	Grit chamber effluent gates	Cast iron made, manually operated sluice gate	700W x 700H	4	—	—	
6	Screenings conveyors	Trough belt conveyor		2	1.5	3	
7	Screenings skip hoist	Wire rope operated		1	—	2.2	
8	Screenings hopper	Steel made, motor operated		1	—	1.5	
9	Screening hoist	Motor operated hoist with trolley		1	—	—	
10	water level gage	Immersion type		2	—	—	
11	Floor drain pumps	Submersible pump	65mmΦ x 0.3m ³ /min. x10m	2 (1)	1.5	1.5	Standby excluded
	Total motor outputs of (1)					11.2	kW

2) Grit Chamber, Flow measurement Equipment

Gravity Tyoe Grit Chamber 1.5mWx0.7mHxL10.0mx4Channels

No.	Equipment	Type	Size and Specifications	Qt'y	Output kW/unit	Total output(kW)	Remarks
1	Grit channel Influent channel gates	Manually operated, cast iron sluice gate	700mmWx700mmH design hydraulic depth;2m	4	—	—	
2	Grit collector	Trolley with grit lifting pump	125mm x 15m ³	2	—	—	
3	Blowers	turbo blower		1	15	15	
4	Grit channel effluent channel gates	Manually operated, cast iron sluice gate	700mmWx700mmH design hydraulic depth;2m	4	—	—	
5	Flow measurement equipment	Parshall flume	3 ft,type	1	—	—	
	Total motor outputs of (2)					15	kW

3) Pumping Equipment

No.	Equipment	Type	Size and Specifications	Qt'y	Output kW/unit	Total output(kW)	Remarks
1	No.1 Pumps	Submersible pump	300mmF x 9.5m ³ /mi x17m	2	45	90	
2	Check valves	Slow-closing check valve		2	—	—	
3	Discharge valves	Motor-operated butterfly valve		2	0.2	0.4	
4	No.2 Pumps	Submersible pump	450mmF x 19m ³ /mi x17m	2 (1)	90	90	Standby excluded
5	Check valves	Slow-closing check valve		2	—	—	
6	Discharge valves	Motor-operated butterfly valve		2	0.2	0.4	
7	No.3 Pumps	Submersible pump	450mmF x 23m ³ /mi x11m	2	55	55	
8	Check valves	Slow-closing check valve		2	—	—	
9	Discharge valves	Motor-operated butterfly valve		2	0.2	0.4	
10	Crane for pumps	Manually-operated crane with chain block		1	—	—	
	Total motor outputs of (3)					236.2 kW	

4) Primary Sedimentation Tanks(8Tanks)

W5m x L18m x 16Channels(8Tanks)

No.	Equipment	Type	Specifications	Qt'y	Output kW/unit	Total ouput	Remarks
1	Distribution tank gate	Sluice gate, manual operated cast iron, rectangular	300W x 300H.Design hydraulic depth,0.7m	4	—	—	
2	Inlet gates	Sluice gate, manual operated cast iron, rectangular	300W x 300H.Design hydraulic depth,0.7m	16	—	—	
3	Sludge collector	Chain flight method 2 units 1 drive	W10m x L18m x H3.0m	8	0.75	6	w10=w5x2channels
4	Sludge draw-off valve	Motor operated eccentric	200mmF	16	0.2	3.2	
5	Raw sludge pumps	Non-clog centrifugal pump	100mmFx1m ³ /min .x10m	4 (2)	3.7	7.4	Standby excluded
6	Bypass gates	Manually operated, cast iron made, circular sluice gate	F1,000mm.Design hydraulic depth,1.5m	2	—	—	
7	Raw sludge flow meter	Electro-magnetic flow meter	100mmF	2	—	—	In electric works
8	Raw sludge densitometer	Ultra-sonic type		2	—	—	
	Total motor output of (4)					16.6	kW

5) Aeration Tanks (16 tanks)

W5m x L55mx H5mx16Tanks

No.	Equipment	Type	Specifications	Qt'y	Output kW/unit	Total ouput	Remarks
1	Inflow control weirs	Manually operated movable weirs	400W x 600H.Design hydraulic depth,0.7m	16	—	—	
2	Movable weirs for control of step inflow	Cast iron made, movable weirs	400W x 600H.Design hydraulic depth,0.7m	64	—	—	
3	Return sludge inflow control weirs	Cast iron made, movable (separate type)	600W x 600H.Design hydraulic depth,0.7m	16	—	—	
4	Aeration diffusers	Ceramic made diffuser (fine bubble, 300μ)	0.82m ³ /min. 8plates/holder header		—	—	SUS holder headers, & butterfly valves
5	Air control valves	Air operated butterfly valve	250mmF	16	—	—	Electro-magnetic box
6	Froth spray nozzles	Cast iron made movable type	15mmFx 8l/min. x 1kg/cm ²	592	—	—	1.5 m interval 55/1.5=37units./tank
7	Air flow meters	Oriffice	250mmF	4	—	—	Included in electric works
	Total motor output of (5)					0	kW

6) Final Sedimentation Tanks (8 tanks)

W5m x L35.5m x H3.0m x 16 Channels (8 Tanks)

No.	Equipment	Type	Size and Specifications	Qt'y	Output kW/unit	Total output	Remarks
1	Inlet gates	Sluice gate, manual operation, cast iron	300W x 300H Design hydraulic depth, 0.7m	16	—	—	
2	Sludge collector	Chain flight method 2 units 1 drive	W10m x L35.5m x H3.0m	8	1.5	12.0	w10= w5x2channels
3	Telescope pipe		200mmF	16	—	—	
4	Return sludge pumps	Submersible pump	250mmF x 3.0m ³ /min, x 6m	8	11	77.0	
5	Excess sludge pumps	”	100mmF x 0.5m ³ /min. x 6m	8 (4)	3.7	14.8	Standby excluded
6	Return sludge flow meters	Electronic-magnetic flow meter	250mmF	4	—	—	Included in electric works
7	Excess sludge flow meters	Electronic-magnetic flow meter	100mmF	4	—	—	”
8	Return sludge densitometers	Ultra-sonic type	250mmF	4	—	—	”
	Total motor output of (6)					103.8 kW	

7) Sludge Thickeners (2 tanks)

D12.0 m x H3.0m x 2 Tanks

No.	Equipment	Type	Size and Specifications	Qt'y	Output kW/unit	Total output	Remarks
1	Sludge thickeners	Rotating scraper, with pickets	12.0mF x 3.0mH	2	0.4	0.8	
2	Distribution tank, movable weirs	Manually operated, cast iron weir	300mmW	2	—	—	
3	Sludge draw-off pump	Non-clog centrifugal pump	100mmF x 0.5m ³ /min x 10m	2 (1)	15	15	Standby excluded
4	Sludge draw-off valve	Air operated eccentric valve	100mmF	2	0.2	0.4	
	Total motor outputs of (7)					16.2 kW	

8) Sludge Digestion Facilities (4 digesters)

No.	Equipment	Type	Size and Specifications	Qt'y	Output kW/unit	Total output	Remarks
1	Scum draw-off valves	Motor operated eccentric valve.	100mmF x 0.5m ³ /min x 10m	4 (2)	15	30	Standby excluded
2	Digested sludge draw off valves	Motor operated eccentric valve.	100mmF	4	0.2	0.8	
3	Sludge mixer	Gas stirring device.		4	—	—	
4	Compressor for gas stirring.			4 (2)	1.5	3	Standby excluded
	Total motor outputs of (8)					33.8 kW	

9) Sludge Dewatering Equipment

No.	Equipment	Type	Size and Specifications	Qt'y	Output kW/unit	Total output	Remarks
1	Sludge storage tank mixers	Vertical paddle type	2,000mmF	2	7.5	15	
2	Sludge feed pumps	Positive displacement pump	100mmF x 20m ³ /hr. x 20m	6	5.5	33	
3	Sludge dewatering	Belt filter press	3 m effective belt width	6	4.85	29.1	
4	No.1 Cake conveyor	Trough belt	600mmW x 8,500mmL	2	1.5	3	
5	No.2 Cake conveyor	Horizontal trough belt conveyor	600w x 5,500L	2	1.5	3	
6	Cake hoppers	Motor operated	10m ³	2	3.7	7.4	
7	Chemical container	Cylinder type	700 L	2	—	—	
8	Chemical feeders	Volumetric dry feeder	4L/min.	2	0.4	0.8	
9	Chemical dosage tank	Cylinder type	10m ³ capacity	2	5.5	11	
10	Chemical feed pump	Positive displacement pump	50mmF x 3m ³ /hr x 20m	2	1.5	3	
11	Chemical container hoists	Motor operated	1 ton	1	1.5 0.4	1.5	
12	Pumps for belt filter cleaning water	Centrifugal pump	50mmF x 0.3 m ³ /min. x 60 m	2 (1)	7.5	7.5	Standby excluded
13	Maintenance crane	Suspension type	2 ton	1	—	—	
14	Chain block	Geared trolley type	2 ton	1	—	—	
15	Floor drain pumps	Submersible non-clog pump	65mmF x 0.3m ³ /min. x 10 m	1	5.5	5.5	
	Total motor outputs of (9)					119.8	kW

10) Aeration Tank Blower System

No.	Equipment	Type	Size and Specifications	Qt'y	Output kW/unit	Total output	Remarks
1	No.1 Blowers	Multiple step blower	300mm/250 mm	5	—	—	
		manufactured by the steel boiler	62m ³ /min	(1)			
2	Electric motors for No.1 blowers			5 (1)	90	360	Standby excluded
3	No.1 blower valves	Electric-operated valve	250mm	5 (1)	0.4	1.6	Standby excluded
4	Maintenance crane	Geared trolley type	3 tons	1	—	—	
	Total motor outputs of (10)					361.6	kW
	Grand Total of Motor Outputs					914.2	kW

A11.3.2 TADEO WWTP

The Outline of Tadeo WWTP is shown in the following and the layout of Tadeo WWTP is shown in Figure A11.13.

(1) Design Flows (m³/day)

Qaverage	9,400
Qdaily maximum flow	11,200
Qhourly maximum flow	22,900

(2) Wastewater and Sludge Treatment Process

Wastewater Treatment: Conventional activated sludge process

Sludge Treatment: Sludge thickening → Anaerobic Digestion without any heating system → Mechanical Dewatering (70%) + Drying bed (30%)
→ (Sanitary Landfill)

(3) Design Wastewater Quality

Parameter	Treatment Efficiency (%)			Design Treated Wastewater Quality (mg/L)		
	Primary	Secondary	Overall	Influent	Primary Effluent	Secondary Effluent
BOD ₅	30	86	90.2	210	147	20.6
SS	40	84	90.4	210	126	20.2

(4) Main Facilities

Facility	Facility Type	Quality	Size, Capacity, Specs	Remarks
1.Submersible pumps		3(1)units	300mmFx8m ³ /min	1standby
2.Primary sedimentation tank		4units	6.0mWx9.5mLx3.0mH	Surface loading 50m ³ /m ² /day
3.Aeration tank		4units	6.0mWx25.0mL x5.0mH	BOD-SS loading: 0.35kgBOD/kgSS/day Retention time 6hours 1standby、5Q
	Rotary Blower	3(1)units	F150mmx19m ³ /min	
4.Final sedimentation tank		4units	6.0mWx18.7mL x3.0mH	Surface loading: 25m ³ /m ² /day
5.Sludge thickener		2units	4.5mWx4.5mLx4.0mH	Floor loading: 60kg/m ² /day
6.Sludge digester		2units	13.5mWx13.5mLx4.0mH	Retention time: 20days
7.Mechanical dewatering Belt filter press		2units	Filter width: 1.5m	Filter loading rate: 90kg/m/hour
8.Drying bed		1,300m ²	Water depth 0.2m	Retention time: 11days

A11.3.3 GUANABACOA WWTP

The Outline of Guanabacoa WWTP is shown in the following and the layout of Guanabacoa WWTP is shown in Figure A11.14.

(1) Design Flows (m³/day)

Qaverage	24,300
Qdaily maximum flow	28,900
Qhourly maximum flow	50,300

(2) Wastewater and Sludge Treatment Process

Wastewater Treatment: Conventional activated sludge process

Sludge Treatment : Sludge thickening → Anaerobic Digestion without any heating system → Drying Bed → (Sanitary Landfill)

(3) Design Wastewater Quality

Parameter	Treatment Efficiency (%)			Design Treated Wastewater Quality (mg/L)		
	Primary	Secondary	Overall	Influent	Primary Effluent	Secondary Effluent
BOD ₅	30	86	90.2	210	147	20.6
SS	40	84	90.4	210	126	20.2

(4) Main Facilities

Facility	Facility Type	Quality	Size, Capacity, Specs	Remarks
1.Submersible pumps		2(1)units 2units	400mmF x 16m ³ /min 300mmF x 8m ³ /min	1standby
2.Primary sedimentation tank		8units	6.0mWx12.5mLx3.0mH	Surface loading 50m ³ /m ² /day
3.Aeration tank		8units	6.0mWx32.0mLx5.0mH	BOD-SS loading: 0.35kgBOD/kgSS/day Retention time 6hours 1standby、 5Q
Rotary Blower		5(1)units	F200mmx26m ³ /min	
4.Final sedimentation tank		8units	6.0mWx24.2mLx4.0mH	Surface loading: 25m ³ /m ² /day
5.Sludge thickener		2units	6.8mWx6.8mLx4.0mH	Floor loading: 60kg/m ² /day
6.Sludge digester		2units	21.5mWx21.5mLx4.0mH	Retention time: 20days
8.Drying bed		11,100m ²	Water depth 0.2m	Retention time: 11days

11.3.4 LA CUMBRE WWTP

The Outline of La Cumbre WWTP is shown in the following and the layout of La Cumbre WWTP is shown in Figure A11.15.

(1) Design Flows (m³/day)

Qaverage	21,400
Qdaily maximum flow	25,400
Qhourly maximum flow	45,000

(2) Wastewater and Sludge Treatment Process

Wastewater Treatment: Conventional activated sludge process


Sludge Treatment : Sludge thickening → Anaerobic Digestion without any heating system → Mechanical Dewatering → (Sanitary Landfill)


(3) Design Wastewater Quality


Parameter	Treatment Efficiency (%)			Design Treated Wastewater Quality (mg/L)		
	Primary	Secondary	Overall	Influent	Primary Effluent	Secondary Effluent
BOD ₅	30	86	90.2	200	140	19.6
SS	40	84	90.4	200	120	19.2


(4) Main Facilities

Facility	Facility Type	Quality	Size, Capacity, Specs	Remarks
1.Submersible pumps		2(1)units 2units	400mmF x 16m ³ /min 300mmF x 8m ³ /min	1standby
2.Primary sedimentation tank		8units	5.0mWx12.8mLx3.0mH	Surface loading 50m ³ /m ² /day
3.Aeration tank		8units	5.0mWx35.0mLx5.0mH	BOD-SS loading: 0.35kgBOD/kgSS/day Retention time 6hours
Rotary Blower		3(1)units	F200mmx22m ³ /min	1standby、 5Q
4.Final sedimentation tank		8units	5.0mWx25.5mLx3.0mH	Surface loading: 25m ³ /m ² /day
5.Sludge thickener		2units	6.3mWx6.3mLx4.0mH	Floor loading: 60kg/m ² /day
6.Sludge digester		2units	19.7mWx19.7mLx4.0mH	Retention time: 20days
7.Mechanical dewatering Belt filter press		4units	Filter width: 2m	Filter loading rate: 90kg/m/hour












THE DEVELOPMENT STUDY OF THE IMPROVEMENT OF
SEWERAGE AND DRAINAGE SYSTEM FOR THE HAVANA BAY

JAPAN INTERNATIONAL COOPERATION AGENCY

Figure A11.4
Rehabilitation of Casablanca
Pumping Station (2/2)










THE DEVELOPMENT STUDY OF THE IMPROVEMENT OF
SEWERAGE AND DRAINAGE SYSTEM FOR THE HAVANA
BAY

JAPAN INTERNATIONAL COOPERATION AGENCY

Figure A11-7
Hydraulic Profile of Luyano
WWTP








THE DEVELOPMENT STUDY OF THE IMPROVEMENT OF
SEWERAGE AND DRAINAGE SYSTEM FOR THE HAVANA BAY

JAPAN INTERNATIONAL COOPERATION AGENCY


Figure A11.10
Final Sedimentation Tank in
Luyano WWTP



THE DEVELOPMENT STUDY OF THE IMPROVEMENT OF
SEWERAGE AND DRAINAGE SYSTEM FOR THE HAVANA
BAY

JAPAN INTERNATIONAL COOPERATION AGENCY

Figure A11.11
Sludge Thickener in Luyano
WWTP



THE DEVELOPMENT STUDY OF THE IMPROVEMENT OF
SEWERAGE AND DRAINAGE SYSTEM FOR THE HAVANA
BAY

JAPAN INTERNATIONAL COOPERATION AGENCY

Figure A11.12
Digestion Tank in Luyano WWTP

