

Japan International Cooperation Agency

Department of Energy Affairs,

Ministry of Mines, Natural Resources and Environment, Republic of Malawi

The Feasibility Study Implementation Manual for Grid Extension

September 2004

Nomura Research Institute, Ltd.

ED
JR
04 - 017

Table of Contents

- 1. Objectives..... 1
- 2. Process on Implementation for Rural Electrification..... 2
- 3. Process on Feasibility Study 3
- 4. Review on the Master Plan (preliminary study) completed by JICA in March 2003 4
 - 4.1 General..... 4
 - 4.2 Voltage classes of distribution lines..... 4
 - 4.3 System configuration 4
 - 4.4 Distribution system facilities 4
 - 4.5 Construction cost 5
- 5. Description on each activity 6
 - 5.1 Preparation..... 6
 - 5.2 Map Study..... 7
 - 5.3 Field Survey 7
 - 5.4 Electricity Demand Forecast Method 10
 - 5.4.1 Preface 10
 - 5.4.2 Ordinary Electricity Demand Forecast Methods..... 10
 - 5.4.3 New Electricity Demand Forecast Method..... 12
 - 5.4.4 Check Sheet 14
 - 5.4.5 Example of Demand Forecast Sheet 15
 - 5.5 How to Revise Demand Forecast System..... 16
 - 5.5.1 File Structure..... 16
 - 5.5.2 Revision of Existing File 17
 - 5.5.3 Making of New TC File 18
 - 5.6 Prioritization of Non-Electrified TCs 18
 - 5.7 How to Revise TC Priority System..... 21
 - 5.7.1 Prioritization for Phase 7 21
 - 5.7.2 Addition of New TCs 21
 - 5.8 Voltage drop calculation 23
 - 5.8.1 General 23
 - 5.8.2 Calculation method 23
 - 5.9 Cost Estimation..... 26
 - 5.10 Calculation of an Internal Rate of Return(IRR) 27
 - 5.10.1 Data sheet..... 29

5.10.2	FIRR sheet	30
5.10.3	EIRR sheet	31
6.	Management on progress	32
7.	Reporting	33

Attachment 1

- a. Check Sheet on Equipment Preparation
- b. Check Sheet on Field Survey
- c. The Basic Time Schedule and each Role in Field Survey
- d. Check sheet for Demand Forecast

Attachment 2

- a. Demand Forecast in TC
- b. Voltage Drop Calculation Sheet
- c. Cost Estimation Calculation Sheet
- d. Internal Return Rate Calculation Sheet

Attachment 3

- a. Progress Management Sheet

Attachment 4

- a. Format of Report
- b. Sample of Report

1. Objectives

The Feasibility Study (hereinafter referred to as FS) at each candidate Trading Center (hereinafter referred to as "TC") is carried out for two objectives.

- (1) To confirm an actual route and arrangement of equipment considering technical issues below:
 - (a) Selection of routes for middle voltage lines such as 33kV and 11kV lines
 - (b) Selection of routes to extend 400/230V distribution lines to public facilities in TCs
 - (c) Demand forecast if necessary
 - (d) To study if electricity supply is possible or not under the voltage regulation
- (2) To estimate costs and viability in order to check the bill of constructor and analyze the possibility of enterprise.

2. Process on Implementation for Rural Electrification

The FS will be carried out after the Master Plan (Pre-Feasibility Study) which is based on a criterion as well as a demand forecast. Not viable sites (TCs) should be in the field of rural electrification to be managed by the Government of Malawi. The process of implementation is shown in the Figure 1.




Figure 1 : Process for Implementation of Rural Electrification

3. Process on Feasibility Study

FS consists of five activities such as Preparation, Map Study, Field investigation, Voltage Drop Study, Cost Estimation and Economical Analysis. The process of FS is shown in the Figure 2.




Figure 2 : Process on Feasibility Study

4. Review on the Master Plan (preliminary study) completed by JICA in March 2003

4.1 General

The cost of each Phase was estimated mainly based on map study at the Master Plan. Before carrying out the FS, some assumptions of the Master Plan listed below should be put in mind.

4.2 Voltage classes of distribution lines

- Class of the existing distribution line to trading centers shall be 33kV
- 3-phase 3-wire system

4.3 System configuration

- A radial system with no reserve line is adopted for cost reduction
- Disconnecting Switches (DS) shall be installed every 10km to separate faulty section
- A circuit Breaker (CB) shall be installed at each starting point of new lines

4.4 Distribution system facilities

Conductor	33kV	AAAC 100mm ²
	11kV	AAAC 100mm ²
	400V / 230V	AAC100mm ²
	Dip	5% of distance
Supporting Structure	Wooden poles	
Span Length	33kV	100m
	11kV	100m
	400V	50m
Distribution Transformer	3 phase, 100kVA, max load shall be 80% of rated capacity	

4.5 Construction cost

(a) Definition

- Lengths of 33kV and 11kV lines are estimated at 120% of straight distance of maps.
- Extensions must be planed in line with priority. Estimate does not incorporate all TCs.
- Number of 33kV/0.4kV transformers per TC

$$n = \frac{\text{total load of TC}(kVA)}{\text{rated capacity}(kVA) * \text{loading}80\%}$$

where

$$\begin{aligned} & \text{total load of TC}(kVA) \\ &= \frac{\text{demand of maize mill}(kW)}{\text{power factor}80\%} + \frac{\text{demand of others}(kW)}{\text{power factor}90\%} \end{aligned}$$

*maximum loading is 80% of rated capacity

*standard power factors are 80% for maize mills and 90% for the rest

- 400V/230V lines
- Length between a transformer and a household plug of is 500m
Two lines are extended from each transformer
- Circuit breaker
A circuit breaker is installed at the starting point of new lines
- Disconnecting Switch
Disconnecting switches are installed every 10km

(b) Unit cost and total cost

- Unit cost
Unit cost of 33kV line, transformers and 400V/230V are calculated using (latest total cost / total quantity)
- Total cost
A total cost was estimated to the sum of costs on 33kV lines, transformers, circuit breakers, disconnection switches and 400/230V lines. Then, 8% of an engineering service fee, 2% of an administrative fee for DOE and 10% of an surtax are added.

5. Description on each activity

5.1 Preparation

(a) Data collection

Before a FS, some data listed below should be collected in advance.

- Existing lines and future planning of ESCOM
- Cost data per km including local cost such as labors, transport, fuels, etc.
- Technical data for voltage drop calculation
- Tariff, energy cost, O&M cost per kWh

(b) Equipment/materials for the FS (Refer to Attachment 1-a)

For FS, some equipment/materials listed below should be prepared in advance.

- 1/250,000 scale maps, hopefully more detailed maps
- Roller measure
- Plane board for drawings
- White papers and section papers
- Rulers
- Calculators
- GPS
- Laser binoculars
- Magnet compass

And the objectives, directions of main equipment are shown in the Table 1.

Table 1 : Objectives, Directions of Main Equipment

Equipment	Objectives	Directions (how to use)
GPS	To confirm the current position during driving and drawing.	Push the “page” button after turning on the source switch.
Laser binoculars	To measure the long distance or distance with obstacle. Mainly vertical direction along the main load.	Depress the source switch after aligning the reticule with the target.
Roller measure	To measure the short distance exactly. Mainly horizontal direction along the main load.	Roll after pushing button to reset.
Magnet compass	To confirm the current direction during driving and drawing.	Put in the horizontal place.

(c) Scheduling on field survey

Time and cost effectiveness should be considered for scheduling on the field survey. However, long duration of survey trip is not practical. One-week field survey, one-week desk work and re-planning for the next trip would be recommended.

5.2 Map Study

An objective of carrying out map study is to decide the tentative routes for the 33kV or 11kV lines from the starting point to the candidate TC. The 1:250,000 maps that are already put information obtained by data collection will be used, and standard routes are drawn along the roads on these maps.

5.3 Field Survey (Refer to Attachment 1-b,1-c)

(a) Identification on starting point of 33kV or 11kV lines

An end pole, substation or power station selected in the map study will be identified. If other distribution lines are found to have been extended near the TC, the tentative routes decided by the map study will be revised.

(b) Identification on the of 33kV or 11kV lines

This survey is conducted to investigate a route from the identified starting point to TC. If any obstacles such as large rivers and/or steep terrain are identified during the survey, and the route of distribution has to be changed considerably, the map study will be repeated.

(c) Distribution transformer and 400V/230V lines

The tentative locations of distribution transformer and 400V/230V lines are studied. The procedure is the followings

- a. Draw an outline map of the candidate-trading center.
- b. Select the appropriate area sites where pole-mounted transformer will be installed with consideration of the position of maize mills.
- c. Draw the most appropriate route between the distribution transformer and public facilities on the outline map. Route distances will be measured.

(d) Standard symbols

Standard symbols for making drawing are as shown in Table 2.


















Table 2 Standard Symbols

(1/2)

Item		Example		
Scale	Choose a suitable reduced scale fitting A4 size paper		1/500, 1/1000, 1/5000 etc	
Symbol	Transformer			
			33kV HV	
	33kV HV line		Blue dotted-line means "proposed."	
			Green dotted-line marked by fluorescent pen means "planned."	
			Green solid line marked by fluorescent pen means "existing."	
	11kV HV line		11kV HV	
			Blue dotted-line means "proposed."	
			Red dotted-line marked by fluorescent pen means planned."	
	LV line		Red solid line marked by fluorescent pen means "existing."	
			3 : 3-phase 4-wire system (400V) 1 : 1-phase 2-wire system (230V)	
	Existing Extra High Voltage Line		Blue solid line means "proposed."	
	Existing Telecommunication Line		Red solid line	
	Direction		Red solid line	
	Maize Mill			
	Shop		Sh means "Maize Mill with Sheller"	
	House			
	Secondary School		H in square is not necessary to be shown.	
Primary School				
Church				
Mosque				
Court				
Health Center				
Hospital				
Clinic				

Table 2 Standard Symbols

(2/2)

Item		Example	
Symbol	Police Station		
	Police Unit		
	Police Post		
	Agriculture Office		
	Government Office		
	Post Office		
	Admarc		
	Teacher's Training Center		
	Government Office		
	Agriculture Office		
	Staff House		
	Other Public Facility		Write the concrete type of facility
	Market		Solid line means "the area."
	Restaurant		
	Rest House		
	Battery Charge Station		
	Tree		Solid line means "the area."

5.4 Electricity Demand Forecast Method (Refer to Attachment 1-d,2-a)

5.4.1 Preface

To electrify a non-electrified TC, a demand forecast is significant for designing appropriate distribution facilities and estimating accurate distribution costs because a demand forecast of a TC is a basic in a plan for electrification.

In the present condition in Malawi, however, the main role of the Government of Malawi is to raise the electrification ratio to the level that the nation can have access to electricity as at least basic human needs and the Government of Malawi is not responsible for power sector as business. Therefore, the targets to electrify that the Government of Malawi has a responsibility is public facilities and maize mills in TC and electrification of other facilities such as business entities and households are under the control of private power companies. In this circumstance, a demand forecast in each TC is only an indicator for reference or could be data for comparison with demand forecasts submitted by private power companies. In addition, an estimated distribution system for a TC in FS implemented by DOE is set to satisfy the present power demand in public facilities and maize mills in the TC. Although the present demand is calculated for determination of facilities for the distribution system, the demand forecast is not used in FS.

The demand forecast for each non-electrified TC was examined in "The Master Plan Study on Rural Electrification Plan in Malawi." In this FS Manual, the ordinary electricity demand forecast methods, the problems in the demand forecast in the Master Plan, and the new demand forecast method are explained. Since this is only a manual, however, the "how to" is focused on and the theoretical aspects are not deeply explained. Please refer the report of the Follow-up Study for the theoretical details.

5.4.2 Ordinary Electricity Demand Forecast Methods

In electricity demand forecast methods, there are two major approaches; the macro approach and the micro approach. These both have their characters, advantages and disadvantages. In Japan, we use both approaches to estimate future demand forecasts.




Figure 3 : The Example of the simplest demand forecast

(1) Macro Approach

The Macro Approach is a method in electricity demand forecasts using statistics of the macro economic data such as population growth, GNP growth, and IIP (Index of Industrial Production) growth. The simplest way is that, based on the actual data of demands in MW and GWh, we estimate the growth of both demands by the averages of these growths. The longer terms for calculation of the averages are, the better it is. The example is shown in Fig. V-1. These macro economic data can be obtained from organizations like a national statistic agency.

In addition that this approach is used for electrified areas since the past demand data is needed for estimation, however, it is usually used for estimation in grid system. The reason is that grid-connected areas usually have a good correlation with macro economic indicators because an electricity demand in industries excels in grid-connected areas comparing with other customers. However, the demand in non-electrified areas does not always fit with economic movements since electricity has not been needed for their life.

The advantages and the disadvantages of the macro approach are as follows;

<Advantages>

- Since macro economic indicators are considered, the results of demand forecast match to the national economic conditions.
- The calculation is not complicated comparing with the micro method.

<Disadvantages>

- The result depends on how long the terms of economic indicators are.
- In especially developing countries, it is difficult to acquire accurate economic indicators.
- The longer forecast terms, the worse accuracy since it is impossible to forecast future economic and political issues.

(2) Micro Approach

The Micro Approach (End-user Approach) is a method in electricity demand forecasts using unit demands which is estimated from power consumptions in customers such as households, business units, schools, and hospitals. The electricity demand is calculated with piling up these unit demands.

A unit demand is estimated from actual consumptions and its power usage hours referring already electrified areas. For example, when estimating a unit demand in a household, we research actual power consumption hour by hour through interviews in electrified houses and assume an ordinary power usage form as a unit demand. Then we pile up the unit demand multiplying the number of household in the area.

The end-user approach is especially good for the estimation in non-electrified areas which demands are difficult to estimate and are not along with macro economic movements like TCs.

The advantages and the disadvantages of the macro approach are as follows;

<Advantages>

- Since a unit demand which is a base of a demand forecast in micro approach is assumed based on actual power consumption, the forecasted demand is nearly right.
- Relatively accurate analyses can be expected because the unit demands in types such as households, industries, shops are calculated
- Not only quantitative data but also qualitative data in both electrified and non-electrified areas such as willingness to pay, capacity to pay can be acquired through socio-economic survey.

<Disadvantages>

- The needed data for assuming a unit cost is great in quantity and collecting data takes much time.
- The data analyses from interviews are complicated.
- A unit demand changes depending on the target year to forecast.

5.4.3 New Electricity Demand Forecast Method

Based on the demand forecast method in the Master Plan, the new demand forecast method was developed.

(1) Policies

The basic policies for the DOE demand forecast are as follows.

- The demand forecasts for non-electrified TCs in the Master Plan indicate electricity demand until 2020 according to the Master Plan.
- The micro method was adopted in order to grasp more accurate electricity demand in a non-electrified TC.

(2) Preconditions

(a) The facilities in each TC which DOE targets to are as follows.

• *Public Facilities*

- 1) Secondary School
- 2) Primary School
- 3) Teacher's Development Center
- 4) Staff House
- 5) Hospital

- 6) Health Center
- 7) Clinic
- 8) Post Office
- 9) Police Station
- 10) Police Post
- 11) Police Unit
- 12) Admarc
- 13) Other Government Offices
- 14) Church
- 15) Mosque
- 16) Court
- 17) Other Public Facilities

• *Business Entities*

- 1) Maize Mill
- 2) Shop

• *Households*

- 1) Ordinary Household
- 2) Rich Household

(b) The electricity demand forecasts are made based on the analyses of the Socio-Economic Survey in the Master Plan

(c) The electricity demand is calculated multiplying the unit demand in each facility and the number of the facility

(d) The power consumption of each electric device is calculated from average of the consumption data acquired through the Socio-Economic Survey.

(e) The preconditions for each facility are as follows.

➤ Public Facility

- 1) Electric device(s) is (are) provided from ministries concerned every 3 years.
- 2) After 17 years from electrification all assumed devices will have been set.

➤ Maize Mill

- 1) After electrification, existing maize mills in a TC are immediately connected.
- 2) Increase of the number of maize mill is along with the equation of the Master Plan.
- 3) An electric device is bought every year.

➤ Business Entity

- 1) The ratio that business entities connect to distribution lines is 50%.
- 2) An electric device is bought every year.
- 3) Increase of the number of business entity is to be calculated based on the correlation between the household population and the number of business entity.

➤ Household

- 1) The ratio that ordinary households connect to distribution lines is 40%.
- 2) Households are separated in two, ordinary household and rich household. The ratio between ordinary households and rich households is 95:5.
- 3) An electric device is bought every three years in ordinary households and every year in rich households.
- 4) The number of electric device matures 17 years after electrification.
- 5) The total household demand in a TC considers the household growth rate indicated in the Master Plan. (1.27%)
- 6) The growth rate of electric demand after 17 years depends on the household growth rate.

(3) Necessary Data

In order to calculate an electricity demand forecast in a TC, following data should be collected in FS.

- Number of each existing public facility
- Number of existing maize mill
- Number of existing business entity
- Number of existing household inside the TC

5.4.4 Check Sheet

In a FS, a check sheet is useful for a smooth implementation and an avoidance of oversights. Though all data is significant for calculation of a demand forecast in a TC, the data to acquire can be reduced depending on allowed time in a site survey. The least data that should be absolutely needed is written in bold. Also, since the check sheet made by DOE was based on the rural electrification database created in the Master Plan Study, the check sheet recommended in this FS Implementation Manual follows the format.

After inputting the necessary data to a check sheet, the electricity demand in a TC until 2020 is automatically calculated.

Note) Do not delete the file named “Unit Demand Forecast Sheet” since data in each TC is linked to the file. linked to the file.

5.4.5 Example of Demand Forecast Sheet

The unit demand in an ordinary secondary school is shown bellow as an example.

a) Daily Load in an Ordinary Secondary School

Basic Assumption: Number of Classroom 4

Electrical Devices	Number	Capacity (W)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00
1) Incandescent Light	4	100	2	2	2	2	2	2												4	4	4	2	2	2	2
2) Fluorescent Light	8	40																		8	8	8				
3) Cooking Device	0	1,600																								
4) Refrigerator	0	280																								
5) Radio	0	10																								
6) Cassette/CD Player	1	30							1	1	1	1	1	1	1	1	1	1	1							
7) Television	0	80																								
8) Video Cassette Recorder	0	20																								
9) Electric Iron	0	1,000																								
10) Electric Heater	0	1,200																								
11) Electric Fan	2	50										2	2	2	2	2	2	2	2	2						
12) Air Conditioner	0	1,000																								
13) Mill	0	20,000																								
14) Computer	2	200									2	2	2	2	2	2	2	2	2	2						
15) Others	0	200																								


Electrical Devices	Number	Capacity (W)	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00
1) Incandescent Light	4	100	200	200	200	200	200	200												400	400	400	200	200	200	200
2) Fluorescent Light	8	40																		320	320	320				
3) Cooking Device	0	1,600																								
4) Refrigerator	0	280																								
5) Radio	0	10																								
6) Cassette/CD Player	1	30							30	30	30	30	30	30	30	30	30	30	30							
7) Television	0	80																								
8) Video Cassette Recorder	0	20																								
9) Electric Iron	0	1,000																								
10) Electric Heater	0	1,200																								
11) Electric Fan	2	50										100	100	100	100	100	100	100	100							
12) Air Conditioner	0	1,000																								
13) Mill	0	20,000																								
14) Computer	2	200									400	400	400	400	400	400	400	400	400							
15) Others	0	200																								
Max Capacity (W)		1,250	200	200	200	200	200	200	30	30	430	430	530	530	530	530	530	530	850	1,250	720	720	200	200	200	200
Total Consumption (Wh)		9,640	200	200	200	200	200	200	30	30	430	430	530	530	530	530	530	530	850	1,250	720	720	200	200	200	200

The electricity demand forecast until 2020 in Kapoka in Chitipa District is shown as follow.

Demand Forecast in TC

DISTRICT: Chitipa
TC NAME: Kapoka

Year	Secondary School		Primary School	Teacher's Development Center	Staff House	Hospital	Health Center	Clinic	Post Office	Police Station	Police Post	Police Unit	Admarc	Government Office	Church	Mosque	Court	Other Public Facilities	Public Facilities Total	Maize Mill		Business Entities		Business Entities Total	Ordinary Household		Rich Household	Household Total	TC Total	
	Number	kW																		Number	kW	Number	kW		Number	kW				
2007	0.4000	0.4000	0.4000	0.0000	0.0000	0.0000	0.3100	0.0000	0.0000	0.3000	0.0000	0.0000	0.0000	0.0000	0.1000	0.0000	0.0000	0.4000	1,910	1	20,010	3	0.2400	20,250	114	22,800	6	1,200	24,000	46,160
2008	0.4000	0.4000	0.4000	0.0000	0.0000	0.0000	0.3100	0.0000	0.0000	0.3000	0.0000	0.0000	0.0000	0.0000	0.1000	0.0000	0.0000	0.4000	1,910	1	20,010	3	0.8400	20,850	116	23,200	7	1,960	25,160	47,920
2009	0.4000	0.4000	0.4000	0.0000	0.0000	0.0000	0.3100	0.0000	0.0000	0.3000	0.0000	0.0000	0.0000	0.0000	0.1000	0.0000	0.0000	0.4000	1,910	1	20,050	3	0.8400	20,890	117	23,400	7	1,960	25,360	48,160
2010	0.7200	0.8800	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.5000	0.0000	0.0000	0.0000	0.0000	0.1400	0.0000	0.0000	0.0000	0.4000	3,430	1	20,050	3	0.8400	20,890	119	33,320	7	2,520	35,840	60,160
2011	0.7200	0.8800	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.5000	0.0000	0.0000	0.0000	0.0000	0.1400	0.0000	0.0000	0.0000	0.4000	3,430	1	20,050	3	1,680	21,730	120	33,600	7	4,480	38,080	63,240
2012	0.7200	0.8800	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.5000	0.0000	0.0000	0.0000	0.0000	0.1400	0.0000	0.0000	0.0000	0.4000	3,430	2	40,100	3	1,680	41,780	122	34,160	7	14,000	48,160	93,370
2013	0.7500	0.9100	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.5100	0.0000	0.0000	0.0000	0.0000	0.1400	0.0000	0.0000	0.0000	0.4000	3,500	2	40,100	3	1,680	41,780	123	34,440	7	14,000	48,440	93,720
2014	0.7500	0.9100	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.5100	0.0000	0.0000	0.0000	0.0000	0.1400	0.0000	0.0000	0.0000	0.4000	3,500	2	40,100	3	1,680	41,780	125	35,000	7	14,140	49,140	94,420
2015	0.7500	0.9100	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.5100	0.0000	0.0000	0.0000	0.0000	0.1400	0.0000	0.0000	0.0000	0.4000	3,500	2	40,100	3	1,680	41,780	126	35,280	7	14,140	49,420	94,700
2016	0.8500	1.0100	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.5600	0.0000	0.0000	0.0000	0.0000	0.1400	0.0000	0.0000	0.0000	0.4000	3,750	2	40,100	3	1,680	41,780	128	46,080	7	14,140	60,220	105,750
2017	0.8500	1.0100	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.5600	0.0000	0.0000	0.0000	0.0000	0.1400	0.0000	0.0000	0.0000	0.4000	3,750	2	40,100	3	1,680	41,780	130	46,800	7	14,140	60,940	106,470
2018	0.8500	1.0100	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.5600	0.0000	0.0000	0.0000	0.0000	0.1400	0.0000	0.0000	0.0000	0.4000	3,750	2	40,100	3	1,680	41,780	131	47,160	7	14,140	61,300	106,830
2019	1.2500	1.4100	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.7600	0.0000	0.0000	0.0000	0.0000	0.1400	0.0000	0.0000	0.0000	0.4000	4,750	2	40,100	3	1,680	41,780	133	85,120	7	14,140	99,260	145,790
2020	1.2500	1.4100	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.7600	0.0000	0.0000	0.0000	0.0000	0.1400	0.0000	0.0000	0.0000	0.4000	4,750	2	40,100	3	1,680	41,780	135	86,400	8	16,160	102,560	149,090



Year	Secondary School		Primary School	Teacher's Development Center	Staff House	Hospital	Health Center	Clinic	Post Office	Police Station	Police Post	Police Unit	Admarc	Government Office	Church	Mosque	Court	Other Public Facilities	Public Facilities Total	Maize Mill		Business Entities		Business Entities Total	Ordinary Household		Rich Household	Household Total	TC Total	
	Unit	Year																		Unit	Year	Number	Year		Number	Year				
2007	884	884	884	0	0	0	1,099	0	0	1,820	0	0	0	0	473	0	0	1,560	6,720	1	57,229	3	175	57,403	114	82,992	6	4,368	87,360	151,484
2008	884	884	884	0	0	0	1,099	0	0	1,820	0	0	0	0	473	0	0	1,560	6,720	1	57,567	3	2,577	60,144	116	84,448	7	5,911	90,359	157,224
2009	884	884	884	0	0	0	1,099	0	0	1,820	1,560	0	0	0	473	0	0	1,560	6,720	1	57,587	3	2,719	60,306	117	85,176	7	6,676	91,	

5.5 How to Revise Demand Forecast System

5.5.1 File Structure

File Structure is shown in Figure 4.




Figure 4 : File Structure (Demand Forecast System)

Unit Demand Analyses: Calculation of unit demand for facilities

Place: Desktop – JICA MP Followup Demand Forecast

TC Demand Condition files: Calculation of electricity demand from 2007 to 2020 in a TC

Place: Desktop – JICA MP Followup Demand Forecast – Phase 6

TC Priority: Prioritization of non-electrified TCs for Phase 6

Place: Desktop – JICA MP Followup Demand Forecast

5.5.2 Revision of Existing File

(1) TC Data Revision

If you want to revise number of facilities, following procedure shows how to revise.

(Step 1) Start up EXCEL

(Step 2) Open the file you want to revise

cf the file name, “Demand Condition Sheet for Phase6(Chitipa Kameme)”

(Step 3) In the “TC DATA FORM” sheet, revise corresponding cells such as “Number of Secondary School.” All you can revise is only pink cells.

(Step 4) The demand forecast results will be automatically revised based on your input.

(Step 5) Save the file.

(2) Unit Demand Data Revision

If you want to revise unit demand data of facilities, following procedure shows how to revise.

(Step 1) Start up EXCEL

(Step 2) Open “Unit Demand Analyses” file in “JICA MP Followup Demand Forecast” folder on Desktop.

(Step 3) Revise corresponding cells. (From D7 cell to AA21 cell)

Note) • The data sheets you can revise are from “Demand Forecast in Sec. School” sheet to “Demand Forecast in Rich HH” sheet since each TC data file is linked to these “Demand Forecast ~” sheets. It does not make any sense if you revise “a) Secondary School” sheet to “u) Rich Household” sheet.

- On inputting number data in upper rows, power consumptions are automatically calculated.
- In from “Demand Forecast in Sec. School” sheet to “Demand Forecast in Rich HH,” yearly growth of electric device purchase is chronically expressed. Therefore, if you revise unit demand, you also have to revise chronicle data.

(Step 4) Save the file.

Note) Do not move the file to other directory because the file is linked to other TC data files.

5.5.3 Making of New TC File

If you want to add a new TC for demand forecast, following procedure shows how to add.

(Step 1) Start up EXCEL

(Step 2) Open a file in the same district in the directory “Phase 6”

(Step 3) Save the file as the new TC name

(Step 4) Input necessary data such as TC name, number of facility.

(Step 5) The electricity demands (kW and kWh) are automatically calculated.

(Step 6) Save the file.

5.6 Prioritization of Non-Electrified TCs

The prioritization method was also revised based on the Master Plan.

(1) Policies

The basic policies of the DOE prioritization method are as follows.

- DOE electrifies two non-electrified TCs in each District in every phase.
- After determination of two TCs in a district in a phase, the rest TCs are to be prioritized again for subsequent phases.

(2) Preconditions

1. The criteria used in the prioritization are as follows.

- Amount of Electricity Demand
- Distance from a tapping point, which is equal to distance from the existing distribution line
- Public Electricity Demand Ratio (PEDR: Electricity demand in Public facilities in a TC divided by all electricity demand in the TC)

2. Regarding each criterion, a weight as follow was given. TCs are prioritized in each criterion and points in and a TC which gets higher total points is prioritized.

Criteria	Weight
Amount of Electricity Demand	10
Distance from a tapping point	2
PEDR	1

Although the weights of criteria were determined in the Follow-up Study as above, they should be changed by DOE depending on situation changes.

<Example>

Criteria		A TC	B TC	C TC
Amount of Electricity Demand	Value	200kWh	250kWh	180kWh
	Rank	2 nd	1 st	3 rd
	Point	<u>20 points</u> (2 points × 10 = 20 points)	<u>30 points</u> (3 points × 10 = 30 points)	<u>10 points</u> (1 points × 10 = 10 points)
Distance from a tapping point	Value	12km	20km	3km
	Rank	2 nd	3 rd	1 st
	Point	<u>4 points</u> (2 points × 2 = 4 points)	<u>2 points</u> (1 points × 2 = 2 points)	<u>6 points</u> (3 points × 2 = 6 points)
PEDR	Value	10%	12%	6%
	Rank	2 nd	1 st	3 rd
	Point	<u>2 points</u> (2 points × 1 = 2 points)	<u>3 points</u> (3 points × 1 = 3 points)	<u>1 points</u> (1 points × 1 = 1 points)
Total Point		26	35	17
Priority		2	1	3

(3) Necessary Data

In order to prioritize TCs to electrify, distance from a tapping point in each TC should be collected in FS. Other data, amount of demand and public electricity demand ratio are calculated through the demand forecast in the TC.

(4) Prioritization Sheet

The prioritization sheet for Chitipa District is shown as follow. All data except distance from tapping point is automatically calculated through the demand forecast sheet.

DISTRICTS TC DATA COLLECTION

NAME OF DISTRICT: CHITIPA

TC Number	4			5			6			252			253		
	Kameme			Chesenan			Kapoka			Chisenga			Mwenemulembe		
1. Name of Trading Center	Number	kW at 2020	kWh at 2020	Number	kW at 2020	kWh at 2020	Number	kW at 2020	kWh at 2020	Number	kW at 2020	kWh at 2020	Number	kW at 2020	kWh at 2020
2. Traditional Authority	Kameme			Chesenan			Kapoka			Chisenga			Mwenemulembe		
3. Distance from the Existing Distribution Line (km)	23			8			2			20			8		
4. Market Fee															
a) Monthly Market Fee per Person (MK/month)															
b) Total Collected Annual Market Fee in TC (MK/year)	45,000			35,000			35,000			0			0		
5. a) Population in TC	1,710			806			1,110								
b) Population in CA [inc. the TC]	6,840			3,223			4,440								
6. Number of Existing Public Facilities															
a) Secondary School	1	1,250	2,551				1	1,250	2,551						
b) Primary School	1	1,410	2,592				1	1,410	2,592						
c) Teacher's Development Center	0	0.000	0				0	0.000	0						
d) Staff House	0	0.000	0				0	0.000	0						
e) Hospital	0	0.000	0				0	0.000	0						
f) Health Center	1	0.790	5,584				1	0.790	5,584						
g) Clinic	0	0.000	0				0	0.000	0						
h) Post Office	0	0.000	0				0	0.000	0						
i) Police Station	1	0.760	4,834				1	0.760	4,834						
j) Police Post	0	0.000	0				0	0.000	0						
k) Police Unit	0	0.000	0				0	0.000	0						
l) Admnic	0	0.000	0				0	0.000	0						
m) Government Office	2	0.280	1,378				0	0.000	0						
n) Church	1	0.140	517				1	0.140	517						
o) Mosque	0	0.000	0				0	0.000	0						
p) Court	1	0.530	1,277				0	0.000	0						
q) Other Public Facility	4	0.400	2,392				4	0.400	2,392						
Total	12	5.560	21,124	0	0	0	9	5	18,469	0	0	0	0	0	0
7. Targeted Business Entities in 2020															
r) Maize Mills	5	100,250	287,937				2	40,100	115,175						
s) Business Entity	16	8,960	59,696				3	1,680	11,193						
Total	21	109,210	347,633	0	0	0	5	42	128,368	0	0	0	0	0	0
8. Targeted Household in 2020															
t) Ordinary Household	207	132,480	734,643	0.0			135	86,400	479,115	0.0			0.0		
u) Rich Household	11	22,220	63,303	0.0			8	16,160	46,039	0.0			0.0		
Total	218	154,700	797,946	0	0	0	143	103	525,154	0	0	0	0	0	0
Grand Total	269	1,166,703	4,166,703	0	0	0	149	669,991	1,166,703	0	0	0	0	0	0
		MP	Follow-up		MP	Follow-up		MP	Follow-up		MP	Follow-up		MP	Follow-up
kW		391	269		208	141		263	149		94	64		35	24
kWh		1,960,000	1,166,703		1,042,000	706,226		1,319,000	669,991		472,000	319,903		174,000	117,930

Ranking

Amount of Demand	1	2	3	4	5
Distance from Tapping Point	5	2	1	4	2
Public Electricity Demand Ratio	5	2	1	2	2

Points

Amount of Demand	15	12	9	6	3
Distance from Tapping Point	2	6	10	4	6
Public Electricity Demand Ratio	1	2	3	2	2
Total	18	20	22	12	11
Priority	3	2	1	4	5

[Points]

- 1) Input a value of distance from tapping point in the TC's cell "3. Distance from the Existing Distribution Line."
- 2) If there is no data of number of facility like Chesenan in the example, use the data in the Master Plan. From the analysis, a kWh calculated by the new demand forecast method is 32.2% less than that in the Master Plan.
- 3) If it is impossible to collect data such as distance from a tapping point and Public Electricity Demand Ratio of a TC, you can use an average data of other TCs in the district.
- 4) If there are the same total score TCs, Choose a TC which has a higher amount of electricity demand.
- 5) After determination of two TCs to electrify, delete the two and input new distances from tapping points since the distances may change because of expanding distribution lines.

5.7 How to Revise TC Priority System

5.7.1 Prioritization for Phase 7

If you want to prioritize non-electrified TCs for Phase 7, following procedure shows how to make.

(Step 1) Start up EXCEL

(Step 2) Open the “TC Priority” file

(Step 3) Save as TC Priority (Phase 7)

(Step 4) Go to the district sheet you want to make

(Step 5) Delete TC cells which are in Phase 6

Note) Do not delete all columns because there may be needed cells in down rows. Delete only corresponding cells.

(Step 6) Input new data of “Distance from existing distribution line”

Note) The distance from distribution line will be changed since if you expand lines, the distance may be changed.

(Step 7) New prioritized TCs are shown in “Priority”

(Step 8) Save the file

Note) Even if you want to make the Phase 8 and later, the procedure is the same.

5.7.2 Addition of New TCs

If you want to add non-electrified TCs and prioritize them, following procedure shows how to make. Please be careful since it is a little complicated.

(Step 1) Start up EXCEL

(Step 2) Open the corresponding “TC Priority(Phase)” file to the phase you want to make

(Step 3) Go to the district sheet you want to make

(Step 4) Copy the all columns of a TC data

(Step 5) Paste the data to the end of lines

(Step 6) Input necessary data to the new pasted columns

(Step 7) Expand the calculation range of the equations “=Rank(…)” of the first TC’s cells in Ranking section to the added TC.

$$cf = \text{RANK}(D54, \$D\$54: \boxed{\$R\$54}) \quad = \text{RANK}(D54, \$D\$54: \boxed{\$U\$54})$$

Note) This is about “Ranking” section.

(Step 8) Expand the calculation range of the equations “=Rank(…)” of the first TC’s cells in Priority section to the added TC.

$$cf = \text{RANK}(D54, \$D\$54: \boxed{\$R\$54}) \quad = \text{RANK}(D54, \$D\$54: \boxed{\$U\$54})$$

Note) This is about “Priority section.”

(Step 9) Expand all data in Rank section and Priority section to right side

(Step 10) Replace the old TC file name to new TC file name in each cell

$$cf [\text{Demand Condition Sheet for Phase6}(\text{Chitipa } \boxed{\text{Kameme}}).xls]$$

Encircled part has to be changed

$$[\text{Demand Condition Sheet for Phase6}(\text{Chitipa } \boxed{}).xls]$$

Note) Do not input any data in cells in which there are equations.

(Step 11) New prioritized TCs are automatically ranked in the Priority part

5.8 Voltage drop calculation (Refer to Attachment 2-b)

5.8.1 General

Voltage drops after installation of lines are assumed based on a demand forecast, distance of distribution lines and the current voltage condition. The current voltage conditions are collected from ESCOM.

If any problems occur with respect to the voltage of 33kV lines, a discussion with ESCOM regarding the below listed issues related to voltage compensation is necessary.

- Re-evaluation of route (ex. new feeder from substation)
- Installation of facilities to compensate for voltage drop (ex. static capacitors, step voltage regulators, load ratio control transformer)

As for 400V/230V lines, the following measures are considered.

- Change of the pole-mounted transformer location

5.8.2 Calculation method

The voltage criterion under the regulation in Malawi is $\pm 6\%$ against rated voltages. The following table shows the range and limits of voltage for each voltage grade.

Rated Voltage	Range	Limitation
33 kV	± 1.980 kV	34.98 kV – 31.02 kV
11 kV	± 0.660 kV	10.34 kV – 9.34 kV
400V/230V	± 24 (400V) ± 13.8 (230V)	424V – 376V 243V – 216V

(a) 33kV and 11kV lines

A voltage of 33kV and/or 11kV lines is generally estimated using the following equation (1).

$$V_r = V_s - 1.732I(R\cos\phi + X\sin\phi) \quad \text{equation (1)}$$

where

V_s	Voltage at sending point of distribution line
V_r	Voltage at receiving point of distribution line
I	Load current
R	Resistance of line
X	Reactance of line
$\cos\phi$	Power factor of load at receiving point

The following parameters are applied in Equation (1)

V_s 35kV for systems with a rated voltage of 33kV and 11.5kV with 11kV system according to operation data from ESCOM

V_r Rated voltage (33kV or 11kV)

I Demand of public facilities in each TC

$\cos\phi$ 0.9 (including Maize Mill)


R, X

Conductor type	Resistance (Ω/km)	Reactance (Ω/km)
Hazel	0.616	0.380
Oak	0.311	0.358

Source: ESCOM, Pole type "A", None earth wire

The simplified calculation procedure is as follows.

- Calculation of V_{r1} (voltage at the first load point) using Equation (1)
- Replacement of V_s by V_{r1} of Equation (1) and calculation of V_{r2} (voltage at the second load point) by Equation (1)
- This procedure is repeated until the terminal point



(b) 400V/230V lines

In case of low voltage lines, Equation (2) is generally used for voltage drop calculation, since the load power factor at the receiving point is almost 1.0, except for motors.

$$V_r = V_s - 2IR$$

equation (2)

A calculation procedure is the same as for the 33kV lines.

Equation (1) should be applied for this calculation in the case that a connection of a maize mill is expected. And 0.8 is applied for power factor because that of maize mills in Malawi is usually 0.8.

The following table shows the calculated voltage drop for 400V/230V by using equation (1) when a maize mill is connected to the end point of the line. “ANT” and “WASP” are the name of typical conductors in Malawi.

Conductor	Resistance * ¹ (Ω/km)	Reactance * ¹ (Ω/km)	Voltage drop * ² (V)
ANT	0.6638	0.2750	31.50
WASP	0.3309	0.2530	17.79

*1	Equations are shown in reference2	
	Conductor temperature	75
*2	Capacity of maize mill	25kVA (20kW)
	Power factor	0.8
	V _s	Rated (Equipment is selected such that the tap of the mole-mounted transformer maintains the voltage of the secondary at the rated value)

According to regulations in Malawi, the voltage criterion is $\pm 6\%$ against rated values. This means that $\pm 24.0V$ (three phase), $\pm 13.8V$ (single phase) are the limitation for 400V/230V line. The above table shows that any conductor cannot meet this voltage regulation for a length of 1.3km.

In case of maize mill, the limited lengths are approximately 700m for ANT and 1300m for WASP conductors. Therefore, when the length of 400V/230V lines is less than 700m and the demand is smaller than standard for a maize mill (20kW), voltage calculation is not always necessary.

In case of not maize mill, when the length of 400V/230V lines is less than 500m and the demand is smaller than 4.6kW, voltage calculation is not always necessary.

5.9 Cost Estimation (Refer to Attachment 2-c)

The scope of work for MAREP is the construction of distribution lines to public facilities in the TC. The installation cost of electrification for public facilities within each TC is estimated in this section.

The installation cost of grid extension to satisfy the total demand of each TC is estimated based on a field survey to public facilities, since the extension of distribution lines to private sectors, such as households, retail shops and maize mills, shall be done by other parties who will manage the distribution by their own financial resources. Economical and financial evaluations are carried out for the total demand of each TC. The equipment to be extended includes the pole-mounted transformer and 400V/230 V lines.

Cost data should be based on construction cost per km for 33kV lines and 400V/230V lines, and construction cost per unit for transformers using ESCOM's latest data including materials, labors, transportations and fuel together with coming up with Bill of Quantities (BOQ).

Total cost is estimated to the sum of costs on 33kV lines, transformers, and 400V/230V lines.

5.10 Calculation of an Internal Rate of Return(IRR) (Refer to Attachment 2-d)

There are two methods of calculating an internal rate of return. One is an economic internal rate of return (EIRR), and another is a financial internal rate of return (FIRR). In the feasibility study, users can calculate both IRRs using the EIRR and FIRR calculation sheets.

Difference of financial and economic analyses

Financial analysis of a project is similar in form to economic analysis because both appraise the profit of an investment. The concept of financial profit is, however, not the same as in economic analysis. The financial analysis of a project estimates the accrued profit of the project-owner (i.e., investor), while the economic analysis evaluates the effect of the project on the national economy.

Both analyses are conducted in monetary terms, but big differences exist in respect of the definition of cost and benefit. In financial analysis, all expenditures incurred in the project and revenues resulting from it are taken into account. In contrast, economic analysis attempts to assess the overall impact of a project for improving the economic welfare of the citizens of the country concerned.

For this reason, analysts use current value in monetary terms for financial analysis, but real value for economic analysis. Furthermore, they take account of government subsidies in financial analysis but not in economic analysis, because such subsidies increase the revenue for the project-owner but do not contribute directly to national economic growth.

Purpose of using the calculation sheet

To judge whether a project fulfills the legally required condition of rural electrification (RE), the EIRR sheet must be used because the EIRR of the RE project must not be more than 6% as stipulated in the Implementing Rules and Regulations of the Rural Electrification Act.

On the other hand, to evaluate project viability, the FIRR sheet must be used. Using this sheet, users can simulate not only the profitability of the project from a Concessionaire's standpoint but also financial conditions including annual income and cash flow.

General conditions

- Monetary terms: The US dollar was used in both calculation sheets, because estimation of the current value of the Malawi kwacha during the project term would be too difficult, due to the country's high inflation. The only difference between the "Economic Analysis" and "Financial Analysis" sheets is that the former is in real terms and the latter is in nominal (current terms).
- Deflator: The GDP deflator for the USA is used (i.e, 1.7% p.a. between 1995 and 2002).
- Effective income tax: It is necessary to apply the common figure in commercial business operations of Malawi.
- Power retail price: The personnel using this spreadsheet may set it as a precondition of simulation.
- Annual power sales: The result of the demand forecast is used. On the "Economic Analysis" and "Financial Analysis" sheets, values calculated on the demand forecast sheet—"Transformer Calculation"—are automatically retrieved.
- Power loss: The personnel using this spreadsheet may set it based on the technical evaluation.
- Year of starting construction work: The personnel using these calculation sheets may decide this year.
- Project term: 20 years
- O&M cost: The personnel using these calculation sheets may set it based on the technical evaluation. Tentatively, 2% of the investment cost is used.
- Monetary value: It must be the year when the user estimates the project cost.
- Direct capital cost: Value is retrieved from the linked "Cost Estimation" sheet.
- Inventory & startup cost: Tentatively, 5% of the investment cost is used.
- Depreciation: Straight line method is used.
- Concession fee: The personnel using these calculation sheets may set it as a precondition of simulation.
- Equity portion of the concessionaire: Automatically calculated.
- Power wholesale price: For the time being, the rate applied by ESCOM is used, but in the future, the wholesale price in market transactions will be used.

5.10.1 Data sheet

Data input in the column of “Premises”

The personnel using the calculation sheet must input data for the following items: GDP Deflator, Effective Income Tax, Power Wholesale and Retail Prices, Year of Starting Construction Work, Project Term, and O&M Cost

Only the input data on the wholesale and retail prices are in terms of kwacha per kWh, but they are automatically converted into US cents per kWh using currency conversion rate in the “Cost Estimation Sheet.”

Depreciation Base/Schedule

The user must input data for only three items: “Value in,” “Inventory & Startup Cost,” and “Concession Fee.” Other values (i.e., data) are linked to other calculation sheets.

Data Sheet

Premises					
GDP Deflator	%/Yr	1.7			
Effective Income Tax	%	30			
Power Wholesale Price	US\$/kWh	2.6	2.9121		
Power Retail Price	US\$/kWh	6.0	6.6		
Power Loss	%	6			
Year of Start of Construction Work		2004			
Project Term	Year	20			
O&M Cost	%	2			
Depreciation Base/Schedule					
Value in	Year	2004			
Direct Capital Cost	US\$	242,472			
Inventory & Startup Cost	US\$	12,124	<=	5	% of direct capital cost, and paid by the concessionaire
Total Project Capitalized Cost	US\$	254,596			
Depreciable Portion of Capitalized Cost	US\$	242,472			
Concession Fee	US\$	100	<=		<=paid by the concessionaire
Equity Portion of the Concessionaire	US\$				

5.10.2 FIRR sheet

Two types of project schemes are shown: One is applied to the program up to Phase 4 where ESCO take over the project, and another, to the concessionaire.

The only value to be input is “O&M Subsidy.” The user changes the value and evaluates a reasonable FIRR. Tentatively, the value of the O&M subsidy is constant during the project life (i.e., it is not escalated.)

The user must be careful about the following points:

- If the value of cash flow of each year becomes minus, it means that the business operation faces a cash shortage, and an additional capital injection is needed.
- In this calculation, therefore, this situation must be avoided by increasing the O&M subsidy or decreasing the leasing fee.

FIRR Sheet

	Value /Costs of 2004	Year																					
		0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	
Premises																							
ODP Deflator	%/Yr	1.7																					
Effective Income Tax	%	30																					
Power Wholesale Price	US\$/MWh	2.6																					
Power Retail Price	US\$/MWh	6.0																					
Adjusted Power Sales	kWh/Yr		404,551	409,023	413,544	418,115	422,737	427,357	432,081	436,858	441,687	446,570	451,507	456,507	461,498	466,492	471,492	476,495	481,498	486,498	491,498	496,498	
Power Loss	%	6																					
Year of Start of Construction Work	Year	2004																					
Project Term	Year	20																					
O&M Cost	%	2	= An expected percentage share of the direct capital cost.																				
Depreciation Base/Schedule																							
Direct Capital Cost	US\$	242,472	242,472	**paid by the government																			
Inventory & Startup Cost	US\$	12,124	12,124	= 5 % of direct capital cost, and paid by the concessionaire																			
Total Project Capitalized Cost	US\$	254,596	254,596																				
Depreciable Portion of Capitalized Cost	US\$	242,472	242,472																				
Concession Fee	US\$	100	**paid by the concessionaire																				
Equity Portion of the Concessionaire	US\$	12,224																					
Depreciation	%	5.00	**straight line method																				
Income Statement under the Current Scheme Applied to ESCOM																							
Power Sales	US\$		24,273	24,967	25,681	26,416	27,171	34,157	35,064	35,996	36,953	37,937	38,947	39,985	40,054	40,271	40,520	40,802	41,118	41,464	41,840	42,246	
O&M Subsidy	US\$		3,980	4,000	4,020	4,040	4,060	4,080	4,100	4,120	4,140	4,160	4,180	4,200	4,220	4,240	4,260	4,280	4,300	4,320	4,340	4,360	
Total Revenue	US\$		28,253	28,967	29,701	30,456	31,231	38,237	39,164	40,116	41,093	42,097	43,127	44,185	44,495	44,811	45,142	45,488	45,848	46,222	46,610	47,012	
Power Purchased	US\$		11,294	11,719	12,055	12,399	12,754	16,033	16,459	16,896	17,346	17,807	18,281	18,769	19,270	19,784	20,312	20,854	21,410	21,980	22,564	23,162	
O&M Cost	US\$		4,249	4,934	5,019	5,106	5,195	5,285	5,377	5,470	5,565	5,662	5,760	5,860	5,962	6,065	6,170	6,277	6,386	6,497	6,610	6,725	
Depreciation of Asset	US\$		12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	
Taxable Income	US\$		3,966	4,191	4,484	4,787	5,099	8,715	9,105	9,506	9,919	10,344	10,782	11,233	11,413	11,555	11,653	11,708	11,720	11,696	11,538	11,346	
Income Tax	US\$		1,172	1,237	1,345	1,436	1,530	2,615	2,731	2,832	2,929	3,023	3,113	3,200	3,284	3,355	3,413	3,458	3,491	3,512	3,521	3,518	
Income After tax	US\$		2,793	2,953	3,139	3,351	3,569	6,100	6,374	6,674	6,990	7,321	7,669	8,033	8,129	8,199	8,240	8,250	8,228	8,184	8,019	7,828	
Cash Flow	US\$		-254,596	14,838	15,057	15,362	15,744	16,693	18,224	18,407	18,728	19,067	19,365	19,671	19,907	20,092	20,232	20,326	20,374	20,376	20,322	20,212	
FIRR to Equity		4.36%																					
Note 1: Initial capital investment paid by the government is a sort of equity financing measure.																							
Income Statement under a New Scheme Applied to a Concessionaire																							
Power Sales	US\$		24,273	24,967	25,681	26,416	27,171	34,157	35,064	35,996	36,953	37,937	38,947	39,985	40,054	40,271	40,520	40,802	41,118	41,464	41,840	42,246	
O&M Subsidy	US\$		5,100	4,100	4,100	4,100	4,100	4,100	4,100	4,100	4,100	4,100	4,100	4,100	4,100	4,100	4,100	4,100	4,100	4,100	4,100	4,100	
Total Revenue	US\$		29,373	29,067	29,781	30,516	31,271	38,257	39,164	40,096	41,053	42,037	43,047	44,085	44,175	44,371	44,620	44,902	45,218	45,564	45,940	46,346	
Power Purchased	US\$		11,294	11,719	12,055	12,399	12,754	16,033	16,459	16,896	17,346	17,807	18,281	18,769	19,270	19,784	20,312	20,854	21,410	21,980	22,564	23,162	
O&M Cost	US\$		4,949	4,934	5,019	5,106	5,195	5,285	5,377	5,470	5,565	5,662	5,760	5,860	5,962	6,065	6,170	6,277	6,386	6,497	6,610	6,725	
Depreciation of Concession Fee	US\$		5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
Leasing Fee Paid Back to the FE	US\$																						
Fund (= Depreciation of the Asset)	US\$		12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	12,124	
Taxable Income	US\$		1	286	379	882	1,194	4,810	5,200	5,601	6,014	6,439	6,877	7,328	7,520	7,575	7,592	7,560	7,489	7,381	7,236	7,063	
Income Tax	US\$		0	86	174	264	358	1,443	1,560	1,680	1,804	1,932	2,063	2,198	2,247	2,262	2,243	2,190	2,104	2,007	1,897	1,773	
Income After tax	US\$		1	200	205	528	836	3,367	3,640	3,921	4,210	4,507	4,914	5,231	5,328	5,313	5,328	5,270	5,185	5,074	4,939	4,790	
Cash Flow	US\$		-12,224	6	205	410	622	841	3,372	3,645	3,926	4,215	4,513	4,819	5,134	5,061	5,061	4,988	4,833	4,591	4,246	3,801	
FIRR to Equity		18.60%																					
Note 2: Assets invested by the government is leased to a concessionaire. This is a sort of lease scheme. In this case, a judicial body, Asset Management Corporation, that owns and manages this asset must be established.																							
<div style="border: 1px solid black; padding: 5px; margin-top: 10px;"> <p>If the value of cash flow of each year becomes minus, it means that the business operation faces cash shortage, and an additional capital injection is needed.</p> <p>In this calculation, therefore, this situation must be avoided by increasing O&M subsidy or decreasing leasing fee.</p> </div>																							

5.10.3 EIRR sheet

This sheet is completely automatically calculated if necessary data in the data sheet are input.

EIRR Sheet

Power Wholesale Price		US\$/kWh	2.6																				
Power Retail Price		US\$/kWh	6.0																				
Power Loss		%	6.0																				
O&M Cost		%	2																				
Value of 2004 US\$																							
Years	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20		
Power Sales (kWh)	484,551	489,023	413,544	411,115	422,787	522,337	527,081	531,838	536,607	541,570	546,507	551,408	651,492	656,593	661,715	666,869	672,042	677,242	682,709	688,063			
Item	Initial amount	Replacement period																					
A. Investment Schedule																							
Direct Capital Cost	342,472	20	342,472																				
I. Total	342,472		342,472	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
II. Working capital (Inventory and Startup Cost)	12,134		12,134																				
C. Annual costs																							
Power Purchased	11,394		11,519	11,647	11,776	11,906	14,711	14,844	14,979	15,115	15,252	15,392	15,532	18,340	18,482	18,627	18,774	18,923	19,071	19,220	19,370		
O&M	4,040		4,040	4,040	4,040	4,040	4,040	4,040	4,040	4,040	4,040	4,040	4,040	4,040	4,040	4,040	4,040	4,040	4,040	4,040	4,040		
III. Total	0		16,243	16,369	16,486	16,625	16,755	19,561	19,694	19,828	19,964	20,102	20,241	20,382	23,198	23,341	23,487	23,634	23,782	23,931	24,079		
D. Benefits																							
IV. Incremental output			34,273	34,541	34,813	25,087	25,364	31,341	31,625	31,911	32,201	32,494	32,790	33,090	39,090	39,396	39,705	40,016	40,333	40,651	40,967		
E. Net benefits			-3,40,473	-4,094	8,172	8,316	8,462	8,609	11,781	11,931	12,083	12,237	12,392	12,548	12,708	15,892	16,054	16,219	16,385	16,552	16,720		
IV. I.O.R.																							
Discount rate	12%																						
Net present value	-169,778		-242,472	-3,655	6,515	5,919	5,378	4,885	5,968	5,397	4,880	4,413	3,990	3,608	3,262	3,642	3,285	2,963	2,673	2,411	2,174		
Internal rate of return	0.7%		-242,472	-4,072	8,089	8,189	8,289	8,389	11,419	11,509	11,591	11,678	11,765	11,852	11,940	14,854	14,928	15,002	15,078	15,153	15,227		

As regards the economic opportunity cost for capital international institutions generally use 12% as a hurdle rate. (But this does not necessarily reflect the cost of capital in Malawi)

6. Management on progress (Refer to Attachment 3-a)

As mentioned in Section 5.1 (c) Scheduling on field survey, One-week field survey and one-week deskwork for reviewing the progress would be recommended. Progress on a FS should be checked and next survey schedule should be reviewed together with analyses.

7. Reporting (Refer to Attachment 4-a, 4-b)

Report on the result of each and every TC should be made immediately after field surveys together with drawings and results of calculation. It should include some important information listed below and be described as simply as possible.

Check Sheet on Equipment Preparation

Name of the Trading Center: _____

Equipment	Check
1/250,000 scale maps, hopefully more detailed maps	
Feasibility Study Manual	
Case study report on MAREP Master Plan	
Copies of the maps around the TC (At least 2/TC) (TC should be at the center of the map)	
Data sheet on public facilities	
More than 30m measuring tape	
Roller measure	
Results on Demand Forecast (as of master plan)	
Plane board for drawings	
White papers (more than 30 for each trip)	
Section papers	
Pencils	
Eraser	
Colored pens	
Rulers	
Calculators (at least 1 per team)	
GPS	
Batteries for GPS	
Magnet compass	
Laser binocular	
Diskette(s) (except one day trip)	
Lap top (except one day trip)	
Watch	
Check sheet on the Field Survey (at least one per TC)	
(Umbrellas)	
(Caps)	

Check Sheet on Field Survey

Name of the Trading Center: _____

No	Activities	Check
	Map Study (Using 1/250,000 maps)	
1	Put existing/planned lines on the map	
2	Decide estimated route distance from branch points on existing line to the target TC on the map	
	Field Survey – Outside TC	
3	Confirm GPS position at each and every relevant corner of the road	
4	Confirm relevant TCs, bridges etc on the route to the target TC	
5	Confirm the target TC	
6	Confirm existing line and end pole with GPS	
7	Confirm planned line or relevant TCs with GPS if any	
8	Confirm distance from branch points on existing line to the target TC by odometer	
9	Confirm voltage level of existing line (ESCOM engineer)	
10	Check size "square mm" and condition of conductor on existing line (ESCOM engineer)	
	Field Survey – Inside TC (Sketching)	
11	* The TC's name of, date, start and finish time, drawer's name, direction (North), scale and GPS position should be included on the drawings	
12	Confirm public facilities by interviewing responsible person(s)	
13	Confirm private entities	
14	Confirm daily activities inside/outside of the TC	
15	Measure each person's step length if no digital roller measure	
16	Measure radius (length and width) of the TC	
17	Measure width of the main road through the TC and branches	
18	Measure distance from the main road to existing public facilities	
19	Include major features such as shops in the sketch	
20	Confirm maize mill(s) and measure distance	
21	Confirm obstacles for the proposed line	
22	Decide the transformer position (normally load center) considering the voltage drop	
23	Measure GPS position of the transformer	
24	Put tentative 400/230V lines on the sketch considering the voltage drop	
25	Cross check proposed/planned/existing lines for the TC	

The Basic Time Schedule and each Role in Field Survey

Person	Main Role	Main Equipment	The Basic Time Schedule					
			Start	1st Meeting for confirmation	2nd Meeting for confirmation	Finish		
			☆	☆	☆	☆		
			Outside TC	Inside TC				
DOE Economist	Socio-economic Survey		Assistance of Engineer	12	13,14	25		
DOE Engineer	Making Sketch	<ul style="list-style-type: none"> • GPS • Compass 	3,4,5,6,7	11	15,16,17,18	19	23,24	25
ESCOM Engineer	Measuring the Distance Deciding the position of Transformar	<ul style="list-style-type: none"> • Digital Roller Measure • Laser Meters 	8,9,10	15,16,17,18	20,21,22,24	25		

*After finishing your survey, cooperate with and help other member.

*The numbers in bar show ones in [Check sheet on field survey]

Check Sheet for Demand Forecast (Public Facility and Business Entity)

TC DATA FORM: FEASIBILITY STUDY FOR MAREP PHASE V

DATE: _____

DISTRICT: Chitipa

TA: _____

TC NAME: Kameme

DISTANCE FROM DL: _____

LOCATION BY GPS: _____

Market Fee: _____

IRR: _____

No. OF PUBLIC FACILITIES

	Number				Number				Number				Number		
	M/P	Survey	Planned		M/P	Survey	Planned		M/P	Survey	Planned		M/P	Survey	Planned
Secondary School:		1		Health Center :		1		Police Unit:		0		Court:		1	
Primary School:		1		Clinic :		0		Admarc:		0		Other Public Facilities:		4	
Teacher's Development Center:		0		Post Office:		0		Government Offices:		2					
Staff House:		0		Police Station:		1		Church:		1					
Hospital:		0		Police Post:		0		Mosque:		0					
TOTAL PUBLIC FACILITIES:	0	12	0												

BUSINESS ENTITIES

	Number				Number				Number				Number		
	M/P	Survey	Planned		M/P	Survey	Planned		M/P	Survey	Planned		M/P	Survey	Planned
Markets:				Maize Mills:	2	2		Restaurants:				Rest Houses:			
Battery Charge Stations:				Shops:		25		Other BE:							
TOTAL BUSINESS ENTITIES:	2	27	0	Total Number for Demand Forecast without Maize Mills:						25					
GRAND TOTAL	2	39	0												

(A rest house is counted as 5 business entities)

HOUSEHOLD

	Number	
	Census	Survey
Number of Household:		342

NAME: _____



SIGNATURE: _____

Demand Forecast in TC

DISTRICT: Chilipa
TC NAME: Kameme

Year	Max Capacity (kW)																	Public Facilities Total	Maize Mill		Business Entities		Business Entities Total		Ordinary Household		Rich Household		Household Total	TC Total
	Secondary School	Primary School	Teacher's Development Center	Staff House	Hospital	Health Center	Clinic	Post Office	Police Station	Police Post	Police Unit	Admarc	Government Office	Church	Mosque	Court	Other Public Facilities		Number	kW	Number	kW	Number	kW	Number	kW				
2007	0.4000	0.4000	0.0000	0.0000	0.0000	0.3100	0.0000	0.0000	0.3000	0.0000	0.0000	0.0000	0.2000	0.1000	0.0000	0.2000	0.4000	2.3100	2	40.0200	14	1.1200	41.1400	176	35.2000	10	2.0000	37.2000	80.6500	
2008	0.4000	0.4000	0.0000	0.0000	0.0000	0.3100	0.0000	0.0000	0.3000	0.0000	0.0000	0.0000	0.2000	0.1000	0.0000	0.2000	0.4000	2.3100	3	60.0300	14	3.9200	63.9500	178	35.6000	10	2.8000	38.4000	104.6600	
2009	0.4000	0.4000	0.0000	0.0000	0.0000	0.3100	0.0000	0.0000	0.3000	0.0000	0.0000	0.0000	0.2000	0.1000	0.0000	0.2000	0.4000	2.3100	3	60.1500	14	3.9200	64.0700	180	36.0000	10	2.8000	38.8000	105.1800	
2010	0.7200	0.8800	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.5000	0.0000	0.0000	0.0000	0.2000	0.1400	0.0000	0.2800	0.4000	3.9100	3	60.1500	15	4.2000	64.3500	182	50.9600	10	3.6000	54.5600	122.8200	
2011	0.7200	0.8800	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.5000	0.0000	0.0000	0.0000	0.2000	0.1400	0.0000	0.2800	0.4000	3.9100	3	60.1500	15	8.4000	68.5500	185	51.8000	10	6.4000	58.2000	130.6600	
2012	0.7200	0.8800	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.5000	0.0000	0.0000	0.0000	0.2000	0.1400	0.0000	0.2800	0.4000	3.9100	3	60.1500	15	8.4000	68.5500	187	52.3600	10	20.0000	72.3600	144.8200	
2013	0.7500	0.9100	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.5100	0.0000	0.0000	0.0000	0.2000	0.1400	0.0000	0.4800	0.4000	4.1800	3	60.1500	15	8.4000	68.5500	190	53.2000	10	20.0000	73.2000	145.9300	
2014	0.7500	0.9100	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.5100	0.0000	0.0000	0.0000	0.2000	0.1400	0.0000	0.4800	0.4000	4.1800	3	60.1500	15	8.4000	68.5500	192	53.7600	11	22.2200	75.9800	148.7100	
2015	0.7500	0.9100	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.5100	0.0000	0.0000	0.0000	0.2000	0.1400	0.0000	0.4800	0.4000	4.1800	4	80.2000	15	8.4000	88.6000	194	54.3200	11	22.2200	76.5400	169.3200	
2016	0.8500	1.0100	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.5600	0.0000	0.0000	0.0000	0.2800	0.1400	0.0000	0.5300	0.4000	4.5600	4	80.2000	16	8.9600	89.1600	197	70.9200	11	22.2200	93.1400	186.8600	
2017	0.8500	1.0100	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.5600	0.0000	0.0000	0.0000	0.2800	0.1400	0.0000	0.5300	0.4000	4.5600	4	80.2000	16	8.9600	89.1600	199	71.6400	11	22.2200	93.8600	187.5800	
2018	0.8500	1.0100	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.5600	0.0000	0.0000	0.0000	0.2800	0.1400	0.0000	0.5300	0.4000	4.5600	4	80.2000	16	8.9600	89.1600	202	72.7200	11	22.2200	94.9400	188.6600	
2019	1.2500	1.4100	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.7600	0.0000	0.0000	0.0000	0.2800	0.1400	0.0000	0.5300	0.4000	5.5600	4	80.2000	16	8.9600	89.1600	204	130.5600	11	22.2200	152.7800	247.5000	
2020	1.2500	1.4100	0.0000	0.0000	0.0000	0.7900	0.0000	0.0000	0.7600	0.0000	0.0000	0.0000	0.2800	0.1400	0.0000	0.5300	0.4000	5.5600	5	100.2500	16	8.9600	109.2100	207	132.4800	11	22.2200	154.7000	269.4700	

Year	Power Consumption (kWh)																	Public Facilities Total	Maize Mill		Business Entities		Business Entities Total	Ordinary Household		Rich Household		Household Total	TC Total
	Secondary School	Primary School	Teacher's Development Center	Staff House	Hospital	Health Center	Clinic	Post Office	Police Station	Police Post	Police Unit	Admarc	Government Office	Church	Mosque	Court	Other Public Facilities		Unit	Year	Unit	Year		Number	Year	Number	Year		
2007	884	884	0	0	0	1,099	0	0	1,820	0	0	0	728	473	0	468	1,560	7,916	2	114,457	14	815	115,273	176	128,128	10	7,280	135,408	258,597
2008	884	884	0	0	0	1,099	0	0	1,820	0	0	0	728	473	0	468	1,560	7,916	3	172,700	14	12,027	184,726	178	129,584	10	8,445	138,029	330,672
2009	884	884	0	0	0	1,099	0	0	1,820	0	0	0	728	473	0	468	1,560	7,916	3	172,762	14	12,689	185,451	180	131,040	10	9,537	140,577	333,945
2010	1,217	1,258	0	0	0	5,293	0	0	3,800	0	0	0	1,144	517	0	666	1,934	15,829	3	172,762	15	19,274	192,036	182	153,695	10	11,029	164,725	372,589
2011	1,217	1,258	0	0	0	5,293	0	0	3,800	0	0	0	1,144	517	0	666	1,934	15,829	3	172,762	15	55,965	228,727	185	156,229	10	35,490	191,719	436,275
2012	1,217	1,258	0	0	0	5,293	0	0	3,800	0	0	0	1,144	517	0	666	1,934	15,829	3	172,762	15	55,965	228,727	187	157,918	10	52,962	210,880	455,436
2013	1,303	1,344	0	0	0	5,584	0	0	3,888	0	0	0	1,196	517	0	1,186	2,028	17,045	3	172,762	15	55,965	228,727	190	181,199	10	56,602	237,801	483,573
2014	1,303	1,344	0	0	0	5,584	0	0	3,888	0	0	0	1,196	517	0	1,186	2,028	17,045	3	172,762	15	55,965	228,727	192	183,107	11	62,502	245,609	491,381
2015	1,303	1,344	0	0	0	5,584	0	0	3,888	0	0	0	1,196	517	0	1,186	2,028	17,045	4	230,350	15	55,965	286,315	194	185,014	11	63,303	248,317	551,676
2016	1,511	1,552	0	0	0	5,584	0	0	4,033	0	0	0	1,378	517	0	1,277	2,392	18,243	4	230,350	16	59,696	290,046	197	217,275	11	63,303	280,578	588,867
2017	1,511	1,552	0	0	0	5,584	0	0	4,033	0	0	0	1,378	517	0	1,277	2,392	18,243	4	230,350	16	59,696	290,046	199	219,481	11	63,303	282,784	591,073
2018	1,511	1,552	0	0	0	5,584	0	0	4,033	0	0	0	1,378	517	0	1,277	2,392	18,243	4	230,350	16	59,696	290,046	202	222,790	11	63,303	286,093	594,382
2019	2,551	2,592	0	0	0	5,584	0	0	4,834	0	0	0	1,378	517	0	1,277	2,392	21,124	4	230,350	16	59,696	290,046	204	723,996	11	63,303	787,299	1,098,469
2020	2,551	2,592	0	0	0	5,584	0	0	4,834	0	0	0	1,378	517	0	1,277	2,392	21,124	5	287,937	16	59,696	347,633	207	734,643	11	63,303	797,946	1,166,703



VOLTAGE DROP CALCULATION FOR HV DISTRIBUTION LINES

Equation 1

Input figures in green cell.

HAZEL CONDUCTORS (AAAC 50mm²)

Sqrt of 3	R/km	X/km	cos φ	sin φ	dist.of line (km)	dem.(kw)	syst.volt.(kV)
1.732	0.616	0.38	0.9	0.48	30.0	3000	33

I(A)	Vs (kV)	VD (kV)	Vr (kV)	% VD
52.486	35	2.009	32.991	0.029

OAK CONDUCTORS (AAAC 100mm²)

Sqrt of 3	R/km	X/km	Cos φ	sin φ	dist.of line (km)	dem.(kw)	syst.volt.(kV)
1.732	0.311	0.358	0.9	0.48	100.0	2000	33

I(A)	Vs (kV)	VD (kV)	Vr (kV)	% VD
34.991	35	2.738	32.262	2.236

Equation : $V_r = V_s - 1.732I(R \cos \phi + X \sin \phi)$

$I = (\text{Demand}/1.732)/33\text{kV}$

$\% \text{ VD} = 100 (33\text{kV} - V_r)/33\text{kV}$

Vs = Supply Voltage

Vr = Received Voltage

VD = Voltage Drop

I = Current

R = Resitance

X = Reactance

cosφ = Power Factor

TAKE NOTE

* In case of 11kV, [syst.volt.(kV)] should be changed from 33kV into 11kV, and [Vs (kV)] also should be changed.

VOLTAGE DROP CALCULATION FOR LV DISTRIBUTION LINES

Equation 2

Input figures in green cell.

ANT CONDUCTORS (50mm²)

R/km	X/km	dist.of line-(km)	demand-(w)	No.of Facility
0.6638	0.275	0.5	4600	1

I(A)	supply voltage	Vr	VD	% VD
20	230	216.724	13.276	5.772

WASP CONDUCTORS (100mm²)

R/km	X/km	dist.of line-(km)	demand-(w)	No.of Facility
0.3309	0.253	1	4600	1

I(A)	Vs (V)	Vr (V)	VD (V)	% VD
20	230	216.764	13.236	5.755

Equation : $V_r = V_s - 2IR$ $I = (\text{Demand} \times \text{No.of Facility}) / \text{voltage}$ $\% \text{ VD} = (V_s - V_r) / V_s$

Vs = Supply Voltage

R = Resitance

Vr = Received Voltage

X = Reactance

VD = Voltage Drop

I = Current

TAKE NOTE

* In case of a maize mill connection, voltage drop calculation should be done using equation3 below.

VOLTAGE DROP CALCULATION FOR LV LINE WITH A MAIZE MILL AS LOAD

Equation 3

Input figures in green cell.

ANT CONDUCTORS (50mm²)

Sqrt of 3	R/km	X/km	Cos ϕ	sin ϕ	dist.of line (km)	dem.(kw)	syst.volt.(V)
1.732	0.6638	0.275	0.8	0.36	0.7	25	400

I (A)	Vs (V)	VD (V)	Vr (V)	% VD
36.084	400	27.564	372.436	6.891

WASP CONDUCTORS (100mm²)

Sqrt of 3	R/km	X/km	Cos ϕ	sin ϕ	dist.of line (km)	dem.(kw)	syst.volt.(V)
1.732	0.3309	0.253	0.8	0.36	1.3	20	400

I (A)	Vs (V)	VD (V)	Vr (V)	% VD
28.868	400	23.127	376.873	5.782

Equation : $V_r = V_s - 1.732I(R \cos \phi + X \sin \phi)$

$I = (\text{Demand}/1.732)/0.4\text{kV}$

$\% \text{ VD} = 100(V_s - V_r) / V_s$

Vs = Supply Voltage
Vr = Received Voltage
VD = Voltage Drop
I = Current

R = Resitance
X = Reactance
cos ϕ =Power Factor

CALCULATION FOR BILL OF QUANTITIES FOR 33kV OVERHEAD LINE

NOTE: Enter length of line in column C3

33.75 km

(unit:MK)

QUANTITY/km	MATERIAL DESCRIPTION	TOTAL QUANTITY	UNIT PRICE	TOTAL PRICE
3150	100mm ² AAAC 'OAK'	106312.5	75.39	8,014,899
90	7/8 GMSW	3037.5	97.29	295,518
18	7/8 guy grips	607.5	182.54	110,893
77	Barbed wire	2598.75	24	62,370
1	33kV 200Kg spindles	33.75	166.05	5,604
48	Binding stirrups (33kV)	1620	0.65	1,053
25	Pilot spindles	843.75		0
25	33kV pin insulators	843.75	607	512,156
6	HV stay insulators	202.5	539.75	109,299
27	Disc insulators	911.25	1,117.32	1,018,158
40	Aluminium binding tape	1350	3.31	4,469
16	M12/150 nuts & bolts	540	29.66	16,016
16	M16/150 bolts & nuts	540	58.07	31,358
8	M16/260 bolts & nuts	270	68.81	18,579
10	M16/300 bolts & nuts	337.5	115.13	38,856
66	M16 flat washers	2227.5	0.47	1,047
32	M16 spring washers	1080	0.02	22
4	18mm stay rods	135	868.44	117,239
2	M20/400 bolts & nuts	67.5	134.75	9,096
10	M20 flat wahers	337.5	5.18	1,748
28	M20 spring washers	945	0.04	38
6	M20/400 eye bolts & e/nuts	202.5	145.95	29,555
9	100mm ² Snail clamps	303.75	809.23	245,804
16	Tie straps	540	231.41	124,961
9	Clevis adaptors	303.75	131.38	39,907
9	Insulator hooks	303.75	274.11	83,261
3	Danger plates	101.25	249.76	25,288
1	9.0m wood pole	33.75	853.88	28,818
8	10.8m(s) wood pole	270	5664.32	1,529,366
2	12.3m(H) wood pole	67.5	1975.24	133,329
4	X11 cross arms	135	1610.95	217,478
6	Stay baulk	202.5	717.75	145,344
6	SP 10 spacer block	202.5	111.65	22,609
8	X49 cross arm	270	1988.23	536,822
1	33kV Air Break Switch	33.75	65726	2,218,253
1	33kV Auto-recloser	33.75	79860	2,695,275
SUB-TOTAL				18,444,489
1	Manhrs for gang and Cost	33.75	77,767.00	2,624,636
1	Manhrs for OHL Supervisor &Cost	33.75	14,274.10	481,751
1	km + Hiring for Gang	33.75	66,154.00	2,232,698
1	km + Hiring for Supervisor	33.75	19,795.00	668,081
1	km + Allowed for fuel for gang	33.75	7,817.00	263,824
1	km + Allowed for fuel for Supervisor	33.75	1,868.00	63,045
1	compensation fee	33.75	unknown	
SUB-TOTAL				6,334,035

TOTAL**24,778,524.04**

CALCULATION FOR BILL OF QUANTITIES FOR 400V OVERHEAD LINE

NOTE: Enter length of line in column C48

3.3 km

(unit:MK)

QUANTITY/km	MATERIAL DESCRIPTION	TOTAL QUANTITY	UNIT PRICE	TOTAL PRICE
4200	100mm2 AAC 'WASP'	13860	53.53	741,926
154	7/12 GMSW	508.2	36.61	18,605
4	70mm2, 4 core MV Cu Cable	13.2	612.56	8,086
32	MO-O line taps	105.6	128.38	13,557
4	MO-5/5 line taps	13.2	258.4	3,411
4	70mm2 bimetal pin terminals	13.2	11.84	156
88	Bobbin insulators	290.4	44.44	12,905
14	LV stay insulators	46.2	46.07	2,128
14	12mm2 stay rods	46.2	793.85	36,676
32	M16/200 bolts & nuts	105.6	58.28	6,154
40	M16/260 bolts & nuts	132	68.81	9,083
48	D' irons	158.4	88.14	13,961
16	9.0m wood pole	52.8	853.88	45,085
14	Stay baulk	46.2	717.75	33,160
SUB-TOTAL				944,894
1	Manhrs for gang and Cost	3.3	77,767.00	256,631
1	Manhrs for OHL Supervisor &Cost	3.3	14,274.10	47,105
1	km + Hiring for Gang	3.3	66,154.00	218,308
1	km + Hiring for Supervisor	3.3	19,795.00	65,324
1	km + Allowed for fuel for gang	3.3	7,817.00	25,796
1	km + Allowed for fuel for Supervisor	3.3	1,868.00	6,164
1	compensation fee	3.3	unknown	
SUB-TOTAL				619,328
TOTAL				1,564,222

COST ESTIMATION CALCULATION SHEET

TC name: Nthalire
Region NORTHERN
District Chitipa
Date: 5/12/03

												Exchange rate	110
HV types	HV(km)	HV COST/km*	LV(km)	LV COST/km	HV COST	LV COST	No.of Tx50	50kVA Cost	No.of Tx 100	100kVA Cost	Tx COST	TC COST(Total) MK	TC COST(Total) US\$
33kV OAK	33.75	749,687	3.3	286,332	25,301,932	944,894	1	174,400	1	250,700	425,100	26,671,926	242,472
33kV HAZEL		632,662		286,332	0	0		174,400		250,700	0	0	0
11kV OAK		685,957		286,332	0	0		174,400		250,700	0	0	0
11kV HAZEL		572,670		286,332	0	0		174,400		250,700	0	0	0

*(HV COST/km) depend on types of HV

Types of HV	HV COST/km
11kV overhead line constructed with 50mm ² AAAC (HAZEL)	572,670
11kV overhead line constructed with 100mm ² AAAC (OAK)	685,957
33kV overhead line constructed with 50mm ² AAAC (HAZEL)	632,662
33kV overhead line constructed with 100mm ² AAAC (OAK)	749,687

Premises

GDP Deflator	%/Yr	1.7	
Effective Income Tax	%	30	
Power Wholesale Price	US¢/kWh	2.6	2.9121
Power Retail Price	US¢/kWh	6.0	6.6
Power Loss	%	6	
Year of Start of Construction Work		2006	
Project Term	Year	20	
O&M Cost	%	2	

Depreciation Base/Schedule

Value in	Year	2006	
Direct Capital Cost	US\$	242,472	
Inventory & Startup Cost	US\$	12,124	<= 5 % of direct capital cost, and paid by the concessionaire
Total Project Capitalized Cost	US\$	254,596	
Depreciable Portion of Capitalized Cost	US\$	242,472	
Concession Fee	US\$	100	<= <=paid by the concessionaire
Equity Portion of the Concessionaire	US\$		

Progress Management Sheet (on MAREP Phase 5 FS)

D: Done, S: Sent to the Study Team

Region	Name	Phase by M/P	TC Name	complete	Date of Survey	Report	Route Map 1/250,000	Route Map Around TC	Map Inside TC (White)	Map Inside TC (Trans. Line)	Table on Socio-Economic	Calculation Voltage Drop	Calculation Cost	Demand Forecast	Calculation IRR	BOQ	Num. of TC along the line	Remarks and public facilities within about 1km from the TC	
Northern	Chitipa	5	Nthalire	1	5/12/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				3	1 Primary School	
	Chitipa	6-1	Wenya	1	4/12/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				3	No comment	
	Karonga	7-2	Mulare	1	3/12/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				0	2 Secondary schools (2 groups)	
	Karonga	9-1	Hara	1	2/12/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				0	No comment	
	Rumphi	5	Katowo	1	10/12/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				2	1 Agriculture offices	
	Rumphi	5	Chitimba	1	11/12/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				1	No comment	
	Nkhata Bay	5	Mpamba																
	Nkhata Bay	5	Kavuzi																
	Mzimba	5	Edingeni	1	12/12/03													0	
	Mzimba	7-1	Mnyamula	1	13/12/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				0		
	Central	Kasungu	5	Chamama															
		Kasungu	5	Mpepa															
		Nkhotakota	5	Mkaika															
Nkhotakota		5	Dwambadzi																
Nichisi		5	Nthesa																
Ntchisi		5	Khuwi																
Dowa		5	Thambwe																
Dowa		5	Bowe																
Salima		5	Kandulu	1	4/12/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				0	No comment	
Salima		5	Chilambula	1	1/12/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				0	No comment	
Lilongwe		5	Chilobwe																
Lilongwe		5	Nyanja																
Mchinji		5	Mkanda																
Mchinji		5	Chiosya																
Dedza		5	Kabwazi																
Dedza		5	Golomoti	1	3/12/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				0	No comment	
Nicheu		5	Ntinda																
Nicheu		5	Kasinje	1	2/12/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				0	1 Secondary school	
Southern		Mangochi	5	Makanjira	1	12/11/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				4	1 Police unit must be electrified
	Mangochi	5	Chitipa	1	11/11/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				0	1 Primary Axhool, 1 Secondary school (1 group), 1 ADMARK and 1 Office (1group)	
	Machinga	5	Chikwewu																
	Machinga	5	Nampeya																
	Balaka	5	Chendausiku																
	Balaka	5	Kwitanda																
	Zomba	5	Jenale																
	Zomba	5	Sunuzi																
	Chiradzulu	5	Kanje																
	Chiradzulu	6-1	Chimwawa																
	Blantyre	5	Chikuli																
	Blantyre	5	Mombo																
	Mwanza	6-1	Ligowe																
	Mwanza	5	Thambani																
	Neno	Mwanza	5	Chikonde															
	Neno																		
	Thyolo	5	Nansadi																
	Thyolo	6-1	Lalakani	1	6/11/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				0	1 primary school	
	Mulanje	5	Chinyama	1	7/11/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				2	No comment	
	Mulanje	6-1	Namthombozi	1	8/11/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				0	No comment	
	Phalombe	6-1	Phaloni	1	20/11/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				0	No comment	
	Phalombe	5	Mlomba	1	19/11/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				1	1 Agriculture offices	
	Chikwawa	5	Mitondo	1	18/11/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				2	No comment	
Chikwawa	5	Linyunzu	1	17/11/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				2	1 Primary school		
Nsanje	5	Tangani	1	4/11/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				0	Part of the TC is electrified, 1 Police unit		
Nsanje	5	Mankhokwe	1	5/11/03	D,S	D,S	D,S	D	D,S	D,S	D,S	D,S				0	No comment		

total

23

Format of Report

1. Name of the TC :
2. Date and time of the field survey:
3. Participants:
4. Outline of the TC

Region	
District	
Traditional Authority	
Scale/Size of the TC	
Public facilities ():Number of buildings	
Number of maize mill(s)	
Demand in 2001,2020(kW)	
Activities inside TC	
Activities outside TC	
Public facilities outside TC	
GPS position	
Location of the TC	
Location of existing line	

5. Recommended route

33kV line	Total : 7.6km from Recommended 33kV route is
Step down transformer(s)	Number and capacity of transformer(s): Place of transformer
400/230V line	Total length of 400V (3phases) : m Total length of 230V (single phase): m

6. Voltage drop calculation (Refer to Result)

33kV	
400/230V	

7. Cost estimation (Refer to BOQ)

Total cost (MK)	
Total cost (US)	(Exchange rate: 1US= MK)

8. Economical Analysis(Refer to the results)

Internal Rate of Return	%
-------------------------	---

Sample of Report
(Report on the MAREP Phase V Feasibility Study)

1. Name of the TC: Mulare
2. Date and time of the field survey: From 13.58 hrs to 15.53 hrs, 2 Dec 2003
3. Participants: Mr. K. Lungu, Mr. D. Kalimba, Mr. Y. Kawakami, Mr. G. Moya
4. Outline of the TC

Region	North
District	Karonga
Traditional Authority	Kyungu
Scale/Size of the TC	Medium
Public facilities (): Number of buildings	1 Primary School (16), 1 SEDOM Office (1), 1 Health Centre (3), 1 P0st Office (1).
Number of maize mill(s)	3
Demand in 2020(kW)	38
Activities inside TC	Vending of groceries, foodstuffs and alcoholic beverages
Activities outside TC	Farming
Public facilities outside TC	1 Secondary School about 1km to the East of TC 1 Secondary School about 0.75 km to the west of TC.
GPS position	S10°13'01.6" E034°05'41.5"
Location of the TC	Along the M1 Road, 7.6 km North of Ngara TC (or 15.5 km North of Nyungwe TC) in Karonga.
Location of existing line	An 11KV line following the road from Wovwe to Uliwa and ending at Ngara TC along the M1 Road. GPS Position of end pole is S10°13'01.6" E034°05'41.5"
Trading Centres between end pole and TC	None

5. Recommended route

33kV line	Total: 7.6 km from Ngara TC Recommended 33KV route is from Ngara TC to Mlare TC along the M1 Road
Step down transformer(s)	Number and capacity of transformer(s): 1 X (100KVA) GPS Position of transformer: S10°10'26.1"

	E034°02'30.6"
400/230V line	Total length of 400V (3phases): 1475m Total length of 230V (single phase): Not applicable

6. Voltage drop calculation (Refer to Result)

33kV	0.011295447
400V/230V	Not necessary

7. Cost estimation (Refer to BOQ)

Total cost (MK)	6,552,217
Total cost (US\$)	(Exchange rate: 1US\$= 110 MK) 59,566

8. Economical Analysis (Refer to the results))

Internal Rate of Return	18.32%
-------------------------	--------