

in employment.

## **9.6 PREDICTION OF IMPACTS: OPERATION PHASE**

### **9.6.1 General**

The operation phase of the project will include conveyance of tapped sewage from nalas and pumping stations to sewage treatment plants. It also includes the operation of sewage treatment plants. The predicted impacts of these activities are discussed below.

Overall, the predicted adverse impacts during the operational phase will be minor as compared to the construction phase. During the operation phase all the beneficial impacts of the project will be realised.

### **9.6.2 Beneficial Impacts of the Project during the Operation Phase**

The rehabilitation and extension of sewerage and the treatment of all the city sewage will improve the quality of life and the life style of the people. Better sanitation facilities mean better health conditions, and a cleaner environment. The risk of contagious diseases can be minimised and to an extent even mitigated. Implementation of sewer system in the city would reduce the chances of contamination of the groundwater and in the water supply pipelines therefore minimising the incidence of diseases resulting in improved health and economic well being of the community.

Also, the discharge of sewage wastewater in the nala, and the discharge of sullage into road drain and then into nala, which emanate foul smells and are unsightly, will be eliminated.

In sum, the overall impact of the project on the socio-economic environment is expected to be beneficial and positive. The residents of Lucknow will benefit due to the improvements in public health.

### **9.6.3 Sewerage and Pumping Station Impacts (Operation Phase)**

The impacts of sewerage and pumping station during operation phase are summarised in Table 9.36.

### **9.6.4 Sewage Treatment Plant Impacts (Operation Phase)**

#### **(1) Receiving Water Quality and Treated Effluent Re-use**

The wastewater after treatment will be generated to the tune of 305mld (year 2030) and 100mld (year 2015). It is proposed that the treated wastewater will be used for irrigation on the agricultural fields near the Mastemau site. Currently there is plenty of land available at Mastemau, Bakkas, Chilaula and Ardaunamau where there is a potential to use the treated wastewater. Although there is no norm or a ratio to estimate the quantity of wastewater per hectare of land, considering the previous trend and after studying few reports, it can be safely presumed that 1 mld of treated wastewater is sufficient to irrigate a land of 20 ha.

The potential of land irrigation was calculated by referring to “Practical Handbook on Public Health Engineering by G.S. Bajwa, pp 900, published by Deep Publishers, Shimla”.

Accordingly the calculations are as follows:

|   |                       |
|---|-----------------------|
| Irrigation intervals during summer      | 5 days                |
| Irrigation intervals during winter      | 10 days               |
| Hydraulic loading rate for sandy soil = | 200-250 Cu.M/ ha /day |

|                               |   |                   |                                    |
|-------------------------------|---|-------------------|------------------------------------|
| Loading Rate/ha/day in summer | = | 250 /5 = 50       | Cu.M /ha/day                       |
| Loading Rate/ha/day in winter | = | 250 /10 =25       | Cu.M /ha/day                       |
| Area required for 305mld      | = | 305000/50 = 6,010 | Hectares required during summers   |
| For 1 MLD area required is    | = | 6010/ 305 = 19.7  | (say 20ha) required during summers |

It is proposed that from the total amount of wastewater generated, partial quantity will be used for irrigation, while the remaining wastewater will be discharged into the river.

Currently the crops grown are rice, wheat, pulses and vegetables. The present practice of the farmers is to use ground water for irrigating their lands. From discussions with various officials, it was understood that the continuous use of groundwater is resulting in depletion of the groundwater resources. With the use of treated effluent for the crops, there will be sufficient reduction in the use of groundwater. Further, there will also be reduction in power consumption, which is now being used to pump the ground water.

Considering this, it can be concluded that the application of treated water for agricultural use will prove beneficial both for safe disposal of effluent and secondly beneficial to the farmers.

However, there should be certain norms and standards that should be followed while practicing this method and they are being discussed in the chapter on mitigation measures.

During the rainy season, the amount of wastewater to be used for irrigation will reduce drastically since much of the land will receive good rainfall in the months of July and August. Since the treated sewage will be further diluted, it will not pose any risk towards the pollution of the river.

(2) Use of Sludge for Land Application

The sludge produced at the proposed STP will have the characteristics as given in Table 9.36.

**Table 9.36 Quality of Sludge at the Proposed STP**

|        | N % (W/W) | P % (W/W) | K % (W/W) |
|--------|-----------|-----------|-----------|
| Sludge | 1.7       | 0.9       | 0.2       |

Application of sludge to land will improve the soil conditions of the area and supplement conventional fertilisers usually at a little or no cost. The organic matter increases the soil's ability to hold water, and opens up the soil to allow better air and water movements into the soil. Application of sludge will permit easier root penetration and reduce water runoff and soil erosion.

Sludge produced at the proposed STP site can be sold directly to the farmers near the site.

On average the sludge production will be approximately 56.3 m<sup>3</sup>/day from the STP. It will be dried on the sludge drying beds. During the drying process, there will be a nuisance of insects around the sludge drying beds. It can be minimised by spraying insecticides in the area, also by proper maintenance of sludge drying beds, and proper drainage. The wet sludge should be raked often and the dried sludge removed frequently.

The dried sludge can be given or sold to farmers as manure if it can be handled properly by them. The value of sludge as an organic fertiliser has long been recognised and this offers reduced fertiliser costs to the farmer. Monitoring of the quality of the sludge is however required, especially the monitoring of heavy metals. The sludge should also not contain non-degradable materials. Movement of sludge tankers from sewage treatment to agricultural land can create traffic problems and give rise to noise and odour nuisance.

(3) Odour Production

There is a possibility of generation of localised odours in the case of UASB reactors and sludge drying beds proposed at the STP of Mastemau. Since there is no habitation near the STP site, generation of odour will not lead to any inconvenience. Further, the technology adopted will ensure that minimum or no odour is generated. Plantation and other mitigative measures will help in controlling the smell.

(4) Noise level

Higher noise levels will be generated near the DG sets and gas engines. Although this will be significant, the impact of the noise will be reduced by enclosing the noise generating equipments in a double walled structure.

(5) Worker's and Public Health

Even though the STP will be useful to improve the health of the citizens, it may not be so in regard to the health of the workers who are operating the plant. In the operation phase of the STP, care needs to be taken for the workers' health. The workers may suffer from epidemic diseases, malaria and respiratory diseases if proper precautions are not taken. The impact on their health would be adverse and significant. The workers should be provided with safety equipment for safe handling of the sewage treatment plant - sewage and sludge - and must be instructed in its use. This will eliminate any possibility of adverse health effects on the workers during plant operations. Adequate medical help should also be provided.

Similarly, the farmers will also have to be protected against infection, and special equipment, especially to handle the sludge, should be made available and they should be educated on how to wear it.

## **9.7 ENVIRONMENTAL MITIGATION PLAN**

### **9.7.1 Introduction**

The objective of preparing an Environmental Mitigation Plan (EMP) is to formulate measures, whose implementation will:

- Mitigate adverse effects on various environmental components and resources as have been identified in the EIA study;
- Protect environmental resources wherever possible;
- Enhance the value of the environmental component wherever possible.

The EMP also includes a plan for monitoring so as to enable evaluation of the success or failure of environmental management measures and reorientation of the plan if found necessary.

The mitigation measures to be adopted cover both the construction phase and the operation phase. These measures normally are short term during the construction phase and long term during the operation phase.

The community must be informed in advance about the benefits of the project and possible inconvenience to them. The implementing agency must seek co-operation of the local authorities, and execute the project effectively and efficiently. Success of the project depends upon participation and support of the community. Efforts need to be made to involve the population at different stages of project execution and in subsequent maintenance. The construction work should be carefully planned and managed in order to cause minimum disturbances to people.

A summary of the mitigation measures proposed during construction and operation phases are presented in Table 9.37. The description of each mitigation measure in detail is described below.

### **9.7.2 General Mitigation Measures**

#### **(1) Construction Phase**

The construction phase impacts have been outlined in previous section. All these adverse impacts have been taken into consideration. Following measures should be adopted in general for all activities:

1. Minimum damage to existing flora and fauna, structures, electricity and telephone cables.
2. Minimum disturbance to the local activities and business should be ensured.
3. The sewer pipes should be stacked properly in a pre-determined location and should not be cluttered around blocking the pedestrian area alongside the roads.
4. Excavated earth should be prevented from getting washed into drainage channels, rivers and canals.
5. Surplus excavated earth should be disposed of immediately.
6. Measures should be taken to prevent direct discharge of polluted waters from construction activities into lake, rivers and irrigation canals.
7. Dust pollution should be controlled with the measures outlined in the Table 9.37.
8. Pavements and roads should be repaired immediately following the construction activity and the project and surrounding area should be restored as near as possible to pre-project conditions.
9. Adequate measures should be taken to minimise construction related noise.
10. Proper precautions should be taken against risk of accidents.

#### **(2) Operation Phase**

All the adverse impacts have been taken into consideration. The following measures should be adopted in general for all activities:

1. The treated water quality should be maintained as per the requirements at all times.
2. Air and noise quality should be monitored and corrective action taken in case it exceeds applicable norms.
3. Proper precautions should be taken for the good health of the operators and the population.
4. Greenbelt has been proposed for all the pumping stations of CGPS, TGPS and Martinpurwa. The greenbelt areas are shown in Figures 9.3, 9.4 and 9.5, respectively.

#### **(3) Mitigation Measures for Sewerage**


Selection of route for sewers is one of the most important activities in the pre-construction phase. In order to minimise adverse environmental impacts and land acquisitions, to avoid resettlement and rehabilitation problems and in general, from a social point of view, to minimise severance and other problems due to pipe laying activities, the sewers will be laid along the roads.

- Construction of the sewerage system will comprise: carrying the pipes to the site, excavation, laying the sewer pipeline, making good of the site after laying the pipeline, disposal of spoil/excavated material.
- All relevant codes of practice should be followed during detail engineering and construction phases to ensure pipelines safety and protection against corrosion.
- The risk of accidents should be minimized by taking all the proper precautions during the sewer laying activity.
- In some narrow roads and busy crossings, care must be taken for proper diversions of the traffic

with the help of the traffic police.

- Care should also be taken to avoid damaging existing infrastructure, telephone and power supply electric cabling, poles, etc. and minimizing the construction level impacts.

Final Report on Water Quality Management Plan for Ganga River  
Volume IV-1, Feasibility Study for Lucknow City, Part I, Sewerage Scheme



**NOTES:**  
1) ALL DIMENSIONS ARE IN METERS.  
2) ALL DIMENSIONS ARE TO FACE UNLESS OTHERWISE SPECIFIED.  
3) PLEASE DO NOT SCALE THE DRAWING ONLY WRITTEN DIMENSIONS ARE TO BE FOLLOWED.



**LEGEND:**  
 GREENBELT  
 PROPOSED AREA  
 EXISTING AREA

| INST. | ELEC. | MECH. | STRU. | CIVIL | REV NO. | 0 | 1 | 2 | 3 | 4 |
|-------|-------|-------|-------|-------|---------|---|---|---|---|---|
|       |       |       |       |       |         |   |   |   |   |   |

| REV. | DESCRIPTION OF REVISIONS | DATE | CHECKED |
|------|--------------------------|------|---------|
|      |                          |      |         |

CHECKED BY: SAURABH MISRA  
 APPROVED BY: Y N SONTAKKE

|          |              |       |            |
|----------|--------------|-------|------------|
| DRAWN    | GANKAR C K   | SCALE | NTS        |
| DESIGNED | PABRIKAR N P | DATE  | 14-12-2004 |
| SURVEYED |              |       |            |

**JICA**  
 JAPAN INTERNATIONAL COOPERATION AGENCY  
 CONSULTANTS:  
 TOKYO ENGINEERING CONSULTANTS CO. LTD.  
 CIL ENGINEERING INTERNATIONAL CO. LTD.  
 IWH INDIA PRIVATE LIMITED


**PROJECT:**  
 THE STUDY ON WATER QUALITY MANAGEMENT PLAN FOR GANGA RIVER IN THE REPUBLIC OF INDIA  
 FEASIBILITY STUDY FOR LUCKNOW CITY

**SHEET CONTENTS:**  
 GREENBELT PLAN FOR CIS GOMTI PUMPING STATION

DRAWING NO.

**FIGURE NO.9.3**

Final Report on Water Quality Management Plan for Ganga River  
Volume IV-1, Feasibility Study for Lucknow City, Part I, Sewerage Scheme



**NOTES:**  
1) ALL LEVELS ARE IN METER.  
2) ALL DIMENSIONS ARE IN MM.  
3) PLEASE DO NOT SCALE THE DRAWING ONLY WRITTEN DIMENSIONS ARE TO BE FOLLOWED.

**LEGEND:**  
..... GREENBELT

| INST. | ELEC. | MECH. | STRU. | CIVIL. | REV NO. | 0 | 1 | 2 | 3 | 4 |
|-------|-------|-------|-------|--------|---------|---|---|---|---|---|
|       |       |       |       |        |         |   |   |   |   |   |
|       |       |       |       |        |         |   |   |   |   |   |
|       |       |       |       |        |         |   |   |   |   |   |
|       |       |       |       |        |         |   |   |   |   |   |
|       |       |       |       |        |         |   |   |   |   |   |
|       |       |       |       |        |         |   |   |   |   |   |
|       |       |       |       |        |         |   |   |   |   |   |
|       |       |       |       |        |         |   |   |   |   |   |
|       |       |       |       |        |         |   |   |   |   |   |
|       |       |       |       |        |         |   |   |   |   |   |

| REV. | DESCRIPTION OF REVISIONS | DATE | CHECKED |
|------|--------------------------|------|---------|
|      |                          |      |         |
|      |                          |      |         |
|      |                          |      |         |
|      |                          |      |         |
|      |                          |      |         |
|      |                          |      |         |
|      |                          |      |         |
|      |                          |      |         |
|      |                          |      |         |
|      |                          |      |         |
|      |                          |      |         |

**CHECKED BY:** SAURABH MISRA  
**APPROVED BY:** V N SONTAKKE


**DRAWN:** GANAK C K  
**DESIGNED:** PABRAKAR N P  
**SURVEYED:** DATE: 14-12-2004

**JICA**  
JAPAN INTERNATIONAL COOPERATION AGENCY  
CONSULTANTS:  
TOKYO ENGINEERING CONSULTANTS CO., LTD.  
CTI ENGINEERING INTERNATIONAL CO., LTD.  
IWH INDIA PRIVATE LIMITED

**PROJECT:**  
THE STUDY ON WATER QUALITY MANAGEMENT PLAN FOR GANGA RIVER IN THE REPUBLIC OF INDIA  
FEASIBILITY STUDY FOR LUCKNOW CITY  
GREENBELT PLAN FOR TRANS GOMTI PUMPING STATION

**DRAWING NO.:** **FIGURE NO.9.4**

Final Report on Water Quality Management Plan for Ganga River  
Volume IV-1, Feasibility Study for Lucknow City, Part I, Sewerage Scheme



| INST. | ELEC. | MECH. | STRU. | CIVIL. | REV NO. | 0 | 1 | 2 | 3 | 4 |
|-------|-------|-------|-------|--------|---------|---|---|---|---|---|
|       |       |       |       |        |         |   |   |   |   |   |

| REV. | DESCRIPTION OF REVISIONS | DATE | CHECKED |
|------|--------------------------|------|---------|
|      |                          |      |         |

|               |                 |              |            |
|---------------|-----------------|--------------|------------|
| CHECKED BY:   |                 | APPROVED BY: |            |
| SAURABH MISRA |                 |              |            |
| CHKD BY:      | Y N SONTAKKE    | DATE:        | 14-12-2004 |
| DESIGNED BY:  | PAUREKAR N P    | SCALE:       | NTS        |
| DRAWN BY:     | CHAKRABARTY K K |              |            |

**jica** JAPAN INTERNATIONAL COOPERATION AGENCY  
 CONSULTANTS: TOKYO ENGINEERING CONSULTANTS CO. LTD.  
 CCI ENGINEERING INTERNATIONAL CO. LTD.  
 IWH INDIA PRIVATE LIMITED

PROJECT: THE STUDY ON WATER QUALITY MANAGEMENT PLAN FOR GANGA RIVER IN THE REPUBLIC OF INDIA  
 SHEET CONTENTS: FEASIBILITY STUDY FOR LUCKNOW CITY  
 GREENBELT PLAN FOR MARTIN PURWA PUMPING STATION


DRAWING NO. **FIGURE NO.9.5**

(4) Mitigation Measures for Sewage Treatment Plant

**Treated Water Quality**

First and foremost, care should be taken to ensure adequate treatment to meet the discharge standards. Since it is recommended that the treated wastewater be reused for irrigation purposes, the treated wastewater should meet the required standards for irrigation re-use and be conveyed upstream of an area that can be irrigated.

Treated water quality should be monitored carefully so as to meet the discharge standards effectively. Figure 9.6 demonstrates the use of treated effluents for various purposes. However, in the case of Lucknow, the treated effluent will be used for agricultural irrigation and excess being disposed into the river.



**Figure 9.6 Direct and Indirect Use of Treated Effluent**

**Sludge Disposal**

The sludge from the treatment plant should be disposed of in an environmentally acceptable manner. The sludge should be dewatered in sludge drying beds and the dried sludge is proposed to be used as fertiliser since it is biological in nature and has soil quality enhancing properties. However, the following precautions should be taken in the treatment, handling and disposal of the sludge:

- to rake the wet sludge frequently and remove dried sludge immediately,
- to facilitate proper drainage to avoid standing water leading to mosquito breeding,
- to store the dry sludge in a covered place before its distribution to farmers,
- to develop a green belt all around treatment plant,
- to take care that the operators handling the sludge are properly clothed with gloves and gum boots and will not handle the sludge with bare hands.

**Workers' Health**

The workers' health should be monitored with medical check-ups at the time of joining and thereafter

at regular intervals. In between, in case of any complaints, respiratory ailments, accidents, medical check-up should be conducted.

All the workers should be trained in first aid and emergency medical health should be available round the clock. It is also recommended from the safety point of view that one officer of the managerial cadre is available on duty at all times.

### ***Land Acquisition***

No relocation of people will take place during the project. Land will be acquired with appropriate compensation. Land is normally acquired under the provisions of the Land Acquisition Act, 1894 that is general and basic law in the country for the acquisition of land for public purposes and companies. This Act was comprehensively amended in the year 1984, taking into consideration the recommendations of the Law Commission, the Land Acquisition Review Committee.

There are two types of compensation. Monetary compensation has to be provided to direct Project Affected Persons (PAPs) if their houses have to be acquired and demolished. It has to be provided also to indirect PAPs for their agricultural land to be acquired. Alternate land has to be provided to displaced persons for their resettlement. If land for resettlement can not be provided or PAPs are not willing to resettle in the new resettlement site, then monetary compensation has to be provided to direct PAPs for their homestead (i.e. residential) land to be acquired.

This will ensure that the farmers selling their land will not be affected.

### ***Greenbelt Plantation***

A 15 m greenbelt all along the plant boundary is proposed. Even within the plant premises, vacant land will be used to plant trees. The species should be selected considering the local flora and species. Development of green belt will minimise the noise levels to the outside of the plant boundary and filter the odour levels to a considerable extent. Greenbelt will also give an aesthetic cover to the plot area and the activities going on within the plant will not pose any disturbance to the local people outside.

The greenbelt area for the proposed STP site is given in Figure 9.7



Table 9.37 Summary of Environmental Impacts and Environmental Mitigation Plan

| Environmental Issues      | Adverse Impact   | Nature of Impact          | Proposed Mitigation Measures  | Implementing Authority |
|---------------------------|--|---------------------------|---|------------------------|
| <b>CONSTRUCTION PHASE</b> |  |                           |   |                        |
| Soil Quality              | <ul style="list-style-type: none"> <li>Due to excavation and earthwork: soil erosion, loss of top soil, silting and blocking of drainage/ nallas, which can cause slush; damage to existing structures</li> <li>Due to compacting: loss of original quality, reduction in fertility</li> </ul> | Significant and Permanent | <ul style="list-style-type: none"> <li>Stabilise all slopes with provision of benches/pitching</li> <li>Avoid earthwork during monsoon</li> <li>Provide adequate cross drainage facilities</li> <li>Restrict traffic movements and use low ground pressure machines</li> <li>Preserve top soil to be replaced after the completion of construction activity; avoid wet soils</li> <li>Dispose of surplus earth after raising levels and refilling trenches, in low lying areas with proper compacting and planting of surfaces</li> <li>Plant shrubs/trees/grass on exposed slopes and surfaces</li> </ul>                              | UPJN/<br>Contractor    |
| Air Quality               | <ul style="list-style-type: none"> <li>Localised increase in dust due to excavation &amp; earthwork</li> <li>Temporary increase in the levels of SO<sub>2</sub>/NO<sub>x</sub>, from construction equipment and vehicles</li> </ul>  | Significant and Temporary | <ul style="list-style-type: none"> <li>Dust control through sprinkling / washing of construction sites and access roads particularly in congested areas</li> <li>Use of dust cover over construction material</li> <li>Dust collectors should be used in all drilling operations</li> <li>Unnecessary idling of trucks should be avoided</li> <li>Construction material trucks to be covered to minimise spills</li> <li>Preventive maintenance of construction equipment and vehicles to meet emission standards</li> <li>Construction requiring heavy traffic street closing/diversion to be carried out during night time</li> </ul> | UPJN/<br>Contractor    |
| Noise Pollution           | <ul style="list-style-type: none"> <li>Increase in noise levels due to construction work, transport of construction materials, etc.</li> </ul>   | Significant and Temporary | <ul style="list-style-type: none"> <li>Equipment emitting noise over 90 dB should be avoided</li> <li>Noise generating construction work should be carried out in day time only</li> <li>Equipment maintenance strengthened to keep noise production low</li> <li>Sound barriers should be installed if needed</li> </ul>   | UPJN/<br>Contractor    |

| Environmental Issues          | Adverse Impact   | Nature of Impact          | Proposed Mitigation Measures   | Implementing Authority                    |
|-------------------------------|--|---------------------------|--|---|
| <b>CONSTRUCTION PHASE</b>     |  |                           |  |   |
| Water Quality/<br>Drainage    | <ul style="list-style-type: none"> <li>Increase in turbidity affecting surface water quality</li> <li>Sanitary pollution</li> </ul>  | Significant               | <ul style="list-style-type: none"> <li>Ensure steps to prevent earth and stone from silting up the nalas and drainage systems</li> <li>Control run off and soil erosion through proper drainage channels and structures; improve existing cross drainage and provide extra cross drainage works wherever necessary</li> <li>Provide adequate sanitation facilities to construction site workers</li> </ul>   | UPJN/<br>Contractor                       |
| Loss of Natural<br>Vegetation | <ul style="list-style-type: none"> <li>Loss of avenue trees and natural vegetation, especially in the clearance for treatment plant site</li> </ul>  | Significant and Permanent | <ul style="list-style-type: none"> <li>Replantation on treatment plant area, as well as around the periphery</li> <li>Replantation of avenue trees and ensuring proper care for growth</li> </ul>  | UPJN/ Forest<br>Department/<br>Contractor |
| Traffic                       | <ul style="list-style-type: none"> <li>Traffic jams, bottlenecks, delays and inconveniences to general public</li> <li>Serious disruptions of vehicular traffic, pedestrian access and commerce</li> </ul> | Significant and Temporary | <ul style="list-style-type: none"> <li>Co-ordinate and plan all activities in advance</li> <li>Adequate actions to direct traffic in consultation with highway and traffic police</li> <li>Minimise vehicle movements</li> <li>Preference for unused or low traffic roads</li> <li>Construction of temporary roads and diversion of traffic</li> <li>Use of trenchless sewer technology to minimise the damage</li> <li>Seek public co-operation through public awareness</li> </ul> | UPJN/<br>Contractor/<br>Traffic Police    |
| Social Disruptions            | <ul style="list-style-type: none"> <li>Disruptions in utility services</li> <li>Social hostility due to employment of outsiders on construction activities</li> </ul>                                      | Temporary                 | <ul style="list-style-type: none"> <li>Minimise interruptions to services through proper planning and scheduling of activities and strong inter-departmental co-ordination</li> <li>Preference should be given to local labour/skilled persons during construction, operation and maintenance</li> </ul>   | UPJN                                      |
| Risk of Accidents             | <ul style="list-style-type: none"> <li>Endangering lives of people/workers during construction due to inadequate safety measures</li> </ul>  | Significant               | <ul style="list-style-type: none"> <li>Adequate traffic control measures should be taken</li> <li>Sign board warning presence of open sewer trench</li> <li>Guard rails to protect pedestrians</li> <li>Strong safety policy for workers; protective helmets to be provided</li> </ul>   | Contractor/<br>UPJN                       |

| Environmental Issues       | Adverse Impact   | Nature of Impact              | Proposed Mitigation Measures  | Implementing Authority |
|----------------------------|--|-------------------------------|---|------------------------|
| <b>CONSTRUCTION PHASE</b>  |  |                               |   |                        |
| Aesthetic Conditions       | <ul style="list-style-type: none"> <li>Visually anaesthetic conditions due to cluttering of waste, and spoils, dug up roads and pavements</li> </ul>   | Significant and Temporary     | <ul style="list-style-type: none"> <li>Enhance aesthetics through proper housekeeping of construction site</li> <li>Disposal of construction wastes at the approved sites quickly</li> <li>Repair pavements and roads after sewer laying work is completed</li> <li>Completing the construction activity by removing all spoils</li> </ul>  | UPJN/<br>Contractor    |
| Land Acquisition           | <ul style="list-style-type: none"> <li>Inadequate compensation</li> <li>Loss of Income</li> </ul>  | Significant and Permanent     | <ul style="list-style-type: none"> <li>Advance realistic payments to be made to relocated (estimation for compensation for land and property should be made on the prevailing market rates)</li> </ul>  | UPJN                   |
| Existing Infrastructures   | Site clearance and works: <ul style="list-style-type: none"> <li>Damage existing structures,</li> <li>Affect electricity supply and telecommunication lines,</li> <li>Clutter road sides with pipes,</li> <li>Cause general nuisance to public.</li> </ul> | Not Significant and temporary | <ul style="list-style-type: none"> <li>Minimum damage to existing structures, flora and fauna, avenue trees and other natural vegetation, electricity &amp; telephone lines and other infrastructure services</li> <li>Cleared earth and debris should be properly disposed off</li> <li>Storage sites should be identified for stacking pipes so as not to clutter road sides</li> </ul> | Contractor             |
| Construction Camps         | <ul style="list-style-type: none"> <li>Prevalence of unsanitary conditions and practices like open air defecation</li> <li>Possibilities of public health problems</li> <li>Piling of garbage from workers</li> </ul>                                      | Significant and Temporary     | <ul style="list-style-type: none"> <li>Adequate measures such as provision of septic tanks/pit latrines around the construction camp sites</li> <li>Provision of clean drinking water to potable water standards</li> <li>Collection of garbage in garbage cans in fixed places and disposal of it regularly</li> </ul>   | Contractor             |
| Public and Workers' Health | <ul style="list-style-type: none"> <li>Adverse health of workers due to unsanitary practices and spreading of diseases from vectors</li> </ul>   | Significant and Temporary     | <ul style="list-style-type: none"> <li>Workers are the immediately affected people</li> <li>Proper sanitation and drinking water should be provided</li> <li>Medical facilities to be provided to prevent communicable diseases</li> </ul>  | Contractor/<br>UPJN    |

| Environmental Issues        | Adverse Impact   | Nature of Impact | Proposed Mitigation Measures  | Implementing Authority |
|-----------------------------|--|------------------|---|------------------------|
| <b>OPERATION PHASE</b>      |  |                  |   |                        |
| Air Quality                 | <ul style="list-style-type: none"> <li>Problems of bad odour from the treatment plant</li> </ul>   | Significant      | <ul style="list-style-type: none"> <li>Some bad odour from sewage treatment plant is unavoidable; however, steps should be taken to minimise odour by proper maintenance and housekeeping of the treatment plant.</li> <li>Greenbelt should be adequately maintained.</li> <li>Noise generating equipments will be enclosed in double walled structures</li> </ul>            | UPIN/LJS/Operator      |
| Noise Quality               | <ul style="list-style-type: none"> <li>Noise from DG sets and dual fuel engines will be generated</li> </ul>   | Significant      | <ul style="list-style-type: none"> <li>Preventive maintenance of all components should be performed regularly</li> <li>Relevant standby equipment and spare parts should be provided; standby power generation should be provided at pumping stations, if any</li> <li>Proper response plan must be prepared and all workers must be trained to tackle emergencies</li> </ul> | UPIN/LJS/Contractor    |
| Water Quality               | <ul style="list-style-type: none"> <li>Overflow of sewers and breakdown of treatment plant leading to failure in meeting the requisite standards</li> <li>Poor performance will affect the proposed reuse for irrigation, and also the receiving water body</li> </ul> | Significant      | <ul style="list-style-type: none"> <li>Proper response plan must be prepared and all workers must be trained to tackle emergencies</li> </ul>   | UPIN/LJS/Operator      |
| Sludge Treatment & Disposal | <ul style="list-style-type: none"> <li>Improper treatment of sludge could lead to putrefaction and other related problems such as bad odour, health effects, etc.</li> </ul>   | Significant      | <ul style="list-style-type: none"> <li>Sludge should be treated properly and dewatered</li> <li>Dried sludge should be disposed of in a specified landfill site with proper precautions or given for land application to farmers, if it can be handled properly by them</li> </ul>  | UPIN/LJS/Operator      |
| Aesthetic                   | <ul style="list-style-type: none"> <li>Pumping stations, treatment work site might pose an unaesthetic sight but it affects only close residents</li> </ul>  | Not significant  | <ul style="list-style-type: none"> <li>Sewage plant should be located away from the densely populated residential areas</li> <li>Plantation of trees in and around the pumping stations/treatment plant would improve the aesthetics</li> </ul>   | UPIN/LJS/Operator      |
| Public Health               | <ul style="list-style-type: none"> <li>Mixing of sewage with drinking water</li> <li>Outbreak of waterborne diseases</li> <li>Unhealthy conditions: mosquito breeding over sludge drying beds, etc.</li> </ul>   | Significant      | <ul style="list-style-type: none"> <li>Any such health risk to public should be minimised by proper maintenance and operation of sewers, pumping stations, treatment plant, etc.</li> <li>In case of failure, inform relevant authorities to alert public at risk so that precautions might be taken</li> </ul>   | UPIN/LJS/Operator      |

| Environmental Issues         | Adverse Impact  | Nature of Impact          | Proposed Mitigation Measures  | Implementing Authority    |
|------------------------------|---|---------------------------|---|---------------------------|
| <b>OPERATION PHASE</b>       |   |                           |   |                           |
| Workers Health & Safety      | <ul style="list-style-type: none"> <li>Workers may be afflicted by endemic &amp; other diseases such as malaria or respiratory ailments</li> <li>Accidents and loss of lives may occur during sewer cleaning &amp; maintenance</li> <li>Non availability of emergency medical facilities at all times during day &amp; night</li> </ul> | Significant and Permanent | <ul style="list-style-type: none"> <li>Proper house keeping of the plant to prevent unsanitary conditions</li> <li>Regular medical check ups and immediate treatment of affected workers</li> <li>Maintenance personnel should not perform dangerous tasks when alone, enter the manholes without checking for gas and without proper protective clothing, enter the manholes without ropes and harnesses firmly tied</li> <li>Manholes should not be left open especially in busy roads, near schools and residential areas</li> </ul> | Operator/<br>LJS/<br>UPJN |
| Economically Weaker Sections | <ul style="list-style-type: none"> <li>Filthy, unnaesthetic conditions in slums, open defecation, foul smells, piling of garbage, endemic and epidemic diseases of residents</li> </ul>   | Significant               | <ul style="list-style-type: none"> <li>Provision of sanitation facility should be extended to slums; if possible, shallow sewers should be laid to drain these areas</li> <li>In areas that cannot be sewerred, on site sanitation facilities like pit latrines/community ablution blocks should be provided</li> <li>The residents should be educated on personal hygiene practices and the importance of sanitation and public health</li> </ul>  | UPJN/<br>LJS              |
| Social Disruptions           | <ul style="list-style-type: none"> <li>Breaking of sewer lines by farmers for irrigation as sewage would be a continuous source of water for irrigation</li> </ul>  | Significant               | <ul style="list-style-type: none"> <li>The sewers should be patrolled and any unauthorised human activity should be discouraged</li> <li>Farmers should be educated on health effects of using untreated sewage for irrigation, especially the effect of sewage flooding due to breakage of sewers with risks of epidemics</li> </ul>   | UPJN/<br>LJS/<br>Operator |

Table 9.38 Scoping Matrix for Project Component

| Environmental Elements                 | Social Environment |                   |                           |                     |                             |                         |             |      | Natural Environment    |              |             |                     |                 |                   |           | Pollution     |                 |                    |                     |      |
|--|--------------------|-------------------|---------------------------|---------------------|-----------------------------|-------------------------|-------------|------|------------------------|--------------|-------------|---------------------|-----------------|-------------------|-----------|---------------|-----------------|--------------------|---------------------|------|
|  | Land Acquisition   | Economic Activity | Traffic/Public Facilities | Cultural Properties | Water Right/Right of Common | Public Health Condition | Solid Waste | Risk | Topography and Geology | Soil Erosion | Groundwater | River Water Quality | Flora and Fauna | Local Meteorology | Landscape | Air Pollution | Water Pollution | Soil Contamination | Noise and Vibration | Odor |
| Development Scheme                     | C                  | A-                | B-                        | D                   | C-                          | C-                      | B-          |      | D                      | B-           | D           | C-                  | D               | D                 | B-        | C-            | D               | A-                 | D                   |      |
|  | O                  | A+                | D                         | D                   | C-                          | B+                      | -           | C-   | D                      | D            | D           | A+                  | D               | D                 | B-        | -             | D               | C-                 | C-                  |      |
| Pumping Station                        | C                  | A+                | B-                        | D                   | C-                          | C-                      | B-          |      | D                      | B-           | D           | C-                  | D               | D                 | B-        | C-            | D               | A-                 | D                   |      |
|  | O                  | A+                | D                         | D                   | C-                          | B+                      | -           | C-   | D                      | D            | B+          | B+                  | D               | D                 | B-        | -             | D               | C-                 | C-                  |      |
| Installation of Main Trunk Sewer       | C                  | C-                | A-                        | D                   | D                           | C-                      | B-          |      | D                      | B-           | D           | C-                  | D               | D                 | B-        | C-            | D               | A-                 | D                   |      |
|  | O                  | C+                | D                         | D                   | D                           | A+                      | -           | C-   | D                      | D            | D           | A+                  | D               | D                 | D         | -             | D               | D                  | D                   |      |
| Rehabilitation of Existing Trunk sewer | C                  | D                 | B-                        | D                   | D                           | C-                      | B-          |      | D                      | D            | D           | D                   | D               | D                 | B-        | C-            | D               | A-                 | D                   |      |
|  | O                  | D                 | D                         | D                   | D                           | B+                      | B+          | C-   | D                      | D            | D           | B+                  | D               | D                 | D         | -             | D               | D                  | D                   |      |

**Remarks:**

C: Indicates construction (rehabilitation) stage. O: Indicates operation stage.

A+: Strong positive impact

B+: Moderate positive impact

C+: Low positive impact

D: No impact foreseen

A -: Adverse negative impact

B -: Moderate negative impact

C -: Low negative impact

O: No impact foreseen

**Table 9.39 Analysis of Siting of the Mastemau Sewage Treatment Plant Drainage District IV – 137,500 m<sup>3</sup>/d in 2015, 330,000 m<sup>3</sup>/d in 2030**

| STP at Mastemau                               |  |
|---|--|
| Issues  |  |
| NATURAL PARAMETERS                            |  |
| Soil Quality                                  | <ul style="list-style-type: none"> <li>Construction of plant at this site will not have major impact on soil quality which is already very low.</li> </ul>   |
| Air Quality                                   | <ul style="list-style-type: none"> <li>Present location is away from the residential areas and outside (but not far from) the boundary of proposed development by LDA.</li> </ul>  |
| Water Quality                                 | <ul style="list-style-type: none"> <li>Treated water will be used for irrigation purpose in the surrounding area.</li> <li>The surplus water will be discharged into Gomti river passing near the village.</li> </ul>  |
| Ecologically Sensitive Area                   | <ul style="list-style-type: none"> <li>Present location is not in forest or ecologically sensitive area and is not likely to have any adverse effect on the existing flora and fauna of the project area.</li> <li>A private plantation area is near to the proposed STP site and a water body (Gajaria nala) passes between STP site and the plantation area clearly demarking both the sites avoiding the interference of STP site activities with the green cover.</li> </ul> |
| SOCIO-CULTURAL PARAMETERS                     |  |
| Land Use Pattern                              | <ul style="list-style-type: none"> <li>The present location is undeveloped and a part of the proposed site used for irrigation purpose by farmers.</li> <li>The project is not expected to alter the land use drastically as the area chosen is rather uneven and is criss-crossed by water channels. A part of the land where land is used by farmers for irrigation will have to be acquired.</li> </ul>   |
| Socio-Economic Condition                      | <ul style="list-style-type: none"> <li>Positive impact on socio-economic condition due to increase in employment opportunities during construction and operation and maintenance of the plant</li> </ul>   |
| Public Health                                 | <ul style="list-style-type: none"> <li>Proper housekeeping and maintenance of the plant required to offset problems of mosquito breeding and other nuisances</li> </ul>  |
| Archaeological/ Historical area               | <ul style="list-style-type: none"> <li>Present location does not affect any historical/ or archaeological heritage.</li> </ul>   |
| Aesthetic and Visual                          | <ul style="list-style-type: none"> <li>Present location does not pose such serious aesthetic and visual problems as it is away from dense residential areas.</li> </ul>  |
| PROJECT IMPLEMENTATION PARAMETERS             |  |
| Land Availability & Land Cost                 | <ul style="list-style-type: none"> <li>Location of treatment plant away from inhabited areas (70 ha required)</li> <li>The present location is outside the boundary of expected development</li> <li>Land cost would be cheapest here.</li> </ul>  |
| Sewage Collection                             | <ul style="list-style-type: none"> <li>Sewage from entire Cis-Gomti area can be brought to this site effectively.</li> </ul>   |
| Pumping                                       | <ul style="list-style-type: none"> <li>Will involve 2 sewage pumping stations one at Martin purva and another at STP site</li> </ul>   |
| Treatment Plant                               | <ul style="list-style-type: none"> <li>Treatment plant consists of Primary Treatment, UASB reactors followed by Facultative type Aerated Lagoons and Chlorination.</li> </ul>  |
| Sludge Disposal                               | <ul style="list-style-type: none"> <li>Treated sludge is organic in nature; it can be used as manure for agriculture.</li> </ul>   |
| Reuse –Irrigation potential of Treated Sewage | <ul style="list-style-type: none"> <li>Treated water is proposed to be used for irrigation purpose.</li> <li>The treated water meets discharge standards applicable for its use for agriculture.</li> <li>Irrigation fields are surrounding the STP site and the owners are ready to accept the water.</li> </ul>  |
| Use of biogas                                 | <ul style="list-style-type: none"> <li>Methane enriched biogas produced in UASB reactors can be supplied to nearby villages for cooking and for lighting.</li> <li>Biogas will be generated at the rate of 2800 m<sup>3</sup>/day.</li> <li>Remaining biogas is proposed to be utilised for generation of electricity.</li> <li>Coordination with LESA will be done for street lighting in Mastemau and Bakaas.</li> </ul>   |

## **9.8 ENVIRONMENTAL MANAGEMENT, TRAINING, AND MONITORING PLAN**

### **9.8.1 General**

The success of the Environmental Mitigation Plan depends on the efficiency of the organisational set up responsible for the implementation of the programme.

For a sanitation project of this magnitude, the Environmental Management Plan needs to be entrusted, in both the construction and the operation phases, to an Environmental Management Cell. Regular monitoring of various environmental parameters is necessary to evaluate the effectiveness of the management programme so that necessary corrective measures could be taken in case of any drawbacks.

Thus, the Environmental Management Plan will consist of:

- setting up an Environmental Management Cell to implement the mitigation measures in operation phase;
- ensuring a proper operation and maintenance of the treatment works;
- ensuring a proper maintenance of the sludge drying beds and the disposal of dry chemical sludge in a proper landfill site;
- monitoring the wastewater and treated water quality;
- monitoring the built in pollution control equipment, for vehicles and equipment;
- maintaining tree plantations around the sewage pumping stations and the periphery of the sewage treatment plant.

Details of the Management Cell and the monitoring requirements needed to ensure that construction and operation follow best environmental practices are given in this section.


### **9.8.2 Environmental Management Cell**

The Environmental Management Cell (EMC) will be part of the staff in charge of the operation and maintenance of the sewerage works, since the laboratory will be housed at the treatment plant site. But this staff will be in charge of the overall management of the environmental aspects of the Sanitation Project.

The staff will be provided by the operator of the treatment plant, in case the operation and maintenance of the treatment plant is subcontracted by UPJN.

Under the supervision of an Environmental Engineer, the EMC will comprise of an Environmental Scientist, a Chemist and a Biologist and three Assistants, as shown in the following organisation chart. The Environmental Engineer would report directly to the Top Management of UPJN.

The organisational chart is shown in Figure 9.8



**Figure 9.8 Environment Management Cell**

The main functions of the EMC will be:

1. Collecting water, air, soil and sludge samples;
2. Analysing the samples collected or getting analysis done from outside sources;
3. Preparing and updating a database of environmental parameters;
4. Implementing the environmental control and protective measures;
5. Controlling the sludge treatment, disposal and re-use;
6. Collecting statistics of health of workers and the population of surrounding areas;
7. Ensuring the development and maintenance of the green belts;
8. Monitoring the progress of implementation of EMP;
9. Coordinating the environment related activities within the project as well as with outside agencies

### 9.8.3 Monitoring Plan

To evaluate the effectiveness of the EMP, regular monitoring of the important environmental parameters will be taken up by UPJN. The schedule duration and parameters to be monitored by the environmental team are described below and summarised in Table 9.42.

#### (1) Water Quality

The sampling of various inlets and outlets will be carried out for analysis of relevant parameters. The analysis will be carried out once in a month both at the inlet and outlet of the STP and at strategic locations within the plant. Some of the parameters will be tested daily. This practice would help UPJN evaluate the performance of individual units of the STP and take corrective measures if the results are not satisfactory.

#### (2) Air Quality

Ambient air quality should be monitored for SO<sub>2</sub>, NO<sub>x</sub>, SPM, etc. At the STP, H<sub>2</sub>S and CH<sub>4</sub> should be monitored. Instruments like high volume air samplers and other monitoring kits should be used for the purpose of air quality monitoring. Monitoring points should be fixed in consultation with the UPPCB.

(3) Noise Monitoring

Noise levels should be monitored in working environment, main noise producing sources such as the DG sets, pumping stations, over the boundary and around the STP.

(4) Green Belt and Compensatory Plantation

Greenbelt developed around the pumping stations and STP should be monitored and taken out regularly for its proper growth.

#### **9.8.4 Environmental Testing Laboratory**

A well equipped laboratory for routine analysis of raw sewage and treated wastewater as well as for ambient air quality and sludge analysis should be provided at the STP site. The biological testing facility should be provided in this laboratory in addition to chemical analysis of water. The record of analyses should be maintained at the plant site for all the parameters mentioned in the monitoring plan.

#### **9.8.5 Environmental Training**

The environmental monitoring plan will be successful only if it is implemented by trained and skilled staff. The training of the qualified staff should be necessary not only in day to day operation and maintenance of the STP, but also in environmental aspects.

It will be essential to involve the staff who will be responsible for the execution of the EMP, in the construction phase, as well as to train the staff in practicing the mitigation actions and the day to day monitoring programme during the operation phase of the project.

The training should include:

- Basic concepts of pollution control techniques in the various methods of sewage treatment,
- Operation and maintenance of the STP,
- Emergency preparedness to handle adverse situations,
- Principles of wastewater analysis,
- Other environmental monitoring techniques,
- Development of green belt and its maintenance,
- Sewage farming,
- Communication with farmers and general public.

This training is different from the mandatory training required for operation and maintenance of the STP.

#### **9.8.6 Cost of EMP**

The block and recurring costs for the implementation of the Environment Management Plan is given in Table 9.40 and 9.41, respectively.

**Table 9.40 Block Costs for EMP**

| <b>Components</b>    | <b>Cost (in Rs.)</b> |
|----------------------|----------------------|
| Establishment of EMC | 500,000              |

**Table 9.41 Recurring Costs for EMP**

| <b>Components</b>                     | <b>Frequency</b> | <b>Costs (Rs./ year)</b> |
|---------------------------------------|------------------|--------------------------|
| Waste water and Treated Water Quality | Quarterly        | 52,500                   |
| Groundwater                           | Quarterly        | 60,000                   |
| Surface Water (Receiving Water Body)  | Quarterly        | 60,000                   |
| Ambient Air Quality                   | Quarterly        | 30,000                   |
| Ambient Noise                         | Quarterly        | 30,000                   |
| Environmental Audit                   | Once in year     | 200,000                  |
| Running Costs for EMC                 | Monthly          | 2,400,000                |
| Total                                 |                  | 2,832,500                |

**Table 9.42 Environmental Monitoring Plan**

| Environmental Quality                   | Monitoring Parameters   | Schedule and Duration of Monitoring   |
|---|---|---|
| Waste and Treated Water Quality         | <ul style="list-style-type: none"> <li>• All physico-chemical and bacteriological parameters as per UPCB standards; pH, temperature, TDS, TSS, DO, BOD, COD, heavy metals and <i>E coli.</i>, etc.</li> </ul> | <ul style="list-style-type: none"> <li>• Quarterly Analysis</li> <li>• Monitoring point will be the inlet and outlet of the treatment plant</li> <li>• Technical criteria should be based on UPPCB standards/ guidelines</li> </ul>   |
| Ambient Groundwater                     | <ul style="list-style-type: none"> <li>• pH, TDS, nitrates, fluorides, nitrites, and heavy metals</li> </ul>  | <ul style="list-style-type: none"> <li>• Once in 4 months</li> <li>• At sewage treatment plant location near sludge drying beds</li> <li>• Technical criteria should be based on UPPCB standards/ guidelines</li> </ul>   |
| Ambient Water Quality of Receiving Body | <ul style="list-style-type: none"> <li>• pH, TDS, TSS, BOD, COD, hardness, nitrates, heavy metals</li> </ul>  | <ul style="list-style-type: none"> <li>• Quarterly</li> <li>• At discharge points according to the option selected</li> <li>• Technical criteria should be based on UPPCB standards/ guidelines</li> </ul>  |
| Ambient Air Quality                     | <ul style="list-style-type: none"> <li>• SPM, NO<sub>x</sub>, CO, SO<sub>2</sub>, H<sub>2</sub>S, CH<sub>4</sub></li> </ul>   | <ul style="list-style-type: none"> <li>• Construction period: 3 times a year (January, May and September)</li> <li>• Monitoring point will be near construction sites and residential areas</li> <li>• Operation period: 24 hour samples, for one week, quarterly; Monitoring points will be fixed in consultation with the UPPCB</li> <li>• Technical criteria should be based on UPPCB standards/ guidelines</li> </ul> |
| Ambient Noise                           | <ul style="list-style-type: none"> <li>• Noise level</li> </ul>   | <ul style="list-style-type: none"> <li>• Operation period: Quarterly monitoring will be undertaken as appropriate; Monitoring points should be at pumping stations, near treatment plants</li> <li>• Technical criteria should be based on UPPCB standards/ guidelines</li> </ul>   |

## **9.9 RISK ANALYSIS & CONTINGENCY PLAN**

### **9.9.1 General**

The sanitation project comprises sewer laying, construction of sewage treatment plants and their operation. The risk involved in laying the sewers is mainly for pipelines of DN 600 and larger, which require lifting by cranes. The risk of mechanical equipment failure and thereby occurrence of accidents cannot be overlooked.

Contingency measures plans have been prepared for:

1. sewage treatment works that could reasonably be expected to cause significant environmental impacts as a consequence of operational disruption (i.e. maintenance, etc. or breakdown);
2. accidents which may occur while laying sewers or during construction of the treatment works;
3. discharge of sub-standard wastewater into the environment from treatment plant which could cause a significant public health impact, and which therefore requires a continuous system of influent/effluent monitoring to identify potential problems as and when they arise.

In the preparation of the contingency measures:

- the most likely causes of process disruption/breakdown have been identified;
- the possible resultant environmental adverse impacts are presented;
- the recommended courses of action to minimise the severity of the impacts have been highlighted;
- the responsible agency that will act in case of emergencies has been indicated.

Table 9.43 gives the potential risks due to construction, operation and maintenance and corrective actions. The major risks that can result in breakdowns and disruptions are described below.

### **9.9.2 Power Supply**

One of the main reasons for disruption during the operation phase of the treatment works is very likely to be power cuts due to a transmission line problem and/or energy shortage. Power cuts and the reasons for them should be monitored in advance so as to set a reliability analysis at the new treatment plant.

It is recommended that the new treatment plant influent pumping station is equipped with a branched connection to ensure continuity of operation in case one line remains out-of-order. It is also suggested that standby power generators are provided to ensure at least minimum services in case of prolonged power cuts.

Also the technology chosen should be able to survive short spells of power cuts.

### **9.9.3 E&M Equipment Disruptions**

Operational disruption due to E&M equipment can be avoided by spare parts and stand-by provision available at site.

O&M instructions and manuals should be provided by the contractor of the treatment plant with training of the operation staff.

Table 9.43 Risk Assessment and Contingency Plan

| Works                                       | Risks  | Impact  | Corrective Action Plan  | Responsibility  |
|---|--|---|---|---|
| <b>1. ACCIDENTS RELATED TO CONSTRUCTION</b> |  |   |   |   |
| 1.1<br>Sewerage                             | <ul style="list-style-type: none"> <li>Accidents due to pedestrians falling into the open trenches</li> <li>Accidents due to vehicular traffic and risk to pedestrians, workers, vehicle drivers</li> <li>Accidents due to failure of machinery such as cranes</li> <li>Accidents due to carelessness of workers</li> <li>Breakages of water supply pipes and services connections</li> <li>Risk of accidents</li> </ul> | <p>Significant</p> <p>Significant</p> <p>Significant</p> <p>Significant</p> <p>Significant</p> <p>Significant</p> | <ul style="list-style-type: none"> <li>Excavated trenches should be provided with adequate barricades</li> <li>Signboards in bold letters to be displayed in prominent places</li> <li>Solid planks with guard rails should be provided across the trenches for crossing</li> <li>Traffic diversions and signboards should be displayed prominently</li> <li>Proper lighting should be provided at night time</li> <li>Co-ordination with traffic police in managing traffic</li> <li>Workers to be trained on contingency management</li> <li>Emergency medical help should be available immediately</li> <li>The contractor should have a proper safety policy issued to workers and should strictly comply with all the safety regulations</li> <li>Workers should be provided with protective clothing and helmets</li> <li>Workers should not be allowed to work when alone</li> <li>Workers should be trained on first aid</li> <li>Emergency medical help should be available immediately</li> <li>Inform public in advance about works</li> <li>Make temporary arrangements for not disturbing water supply in case some pipes have to be displaced</li> <li>During construction, effective safety and warning measures including all the above mentioned safety precautions should be followed by the contractor and UPJN should insist on compliance by contractor</li> <li>Lighting of construction site and safety signs to be installed</li> </ul> | <p>Contractor/<br/>UPJN</p> <p>Contractor/<br/>UPJN</p> <p>Contractor/<br/>UPJN</p> <p>Contractor/<br/>UPJN</p> <p>Contractor/<br/>UPJN</p> <p>Contractor/<br/>UPJN</p> <p>Contractor/<br/>UPJN</p> |
| 1.2<br>Treatment Plant & Pumping Stations   |  |   |   |   |

|     | Works  | Risks   | Impact          | Corrective Action Plan   | Responsibility            |
|-----|--|---|-----------------|--|---------------------------|
| 2.  | ACCIDENTS RELATED TO OPERATION & MAINTENANCE |   |                 |  |                           |
| 2.1 | Sewers                                       | <ul style="list-style-type: none"> <li>• Accidents to operator/UPJN personnel</li> </ul>  | Significant     | <ul style="list-style-type: none"> <li>▪ Operators should not enter the manholes when alone</li> <li>• Operators should check for gases before entering the manholes</li> <li>• Operators should wear protective clothing, helmets and masks</li> <li>• Operators should enter the manhole by lowering themselves with a rope or a harness tied safely above</li> <li>• Manhole covers should be lifted using proper lifting keys</li> <li>• Emergency medical services should be available round the clock</li> <li>• At least one person of Management level should be on duty at all times</li> </ul> | Operator/<br>UPJN/LJS     |
| 2.2 | Treatment Plant                              | <ul style="list-style-type: none"> <li>• Breakdown of wastewater treatment units (or overall poor condition)</li> <li>• Breakdown of mechanical equipment</li> </ul>  | Not Significant | <ul style="list-style-type: none"> <li>• The treatment plant will require regular maintenance (preventive maintenance rather than reactive maintenance should be insisted upon)</li> <li>• Adequate standby for pumps and motors should be provided</li> <li>• Adequate quantities of reliable spare parts should be available on site</li> <li>• Presence of mechanics to take corrective action</li> <li>• All standby equipment should be regularly checked to ensure full working order</li> </ul>   | Operator/<br>UPJN/LJS     |
|     |  | Maintenance of sludge drying beds: <ul style="list-style-type: none"> <li>• risks of perpetuation of mosquitoes and other vectors</li> <li>• risk of bad odours</li> <li>• risk of groundwater pollution.</li> </ul>                                      | Not Significant | <ul style="list-style-type: none"> <li>• Sludge drying should be maintained properly</li> <li>• Wet sludge should be raked frequently and dry sludge should be removed and stored/disposed off</li> <li>• Ensure proper drainage</li> <li>• Operator should ensure that there is no standing water on the SDB</li> </ul>   | Contractor/<br>UPJN / LJS |
| 2.3 | Treatment Plant (continued)                  | <ul style="list-style-type: none"> <li>• Failure of biological process due to toxicity, poor maintenance, etc. (contamination of the effluent with toxic industrial effluents is the major reason for failure of biological treatment systems)</li> </ul> | Significant     | <ul style="list-style-type: none"> <li>• The secondary biological treatment should be by passed and the water should be discharged after primary treatment only</li> <li>• All relevant authorities should be informed on potential health risk to public</li> <li>• The biological process should be revived</li> </ul>   | Contractor/<br>UPJN/LJS   |

|     | <b>Works</b>     | <b>Risks</b>  | <b>Impact</b> | <b>Corrective Action Plan</b>  | <b>Responsibility</b> |
|-----|------------------|---|---------------|--|-----------------------|
| 2.4 | Pumping Stations | <ul style="list-style-type: none"> <li>Breakdown of pumping stations leading to flooding and consequent public health problems as well as general nuisance to public</li> </ul> | Significant   | <ul style="list-style-type: none"> <li>Inoculation or addition of nutrients should be carried out, if needed</li> <li>Pumping stations should be avoided as far as possible and in cases where it is not possible, their numbers should be minimised</li> <li>All pumps should be wear resistant</li> <li>Standby pumps should be provided and they should be regularly checked to ensure full working condition when needed</li> <li>Safety overflow should be provided at all pumping stations leading to a ditch or preferable a drain. These emergency overflows should be designed to ensure minimum environmental nuisance, in case of use</li> <li>Standby diesel generators should be provided to cater for a minimum of 1.5 times the average dry weather flow so as to avoid flooding</li> <li>Emergency overflows as above, should also be provided along with the DG sets as a precaution</li> </ul> | Operator/<br>UPJN/LJS |
|     |                  | <ul style="list-style-type: none"> <li>Power failure leading to flooding of sewage on streets and other problems</li> </ul>   | Significant   | <ul style="list-style-type: none"> <li>Standby diesel generators should be provided to cater for a minimum of 1.5 times the average dry weather flow so as to avoid flooding</li> <li>Emergency overflows as above, should also be provided along with the DG sets as a precaution</li> </ul>  | Operator/<br>UPJN/LJS |

## **9.10 CONCLUSIONS**

The objective of implementing the sewerage project in Lucknow is to stop the flow of sewage into the river Gomti and improve the water quality in Gomti along with the sanitary conditions of the city. A sewerage project with such an objective is associated with positive impacts. The most important of those are listed below:

- The collection and treatment of untreated wastewater before entering the river will improve water quality of Gomti.
- Those areas that are presently overflowing with sewage will improve as the sewage will be tapped and diverted through underground drainage systems.
- Risks due to water borne diseases will reduce since at many places the existing sewer lines will be rehabilitated. The contamination of the water supply line with the sewer will reduce considerably.
- Effective planning of sewage pumping stations and the treatment plant will ensure that wastewater does not percolate to sub surface layers of soil and contaminate the ground water.
- Treated effluent use in agriculture will help the farmers to enrich their soil fertility. Groundwater consumption will reduce.
- Sludge generated during the treatment process can be used as manure in nearby agricultural fields.
- Improvement in existing sewerage system will reduce the leakages and overflowing of sewage on the roads and streets.
- The construction activities will provide the local people with some employment.

### **9.10.1 Overall Impacts**

The sewerage project to be implemented in Lucknow for improvement of the river water quality, although would improve the environmental condition of the city, there will be still some areas that would require more focus and attention.

- Many of the areas will still not be connected directly to the sewers and wastewater will continue flowing through the drains.
- Wherever lateral sewer networks and house to house sewer connections are not in place, indiscriminate sewage flow will continue to occur.
- If the implemented projects are not operated and maintained effectively, the purpose of the Project will not be achieved.

### **9.10.2 Inference**

Overall it can be concluded that the priority projects that will be implemented will have a positive effect on the improvement of the quality of the river. The mitigation measures, if followed correctly will not have any adverse impacts on the environment.

**CHAPTER 10**  
**COST ESTIMATION AND IMPLEMENTATION**  
**PROGRAMME**

## **CHAPTER 10 COST ESTIMATION AND IMPLEMENTATION PROGRAMME**

### **10.1 CAPITAL COST ESTIMATION OF THE PRIORITY PROJECTS**

Cost estimates for various works are worked out on the basis of prevailing Schedule of Rates and market rates. Rates for land acquisition are obtained from Finance and Revenue Department, Govt. of Uttar Pradesh. All the figures are in Rs.

Unit prices for the estimate of capital costs are, in principle, derived from the list of prices provided by UPJN. However, prices not provided by UPJN are calculated using Lucknow rates on the basis of Delhi Schedule of Rates taking localities and deflator into account. Furthermore, prices of items such as sewer pipes, reinforcing steel bars, manhole covers and so on that are not found in UPJN Schedule or DSR are obtained by quotation. The following are cost estimation conditions.

- 1) The rates assumed for major civil works are based on UPJN Schedule of Rates for Lucknow and market rates.
  - To apply schedule of rates provided by UPJN in principle.
  - For rates of items not provided by UPJN, to use modified rates based on Delhi Schedule of Rates.
  - To use market prices for items not available in (1) and (2).
- 2) Costing of electrical equipment is based on the price list of standard suppliers.
- 3) Costing of the pump houses is based on actual quantities worked out from preliminary design.
- 4) Costing of pumps and motors is based on the price of reputed suppliers, and other facilities like screens, pipes, valves etc. are based on prevailing market rates.
- 5) Current market rates have been considered for pipes, reinforcement steel, structural steel and specialized items like geo-synthetics etc.
- 6) For STPs based on UASB technology, costs have been calculated on the basis of preliminary design of process units.
- 7) Physical contingencies: 5% of capital cost
- 8) Engineering costs (detailed design (6%) and project management (5%)): 11 % of capital cost
- 9) Project administration: 5 %, including the cost of "Environment Monitoring Plan", which is discussed in the section on Environmental Impact Assessment.

The capital costs of each component are provided in the relevant Chapters and the abstract of cost estimation is shown in Table 10.1.

### **10.2 IMPLEMENTATION PROGRAMME**

In the F/S, a detailed list of the works identified for implementation of the priority projects has been provided.

The implementation programme (Table 10.2) for the priority projects in Lucknow has been prepared considering following assumptions.

- 1) Necessary technical and financial sanctions and inter government agreement (between Japanese Government and Indian Government) shall be finalised within 2005.
- 2) Process of appointment of Project Management Consultant for the project shall start by July 2006 by NRCDC, Ministry of Environment and Forests, Government of India.
- 3) Appointment of consultants for detailed engineering and preparation of detailed project reports and tender documents for project component shall be completed within 2006.
- 4) Actual execution of various priority project components shall start from 2007.

- 5) During execution, various project components shall be executed in parallel.
- 6) UPJN, Lucknow, will acquire 100 % of the land required for construction of proposed sewage treatment plants and pumping stations before the commencement of tendering.

### **10.3 OPERATION & MAINTENANCE COST ESTIMATION**

The following is the summary of the basis of preliminary estimation of operation & maintenance (O&M) cost for the proposed sewerage system.

#### **(1) Estimation Conditions**

##### **i) Sewers and rising mains**

- Annual maintenance cost of trunk sewers: @ 0.5% of capital cost (New & Replacement)
- Annual maintenance cost of rising mains: @ 0.25% of capital cost
- Annual maintenance cost of branch sewers: @ 0.5% of capital cost
- Annual operation cost: manpower cost
- Manpower cost - As per actual salaries and proposed staff requirement <sup>\*1</sup>
- The capital cost of existing and sanctioned sewers is estimated based on unit cost of proposed facilities or Master Plan (M/P).

##### **ii) Pumping stations**

- Power cost (required power) - Rs. 3.25 per unit
- Diesel cost (for power cut) - As per market rate
- Annual power cost is estimated based on average flow
- Maintenance of civil works: @ 1.5% of capital cost of civil works
- Maintenance of mechanical & electrical (M&E) works: @ 3% of capital cost of M&E works
- Manpower cost - As per actual salaries and proposed staff requirement <sup>\*1</sup>
- The capital cost of existing and sanctioned PSs is estimated based on unit cost of proposed facilities or M/P.

##### **iii) Treatment plants**

- Power cost (required power) - Rs. 3.25 per unit
- Gas power generator installed in the STP will be used during power cut
- Chemicals – actual cost
- Maintenance of civil works @ 1.5% of capital cost of civil works
- Maintenance of M&E works @ 3% of capital cost of M&E works
- Manpower cost - As per actual salaries and proposed staff requirement <sup>\*1</sup>
- The capital cost of existing and sanctioned STPs is estimated based on unit cost of proposed facilities or M/P.

Note: <sup>\*1</sup> The manpower requirement of O&M for sewers, pumping stations and treatment plants for 2015 is proposed and its cost is estimated in the PART IV of VOLUME IV-1, Institutional Development Programme.

#### **(2) Facilities Considered for O&M Cost Estimation**

The O&M costs of all facilities including existing, sanctioned and proposed facilities are estimated.

#### **(3) Power Supply Conditions**

The O&M costs in following two cases in terms of power supply conditions are estimated.

- Operation by power from grid (24 hours a day)
- Operation by power from grid (20 hours a day) and diesel (4 hours)

(4) Estimation Results

Table 10.3 presents annual O&M costs of all major facilities including existing, sanctioned and proposed facilities for 2015 and the following table summarises annual O&M costs for 2015.

**Summary of Annual O&M Costs in 2015 (Lucknow)**  
(1,000 Rs./year)

| Facility                    | Case-1<br>Grid Power Supply | Case-2<br>Grid Power Supply<br>Supplemented by Diesel |
|-----------------------------|-----------------------------|---|
| (1) Sewers and Rising Mains | 43,499                      | 43,499  |
| (2) Pumping Stations        | 192,253                     | 281,269   |
| (3) Sewage Treatment Plants | 99,071                      | 99,071  |
| <b>Total</b>                | <b>334,823</b>              | <b>423,839</b>  |

Note: The O&M cost includes all major existing, sanctioned and proposed facilities.

**Table 10.1 Abstract of Project Cost Estimation**

|   | Sewerage District | Capital Cost (Rs.)   | Contingencies      |                    | Detailed Design    | Supervision | Project Administration |          | Total Cost (Rs.)     | Land Acquisition (Rs.) | Total Project Cost (Rs.) |
|---|-------------------|----------------------|--------------------|--------------------|--------------------|-------------|------------------------|----------|----------------------|------------------------|--------------------------|
|   |                   |                      | 5%                 | 6%                 |                    |             | 5%                     | 5%       |                      |                        |                          |
| <b>SEWERAGE SCHEMES</b>                           |                   |                      |                    |                    |                    |             |                        |          |                      |                        |                          |
| <b>Construction / Replacement of Trunk Sewer</b>  |                   |                      |                    |                    |                    |             |                        |          |                      |                        |                          |
| Trans Gomti Trunk Sewer                           | III               | 97,768,000           | 4,888,000          | 5,866,000          | 4,888,000          | 0           | 4,888,000              | 0        | 118,298,000          |                        | 118,298,000              |
| CIS Gomti Relief Trunk Sewer                      | IV                | 444,132,000          | 22,207,000         | 26,648,000         | 22,207,000         | 0           | 22,207,000             | 0        | 537,401,000          |                        | 537,401,000              |
| Sultanpur Road Trunk Sewer                        | IV                | 421,879,000          | 21,094,000         | 25,313,000         | 21,094,000         | 0           | 21,094,000             | 0        | 510,474,000          |                        | 510,474,000              |
| <b>Construction of Sewerage Pumping Station</b>   |                   |                      |                    |                    |                    |             |                        |          |                      |                        |                          |
| Rising Main of Mohan Meakin SPS                   | III               | 13,709,000           | 685,000            | 823,000            | 685,000            | 0           | 685,000                | 0        | 16,587,000           |                        | 16,587,000               |
| Martin Purwa MPS and Rising Main                  | IV                | 200,977,000          | 10,049,000         | 12,059,000         | 10,049,000         | 0           | 10,049,000             | 0        | 243,183,000          | 34,000,000             | 277,183,000              |
| TSPS at Mastemau STP                              | IV                | 372,532,000          | 18,627,000         | 22,352,000         | 18,627,000         | 0           | 18,627,000             | 0        | 450,765,000          |                        | 450,765,000              |
| <b>Construction of Sewerage Treatment Plant</b>   |                   |                      |                    |                    |                    |             |                        |          |                      |                        |                          |
| Mastemau STP (include irrigation channel)         | IV                | 453,075,000          | 22,654,000         | 27,185,000         | 22,654,000         | 0           | 22,654,000             | 0        | 548,222,000          | 173,320,000            | 721,542,000              |
| <b>Rehabilitation of CIS Gomti Trunk Sewer</b>    |                   |                      |                    |                    |                    |             |                        |          |                      |                        |                          |
| Desilting, Detailed Investigation                 | IV                | 74,760,000           | 3,738,000          | 4,486,000          | 3,738,000          | 0           | 3,738,000              | 0        | 90,460,000           |                        | 90,460,000               |
| Rehabilitation                                    | IV                | 346,949,000          | 17,347,000         | 20,817,000         | 17,347,000         | 0           | 17,347,000             | 0        | 419,807,000          |                        | 419,807,000              |
| <b>Rehabilitation of Existing Pumping Station</b> |                   |                      |                    |                    |                    |             |                        |          |                      |                        |                          |
| Trans Gomti SPS                                   | III               | 70,374,000           | 3,519,000          | 4,222,000          | 3,519,000          | 0           | 3,519,000              | 0        | 85,153,000           |                        | 85,153,000               |
| CIS Gomti SPS                                     | IV                | 71,664,000           | 3,583,000          | 4,300,000          | 3,583,000          | 0           | 3,583,000              | 0        | 86,713,000           |                        | 86,713,000               |
| <b>Total</b>                                      |                   | <b>2,567,819,000</b> | <b>128,391,000</b> | <b>154,071,000</b> | <b>128,391,000</b> | <b>0</b>    | <b>128,391,000</b>     | <b>0</b> | <b>3,107,063,000</b> | <b>207,320,000</b>     | <b>3,314,383,000</b>     |

**Table 10.2 Implementation Schedule of Priority Projects (Lucknow)**

|  | (Unit: Rs.)   |                      |                    |             |             |             |             |             |             |  |
|--|---------------|----------------------|--------------------|-------------|-------------|-------------|-------------|-------------|-------------|--|
|  | Capital Cost  | Detailed Design Cost | Total Project Cost | 2007        | 2008        | 2009        | 2010        | 2011        | 2012        |  |
| Capital and Detailed Design Cost Schedule          |               |                      |                    |             |             |             |             |             |             |  |
| <b>Construction of Trunk Sewer</b>                 |               |                      |                    |             |             |             |             |             |             |  |
| Trans Gomti Relief Sewer                           | 97,768,000    | 5,866,000            | 118,298,000        | 5,866,000   | 19,554,000  | 19,554,000  | 19,554,000  | 29,330,000  | 9,776,000   |  |
| CIS Gomti Relief Trunk Sewer                       | 444,132,000   | 26,648,000           | 537,401,000        | 26,648,000  | 88,826,000  | 88,826,000  | 88,826,000  | 133,240,000 | 44,414,000  |  |
| Sultanpur Road Trunk Sewer                         | 421,879,000   | 25,313,000           | 510,474,000        | 25,313,000  | 84,376,000  | 84,376,000  | 84,376,000  | 126,564,000 | 42,187,000  |  |
| <b>Construction of Sewerage Pumping Station</b>    |               |                      |                    |             |             |             |             |             |             |  |
| Rising Main of Mohan Meakin SPS                    | 13,709,000    | 823,000              | 16,587,000         |             |             |             | 823,000     | 6,855,000   | 6,854,000   |  |
| Martin Purwa MPS and Rising Main                   | 200,977,000   | 12,059,000           | 277,183,000        | 12,059,000  | 40,195,000  | 40,195,000  | 40,195,000  | 60,293,000  | 20,099,000  |  |
| TSPS at Mastemau STP                               | 372,532,000   | 22,352,000           | 450,765,000        | 22,352,000  | 74,506,000  | 74,506,000  | 74,506,000  | 111,760,000 | 37,254,000  |  |
| <b>Construction of Sewerage Treatment Plant</b>    |               |                      |                    |             |             |             |             |             |             |  |
| Mastemau STP                                       | 453,075,000   | 27,185,000           | 721,542,000        | 27,185,000  | 90,615,000  | 90,615,000  | 90,615,000  | 135,923,000 | 45,307,000  |  |
| <b>Rehabilitation of CIS Gomti Trunk Sewer</b>     |               |                      |                    |             |             |             |             |             |             |  |
| Detailed Investigation                             | 74,760,000    | 4,486,000            | 90,460,000         | 4,486,000   | 74,760,000  |             |             |             |             |  |
| Sewer desilting, flow diversion and rehabilitation | 346,949,000   | 20,817,000           | 419,807,000        |             |             | 20,817,000  | 115,650,000 | 115,650,000 |             |  |
| <b>Rehabilitation of Existing Pumping Station</b>  |               |                      |                    |             |             |             |             |             |             |  |
| Trans Gomti SPS                                    | 70,374,000    | 4,222,000            | 85,153,000         | 4,222,000   | 35,187,000  | 35,187,000  |             |             |             |  |
| CIS Gomti SPS                                      | 71,664,000    | 4,300,000            | 86,713,000         | 4,300,000   | 35,832,000  | 35,832,000  |             |             |             |  |
| <b>Total</b>                                       | 2,567,819,000 | 154,071,000          | 3,314,383,000      | 132,431,000 | 543,851,000 | 489,908,000 | 514,545,000 | 719,615,000 | 321,540,000 |  |

| Items                | (Unit: million Rs.) |        |        |        |        |        |        |      |      |      |
|----------------------|---------------------|--------|--------|--------|--------|--------|--------|------|------|------|
|                      | Total Project Cost  | 2007   | 2008   | 2008   | 2008   | 2009   | 2009   | 2009 | 2010 | 2010 |
| Capital Cost         | 2,567.82            | 0.00   | 543.85 | 469.09 | 513.72 | 719.62 | 321.54 |      |      |      |
| Detailed Design Cost | 154.07              | 132.43 | 0.00   | 20.82  | 0.82   | 0.00   | 0.00   |      |      |      |
| Contingencies        | 128.39              | 0.00   | 27.19  | 23.45  | 25.69  | 35.98  | 16.08  |      |      |      |
| Supervision          | 128.39              | 0.00   | 27.19  | 23.45  | 25.69  | 35.98  | 16.08  |      |      |      |
| Project-Admin        | 128.39              | 0.00   | 27.19  | 23.45  | 25.69  | 35.98  | 16.08  |      |      |      |
| Total Cost           | 3,107.06            | 132.43 | 625.42 | 560.26 | 591.61 | 827.56 | 369.78 |      |      |      |
| Land Acquisition     | 207.32              | 207.32 | 0.00   | 0.00   | 0.00   | 0.00   | 0.00   |      |      |      |
| Total                | 3,314.38            | 339.75 | 625.42 | 560.26 | 591.61 | 827.56 | 369.78 |      |      |      |

■ Detailed Design  
■ Construction Cost



## *Appendix A*

## **Appendix A 3.1**

### **Technical Evaluation for Selection of Pumps**

Sewage pumps are used to lift liquid wastes from one level of the collection system to another (as in the case of intermediate pumping stations) or to the treatment plant for treatment (as in the case of main pumping stations).

At larger pumping installations, a large quantity of materials, such as rags, jute bags, fibre and plastic pouches is found in sewage. Proper efficient screening shall be done before the sewage enters into the wet well of the pumping station. A sewage pump shall be reliable, unchokable and accessible for quick maintenance, be robust and wear resisting. The type of pump to be installed at each pumping station shall be judged on its technical merits in relation to the rate of pumping, total head, physical composition of the sewage, septicity and requirement of preliminary treatment before pumping.

Pumps may be classified on the basis of the purpose or the application they serve, the material of construction, the liquids they handle, and orientation in the space. A more basic system of classification is to categorize the pumps on the principle by which the energy is supplied to the pump. Under this system, all pumps may be divided into two major categories.

Dynamic, in which energy is continuously added to increase the fluid velocities within the machine to values in excess of those occurring at the discharge such that subsequent velocity reduction within or beyond the pump produces a pressure increase.

Displacement, in which energy is periodically added by application of force to one or more movable boundaries of any desired number of enclosed, fluid containing volumes, resulting in a direct increase in pressure upto the value required to move the fluid through valves or ports into the discharge line.

Dynamic pumps may be further sub-divided into several categories of centrifugal pumps and other special-effect pumps, like jet pumps and hydraulic ram pumps etc. Displacement pumps are essentially divided into reciprocating pumps and rotary pumps.


Reciprocating pumps are suitable for applications where the required capacity is expected to be virtually constant over a wide range of system head variations. Another factor that has to be taken into consideration is that the output from the reciprocating pumps is pulsating. Where this is objectionable, rotary pumps are preferred over the reciprocating pumps. However, the application of rotary pumps is limited to low to medium pressure ranges.

In India, for sewage pumping application centrifugal pumps are in use. A centrifugal pump consists of a set of rotating vanes, enclosed within a housing or casing and used to impart energy to a fluid through centrifugal force. Thus, stripped of all the refinements, a centrifugal pump has two main parts.

- A rotating element, including an impeller and a shaft
- A stationary element made up of a casing, stuffing box, and bearings.

In this type of pump, the liquid is forced by atmospheric pressure or other pressure, into a set of rotating vanes. These vanes constitute an impeller, which discharges the liquid at its periphery at a higher velocity. This velocity is converted into pressure energy by means of a volute or by a set of stationary diffusion vanes surrounding the impeller periphery. Pumps with volute casings are called volute pumps, while those with diffusion vanes are called diffuser pumps.

Depending on the location of motor with respect to the pump, centrifugal pumps can be divided into two types, namely the conventional centrifugal pumps and the submersible centrifugal pumps. The broad classification of the commonly used pumps is shown in the following figure 3.1.



**Figure 3.1: Pump Classification**

### 3.1.1 Conventional Centrifugal Pumps

A conventional centrifugal pump is more specifically described as an end-suction, volute-type, with an overhung impeller of either the non-clog or the radial flow type or the mixed flow type pump.

The installation of conventional centrifugal pump requires considerable length of drive shafting. The addition of this shafting, of the many line bearings, and of an external lubrication system represents a major portion of the total installed cost. Furthermore, power losses increase rapidly due to elongation of shafts.

Conventional centrifugal pumps operate within a dry well adjacent to the wet well. The pumps are connected with the wet well through a suction line. One of the major drawbacks with these pumps is that they generally do not work with any suction lift. Instead they need a suction head or minimum submergence for trouble free pumping. Therefore, it is always advisable to install these pumps at such a level that the impeller or the volute of the pump is positioned below the low water level of the wet well to ensure a positive suction or prime.

### **3.1.2 Submersible Centrifugal Pumps**

Submersible centrifugal pumps are based on modern developments and have integral motors with special seals suitable for operation below liquid level. The pump, along with the motor, is submerged into the wet well and does not need a dry well for installation. The pumps are fitted with semi-open type of impellers cutting and tearing contra-block system, which efficiently handles jute bag pieces, long fibres, plastic bags & pouches, cigarette butts, solid admixes, etc. which are generally present in sewage in India.

Submersible centrifugal pumps eliminate the need for extended shafting, shaft couplings, a stuffing box, a sub-surface motor stand, and an expensive dry well.

Submersible centrifugal pumps are available with closed coupled submersible motors. The pumps are supported by guide rails, which make it possible to lower and lift the pumps by means of a chain hoist. During this operation, the discharge is connected and disconnected without dewatering the wet well.

Motors for this type of pump are hermetically sealed, employing a double mechanically sealed oil chamber with moisture sensing probe to detect any influx or conductive liquid past the outer seal.

Due to their inherent advantages over conventional centrifugal pumps, submersible centrifugal pumps have been popular all over the world, for pumping municipal wastewater. Over the past ten years, the application of submersible centrifugal pumps has become very popular in India, for pumping municipal wastewater and is replacing conventional centrifugal pumps.

Pump




Figure 3.2 Schematic of Conventional Centrifugal Pump




Figure 3.3 Schematic of Submersible Centrifugal Pump

A technical evaluation has been carried out for selection of pumps. For this purpose, conventional centrifugal pumps and submersible centrifugal pumps have been compared.

### 3.1.3 General Comparison of Conventional Centrifugal Pumps and Submersible Centrifugal Pumps

The conventional centrifugal pumps and submersible centrifugal pumps have their own advantages and disadvantages. The merits and demerits of both types can be summarized as given the following table:

**Comparison between Conventional Centrifugal pump vs. Submersible Centrifugal pumps**

| Sr. | Parameter                          | Conventional Centrifugal Pumps   | Submersible Centrifugal Pumps   |
|-----|------------------------------------|--|---|
| 1   | Civil structure to house the pumps | Superstructure is needed for protection of motors and therefore these pumps require a dry well in conjunction with a wet well (sump). Sectional view of a pumping station with conventional centrifugal pumps has been given in Figure 3.2 | Both pump and motor are installed in the wet well. This saves substantial space and brings about significant saving in the civil engineering costs. Sectional view of a pumping station with submersible centrifugal pumps has been given in Figure 3.3 |
| 2   | Land requirements                  | Require more space   | Require very little space   |
| 3.  | Piping                             | Extended   | Shorter   |
| 4   | Column pipes                       | Required   | Not required  |
| 5.  | Suction pipes                      | Required   | Not required  |
| 6.  | Discharge pipes                    | Required   | Required  |
| 7.  | Delivery piping and common header  | Require column assembly  | The discharge pipes of all pumps can be terminated at the common header, which is installed in a shallow valve chamber just adjacent to the collection sump   |
| 8.  | Solid handling capacity            | Lower (80 mm)  | Higher (100 mm and above)   |
| 9.  | Weight of pumps                    | Heavy  | Relatively much lighter   |
| 10. | Lubrication                        | Special attention is required for lubricating lines of intermediate bearing support and further design is required to check intermediate floor for bearing supports, etc.  | No such attention required. Further, the supports required for the intermediate bush bearings is also not applicable  |
| 11  | Vibrations and noise               | Large column lengths always cause vibrations and motor mounted on top causes noise pollution. The vibrations are also due to their heavy weight  | Submersible centrifugal pump being a mechanically robust mono-block unit where impeller is mounted on the motor shaft which is supported by two sturdy bearing, ensures a mechanically  |

| Sr. | Parameter                             | Conventional Centrifugal Pumps  | Submersible Centrifugal Pumps  |
|-----|---------------------------------------|---|--|
|     |                                       |   | robust design which in turn results in vibration free performance of the pump and further whatever vibrations that still remain, are damped because the pump is submerged in sewage  |
| 12. | Starts and stops                      | Capable of less stops and starts per hour (4 to 5) and hence requires more hydraulic retention time (5 minutes at peak flow) for wet well   | Capable of relatively more starts and stops per hour (8 to 10). This results in reducing the hydraulic retention time (3.75 minutes at peak flow) of the sump, ensuring the compactness of wet well.   |
| 13. | Impeller                              | Closed impeller having both front and back shrouds. This type of impeller is not suitable for Indian sewage, which has solids like plastic bags & pouches and jute fibre. Choking and clogging of impeller is quite frequent                            | Fitted with specially designed and specially shaped single/double vane impeller of open type with contra-block cutting system. These two combined features make this pump truly non-clogging and therefore substantially more reliable under Indian conditions |
| 14. | Motor                                 | Squirrel cage induction motor is the prime mover, which is coupled with the pump by means of a rigid or flexible coupling   | Squirrel cage motor is an integral part of the pump and fitted with an aluminium die cast rotor. This totally enclosed motor is equipped with sealing features to permit operation while submerged in a specified medium at a specified depth.                 |
| 15. | Electrical cabling and control panels | Since conventional centrifugal pumps offer substantially reduced kilowatt consumption, the ampere consumption also reduces, resulting in reduction in size of motor cabling, length of cabling, reduction in capacity of transformer and generator set. | Cabling and control cabling is extended.   |
| 16. | Installation and removal              | Installation and removal is cumbersome since the assembly is on a foundation and each pump has to be specially removed and then lifted  | The pump installation and removal are automatic, without having to enter into the sewage pit. Guide rail system and guide pipe are provided to facilitate the automatic coupling of the pump   |

#### **3.1.4 Operation and Maintenance Aspects**

Operation and maintenance is an important aspect to be considered while selecting the type of pumps. It is therefore, necessary to consider ease of installation and removal, materials of construction, safety features and frequency of lubrication etc. as important parameters.

In case of conventional centrifugal pumps, frequent clogging of impeller are more due to its closed type design and lower solid handling capacity. Also, due to presence of line shaft bearings, there is a need of frequent lubrication. There is more wear and tear of glands and other parts due to extended shafts. It is not easy to install and remove these pumps because of their heavy weight and manual fixing onto the foundation.

In case of submersible centrifugal pumps, due to their semi-open type impeller, clogging is less frequent. Furthermore, the special contra-block cutting and tearing system provides on the suction side of the pump facilitates disposing off soft materials like plastic pouches, small jute pieces, which is very typical of sewage in India. Pump bearings are of anti-friction type and are maintenance free and are grease lubricated for long life. The bearings are capable of taking normal thrust loads due to unbalanced hydraulic loads on the impellers.

The maintenance of submersible centrifugal pumps is comparatively less because there are no line shaft bearings, which need reliable lubrication and periodic replacement. Only mechanical seal of this type of pump may need replacement after certain working hours, thereby reducing the maintenance cost substantially.

Selecting a pump with less moving parts and low RPM reduces wear and tear of parts and ensures trouble and maintenance free operations. Submersible pumps offer state of the art technology in pump protection ensuring trouble free operation in toughest applications.

The salient operation and maintenance features of conventional centrifugal pumps and submersible centrifugal pumps are given in the following table.

**Salient Operation and Maintenance Aspects of Conventional Centrifugal Pumps and Submersible Centrifugal Pumps**

| Sr. | Conventional Centrifugal pumps   | Submersible Centrifugal Pumps   |
|-----|--|---|
| 1.  | -  | Thermistor sensors for motor protection                                   |
| 2.  | -  | Bearing monitors for trouble free and smooth operation                    |
| 3.  | -  | Mechanical seal health monitors for ensuring an enhanced pump life        |
| 4.  | Periodic greasing required   | Lubricated for life bearings  |
| 5.  | Absence of warning system results in abrupt failure giving no time for planning not allows selective maintenance | Early warning system allows ample planning time and selective maintenance |
| 6.  | More moving parts  | Less moving parts   |
| 7.  | Design incorporating multiple shafts, resulting in frequent alignment problems.                                  | Compact design on single shaft.   |

With reference to the technical comparison between conventional centrifugal pumps and submersible centrifugal pumps it can be concluded that the submersible centrifugal pumps is based on modern developments in the technology of centrifugal pumps for sewage pumping applications. Development in impeller design like semi-open type with contra-block system, steel material of construction, better solid handling capacity, better design due to direct mounting of motor shaft on impeller, better design

of motor stator rotor (aluminium die cast) makes the submersible centrifugal pumps technically more superior. The facility of guides rail system and automatic coupling facilitate better operation and maintenance. Also the submersible centrifugal pumps offering better safety and construction features ensure reliability and trouble free operation. However, availability of submersible pumps is limited to a specified capacity (usually a maximum of 300 HP) in India.

Based on the above technical evaluation, considering advantages, disadvantages, and also the past experiences of UPJN officials on existing installations, it was decided and recommended that for sewage pumping stations in Lucknow, submersible pumps shall be opted only upto 150 HP capacity and horizontal centrifugal pumps shall be opted for higher (>150 HP) capacities.

## **Appendix A 4.1**

### **4.1 Laying of Sewers Using Trenchless Technology**

#### **4.1.1 Trenchless Options for Trunk Sewer**

The selection of a trenchless option for the construction of a part of the proposed relief trunk sewer will avoid much of the disruption associated with traditional open cut construction. Trenchless construction involves access to the construction works at discrete points along the pipeline route rather than the disruption of a continuous corridor along the route with the requirement for temporary reinstatement and pavement patching. Site management of trenchless process involves the delivery of essential materials to these discrete intervention points in a timely fashion as opposed to the stringing out along the route of pipe and pipe bedding materials. Similarly, the removal of spoil material can be managed in a timely fashion with the attendant avoidance of disruption. However, it should be mentioned here that site management is the key to successful trenchless construction; a poorly organized site and bad practice can be immensely disruptive and damaging to the public interest causing damage to the perception of the implementing authority in a magnitude not dissimilar to open cut construction.

The selection of access points through specially constructed access shafts is important to minimize public disturbance, these access points can be 100-250 mm apart and the adjacent working areas if well managed can be minimized to the order of 30-70 square meters. Damage to adjacent buried infrastructure such as other utility services is always a risk. Careful survey and attention to local information can minimize this risk. Cooperation with other utility providers and the traffic authorities is an important contribution to successful installation. Careful selection of appropriate technology and materials will minimize future maintenance requirements. Trenchless methods can be expected to deliver better built quality for the most part, free from settlement and reinstatement problems.

There are a number of practical problems in the delivery of the trenchless option. Amongst the most important of these is the requirement for specialist product and equipment, much of which is not currently, available in India. Accordingly planning and selection place special burdens on the client, consultant and contractor. Sufficient time for detailed planning, discussion and programming is essential, detailed method statements and specifications are useful to the achievement of an understanding of all the key issues between the parties. This section of the report seeks to set out key issues for consideration to inform the selection process.

The proposed relief trunk sewer involves both trenched and trenchless components; the section identified for trenchless construction, presented in Table 4.9, is ideally suited being a deep sewer 3-10m to invert, located under a busy road where trenched construction would be enormously disruptive. The trenched component is also deep where connecting to the trenchless section; special measures should be taken here and for most of the trenched reaches to use modern practice of closed sheeting or trench boxes to minimize trench width and ensure worker safety.

Open cut construction can be accomplished with reduced disruption using a trench box or drag box method so that regardless of the depth to formation, that is, below the pipe bedding the trench can be excavated safely without battering back the trench sides, to a minimum width. Close sheeting can also be used to control trench width and maintain safe working conditions but is more time consuming to install and requires closer supervision; the trench sheets are liable to damage and may be regarded as project consumables whereas trench or drag boxes can be regarded as capital items and maintained as such. Careful use of a trench box not only restricts the width of the trench and hence the work site but also the length of pipeline open at any one time to about 6-8 metres. Temporary reinstatement of the pavement after backfill and consolidation can minimize the length of road closure necessary.

With good site management the activity zone of the narrow trench construction outlined above can approximate to the scale of a pipe-jacking site, though the site footprint is larger and cannot be selected at optimum points along the pipeline for minimum disruption. Traditional trenching practice usually involves the temporary storage of excavated material and pipe bedding on site, although this inevitably makes the site area larger and more disruptive. Coordinated truck movement to ship in bedding and product pipe can minimize the area required.

#### **4.1.2 The Microtunnelling Option**

There is a wide range of pipe jacking and microtunnelling processes and system providers from Japan, Europe and the US are working internationally. Pipe jacking, pipe ramming and microtunnelling methods have been used in India since about 1997 in Mumbai. Generally, in India the companies working in this sector have developed their own machinery and import specialist items on a project by project basis.

Pipe jacking is defined in the ISTT guidelines as a system for directly installing pipes behind a shield machine by hydraulic jacking from a drive shaft such that the pipes form a continuous string in the ground'. Typically pipe jacking can achieve tolerances of 75mm on line and 50mm on level. Microtunnelling is defined by ISTT as steerable remote control pipe jacking to install pipes of internal diameter less than that permissible for man entry. Microtunnelling was developed from pipe jacking by the Japanese in the early 1980's by the miniaturization of tunnel boring machines (TBMs) and the development of earth pressure balance and slurry microtunnelling machines. Introduced into Germany in the mid 80's the technology was extended by the development of auger machines suited to the sand, silt and clay soils in the Hamburg region. Microtunnelling is now used worldwide to construct 10-20% of new sewer lines. Typically microtunnelling can achieve tolerances of +/- 25 - 50mm on line and level depending on the procedure use.

For a detailed consideration of microtunnelling and selection of the most appropriate process the following basic factors should be reviewed:

- The diameter range of pipe, which can be installed - most machines can be used for a small range (2-3 times the standard size) by changing the cutting head or shield body.
- The type of pipe, which can be installed - pipe compressive strength and surface friction are important factors in determining the length of drive.
- The type of ground, which can be traversed, and the maximum hydrostatic head to be withstood - this will determine the cutting head, the spoil removal system and the need to counterbalance ground water.
- Machine accessibility - in the event of mechanical failure or unforeseen conditions or obstacles.
- The location of access points (drive and receiving shafts) - with respect to achievable drive length, drive shafts are generally larger and more costly than receiving shafts and consideration should be given to driving in both directions.
- The accuracy of alignment achievable - gravity sewers require a very accurate grade whereas pressure mains and casings can tolerate lesser accuracy.
- Sizes of shafts and access thereto - this will depend on the type of microtunnelling machine, hydraulic rams (single or double acting) and pipe length, access is important to operating efficiency and time is critical to avoid the build up of pipe friction.

- Lack of disruption and associated cost benefit - microtunnelling is a capital intensive process and often more costly than open cut pipeline construction at shallow laying depth. Evident reduction of disruption can be expressed as an engineering or social cost saving to justify the use of the procedure.
- Traffic patterns may influence the selection and number of access points, storage areas and support locations are also affected.

In respect of these basic criteria, microtunnelling appears to be appropriate technology for relief trunk sewer. With the wide range of sizes of pipe (1200mm –2400mm) required by flow capacity analysis; a decision shall be taken to rationalize construction to just two sizes to improve the viability of the microtunnelling option so that there is a minimum of disruption to the construction schedule. However, in this report the actual diameter is considered for further detailing. With use of high strength pipes and advanced microtunnelling technology access shafts can be at 200-300 meter centers; such drive lengths are readily achievable with good quality concrete. The route, for the most part could accommodate excavation to access the machine, in the event that this is required. However, there are some sections along the route, for example adjacent to the rail under bridges and in the vicinity of the nala crossing where construction of access shafts should be avoided to the extent possible to minimize disruption and technical problems. Accuracy of +/- 25-50mm is achievable with a variety of machines in drives of length up to 300m consistent with the grade tolerances for the gravity sewer. There are limitations on shaft size evident along the identified route; in the vicinity of the rail under bridge there is barely sufficient space to construct a reasonable sized shaft without significant disruption and concern must be raised about the extent of the footings and foundations for these engineering structures. The route is heavily trafficked and runs through both densely populated areas - the disruption of open trenching would generate a major public nuisance and substantial social costs.

#### **4.1.3 Installation Options**

Microtunnelling machines are generally classified in two groups according to the method of spoil removal

- Auger systems where spoil is transferred from the cutting head to the drive shaft by a system of auger flights located in the casing or product pipeline. A full face cutting head may be used to apply an earth pressure balance to support for the cutting face. Ground water can be controlled to a limited extent by earth pressure balanced by the cutting head; this may be supplemented with compressed air. Auger machines are ideally suited to working in cohesive silts and clays and can accommodate ground water pressure of up to 3m. Auger machines are limited by the torque they can apply, drives of about 130m are possible. The maximum size for auger machines is about 1 m diameter.
- Slurry systems where the spoil is mixed with water at the cutting head for transportation in a discharge pipe back to the surface. Settlement tanks and other separation devices allow the water to be recycled and solid waste is transported away. Use of a slurry system can balance high ground water head up to 30m. Slurry systems are suited to working in saturated sand and gravel strata.
- Cutting heads have been designed for working in rock. Such heads may incorporate a modified cone crusher to break up rocks and boulders up to 30% of the face size. The jacking arrangement will consist of a sturdy frame rigid enough to apply the required force through an arrangement of 2-6 hydraulic cylinders each capable of about 100-300 tons force.

Further classification arises from the operating procedures microtunnelling may involve

- A single stage process where the machine is propelled through the ground by jacking product pipes immediately behind the machine.

- A two stage process where special protective pipes are used to drive the machine the full length to the reception pit; product pipes are then jacked through the completed bore displacing the protective pipes which are recovered for re-use. This procedure reduces substantially the load on the product pipe. The annular space between the product pipe and the bore must be grouted.
- A pilot bore where an initial bore of small diameter is reamed out so that the product pipes can be inserted.

The system selected should fulfill the following requirements:

- The shield must be cylindrical to a fine tolerance - eccentricity or damage from prior use will affect steering capability.
- The jacking frame must be sufficiently robust to withstand the weight of the shield and pipes and not deflect during jacking.
- The cutter head and shield must be suitable for the prevailing ground conditions and ground water head.
- If needed face support should be maintained by earth or slurry pressure.
- It should be capable of dealing with rock or rubble included in the spoil up to 30% of the casing or product pipe diameter.
- The cutter head should be steerable with automatic control capable of programming to the appropriate alignment.
- The hydraulic jacks should apply the required jacking force slowly and evenly through a thrust ring, relief valves should prevent overload.
- It should include a data-logging device to display key parameters such as jacking force, jacking speed, earth or slurry pressure, machine deviation, steering roll and gradient in real time.
- It should be capable of installing a 200-300m pipeline to within +/-50mm of level.
- Addition of product pipe and adjustment of hose and cable lengths in the drive shaft must be readily accomplished.

Subject to confirmation that the soil type is essentially silt and sand, essentially free from larger rocky inclusions and that problems with ground water can be anticipated at the burial depths required, it seems likely that slurry shield type machine may be required. Even though serious ground water is less likely at the shallower depths where a 1200mm pipe (rising main) will be installed, the torque requirements for long length jacking will probably exceed machine capability for the auger type. Access shafts could be either rectangular or circular caisson type; the caisson type is probably well suited to the soil type but rectangular may minimize the width of carriageway required for the larger pipes on this scheme. Accordingly the potential for disruption along the proposed route is minimized.

#### **4.1.4 Product Pipe Options**

Product pipes are subjected to high compressive loads during jacking and microtunnelling. Pipe wall thickness and compressive strength determine drive length; drive length capability, normally 130-200m may be extended by use of lubrication and intermediate jacking stations. Long distance jacking methods combining highest grade pipe and highly developed methodologies can achieve drives in

excess of 400m. Japanese researchers are reported to be aiming for 1000m. However, for the present purposes consideration is given to methods comfortably associated with drives up to 130m. Depending on the selection and size of the shaft and installation equipment, short pipes (1.2 - 2.0m) may be required.

a) Concrete pipes

The vast majority of jacking pipes in use worldwide are manufactured from concrete to accepted standards such as BS EN 5911 pt120, DIN4035, JSWAS A2 or similar. The high compressive strength (70-90N/mm<sup>2</sup>) and the smooth low friction exterior surface required support centrifugal spinning as the preferred method of manufacture. This method has lost some popularity in recent years as high speed vibrated methods have been widely adopted for the production of inexpensive concrete pipe for laying in trench. However in the main jacking pipe markets, Japan and Germany spun pipe production remains popular. Where jacking pipe is made by contractors, wet cast molded methods can provide smooth pipe at low volume consistent with construction rate. Jacking pipe are furnished with butt ended joints with coupling rings of steel, stainless steel or GRP, of external diameter slightly smaller than the pipe outside diameter; the joint rings may be loose or bonded into molded rebated joint surfaces. Butt joints provide the maximum area for load transfer. Elastomeric seals are used between the joint ring and the pipe spigot. Modern jacking pipe joints usually employ seals that combine compression seal and lip seal characteristics. Jacking pipes are supplied with load transfer rings usually of particle board, plywood or plastic bonded onto the pipe at the socket end; squareness of ends is critical, a key element of the pipe specification. Vertical cast pipe are demoulded green and air cured, they may be subject to some distortion of ends due to differential drying shrinkage. Concrete pipes are vulnerable to acid attack, which can be a problem where septicity is permitted to develop in the sewer; high ambient temperature, long retention times and shallow grade can be contributory factors. Concrete pipe may be protected by addition of PVC or HDPE lining.

b) Clay pipes

Stoneware pipes are manufactured in diameters up to DN 1200. Recognised standards include DIN 1230 or BS EN 295 pt 7. Stoneware pipes possess particularly high compressive strength. They are manufactured in the UK, Germany and the USA. Stoneware pipes are resistant to all substances found in sewage or soil and have excellent wear resistance. The joint profiles and butt ends are machined to a high standard. The majority of jacking pipes in the range DN200-600 are of vitrified clay. Hybrid clay lined concrete pipes are made in Japan and Germany. Clay pipes are not available for the 2400 mm sizes required at Lucknow.

c) GRP Pipes

GRP pipes such as Hobas are also used for pipe jacking, the sandwich construction of their composite wall providing sufficient wall thickness for a modest end load capability. They are also chemically resistant. Hobas pipe is the dominant pipe used for microtunnelling in the USA.

d) Polymer Concrete Pipes

Polymer concrete pipes were developed in Germany in the early 1990's, they combine the strength and wall thickness of concrete (90 N/mm<sup>2</sup>) with the chemical resistance of clay or GRP. A manufacturing unit has recently been established in Malaysia.

e) Steel pipes

Steel Pipes have outstanding strength and toughness; this coupled with their weldability makes them attractive for use as casings or carrier pipes installed by pipe jacking or microtunnelling. However, they have low corrosion resistance and for this reason they have never been widely used in the sewage sector though they are commonly used for water and gas mains often with polymer coatings and

cathodic protection. Steel pipes are often used where a dynamic process such as pipe ramming is used for construction and where a two stage process like auger boring may be used to install other product pipes such as concrete inside the steel carrier pipe.

Centrifugally spun concrete pipe have been made in India for many years, it is expected that manufacture of such pipe designed according to overseas standards can be reinstated to meet the demands. Wet cast concrete pipe have also been made by pipe jacking contractors.

The process of pipe jacking or microtunnelling subjects the external surface of the pipe to significant abrasion as the pipe is pushed through the ground, the extent of abrasion

Depending on the strata, the length of drive and the lubrication. Even in strata free from rock, the paint or other coating on the tunneling machine may be damaged or removed altogether. Very high surface stress is induced in pipes during jacking, particularly when steering or correcting deviations from line or level, pipes are subject to a severe combination of compressive and transverse loads during installation, such stress may also damage the coatings applied to GRP or steel pipes and prejudice their durability.

Concrete, clay or polymer concrete pipe are preferred for medium and long distance jacking. The jacking pipe share of the overall pipe market is relatively small, generally less than 10%. Accordingly jacking pipes are specialty items with higher cost, due to low volume production and the provision of steel or plastic collars. However, the basic pipe cost is a small fraction of the pipeline construction cost, typically 15-20%. Pipe quality should not be compromised, the pipe is a vital component in the performance of the installation and in the subsequent utility and longevity of the installed asset. The pipe, once installed by pipe jacking or microtunnelling will be competently jointed and free from the soil settlement induced in trench construction; it can be expected to perform satisfactorily throughout its working life.

For the relief trunk sewer concrete pipe are recommended. They offer outstanding quality as jacking pipes from the installation perspective. Microtunnelling contractors worked in Mumbai have facilities to make their own pipes by wet casting.

The need for protection from H<sub>2</sub>S corrosion is debatable. Instances of failure due to corrosion may vary from place to place and good operational practice may be sufficient to minimize acid attack.

#### **4.1.5 Working Area Requirements**

A limited space is required to stage a microtunnelling project, typically 350-500 m<sup>2</sup> – the largest space required will be at the drive shaft, receiving shafts are generally smaller. At the drive shaft additional space will be required for the processing and disposal of spoil; this may involve settlement tanks for slurry machine, a crane, a control cabin, pipe storage, vehicle access and support facilities like power generation and lubricant processing. A crane or gantry is used for lowering the machinery and product pipe into the drive shaft and for spoil removal. Overhead cables, buildings or trees should not restrict movement of the crane. The size of drive pit/shaft will depend on the size of the machinery employed, the length of pipe and the method of working. For a 1200 mm pipe a pit of 4 m x 7 m or shaft of diameter 4 m should be adequate, the receiving shaft used to recover the machine may be smaller say 4 m x 6 m. The DNH 2400 pipe may require a wider shaft 6 m x 8 m or 7 m diameter.

The drive/receiving pit may be constructed by sheet piling, by use of concrete caisson unit, by construction of a diaphragm walled shaft or a shotcreted shaft. The pit may be converted on completion to function as a manhole. In Europe, the use of pre-case caissons has become popular, standardizing shaft dimensions and influencing pipe and manhole design. Fabrication of similar pre-cast products in India should present no problem. Careful positioning and installation of the caisson shafts is required. The caisson becomes in effect the foundation stone of the new pipeline. Caisson units are designed with water proof seals and are bolted together in position and sunk as the spoil is

excavated. It is important to ensure that the caisson is truly vertical during the early stages of installation. The caisson must be designed to accommodate the thrust reaction force. The floor of the shaft must be sealed to the caisson and the structure prevented from floating or otherwise moving due to changes in ground water level.

For longer distance jacking a substantial thrust wall or thrust block will be necessary. Consideration must be given to lubricating pipes through injection point along the length of the drive by injection through the pipe wall. Intermediate jacking points enabling the full length of the drive to be move forward in sections will also be helpful to lengthen the drive, special interjack pipes with modified steel collars will be required for these stations. Limited numbers of drive pits/shaft, offsite pipe storage and coordinated spoil removal will significantly limit the congestion caused by site operation.

#### **4.1.6 Ground Water**

The ground water table in the proposed stretches ranges from 2.5 m to 10 m, thus ground water control will certainly be necessary and a gland wall seal or entry and exist lock arrangements will be needed when launching the machine. Furthermore, the probable ground water table will certainly be in the vicinity of the nala crossing, there will be ground water to deal with. Various dewatering options are available – sump drainage, ground water lowering and ground water damming by closed sheeting, caisson sheeting or other form of prefabricated sheeting. Ground water lowering by use of well pointing use of compressed air or other means should only be temporary measure because it can endanger shaft stability and adjacent structures; it can be used for example when placing the drive pit bottom or inserting or removing the machine.

#### **4.1.7 Traffic Considerations**

Inevitably there will be problems associated with traffic routing at the rail under bridge, Hazratganj junction, in front of the civil hospital (park road) and in the trenched reached. Some diversions and route planning will be necessary if working areas and access pits/shafts compromise traffic flow. However irksome this may be it will be significantly better than the disruption inevitable with open cut working, the impact of the working area being finite, temporary and minimal. Permits must be obtained in connection with working in the highway. Smooth progress with regard to the issue of such permits is essential to the execution of the micro-tunneling operations. It is customary practice for the client, in this case UPJN, to take responsibility for the grant of such permits as may be necessary. Permits will be needed for driving the sewer under the railway that bisects the proposed route; negotiations with the railway authority are understood to be particularly difficult and should be undertaken by UPJN by interaction between the agencies.

#### **4.1.8 Contractor Experience**

There is some pipe jacking and micro tunneling experience in India, particularly in Mumbai at this time, but local contractors wishing to bid for the relief trunk sewer will need to collaborate with overseas suppliers and equipment specialists to get the slurry shield microtunnelling machinery. A number of competent collaborators are either already active in marketing and the execution of initial projects but additional candidates from the Japan and US could be encouraged. It is however essential that the credentials of collaborative contractor teams are thoroughly checked and that the "experienced" staff is available at all critical times from planning through execution. The qualifications of staff must be properly documented giving full details of training and experience on similar projects and preferably in developing markets. Microtunnelling is a highly specialized skill; usually an engineer from the machine manufacturer can be available to ensure that local staff is properly trained, that equipment is properly used and maintained. Equipment suppliers providing training should be required to certify trainee competence after training and periods of supervised site experience. Technical visits by the product pipe manufacturer are also helpful particularly during product inspection and testing. These requirements could be written into the project bid documents.

#### **4.1.9 Client Experience**

Successful implementation of microtunnelling and other trenchless technologies and the establishment of an effective partnership between the UPJN and its suppliers depend upon an effective dialogue between the contractors and suppliers of technology and the Jal Nigam engineers. This dialogue is essential because there are few internationally recognized specifications available for trenchless technologies and the parties will have to develop a shared vision of the issues rather than fallback on a prescriptive relationship. A period of training is recommended for the executing engineering staff at all levels. A number of training organisations such as the UK's WTI and other specialist small consultants offer training packages, some leading to formal qualifications, other being simply familiarisation with the technologies. The depth of such courses is a function of the time and money invested by all parties concerned but they are nonetheless valuable if they can skill the engineers to interact with their contractors and particularly their overseas collaborators in regards to the operational issues thrown up by implementation of these technologies.

#### **4.1.10 Programming**

Sufficient time must be allocated for all essential operations, equipment and product supply and approval, sinking of shafts and caissons and machine maintenance and overhaul. Microtunnelling is a dynamic process, the transverse loads experienced by the pipe are time dependent, that is to say the pipe friction develops as the ground locks onto the pipe. For optimum working, every phase of the process must be conducted on schedule lest the machine or product pipeline still causing the contractor to abort the drive, construct an emergency shaft and excavate the machine. Delays due to breakdown or intermittent delivery of product pipe cannot be tolerated. The drive once commenced should be continuous until the machine arrives in the receiving shaft. This continuity of operation usually involves shifts working round the clock.

#### **4.1.11 Method Statement**

There are relatively few process and product standards available for the trenchless installation of pipelines and those that exist are limited in scope and inevitably are dated in respect to developing technology. Accordingly installation by trenchless means rely heavily on understanding between the supplier / contractor and the client or the clients the managing consultant. For the avoidance of doubt and the clarity of understanding the required to equitably resolve and adjudicate problems as they arise, clear documentation of the aims and objectives, goals and outcomes, and expectation of the parties is valuable at the precontractor stage. The client can reasonably be expected to have a simple and clear concept of expectation, for example a sewer line installed to line and level with specified performance characteristic. The contractor on the other hand as an understanding of the capability of the staff and their abilities to utilize their equipment to meet the clients needs in a specific environment, chosen by the client but unknown in detail to both parties. To facilitate this improvement dialogue, detail method statement and working procedures will be called for at the tender stage for discussion during bid evaluation.

#### **4.1.12 Calculations**

The contractor will be expected to submit calculations showing the maximum expected jacking force taking in to account the method face support, pipe frictional resistance, pipe weight, lubrication measures and the cutter characteristics, degree of over cut, soil type, groundwater, depth of cover, rate of advance, deviation from the line and level and steering measures. The pipe selected should be capable of carrying 300 to 400 % of this force without distress and thrust wall or caisson must also be capable of supporting this load with normal margins of safety. Jacking force should be monitored at all times: modern equipment has an automatic recording capability, at no time should the 80 % safe working load on the pipe be exceeded.

## Appendix A 6.1 STP Design Spec

### 6.1 DESIGN SPECIFICATIONS FOR STP

#### 6.1.1 Civil Works

Natural ground level of the treatment site is more or less flat with a moderate slope towards south i.e. Pandu river. Land area available at the western side of the identified plot is utilised for the proposed STP for Phase I.

(1) Design Loads

1) Dead Loads

Dead loads (D) shall mean the total weight of the structural components and/or foundations, all architectural appurtenances incorporated in the structure and all permanent externally applied loads. The unit weight of materials in general, shall be in accordance with IS:875. Also, the following unit weights shall be considered for the purpose of design.

- 6 mm thick chequered plate = 55 kg/sq.m
- 25 mm thick grating = 40 kg/sq.m
- Hand rail = 15 kg/sq.m

2) Live Loads

Live loads (L) shall mean, the total weight of moving or movable external loads on structures, buildings and/or foundations, produced by people, tools, furnishings of buildings, etc. which are not permanently fixed thereto.

However, weight for small equipments and miscellaneous facilities like following, which may be permanently fixed there to, shall be included in live loads.

- Local lighting facilities,
- Local instrumentation and electrical facilities and cables, and
- Local small pipings.

(2) Live loads on locations other than roofs

The design live loads shall be those appropriate to the actual situations but shall not be less than the following values.

| Location              | Live Loads    |
|-----------------------|---------------|
| Office                | 400 kg/sq.m   |
| Operating floors      | 500 kg/sq.m   |
| Storage               | 750 kg/sq.m   |
| Work shop light duty  | 500 kg/sq.m   |
| Work shop medium duty | 700 kg/sq.m   |
| Work shop heavy duty  | 1,000 kg/sq.m |
| Platform              | 500 kg/sq.m   |
| Staircase             | 500 kg/sq.m   |
| Corridors             | 500 kg/sq.m   |
| Walkways              | 500 kg/sq.m   |
| Floor under conveyors | 300 kg/sq.m   |
| Kitchen, toilet       | 200 kg/sq.m   |

(3) Live Loads on Roof

- i) Flat roof, sloping roof with slope < 10°
- a) With access : 150 kg/sq.m
- b) Without access except for maintenance : 75 kg/sq.m
- ii) Sloping roof with slope > 10°

|   |   |   |
|---|---|---|
| A | For roof membrane sheet or purlins  | 75 kg/sq.m less 2 kg/sq.m for every degree increase in slope over 10 degrees subject to minimum of 40 kg/sq.m |
| B | For member supporting the roof purlins such as trusses, beams and girders, etc. | 2/3 of the load calculated in (ii) - (a)  |

(4) Wind Load

Wind loads (W) on plant buildings/structures shall be calculated in accordance with IS 875.

Reference : IS : 875 Part 3

(5) Seismic Load (S)

- 1) Reference : IS : 1893
- 2) Seismic zone : III
- 3) Basic seismic coefficient ( ) : 0.04
- 4) Importance factor (I) : 1.5
- 5) Seismic coefficient method ( $\alpha_h$ ) :  $\beta I \alpha_o$
- where  $\alpha_h$  : Horizontal seismic coefficient
- $\beta$  : Soil foundation factor

(6) Equipment Loads

Equipment loads shall be defined as per the following three cases, according to the governing conditions of erection, operation and testing.

1) Equipment Loads for Erection

Equipment loads for erection (Ee) shall mean the weight of equipment during erection and exclude, the weight of internals, fluids and solids within the equipment, platforms, insulations and piping attached to the equipment.

2) Equipment Loads for Operation

Equipment loads for operation (Eo) shall mean the load of equipment during normal operating conditions, including the weight of internals, fluids and solids within the equipment and all materials permanently attached to the equipment, such as platforms, insulation and piping.

Vibration caused by operation of equipment shall be considered separately as vibration loads.

3) Equipment Loads for Testing

Equipment loads for testing (Et) shall mean the load of equipment during hydrostatic testing after erection/installation, including the weight of water within the equipment, piping and all materials permanently attached to the equipment, such as platforms, insulation and pipings.

(7) Piping Loads

Piping load (P) shall mean the weights of pipes, fittings, valves, insulations and the fluid contents of piping including the weight of cable ducts wherever installed.

Piping loads shall be assumed as the equivalent loads considering the pipe diameter and piping arrangement.

(8) Handling Device Loads

Handling device loads (H) shall mean the loads of cranes, hoists and lifts including the lifted weight in the normal operation

Handling device loads shall be increased with the following percentages to include adequate allowance for the following impact conditions.

1) Vertical Impact Loads

|   |   |      |
|---|---|------|
| Frames supporting lifts and hoists                  | : | 100% |
| Foundations supporting lifts and hoisting apparatus | : | 40%  |
| Vertical loads for electrical overhead cranes       | : | 25%  |
| Hand operated cranes                                | : | 10%  |

2) Horizontal Impact Loads

a. Overhead Cranes

|                                      |  |
|--------------------------------------|--|
| Horizontal loads transverse to rails | 10% of the maximum wheel loads of the crane applied at the top of rail |
| Horizontal loads along the rails     | 5% of all static wheel loads   |

b. Monorails

- a) Transverse load : 20% of the lifted load
- b) Longitudinal load : 10% of the lifted load, hoist and trolley

(9) Vibration Loads

Vibration loads (V) shall mean the vibration forces caused by heavy vibrating equipment or machinery and dynamic forces caused by fluids in the normal operation.

Frames, structures and foundations for machinery or equipment causing vibration shall be designed to limit vibrations to an acceptable level.

It shall be designed such that whether they are independent or part of the building, it shall not only safely carry the loads for such items, but also prevent resonance. Natural frequencies of frames, structures and foundations must differ by more than 30% from that of the machinery under operating conditions.

In the design of structures and/or foundations for the equipment and machinery with dynamic loads, the loads indicated by vendor in his documents shall be used. However, in the absence of such vendor data, the following loads shall be assumed as the equivalent static loads when the dynamic analysis is not carried out.

1) Reciprocating and Rotating (Centrifugal) Type

|     |   |   |
|-----|---|---|
| a)  | Vertical direction  | 0.5 times the weight of equipment or machinery  |
| b)  | Horizontal direction  |   |
| i)  | Along direction of rotation (perpendicular to centre line of shaft) | 0.25 times the weight of equipment or machinery |
| ii) | Along direction of shaft axis                                       | 0.1 times the weight of equipment or machinery  |

(10) Thermal Loads

1. Thermal loads (T) shall mean, the forces caused by the thermal expansion or contraction of vessel or piping on the supporting structures and / or foundations. When the thermal expansion or contraction results in friction between the equipment and its support, the friction force shall be calculated in accordance with the following friction coefficients.

- Steel to steel : 0.3
- Steel to concrete : 0.4
- Concrete to soil : 0.5

2. Pipe anchor points on pipe racks shall be designed in accordance with the actual anchor forces. These anchor forces shall be transferred to the appropriate resisting frames/bracing and foundations.
3. In the design of pipe supporting beams, the horizontal frictional forces exerted by expanding or contracting pipe or pipe racks shall be assumed by the 30% of the piping loads on the beams. These frictional forces shall not be transferred to the columns and foundations

(11) Earth Pressure

1. Earth pressure (Ep) shall mean pressure of the soil acting on the underground structures and / or foundations retaining walls, dikes etc.
2. Earth pressure at rest, acting on basement, trenches and pit shall be calculated from the following equations :

a) Above ground water level

$$P_v = y h_o + q \text{ (T/sq.m)}$$

$$P_h = K_o P_v \text{ (T/sq.m)}$$

b) Below ground water level

$$P_v = yH_1 + q + y_1 (h_o - H_1) + y_w (h_o - H_1) \text{ (T/sq.m)}$$

$$P_h = K_o (yH_1 + 1 + y_1 (h_o - H_1)) + y_w (h_o - H_1) \text{ (T/sq.m)}$$

where

$P_v$  = Vertical soil pressure (T/sq.m)

$P_h$  = Horizontal soil pressure (T/sq.m)

$y$  = Unit weight of soil (T/sq.m)

$h_o$  = Soil depth from grade surface (m)

$q$  = Distributed load on ground surface (T/sq.m)

$H_1$  = Underground water level from grade surface (m)

$y_1$  = Submerged weight of soil in water (T/sq.m)

$y_w$  = Unit weight of water (T/sq.m)

$K_o$  = Ratio of horizontal to vertical pressure =  $\tan^2 (45^\circ - \emptyset/2)$

$\emptyset$  = Internal friction angle of soil =  $30^\circ$

3. Active and passive earth pressure acting on retaining wall shall be calculated from Coulomb's or Rankine's earth pressure equation.

(12) Liquid Pressure (LP)

1. Liquid pressure shall mean the pressure of liquid acting on the pit / basin structures
2. Liquid pressure shall be calculated by using the following equation

$$P1 = y \times h1 \text{ (T/sq.m)}$$

where

P1 = Liquid pressure (T/sq.m)

h1 = Depth from liquid surface (m)

y = Unit weight of liquid T/sq.m

(13) Traffic Loads

Traffic loads for plant engineering and construction shall be defined according to the governing condition at the time construction. Unless otherwise specified, appropriate IRC (Indian Road Congress) loading shall be applied to the design of road crossing constructions such as drainage pipes and cable trench.

(14) Combination of Loads

1) Types of Loads

Unless otherwise specified, all loads listed herein, shall be considered in the design

D = Dead loads

L = Live loads

W = Wind loads

S = Seismic loads

Equipment loads (Ee, Eo, Et)

Ee = On erection condition

Eo = On operation condition

Et = On test condition

P = Piping loads

H = Handling device loads

V = Vibration loads

T = Thermal loads

Ep = Earth pressure

Lp = Liquid pressure

(15) Loading Combinations

Buildings, structures, foundations, and all structural components shall generally be designed for the following load combinations

| Sr. | Load Combinations   | Category of Loading Combinations |
|-----|---|----------------------------------|
| 1)  | Loading combinations for buildings                          |                                  |
|     | D + L + H   | A                                |
|     | D + L + H* + W  | B                                |
|     | D + L + H* + S  | B                                |
| 2)  | Loading combinations for equipment supporting structures ** |                                  |
|     | D + L + Eo + P + H + T                                      | A                                |
|     | D + l + Eo + P + H* + R + W                                 | B                                |
|     | D + l + Eo + P + H* + R + S                                 | B                                |

| Sr. | Load Combinations   | Category of Loading Combinations |
|-----|---|----------------------------------|
|     | D + Ee + W  | B                                |
|     | D + L + Et + P + H*   | A                                |
| 3)  | Loading combinations for pipe racks                                 |                                  |
|     | D + L + P + T   | A                                |
|     | D + L + P + T + W   | B                                |
|     | D + L + P + T + S   | B                                |
| 4)  | Loading combinations for equipment foundations                      |                                  |
|     | D + Eo + T  | A                                |
|     | D + Eo + T + W  | B                                |
|     | D + Eo + T + S  | B                                |
|     | D + Ee + W  | B                                |
|     | D + Et + 25% Wind   | A                                |
| 5)  | Loading combinations for machine foundations                        |                                  |
|     | D + Eo + P  | A                                |
|     | D + Eo + P + V  | A                                |
| 6)  | Loading combinations for sleeper and local support foundations      |                                  |
|     | D + P + T   | A                                |
| 7)  | Loading combinations for dykes, trenches and underground pits (***) |                                  |
|     | D + L + Ep + Lp   | A                                |

1) Notes

- A - Basic combination and no increase of allowable values shall be considered
- B - Combination considering wind loads/seismic forces or considering temporary erection. maintenance conditions
- (\*) - Only dead load of handling device shall be considered in the design
- (\*\*) - When the structural effect of the vibration loads are significant they shall be considered in the design.
- (\*\*\*) - Traffic loads shall be considered, where required

(16) Load Factors for Limit State Design

| Loads                  | Item | Buildings<br>(1) |      |     |           | Equipment Supporting Structures<br>(2) |      |     |           |      |
|------------------------|------|------------------|------|-----|-----------|--|------|-----|-----------|------|
|                        |      | Normal           | Wind | Eo  | Stability | Normal                                 | Wind | Eo  | Erection  | Test |
| Dead loads             | D    | 1.5              | 1.2  | 1.2 | 0.9/φ 1.5 | 1.5                                    | 1.2  | 1.2 | 0.9/φ 1.5 | 1.5  |
| Live loads             | L    | 1.5              | 1.2  | 1.2 |           | 1.5                                    | 1.2  | 1.2 |           | 1.5  |
| Wind loads             | W    |                  | 1.2  |     | 1.5       |  | 1.2  |     |           |      |
| Seismic loads          | S    |                  |      | 1.2 |           |  |      | 1.2 |           |      |
| Equipment loads        |      |                  |      |     |           |  |      |     |           |      |
| On erection condition  | Ee   |                  |      |     |           |  |      |     | 0.9/φ 1.5 |      |
| On operation condition | Eo   |                  |      |     |           | 1.5                                    | 1.2  | 1.2 |           |      |
| On test condition      | Et   |                  |      |     |           |  |      |     |           | 1.5  |
| Piping loads           | P    |                  |      |     |           | 1.5                                    | 1.2  | 1.2 |           | 1.5  |
| Handling device loads  | H    | 1.5              | 1.2  | 1.2 |           | 1.5                                    | 1.2  | 1.2 |           | 1.5  |
| Vibration loads        | V    |                  |      |     |           |  |      |     |           |      |
| Thermal loads          | T    |                  |      |     |           | 1.5                                    | 1.2  | 1.2 |           |      |
| Earth pressure         | Ep   |                  |      |     |           |  |      |     |           |      |
| Liquid pressure        | Lp   |                  |      |     |           |  |      |     |           |      |

φ Value of 0.9 to be considered when stability against overturning of stress reversal is critical.

| Loads                  | Item | Pipe Racks<br>(3) |      |     | Equipment Foundations<br>(2) |      |     |          |      |
|------------------------|------|-------------------|------|-----|------------------------------|------|-----|----------|------|
|                        |      | Normal            | Wind | Eo  | Normal                       | Wind | Eo  | Erection | Test |
| Dead loads             | D    | 1.5               | 1.2  | 1.2 | 1.5                          | 1.2  | 1.2 | 1.2      | 1.5  |
| Live loads             | L    | 1.5               | 1.2  | 1.2 |                              |      |     |          |      |
| Wind loads             | W    |                   | 1.2  |     |                              | 1.2  |     | 1.2      | 1.5  |
| Seismic loads          | S    |                   |      | 1.2 |                              |      | 1.2 |          |      |
| Equipment loads        |      |                   |      |     |                              |      |     |          |      |
| On erection condition  | Ee   |                   |      |     |                              |      |     | 1.2      |      |
| On operation condition | Eo   |                   |      |     | 1.5                          | 1.2  | 1.2 |          |      |
| On test condition      | Et   |                   |      |     |                              |      |     |          | 1.5  |
| Piping loads           | P    | 1.5               | 1.2  | 1.2 |                              |      |     |          |      |
| Handling device loads  | H    |                   |      |     |                              |      |     |          |      |
| Vibration loads        | V    |                   |      |     |                              |      |     |          |      |
| Thermal loads          | T    | 1.5               | 1.2  | 1.2 | 1.5                          | 1.2  | 1.2 |          |      |
| Earth pressure         | Ep   |                   |      |     |                              |      |     |          |      |
| Liquid pressure        | Lp   |                   |      |     |                              |      |     |          |      |

| Loads                  | Item | Machine FDN<br>(5) |           | Local<br>FDN<br>(6) | Dykes<br>Trenches &<br>U/G Pits<br>(7) |
|------------------------|------|--------------------|-----------|---------------------|--|
|                        |      | Normal             | Vibration | Normal              | Normal                                 |
| Dead loads             | D    | 1.5                | 1.5       | 1.5                 | 1.5                                    |
| Live loads             | L    |                    |           |                     | 1.5                                    |
| Wind loads             | W    |                    |           |                     |  |
| Seismic loads          | S    |                    |           |                     |  |
| Equipment loads        |      |                    |           |                     |  |
| On erection condition  | Ee   |                    |           |                     |  |
| On operation condition | Eo   | 1.5                | 1.5       |                     |  |
| On test condition      | Et   |                    |           |                     |  |
| Piping loads           | P    | 1.5                | 1.5       | 1.5                 |  |
| Handling device loads  | H    |                    |           |                     |  |
| Vibration loads        | V    |                    | 1.5       |                     |  |
| Thermal loads          | T    |                    |           | 1.5                 |  |
| Earth pressure         | Ep   |                    |           |                     | 1.5                                    |
| Liquid pressure        | Lp   |                    |           |                     | 1.5                                    |

(17) Safety Factors for Stability

All buildings, structures and foundations shall be designed, such that the safety factor shall not be less than the values mentioned before in any condition

|             |   |                                  |
|-------------|---|----------------------------------|
| Overturning | : | 1.5 during erection              |
|             | : | 1.5 during operation and testing |
| Sliding     | : | 1.5                              |
| Buoyancy    | : | 1.2                              |

(18) Materials – Concrete

1) General

Unless otherwise specified in the drawings, material specifications shall conform to the following.

2) Cement

Cement used for all concrete works both above and below ground shall be ordinary Portland cement conforming to IS : 8112.

3) Aggregates

Aggregates used in the concrete works shall be locally available gravel or crushed stone conforming to IS : 383.

Unless otherwise specified, the maximum size of aggregates shall be as follows:

|   |   |
|---|---|
| For large foundations and mass concrete | 40 mm graded down (provided the pitch of reinforcement is more than 100 mm) |
| For others                              | 20 mm graded down   |

4) Reinforcement

Reinforcement shall be high strength deformed bars and shall conform to IS: 1786.

5) Anchor Bolts

Anchor bolts shall be of structural steel quality conforming to IS: 2062.

6) Insert Plates

Insert plates shall be of structural steel quality conforming to IS: 2062 and shall be provided with mild steel lugs as per drawings/ standards.

Mild steel bars shall conform to IS: 432.

(19) Design Strength of Concrete

Unless otherwise specified, the design compressive strength of Cast-in-situ concrete at 28 days (conforming to IS: 456) shall be as follows:

|                                     |              |
|-------------------------------------|--------------|
| Structural concrete (M 20)          | 200 kg/sq.cm |
| Liquid retaining structures (M 20)  | 200 kg/sq.cm |
| Paving (M 20)                       | 200 kg/sq.cm |
| Grade slab (M 15)                   | 150 kg/sq.cm |
| Leveling concrete (M 10)            | 100 kg/sq.cm |
| Filling / mass/ plum concrete (M 5) | 50 kg/sq.cm  |

(20) Design Basis

1) Design Loads

1. Design loadings shall be as per design loads and shall be applied to the following
  - Design loads
  - Loading combinations
  - Safety factors for stability
  - Load factors for required strength
2. The calculation of stability and soil contact pressure of foundation shall be carried out on the basis of working load and allowable soil bearing capacity.
3. The resisting lateral force against the sliding of foundation shall generally be based on the friction force between the foundation and its supporting subsoil within factor of 0.5

2) Foundation Design Criteria

The foundation design criteria such as foundation depths, allowable soil bearing capacities, foundation settlement and soil design parameters shall be in accordance with relevant IS Codes and geotechnical survey report.

(21) Design Basis and Requirements

1. Framing systems shall be arranged so that the stiffness of structure can be well balanced and the structural stability can be secured
2. Expansion joints for the structure shall be provided every 45 to 50 meters in the longitudinal direction.
3. Structural analysis and section design shall be made in accordance with the applicable codes, standards and specifications and by using the authorised and approved methods.

4. In case of heavy and/or tall equipments installed on the reinforced concrete structure, the floor and beam arrangement shall be planned so that the firm anchoring and structural stability shall be assured.
5. Pits and basins shall be designed to withstand the water pressure, earth pressure, buoyancy and surcharge where required.

Pits and basins containing liquids shall be designed for both full and empty conditions and partition walls between compartments shall be designed for alternative liquid pressure on either side.

Dikes shall be designed to withstand the pressure of containing liquid for both full and empty conditions.

Liquid retaining structures shall be designed as per IS: 3370, with crack width criteria of 0.1 mm.

(22) Minimum Dimensions of Members

Member sizes shall be as per design requirements. However, minimum dimensions of structural members shall be as given below:

|                                       |                             |
|---------------------------------------|-----------------------------|
| Grade slabs                           | 150 mm thick                |
| Floor slab (Non suspended)            | 150 mm thick                |
| Floor slab (Suspended)                | 120 mm thick                |
| Footings                              | 200 mm thick                |
| Underground pit/drain walls           | 150 mm thick                |
| Water retaining walls                 | 150 mm thick                |
| Water retaining slabs (non suspended) | 150 mm thick                |
| Water retaining slabs (suspended)     | 120 mm thick                |
| Columns and pedestals                 | 230 mm width. 230 mm length |
| Beams                                 | 150 mm width. 300 mm depth  |
| Insert plate                          | 10 mm thick                 |
| Corner angle                          | 8 mm thick                  |

(23) Minimum Height of Plinth and Pedestals above Finished Grade Level

|                                  |        |
|----------------------------------|--------|
| Building plinth                  | 500 mm |
| Pedestals for structural columns | 300 mm |
| Stair pedestals                  | 200 mm |
| Ladder pedestals                 | 200 mm |
| Equipment including pump etc.    | 300 mm |

(24) Minimum Cover to Main Reinforcement

Reinforcement shall have concrete cover not less than twice the diameter of bar end. Minimum cover to main bar shall be:

- |    |                     |                              |       |
|----|---------------------|------------------------------|-------|
| 1) | Slab                | : Free face                  | 25 mm |
|    |                     | : Face in contact with earth | 30 mm |
| 2) | Beam                | : Top/Bottom                 | 40 mm |
|    |                     | : Side                       | 30 mm |
|    |                     | : Face in contact with earth | 40 mm |
| 3) | Column and pedestal | :Super structure             | 40 mm |

|    |  |                              |       |
|----|--|------------------------------|-------|
|    | Face in contact with earth   | 40 mm                        |       |
| 4) | Retaining wall   | :Face in contact with earth  | 40 mm |
|    | Basement and pit wall  | :Free face                   | 40 mm |
| 5) | Liquid Retaining Structure   | :Face in contact with liquid | 40 mm |
|    |  | :Face in contact with earth  | 40 mm |
|    |  | Free face                    | 40 mm |
| 6) | Plinth beam  | :Top and side                | 30 mm |
|    |  | :Bottom                      | 40 mm |
| 7) | Foundation:  | Bottom                       | 50 mm |
|    |  | :Top                         | 50 mm |
| 8) | The above requirements shall not be applied to concrete construction of trench, local foundation, minor platform foundation, sump pit/manhole, paving and other miscellaneous concrete construction, for which minimum cover shall be 25 mm. |                              |       |
| 9) | Minimum Bar Diameter   |                              |       |
|    | Major foundation   |                              | 10 mm |
|    | Block foundation – main bars   |                              | 10 mm |
|    | Block foundation – tie bars  |                              | 8 mm  |
|    | Minor foundation (local foundation etc.)   |                              | 8 mm  |
|    | Column, pedestal – main bars   |                              | 12 mm |
|    | Column, pedestal – ties  |                              | 8 mm  |
|    | Beam – main bars   |                              | 12 mm |
|    | Beam – anchor bars   |                              | 10 mm |
|    | Beam – stirrups  |                              | 8 mm  |
|    | Slab – main bars   |                              | 8 mm  |
|    | Slab – distribution bars   |                              | 8 mm  |
|    | Wall – main bars   |                              | 8 mm  |
|    | Wall – distribution bars   |                              | 8 mm  |
|    | Minor elements such as chajjas, lintel beams etc.  |                              | 8 mm  |

10) Bar Spacing<sup>1</sup>

|                             | <b>Minimum</b> | <b>Maximum</b> |
|-----------------------------|----------------|----------------|
| Foundations                 | 125 mm         | 200 mm         |
| Slabs                       | 100 mm         | 300 mm         |
| Stirrups for beams          | 100 mm         | 300 mm         |
| Ties for columns, pedestals | 100 mm         | 300 mm         |
| Walls                       | 100 mm         | 300 mm         |

(25) Foundations

1. Foundation shall be proportioned in such a way that the allowable soil bearing capacity is not exceeded and the resulting settlement is within the acceptable limit.
2. All major foundations shall be placed below the natural ground level even in places filled up during the site preparation.
3. Foundation sizes and depths shall be planned considering subsurface conditions and surrounding underground constructions such as adjacent foundations, underground pipes and cables, trenches, pits, roads as well as the slope of ground.

---

<sup>1</sup> Bar Spacing shall be provided in multiples of 25 mm

4. Isolated footing shall be planned for each foundation. However, where adjacent footings interfere with each other, combined footing may be provided.
5. Where applicable the elevation of foundation top shall be in accordance with the process, mechanical and piping requirements.

1) Foundations for Rotating and Reciprocating Equipment

1. Foundation for rotating and reciprocating equipment such as turbines, engines, compressors and generators shall be designed to secure the dynamic stability of the foundation system, as well as the static stability.
2. Dynamic stability for foundation supporting heavy vibrating equipment like the following shall be secured by dynamic analysis in general :
  - Heavy vibrating equipment
  - Equipment sensitive to vibration
  - Equipment causing large dynamic force

Unless otherwise specified foundation design shall follow general criteria indicated below :

| <b>Criteria</b>           |                                  | <b>Application</b>   |
|---------------------------|----------------------------------|--|
| Dynamic analysis          | Allowance amplitude <sup>2</sup> | Rotating : $P \geq 400$ kW                                   |
|                           | Natural frequency of foundation  | Reciprocating : $P \geq 100$ kW                              |
|                           | Natural frequency of foundation  | Rotating : $P \geq 100$ kW<br>Reciprocating : $P \geq 40$ kW |
| Foundation weight control | More than 3 x equip. Weight      | Rotating : $P < 100$ kW                                      |
|                           | More than 5 x equip. Weight      | Reciprocating : $P < 40$ kW                                  |

P = Rated Power output of equipment (unit kW)

(26) General Requirements for Design

Following requirements shall be taken into account for foundation design in principle:

1. Foundation for heavy vibrating equipment shall be kept independent of building floors/foundations and other adjacent foundations.
2. Foundation weight shall be at least three times the weight of the rotating equipment and five times the weight of the reciprocating equipment
3. Foundation shall be of uniform rectangular/square shape.
4. Beams and columns of foundations shall be of uniform rectangular/square shape.
5. The horizontal eccentricity, in any direction, between the center of gravity of the machine - foundation system and the center of base contact area, shall be within 5%.
6. The geometric layout of the foundation and structure shall be basically symmetric with respect to the vertical plane passing through the rotational axis of the equipment.

(27) Dynamic Analysis

1) General

Dynamic analysis shall be performed by suitable and approved method so that dynamic features can be evaluated correctly.

The following effects shall be taken into account:

<sup>2</sup> If the Suppliers requirement is available, it shall be considered

- Dynamic features of subsoil
- Dynamic features of supporting foundation system
- Dynamic effect of the foundation system
- Dynamic forces of equipment

Data of dynamic load to be used for the dynamic analysis, shall be supplied by equipment supplier and shall state unbalanced force due to :

- Eccentricity of dynamic mass of rotating equipment
- Different crank arrangement of reciprocating equipment

## 2) Evaluation of Dynamic Analysis

### Frequency Ratio

Wherever possible the natural frequency of the foundation soil-system shall be higher than the highest disturbing frequency and the frequency ratios shall be less than 0.7. Where this is not possible, the natural frequency of the foundation soil system shall be kept lower than the lowest disturbing frequency. The frequency ratio in such cases shall not be lower than 1.50. While the above criteria shall be applied to all possible modes of vibration, it may be permitted to operate machines closer to the resonance in certain modes of vibration provided the resulting amplitudes do not exceed the permissible limit.

## 3) Allowable Amplitude Due To Dynamic Load

Amplitude of the foundation systems for vibrating equipment shall be calculated through dynamic analysis by using dynamic analysis by using dynamic load supplied by supplier and the allowable amplitude shall conform to supplier's requirement.

If supplier's requirements on amplitude are not specified, following criteria shall be applied. The amplitude of vibration of the foundation in any direction, at any point in the foundation of structure shall be such that, it will fall down the zone ACC' for the specific exciting frequency.

## (28) Design Details

### 1) Anchor Bolts

1. In case of no tension load in the anchor bolts of equipment such as small towers, tanks, heat exchangers, pumps, blowers, compressors, etc. Anchor bolts shall generally be set in anchor boxes unless embedment is required. Minimum distance between the inside surfaces of the anchor boxes and the outside surface of the foundation shall be 75 mm.
2. In general, anchor bolts for structural steel columns are embedded into the pedestal.
3. Anchor bolts for heavy towers, which are subject to pull out force, shall be embedded into the foundation at the time of placing concrete using templates.

### 2) Grouting

- i) Unless otherwise specified by equipment manufacturers, top of foundations except for local foundations shall be provided with an allowance for grouting as specified below:
  - a) Foundation for large heavy duty compressors, generator, etc. 50 mm
  - b) Foundation for big towers (>20 m) 50 mm
  - c) Other foundations 30 mm
- ii) All grout shall be composed of one part cement and two parts clean sand. Grout material for heavy rotating machines shall be used in accordance with manufacturer's requirement where required.

(29) Foundation for Steel Structure

1. Generally tops of all foundations except for local foundation shall be provided with grouting of 30 mm thickness
2. All grout shall be composed of one part cement and two parts clean sand unless otherwise specified.

(30) Covering for Pit/Basins

1. Open pits and basins without roofing or covering shall have safety railings. Stepladders shall also be provided for the pits and basins having a depth of more than 1.0m.
2. The minimum 600 mm diameter cover for access, shall be provided for Pits and Basins.

(31) Materials - Structural Steel

1) Design Basis and Requirements

1. Framing and bracing shall be planned so that the stiffness of the structure can be well balanced with the loads and the structural stability can be secured.
2. Vertical and horizontal bracings shall be arranged properly, considering the following requirements :
  - Plant layout
  - Equipment
  - Piping arrangement
  - Structural layout/construction, operation & maintenance requirementThe vertical bracings furnished for lateral stability of structure may be knee braced, diagonal or "V" type and shall satisfy clearance and rigidity requirements.
3. Expansion joints for the structure shall be provided every 45 to 50 meters in the longitudinal direction
4. Structural analysis and members selections shall be made in accordance with the applicable codes, standards and specifications and by using the authorised and approved methods

2) Bolt Holes

Bolt holes for structure bolts shall be as follows, unless otherwise specified on drawings.

- |                   |   |          |
|-------------------|---|----------|
| a) Ordinary bolts | : | D + 2 mm |
| b) Anchor bolts   | : | D + 5 mm |

Where D = Nominal bolt diameter

3) Minimum Size of Structural Members

|                        |   |                     |
|------------------------|---|---------------------|
| Columns, framing beams | : | ISMB 150, ISMC 150. |
| Bracing members        | : | ISA 50 x 50 x 6     |
| Column base plate      |   |                     |
| For major structure    | : | 16 mm thick         |
| For minor structure    | : | 12 mm thick         |

4) Gusset Plate

Thickness of gusset plate shall be a maximum of the followings:

- a) Thickness required by design
- b) mm

5) Connections

Unless otherwise specified.

1. Shop connections shall be welded and all welds shall be continuous structural welds. Where galvanizing is specified, seal welding is required at all shop connections prior to hot-dip galvanizing.
2. Field connections shall be bolted connections for all main framing and bracing members.
3. Field connection for ladder, handrails, post, stair stringers, removable members, platform framing members shall be made with black colts.
4. Bolted connection for structural members shall be made, with at least two bolts except for lacing bolts, where it may be with single bolt.
5. High tensile friction grip bolts shall be used for connections subjected to repetitive cycles of loadings.

6) Stopper to Hoist Beams

Removable stoppers, fixed with ordinary black bolts shall be provided on both sides of hoist beams.

7) Column Base

Steel column bases shall be designed to transfer all loads to the foundations or to the supporting reinforced concrete structure.

8) Deflection

Pipe Rack and Equipment Supporting Structure

Allowable deflection of beams and columns, to support pipe and / or equipment directly during normal operation, shall be as stated below, in fraction of the supported span of the beam.

- |  |   |                                       |
|--|---|---------------------------------------|
| i. Pipe rack beams                                   | : | 1/325 or less but not more than 30 mm |
| ii. Equipment supporting structure                   |   |                                       |
| Equipment supporting beams                           | : | 1/400 or less but not more than 30 mm |
| Other beams  | : | 1/325 or less but more than 30 mm     |
| iii. Horizontal sway at top of column of each storey |   |                                       |
| For open framed structures                           | : | Height 1/200                          |
| For clad structures                                  | : | Height 1/400                          |
| iv. Cantilevers                                      | : | 1/250 but more than 20 mm at end      |

Crane Girders

Allowable vertical and horizontal deflection of girders for traveling cranes during normal operation, depending on types, shall be as stated below, in fraction of the supported span of the girders.

- |  |   |         |
|--|---|---------|
| i) Hand operated crane                           | : | 1/500   |
| ii) Electric overhead traveling crane upto 50 T  | : | 1/750   |
| iii) Electric overhead traveling crane over 50 T | : | 1/ 1000 |
| iv) Other moving loads such as charging cars     | : | 1/ 600  |
| v) Monorails and hoist beams                     | : | 1/500   |
| vi) Joist  | : | 1/ 325  |
| vii) Purlins, furring strips                     | : | 1/200   |

(32) Floors, platforms and walkways

- a) Platform and walkways shall be minimum 900 mm wide and shall be made of chequered plate flooring or grating flooring as specified in the drawings.
- b) The minimum clear headroom over platforms and walkways shall be 2100 mm to the lowest point of overhead structural framing or equipment. This clearance may be reduced to 1800 mm locally for Support beams when structurally required.

- c) Chequered plates shall be 6 mm thick.
- d) Floor gratings shall typically be pressure locked or pressure welded type steel grating with bearing bars 25 x 5 mm x 30 centers with secondary cross bars 12 x 5 mm x 75 mm centers. Serrated style grating shall be used for stair treads. Landing and stair treads shall have full width chequered round nosing plates.
- e) Openings more than 200 mm diameter on the floors, shall be guarded by surrounding toe plates of flat bar 100 x 6 mm.
- f) Drip holes having 10 mm diameter shall be properly arranged on the chequered plate flooring of outdoor platforms and walkways.
- g) High elevation platform and walkways around equipments (towers, tanks, etc.) shall be described in vessel standard and/or other engineering specifications.

(33) Staircases

- a) Staircase shall be minimum 900 mm wide and shall be made of channel stringers with grating treads.
- b) Unless otherwise specified, staircase shall have risers of not more than 200 mm and treads not less than 250 mm.
- c) The vertical rise of stairs shall not exceed 4.0 m for the single unbroken flight.
- d) The minimum length of landings shall be 900 mm in the direction of stairs.
- e) The vertical clear headroom over stairs shall be 2100 mm.

(34) Ladders

- a) Ladders shall be minimum 450 mm wide and shall be made of stringers with 20 mm diameters. MS rungs at 300 mm intervals.
- b) The flight of Ladder without the intermediate platform shall not exceed 9 m.
- c) Ladders over 4.0 m in height or originated from a point, which is 4.0 m or more above grade, shall be provided with safety cages, originating 2.1 m from the bottom.
- d) Ladder access openings shall be provided with the safety chain.

(35) Hand Rails

- a) Platform, walkways and stairs located 1 m above grade or floor shall be provided with handrails consisting of top rails, posts, mid-bars and toe plates.
- b) Handrails shall be 1025 mm high.
- c) All projecting cut edges on top rails be rounded to smooth finish

(36) Geotechnical Information

Five numbers of boreholes were taken at the identified site of Panka STP. The same data is used in the design of foundations.

(37) Reference

- a) IS: 456 – 2000 : Code of practice for plain and reinforcement concrete (Incor. amendment no.1) (third revision)
- b) IS:3370 – 1967 Code of practice for concrete structures for the  
(Parts I to IV) Storage of liquids
- c) IS:269 – 1979 Specification for ordinary, rapid hardening and low heat Portland cement.
- d) IS:875 – 1987 Code of practice of design load for building and structures (parts I to IV)
- e) IS:1786 – 1979 Specifications for high yield deformed bars
- f) IS:1893 – 1984 Criteria for earthquake resistant design of structures (fourth revision)

|                                |   |
|--------------------------------|---|
| g) IS:4236 – 1993<br>revision) | Specification for earthquake resistant construction of building (second revision) |
| h) IS:1904 – 1986              | Specification for design and construction of foundation in soils                  |
| i) IS:800 – 1984               | Specification for general construction in steel                                   |
| j) IS:2974 – 1979              | Specification for design and construction of machine foundations                  |
| k) IS:13920 – 1993             | Ductile detailing of reinforced concrete structures subjected to seismic forces   |
| l) SP:34 (S&T)-1987            | Handbook on concrete reinforcement and detailing                                  |
| m) SP:16(S&T)-1980             | Design aids for reinforcement concrete to IS:456 – 1978                           |
| n) SP:24-1983                  | Explanatory handbook on IS:456 – 1978   |
| o) C.E.Reynolds                | Reinforced concrete designer's handbook by J.C.Steedman                           |
| p) Jai Krishna                 | Plain and reinforced concrete Volume I & II – O.P Jain                            |

### **6.1.2 Mechanical Works**

The mechanical equipment consists of screens, grit removal mechanism, aerators, pumps, etc. The equipment is selected to suit the performance requirements and the prevailing site conditions. The requirements of mechanical equipment are described here under.

#### **(1) Aluminium Gates**

For the control of the flow and for maintenance of the mechanically raked screens, rising spindle aluminum gates are provided. The gates shall be single faced, rising spindle, flush bottom closing, wall mounted flange back frame. Aluminum sluice gates suitable for seating water head of 1.5m and mounting on the flat face of a wall, water sealing at two vertical sides, top and bottom side of gate frame by means of neoprene rubber seal fitted in gate aperture and having forced contact with gate slide, to be provided with aluminum frame and shutter, SS 304 spindle to suit distances as specified in the bill of quantities. All fasteners shall be in SS 304 and anchor bolts, EPDM rubber seals, SS 304 rubber seal retainer bars, CI stem guide bracket, SS 304 coupling, CI manually operated head stock.

#### **(2) Screens**

At STP, there will be six screen channels, each of 1800 mm width and 1000 mm liquid depth. Four channels are working which are provided with mechanical screens and two channels are standby which have manual screens. The mechanical screens will have 6mm clear opening and manual screens will have 12 mm clear openings.

##### **1) Specifications of Mechanical Screens**

Each mechanical screen shall mainly consist of the screen surface (bar screens), rotor arm (raking arrangement), chute and a drive system.

The frame is rigidly framed on all ends and anchored to the RCC channel top surface and to the bottom of the channel. The frame is curved in shape the curvature radius will match the rotor arm tip radius. The entire channel width and depth will be covered by the screen surface.

The rotor arm assembly will be placed on the inlet side of the screen. The rotor consists of two main Bearing Blocks having an axle running in their journals across the channel. Two rake arms at 180 degrees to each other, fixed to the axle, shall carry the retriever combs made of cast steel. The outer radius of the combs shall match the radius of the screen surface and the combs will engage into the bars to carry the trapped screenings to the top end of the screen. The bearing blocks are anchored to the RCC channel, parallel to the screen surface.

The cleaning rake will be revolving rake type with four steel combs. The rake will be suitably sized for heavy duty and shaped to effectively clean the bar screen. The sprocket chain will be split type. The screenings is to be dropped on conveyor about 600 mm above the top of the screen channel.

The chute shall be placed on the outlet side of the screen surface, near the top end and shall receive the screenings through an interceptor plate from the rotor arms combs. The client shall have to either place a conveyor belt to receive the screenings or have a mobile trolley under the chute.

The drive system operates the axle and correspondingly the rotor arms. The system consists of a motor of required HP driving a reduction gearbox, which in turn drives another gearbox through chain and sprocket transmission to obtain the desired RPM on the rotor. The system is assembled over a base frame that is anchored to the RCC channel top near the rotor.

The drive machinery includes TEFC motor, speed reducer, head shaft, etc. All fasteners will be of SS 316. All the steel structures shall be sand/ball blasted to near white and painted with two coats of zinc rich primer followed with two coats of epoxy paint.

The bar screens are fabricated from 50 mm x 10 mm mild steel flats spaced at required clear opening as mentioned above and fixed at an inclination of 75° to the structural steel frame work such that all bars project on upstream side and teeth of the rake engages within the clearances of the bars without hindrance.

A dead plate of not less than 6 mm thick is provided from top of the bar screen to prevent falling of screenings in the channel. It shall have pivot plate at the bottom for preventing jamming of bottom shaft. The complete unit above the floor will be totally enclosed with hinged clean out and inspection doors.

## 2) Conveyor

A common conveyor is provided for collecting screenings from four mechanised fine screens and will drop the screening in a trolley type container kept at one end of the conveyor for taking out the screening for disposal. The conveyor will also cover manually cleaned screen channel. The screening from manual screens will be put on conveyor manually.

Each assembly of conveyor will consist of two pulleys with their shaft and bearings for driving the belt and idler pulleys for supporting the belt. The upper level idler pulleys will have three roll twenty degree roughing idlers. The bottom level idlers for belt return will be flat roll-type.

At the end of the belt drive, an adjustable scrapper is provided on the screening hopper for diverting the screening through hopper to the container

The belt material will be two - ply nylon or equivalent with 3 mm neoprene covering on carrying side and 0.75 mm neoprene covering on pulley side. The speed of the belt will be between 25 m to 30 m per minutes. The width of the belt will be 750 mm

The power transmission will be by means of TEFC motor coupled to the reduction gears. The gears will have service factor of 2.

The whole conveyor will be supported on steel structure over the screen channel.

## (3) Grit Chamber

Two grit chambers are provided for grit removal. It has a rotating grit scraping mechanism, adjustable influent deflector, reciprocating rake mechanism to remove the grit and organic return pump. The grit scraping mechanism shall have fixed bridge with rotating scrapper arms. The scrapper arms will have adjustable squeezes, which will scrap the grit to the grit sump. An overload alarm is provided. This arrangement will trip the machine in case of overload.

Suitable classifier mechanism along with the organic return pump will be provided. The reciprocating rake mechanism will lift the grit up. The reciprocating rake mechanism will be installed at about 35°

inclination. Chute is located at the top, through chute grit will fall to the ground/container, for further disposal. A grit cleaning arrangement is provided to remove organic particles from the grit and is pumped back to the inlet by an organic pump.

(4) Sludge Pumps

There will be two sludge pumping stations to pump out the sludge to sludge drying beds. Each sludge pumping station will have two pumps, one working and one standby. The required capacity of these pumps is 50 cum/hr so that sludge withdrawal from all reactors is completed during general shift of eight hours, with sufficient safety in operating time. The operating head of the pump will be 10.0 m. The sludge volume to be withdrawn from UASB reactors is approximately 563 cum/day.

The sludge pumps will be of centrifugal, non-clog submersible cavity type. The specifications are mentioned in the following table.

|    |                      |  |
|----|----------------------|--|
| 1  | Liquid               | Sludge   |
| 2  | Capacity             | 50 cum/hour  |
| 3  | Head                 | 10.0 m   |
| 4  | Solids size          | 40mm hard, incompressible<br>80mm soft, compressible |
| 5  | Temperature          | Ambient  |
| 6  | Specific gravity     | 1.1  |
| 7  | Installation type    | Fixed  |
| 8  | Casing material      | 2.0 - 2.5% Ni CI                                     |
| 9  | Impeller material    | CF 8M  |
| 10 | Motor body           | CI IS 210 Gr FG 260                                  |
| 11 | Seal cover           | CI IS 210 Gr FG 260                                  |
| 12 | Shaft                | AISI 410   |
| 13 | Guide pipe and chain | SS 304   |
| 14 | Top cover            | CI IS 210 Gr FG 260                                  |
| 15 | Motor rating         | 30 kW  |
| 16 | Motor RPM            | Less than 980  |
| 17 | Rated voltage        | 415 V  |
| 18 | Frequency            | 50 Hz  |

The pump will have automatic coupling arrangement at discharge end for removal and refixing of the pump from top. A guide pipe/wire rope will be provided for smooth removal and lowering of pumps.

(5) Floating Type Aerators

8 nos. of 50 HP aerators are provided in the first compartment of facultative type of aerated lagoon. The purpose of aeration is for removal of anerobicity of the effluent and also for removal of residual BOD and sulphides present in the effluent from UASB reactor. These aerators will be of slow speed. The aerators will have minimum capacity of 1.5 kg oxygen/kWh oxygen transfer under field condition. The aerator will be fabricated from mild steel sheets of not less than 3 mm. The aerators will be dynamically balanced. The gears will be helical-type with service factor not less than 2.

The motors will be with TEFC enclosure. The aerators will be sand/ball blasted and will be epoxy painted after applying zinc rich primer.

Aerator are provided with helical gear box with a service factor of 2, casing in horizontal split condition with integrally cast mounting blocks with casing to facilitate 150mm adjustment of aerator

cone in water. Also, aerators are provided with dry well arrangement on output shaft to make the output end of gear box leak proof.

Mounting studs with lock nuts and fasteners shall be in SS304

Rectangular/circular floats shall be in MS duly FRP coated with 4mm FRP lining thickness, hydraulically tested with mounting platform and handrails. The floats will be filled with polyurethane foam and will have ballast compartment at both ends to fill the ballast made up of RCC cubes to stabilise the floating aerator operation in water.

Mooring arrangement of nylon rope of sufficient length to secure floating aerator with RCC column shall be provided. Each float will be provided with lifting hooks and hooks for connecting mooring arrangement.

(6) Monorail Trolley and Chain Pulley Block

Monorail trolley and the chain pulley block will be provided for lifting of sludge pump. The trolley and the chain pulley block will be hand driven. The capacity of trolley and chain pulley block is 1 tonne, which is sufficient to remove complete pump set.

The trolley will be gear-less and will have four wheels to run on the lower flange of the rolled steel joist. The wheels will be of carbon steel casting. The trolley will have arrangement to fix the chain pulley block.

The chain pulley block will have spur type gears, load sheave, brake unit, hand chain wheel, loan chain wheel and hooks for suspension on monorail trolley and load.

(7) Biogas Holder

The biogas produced is to be utilised for power generation using fuel engine generator. The expected maximum gas generation will be about 1000 m<sup>3</sup>/day. The capacity of biogas holder is provided for its storage for 6 hrs of retention time. The generation will depend on ambient temperature. To have uniform supply of required gas for power generation a gasholder has been included. Provision has been made for flaring of gas if there is excess.

The gas produced in the UASB reactors is to be led to the gasholder through a moisture trap and gas flow meter. The tap-offs are provided after the gas pipe enters the gasholder, one going to the generator room for supply to dual fuel engines and the other to the gas flaring equipment.

The biogas holder will be of the wet type with a sealing of water. The biogas holder would be a RCC circular structure. The gas dome would be fabricated from mild steel plate having minimum 6 mm thickness. Guide rails embedded in RCC structure facilitate the vertical movement of the gas dome. The gas dome surface shall be coated with 350-micron thickness.

One pressure release valve will be provided at the top of the dome, which will open out when the level reaches 100% value. One high-level limit switch will be provided at 95% to give an audible alarm signal in the control room.

At low-level, say 20%, the running engines will be shut off and the biogas holder will be allowed to rise again. However, in case of heavy leakage, or otherwise, if the level goes to a very low level of say 5%, the vacuum breaking glass will break and will prevent the biogas holder from any damages due to vacuum condition.

(8) Chlorine Mixer

Mechanical chlorine mixers suitable for a tank of size of 7.5m x 7.5m x 2.5m SWD are required. These mixers shall comprise of a suitable reduction gear box of worm wheel type driven by a 5 HP motor. It shall have turbine type impeller in SS 304 with output speed of 36 RPM.


(9) Gas Scrubber Unit and Gas Blowers

The biogas produced from the reactors contains corrosive gas H<sub>2</sub>S at about 1% concentration and is at a very low pressuring (100 to 250 mm water column).

The biogas has to be supplied at 0.4 kg/sq.cm to the gas engine. H<sub>2</sub>S content in the biogas shall be less than 0.1%. Thus the biogas needs to be pressurised and H<sub>2</sub>S is to be reduced to less than 0.1%. The biogas consumption is about 135 cum/hr at full load. The gas scrubber and blower system is designed for 135 cum/hr.

First, H<sub>2</sub>S is removed in scrubber. In the scrubber, the H<sub>2</sub>S containing gas is contacted in counter current mode with a scrubbing liquid. Absorption of H<sub>2</sub>S occurs in the scrubber under certain specific conditions and a chemical reaction with metal ions takes place.

H<sub>2</sub>S when dissolved in aqueous medium is ionized to H<sup>+</sup> and S<sup>2-</sup>. The sulfur ions can be oxidized by polyvalent metal ions, such as those irons, which can exist in ferric (Fe<sup>3+</sup>) or Ferrous (Fe<sup>2+</sup>) form. When sulphide ion comes in contact with ferric ion, it is oxidized to elemental sulfur and gets precipitated. The ferric ion is in turn reduced to ferrous form. This reaction can be written as



The ferrous ions can later be oxidized to ferric ions by reaction with oxygen in the atmosphere air. The oxidation of ferrous ion can be written as



A root type blower has been considered to increase the pressure and since the engine may run at different times the biogas pressure is raised upto 1 kg/sq.cm and stored in a pressure vessel. The blower will operate on pressure switches and will be generally operated when biogas pressure in the pressure vessel drops below 0.6 kg/sq.cm and will stop as soon as the pressure develops to 1 kg/sq.cm. Since raising of gas pressure increases the temperature of the gas, an after cooler is provided. The cooling of the blower and after cooler will have cooling tower and cooling water pump.

(10) Biogas Flaring System

Gas flaring system will be installed to burn excess biogas generated at the STP. The burning capacity of the flare will be 250 cum/hr. The biogas flaring system will consist of the following:

- Moisture separator
- Flame arresters on pilot and main gas burner
- Non-return valve
- Pressure relief valve
- Flare gas burner (6m height from ground level)
- Pilot gas burner with push button ignition complete with ignition electrode
- Fusion plug

(11) Pure Gas Engine

1) Working Principal

A pure gas engine is has a conversion kit to run the engine with biogas. Gaseous fuel is added to the air, which is included at air intake manifold or before turbocharger. This mixture of air and gas is compressed in the cylinder just as air compressed in normal IC engine.

## 2) Components for Pure Gas Engines

- Gas engine
- Governor
- Direct coupling between alternator and the engine
- Air filtration
- All mountings shall be anti vibration type
- Gas train consisting of solenoid valve, regulator, low/high pressure switch, and filter
- All necessary safety measures
- Necessary accessories
- Alternator of required rating
- Fabrication of gas piping between regulator and gas control valve and air intake connection

The following aspects on auxiliary and utility system shall be taken into consideration for gas utilisation systems:

- Inlet air system,
- Filter or duplex filter to be located at an elevated position to prevent ingress of dust,
- Air inlet silencer, and
- All piping, ducting, supports, instrumentation and control.

## 3) Exhaust Gas System

Ducting with thickness 6mm, expansion joints upstream and down stream of turbocharger (if provided), silencer insulation etc. stack leading outside the building at safe height from ground level.

## 4) Safety Requirement

1. Anti vibration mounting for engine and alternators.
2. Enclosure ventilation/ cooling fans with drives.
3. Enclosure lighting
4. Inspection opening in the frame to permit easy inspection of the driving gear, lube oil pump, bearing etc.
5. Gas and fire detection system.
6. Explosion valve in DG room maintenance doors.
7. Crank case explosion relief valve.
8. Compression relief valve.

## 5) Cooling Water System

The cooling water system shall consist of the following:

1. Primary and secondary cooling water system (closed cycle) for engine cooling, lube oil cooling (if applicable) start up air compressor cooling (if applicable) etc.
2. For primary circuit, one CW pump shall be engine driven. During standby conditions, the engine jacket water shall be kept warm by means of thermostatically controlled electric heaters.

## (12) Fire Fighting

Suitable number of portable extinguishers CO<sub>2</sub> and dry powder type shall be provided for all pump house, gas engine room, electrical and control room at strategic locations as per Indian tariff, advisor committee rules/ NFPA standards.

(13) Maintenance of Crane/ Hoists

Composite hoist double girder electrically operated overhead crane shall be provided for gas engine room.

(14) Ventilation Fans

Suitable number of ventilation fans shall be provided in gas engine room.

(15) Lube Oil System

- Motor driven pre-lube pump
- Duplex lube oil filter.
- Oil mist pipe leading to atmosphere at safe height.
- Lube oil centrifuges if necessary.
- 

(16) Specific Requirements

1. All equipment and plant shall conform to the provision of statutory and other regulations in force in India and/ or in the state of Uttar Pradesh and local municipal authority such as Indian electricity act., Indian explosives act., Indian electricity rules, Environmental rules, obtaining of all permissions and approvals from the statutory authorities shall be the responsibility of the contractor.
2. All electrical and instruments in fuel gas and fuel oil system shall be flame proof/ intrinsically safe type/ increased safety type as per statutory rule prevailing in India.
3. All gas vent/ relief valve discharge shall be led to atmosphere at safe height.
4. Suitable drain and vents with valve shall be provided at lowest and highest points as per site layout.
5. All high temperature piping and ducting shall be insulated to keep outside surface temperature at 60°C (worst ambient temp).
6. Level switches shall be provided in gasholder for automatic operation of gas burners.
7. All gas vent line shall be provided with flame arrestor.
8. Cooling tower shall be provided for cooling and shall be designed for total load arising from charge air cooling, lube oil cooling and engine cooling, booster compressor and re-circulation gas compressor cooling (if applicable).
9. The power generation plant shall be designed so that quality of liquid effluent if any shall meet the requirement of IS :2490.
10. All controls (electrical/ pneumatic devices) have failed safe features with redundancy as per good engineering practice.
11. All atmospheric tanks shall be designed to IS:803 or equivalent.
12. All pressure vessels shall be designed as per ASME SEC-VIII or IS-2825 or equivalent.
13. Pure gas engine alternator shall be packaged skid mounted type.
14. Generator plant shall be continuously rated and shall be suitable for black start. In particular the engine set shall be capable of start-up and running without water supply system for a minimum period of three (3) minutes for achieving black start.
15. All pumps in power generation package shall have 50% or minimum one stand by.
16. Generator shall be able to start when room temperature is 4 deg cel.
17. All valves in fuel oil shall be of welded construction. All drain and vent valves in lube oil line shall be lockable type. Lube oil lines after filters upto bearings shall be of stainless steel. Oil cooler tubes shall be of stainless steel.

(17) Instrumentation and control

Each generator unit shall be provided with complete instrumentation and control system for safe and reliable operation. The standard instrumentation and control system shall include the following relay based control

1. Pressure and temperature gauge for lube oil, primary and secondary CW, fuel oil, fuel gas, inlet and outlet of engine, heat exchangers/ coolers, exhaust gas temp. outlet from cylinder and turbo charger (if applicable), pressure gauge for each pump discharge.
2. Gas flow meter inlet to engine.
3. Fault detectors with pressure and temperature switches for status indication, alarm and trip for high CW temperature, low lube oil pressure, high lube oil temp., high charge air temp. (if applicable) high and low fuel oil level in service tank, gas pressure low, low fuel oil pressure, makeup/ expansion water level low, pre lube oil pressure, high charge air temp., fire alarm, gas detection, air starting OK, vibration detection, over speed , over voltage , control air, pressure low, crankcase pressure abnormal starting fault, engine exhaust temperature - high and low etc.
4. Engine speed, running hour meter, watt meter etc,
5. Emergency stop-push button, auto manual selector switch.
6. Differential pressure gauge across lube oil and fuel oil strainer.
7. All tanks shall be provided with level gauge. Level switches shall be provided for fuel oil tanks.
8. Emergency shutdown provision acting on signal from gas detection equipment.
9. Thermostatic control in lube oil and CW system, charge air circuit by-pass shall be provided to control lube oil and jacket water temp.

(18)      **Layout**

Layout of the powerhouse shall be developed to ensure operability maintainability and conformity to good engineering practice and suitable for future expansion. Suitable lay down area shall be provided for maintenance in powerhouse at one end. Necessary statutory clearance shall be observed while locating HT equipment and fuel oil installation.

Suitable platforms, walkways, stairs and handrails shall be provided for access and walk space for operation. Separate electrical room annex in engine room shall be provided for housing electrical equipment and panels. Space for office shall be provided adjacent to electrical room.

Necessary access to all on base equipment i.e. lube oil console, fuel oil tanks, CW console etc. shall be provided. Space will be required for all heat exchangers.

Space provision in electrical equipment placement shall envisage safety clearances as per factory rules and IS rules as well as adequacy of same for maintenance, testing and data logging for panel boards, generators transformers and cabling.

### **6.1.3      Electrical & Instrumentation Works**

The electrical system design for STP is based on electrical load requirements, i.e. connected load and peak load for functional and lighting requirements in various areas of the plant. The basic equipments are aerators, coarse & fine screens, grit removal mechanism, sewage pumps, aerators, chlorine mixer, chlorination system, sludge pumps, air compressors system and gas scrubbers etc. The utilities are administrative building with laboratory, panel room, plant area lighting, staff quarters etc.

The power distribution system to the plant has been considered based on the peak load requirements and captive power available from pure gas engine.

From installation and operation point of view, two main load centres are proposed, one for TSPS and one for STP. The installations for TSPS have been discussed in the earlier section.

The STP shall have one outdoor substation for receiving power from UPSEB. The power from UPSEB metering panel shall be fed to HT vacuum circuit breaker (VCB) panel with outgoing transformer feeder. HP power from VCB panel shall be fed to the transformer installed in the same substation. One main electrical panel shall be installed in the electrical panel room.

One pure gas engine is proposed which shall be installed in the gas engine room. The power from pure gas engine panel shall be fed to aerators and other panels installed in a room near to the aeration tanks. This panel shall have two supplies, one from pure gas engine and other from local electric supply company - Uttar Pradesh State Electricity Board (UPSEB), which can be switched on in case of failure of the pure gas engine or insufficient availability of biogas. Power produced from pure gas engine will be supplied only to this panel (for aerators and chemical house & chlorination system load), as the generated power is sufficient only to take care of this load only. Since synchronising of captive generator and UPSEB's supply is not considered, as it is normally not permitted, interlocking provision is made between two supplies, so that only one supply can be put on at a time. The complete load of this load centre shall be generally on pure gas engine supply. In case of non-availability of pure gas engine power supply, this load centre shall be switched over to UPSEB power. The biogas produced from the reactors will be utilised for the pure gas engine.

The electrical system incorporates all safety requirements as per I.E. rules and all the components considered be as per relevant IS standards. The single line diagram, as enclosed, provides general requirements of various units of electrical distribution system.

The various equipments and panels considered at STP are :

- a) Main electrical panel
- b) Aerator and chlorine house panels
- c) Fine screen & grit chamber panel
- d) Compressor panel
- e) Gas scrubber panel
- f) Sludge pump panels
- g) Filtrate pump panels
- h) Main lighting panel
- i) Sub lighting panels
- j) Administrative block cum laboratory power distribution board
- k) Staff quarter power distribution board

(1) Power Supply

The electrical supply system for the STP will be as given hereunder:-

1) Normal Power Supply

UPSEB power for the TSPS & STP is proposed to get from the nearby UPSEB switchyard. It is presumed that power from the nearby UPSEB switchyard shall be released at 33kV by laying an overhead transmission line up to the TSPS site. Cost of this transmission line is covered under costing of TSPS. This power from the UPSEB metering panel to be installed at the point of supply in the TSPS, shall be received at the 33kV VCB panel proposed to feed 33kV power to TSPS as well as STP transformers.

In STP, 33 kV UPSEB power shall be fed from the main 33 kV VCB panel at TSPS. 33 kV power from this VCB panel at TSPS shall be transmitted to STP site by laying overhead transmission line. Power from transmission line shall be received at 33 kV outdoor isolator proposed to be installed near MEP room at STP. One 33 kV VCB panel shall be installed in MEP room which will receive power from outdoor isolator and will feed this power to transformers. Two numbers of transformers are

proposed for each STP. Each transformer shall be rated to run the entire plant load. Power stepped down to 0.433 kV shall be fed to MEP by laying 1.1 kV 3.5 core cable.

The entire plant will be operated on 415 V, 3-Phase, 50 c/s 3 wire/4 wire system for which, one main electrical panel will be provided. The variation in the voltage is considered as  $\pm 10\%$  and frequency as  $\pm 10\%$  and combined voltage and frequency variation  $\pm 3\%$ .

Power for entire plant equipments and utilities shall be distributed from this panel.

## 2) Gas Engine Supply

The proposed STP will have its own generation system utilising the produced biogas with pure gas engine. One pure gas engine is proposed in STP area, which shall be capable of taking the entire load of aeration and chlorine house panel.

Both the supplies will operate independently and no paralleling will be done at any time.

### **6.1.4 Utilities**

#### (1) Administration Building

Administrative block cum laboratory building of built-up area of 240 sqm is proposed at Panka STP. The proposed administrative block is a double storey structure. The laboratory is also provided in the same administrative building.

The laboratory along with rooms for plant manager and the supporting staff are provided in the administrative block. A storeroom for storing the chemicals and other materials is also provided. The office block is also equipped with a kitchen and sanitation facility.

#### (2) Laboratory

Laboratory for analysing the wastewater and sludge samples is proposed at the STP. It is located in the ground floor. The laboratory will be equipped with the required equipment so as to analyse the following parameters:

- pH,
- Bio-chemical oxygen demand (BOD),
- Chemical oxygen demand (COD),
- Total suspended solids (TSS),
- Total dissolved solids (TDS),
- Total solids (TS),
- Volatile suspended solids (VSS),
- Volatile fatty acids (VFA),
- Alkalinity,
- Sulphates,
- Sulphides,
- Nitrates,
- Sludge stability,
- Gases (CH<sub>4</sub>, H<sub>2</sub>S etc.)
- Fecal coliform count.

The working platforms in the laboratory are provided with glazed white tiles. Mosaic flooring is proposed in the laboratory. Sinks with water taps are proposed for cleaning of the glassware and other equipment. The list of laboratory equipment is presented in Table no. 6.4.

**Table 6.4 : List of Laboratory Apparatus and Equipment**

| Sr.      | Particular   | Nos.   |
|----------|--|--------|
| <b>A</b> | <b>Instrument</b>  |        |
| 1        | Oil free diaphragm type vacuum cum pressure pump   | 1      |
| 2        | Laboratory hot air oven  | 1      |
| 3        | Muffle furnace   | 1      |
| 4        | Digital fully automatic electronically controlled BOD incubator  | 1      |
| 5        | Electronically controlled incubator, 37 Degree Celsius   | 1      |
| 6        | Specific ion electrodes of Orion USA make, Model-901. 1. Cyanide, 2. Chromium, 3. Copper, 4. Arsenic, 5. Mercury, 6. Boron, 7. Manganese, 8. Nickel, 9. Lead, 10. Cadmium, 11. Sulphide, 12. Silver, 13. Selenium.           | 1 each |
| 7        | Autoclave (vertical) working pressure 5.2 lb.psi 750 x 500 mm with SS basket, inner chamber SS, 6 kW with pedal lifting, pressure and temperature gauges and water level indicator with insulated radial locking arrangement | 1      |
| 8        | COD apparatus with 6 hot plates  | 1      |
| 9        | Colony counter   | 1      |
| 10       | Gas analyzer for CH <sub>4</sub> , H <sub>2</sub> S  | 1      |
| 11       | UV-VS Spectrophotometer with personal computer   | 1      |
| 12       | Gas chromatograph with thermal detector  | 1      |
| 13       | Electron detector with printer, gas column   | 1      |
| 14       | Refrigerator   | 1      |
| 15       | Electronic single pan balance  | 1      |
| <b>B</b> | <b>Air conditioning for laboratory and office building</b>   |        |
| 1        | 1.5 tonne capacity room air conditioner  | 1      |
| 2        | Air cooler for office  | 3      |
| 3        | Personal computer and printer for data analysis and plant monitoring   | 2      |

(3) Water Supply

The STP is provided with water from the proposed tube well station. This tube well will also take care of the water requirement for the gardening, fire hydrant and other miscellaneous uses as well. The water distribution will be done by means of 100 mm AC pipes for the administrative and staff quarters. Hydrants with valves are provided for cleaning and flushing of the units. Sufficient residual pressure will be available for cleaning purposes.

(4) Waste Collection and Disposal

Liquid Wastes

Liquid waste, generated at within the STP premises, is storm water as well as the sewage from the utility of the STP. Open drains of 230 mm x 300 mm depth are provided to take care of the water logging at STP. Sanitation facilities are provided for the proposed administrative building and the staff quarters. The sewage from the administrative block and staff quarters will be discharged into the sump well of main pumping station within the STP premises.

Solid Wastes

The solid waste generated within the treatment plant will be from the following units:

Screen Chamber

Large amount of floating materials and other inert material like cloth, plastic, wood etc will be there in the raw sewage. Screens are used to stop these materials into the treatment plant units. Two screens, one of 12 mm clear opening alongwith 25 x 25 mm aluminum wire mesh is provided. The screenings collected will be transferred to the conveyor belt and thus into a chute. The screenings will be transported to the disposal site by means of trucks/trailers.

#### Grit Chambers

Grit will be removed from the grit chamber by mechanical means. The grit removed from the tank will be taken to the near by landfill sites by means of wheelbarrows.

#### Staff Quarters and Office Building

The domestic solid waste from the administrative building and the staff quarters will be collected in the dust bins. Staff quarters will be provided with masonry dust bins of 1.5 x 1.5 x 1.25m depth, at the place of transporting points. The waste, which arises by street sweepings, will be transferred to the transporting points. The solid waste from the transporting points will be transferred to the disposal site by means of trucks or trailers.

#### (5) Security Room

Security will be provided to guard against vandalism of the STP property. The security staff is provided with a room at the gate for giving shelter against the vagrancy of the nature. The shelter will be made of brick masonry with RCC roof. The shelter will have the necessary electrical and mechanical furnishings as deemed necessary.

#### (6) Staff Quarters

Staff quarter will be provided at the treatment plant site for the operating and maintenance staff. The costs for providing the same have been included in the cost estimates of the treatment plants. Based on the NRCD guidelines, staff quarters are provided only for the staff at the operating level.

**Table 6.5: Type and Size of Proposed Staff Quarters**

| Sr. | Designation                      | Type of Quarters | Plinth Area (sq.m) | Number of Quarters |
|-----|----------------------------------|------------------|--------------------|--------------------|
| 1   | Watchmen, gardeners and sweepers | A                | 34.2               | 4 (double storey)  |
| 2   | Chemist & operator               | B                | 45.6               | 7 (single storey)  |
| 3   | Junior engineer                  | C                | 62.7               | 1 (single storey)  |
| 4   | Sub-divisional engineer          | D                | 86                 | 1 (single storey)  |

#### (7) Internal Roads

The various units as well as facilities of the treatment plant are provided with a 4.0 meter wide asphalt road for comfortable movement of men and material within the plant premises. At places where vehicular traffic is not expected, particularly above underground/surface pipes or insufficient space for laying of roads, brick pavement having a width of 1.0 meter are proposed so that there is access from the 4.0 meter road to the destination.

(8) Plant Lighting

Sodium vapour lamps mounted on 9 m height steel/aluminium tubular pole are provided at every 30.0 m interval on the road for sufficient illumination and provide the treatment plant personnel with a smooth, glare and accident free environment due to bad illumination.

(9) Green Belt

There will be a green belt zone all around the treatment plant. The green belt will have various trees at every 20 meter interval, as they act as air purifiers. This will help in circumventing to some extent the odour problem in the eventuality of an improper operation of the treatment plant. Besides, a green belt will act as natural screen against the outside populace.

(10) Bypass Arrangement

A bypass arrangement has been considered for the STP in case of breakdowns. This is provided from downstream of grit chamber to downstream of UASB reactors. Here onwards, two different bypass arrangements shall be provided where one will connect to the facultative aerated lagoon and the other one will connect directly to the treated effluent channel.

## Appendix A 9.1

### SOIL ANALYSIS REPORT

| Sl. No. | Parameters / Tests   | La Martienierie Pumping Station / Power House | Cis Gombi Sewage Pumping Station | Mastemau site sample |
|---------|--|---|----------------------------------|----------------------|
|         |  | I   | II                               | III                  |
|         | <b>Physico-Chemical &amp; Metals</b>   |   |                                  |                      |
| 1.      | pH (Electrode method)  | 8.26  | 8.39                             | 9.81                 |
| 2.      | Conductivity <span style="float: right;">μS/cm</span>                                    | 228.0   | 79.0                             | 225.0                |
| 3.      | Moisture Content <span style="float: right;">%</span>                                    | 2.66  | 4.34                             | 20.0                 |
| 4.      | Bulk Density <span style="float: right;">g/c.cm</span>                                   | 1.32  | 1.22                             | 1.19                 |
| 5.      | Organic Carbon <span style="float: right;">%</span>                                      | 0.26  | 0.25                             | 0.19                 |
| 6.      | Chloride as Cl <sup>-</sup> (ILC) <span style="float: right;">μg/gm</span>               | 188.5   | 48.25                            | 60.15                |
| 7.      | Sulphate as SO <sub>4</sub> <sup>-2</sup> (ILC) <span style="float: right;">μg/gm</span> | 290.25  | 54.6                             | 97.4                 |
| 8.      | Nitrate as NO <sub>3</sub> (ILC) <span style="float: right;">μg/gm</span>                | 181.25  | 39.3                             | 38.1                 |
| 9.      | Fluoride (ILC) <span style="float: right;">μg/gm</span>                                  | 17.85   | 9.15                             | 12.87                |
| 10.     | Phosphate as P (ILC) <span style="float: right;">μg/gm</span>                            | 2.48  | 10.17                            | 1.97                 |
| 11.     | Iron as Fe (AAS) <span style="float: right;">μg/gm</span>                                | 22976.35                                      | 17307.5                          | 28348.8              |
| 12.     | Calcium as Ca (AAS) <span style="float: right;">μg/gm</span>                             | 3594.65                                       | 4284.65                          | 4994.65              |
| 13.     | Sodium as Na (ILC) <span style="float: right;">μg/gm</span>                              | 782.94  | 339.4                            | 1526.0               |
| 14.     | Potassium as K (ILC) <span style="float: right;">μg/gm</span>                            | 15.47   | 25.27                            | 14.5                 |

**Appendix A9.2**

**RESULTS OF PRIMARY GROUNDWATER SURVEY**

| Sr. No. | Sampling Point   | Date     | Color     | Odor     | pH   | Conductivity msm-1 | Hardness mg/l | Calcium mg/l | Turbidity NTU | Chloride NH <sub>3</sub> | Alkalinity mg/l | TDS mg/l |
|---------|--|----------|-----------|----------|------|--------------------|---------------|--------------|---------------|--------------------------|-----------------|----------|
| 1.      | Borewell water Mr. Hira Lal Yadav                          | 23.11.04 | Colorless | Odorless | 7.62 | 1.48               | 200.0         | 190.0        | 18.2          | 22.0                     | 292.0           | 154.0    |
| 2.      | Borewell water Mr. J.O. Sharma Farm                        | 23.11.04 | Colorless | Odorless | 7.72 | 0.77               | 190.0         | 170.0        | 20.0          | 55.0                     | 290.0           | 128.0    |
| 3.      | Martinpura borewell water UPPCL Power House                | 23.11.04 | Colorless | Odorless | 7.63 | 0.76               | 148.0         | 126.0        | 22.0          | 21.0                     | 384.0           | 112.0    |
| 4.      | Pipra Ghat Vasahat Near 2/2 Railway Phatak bore well water | 23.11.04 | Colorless | Odorless | 6.54 | 0.76               | 130.0         | 116.0        | 18.0          | 14.0                     | 408.0           | 122.0    |
| 5.      | Cis Gomti sewage pumping station borewell water            | 23.11.04 | Colorless | Odorless | 7.97 | 1.13               | 120.0         | 78.0         | 22.0          | 46.0                     | 400.0           | 148.0    |
| 6.      | Shri Ram Verma bore well water Sikandar Nagar              | 23.11.04 | Colorless | Odorless | 7.37 | 0.88               | 208.0         | 110.0        | 104.0         | 35.0                     | 418.0           | 133.0    |

### HEAVY METAL ANALYSIS

| Sr. No. | Sampling Point   | Date     | Copper mg/l | Chromium mg/l | Zinc mg/l | Lead mg/l | *Cadmium mg/l | *Iron mg/l |
|---------|--|----------|-------------|---------------|-----------|-----------|---------------|------------|
| 1.      | Borewell water Mr. Hira Lal Yadav                          | 23.11.04 | 0.02        | Nil           | 0.092     | Nil       | -             | -          |
| 2.      | Borewell water Mr. J.O. Sharma Farm                        | 23.11.04 | 0.13        | Nil           | 0.865     | Nil       | -             | -          |
| 3.      | Martimpura borewell water UPPCL Power House                | 23.11.04 | 0.16        | Nil           |           | Nil       | -             | -          |
| 4.      | Pipra Ghat Vasahat Near 2/2 Railway Phatak bore well water | 23.11.04 | 0.21        | Nil           | 0.454     | Nil       | -             | -          |
| 5.      | Cis Gomti sewage pumping station borewell water            | 23.11.04 | 0.24        | Nil           | 0.422     | Nil       | -             | -          |
| 6.      | Shri Ram Verma bore well water Sikandar Nagar              | 23.11.04 | 0.02        | Nil           | 0.704     | Nil       | -             | -          |

- Was not analysed due to problem in Lamp

**Appendix A9-3 List of Plot Owners at Proposed STP Site (Mastemau)**

| <b>Sr.</b> | <b>Gata No.</b> | <b>Area (ha)</b> | <b>Owner Name</b>            |
|------------|-----------------|------------------|------------------------------|
| 1          | 1               | 0.013            | Gaya Prasad etc.             |
| 2          | 2               | 0.076            | Ramkumar Shivkumar, etc.     |
| 3          | 3               | 0.307            | Gaya Prasad, etc             |
| 4          | 4               | 1.345            | N.P                          |
| 5          | 5               | 0.291            | Kamladevi, etc.              |
| 6          | 6               | 0.565            | Rambarose, etc               |
| 7          | 7               | 1.220            | Ramsevak, etc                |
| 8          | 8               | 0.721            | Dayaram Pardin, etc          |
| 9          | 9               | 0.679            | Rampal, etc                  |
| 10         | 10              | 0.354            | Gaya Prasad, etc             |
| 11         | 11              | 0.291            | Ishwardeep, etc.             |
| 12         | 12              | 0.714            | Ramavatar, etc               |
| 13         | 13              | 0.326            | Shravankumar, etc            |
| 14         | 14              | 0.329            | Manjupande, etc              |
| 15         | 15              | 0.253            | Jagatnarayan, etc            |
| 16         | 18              | 0.342            | Ramprasad, etc               |
| 17         | 19              | 0.141            | Thakurji Radhakrishna, etc   |
| 18         | 20              | 0.468            | Harishankar, etc             |
| 19         | 22              | 0.516            | Ramlakhan, etc               |
| 20         | 23              | 0.506            | Radhakrishna, etc            |
| 21         | 24              | 0.496            | Malilram Verma, etc          |
| 22         | 25              | 0.493            | Malilram Verma, etc          |
| 23         | 26              | 0.509            | Shravankumar, etc            |
| 24         | 27              | 0.114            | Shravankumar, etc            |
| 25         | 28              | 0.164            | Shravankumar, etc            |
| 26         | 29              | 0.506            | Sarochiskumar, etc.          |
| 27         | 30              | 0.114            | Ramadhar, etc                |
| 28         | 31              | 0.335            | Jagatnarayan, etc            |
| 29         | 32              | 0.269            | Ramesh Naresh, etc           |
| 30         | 33              | 0.474            | Bhanjar                      |
| 31         | 34              | 0.316            | Vinod Kumar Singh, etc.      |
| 32         | 35              | 0.360            | Ramdulal Munshilal, etc      |
| 33         | 36              | 1.024            | Dayashankar Ramdayal, etc.   |
| 34         | 37              | 0.506            | Vinod Kumar Singh, etc.      |
| 35         | 38              | 0.506            | Durgaprasad, etc.            |
| 36         | 39              | 0.139            | Ramsharan, etc               |
| 37         | 40              | 0.158            | Ramsharan, etc               |
| 38         | 41              | 0.135            | Anilkumar, etc               |
| 39         | 42              | 0.114            | Anilkumar, etc               |
| 40         | 43              | 0.297            | Radhakrishna, etc            |
| 41         | 44              | 0.211            | Maikulal, etc.               |
| 42         | 45              | 0.218            | Ramesh Rajesh Ramadevi, etc. |
| 43         | 46              | 0.347            | Sunil Kumar, etc.            |
| 44         | 47              | 0.202            | Sunil Kumar, etc.            |
| 45         | 48              | 0.329            | Ramgopal Paunchilal, etc.    |
| 46         | 49              | 0.076            | Navmilal, etc.               |
| 47         | 50              | 0.063            | Ramjanki Thakur, etc.        |
| 48         | 51              | 0.057            | Ramjanki Thakur, etc.        |
| 49         | 52              | 0.069            | Ramjanki Thakur, etc.        |
| 50         | 53              | 0.110            | Ramesh Rajesh Ramadevi, etc. |
| 51         | 54              | 0.417            | Sunil Kumar, etc.            |
| 52         | 55              | 0.193            | Rajankumar Misra, etc.       |
| 53         | 56              | 0.449            | Shambahadur Singh, etc       |
| 54         | 57              | 0.493            | Dayashankar Ramdayal, etc.   |
| 55         | 58              | 0.610            | Dayashankar Ramdayal, etc.   |
| 56         | 59              | 0.155            | Dayashankar Ramdayal, etc.   |

| <b>Sr.</b> | <b>Gata No.</b> | <b>Area (ha)</b> | <b>Owner Name</b>           |
|------------|-----------------|------------------|-----------------------------|
| 57         | 60              | 0.397            | Dayashankar Ramdayal, etc.  |
| 58         | 61              | 0.379            | Shivpal Mukesh Kumar, etc.  |
| 59         | 62              | 1.594            | Dayashankar Ramdayal, etc.  |
| 60         | 63              | 0.879            | Radheshyam Ramvilas, etc.   |
| 61         | 68              | 0.091            | Rampal, etc.                |
| 62         | 69              | 0.092            | Rampal Pujari, etc.         |
| 63         | 70              | 0.092            | Mahavir, etc.               |
| 64         | 71              | 0.093            | Gurudeep, etc.              |
| 65         | 73              | 0.177            | Ramjanki Thakur, etc.       |
| 66         | 75              | 0.020            | Nalla                       |
| 67         | 76              | 0.772            | Purvidin, etc.              |
| 68         | 77              | 1.096            | Manju Pandey, etc.          |
| 69         | 78              | 0.008            | Nalla                       |
| 70         | 79              | 0.350            | Banshilal Bihari, etc.      |
| 71         | 80              | 0.350            | Sunderlal Bihari, etc.      |
| 72         | 81              | 0.035            | Nalla                       |
| 73         | 82              | 0.380            | Shivshankar                 |
| 74         | 83              | 0.670            | Shivraj Roopchand, etc.     |
| 75         | 84              | 0.834            | Kalawati                    |
| 76         | 86              | 0.783            | Ramesh, Naresh              |
| 77         | 87              | 0.520            | Road                        |
| 78         | 88              | 0.783            | Ramadhar, etc.              |
| 79         | 89              | 0.532            | Ramsevak, etc.              |
| 80         | 90              | 0.212            | Shivpal Mukesh Kumar, etc.  |
| 81         | 91              | 0.691            | Jagatnarayan, etc.          |
| 82         | 92              | 0.055            | Road                        |
| 83         | 93              | 0.024            | Drain (Gram sabha)          |
| 84         | 94              | 0.514            | Nankau                      |
| 85         | 95              | 0.553            | Shivkumar Avasti, etc.      |
| 86         | 96              | 0.699            | Shivprasad, etc.            |
| 87         | 97              | 1.256            | Durgaprasad, etc.           |
| 88         | 98              | 0.573            | Babulal Mohanlal, etc.      |
| 89         | 99              | 0.633            | Pratap Yadav, etc.          |
| 90         | 100             | 0.019            | Chackmarg (Gram sabha)      |
| 91         | 101             | 0.017            | Drain (Gram sabha)          |
| 92         | 102             | 0.550            | Shri Radhakrishna Thakur    |
| 93         | 103             | 1.252            | Navipati, etc.              |
| 94         | 104             | 0.237            | Satayanarayan Lalaram, etc. |
| 95         | 105             | 0.253            | Ramnath, etc.               |
| 96         | 106             | 1.477            | Keshan Nanhe, etc.          |
| 97         | 107             | 0.005            | Drain (Gram sabha)          |
| 98         | 110             | 0.278            | Vijay Kumar / Sravan Kumar  |
| 99         | 111             | 0.240            | Jagatnarayan, etc.          |
| 100        | 112             | 0.253            | Sunil Kumar, etc.           |
| 101        | 113             | 0.088            | Nalla                       |
| 102        | 114             | 1.115            | Ramnath                     |
| 103        | 115             | 0.402            | Uma Dutt / Hanumant         |
| 104        | 116             | 0.221            | Kishore                     |
| 105        | 117             | 0.031            | Chackmarg (Gram sabha)      |
| 106        | 118             | 0.813            | lalu                        |
| 107        | 119             | 0.859            | Gaya Prasad                 |
| 108        | 120             | 0.021            | Nalla                       |
| 109        | 121             | 0.870            | Kalicharan                  |
| 110        | 122             | 0.781            | Ram Gulam / Munshi Lal etc. |
| 111        | 123             | 1.099            | Gaya Prasad                 |
| 112        | 124/1, 124/2    | 0.353, 0.354     | Umesh Kumar / Ashok Kumar   |
| 113        | 125             | 0.722            | Mayaram                     |
| 114        | 126             | 0.152            | Road                        |

| Sr.                     | Gata No.   | Area (ha)     | Owner Name  |
|-------------------------|------------|---------------|---|
| 115                     | 127        | 0.503         | Kuntlal, etc  |
| 116                     | 163        | 0.431         | Ram Charan  |
| 117                     | 207        | 0.020         | Nalla   |
| 118                     | 210        | 0.459         | Ram Janki/Thakurdwara Truct, Raghurai                       |
| 119                     | 211        | 0.038         | Navmilal, etc.  |
| 120                     | 213        | 0.147         | Road  |
| 121                     | 214        | 0.312         | Babadin   |
| 122                     | 215        | 0.443         | Gaya Prasad   |
| 123                     | 216        | 0.316         | Dayaram Nanhe, etc  |
| 124                     | 217        | 0.208         | Dayashankar Ramdayal, etc.                                  |
| 125                     | 218        | 0.350         | Dayashankar Ramdayal, etc.                                  |
| 126                     | 219        | 0.219         | Mansharam, etc.   |
| 127                     | 220        | 0.251         | Ramadhar  |
| 128                     | 221        | 0.010         | Nalla   |
| 129                     | 222        | 0.041         | Road  |
| 130                     | 223        | 0.347         | Ramgopal Rajeshkumar, etc.                                  |
| 131                     | 224        | 0.025         | Road  |
| 132                     | 225        | 0.347         | Ram Narayan   |
| 133                     | 226        | 0.061         | Kuldeep / Pradeep Kumar                                     |
| 134                     | 227        | 0.961         | Sripal / Satau etc.   |
| 135                     | 228        | 0.420         | Dayashankar Ramdayal, etc.                                  |
| 136                     | 229        | 0.506         | Puttilal / Shivraj  |
| 137                     | 279        | 6.552         | Tarai / Gram Panchayat                                      |
| 138                     | 100        | 0.022         | Main Road   |
| 139                     | 101        | 0.030         | Nalla   |
| 140                     | 107        | 0.043         | Nalla   |
| 141                     | 108        | 0.058         | Main Road   |
| 142                     | 109        | 0.038         | Road  |
| 143                     | 77         | 1.096         | Manjupande, etc   |
| 144                     | 86         | 0.783         | Ramesh Naresh, etc  |
| 145                     | 10./1207   | 1.265         | Ramgulam Munshilal, etc.                                    |
| <b>Village - Bakkas</b> |            |               |   |
| 146                     | 1          | 0.588         | Gomti River   |
| 147                     | 2          | 0.474         | Ram Bilas s/o Bhola etc.                                    |
| 148                     | 3/1, 3/2   | 0.101         | Smt Aparna Watal C/o 2- lakh                                |
| 149                     | 4          | 0.287         | Arjun Singh s/o Sitaram, etc., C. H. Singh s/o Sitaram, Jai |
| 150                     | 5          | 0.519         | Arjun Singh s/o Sitaram, etc., C. H. Singh s/o Sitaram, Jai |
| 151                     | 6          | 0.338         | Sarju Gajraj Shivprasad c/o Govind Raju Rajesh Rajjha       |
| 152                     | 7          | 0.259         | Pyaralal Ram Sanjivan Prem Madanlal Virendra c/o            |
| 153                     | 8          | 0.123         | Vikram Ramadhar, Smt. Ishwardevi                            |
| 154                     | 9          | 0.699         | Smt. Vishundevi w/o Babu                                    |
| 155                     | 10         | 0.253         | Sriram s/o Kallu  |
| 156                     | 11         | 0.531         | Cheda s/o Sushma  |
| 157                     | 13         | 0.506         | Rajeshwar kumar, Sunil Kumar, Ravimohan, Nirmaldevi,        |
| 158                     | 14         | 0.060         | Rajesh, etc.  |
| 159                     | 15         | 0.519         | Rajesh, etc.  |
| 160                     | 16/1, 16/2 | 0.117 , 1.379 | Shripal Chandrapal s/o Parikshit Hedakant, s/o Smt          |
| 161                     | 17         | 0.651         | Bhagwant Manoharlal   |
| 162                     | 18         | 0.439         | Tripal etc.   |
| 163                     | 19         | 0.481         | Arjun Singh, etc.   |
| 164                     | 20         | 0.341         | Vikram etc. s/o Baijnath                                    |
| 165                     | 21         | 0.379         | Smt. Vishundevi w/o Babu                                    |
| 166                     | 22         | 0.054         | Prem etc. Ramchandra Lalla                                  |
| 167                     | 23         | 0.506         | Natha Singh s/o Maikulal                                    |
| 168                     | 24         | 0.215         | Santlal etc. s/o Bhagwandas                                 |
| 169                     | 25         | 0.412         | Gomti Prasad s/o Jagdeo                                     |
| 170                     | 26         | 0.159         | Gomti Prasad. Etc.  |
| 171                     | 27         | 0.173         | Gomti Prasad. Etc.  |

| <b>Sr.</b> | <b>Gata No.</b>  | <b>Area (ha)</b>  | <b>Owner Name</b>                            |
|------------|------------------|-------------------|--|
| 172        | 28               | 0.142             | Ram kumar, etc.                              |
| 173        | 29               | 0.948             | Ram Sevak etc.                               |
| 174        | 30               | 0.114             | Ragunath Prasad, etc.                        |
| 175        | 31               | 0.477             | Ragunath Prasad, etc.                        |
| 176        | 32               | 0.417             | Rampal s/o Totaram                           |
| 177        | 33 - 1, 2, 3, 4  | 1.011             | Ram Chandra, etc.                            |
| 178        | 34               | 0.114             | Smr. Gauri etc.                              |
| 179        | 35               | 0.367             | Ram Sewak s/o Dheerandas, etc.               |
| 180        | 36               | 0.278             | Smt. Aparna Vatal                            |
| 181        | 37               | 0.699             | Ramnaresh, etc.                              |
| 182        | 38               | 0.095             | Nadi Gomti                                   |
| 183        | 39               | 0.531             | Ramkumar etc.                                |
| 184        | 40               | 0.357             | Rak Krupal, etc.                             |
| 185        | 41/1, 41/2       | 0.139, 0.284      | Pannalal, etc., Jayan Raman                  |
| 186        | 42               | 0.645             | Mahesh s/o Pyarelal, etc.                    |
| 187        | 43/1, 43/2       | 0.279, 0.280      | Saligram / Satyanarayan s/o Kallu            |
| 188        | 44               | 0.847             | Ramnaresh Raju Bahadur, s/o Mathura          |
| 189        | 45/1, 45/2, 45/3 | 0.170, 0.177, 0.1 | Shamlal s/o , Dheersingh, etc,               |
| 190        | 46               | 0.537             | Sukhdev, etc.                                |
| 191        | 47               | 0.531             | Mewalal, etc.                                |
| 192        | 48               | 0.563             | Arjun Singh, e tc.                           |
| 193        | 49               | 0.711             | Prem etc.                                    |
| 194        | 50               | 0.632             | Akbar, etc.                                  |
| 195        | 51               | 0.721             | Pareedi, etc.                                |
| 196        | 52               | 0.436             | Arjun Singh etc., Charan Singh, Jai Singh    |
| 197        | 53               | 0.664             | Arjun Singh etc., Charan Singh, Jai Singh    |
| 198        | 54               | 0.620             | Sarju, etc.                                  |
| 199        | 55               | 1.265             | Jagat Narayan, etc.                          |
| 200        | 56               | 0.537             | Keshav, etc                                  |
| 201        | 57               | 0.411             | Panna Lal s/o Cheda, etc.                    |
| 202        | 58               | 0.506             | Ramsevak, etc.                               |
| 203        | 59               | 0.771             | Smt. Shastridevi, etc.                       |
| 204        | 60               | 0.190             | Mahesh, etc.                                 |
| 205        | 61               | 0.196             | Ram Swaroop, etc.                            |
| 206        | 62/1, 62/2       | 0.717, 0.200      | Vikram etc, Ayodhya Prasad, Ganshyam Prasad. |
| 207        | 131              | 0.506             | Ramkumar etc.                                |
| 208        | 132              | 0.392             | Baba Jagmohandas, etc.                       |
| 209        | 133              | 0.357             | Baba Jagmohandas, etc.                       |
| 210        | 134              | 0.132             | Ramlal etc.                                  |
| 211        | 135              | 0.297             | Santram, etc                                 |
| 212        | 136              | 0.202             | Pyare, etc.                                  |
| 213        | 137              | 0.224             | Rahie, etc.                                  |
| 214        | 138              | 0.019             | Ram Kuvar Singh, etc.                        |
| 215        | 139              | 0.034             | Banjar                                       |
| 216        | 140              | 0.246             | Ram Kuvar Singh, etc.                        |
| 217        | 141              | 0.101             | Ram Kuvar Singh, etc.                        |
| 218        | 142              | 0.266             | Santram, etc                                 |
| 219        | 143              | 0.047             | Santram, etc                                 |
| 220        | 144              | 0.101             | Sripal, etc.                                 |
| 221        | 145              | 0.275             | Sripal, etc.                                 |
| 222        | 147              | 0.234             | Sripal, etc.                                 |
| 223        | 148              | 0.461             | Jungle                                       |
| 224        | 150              | 0.196             | Balram, etc.                                 |
| 225        | 151              | 0.231             | Jagat Narayan, etc.                          |
| 226        | 152              | 0.063             | Jungle                                       |
| 227        | 153              | 0.228             | Jagat Narayan, etc.                          |
| 228        | 154              | 0.405             | Bhagwan, etc.                                |
| 229        | 155              | 0.392             | Bhagwan, etc.                                |

| <b>Sr.</b> | <b>Gata No.</b> | <b>Area (ha)</b> | <b>Owner Name</b>                               |
|------------|-----------------|------------------|---|
| 230        | 156             | 0.016            | Bhagwan, etc.                                   |
| 231        | 157             | 0.237            | Rahie, etc.                                     |
| 232        | 158             | 0.341            | Rahie, etc.                                     |
| 233        | 159             | 0.319            | Prem etc.                                       |
| 234        | 160             | 0.063            | Bhangar   |
| 235        | 161             | 0.300            | Hulli   |
| 236        | 162             | 0.297            | Balram, etc.                                    |
| 237        | 163             | 0.006            | Balram, etc.                                    |
| 238        | 164             | 0.689            | Banjarlal, etc.                                 |
| 239        | 165             | 0.224            | Jagat Narayan, etc.                             |
| 240        | 166             | 0.009            |   |
| 241        | 167             | 0.711            | Santram, etc                                    |
| 242        | 168             | 0.044            |   |
| 243        | 169             | 0.461            | Ramlal, etc.                                    |
| 244        | 170             | 0.376            | Santram, etc                                    |
| 245        | 171             | 0.385            | Santram, etc                                    |
| 246        | 172             | 0.034            | Banjar  |
| 247        | 173             | 0.388            | Punvapi, etc.                                   |
| 248        | 174             | 0.272            | Balram, etc                                     |
| 249        | 175             | 0.044            | Kuvarlal, Pulchand, Ramnaresh, Kishore, Keshav. |
| 250        | 176             | 0.196            | Balram, etc                                     |
| 251        | 177             | 0.047            | Smt. Meena                                      |
| 252        | 178             | 0.367            | Kanayalal, Ramkilavat                           |
| 253        | 179             | 0.038            | Smt. Meenana                                    |
| 254        | 180             | 0.155            | Ramkumar  |
| 255        | 181             | 0.183            | Matadin Ramadan                                 |
| 256        | 182             | 0.420            | Ramsadan Molhe                                  |
| 257        | 183             | 0.436            | Sarju   |
| 258        | 184             | 0.847            | Ramnath Keshav                                  |
| 259        | 185             | 0.164            | Sriram, etc                                     |
| 260        | 186             | 0.272            | Sriram, etc                                     |
| 261        | 188             | 0.224            | Rambalak  |
| 262        | 189             | 0.443            | Smt. Meenana                                    |
| 263        | 190             | 0.028            | Smt. Meenana                                    |
| 264        | 191             | 0.410            | Abadi   |
| 265        | 192             | 0.051            | Bhagwan, etc.                                   |
| 266        | 193             | 0.173            | Bhagwan, etc.                                   |
| 267        | 194             | 0.082, 0.044     | Jungle  |
| 268        | 195             | 0.031            | Jungle  |
| 269        | 196             | 0.104            | Bhagwan, etc.                                   |
| 270        | 197             | 0.253            | Ramsharan, etc                                  |
| 271        | 198             | 0.142            | Ramsharan, etc                                  |
| 272        | 199             | 0.170            | Ramsharan, etc                                  |
| 273        | 200             | 0.443            | Rambalak  |
| 274        | 201             | 0.089            | Matadin Ramadan                                 |
| 275        | 202             | 0.101            | Matadin Ramadan                                 |
| 276        | 203             | 0.120            | Rampratap Ramdin                                |
| 277        | 204             | 0.224            | Prem etc.                                       |
| 278        | 205             | 0.132            | Prem etc.                                       |
| 279        | 207             | 0.360            | Ramvilas, etc.                                  |
| 280        | 208             | 0.237            | Ramvilas, etc.                                  |
| 281        | 209             | 0.177            | Santram, etc                                    |
| 282        | 210             | 0.132            | Rahie, etc.                                     |
| 283        | 211             | 0.190            | Ashakti and Ramrathi                            |
| 284        | 212             | 0.085            | Ashakti and Ramrathi                            |
| 285        | 213             | 0.006            | Ashakti and Ramrathi                            |
| 286        | 214             | 0.316            | Ramrathi Santoshkumar                           |
| 287        | 215             | 0.135            | Hariram Ramgulam                                |

*Final Report on Water Quality Management Plan for Ganga River  
Volume IV-1, Feasibility Study for Lucknow City, Part I, Sewerage Scheme*

| <b>Sr.</b> | <b>Gata No.</b> | <b>Area (ha)</b> | <b>Owner Name</b>              |
|------------|-----------------|------------------|--------------------------------|
| 288        | 216             | 0.076            | Ramnath                        |
| 289        | 217             | 0.051            | Ramnath                        |
| 290        | 218             | 0.089            | Paridhin                       |
| 291        | 219             | 0.183            | Ramnath                        |
| 292        | 220             | 0.388            | Banjar                         |
| 293        | 221             | 0.313            | Panalal, etc.                  |
| 294        | 222             | 0.259            | Munilal, etc.                  |
| 295        | 223/1, 223/2    | 0.557, 0.531     | Kurena, etc., Smt. Chandrakala |
| 296        | 224             | 0.550            | Smt. Neetaram                  |
| 297        | 225             | 0.228            | Kanayalal, etc.                |
| 298        | 226             | 0.388            | Shreekeshan                    |
| 299        | 227             | 0.370            | Smt. Meethana                  |
| 300        | 228             | 0.357            | Jagdev, etc.                   |
| 301        | 229             | 0.357            | Phulchand                      |
| 302        | 230             | 0.089            | Phulchand                      |
| 303        | 231             | 0.626            | Prem etc.                      |
| 304        | 232             | 0.135            | Ramvilas, etc.                 |
| 305        | 233/1, 233/2    | 0.117, 0.104     | Matadin Ramprasad Shobha       |
| 306        | 234             | 0.095            | Shobha                         |
| 307        | 235             | 0.095            | Premramchandra                 |
| 308        | 236             | 0.082            | Cheda, etc.                    |
| 309        | 237             | 0.164            | Lala, etc.                     |
| 310        | 238             | 0.057            | Lala, etc.                     |
| 311        | 239             | 0.109            | Lala, etc.                     |
| 312        | 240/1, 240/2    | 0.199, 0.338     | Deksha Aksh, Dubre Aksh        |
| 313        | 241             | 0.117            | Shobha                         |
| 314        | 242             | 0.120            | Smt. Meenana                   |
| 315        | 243             | 0.253            | Smt. Meenana                   |
| 316        | 244             | 0.082            | Jagatnarayan, etc.             |
| 317        | 245             | 0.120            | Smt. Meenana                   |
| 318        | 246             | 0.142            | Smt. Gauri, etc                |
| 319        | 247             | 0.269            | Smt. Gauri, etc                |
| 320        | 248             | 0.484            | Smt. Gauri, etc                |
| 321        | 249             | 0.107            | Ramvilas, etc.                 |
| 322        | 250             | 0.057            | Duber Gangaram                 |
| 323        | 251             | 0.069            | Ramvilas, etc.                 |
| 324        | 252             | 0.089            | Duber etc.                     |
| 325        | 253             | 0.196            | Smt. Gauridevi, etc.           |
| 326        | 254             | 0.069            | Smt. Gauridevi, etc.           |
| 327        | 255             | 0.120            | Jagatnarayan, etc.             |
| 328        | 256             | 0.139            | Jagatnarayan, etc.             |
| 329        | 257             | 0.329            | Virendrakumar, etc.            |
| 330        | 258             | 0.228            | Virendrakumar, etc.            |
| 331        | 259             | 0.019            | Virendrakumar, etc.            |
| 332        | 260             | 0.019            | Rakeshkumar                    |
| 333        | 261             | 0.044            | Rakeshkumar                    |
| 334        | 262             | 0.107            | Rakeshkumar                    |
| 335        | 263             | 0.095            | Virendrakumar, etc.            |
| 336        | 264             | 0.145            | Ramsharan,. Etc.               |
| 337        | 265             | 0.190            | Smt. Garui                     |
| 338        | 266             | 0.205            | Jagatnarayan, etc.             |
| 339        | 267/1, 267/2    | 0.490, 0.187     | Brijkumar, Hariprasad          |
| 340        | 268             | 0.123            | Shripal, etc                   |
| 341        | 269             | 0.626            | Hariprasad                     |
| 342        | 270             | 0.066            | Smt. Meethana                  |
| 343        | 271             | 0.044            | Smt. Meethana                  |
| 344        | 272             | 0.025            | Akbar, etc.                    |
| 345        | 273             | 0.114            | Jungle                         |

*Final Report on Water Quality Management Plan for Ganga River  
Volume IV-1, Feasibility Study for Lucknow City, Part I, Sewerage Scheme*

| <b>Sr.</b> | <b>Gata No.</b> | <b>Area (ha)</b> | <b>Owner Name</b>                     |
|------------|-----------------|------------------|---------------------------------------|
| 346        | 274             | 0.063            | Jagatnarayan, etc.                    |
| 347        | 275             | 0.066            | Akbar, etc.                           |
| 348        | 276             | 0.076            | Akbar, etc.                           |
| 349        | 277             | 0.104            | Prem, etc                             |
| 350        | 278             | 0.013            | Prem, etc                             |
| 351        | 279             | 0.101            | Prem, etc                             |
| 352        | 280             | 0.069            | Jagatnarayan, etc.                    |
| 353        | 281             | 1.075            | Ramkishore, Ramsuchin                 |
| 354        | 282             | 0.060            | Bhagrang, etc..                       |
| 355        | 283             | 0.072            | Bhagwant, etc.                        |
| 356        | 284             | 0.101            | Bhagwant, etc.                        |
| 357        | 285             | 0.006            | Bhagwant, etc.                        |
| 358        | 286             | 0.006            | Bhagwant, etc.                        |
| 359        | 287             | 0.066            | Bhagwant, etc.                        |
| 360        | 288             | 0.038            | Bhagwant, etc.                        |
| 361        | 289             | 0.085            | Bhagwant, etc.                        |
| 362        | 290             | 0.095            | Bhagwant, etc.                        |
| 363        | 291             | 0.234            | Jungle                                |
| 364        | 292             | 0.164            | Parideen etc.                         |
| 365        | 293             | 0.126            | Parideen etc.                         |
| 366        | 294             | 0.044            | Parideen etc.                         |
| 367        | 295             | 0.038            | Parideen etc.                         |
| 368        | 296             | 0.060            | Bajrang etc.                          |
| 369        | 297             | 0.076            | Bajrang etc.                          |
| 370        | 298             | 0.110            | Smt. Meenana                          |
| 371        | 299             | 0.089            | Chandra Pal, Rammilan, Kilash Bahadur |
| 372        | 300             | 0.145            | Jagdev, etc                           |
| 373        | 301             | 0.069            | Smt. Pithararamgopal                  |
| 374        | 302             | 0.063            | Hulli                                 |
| 375        | 303             | 0.076            | Smt. Pithara, etc.                    |
| 376        | 304             | 0.161            | Hulli                                 |
| 377        | 305             | 0.152            | Gram Panchayat                        |
| 378        | 306             | 0.038            | Gram Panchayat                        |
| 379        | 322             | 0.107            | Talaab                                |
| 380        | 323             | 0.414            | Mathuraprasad Gangadin Mahadev        |
| 381        | 324             | 0.734            | Prem, etc                             |
| 382        | 393             | 0.126            | Ram Vilas etc.                        |
| 383        | 394             | 0.070            | Ram Vilas etc.                        |
| 384        | 395             | 0.038            | Bhangar                               |
| 385        | 396             | 0.193            | Chandra Pal                           |
| 386        | 397             | 0.114            | Jaidev Prasad                         |
| 387        | 400             | 0.240            | Ram Vilas etc.                        |
| 388        | 401             | 0.321            | Baba Jagmohandas, Etc.                |
| 389        | 402             | 0.331            | Jaidev Prasad, etc.                   |
| 390        | 403             | 0.474            | Ramsharan, etc.                       |
| 391        | 404             | 0.342            | Punvasi, etc.                         |
| 392        | 405             | 0.382            | Pachprem, etc                         |
| 393        | 406             | 0.218            | Pachprem, etc                         |
| 394        | 407             | 0.461            | Balaram, etc                          |
| 395        | 408             | 0.297            | Santalal, etc.                        |
| 396        | 409             | 0.398            | Smt. Pithara, etc.                    |
| 397        | 410             | 0.481            | Duber, etc. Leela Bhanilal            |
| 398        | 411             | 0.162            | Asharfi etc. Ramvati                  |
| 399        | 412             | 0.079            | Ramkumar Radhashayam                  |
| 400        | 413             | 0.069            | Baba Jagmohandas,                     |
| 401        | 414             | 0.281            | Ram Kumar etc.                        |
| 402        | 415             | 0.016            | Ram Kumar etc.                        |
| 403        | 416             | 0.347            | Ram Kumar etc.                        |

| <b>Sr.</b> | <b>Gata No.</b> | <b>Area (ha)</b> | <b>Owner Name</b>                    |
|------------|-----------------|------------------|--------------------------------------|
| 404        | 417             | 0.202            | Ramjiavan                            |
| 405        | 418             | 0.145            | Ramjiavan                            |
| 406        | 419             | 0.417            | Smt. Meenana, etc                    |
| 407        | 420             | 0.316            | Ramlalan, etc,                       |
| 408        | 421             | 0.670            | Mewalal, etc                         |
| 409        | 422             | 0.426            | Kallu, etc.                          |
| 410        | 423             | 0.063            | Naseer                               |
| 411        | 424             | 0.249            | Rakesh Kumar, etc                    |
| 412        | 425             | 0.136            | Banjar                               |
| 413        | 426             | 0.253            | Pannalal etc.                        |
| 414        | 450             | 0.120            | Gram Panchayat                       |
| 415        | 459             | 0.287            | Hariram etc.                         |
| 416        | 460             | 0.246            | Jaya Narayan                         |
| 417        | 461             | 0.259            | Umar Pal etc. s/o Babulal, Kumbarpal |
| 418        | 462             | 0.259            | Umar Pal etc. s/o Babulal, Kumbarpal |
| 419        | 463             | 0.107            | Virendra Kumar etc.                  |
| 420        | 464             | 0.098            | Santaram                             |
| 421        | 465             | 0.098            | Naseer                               |
| 422        | 468             | 0.170            | Prem etc.                            |
| 423        | 469             | 0.196            | Nusrat Ali etc.                      |
| 424        | 476             | 0.322            | Naseer s/o Basheer                   |
| 425        | 477             | 0.120            | Abaadi, Nazool                       |
| 426        | 478             | 0.038            | Abaadi, Nazool                       |
| 427        | 479             | 0.069            | Abaadi, Nazool                       |
| 428        | 483             | 0.126            | Dhirkhaya, etc                       |
| 429        | 506             | 0.129            | Vikram, Kisun s/o Nanha              |
| 430        | 508             | 0.294            | Hariram etc.                         |
| 431        | 509             | 0.072            | Kumari Reena / Kurjan                |
| 432        | 510             | 0.177            | Kumari Reena / Kurjan                |
| 433        | 511             | 0.190            | Naushad                              |
| 434        | 512             | 0.215            | Naushad                              |
| 435        | 513             | 0.025            | Kumari Reena Kurjan                  |
| 436        | 514             | 0.076            | Pannalal s/o Chedda                  |
| 437        | 518             | 0.379            | Pannalal s/o Chedda                  |
| 438        | 519/1, 519/2    | 0.379            | Parideen s/o Maiku, Paridhi          |
| 439        |                 | 0.658            |                                      |