### THE DETAILED DESIGN STUDY OF THE RAILWAY ELECTRIFICATION AND DOUBLE-DOUBLE TRACKING OF JAVA MAIN LINE PROJECT IN INDONESIA



FINAL REPORT - DRAWINGS VOLUME X ■ BUILDING WORKS (6/6) (MECHANICAL DRAWINGS)

**MARCH 2005** 



**Pacific Consultants International** Japan Railway Technical Service



S D

CR(5)

05-11

Japan International Cooperation Agency (JICA)

Directorate General of Land Communications (DGLC)


Ministry of Communications

Government of the Republic of Indonesia

# THE DETAILED DESIGN STUDY OF THE RAILWAY ELECTRIFICATION AND DOUBLE-DOUBLE TRACKING OF JAVA MAIN LINE PROJECT IN INDONESIA

FINAL REPORT
DRAWINGS VOLUME X
BUILDING WORKS (6/6)
(MECHANICAL DRAWINGS)

**MARCH 2005** 



Pacific Consultants International Japan Railway Technical Service

## THE RAILWAY ELECTRIFICATION AND DOUBLE - DOUBLE TRACKING OF JAVA MAIN LINE PROJECT IN INDONESIA MECHANICAL DRAWING LIST

МО	DRAWING NO.	DRAWING TITLE	SCALE	
		STATIONS BUILDING		
		GENERAL STANDARD		
01	AM - 00 - 001	LEGEND & SYMBOL (1)	NTS	
02	AM 00 002	LEGEND & SYMBOL (2)	NTS	
03	AM - 00 - 003	ABBREVIATION	NTS	
04	AM - 00 - 004	EQUIPMENT SCHEDULE ( 1 )	NTS	
05	AM - 00 - 005	EQUIPMENT SCHEDULE (2)	NTS	
<b>06</b>	AM - 00 - 006	EQJIPMENT SCHEDULE (3)	NTS	
07	AM - 00 - 007	EQUIPMENT SCHEDULE (4)	NTS	
08	AM - 00 - 008	EQUIPMENT SCHEDULE ( 5 )	NTS	
09	AM - 00 - 009	EQUIPMENT SCHEDULE ( 6 )	NTS	
10	AM - 00 - 010	EQUIPMENT SCHEDULE (7)	NTS	
11	AM - 00 - 011	EQUIPMENT SCHEDULE (8)	NTS	
12	AM - 00 - 012	EQUIPMENT SCHEDULE (9)	NTS	
13	AM - 00 - 013	EQUIPMENT SCHEDULE ( 10 )	NTS	
14	AM - 00 - 014	EQUIPMENT SCHEDULE ( 11 )	NTS	
15	AM - 00 - 015	EQUIPMENT SCHEDULE ( 12 )	NTS	
16	AM - 00 - 016	STANDARD DETAIL ( 1 )	NTS	
17	AM - 00 - 017	STANDARD DETAIL (2)	NTS	
18	AM - 00 - 018	SEANDARD DETAIL (3)	NIS	
19	AM - 00 - 019		NTS	
20		STANDARD DETAIL ( 4 )		
	AM - 00 - 020	STANDARD DETAIL (5)	NTS	
21	AM - 00 - 021	STANDARD DETAIL (6)	NTS	
		MANGGARAI STATION		
22	AM - 01 - 001	SCHEMATIC DIAGRAM AC / VENTILATING AND PIPING SYSTEM	NTS	
23	AM - 01 - 002	PIPING GROUND FLOOR PLAN	1 : 600	
24	AM - 01 - 003	PIPING 1st FLOOR PLAN	1 : 400	
25	AM - 01 - 004	PIPING 2nd FLOOR PLAN	1:400	
26	AM - 01 - 005	AC AND VENTILATING 1st FLOOR PLAN	1:400	
27	AM - 01 - 006	TOILET DETAIL PLAN	1 : 100	
28	AM - 01 - 007	CHILLER AND PUMP ROOM LAYOUT	1:75 / 100	
		MATRAMAN STATION		
29	AM - 02 - 001	SCHEMATIC DIAGRAM AC / VENTILATING AND PIPING SYSTEM	NTS	
30	AM - 02 - 002	AC AND VENTILATING GROUND FLOOR PLAN	1 : 200	
31	AM - 02 - 003	PIPING GROUND FLOOR PLAN	1 : 200	
		JATINEGARA STATION		
32	AM - 03 - 001	SCHEMATIC DIAGRAM AC / VENTILATING AND PIPING SYSTEM	NTS	
33	AM - 03 - 002	AC / VENTILATING GROUND AND 1st FLOOR PLAN	1:800	
34	AM - 03 - 002	PIPING GROUND AND 1st FLOOR PLAN	1 : 800	
35	AM - 03 - 003	TOILET DETAIL PLAN	1:100	
36	AM - 03 - 005	CHILLER AND PUMP ROOM LAYOUT	1:75	
		KLENDER STATION	= =	
37	AM - 04 - 001	SCHEMATIC DIAGRAM AC / VENTILATING AND PIPING SYSTEM	NTS	
		( FOR KLENDER, BUARAN, KLENDER BARU, CAKUNG, KRANJI STA. )		
38	AM - 04 - 002	AC / VENTILATING GROUND AND 1st FLOOR PLAN	1 : 400	
		( FOR KLENDER, BUARAN, KLENDER BARU, CAKUNG, KRANJ: STA. )		
39	AM - 04 - 003	PIPING GROUND AND 1st FLOOR PLAN	1:400	
		( FOR KLENDER, BUARAN, KLENDER BARU, CAKUNG, KRANJI STA. )		
40	AM - 04 - 004	TOILET DETAIL PLAN	1 . 100	
		( FOR KLENDER, BUARAN, KLENDER BARU, CAKUNG, KRANJI STA. )		
41	AM - 04 - 005	PUMP ROOM LAYOUT	1 : 30	

NO	DRAWING NO.	DRAWING TITLE	SCALE
		BUARAN STATION	
42	AM - 05 - 001	AC / VENTILATING GROUND AND 1st FLOOR PLAN	1:400
43	AM - 05 - 002	PIPING GROUND AND 1st FLOOR PLAN	1 : 400
	7407 55 552		7 . 100
		KLENDER BARU STATION	
44	AM 06 001	AC / VENTILATING GROUND AND 1st FLOOR PLAN	1:400
45	AM - 06 - 002	PIPING GROUND AND 1st FLOOR PLAN	1:400
		CAKUNG STATION	
45	AM 07 001	AC / VENTILATING GROUND AND 1st FLOOR PLAN	1 : 500
46	AM - 07 - 001 AM - 07 - 002	PIPING GROUND AND 1St FLOOR PLAN	1 : 500
4/	AM - 07 - 1812	PIPING GROUND AND ISLEGON FLAN	1 . 500
		KRANJI STATION	
48	AM - 08 - 001	AC / VENTILATING GROUND AND 1st FLOOR PLAN	1 : 400
49	AM - 08 - 002	PIPING GROUND AND 1st FLOOR PLAN	1 : 400
50	AM - 09 - 001	BEKASI STATION  SCHEMATIC DIAGRAM AC / VENTILATING AND PIPING SYSTEM	NTS
51	AM - 09 - 002	AC / VENTILATING GROUND AND 1st FLOOR PLAN	1 600
· · · · · · · · · · · · · · · · · · ·		PIPING GROUND AND 1st FLOOR PLAN	
52	AM - 09 - 003		I : 600
53	AM - 09 - 004	TOILET DETAIL PLAN	1 : 100
54	AM - 09 - 005	CHILLER AND PUMP ROOV LAYOUT	1 : 50 / 75
	11 - 11 - 11		
**			
			_
	···-		
<b> </b>			<u>i</u>
<b> </b>			

The Railway Electrification and Double - double Tracking of Java Main Line Project



Note

This detailed design has been executed by a team of consultants as shown below in accordance with the agreement between Japan International Cooperation Agenccy (JICA) and JICA Study Feom.

The copyright of this drawing rests with JICA.

Designed by:

Japan International Cooperation Agency (JICA)

JICA Study Team:

Joint Venture of Pacific Consultants international and Japan Railway Technical Service

MECHANICAL

GENERAL

DATE 14/Jan/2005

Drawing Title:

LIST OF DRAWING

Scale: A3/NTS

#### THE RAILWAY ELECTRIFICATION AND DOUBLE - DOUBLE TRACKING OF JAVA MAIN LINE PROJECT IN INDONESIA **MECHANICAL DRAWING LIST**

О	DRAWING NO.	DRAWING TITLE	SCALE
		TRAIN OPERATION RELATED FACILITIES	
$\dashv$		ATIMECADA ODERATION CENTER	
04	AM - 22 - 000	JATINEGARA OPERATION CENTER PIPING SITE PLAN	1:1000
01 02	AM - 22 - 001	SCHEMATIC DIAGRAM PIPING SYSTEM	NTS
03	AM - 22 - 002	SCHEMATIC DIAGRAM AC AND VENTILATING SYSTEM	NTS
04	AM - 22 - 003	PIPING GROUND FLOOR PLAN	1:200
05	AM - 22 - 004	PIPING 1st FLOOR PLAN	1:200
06	AM - 22 - 005	PIPING 2nd FLOOR PLAN	1:200
07	AM - 22 - 006	PIPING 3rd FLOOR PLAN	1:200
08	AM - 22 - 007	AC AND VENTILATING GROUND FLOOR PLAN	1:200
09	AM - 22 - 008	AC AND VENTILATING 1st FLOOR PLAN	1:200
10	AM - 22 - 009	AC AND VENTILATING 2nd FLOOR PLAN	1:200
11	AM - 22 - 010	AC AND VENTILATING 3rd FLOOR PLAN	1:200
12	AM - 22 - 011	TOILET DETAIL PLAN	1:50
13	AM - 22 - 012	CHILLER AND PUMP ROOM LAYOUT	1:50
		SUBSTATION (BUARAN) & SIGNAL HUT (CAKUNG)	
14	AM - 23 - 01	AC/VENTILATING AND PIPING GROUND FLOOR PLAN	1:200/400
$\dashv$		SIGNAL CABIN	
15	AM - 24 - 01	AC/VENTILATING AND PIPING GROUND AND	1:250
		1st FLOOR PLAN	
-		TELECOM EQUIPMENT ROOM	
16	AM - 26 - 01	AC AND VENTILATING GROUND FLOOR PLAN	1:200
17	AM - 27 - 01	LEVEL CROSSING WATCHMAN SHED  AC/VENTILATING AND PIPING GROUND FLOOR PLAN	1:100
17	AWI-21-01	ACTVENDENTING AND FIFING GROUND FLOOR FEAT	1,100
		PLATFORM OPERATION OFFICE	
18	AM - 28 - 01	AC/VENTILATING AND PIPING GROUND FLOOR PLAN	1:100
		CIPINANG DEPOT	
19	AM - 29 - 001	PARTIAL PIPING PLAN 1	1:1000
20	AM - 29 - 002	PARTIAL PIPING PLAN 2	1:1000
21	AM - 29 - 003	PARTIAL PIPING PLAN 3	1:1000
22	AM - 29 - D04	PARTIAL PIPING PLAN 4	1 : 1000
23	AM - 29 - 005	SCHEMATIC WATER SUPPLY, FIRE HYDRANT AND	NTS
		DRAINAGE SYTEM	
24	AM - 29 - 006	PUMP ROOM LAY-OUT	1:100
		CIPINANG ADMINISTRATION BUILDING	
25	AM - 30 - 001	SCHEMATIC DIAGRAM PIPING	NTS
26	AM - 30 - 002	SCHEMATIC DIAGRAM AIR CONDITIONING AND	NTS
		VENTILATING	
27	AM - 30 - 003	P!PING GROUND FLOOR PLAN	1:200
28	AM - 30 - 004	PIPING † St. FLOOR PLAN	1;200
29	AM - 30 - 005	PIPING 2 nd FLOOR PLAN	1:200
30	AM - 30 - 006	AIR CONDITIONING GROUND FLOOR PLAN	t : 200
31	AM - 30 - 007	AIR CONDITIONING 1 st FLOOR PLAN	1:200
32	AM - 30 - 008	AIR CONDITIONING 2 nd FLOOR PLAN	1:200
33	AM - 30 - 009	TOILET DETAIL	1:75
34	AM - 30 - 010	CHILLER AND PUMP ROOM LAYOUT	1;50

Ю	DRAWING NO.	DRAWING TITLE	SCALE
		CIPINANG LOCO DAILY INSPECTION SHED AND	
		YARDMEN SUB ROOM	
35	AM - 31 - 001	AC & VENTILATING AND PIPING PLAN	1:300-1:200
_		CIPINANG MONTLY INSPECTION SHED	
36	AM - 32 - 901	AC & VENTILATING GROUND FLOOR AND 1st FLOOR PLAN	1 : 250
37	AM - 32 - 002	PIPING GROUND FLOOR & 1st FLOOR PLAN	1:250
		CIPINANG STATION AND SUBSTATION	
38	AM - 35 - 001	AC & VENTILATING AND PIPING PLAN	1 : 200
1		CIPINANG SIGNAL HUT AND MAIN SUBSTATION	
39	AM - 36 - 001	AC & VENTILATING AND PIPING PLAN	1 : 200
	w <u></u>	CIPINANG COACH CLEANING CONTRACTOR OFFICE &	
$\dashv$		CIPINANG COACH YARDMEN MAIN ROOM	
10	AM 90 704		1:250
40	AM - 39 - 001	AC & VENTILATING AND PIPING PLAN	1.200
		CIPINANG BRIDGE MAINT, OFFICE AND	
		BRIDGE MAINT SHED	
41	AM - 41 - 001	AC & VENTILATING AND PIPING PLAN	1:100
		CIPINANG SIGNAL CABIN	
40	AM - 43 - 001	AC & VENTILATING AND PIPING PLAN	1;200
42	Witt - 49 - (10)	CONTRACTION AND LITTLE LIPT	. , 200
		GATE HOUSE 1 AND 2	
43	AM - 44 - 001	AC & VENTILATING AND PIPING PLAN	1:100
	1 1 2 2 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3		<del>-</del>
	<del></del>		······································
	Ī		l

The Railway Electrification and Double - double Tracking of Java Main Line Project



This detailed design has been executed by a team of consultants as shown below in accordance with the agreement between Japan International Cooperation Agency (BCA) and JICA Study Team.

The copyright of this drawing rests with JICA.

Designed by:

Japan International Cooperation Agency (JICA)

JICA Study Team:

Joint Venture of Pacific Consultants International and Japan Railway Technical Service

MECHANICAL

GENERAL

DATE

/MARCH/2005

Drawing Title:

LIST OF DRAWING

Drawing No.:

AM - 00 - 000

#### LEGEND

SYMBOL	NAME	FROME CODE	SPECIFICATION	REMARKS
>1				
w	Water Supply	JIS G 3452	Galvanized Steel Pipe (Seamless)	Embeded in the wal
••	Pressure rizeed Water	ISO 4065	Polyethylene Pipe (PE100, S5 10Bar)	
•••	Water Pipe from Deep Well	ISO 4065	Polyethylene Pipe (PE100, S5-10Bar)	
M	Water Meter	ISO 4064B	Dry-Dial type Min. Reading 0,0001rn3	 ·
F Ø : B.T	Ball Float Valve		F.R.P. Ball	
WLV	Water Level Control Valve		w/Ball Float Valve	
WIC	Water Level Control	·	SST Bar or Mercury Float	
<u> </u>	Gate Valve		Out body steam (10 Bar, 16 Bar)	-
<del>o</del>	Gate Valve			
	Glove Valve		Out body steam (10 Bar, 16 Bar)	
	Glove Valve		ost body stodiii (75 Sai, 15 Sai,	
	Stop Valve		(10 Bar, 16 Bar)	
	Y - Type Strainer		(10 Bar, 16 Bar)	
	1 - Type Strumer		(10 Bur, 16 Bur)	<del></del>
#	Ball Float Check Valve		For discharged pipe for SMP.	
<del></del>	Flexible Joint		Stainless Steel Type	
——  <u>——  s</u>	Expontion Joint (Single)		Flanged connection	
	Expantion Joint (Double)		Flanged connection	
<u> </u>	Flexible Joint		2 Rubber Mountains Flanged Type	
<u> </u>	Swing Check Valve			
	Flanged Joint		(10 Bar, 16 Bar)	
	Isolation Flanged Connection			
CFV	Constant Flow Valve		Rubber or Spring type	
$\overline{\mathbf{g}}_{i}$	Wall Mounted Faucet			
¤,	Wall Mounted Faucet			
	(Long Nozzie)			
<b>D</b> ,	Counter Mounted Faucet			
$\mathbf{p}_{4}^{3}$	Water Faucet for External Spray			
<b>H</b>	Hot Water Faucet			
— Ř.	Single Lever Mixing Faucet			
$\overline{\mathfrak{p}}_{\scriptscriptstyle \mathrm{D}}^{\scriptscriptstyle \mathrm{S}}$	2 Handles Mixing Faucet			
<u> </u>	Flash Valve			
$\overline{\Delta}$				
<u>as</u>	Shower & Faucet No Branched Down Pipe			
	90° LL Elbow Flow			
	SO EL EIDOM FIOM			
>2	Pump			
	· · · · · · · · · · · · · · · · · · ·	NO 07450 555		
HWH	Supply Domestic Hot Water	JIS G3452 GSP		<u></u>
	Return Domestic Hot Water	JIS G3452 GSF		
EH	Electrical Water Heater			
GII <sub>S</sub>	Storaged Gas Water Heater			-
НС	Hood Cover			

#### LEGEND

SYMBOL	NAME	FROME CODE	SPECIFICATION	REMARKS
Ф50Л	50 mm dia of C.O.A			
Ф50В	50 mm dia of C.O.B			
<b>(b</b> )100	100 mm dia of C.O.C			
<b>2</b> 100	100 mm dia Dry Floor Drain			
<b>——</b> O100	100 mm dia Wet Floor Drain			
⊗	Sink Drain			
SD	Soil Drain Pipe	JIS K6741	(VP)	
К	Kitchen Drain Pipe	JIS K6741	(VP)	
	Concrete Pipe			
	Y type Fitting			
<del></del>				
` <b>`</b>	45' Fitting			
Ţt.	90" L.L. Fitting			
<u></u>			·	
	Clean Out on the Floor for			
	Every Floor			
	Rain Control Pit Made Concrete			
	With Concrete Cover			
	Rain Control Pit Made Concrete			
3-21	With Iron Cover			
	(W/Frome, Chain and Key Lock)			
	Inverted Control Pit Made			
	Concrete With Concrete Cover			
	Inverted Control Pit Made			
	Concrete With Iron Cover			
	(W/Frame, Chain and Key Lock)			
<u> </u>	Rain Control Pit Made Concrete			
	With Ductile Iron Cover			
	(W/Frame, Chain and Key Lock)			
X	Inverted Control Pit Made			
	Concrete With Ductile Iron			
	Cover			
	(W/Frame, Chain and Key Lock)			
GT	Grease Trap Made Concrete			
GI	Grease Trap Made Manufacture			
0.7	Gasoline / grease Trap			
	ousume / grease trap			
>3	Vent Pipe	NO MODAL	(/p)	
	<u> </u>	JIS K6741	(VP)	
<del></del> D\(\xi \)	Vent Cap		Alminum with powder baked colour	
	0.100		w/SST mesh	
				l

The Railway Electrification and Double - double Tracking of Java Main Line Project



This defailed design has been executed by a team of consultants as shown below in accordance with the agreement between Japan International Cooperation Agencay (JICA) and JICA Study Team.

The copyright of this drawing rests with JICA.

#### Designed by:

Japan International Cooperation Agency (JICA)

JICA Study Team:

Joint Venture of Pacific Consultants International and Japan Railway Technical Service

MECHANICAL

GENERAL

DATE 14/Jan/2004

#### Drawing Title:

LEGEND & SYMBOL (1)

AM - 00 - 001

A3/NTS

#### LEGEND

SYMBOL	NAME	FROME CODE	SPECIFICATION	REMARKS
PP	Pump - Up Pipe	JIS G3452	Galvanized Steel seamless pipe in the sump pit VP for out tank.	
XI	Fire Hydrant Pipe		SCH 40 (Seamless)	
хо	Fire Hydrant Pipe		SCH 40 (Seamless)	
	Hydrant Box inside Building		SST Hairline finishing	
P	Hydrant Box at External		SST Hairline finishing	
<b>⊬</b> D	Sigmese Connection		100x(65x2) with flame sst panel	
N.G —	Natural Gas Line		Seamless Galvanized Steel pipe	
L.G	Liquid Gas Line		Seamless Galvanized Steel pipe	
0.A	Out Door Air Duct		Galvanized Sheet	
SA	Supply Air Duct		Galvanized Sheet	
	Return Air Duct		Galvanized Sheet	
ExA	Exhaust Air Duct		Galvanized Sheet	
К.Ех	Kitchen Exhaust Air Duct		Galvanized Sheet	
	Refrigerant Pipes		Cooper Pipes	
c.s	Supply Chilled Water		Seamless Calvanized Steel pipe	
CR	Return Chilled Water		Seamless Galvanized Steel pipe	
[FCU]	Fan Coîl Unit (Floor Mounted)			
[FCU]	Fan Coil Unit (Ceiling Mounted)			
•	FCU's Remote Controller Switch			
•	Chiller's Remote Controller Switch			
)Ú	Square Type Air Outlet Deffuser		Alminum with power booked colour with chamber box	
X	Round Type Air Outlet Deffuser		Alminum with power booked colour with chamber box	
具	Breeze Line Type Deffuser		Alminum with power boaked colour with chamber box	
尸、	Slot Type Deffuser		Alminum with power boaked colour with chamber box	
9 💹 🌉	- Nuzzle Type Deffuser		Alminum with power boaked colour with chamber box	
VIIS	Vertical, Harizontal Slit type Deffuser		Alminum with power boaked colour with chamber box	
ns	Horizontal Slit Type Air In take Deffuser		Alminum with power booked colour with chamber box	
	Lauver on External Wall		w/SST Mesh	
	Lauver on External Wall		w/SST Mesh	
			:	
			İ	

#### LEGEND

SYMBOL	NAME	FROME CODE	SPECIFICATION	REMARKS
4				
ØP.G \$	Pressure Gauge w/cock			
文 c.g	Coumpound Gauge w/cock			
ØT.G	Thermo Gauge			
	2 Way Valve Unit		From CV valve	
	3 Way Valve Unit		From CV valve	
<u> </u>			<u> </u>	
			***************************************	
<del></del>				
***************************************		<u>:</u>		
		! !		
<del></del>				
				<u> </u>
				. =
·				:

The Railway Electrification and Double - double Tracking of Java Main Line Project



Note:

This detailed design has been executed by a fearm of consultants as shown below in accordance with the agreement between Jopan International Cooperation Agenccy (JICA) and JICA Study Team.

The copyright of this drawing rests with JICA,

Designed by:

Japan International Cooperation Agency (JICA)

JICA Study Team:

Joint Venture of Pacific Consultants International and Japan Railway Technical Service

MECHANICAL

GENERAL

DATE 14/Jan/2004

Drawing Title:

LEGEND & SYMBOL (2)

Scale: Drawing No.: A3/ N | S AM - 00 - 002

#### **ABBREVIATION**

OUT LINE	OFFICIAL	OUT LINE	OFFICIAL	OUT LINE	OFFICIAL	OUT LINE	OFFICIAL	OUT LINE	OFFICIAL
GENER	AL	1		MECHANI	CAL WORKS	,		1	
Α	Ampere	Max	Maximum	Ø	Mili Meter Dia or Phase of	E.P	Engine Pump	RH	Relative Humidity
AG.	Aluminium Grille	MECH	Mechanical	,	Electrical	Ex. T	Expansion Tank	RPM(rpm)	Revolutions per minute
APX	Approximately	MFR	Manufacture	ACWC	Air Cooled Water Chiller Unit	F.C.C	Ceiling Mounted Fan Coil Unit	RV	Reducing Valve
B.M	Bench Mark	MH	Man Hole	ACC	Ceilingmounted Separated	F.C.F	Floor Mounted Fan Coil Unit	S.A	Supply Air
B.O.P	Bottom of Pipe	Min	Minimum		Air Conditioner	F.D	Floor Dry	S.A.D	Supply Air Duct
в.Р.	Booster Pump Unit	MIR	Mirror	ACCE	Ceiling Exposed Suspended	F.D.M	Fire Damper	SC	Siamese Connection
C.H	Ceiling Hight	MM (mm)	Mili Meter		Air Conditioner	F.E.P	Fire Extingushed Pump	SD	Soil Drain Pipe
C.F	Ceiling Fan / Blade Type	ΜT	Male Toilet	ACO -	Outdoor Unit For ACC / ACCE Unit	F.J	Flexible Joint	SF	Supply Air Fan
C.O.P	Center of Pipe	N	North	ACW	Wallmounted Separate Air	F.P	Fire Pillar	SMP	Submarsible Pump
D	Depth	No	Number		Conditioner	F.V.D	Fire Volume Controled Damper	SP	Static Pressure
DM	Dimension	O.D	Out Side Diameter	ACO	Outdoor Unit For ACW Unit	G.T	Grease Trap	ST	Septic Tank
DS	Duct shaft		Pipe Shaft	ARV	Air Released Valve	G.V	Gate Valve	STS	Y - Type Strainer
DWG	Drawing		Public	В.Т	Ball Float Valve	GLV	Glove Valve	STV	Stop Valve
E	East		Room	BCV	Ball Float Check Valve	O.H.B.	Outdoor Hydrant Box	SV	Solenoid Valve
EL	Elevation		Return Air Grill	C.C	Concrete Cover for Pit	I.H.B.	Indoor Hydrant Box	SWP	Spring Well Pump
EMER	Emergency		Roof Drain	C.H.W.P	Chilled Water Circulation Pump	H.C	Hood Cover	T.G	Thermo Gauge
EPS	Electrical Pipe Shaft		Reffrigerant Pipe	C.D	Check Damper	H.C.P	Hot Water Circulation Pump	V	Vent Pipe For Soil/Waste Pipe
EQ (eq)	Equal		Required	CFV	Constant Flow Valve	H.D	Hood	V.D	Volume Control Damper
ESC	Escalator		Roof	C.I.D	Ductile Iron Cover for Pit	H.W.R	Domestic Hot Water Return	W	Water Supply
F.D	Floor Drain	RND	Round	C.G	Compound Gauge	H.W.S	Domestic Hot Water Supply	ws	Washing Water
F,E	Fire Extinguisher		South	C.H	Heavy Duty Ductile Iron Cover	H.E.X.F	Heat Exchanged Exhaust Fan	W.B	Wet Bulb
F.E.C	Fire Extinguisher Cab		Siamese Connection		for Pit	I.P	Incinerator Plant	W.L.	Water Level
F.F.L	Standard Floor Level	S/STA	Sub. Station	C.I	Iron Cover for Pit	I.W	Incoming Water Pipe from	W.L.C	Water Level Control Sensor
F.L	Floor Line	SG	Steel Grille	CP (I)	Control Pit of Soil and Waste		Outside Border Line	W.L.V	Water Level Controll Valve
F.O.C	Face of Concrete	SHT	Sheet	CP (R)	Control Pit of Rain	J.P	Jockey Pump		For Water Receiver Tank
F.Q.F	Face of Finishing	SK	Sink	CPH	(m3/hr) (Cubic Meter per Hour)	К	Kitchen Drain Pipe	W.M	Water Meter
F.T	Female Toilet	SPEC	Specification	CTP	Combination Treatment Plant	K.Ex	Kitchen Exchaust Air	W.R.	Water Reservoir
GALV	Galvanized	SST	Stainless Steel	CV	Check Valve	K.P.H	Kilocalorie per hours (Kcal/hr)	W.T	Water Receiver Tank
GASK	Gasket	STD	Standard	CD	Condencing Drain	L	Louver	W.T.U.	Waste Treatment Unit
GEN	General	STL.	Steel	COA	Clean - Out on Dry Floor	L.G	Liquid Gas Line	X.I	Fire Hydrant Pipe In Home
GL	Glass		Switch	COB	Clean - Out on Wet Floor	LL	Large 90 degree Angle Type	X.O	Fire Hydrant Pipe At External
GLL	Ground Level Line	T	Ton	coc	Clean - Out in The Ceiling		Fitting	ОС	Celcius
GRL	Grille	TEL	Telephone	CHWR	Return Chilled Water Pipe	LPM	Litter per Minutes (i/min)		
HOR	Horizontal	Tk	Thickness	CHWS	Supply Chilled Water Pipe	NC	Normally Closed		
HR (hr)	Hour	TRD	Thread	DB	Dry Bulb	NG	Natural Gas Line		
HT (h)	Height	TV	Television	DP	Distribution Pump For	NO	Normally Open		
I.Đ	Inside Diameter	TYP	Typical		Potable Water	O.A	Outdoor Air		
IND	Industrial	UG	Under Ground	DWP	Deep Well Pump	O.A.D	Outdoor Air Duct		
INFO	Information	UR	Urinal	E.A	Exhaust Air	O.A.F	Outdoor Intake Fan		
INSP	Inspection	V	Volt	E.D	Exhaust Duct	O.T	Oil Gasoline Trap		
INSU	Insulation	w	West	E.F	Exhaust Air Fan	P,D	Pump - Up Drain Pipe		
Kg	Kilo gram		Widht(mm) x Heigh(mm)	E.H	Electrical Heater	P.G	Pressure Gauge		
kW	Kilo Watt		x Length (mm)	E.H.S	Storaged Electrical Heater	P.R.V	Pressure Released Valve		
M	Meter		Water Closet	1	J	P.T	Pit		
-		WT	Weight			R	Rain Drain Pipe		

The Railway Electrification and Double - double Tracking of Java Main Line Project



This detailed design has been executed by a team of consultants as shown below in accordance with the agreement between Japan International Cooperation Agenccy (JICA) and JICA Study Team.

The copyright of this drawing rests with JICA.

Designed by:

Japan International Cooperation Agency (JICA)

JICA Study Team:

Joint Venture of Pacific Consultants International and Japan Railway Technical Service

MECHANICAL

GENERAL

DATE 14/Jan/2004

Drawing Title:

**ABBREVIATION** 

Scale: Drawing No.: A3/ N T S AM - 00 - 003

#### EQUIPMENT SCHEDULE LIST (1)

Equipment Legend	Description	QTY	SPECIFICATION	REMARKS
ACWC - 1	AIR - COOLED		Cooling Capacity : 219.000 w	
ACTIO - 1	WATER CHILLER UNIT	-	Chilled Water Temperatur : 12°C ( inlet ), 7°C ( outlet )	
			Chilled Water Flow Rate : 571 Liter/ min	
	For Cipinang Administrasi Builiding	1	Circulation Pump : 80 dia x 285 Liter / min x 20 m H	
	Station Office Zone ( A )	- '	x 2.2 kw x 3 sets (1 stanby) pararel/ alternate opert.	
			Compressor : 2 sets	
		•	Condenser Fan : 2 sets x 1.0 kw	
			Acessories : Packaged Type Air Cooled Water Chiller Unit	
<del></del>			Controller	
			Interlocked Wiring Remote Controller and Inverter units,	
			Include : 3 way valves, fans and others, anti vibration rubbers,	
			anchore bolts.	
			Reinforced Concrete Base : 300 H	
ACWC - 2	AIR - COOLED	1	Cooling Capacity : 180,000 w	
	WATER CHILLER UNIT		Chilled Water Temperatur : 12°C ( inlet ), 7°C ( outlet )	
	For Jatinegara Operation Center		Chilled Water Flow Rate : 516 Liter/ min	
	Station Office Zone ( A )	1	Circulation Pump : 80 dia x 258 Liter / min x 20 m H	
			x 2.1 kw x 3 sets (1 stanby ) pararel/ alternate opert.	
			Compressor : 1 sets	
			Condenser Fan : 2 sets x 1.0 kw	
			Acessories : Packaged Type Air Cooled Water Chiller Unit	
			Controller	
			Interlocked Wiring Remote Controller and Inverter units,	
			Include : 3 way valves, fans and others, anti vibration rubbers,	
			anchore botts.	
			Reinforced Concrete Base : 300 H	
ACWC - 3	AIR - COOLED		Cooling Capacity : 118.000 w	
	WATER CHILLER UNIT		Chilled Water Temperatur : 12°C (inlet), 7°C (outlet)	
	For Jatinegara Operation Center	-	Chilled Water Flow Rate : 516 Liter/ min	
	- Station Office Zone ( D )	1	Circulation Pump : 80 dia x 258 Liter / min x 20 m H	
			x 2.1 kw x 3 sets (1 stanby ) pararel/ alternate opert.	
			Compressor : 1 sets	
			Condenser Fan : 2 sets x 1.0 kw	
			Acessories : Packaged Type Air Cooled Water Chiller Unit	
	•		Controller	
			Interlocked Wiring Remote Controller and Inverter units,	
			Include : 3 way valves, fans and others, anti vibration rubbers	
			anchore bolts.	
			Reinforced Concrete Base : 300 H	
ACWC - 4	AIR - COOLED		Cooling Capacity : 106.000 W	
	WATER CHILLER UNIT		Chilled Water Temperatur : 12°C (inlet), 7°C (outlet)	
	For Manggarai Station		Chilled Water Flow Rate : 215 Liter/ min	
	- Station Office Zone ( A )	1	Circulation Pump : 65 dia x 110 liter/ m x 20 m H	
			x 1.5 kw x 3 sets pararel/ alternate opert.	
	1		Compressor : 1 sets	

Equipment Legend	Description	QTY	SPECIFICATION	REMARKS
			Condenser Fan : 2 sets x 1.0 kw	
			Acessories : Packaged Type Air Cooled Water Chiller Unit	
			Controller	
			Interlocked Wiring Remote Controller and Inverter units,	
			include : 3 way valves, fans and others, anti vibration rubbers,	
			anchore bolts.	
<del></del>		+	Reinforced Concrete Base : 300 H	
		+		
ACWC - 5	AIR - COOLED	-	Cooling Capacity : 67.000 W	
	WATER CHILLER UNIT		Chillied Water Temperatur : 12°C (inlet), 7°C (outlet)	
	For Jatinegara Operation Center		Chilled Water Flow Rate : 192-215 Liter/ min	
	Station Office Zone (.C.)	1	Circulation Pump : 65 dia x 192 Liter / min x 20 m H	
	\ - 1		x 1.5 kw x 2 sets (1 stanby)	
			Compressor :2 sets	
			Condenser Fan : 2 sets x 0.215 kw	
			Acessories : Packaged Type Air Cooled Water Chiller Unit	
			Controller	İ
			Interlocked Wiring Remote Controller and Inverter units,	
• •		<del> </del>	include : 3 way valves, fans and others, anti vibration rubbers,	
		-	anchore boits.	
		+	Reinforced Concrete Base : 300 H	
		-		
ACWC - 6	AIR - COOLED	<u> </u>	Cooling Capacity : 56.000 W	
<b>~_</b>	WATER CHILLER UNIT		Chilled Water Temperatur : 12°C ( inlet ), 7°C ( outlet )	
	For Jatinegara Operation Center		Chilled Water Flow Rate : 161 Liter/ min	
	Station Office Zone (B)	1	Circulation Pump : 65 dia x 161 Liter / min x 20 m H	
******	For Manggarai Station		x 1.5 kw x 2 sets (1 stanby)	
	Station Office Zone ( B )	1	Compressor : 2 sets	
	For Bekasi Station		Condenser Fan : 2 sets x 0.215 kw	
	Station Office Zone ( A )	1	Accessories : Packaged Type Air Cooled Water Chiller Unit	
		+	Controller	
			Interlocked Wiring Remote Controller and Inverter units,	
			Include : 3 way valves, fans and others, anti vibration rubbers,	
			anchore botts.	
			Reinforced Concrete Base : 300 H	<del>                                     </del>
		+		
ACWC - 7	AIR - COOLED	+	Cooling Capacity : 45.380 W	
	WATER CHILLER UNIT		Chilled Water Temperatur : 12°C ( inlet ), 7°C ( outlet )	
	For Jatinegara Station	1	Chilled Water Flow Rate : 129 Liter/ min	
	- Station Office Zone (A)	1	Circulation Pump : 50 dia x 129 Liter / min x 20 m H	
		+	x 1.25 kw x 2 sets (1 stanby)	<del>                                     </del>
			Compressor : 3 sets	
		-	Condenser Fan : 2 sets x 0.215 kw	<del>!</del> :
			Acessories : Packaged Type Air Cooled Water Chiller Unit	<u> </u>
			Controller	
*****		-		
			Interlocked Wiring Remote Controller and Inverter units,	<u>!</u> 
			Include : 3 way valves, fans and others, anti vibration rubbers,	
			anchore bolts.	
			Reinforced Concrete Base: 300 H	I

The Railway Electrification and Double - double Tracking of Java Main Line Project



Note:

This detailed design has been executed by a feam of consultants as shown below in accordance with the agreement between Japon international Cooperation Agency (JICA) and JICA Study Team.

The copyright of this drawing rests with JICA.

Designed by:

Japan International Cooperation Agency (JICA)

JICA Study Team:

Joint Venture of Pacific Consultants International and Japan Railway Technical Service

MECHANICAL

GENERAL

DATE 14/Jan/2005

Drawing Title:

EQUIPMENT SCHEDULE ( 1 )

Scale: A3 / NTS

#### EQUIPMENT SCHEDULE LIST ( 2 )

Equipment Legend	Description	QTY	SPECIFICATION	REMARKS
ACWC - 8	AIR - COOLED		Cooling Capacity : 17.000 W	
	WATER CHILLER UNIT		Chilled Water Temperatur : 12°C ( inlet ), 7°C ( outlet )	
	For Bekasi Station		Chilled Water Flow Rate : 49 Liter/ min	
	Office Zone (A)	1	Circulation Pump : 40 dia x 49 Liter / min x 20 m H	
	For Manggarai Station		x 0.75 kw x 2 sets (1 stanby)	
	Office Zone ( C )	1	Compressor : 1 sets	
			Condenser Fan : 2 sets x 0.215 kw	
			Acessories : Packaged Type Air Cooled Water Chiller Unit	
			Controller	
<u> </u>			Interlocked Wiring Remote Controller and Inverter units,	
			include : 3 way valves, fans and others, anti vibration rubbe	rs,
			anchore bolts.	
			Reinforced Concrete Base : 300 H	
ACP - 1	AIR - COOLED		Cooling Capacity : 10.800 w	n e a commente de la Marce Nation
	WATER CHILLER UNIT		Power Consumption : 3.48 w	**************************************
	For Jatinegara Operation Center		Air Flow Rate : 1060 Cfm	
	Special Dispatcher Equipment	1	Static Pressure : 69 Pa	
	Shoote Subtractor Edubutour	<u>'</u>	Completed with indoor and ducting and insulated	
			Supply Air Grill : Stot Linier type	:
			. Sist Entrol 1995	
FCU - 1	FAN COIL UNIT IN CEILING		Cooling Capacity : 7.940 kcal/h ( 9.234 w )	İ
T-CO - 1	MOUNTED		Power Consumption : 63 x 2 watt	
		4	Chilled Water Flow Rate : 23.7 Liter/ min	
	For Manggarai Station		Air Flow Rate : 1200 cfm	
			Fan Speed Controller w/ embeded Switch Box	
			Pail Speed Collitolies W Gillbeded Swilds DOX	
FCU - 2	FAN COIL UNIT IN CEILING		Cooling Capacity : 6.060 kcal/h (7.047 w )	
	MOUNTED		Power Consumption : 105 watt	
	For JATINEGARA OPERATION CENTER	16	Chilled Water Flow Rate : 18.1 Liter/ min	
	TO SATINEGARA OF ERATION CENTER		Air Flow Rate : 800 cfm	
			Fan Speed Controller w/ embeded Switch Box	
			Resin Nett Filter, Insulated Drain Pan	1
			Noom Nett Hitel, moulated Dram Fair	
FCU - 3	FAN COIL UNIT IN CEILING		Cooling Capacity : 5.530 kcal/h ( 6.431 w )	
100-3			Power Consumption : 105 watt	
	MOUNTED	10	Chilled Water Flow Rate : 21.1 Liter/ min	
	For JATINEGARA OPERATION CENTER	16		
	For MANGGARAI STATION	16		
			Fan Speed Controller w/ embeded Switch Box	
			Resin Nett Filter, Insulated Drain Pan	
FCU-4	FAN COIL UNIT IN CEILING		Cooling Capacity : 4.530 kcal/h ( 5.268 w )	
	MOUNTED		Power Consumption : 63 watt	
****	For JATINEGARA OPERATION CENTER	4	Chilled Water Flow Rate : 13.5 Liter/ min	
	For CIP. ADM. BUILDING	14	Air Flow Rate : 600 cfm	1
	For MANGGARAI STATION	4	Fan Speed Controller w/ embeded Switch Box	
	For BEKASI STATION	1	Resin Nett Filter, Insulated Drain Pan	
	POLAFRASISTATEM			

Equipment Legend	Description	QTY	SPECIFIC	CATION	REMARK
FCU - 5	FAN COIL UNIT IN CEILING		Cooling Capacity	: 3.900 kcal/h ( 4.535 w )	
	MOUNTED		Power Consumption	; 63 watt	
	For JATINEGARA OPERATION CENTER	4	Chilled Water Flow Rate	: 13.5 Liter/ min	
	For CIP. ADM. BUILDING	6	Air Flow Rate	: 580 cfm	
	For MANGGARAI STATION	7	Fan Speed Controller w/ e	embeded Switch Box	
	For BEKASI STATION	7	Resin Nett Filter, Insulated	d Drain Pan	
FCU-6	FAN COIL UNIT IN CEILING		Cooling Capacity	: 3.110 kcal/h ( 3.616 w )	
100 0	MOUNTED		Power Consumption	: 45 watt	
	For JATINEGARA OPERATION CENTER	33	Chilled Water Flow Rate		
		27	Air Flow Rate	: 400 cfm	
v	For CIP. ADM. BUILDING	14	Fan Speed Controller w/ e		
	For JATINEGARA STATION	4	Resin Nett Filter, Insulated		
	FOR BEKASI STATION	*	Resil Nett Filler, Insulated	J Drail Fall	
FCU-7	FAN COIL UNIT IN CEILING		Cooling Capacity	: 2.510 kcal/h ( 2.919 w )	
	MOUNTED		Power Consumption	: 27 watt	
	For JATINEGARA OPERATION CENTER	42	Chilled Water Flow Rate	: 6.4 Liter/ min	
	For CIP. ADM. BUILDING	9	Air Flow Rate	: 300 cfm	
			Fan Speed Controller w/ e	embeded Switch Box	
		i	Resin Nett Filter, Insulated	d Drain Pan	
FCU - 8	FAN COIL UNIT IN CEILING		Cooling Capacity	: 2.510 kcal/h ( 2.500 w )	
	MOUNTED		Power Consumption	: 27 watt	
	For JATINEGARA OPERATION CENTER	42	Chilled Water Flow Rate		
	For CIP. ADM. BUILDING	9	Air Flow Rate	: 300 cfm	
	For BEKASI STATION	1	Fan Speed Controller w/ e		
	, a began official	·	Resin Nett Filter, Insulated		
FCU - 9	FAN COIL UNIT IN CEILING		Cooling Capacity	: 1.650 kcal/h ( 1.920 w )	
	MOUNTED		Power Consumption	: 16 watt	
	For JATINEGARA OPERATION CENTER	29		: 4.9 Liter/ min	
			Air Flow Rate	: 200 cfm	
			Fan Speed Controller w/ e	embeded Switch Box	
			Resin Nett Filter, Insulate	d Drain Pan	
ACCE - 1	AC CEILING EXPOSED		Cooling Capacity	: 10.500 w	
·			Power Consumption	: 3 kw	
		<b></b>	C/w remote controller		
			and the second of the second o		
ACCE - 2	AC CEILING EXPOSED		Cooling Capacity	: 9.360 w	
			Power Consumption	: 2 kw	
	,		C/w remote controller		
ACCE 3	AC CELLING EYDOSED			· 8 100 w	
ACCE - 3	AC CEILING EXPOSED		Cooling Capacity	: 8.100 w	
ACCE - 3	AC CEILING EXPOSED For Substation Buaran	4		: 8.100 w : 2.5 kw	

The Railway Electrification and Double - double Tracking of Java Main Line Project



Note:

This detailed design has been executed by a team of consultants as shown below in accordance with the agreement between Japon International Cooperation Agenccy (JICA) and JICA Study Team,

The copyright of this drawing rests with JICA.

Designed by:

Japan International Cooperation
Agency (JICA)

JICA Study Team:

Joint Venture of Pacific Consultants International and Japan Railway Technical Service

MECHANICAL

GENERAL

DATE 14/Jan/2005

Drawing Title:

EQUIPMENT SCHEDULE (2)

scale: A3 / NTS

AM - 00 - 005

#### EQUIPMENT SCHEDULE LIST ( 3 )

Equipment Legend	Description	QTY	SPECIF	ICATION	REMARKS
ACCE - 4	AC CEILING EXPOSED		Cooling Capacity	: 7.200 w	İ
	For Signal Cabin ( Device Room )	~~~~	Power Consumption	: 2.2 kw	1
	Located : Manggarai, Jatinegara, Bekasi	6	C/w remote controller		
	For Telecom Equipment Room MNG	3			
ACCE - 5	AC CEILING EXPOSED INDOOR UNIT		Cooling Capacity	: 6.240 w	000000000000000000000000000000000000000
	For Bridge Maintenance Room (Office)	4	Power Consumption  C/w remote controller	: 2 kw	Cipinang Yard
			O/# 10/11/00/C CONTROLLO	A STATE OF THE PARTY OF THE PAR	
CCE - 6	AC CEILING EXPOSED INDOOR UNIT		Cooling Capacity	: 5.120 w	
	For Telecom Equipment Room Jatinegara	2	Power Consumption	: 1.6 kw	
•			C/w remote controller		
ACCE - 7	AC CEILING EXPOSED		Cooling Capacity	: 4.320 w	
1002	For Signal Hut / Device Room Cakung	2	Power Consumption	: 1.3 kw	
	Ogna nav somo nom outung		C/w remote controller		
				<del></del> .	
ACCE - 8	AC CEILING EXPOSED		Cooling Capacity	: 2.988 w	
	For Signal Cabin ( Control Room )		Power Consumption	: 2 kw	
	Located : Manggarai, Jatinegara, Bekasi	6	C/w remote controller		
ACW - 1	AC WALL MOUNTED INDOOR UNIT				
	For Jatinegara Station		Cooling Capacity	: 5.600 w	
	Small Office 1	1	Power Consumption	: 2.2 kw	
	For Yardmen Main Room	1	C/w Outdoor Unit and re		Cipinang Yard
	For Coach Cleaning Cont. Office	2			Cipinang Yard
				·	
ACW - 2	AC WALL MOUNTED INDOOR UNIT			5.000	
	For Bekasi Station		Cooling Capacity	: 5.300 w	
	Ticket Selling	1	Power Consumption	: 2.0 kw	01.11
	For Yardmen Sub Room	1	C/w Outdoor Unit and re	suriore courollet	Cipinang Yard
ACW - 3	AC WALL MOUNTED INDOOR UNIT				
	For Manggarai Station				
	Police Room	1			
	For Bekasi Station		Cooling Capacity	: 4.940 w	
	Ticket Reservation	2	Power Consumption	: 1.68 kw	
	For Coach Clean. Cont.Office (Bed Room)	1	C/w Outdoor Unit and re	emote controller	Cipinang Yard
	For Signal Cabin at Location Cipinang Yard		-		
	Device Room & Control Room	4	-		Cipinang Yard
	For Signal Hut at Location Cipinang Yard	2			Cipinang Yard
ACW - 4	AC WALL MOUNTED INDOOR UNIT				
	For Cipinang Depot		Cooling Capacity	: 3.600 w	
	: Master Room	1	Power Consumption	: 1.1 kw	
	For Maintenance room at Located		C/w Outdoor Unit and re	emote controller	
	Telcom Equipment Manggarai	1			
	For Cipinang Station (Master Room)	1			Cipinang Yaro

Equipment Legend	Description	QTY	SPECIFICATION	REMARKS
ACW - 5	AC WALL MOUNTED INDOOR UNIT		Cooling Capacity : 3.300 w	-
7011 0	For Cipinang Depot	<del></del>	Power Consumption : 1.1 kw	
	Meeting Room	1	C/w Outdoor Unit and remote controller	
	For Bridge Maint, Room (Master Room)	1	OW OURDER OTHER BROTHSTONE	
	For Bridge Maint, Isouri (Iviasie) Isosii j			
ACW - 6	AC WALL MOUNTED INDOOR UNIT			
<u> </u>	For Manggarai Station			
	Ticket Booth 1 & 2	2	Cooling Capacity : 3.120 w	
	For Jatinegara Station	i	Power Consumption : 1.1 kw	
	Small Office 1	1	C/w Outdoor Unit and remote controller	
	Ticket Booth 1 & 2	2		
	For Signal Cabin MNG, JTN, BKS	6		
	For Maintenance Room at Located	<del></del>		
	Telcom Equipment Manggarai	2		
	reason = darker	Ī .		
ACW - 7	AC WALL MOUNTED INDOOR UNIT	Ī		-
	For Matraman Station	-		
	Ticket Booth	1	Cooling Capacity : 2.600 w	
	For Jatinegara Station		Power Consumption : 0.74 kw	
	Ticket Booth 2	1	C/w Outdoor Unit and remote controller	
ACW - 8	AC WALL MOUNTED INDOOR UNIT			
1.0	For Jatinegara Station			
•	Reservation	1	Cooling Capacity : 2.160 w	
	For Bekasi Station		Power Consumption ; 0.6 kw	
	Telecom Equipment room	1	C/w Outdoor Unit and remote controller	
ACW - 9	AC WALL MOUNTED INDOOR UNIT	-		
Non .	For Klender, Buaran, Klender Baru,			
	Cakung, Kranji	5	Cooling Capacity : 1.950 w	
	Ticket Booth	-	Power Consumption : 0.5 kw	
	For Platform Operation room	-	C/w Outdoor Unit and remote controller	
	Manggarai, Jatinegara, Bekasi, Klender,	<del> </del>	OW OULDOO OTHER SHEET COLLEGE CO. C. C. C. C. C. C. C. C. C. C. C. C. C.	
	Klender Baru, Buaran, Cakung, Kranji	20		
	For Cipinang Admin. Building	1		Cipinang Yard
	For Sub Station Buaran	1		
	For Bekasi Station ( Maintenance Room )	1		
40	ACCUMENTED INDOOR HAIT			
ACW - 10	AC WALL MOUNTED INDOOR UNIT	<del></del>	<u> </u>	
•	For Bekasi Station		. 4 200 m	
	Cash Handling	1	Cooling Capacity : 1.300 w	
	# 141 BL-N	1	Power Consumption : 2 kw	
	For Jatinegara Station	-		i i
	For Jatinegara Station  Cash Handling		C/w Outdoor Unit and remote controller	
ACC-1			C/w Outdoor Unit and remote controller  Cooling Capacity : 9.680 w	
ACC-1	Cash Handling			

The Railway Electrification and Double - double Tracking of Java Main Line Project



Note:

This detailed design has been executed by a team of consultants as shown below in accordance with the agreement between Japan Herrational Cooperation Agenccy (JICA) and JICA Study Team.

The copyright of this drawing rests with JICA.

Designed by:

Japan International Cooperation Agency (JICA)

JICA Study Team:

Joint Venture of Pacific Consultants International and Japan Railway Technical Service

MECHANICAL

GENERAL

DATE 14/Jan/2005

Drawing Title:

EQUIPMENT SCHEDULE (3)

scale: A3 / NTS

#### EQUIPMENT SCHEDULE LIST ( 4 )

Equipment Legend	Description	QTY	SPECIF	ICATION	REMARKS
ACC - 2	AC CEILING CASSETTE		Cooling Capacity	: 7.865 w	
***************************************	: For Kranji Station		Power Consumption	: 2 kw	
	Station Office	2	C/w remote controller		
ACC - 3	AC CEILING CASSETTE		Cooling Capacity	: 7.200 w	
	For Matraman Station		Power Consumption	: 2 kw	
	Station Office	2	C/w remote controller		
	For Manggarai Station				
	Ticket Reservation	2			
	Waiting Room/ Shop	2			
	For Matraman Station				
	Station Office	2			
	For Loco Monthly Insp. (Inspection Room)	2			Cipinang Yard
	For Loco Daily Insp. ( Meeting Room )	2			Cipinang Yard
ACC - 4	AC CEILING CASSETTE		Cooling Capacity	: 6.000 w	:
	INDOOR UNIT		Power Consumption	: 2 low	
	For Loco Daily Insp. (Inspection Room)	2	C/w remote controller		Cipinang Yard
ACC - 5	AC CEILING CASSETTE		Cooling Capacity	: 5.000 w	
	For Buaran Station Office	2	Power Consumption	: 2 kw	
	For Loco Monthly Insp. ( Meeting Room )	2	C/w remote controller		Cipinang Yard
· · · · · · · · · · · · · · · · · · ·					
ACC - 6	AC CEILING CASSETTE		Cooling Capacity	: 4.500 w	
	INDOOR UNIT	2	Power Consumption	: 2 kw	
	For Klender Baru Station Office	2	C/w remote controller		Cipinang Yard
	For Cipinang Station ( Staff Room )				
	For Jatinegara Station				
	VIP Lounge	2			
	For Bekasi Station				
	VIP Lounge	2			
ACC - 7	AC CEILING CASSETTE		Cooling Capacity	: 4.000 w	
A00-1	AO OLILINO GADOLITE	2	Power Consumption	: 2 kw	Cipinang Yard
	11 11 10 10 10 10 10 10 10 10 10 10 10 1	_	C/w remote controller		
ACC - 8	AC CEILING CASSETTE		Cooling Capacity	: 3.680 w	
	For Klender Station		Power Consumption	: 2 kw	
	Station Office	2	C/w remote controller		
ACO -1	AIR COOLED HEAT PUMP MULTI	1	Cooling Capacity	: 15.730 w	
	TYPE/ OUTDOOR UNIT				
	For Kranji Station Office	1			
	For Manggarai Ticket Reservation	1			
	For Manggarai Waiting/ Shop Room	1			
ACO - 2	AIR COOLED HEAT PUMP MULTI	-	Cooling Capacity	; 14.400 w	
	TYPE/ OUTDOOR UNIT				
	For Matraman Station Office	1			<del></del>

Equipment Legend	Description	QTY	SPECIFIC	CATION	REMARKS
ACO-3	AIR COOLED HEAT PUMP MULTI	1	Cooling Capacity	: 12.960 w	
	TYPE/ OUTDOOR UNIT				
ACO-4	AIR COOLED HEAT PUMP MULTI		Cooling Capacity	: 10.650 w	
	TYPE/ OUTDOOR UNIT				
	For Jatinegara Station				
	Facilities Zone (B)	1			
	promitive also smooth .				
ACO - 5	AIR COOLED HEAT PUMP MULTI		Cooling Capacity	: 9.000 w	
	TYPE/ OUTDOOR UNIT				
	For Buaran Station Office	1			
	For Bekasi Station				
	Facilities Zone ( C )				
	For Jatinegara Station				
	Lounge Zone ( C )				
ACO - 6	AIR COOLED HEAT PUMP MULTI		Cooling Capacity	: 8.000 w	
	TYPE/ OUTDOOR UNIT	ļ			
	For Bekasi Station				
	VIP Zone (B)	1			
	For Klender Station Office	1			
		+			
			-		
		-			
			·		
		-			
		-			
		+			
		-			
	1	-			
	-				1.00
		1			

The Railway Electrification and Double - double Tracking of Java Main Line Project



Note:

This detailed design has been executed by a team of consultants as shown below in accordance with the agreement between Japon International Cooperation Agencey (JICA) and JCA Study Feam.

The copyright of this drawing rests with JICA.

Designed by:

Japan International Cooperation Agency (JICA)

JICA Study Team:

Joint Venture of Pacific Consultants International and Japan Railway Technical Service

MECHANICAL

GENERAL

DATE

14/Jan/2005

Drawing Title:

EQUIPMENT SCHEDULE ( 4 )

Scate: A3 / NTS

#### EQUIPMENT SCHEDULE LIST (5)

Equipment Legend	Description	QTY	SPECIFICATION		REMARKS
EXWI - 1	EXHAUST FAN AXIAL			0.700.0181	
	WALL MOUNTED INDUSTRIAL		Air Volume	: 3.780 CMH	
	For Jatinegara Operation Center		Static Pressure ( min )	: 140 Pa	
	LVMDP Room	1	Power Supply	: 161 w	
.,	Generator Room	1	Axial Propeller Fan, Fan Blade	: 400 dia	
	Pump Room	1	Fan & Motor, Steel Frame		
	Transformer room	1	Related Shutter, Speed Contro	ller	
	Electrical room	1			
			W W//W 1174 - 174		
EXWI - 2	EXHAUST FAN AXIAL				
	WALL MOUNTED INDUSTRIAL		Air Volume	: 2.670 CMH	
	For Jatinegara Operation Center	ļ	Static Pressure ( min )	: 120 Pa	
<u>.</u>	Baterry Room	1	Power Supply	: 88 w	
	Eletrical room	2	Axial Propeller Fan, Fan Blade	: 350 dia	
	For Bekasi Station		Fan & Motor, Steel Frame		
	MDB room	1	Related Shutter, Speed Contro	ller	
EXWI-3	EXHAUST FAN AXIAL		A: 37.1	1 000 0141	
	WALL MOUNTED INDUSTRIAL		Air Volume	: 1.800 CMH	
	For Jatinegara Operation Center	1	Static Pressure (min)	: 120 Pa	
	SDP Panel Room	1	Power Supply	: 59 w	
	Electrical Room 1 st FL	1	Axiai Propeller Fan, Fan Blade	: 300 dia	
	Electrical Room 2 nd FL	1	Fan & Motor, Steel Frame		
	PLN / MV Room	1	Related Shutter, Speed Control	oller	
	KAI / MV Room	1			
	For Manggarai Station				
	Electrical room	1			
	Pump Room	1			
	For Bekasi Station			· · · · · · · · · · · · · · · · · · ·	
	Genset room	2			
	Trafo room	1			
	Pump room	2			
	For Cipinang Adm. Builiding				
	Kitchen G fl	1			
	For Signal Cabin Facilities				
	Genset room	3			
	Signal Device	3			
	For Telcom. Equip. Room KLD,				
	CKN.				
	Telcom room	2			
	For Telcom, Equip. Room JTN,				
	KLD.				
	Power supply room	2			
	For Telcom, Equip, Room				
	Manggarai				
	Equipment room	2			
				•	
	<del> </del> -				

For Telcom. Equip. Room Jatinegara Equipment room For Jatinegara Station Dist. Board Room Genset room For Loco Monthly Inspection Mechanical room High Voltage Genset Room	2 2 2 2 2 2 2			
Jatinegara  Equipment room  For Jatinegara Station  Dist. Board Room  Genset room  For Loco Monthly Inspection  Mechanical room  High Voltage	2 2			
Equipment room For Jatinegara Station Dist. Board Room Genset room For Loco Monthly Inspection Mechanical room High Voltage	2 2			
For Jatinegara Station  Dist. Board Room  Genset room  For Loco Monthly Inspection  Mechanical room  High Voltage	2 2			
Dist. Board Room  Genset room  For Loco Monthly Inspection  Mechanical room  High Voltage	2			
Genset room For Loco Monthly Inspection Mechanical room High Voltage	2			
For Loco Monthly Inspection  Mechanical room  High Voltage	2			
Mechanical room High Voltage				
High Voltage				
	2			
Genset Room			···	
	2			
EXHAUST FAN AXIAL				
WALL MOUNTED INDUSTRIAL		Air Volume	: 1.100 CMH	
For Cipinang Adm.Building		Static Pressure ( min )	: 120 Pa	
Switchboard Room	1	Power Supply	: 59 w	Cipinang Yard
EPS & Elect.Room G fl & 1 st fl		Axial Propeller Fan, Fan Bla	ade : 250 dia	
Loco. Maintenance	2	Fan & Motor, Steel Frame		
Line Laundry	t	Related Shutter, Speed Co	ntroller	
For Manggarai Station				
Genset Room	2			
Travo Room	2			
Distribution Board.	2			
For Klender, Buaran, Klender Br,				
Cakung and Kranji Station				
Pump Room	5			
Electrical Room	5			
For Jatinegara Station				
	2			
Water Tank Room	1			
Kitchen	1			
····		O TO THE THEORY OF THE TO		<u> </u>
	1			
Genset Room	1			<u>!</u>
	1			·
	1			
	1			:
	1	·		:
	1			
				Cipinang Yan
	1			2-F
·	·			Cipinang Yan
				Spring (a)
				-
	EXHAUST FAN AXIAL WALL MOUNTED INDUSTRIAL For Cipinang Adm. Building Switchboard Room EPS & Elect.Room G fl & 1 st fl Loco. Maintenance Line Laundry For Manggarai Station Genset Room Travo Room Distribution Board. For Klender, Buaran, Klender Br, Cakung and Kranji Station Pump Room Electrical Room For Jatinegara Station Pump Room Water Tank Room Kitchen For Telecom Equip.Room Manggarai Station Baterry Room For Signal Hut Cakung	EXHAUST FAN AXIAL  WALL MOUNTED INDUSTRIAL  For Cipinang Adm. Building  Switchboard Room  EPS & Elect.Room G fl & 1 st fl  Loco. Maintenance  Line Laundry  For Manggarai Station  Genset Room  2  Travo Room  2  Distribution Board.  For Klender, Buaran, Klender Br,  Cakung and Kranji Station  Pump Room  Electrical Room  For Jatinegara Station  Pump Room  Ikitchen  For Telecom Equip.Room  Manggarai Station  Baterry Room  I For Signal Hut Cakung  Genset Room  I Baterry room  Power Room  I Baterry room  I Bouran  For Substation Buaran  Genset Room  I Main Switchboard Room  I For Loco Monthly Inspection  Main Switchboard Room  I Main Switchboard Room	EXHAUST FAN AXIAL  WALL MOUNTED INDUSTRIAL For Cipinang Adm. Building Switchboard Room 1 Power Supply EPS & Elect.Room G fl & 1 st fl Loco. Maintenance 2 Fan & Motor, Steel Frame Line Laundry 1 Related Shutter, Speed Cor For Manggarai Station Genset Room 2 Travo Room 2 Distribution Board. For Klender, Buaran, Klender Br, Cakung and Kranji Station Pump Roorn 5 Electrical Room 5 For Jatinegara Station Pump Room 2 Water Tank Room 1 Kitchen 1 For Telecom Equip.Room Manggarai Station Baterry Room 1 Baterry Room 1 Power Room 1 Power Room 1 Power Room 1 High Voltage 1 For Loco Monthly Inspection Main Switchboard Room 1 Main Switchboard Room	EXHAUST FAN AXIAL  WALL MOUNTED INDUSTRIAL For Cipinang Adm. Building Switchboard Room 1 Power Supply Sign W EPS & Elect. Room C fl & 1 st fl Loco. Maintenance 2 Fan & Motor, Steel Frame Line Laundry 1 Related Shutter, Speed Controller For Manggarai Station Genset Room 2 Travo Room 2 Distribution Board. For Klender, Buaran, Klender Br, Cakung and Kranji Station Pump Room 5 Electrical Room 5 For Jalinegara Station Pump Room 1 Kitchen 1 For Telecom Equip. Room Manggarai Station Baterry Room 1 For Signal Hut Cakung Genset Room 1 Restary room 1 Restary room 1 Restary room 1 Power Room 1 For Substation Buaran Genset Room 1 Main Switchboard Room 1 For Loco Monthly Inspection Main Switchboard Room 1 For Cipinang Main Sub-Station Genset Room 1 Main Switchboard Room 1 For Cipinang Main Sub-Station Genset Room 1 Main Switchboard Room 1 Main Swi

The Railway Electrification and Double - double Tracking of Java Main Line Project



#### Note:

This detailed design has been executed by a team of consultants as shown below in accordance with the agreement between Lepon Informational Cooperation Agenacy (JCA) and JICA Study Team.

The copylight of this drowing rests with JICA.

Designed by:

Japan International Cooperation Agency (JICA)

JICA Study Team:

Joint Venture of Pacific Consultants International and Japan Railway Technical Service

MECHANICAL

GENERAL

DATE 14/Jan/2005

Drawing Title :

EQUIPMENT SCHEDULE ( 5 )

scale: A3 / NTS

#### EQUIPMENT SCHEDULE LIST (6)

Equipment Legend	Description	QTY	SPECIFICATIO	)N	REMARKS
	For Cipinang SubStation				Cipinang Yard
<del></del>	Genset Room	1			
***	Main Switchboard Room	†			
	High Voltage	1			
EXW - 1	EXHAUST FAN AXIAL			<del></del>	
	WALL MOUNTED		Air Volume	: 840 CMH	
	For Jatinegara Operation Center		Static Pressure ( min )	: 60 Pa	
	Toilet Ground FL	2	Power Supply	: 31 w	
	Toilet 1 st FL	2	Metal Fan Blade	: 250 dia	
	Toilet 2 nd FL	2	Wall Mount Ventilating Fan		
	Toilet 3 rd FL	1			
-	For Loco Monthly Inspection				Cipinang Yard
	Prayer room/ Mushola	1			
	Tool Room	1			
	70017100111				
EXW-2	EXHAUST FAN AXIAL				
LATT E	WALL MOUNTED		Air Volume	: 570 CMH	
	For Signal Cabin Cipinang Yard		Static Pressure ( min )	: 40 Pa	
•	Power Room	1	Power Supply	: 23 w	
	For Signal Hut Cipinang Yard		Metal Fan Blade	: 250 dia	
	Power Room	1	Wall Mount Ventilating Fan	. 200 414	Cipinang Yard
			TVAIL INDUITE VOITSALEIG T CET		Cipitizing 12rd
	For JTN. Opert. Center  Toilet G fl	1	:		
	For Signal Cabin Facilities	3			
	Power Room				
	For Telcom Equip. room JTN, BKS	2			
	Maintenance room				<u> </u>
EXW-3	EXHAUST FAN AXIAL				
	WALL MOUNTED				
	For Coach Yard Men Room		Air Volume	: 552 CMH	
	Toilet	1	Static Pressure (min)	: 60 Pa	
	For Coach Cleaning Contr. Office		Power Supply	: 31 w	
	Bed Room		Metal Fan Blade	: 250 dia	
	Pray Room	1	Wall Mount Ventilating Fan		-
	Toilet	1			
	For Signal Cabin Cipinang Yard				<del> </del>
	Battery Room	1			
	For Signal Hut Cipinang Yard				
	Battery Room	1			
	For Jatinegara Operation Center				
	Mushola	3			
	For Signal Cabin Facilities				
	Battery Room	1			
	For Jatinegara Station	. '			
	Tailet / Old Duilding - \	. 1			
	Toilet ( Old Building )	1			

Equipment Legend	Description	QTY	SPECIF	CICATION	REMARKS
EXW - 4	EXHAUST FAN AXIAL				
	WALL MOUNTED				
	For Coach Yard Men Room		Air Volume	: 288 CMH	Cipinang Yard
	Beed Room	1	Static Pressure (min)	: 40 Pa	
	Pray Room	1	Power Supply	: 23 w	Cipinang Yard
	For Signal Cabin Cipinang Yard		Metal Fan Blade	: 250 dia	
	Pray Room	1	Wall Mount Ventilating Fan		
	Toilet	1			
	For Signal Hut Cipinang Yard				Cipinang Yard
	Switching Room	1			
	For Cipinang Station				
	Mushola	1			
	Storage	1			
	Bed Room	1			
	For Brid. Maint. Office			***	Cipinang Yard
	Electrical room	1			-
	Storage 1	1			
	For Jatinegara Opert. Center				
	Storage	1			
	Mushola	3			
	For Cipinang Adm. Building				Cipinang Yard
	Stroge	3		-	
	For Matraman Station		<del></del>		
	Maintenance room	1			i
	Electrical room	1			
	For Signal Cabin Facilities	<u> </u>			
	Pray room	1			
	Toilet	<u>'</u>			
		'			
	For Telcom. Equip.Room  Manggarai Station				
	Kitchen & Toilet	2			
	·	Ž.			
	For Platfrom Opert. Office MNG,				
	BKS, JTN	28			
	Pantry, and Toilet	20			
	for Sub-Station Buaran	2			-
	Storage and Toilet				Cipinang Yard
	for Loco Monthly Inspection	1			Orbania Lara
	Storage				
	for Loco Daily Inspection	1			
	Storage	<u> </u>			
		<del> </del>			
		:			
		!			

The Railway Electrification and Double - double Tracking of Java Main Line Project



DEPARTMENT PERCURENCIAN
MERISTEY OF CONSUMERATION
DESCRIPART SENDERAL PERCURENCIAN DARAY
DESCRIPART CENTERAL OF LAND COMMUNICATION
John Medico Densi no. 9 Delang Koya R. 11 Sp. 1221 – 3505529 – 35
A K A R T A

Note:

This detailed design has been executed by a team of consultants as shown below in accordance with the agreement between Japan Internalianal Copperation Agencey (JICA) and JICA Study Team.

The copyright of this drawing rests with JICA.

Designed by:

Japan International Cooperation Agency (JICA)

JICA Study Team:

Joint Venture of Pacific Consultants International and Japan Railway Technical Service

MECHANICAL

GENERAL

**DATE** 14/Jan/2005

Drawing Title :

EQUIPMENT SCHEDULE ( 6 )

Scale: A3 / NTS

#### EQUIPMENT SCHEDULE LIST (7)

Equipment Legend	Description	QTY	SPECIFICATION	REMARK
EXW - 5	EXHAUST FAN AXIAL			
	WALL MOUNTED		Air Volume : 226 CMH	
	For Coach Cleaning Contr. Office		Static Pressure ( min ) : 60 Pa	
	Stroge	1	Power Supply : 28 w	
	For JTN Opert. Center		Metal Fan Blade : 200 dia	
	Toilet	2	Wall Mount Ventilating Fan	
	Mushola	1		
	For Level Cros.Watchman Shed			
	Bks, Cpn, Kldb, Jtn, and Ckn			
	Toilet	5		
	For Loco Monthly Inspection			
	Store Attendent	1		
EXC-1	EXHAUST FAN AXIAL			
· · ·	WALL MOUNTED		Air Volume : 438 CMH	
	For Manggarai Station		Static Pressure ( min ) : 40 Pa	
	Staff Toilet 1 st FL	4	Power Supply : 23 w	
	Puplic Toilet	8	Plastic Fan Blade : 223 dia	
	Ticket Booth 3	1	Ceiling Mount Propeller Exhaust Fan	
	Waiting Room & Female	1		
	For Matraman Station			
	Toilet Male & Female	4		
EXC - 2	EXHAUST FAN AXIAL			
EAU-2			Air Volume : 420 CMH	
	CEILING MOUNTED		Static Pressure (min) : 40 Pa	
	For Bekasi Station	2	Power Supply : 44 w	
	Toilet Male & Female G FI	1	Plastic Fan Blade : 223 dia	
	FOI Watraman Station	. 1		
	Toilet Male & Female G FI	2	Ceiling Mount Siroco Ventillating Fan	
			Related Shutter, Speed Controller	
EXC - 3	EXHAUST FAN AXIAL			
	CEILING MOUNTED	:	Air Volume : 330 CMH	
	For Manggarai Station		Static Pressure (min) : 40 Pa	
	Public Toilet G fl	1	Power Supply : 23 w	
	Toilet VIP Lounge Ground FL	1	Plastic Fan Blade : 223 dia	
	Ticket booth 1 & 2	2	Ceiling Mount Siroco Ventillating Fan	
	For Jatinegara Station		Related Shutter, Speed Controller	
	Male Toilet ( Public )	6		
	Female Toilet ( Public )	6		
	Staff Toilet	3		
	For Bekasi Station			
	Toilet Female 1 st fL	6		
	For Matraman Station			
	Ticket Booth	1		
	For Klender, Buaran, Kld Baru,			
	Cakung and Kranji Station			
	Toilet Female	10		
	For Jatinegara Station			
	Public Toilet ( old building )			

Equipment Legend	Description	QTY	SPECIFICATION	REMARKS
EXC - 4	EXHAUST FAN AXIAL			
	CEILING MOUNTED		Air Volume : 265 CMH	
	For Manggarai Station		Static Pressure (min) : 40 Pa	
	Pantry	1	Power Supply : 23 w	
	For Bekasi Station		Plastic Fan Blade : 121 dia	
	Toilet Male 1 st fl	6	Ceiling Mount Siroco Ventillating Fan	
	For Kld. Buaran, Kld.br, Cakung		Related Shutter, Speed Controller	
	Kranji Station			
	Toilet Male	10		
	For Jatinegara Station		#III.1 # #41 - #III.	
	Staff toilet & Public Toilet	15	COMPT VIEW OF A NOTE AND POST OF STREET AND AND AND AND AND AND AND AND AND AND	
	For Klender Station			
	Ticket Booth	1		
	TRINGS DOCATI			
EXC-5	EXHAUST FAN AXIAL			
	CEILING MOUNTED		Air Volume : 207 CMH	
	For KLD, BRN, KLDB, KRJ, CKN		Static Pressure ( min ) : 40 Pa	
	Ticket Booth	4	Power Supply : 26 w	
	For Bekasi Station		Plastic Fan Blade : 121 dia	
	Staff toilet ( male & female )	6	Ceiling Mount Siroco Ventillating Fan	
	For Manggarai Station		Refated Shutter, Speed Controller	
	Storage	2		
	Pantry	1		Cipinang Yard
	For CPN Adm. Building			
	Toilet for staff	10		
	Ablution	2		
EXC-6	EXHAUST FAN AXIAL			
	WALL CEILING MOUNTED		Air Volume : 173 CMH	
	For Bekasi Station		Static Pressure ( min ) : 40 Pa	
	Storage	1	Power Supply : 25 w	
	Handycap Toilet	2	Plastic Fan Blade : 121 dia	
	Tanayorp Tonot	- · <del>-</del>	Ceiling Mount Siroco Ventillating Fan	
			Related Shutter, Speed Controller	
			riolated criatics, opera controller	
EXC - 7	EXHAUST FAN AXIAL			· :
	WALL CEILING MOUNTED		Air Volume : 140 CMH	
	For Bekasi Station		Static Pressure (min) : 40 Pa	
	Storage	1	Power Supply : 11 w	
	Handycap Toilet	2	Plastic Fan Blade : 121 dia	
	For Jatinegara Operation Center		Ceiling Mount Siroco Ventillating Fan	
	Toilet Female Ground FL	1	Related Shutter, Speed Controller	
	Toilet Female 1 st FL	1		
	For Bridge Main. Office			
	Storage 2	1		
	For Cipinang Adm. Building			
	Toilet Bed room	38		
	For Loco Monthly Inspection			
	Toilet	5		
	LOUGE			

The Railway Electrification and Double - double Tracking of Java Main Line Project



DEFINITION OF COMMUNICATION

DESIGNATOR OF COMMUNICATION

DESIGNAT ASSISSABLE PERSURBINGAN DARAY

TOPSTORMS CENERAL OF LAND COMMUNICATION

John Maden National Generals On Communication

John Maden National Generals On Communication

John Maden National Generals On Communication

John Maden National Generals On Communication

John Maden National Generals On Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communication

John Maden National Communi

#### Note

This detailed design has been executed by a feam of consutants as shown below in accordance with the agreement between Logon International Cooperation Agencey (JICA) and JICA Study Team.

The copyright of this drawing rests with JICA.

#### Designed by:

Japan International Cooperation Agency (JICA)

JICA Study Team:

Joint Venture of Pacific Consultants International and Japan Raliway Technical Service

MECHANICAL

GENERAL

DATE 14/Jan/2005

Drawing Title :

EQUIPMENT SCHEDULE (7)

scale: A3 / NTS

#### EQUIPMENT SCHEDULE LIST (8)

Equipment Legend	Description	QTY	SPECIFICATION	REMARKS
	For Loco Daily Inspection			
	Toilet	2		
CF - 1	CEILING FAN PROPPELER	·		
	For Manggarai Station		Air Volume : 225 CMH	
	Mushola	4	Power Supply : 80 Pa	
	For Jatinegara Station		Metal Blade : 140 dia	
	Mushola	2	Thermal Fuse, Speed Regulator	
	For MTM, KLD, BRN, KLDB, KRJ,		Speed Controller	
	& CKN Station			
	Mushola	6		
· · · ·	For Bekasi Station			
	Mushola	2		<del>                                     </del>
	For Cipinang Adm. Building			Cipinang Yar
	Mushola	10		
	For Jatinegara Station			1
	Mushola	2		
	Widanija	_		
HEXF -1	HEAT EXCHANGED		Total Heat ( temperatur and humidity ) Ventilation	
	EXHAUST FAN UNIT		Air Dolivery : 1.500 CMH	
	For Jatinegara Oprt, Cent.		Static Pressure : 20 mm H2O	
	Train Dispatcher 3 rd fl	4	Power : 705 dia	
			Outside Air Intake/ Exhaust: 300. día x 2 duct	
	For Cipinang Adm. Building		OA Grille/ Exhaust grill c/w insect screen	Cipinang Ya
	Dining Room	1		
	General Management	1		
	For Bekasi Station			
	Station Office	2		1
	For Matraman Station			
	Station Office	1		
	For Kranji Station			
	Office	1		
	For Cakung Station	· · · · · · · · · · · · · · · · · · ·		
	Office	1		
HEXF - 2	HEAT EXCHANGED			
	EXHAUST FAN UNIT			
	For Jatinegara Operation Center			
	Rest room 2 fl	2		
	Entrance hall G fl	2		
	Bed room G fl	2		
	Telecom Office 1 st fl	2		
	Signal Room 1 st FL	2	Total Heat (temperatur and humidity) Ventilation	
	Signal Office 1 st FL	2	Air Delivery : 1.000 CMH	
	Elect, Power Opert.Room 2 fl	1	Static Pressure : 15 mm H2O	
	Meeting Room	1	Power : 680 w	
	Cts Room	1	Outside Air Intake/ Exhaust: 250. dia x 2 duct	
	For Manggarai Station		OA Gritle/ Exhaust gritl c/w insect screen	<del></del>
	- VIP Lounge	1		

Equipment Legend	Description	QTY	SPECIFICATION	REMARKS
	- Frist Class Launge	1		
	For Bekasi Station			
	- Meeting room	1	<u> </u>	
	For Bekasi Station			
	- Meeting room	1		
	For Bridge Main. Office			
	- Office	2		
	For Cipinang Adm. Building			
	Training Room	1		
	Entrance Hall	1		
	Security Room	1		
	Clinic	1		
	Conference room	1		
	Loco. Management	1		<u> </u>
	For Buaran Station			
	Office	1		
	For Jatinegara Station			
	Meeting room	1		
	Station Office	2		
	VIP Launge	1		
	For Loco Monthly Inspection			: :
	Meeting room & Inspector, Room	2		į
	For Loco Daily Inspection			į
	Inspector Room	1		
HEXF - 3	HEAT EXCHANGED			
	EXHAUST FAN UNIT		Total Heat (temperatur and humidity) Ventilation	ו
	For Jatinegara Operation Center		Air Delivery : 800 CMH	
	Corridor G FL	2	Static Pressure : 12 mm H2O	
	Maintenance room G FL	2	Power : 450 w	
	Radio room 1 st FL	2	Outside Air Intake/ Exhaust: 200. dia x 2 duct	
	Corridor 1 st FL	2	OA Grille/ Exhaust grill c/w insect screen	
	Telecom room 1 st FL	2		
	Telecom workshop 2 nd FL	7		
	Voice recorder room 2 nd FL	1		
	Telecom office 2 nd FL	2		
	Corridor 2 nd FL	2		
	Rest room 2 fl	1		
	Rest room 2 fl Signal Telcom Room 2 fl	1	:	
	Signal Telcom Room 2 fl	1		
	Signal Telcom Room 2 fl Meeting Room	1		
	Signal Telcom Room 2 fl Meeting Room Cts Room 3 fl	1		
	Signal Telcom Room 2 fl Meeting Room Cts Room 3 fl For Cipinang Station	1 1		
	Signal Telcom Room 2 fl Meeting Room Cts Room 3 fl For Cipinang Station Staff Room	1 1		
	Signal Telcom Room 2 fl Meeting Room Cts Room 3 fl For Cipinang Station Staff Room For Cipinang Adm. Building Corridor	1 1		
	Signal Telcom Room 2 fl Meeting Room Cts Room 3 fl For Cipinang Station Staff Room For Cipinang Adm. Building	1 1 1		
	Signal Telcom Room 2 fl Meeting Room Cts Room 3 fl For Cipinang Station Staff Room For Cipinang Adm. Building Corridor Driver Waiting Room	1 1 1		

The Railway Electrification and Double - double Tracking of Java Main Line Project



#### Note

This detailed design has been executed by a team of consultants as shown below in accordance with the agreement between Japan International Cooperator Agenccy (JICA) and JICA Study Team.

The copyright of this drawing tests with JICA.

#### Designed by:

Japan International Cooperation Agency (JICA)

#### JICA Study Team:

Joint Venture of Pacific Consultants International and Japan Railway Technical Service

MECHANICAL

GENERAL

DATE 14/Jan/2005

Drawing Title:

EQUIPMENT SCHEDULE (8)

scale: A3 / NTS

#### EQUIPMENT SCHEDULE LIST (9)

Equipment Legend	Description	QTY	SPECIFICATION	REMARKS
	For Klender Station			
	Office	1		
	For Klender Baru Station			
	Office	1		
	For Telcom Equip. Room			
	Manggarai			
	Maintenance Room	1		
	For Jatinegara Station			
	Master Room	1		
	For Signal Cabin (Cipinang Depot)	1		
HEXF - 4	HEAT EXCHANGED			
	EXHAUST FAN UNIT		Total Heat (temperatur and humidity) Ventilation	
	For Jatinegara Operation Center	••	Air Delivery : 500 CMH	
	Corridor 3 rd FL	1	Static Pressure : 4 mm H2O	
	Rest room 3 rd FL	1	Power : 195 w	
	For Manggarai Station		Outside Air Intake/ Exhaust: 200. dia x 2 duct	
	Frist Class Launge	1	OA Grille/ Exhaust grill c/w insect screen	
	Station Master room	1		
	Station Office	1		
	Locker & Rest Room	1		
	Big Stroge	1		
	Office	1		
	Ticket Seiling	1		
	For Bekasi Station			
	Station Master Room	1		
	For Coach Yard Men Room			Cipinang Ya
	Yardmen Room	1		Olpineary 16
	For Coach Cleaning Cont.			Cipinang Ya
		1		Cipinany 1
	Inspector Room			Cininana V
	For Cipinang Adm. Building	1		Cipinang Ya
	Master Room	,		O'- ' V
	For Loco Daily Inspection	•		Cipinang Ya
	Meeting Room	1		
HEXF - 5	HEAT EXCHANGED			
IILAF - J	EXHAUST FAN UNIT			
	For Jatinegara Operation Center			
	Reception Room G FL	1		
	For Manggarai Station		Total Heat (temperatur and humidity) Ventilation	
	Reception Room G FL	1	Air Delivery : 270 CMH	0
	For Cipinang Station		Static Pressure : 2 mm H2O	Cipinang Ya
	Master Room	11	Power : 83 w	
	For Bridge Maintenance Office		Outside Air Intake/ Exhaust: 150. dia x 2 duct	Cipinang Ya
	Master Room	1	OA Grille/ Exhaust grill c/w insect screen	
	TO THE CONTROL OF THE			

Equipment Legend	Description	QTY	SF	PECIFICATION	REMARKS
BP - 1	BOOSTER PUMP UNIT				
	For Manggarai Station	1	Туре	: variable speed	
	33		Cap	; 153 Lt / min	
			Total head	: 30 m	
,			1.5 kw, 3 ph, 380 \	J	
			Automatical alterna		
			2 pump opert in pa	aralel alternate, 1 sandby	
			Accessories	: Including control panel	
			Unit vibration base	ement with anchore volts	
			Concrete plinth	: 100 x 900 x 100 H	
			(by others)	1/44/7 N. W. N. W. 1/44/7 N. W. N. W. 1/44/7 N. W. 1/44/7 N. W. 1/44/7 N. W. 1/44/7 N. W. 1/44/7	
				<b>J</b> (Way)	_
BP-2	BOOSTER PUMP UNIT		Туре	: variable speed	
	For Bekasi Station	1	Сар	: 103 Lt / min	<u> </u>
			Total head	: <b>3</b> 0 m	
			1.2 kw, 3 ph, 380 \		
			Automatical altern		
			2 pump opert in pa	aralel alternate, 1 sandby	
			Accessories	: Including control panel	
			Unit vibration base	ement with anchore volts	
			Concrete plinth	: 100 x 900 x 100 H	
			( by others )	L. B. ALLAND SERVICE STREET, CONTINUES	
BP - 3	BOOSTER PUMP UNIT		, Туре	: variable speed	
<b>DI</b> - 3	For Jatinegara Operation Center	1	Сар	: 60 Lt / min	
	To talinegala operation center	'	Total head	: 30 m	
			0.75 kw, 3 ph, 380		
			Automatical altern	* ****.	
			2 pump opert in paralel alternate, 1 sandby		
		1	Accessories	: Including control panel	
				ement with anchore volts	
			Concrete plinth	: 100 x 900 x 100 H	
			( by others )	. ISS X OOS X ISS I	
			( by onlers )	-	
BP - 4	BOOSTER PUMP UNIT		Туре	: variable speed	
	For Jatinegara Station	1	Cap	: 52 Lt / min	
-			Total head	: 30 m	
			0.75 kw, 3 ph, 380	V	
			Automatical altern	ative run	
			2 pump opert in pa	aralel alternate, 1 sandby	!
			Accessories	: Including control panel	•
			Unit vibration base	ement with anchore volts	
			Concrete plinth	: 100 x 900 x 100 H	
			(by others)		!
		<u> </u>	:		
		<b> </b>			
		<del> </del>			
· · · · · · ·					<del> </del>

The Railway Electrification and Double - double Tracking of Java Main Line Project



#### Note:

This detailed design has been executed by a team of consultants as shown below in accordance with the agreement between Jupan International Cooperation Agencoy (JICA) and JICA Study Team.

The copyright of this chowing tests with JICA,

#### Designed by:

Japan International Cooperation Agency (JICA)

JICA Study Team:

Joint Venture of Pacific Consultants International and Japan Rallway Technical Service

MECHANICAL

GENERAL

DATE 14/Jan/2005

#### Drawing Title :

EQUIPMENT SCHEDULE (9)

scale: A3 / NTS

#### EQUIPMENT SCHEDULE LIST ( 10 )

quipment Legend	Description	QTY	SPE	CIFICATION	REMARKS	
BP - 5	BOOSTER PUMP UNIT		Туре	: variable speed		
	For Klender Station	1	Cap	: 25 Lt / min		
***	For Buaran Station	1	Total head	: 30 m		
	For Klender Baru Station	1	0.50 kw, 3 ph, 380 V	,		
	For Cakung Station	1	Automatical alternati			
	For Kranji Station	1	2 pump opert in para	atel atternate, 1 sandby		
	•		Accessories	: Including control panel		
			Unit vibration basem	nent with anchore volts		
			Concrete plinth	: 100 x 900 x 100 H		
		•	(by others)			
				THE THE PARTY NAMED IN COLUMN TAXABL		
BP-6	BOOSTER PUMP UNIT		Type	: variable speed		
<u> </u>	General use 1 (Cipinang Yard)	1	Сар	: 50 Lt / min		
	(Location: Loco Pump House 1)	,	Total head	: 50 m		
	( zoozion i zooc / amp nodoc / /		0.75 kw, 3 ph, 380 V	·		
			Automatical alternat			
				alel alternate, 1 sandby		
			Accessories	: Including control panel		
				nent with anchore volts		
			Concrete plinth	: 100 x 900 x 100 H		
			(by others)	. 100 x 800 x 100 11		
			( by others )			
DD 7	POCETED DUMB UNIT		Туре	: variable speed	-	
BP - 7	BOOSTER PUMP UNIT	•	Сар	: 100 Lt / min		
	Washing Use 1 (Cipinang Yard)	1	Total head	: 60 m		
	(Location : Loco Pump House 1)		1.3 kw, 3 ph, 380 V	. 00 111		
				ive run		
			ļ	Automatical alternative run  2 pump opert in paralel alternate, 1 sandby		
		·	Accessories	: Including control panel		
	<u> </u>			nent with anchore volts		
			Concrete plinth	: 100 x 900 x 100 H		
			( by others )			
			<b>-</b>			
BP-8	BOOSTER PUMP UNIT		Туре	: variable speed		
	Washing Use 2 (Cipinang Yard) (Location: Loco Pump House 2)	1	Cap Total bood	: 35 Lt / min		
	(Location : Loco Pump House 2)		Total head	: 45 m		
			0.6 kw, 3 ph, 380 V			
			Automatical alternat			
				alel alternate, 1 sandby		
			Accessories	: Including control panel		
				nent with anchore volts	-	
			Concrete plinth	: 100 x 900 x 100 H		
			( by others )		1	
BP - 9	BOOSTER PUMP UNIT		Type	: variable speed		
	Washing Use 2 ( Cipinang Yard )	•	Cap	: 110 Lt / min		
	(Location: Loco Pump House 2)	1	Total head	: 70 m		
			2.2 kw, 3 ph, 380 V		-	
			Automatical alternat	ive run		

Equipment Legend	Description	QTY	SPECIFICATION	REMARKS
			2 pump opert in paralel alternate, 1 sandby	
			Accessories : Including control panel	
	·		Unit vibration basement with anchore volts	,
			Concrete plinth : 100 x 900 x 100 H	
			( by others )	
FP-1	FIRE PUMP			
	For Loco pump House 1	2	Type : end suction	
	Location: Loco Pump House 1		Cap : 300 Lt / min ( 50 GPM )	
	For Manggarai Station	2	Total head : 60 m	
			7.5 kw, 3 ph, 380 V	
			2 pump run on emergency	
			Accessories : Including control panel	
			Unit vibration basement with anchore volts	
			Concrete plinth : 100 x 900 x 100 H	
FP-2	FIRE PUMP			
-FF-Z	For Loco pump House 2	2	Type : end suction	
	Location : Loco Pump House 2		Cap : 700 Lt / mín	
			Total head : 100 m	
			18.5 kw, 3 ph, 380 V	
			2 pump run on emergency	
			Accessories : Including control panel	
			Unit vibration basement with anchore volts	
			Concrete plinth : 100 x 900 x 100 H	
FP - 3	FIRE PUMP		Type ; end suction	
	For Manggarai Station	. 2		
	For Jatinegara Oper. Center	2	Cap : 150 Lt / min	
			Total head : 60 m	
			2.3 kw, 3 ph, 380 V	
			2 pump run on emergency	
			Accessories : Including control panel	
			Unit vibration basement with anchore volts	
			Concrete plinth : 100 x 900 x 100 H	
FP-3	FIRE PUMP			
	For Jatinegara Station	2	Type : end suction	
			Cap : 200 Lt / min	
			Total head : 60 m	
			2.5 kw, 3 ph, 380 V	
			2 pump run on emergency	
-			Accessories : Including control panel	<u>†                                      </u>
			Unit vibration basement with anchore volts	
			Concrete plinth : 100 x 900 x 100 H	
	}	ì		

The Railway Bectrification and Double - double Tracking of Java Main Line Project



This detailed design has been executed by a team of consultants as shown below in accordance with the agreement between Japan International Cooperation Agency (JICA) and JICA Shuch Team.

The copyright of this drawing rests with JICA.

Designed by:

Japan International Cooperation Agency (JICA)

JICA Study Team:

Joint Venture of Pacific Consultants International and Japan Railway Technical Service

MECHANICAL

GENERAL

DATE 14/Jan/2005

Drawing Title :

EQUIPMENT SCHEDULE (10)

Scale: A3/NTS

#### EQUIPMENT SCHEDULE LIST ( 11 )

quipment Legend	Description	QTY	SPECIFICATION	REMARKS
DSP - 1	DEEP WELL SUBMERSIBLE PUMP			
	For Bekasi Station	1	Deep well Submersible Pump	
	For Jatinegara Operation Center	1	Water flow rate: <b>72</b> m <sup>3</sup> /day ( 9 m <sup>3</sup> / hr ) = 150 Lt / min	
	For Locomotve Depot Cipinang	2	Power : 9.0 kw, 3 ph, 380 V Head : 173 m in depth	
	For Coach Depot Cipinang	5	Complete Acessories with remote controls	
			8 hours operation, one day timer control	
SMP-1	SUM PUMP			
	For Manggarai Station	2	Submersible Pump	
			water flow rate: 60 Lt / min , Head: 9 m	
			Power : 0.75 kw, † ph, 220 V	
			Complete Acessories with remote controls	
			8 hours operation, one day timer control	
SMP-2	SUM PUMP			
	For Bekasi Station	2	Submersible Pump	
			water flow rate: 47 Lt / min , Head: 9 m	
			Power : 0.5 kw, 1 ph, 220 V	
			Complete Acessories with remote controls	
			8 hours operation, one day timer control	
WR - 1	WATER RESERVOIR			
	For Locomotive Depot	1	Water Reservoir Under Ground Construction by	
			Architectur work	
			Water Capasity : 125 m³	,
			14 m (L) x7 m (w) devided 3 tank x 2.5 m (H)	
			total. inside ladder, man hole and sand separator	
WR - 2	WATER RESERVOIR			
	For Manggarai Station	t	Fiber Reinforced Prefabricated Panel Tank Assembly	
			Water Capasity : 63 m <sup>3</sup>	
			steel common base w/ reinforced steel	
			500 H x 400 W x 4 Lines.	
WR-3	WATER RESERVOIR			
	For Jatinegara Station	1	Fiber Reinforced Prefabricated Panel Tank Assembly	
			Water Net Capacity: 30 m 3	
			steel common base w/ reinforced steel	
	·		500 H x 400 W x 4 Lines.	
WR-4	WATER RESERVOIR			
	For Standard Station		Fiber Reinforced Prefabricated Panel Tank Assembly	
	Klender Station	1	Water Net Capacity: 7.0 m <sup>3</sup>	
	Cakung Station	1	steel common base w/ reinforced steel	
	Kranji Station	1	500 H x 400 W x 4 Lines.	
WR - 5	WATER RESERVOIR			
	For Standard Station		Fiber Reinforced Prefabricated Panel Tank Assembly	
	Klender Baru Station	1	Water Net Capacity: 4.5 m <sup>3</sup>	
	Kranji Station	1	steel common base w/ reinforced steel	
			500 H x 400 W x 4 Lines.	
WR - 6	WATER RESERVOIR			
	For Standard Station		Fiber Reinforced Prefabricated Panel Tank Assembly	
	Buaran Station	1	Water Net Capacity: 3 m <sup>3</sup>	
		<u>'</u>	steel common base w/reinforced steel	

Equipment Legend	Description	QTY	SPECIFICATION	REMARKS
			500 H x 400 W x 4 Lines.	
WR - 7	WATER RESERVOIR			
	For Standard Station	1	Fiber Reinforced Prefabricated Panel Tank Assembly	
	Bekasi Station	<del></del>	Water Net Capacity, 38.8 m <sup>3</sup>	
	:		steel common base w/reinforced steel	
			500 H x 400 W x 4 Lines.	
WR - 8	WATER RESERVOIR		Water Reservoir Under Ground Construction by	
	For Standard Station	t	Architectur work	
	Jatinegara Operation Center		Water Capasity : 37 m <sup>3</sup>	
	!		6 m (L) x 4 m (w) devided 3 tank x 2.3 m (H)	*****
			total. inside ladder, man hole and sand separator	
WR - 9	WATER RESERVOIR		Water Reservoir Under Ground Construction by	
	For Standard Station	1	Architectur work	
	Coach Depot Cipinang		Water Capasity : 355 m <sup>3</sup>	
			20 m (L) x 9 m (w) devided 3 tank x 2.5 m (H)	
			total. inside ladder, man hole and sand separator	
WTU - 1	WASTE TREATMENT UNIT		Waste Treatment Unit, under Ground Construction	
	For Manggarai Station	1	Protected Reinforced Slab/ Coloumn/ Floor	
			Treated Water Capacity: 81 m <sup>3</sup> / day	
			Dischaged BOD : 10 PPM	
			Equalization, Aeration, Backwash Blowers,	
			Discharged Pit and Submersible Sewage 2 Pumps	
			Automatic Control Panel and Compeleted Devices	
WTU - 2	WASTE TREATMENT UNIT		Waste Treatment Unit, under Ground Construction	
	For Bekasi Station	1	Protected Reinforced Slab/ Coloumn/ Floor	
			Treated Water Capacity: 55.5 m³ / day	
			Dischaged BOD : 20 PPM	
			Equalization/ Aeration/ Backwash Blowers,	
			Discharged Pit and Submersible Sewage 2 Pumps	
			Automatic Control Panel and Completed Devices	
WTU - 3	WASTE TREATMENT UNIT	,	Waste Treatment Unit, under Ground Construction	
	For Jatinegara Operation Center	1	Protected Reinforced Slab/ Coloumn/ Floor	
			Treated Water Capacity: 51.88 m <sup>2</sup> / day	
			Dischaged BOD : 10 PPM	
			Equalization/ Aeration/ Backwash Blowers,	
			Discharged Pit and Submersible Sewage 2 Pumps	
• • • • • • • • • • • • • • • • • • • •			Automatic Control Panel and Completed Devices	
WTU - 4	WASTE TREATMENT UNIT		Waste Treatment Unit, under Ground Construction	
	For Jatinegara Station	1	Protected Reinforced Slab/ Coloumn/ Floor	
	V		Treated Water Capacity: 27.5 m <sup>3</sup> / day	
		<u>:</u> 	Dischaged BOD : 10 PPM	
			Equalization/ Aeration/ Backwash Blowers,	
			Discharged Pit and Submersible Sewage 2 Pumps	
			Automatic Control Panel and Completed Devices	

The Railway Electrification and Double - double Tracking of Java Main Line Project



This detailed design has been executed by a team of consultants as shown below in accordance with the agreement between Japon International Cooperation Agency (JEA) and JEA Study Team.

The copyright of this drawing tests with JICA.

Designed by:

Japan International Cooperation ( Agency (JICA)

JICA Study Team:

Joint Venture of Pacific Consultants International and Japan Railway Technical Service

MECHANICAL

GENERAL

**DATE** 14/Jan/2005

Drawing Title :

EQUIPMENT SCHEDULE (11)

Scale: A3/NTS

#### EQUIPMENT SCHEDULE LIST ( 12 )

Equipment Legend	Description	QTY	SPECIFICATION	REMARKS
WTU-5	WASTE TREATMENT UNIT		Waste Treatment Unit, under Ground Construction	
	For Locomotic Adm. Building	1	Protected Reinforced Slab/ Coloumn/ Floor	
			Treated Water Capacity: 21.87 m³ / day	
			Dischaged BOD : 20 PPM	
			Equalization/ Aeration/ Backwash Blowers,	
	- Control of the Cont		Discharged Pit and Submersible Sewage 2 Pumps	
			Automatic Control Panel and Completed Devices	
WTU-6	WASTE TREATMENT UNIT		Waste Treatment Unit, under Ground Construction	
	For Coach Inspection	1	Protected Reinforced Slab/ Coloumn/ Floor	
	·		Treated Water Capacity: 15.39 m³ / day	
			Dischaged BOD : 20 PPM	
	**************************************		Equalization/ Aeration/ Backwash Blowers,	
			Discharged Pit and Submersible Sewage 2 Pumps	
			Automatic Control Panel and Completed Devices	
14	NAME OF THE ATTACK		Waste Treatment Unit, under Ground Construction	
WTU-7	WASTE TREATMENT UNIT	1	Protected Reinforced Slab/ Colourn/ Floor	
	For Standar Station	I	<u> </u>	
	Cakung Station		Treated Water Capacity: 12.48 m³ / day	
	Kranji Station		Dischaged BOD : 20 PPM	
		· 	Equalization/ Aeration/ Backwash Blowers,	<u> </u>
			Discharged Pit and Submersible Sewage 2 Pumps	<del> </del>
			Automatic Control Panel and Completed Devices	
WTU-8	WASTE TREATMENT UNIT		Waste Treatment Unit, under Ground Construction	
	For Standar Station	1	Protected Reinforced Slab/ Coloumn/ Floor	
	Klender Station		Treated Water Capacity: 11.2 m³ / day	
			Dischaged BOD : 20 PPM	
			Equalization/ Aeration/ Backwash Blowers.	
			Discharged Pit and Submersible Sewage 2 Pumps	
			Automatic Control Panel and Completed Devices	
WTU - 9	WASTE TREATMENT UNIT		Waste Treatment Unit, under Ground Construction	
	For Standar Station		Protected Reinforced Slab/ Coloumn/ Floor	
	Buaran Station	1	Treated Water Capacity: 5.4 m³ / day	
	Matraman Station	1	Dischaged BOD : 20 PPM	
			Equalization/ Aeration/ Backwash Blowers,	
			Discharged Pit and Submersible Sewage 2 Pumps	
			Automatic Control Panel and Completed Devices	
WTU - 10	WASTE TREATMENT UNIT		Waste Treatment Unit, under Ground Construction	
	For Standar Station		Protected Reinforced Slab/ Coloumn/ Floor	
	Jatinegara Station Old. Building	1	Treated Water Capacity: 4 m <sup>3</sup> / day	
	For Bridge Maint. Cipinang Yard	1	Dischaged BOD : 20 PPM	Cipinang Yard
		·	Equalization/ Aeration/ Backwash Blowers,	
······································			Discharged Pit and Submersible Sewage 2 Pumps	
				-
			Automatic Control Panel and Completed Devices	

Equipment Legend	Description	QTY	SPECIFICATION	REMARKS
WTU - 11	WASTE TREATMENT UNIT			
	For Standar Station			
	Bekasi Station			
	Watchman shed	1	Waste Treatment Unit, under Ground Construction	
	Telcom. Equipment Room	1	Protected Reinforced Slab/ Coloumn/ Floor	
	Signal Cabin	1	Treated Water Capacity: 1.6 m <sup>3</sup> / day	
	Buaran Station		Dischaged BOD : 35 PPM	
	Substation	1	Equalization/ Aeration/ Backwash Blowers,	
	Jatinegara Station		Discharged Pit and Submersible Sewage 2 Pumps	
	Watchman Shed	1	Automatic Control Panel and Completed Devices	
	Signal Cabin	2		
	Telcom. Equipment Room	1		
	Klender and Cakung Station		A STATE OF THE STA	
	Watchman Shed	2		
	Manggarai Station			
22 (1964)	Signal Cabin	1		
	Gate House Cipinang Yard	1		
MWT - 1	MAKE UP WATER TANK	······································		
***	For Manggarai Station	1	Pressure tank for Expansion Chiller Water	
	For Jatinegara Station	1	Cap. 100 Liter / min	
	For Bekasi Station	1	mid steel, c/w acessories and pressure switch	
MWT - 2	MAKE UP WATER TANK			
	For Jatinegara Operation Center	1	Gravity tank for Expansion Chiller Water	
<u></u>	For Cipinang Administration Building		Cap. 400 Liter / min	
m*1.			FRD, c/w valve and acessories	Cipinang Yar
IC - 01	INCINERATOR		Canadity 70 kg (am	
	For Coach Depot Cipinang	1	Capacity: 70 kg / cm	Cipinang Yard
	For Coach Depot Cipinang		including fuel tank capacity 4000 Liter	Olphiang rate
			and fuel supply system	
IC - 02	INCINERATOR		Capacity: 47 kg / cm	
	For Manggarai Station	1	including fuel tank capacity 4000 Liter	
	www.windows.win.		and fuel supply system	
IC - 01	INCINERATOR		Capacity: 35 kg / cm	
	For Bekasi Station		including fuel tank capacity 4000 Liter	
		1	and fuel supply system	
10 04	INCINEDATOR	<u></u>	0	
C - 01	INCINERATOR  For letinogera Station	1	Capacity: 20 kg / cm	
	For Jatinegara Station	<u>'</u>	including fuel tank capacity 4000 Liter and fuel supply system	
			l in	
ECH	ELECTRIC WATER HEATER For Cipinang Admin. Building	1	Tank Capacity: 200 Lt (60 <sup>0</sup> C Hot Water)  Power: 1.2 kw/ 1 Ph/ 220 V	Cipinang Yar

The Railway Electrification and Double - double Tracking of Java Main Line Project



Note:

This detailed design has been executed by a team of carealitants as shown below in accordance with the agreement between Japon International Cooperation Agencary (JCA) and JICA Study Team.

The copyright of this drawing rests with JICA.

Designed by:

Japan International Cooperation Agency (JICA)

JICA Study Team:

Joint Venture of Pacific Consultants International and Japan Railway Technical Service

MECHANICAL

GENERAL


DATE


14/Jan/2005


Drawing Title :


EQUIPMENT SCHEDULE ( 12 )


Soulo: A3/NTS







































#### SCHEMATIC DIAGRAM AC / VENTILATING SYSTEM

The Railway Electrification and Double - double Tracking of Java Main Line Project





Note:

This detailed design has been executed by a team of consultants as shown below in accordance with the agreement between Japan international Cooperation Agamacy (JICA) and JICA Study Team.

The copyright of this drawing rests with JICA.

Designed by:

Japan International Cooperation Agency (JICA)

JICA Study Team:

Joint Venture of Pacific Consultants International and Japan Railway Technical Service

MECHANICAL

MATRAMAN STATION

DATE 29/Dec/2004

Drawing Title :

SCHEMATIC DIAGRAM AC / VENTILATING AND PIPING SYSTEM

Scale: Drowing A

AM - 02 - 001

