

Contents of Technical Assistance (Soft Component)

The contents of activities in the Soft Component are as follows.

1. Guidance in water treatment process management technology

The contents of guidance are as follows. Lectures with practical training will be given to the trainees since lectures alone may not raise the trainees' motivation.

- a. Preparation of training texts in Japan
- b. Accurate grasp of the current technical level and problems in water treatment process
- c. Lecture on theory and control techniques of water treatment process
- d. Practical training in water quality control and water treatment process operation
- e. Preparation of standard form for inputting water quality data

2. Guidance in data-based maintenance technology

The contents of guidance are as follows;

- a. Outline explanation of the monitoring system
- b. Guidance in data processing methods
- c. Technical guidance concerning information utilization



M. A. B. S. S. S.

g *DS*

Works undertaken by NOPWASD About Monitoring System

1. The Egyptian side shall supply and install the following measuring equipments with required cables and a terminal box for detecting flow rate and residual chlorine concentration of the treated water from the existing water treatment plant.

- Flow meter (detector)
- Residual chlorine concentration meter (detector)

The Japanese side shall connect the terminal box, which shall be installed near by the above equipments, to the monitoring panel in the proposed electrical room.



2. The Egyptian side shall provide a personal computer with incidental accessories such as a printer and UPS. The personal computer shall be pre-installed type with necessary software such as Windows. The personal computer will be used for processing of the measured data and displaying and printing the processed data for operating and maintenance use of the water treatment plant. The items supplied by the Egyptian side shall be as follows.

- Personal computer
- Printer
- UPS (Uninterruptible Power Supply) Unit
- OS (Operating system) of Windows XP of compatible English and Arabic
- Standard application software of Office



M. Beshir
OS


ed. o. Desheta
50



MKWP-01 General Layout


[Handwritten signature]

SECTION OF EL MALLAH CANAL AT WATER INTAKE FACILITY



wh.o. peshta
S.O

PLAN OF WATER INTAKE FACILITY



h. h.

Appendix-5 Soil Survey

Bahr Engineering Consultant Office,

BECO

Prof. Mohamed Awad Bahr

TECHNICAL SOIL REPORT
for
Upgrading El Mahala Water Treatment Plant
El Mahala El Kobra - Gharbeya

Yachiyo Engineering CO., LTD - Engineering Consultants

C/O: Scientific Office for Engineering

Design & Surveying, **CADEC - A**

Prof. Ayman Soliman Aguib

September 2005

Contents:

1. Introduction.
2. The Site.
3. Borehole Drilling and Soil Sampling.
4. Testing.
 - 4.1 In-situ Testing.
 - 4.2 Laboratory Testing
 - 4.2.1 Soil Classification Tests.
 - 4.2.2 Soil Strength Test.
 - 4.3 Chemical Analysis Tests.
5. Geological Background and Subsurface Soil Conditions.
6. Groundwater.
7. Recommendations.
8. General Precautions.

Tables:

- Water Analysis, Table (1)

Figures:

- General Layout & Location of Boreholes, Fig. (1)
- Soil Logs, Figs. (2-1 to 2-5)
- Grain Size Distribution Curves, Figs. (2-1 to 2-5)

1. Introduction

This report is presented at the request of Yachiyo Engineering Co., LTD. The soil investigation was carried out at the site of El Mahala El Kobra Water Treatment Plant. The soil investigation was carried out by drilling Five boreholes 30m deep. Soil boring was carried out by mechanical means using rotary drilling by a professional soil drilling contractor under our supervision.

Visual inspection of soil samples recovered from different boreholes together with required laboratory tests were performed. Based on the outcome of the geotechnical investigation, our recommendations with respect to the soil formation at the site and other geotechnical construction considerations are presented.

2. The Site

The site under investigation is the existing El Mahala El Kobra Water Treatment Plant at El Mahala El Kobra, Gharbya, Egypt . The study under investigation concerns the areas selected for the intake facilities and the new water treatment plant.

3. Boreholes Drilling and Soil Sampling

Five Boreholes were carried out 30 m deep. Two boreholes were carried out at the location of the new intake facilities, and three boreholes were carried out at the location of the new water treatment plant. The location of boreholes are shown on the general layout of the plant, refer to fig. (1). The boreholes locations were decided by Yachiyo Engineering Co., LTD. Undisturbed samples were obtained wherever the cohesive clay is existed, and disturbed samples were obtained wherever the silty and sandy soils are existed.

المكتب الهندسي الياباني للاستشارات
والقوى الهندسية
رقم الترخيص: ٥٠١٤٨٥١
بغداد، العراق
١٩٦٦

4. Testing

4.1 In - Situ Testing

The standard Penetration Test (SPT) was performed during soil boring according to the Egyptian geotechnical code of practice regulations. The results of the tests are shown on soil logs, refer to figures (2-1 to 2-5).

4.2. Laboratory Testing

An extensive laboratory testing program was developed to determine the physical and mechanical properties of different soil layers encountered at the site. Gradation tests and Atterberg limits were performed to identify soil constituents. Unconfined compression tests were performed for evaluation of the strength characteristics of surface clayey soil encountered at the site.

4.2.1 Soil Classification Tests

Gradation tests were performed to the different soil layers encountered at the site. The grain-size distribution curves are shown in figures (3-1 to 3-5). Bulk density, specific gravity, natural water content, and Atterberg limits were determined for cohesive soil. The results are shown on soil logs of figures (2-1 to 2-5). The tests were performed during soil boring according to the Egyptian geotechnical code of practice regulations.

4.2.2 Soil Strength tests

Unconfined compression tests were performed on five samples taken from the shallow layer of dark brown silty clay. The results of the tests are shown in figures (2-1 to 2-5). The results of the tests show that the clay at shallow depths is stiff to very stiff and the unconfined compression strength is in the range of 157 - 240 kN/m². The test was performed according to the Egyptian geotechnical code of practice regulations.

التحليل الهندسي والاستشارات
والقوى
رقم الترخيص ٥١٩٨٥١
استشارات

4.3. Chemical Analysis Tests

pH tests as well as elusion tests were performed on three soil and water samples taken at about 1-2m depth from the ground surface. One sample was taken from the area of new intake facilities (B.H. 2) and two samples were taken from the area of new water treatment plant (B.H. 3 and B.H.4). The elusion was determined in terms of chloride ions CL^- and sulphate ions SO_4^{2-} . The tests were performed at the Micro Analytical Center. The results of the chemical analysis are given in table (1). The high sulphate contents enhances the using of sulphate resistant Portland cement for all foundations construction.

Table (1) Chemical Analysis Results

Sample No.	B.H. No.	pH	Chlorides CL^-	Sulphates SO_4^{2-}
1	2	8.71	Nil	1750
2	3	8.16	Nil	1400
3	4	8.26	Nil	1340

5. Geological Background and Subsurface Soil Conditions

The subsurface soil profile has been interpreted from the borings and the detailed boring logs are shown in figures (2-1 to 2-5). The soil formation at the site is the typical Nile deposit of the Nile Delta. The top soil is agricultural soil of silt, sand and stones. It extends to about 1.0m to 3.5m below the existing ground surface. The top soil followed by brown medium to very stiff silty clay. It extends 6.0m to 11.5 m. below the top soil. The results of consistency limits and gradation tests show that the clay is active. The results of the unconfined compression tests carried out on undisturbed samples extracted at a depth below the ground water table show that the unconfined compressive strength for this clay ranges between 157 to 240 KN/m^2 . A layer of organic grayish brown silt and fine sand with trace of clay underlies the top layer of silty clay. The layer extends 1.5m. to 5.5m. below

الخبير الاستشاري للمباني والاساس والارضيات
 المهندس محمد فوزي محمد
 رقم الترخيص 019851
 استضاف 1995


medium sand with minimum penetration depth equals to 2.0 in this layer. Friction - end bearing piles are to be considered in the evaluation of allowable pile capacity.

7 General Precautions

- 1) In case the required foundation level lies below the groundwater table, lowering of groundwater level is carried out using surface dewatering techniques.
- 2) Sulphate resistant Portland cement is used for foundations. The cement content shall not be less than 350 kg per cubic meter for reinforced concrete, and not less than 250 kg per cubic meter for plain concrete.
- 3) The exposed faces of footings, tie beams, and pedestals are to be coated with three coats of oxidized bituminous material.
- 4) Concrete cover for footings is 5 cm.

Consultant Engineer

المهندس الاستشاري
المهندس محمد عوض محمد
رقم الترخيص: 019885
التوقيع: 1/12/15



Prof. Mohamed Awad Bahr




Fig. (1) General Layout and Boreholes Locations

المكتبة العامة
 رقم التسجيل: 0151010
 رقم الصنف: 1418



El Mahala El Kobra Water Treatment Plant.
Intake Facilities - Upgrading Project.
Gharbeya - Egypt


Bahr Engineering Consultant Office
BECO
Prof. Dr. Mohamed Awad Bahr

Boring No. (1)

Test Results

Initial Ground Water Table, IGWT =
Final Ground Water Table, FGWT = -2.80
Ground Surface, GS

N	$\frac{\Sigma d}{qu}$	wc	wl	wp	Gs/ <2u
	$\frac{kN}{m^3}$	%	%	%	
	$\frac{kN}{m^2}$				
	1.25	43	102	37	2.75
	220				75
23					
22					
19					
37					
40					
	51/10cm				
	51/7cm				



End of Boring

المكتب الهندسي الاستشاري للمياه والري
م. محمد عوض
م. أحمد / م. محمد / م. محمد
م. محمد / م. محمد / م. محمد
1/1919
015555

Fig. (2-1)

El Mahala El Kobra Water Treatment Plant.
Intake Facilities - Upgrading Project.
Gharbeya - Egypt

Bahr Engineering Consultant Office
BECCO
Prof. Dr. Mohamed Awad Bahr

Boring No. (2)

Test Results

Initial Ground Water Table, IGWT =

Final Ground Water Table, FGWT = -0.75m from G.S
Ground Surface, GS

N	$\sum d$ qu	wc	wl	wp	Gs/ 2u
	$\frac{kN}{m^3}$ $\frac{kN}{m^2}$	%	%	%	
18	145 157	33	55	21	2.7 42
22					
28					
34					
37					
44					
51/ 14cm					
51/ 8cm					




Fig. (2-2)

El Mahala El Kobra Water Treatment Plant.
 New Water Treatment Plant- Upgrading Project.
 Gharbeya - Egypt


Bahr Engineering Consultant Office
BECCO
 Prof. Dr. Mohamed Awad Bahr

Boring No. (3)

Test Results

Initial Ground Water Table, IGWT =

Final Ground Water Table, FGWT = -0.4m from G.S.
 Ground Surface, GS



N	$\sum d$ qu	wc	wl	wp	Gs/ k2u
	kN /m ³ kN /m ²	%	%	%	
19					
	1.50 180	32	45	21	2.68 35
22					
28					
44					
44					
47					
51/ 18cm					
51/ 8cm					

المكتب الهندسي الاستشاري للمباني والاساس والرياح
 المهندس محمد عبد الحليم
 رقم الترخيص: 015851
 استشاري
 1996

Fig. (2-3)

El Mahala El Kobra Water Treatment Plant.
 New Water Treatment Plant- Upgrading Project.
 Gharbeya - Egypt

Bahr Engineering Consultant Office

BECD


Prof. Dr. Mohamed Awad Bahr

Boring No. (4)

Test Results

Initial Ground Water Table, IGWT =

Final Ground Water Table, FGWT = - 1.10 m from G.S.
 Ground Surface, GS



N	$\frac{\Delta d}{qu}$	wc	wl	wp	Gs/ (2u)
	$\frac{kN}{m^3}$ $\frac{kN}{m^2}$	%	%	%	
19					
21	1.50 180	32	61	22	2.68 46
27					
32					
46					
47					
51/19cm					
51/10cm					

المكتب الهندسي الاستشاري للمياه والبيئة
 الدكتور محمد قنبر
 استشاري
 رقم الترخيص: ٥١٩٨٥٠
 ٢٠١٦/١١/١٥

Fig. (2-4)

El Mahala El Kobra Water Treatment Plant.
 New Water Treatment Plant- Upgrading Project.
 Gharbeya - Egypt

Bahr Engineering Consultant Office

BECO


Prof. Dr. Mohamed Awad Bahr

Boring No. (5)

Test Results

Initial Ground Water Table, IGWT = miss measure
 Final Ground Water Table, FGWT = 1.1m
 Ground Surface, GS

N	$\frac{\sum d}{qu}$	wc	wl	wp	Gs/ <2u
	$\frac{kN}{m^3}$	%	%	%	
	$\frac{kN}{m^2}$				
19					
22	$\frac{1.58}{240}$	31	68	21	$\frac{2.68}{46}$
28					
33					
32					
47					
51/					
18cm					
51/					
8cm					



Handwritten signature


المكتب الهندسي الاستشاري للأساس والبناء
 الأستاذ الدكتور محمد عوض باهر
 رقم الترخيص: 019885
 مستشار: 1/1875

Fig. (2-5)

El Mahala New Water Treatment Plant,
 C/O: Yachiyo Eng. Co., LTD
 El Mahala El Kobra, Gharbya, Egypt

Consultant Engineer
 Prof. Mohamed A. Bahr
 BECO

Boring No. (1)



Curve No.	1	2	3			
Depth, m	-4	-16	-22			

(Handwritten signature)


Fig. (3-1) Grading Curves.

المكتب الهندسي الاستشاري للمياه والري
 الأستاذ الدكتور محمد عبد الباقى
 رقم الترخيص: ٥١٢٨٥١
 استشارته: ١/١٥٦٥

El Mahala New Water Treatment Plant.,
 C/O: Yachiyo Eng. Co., LTD
 El Mahala El Kobra, Gharbya, Egypt

Consultant Engineer
 Prof. Mohamed A. Bahr
BECO

Boring No. (2)



Curve No.	1	2	3			
Depth, m	-4	-15	-26			

(Handwritten signature)


Fig. (3-2) Grading Curves.

المهندس محمد أحمد الباهر
 المهندس الاستشاري
 رقم الترخيص: ٥٠١٤٨٥٠
 بتاريخ: ١١/٦/٢٠١٥

El Mahala New Water Treatment Plant,
 C/O: Yachiyo Eng. Co., LTD
 El Mahala El Kobra, Gharbya, Egypt

Consultant Engineer
 Prof. Mohamed A. Bahr
 BECO

Boring No. (3)




Curve No.	1	2	3			
Depth, m	-4	-17	-26			

Fig. (3-3) Grading Curves.

المكتب الهندسي الاستشاري للأستاذة والهندسة
 الدكتور محمد أحمد باهر
 رقم الترخيص: ٥١٢٨٥١
 استشاري: ١/١٥٦٥

Boring No. (4)



Curve No.	1	2	3			
Depth, m	-5	-16	-26			

(Handwritten signature)


Fig. (3-4) Grading Curves.

المكتب الهندسي الاستشاري للمياه والبيئة
 الدكتور محمد أحمد باهر
 رقم الترخيص: ٥١٦٨٤٤
 ستشارك: ١١٥٦٥

El Mahala New Water Treatment Plant,
 C/O: Yachiyo Eng. Co., LTD
 El Mahala El Kobra, Gharbya, Egypt

Consultant Engineer
 Prof. Mohamed A. Bahr
 BECO

Boring No. (5)




Curve No.	1	2	3		
Depth, m	-5	-16	-26		

Fig. (3-5) Grading Curves.

المكتب الهندسي الاستشاري للأبنية والرياحات
 المهندس محمد أحمد باهر
 رقم الترخيص: ١١٥٨٥
 رقم الهاتف: ١١٥٦٥

Appendix-6 Topographic Survey





X-Section A-A

