



2025 Sri Lankan System
P.E. ANALYSIS/2025 NIGHT PEAK
WED FEB 05 2025 14:37
Branch: MATARA (P)
Equipment: MATARA
RV: +40.000 -100.000 +100.000 +100.000



2025 Sri Lankan System
P.F. ANALYSIS 2025 DAY PEAK
WED, FEB 08, 2025 14:37
Bus: VOLTAGE (KVP) 110KV
Equipment: MW/MBANK



N-1 Checking based on 2025_Night_Peak

1. Branches and Tie Lines

Monitored Elements	Base Flow	Maximum Flow	Impact	Rate	%	Contingency	Countermeasures
1570 BIYAG-1 132.00 1590 SAPUGA-1 132.00 1	155.03	284.2	285.39	225	126.8%	OPEN LINE FROM BUS 1570 [BIYAG-1 132.00] TO BUS 1590 [SAPUGA-1 132.00] CKT 2	switching off lines: Bivagama - Sapugaukanda
1570 BIYAG-1 132.00 1590 SAPUGA-1 132.00 2	155.03	284.2	285.39	225	126.8%	OPEN LINE FROM BUS 1570 [BIYAG-1 132.00] TO BUS 1590 [SAPUGA-1 132.00] CKT 1	switching off lines: Bivagama - Sapugaukanda
1950 NCHW 132.00 6290 NATTAN 132.00 1	149.16	244.26	250.33	225	111.3%	OPEN LINE FROM BUS 1950 [NCHW 132.00] CKT 2	switching off lines: N.Chilaw - Nattandiya
1950 NCHW 132.00 6290 NATTAN 132.00 2	149.16	244.26	250.33	225	111.3%	OPEN LINE FROM BUS 1950 [NCHW 132.00] CKT 1	switching off lines: N.Chilaw - Nattandiya
1640 DENY-1 132.00 5641 DENY-T1 132.00 1	42.16	82.32	87.59	80	109.5%	OPEN LINE FROM BUS 1640 [DENY-1 132.00] TO BUS 5642 [DENY-T2 132.00] CKT 2	switching over is effective
1640 DENY-1 132.00 5642 DENY-T2 132.00 2	42.16	82.32	87.59	80	109.5%	OPEN LINE FROM BUS 1640 [DENY-1 132.00] TO BUS 5641 [DENY-T1 132.00] CKT 1	switching over is effective
1710 TRINC-1 132.00 6140 GALENB 132.00 1	65.84	103.83	107.76	100	107.8%	OPEN LINE FROM BUS 1710 [TRINC-1 132.00] TO BUS 6140 [GALENB 132.00] CKT 2	switching over is effective
1710 TRINC-1 132.00 6140 GALENB 132.00 2	65.84	103.83	107.76	100	107.8%	OPEN LINE FROM BUS 1710 [TRINC-1 132.00] TO BUS 6140 [GALENB 132.00] CKT 1	switching over is effective
2580 KOTUG-2 220.00 5581 KOTU-DU1 220.00	201.53		265.12	250	106.0%	OPEN Transformer Unit2	switching over is effective
2580 KOTUG-2 220.00 5582 KOTU-DU2 220.00	201.53		265.12	250	106.0%	OPEN Transformer Unit3	switching over is effective
1130 POLPI-1 132.00 6380 ANGUR 132.00 1	63.49	92.87	93.85	100	93.9%	OPEN LINE FROM BUS 1130 [POLPI-1 132.00] TO BUS 6380 [ANGUR 132.00] CKT 2	-
1130 POLPI-1 132.00 6380 ANGUR 132.00 2	63.49	92.87	93.85	100	93.9%	OPEN LINE FROM BUS 1130 [POLPI-1 132.00] TO BUS 6380 [ANGUR 132.00] CKT 1	-
1100 LAX-1 132.00 1120 WIMAL-1 132.00 1	44.23	88.24	90.19	100	90.2%	OPEN LINE FROM BUS 1100 [LAX-1 132.00] TO BUS 1120 [WIMAL-1 132.00] CKT 2	-
1100 LAX-1 132.00 1120 WIMAL-1 132.00 2	44.23	88.24	90.19	100	90.2%	OPEN LINE FROM BUS 1100 [LAX-1 132.00] CKT 1	-
1680 KURUN-1 132.00 1770 KIRIB-1 132.00 1	41.19	82.64	89.39	100	89.4%	OPEN LINE FROM BUS 1680 [KURUN-1 132.00] TO BUS 1770 [KIRIB-1 132.00] CKT 2	-
1680 KURUN-1 132.00 1770 KIRIB-1 132.00 2	41.19	82.64	89.39	100	89.4%	OPEN LINE FROM BUS 1680 [KURUN-1 132.00] TO BUS 1770 [KIRIB-1 132.00] CKT 1	-

2. Voltage
220kV

Bus	Voltage	Contingency	Countermeasures
Nothing			

132kV

Bus	Voltage	Contingency	Countermeasures
Nothing			

N-1 Checking based on 2025_Day_Peak

3. Branches and Tie Lines

Monitored Elements	Base Flow	Maximum Flow	Impact Rate	%	Contingency	Countermeasures
1590 SAPUGA-1 132.00 1870 K_NIYA-1 132.00 1	123.61	224.22	223.35	135.4%	OPEN LINE FROM BUS 1590 [SAPUGA-1 132.00] TO BUS 1870 [K_NIYA-1 132.00] CKT 2	switching off lines: Sapugaskanda – Kelaniya
1590 SAPUGA-1 132.00 1870 K_NIYA-1 132.00 2	123.61	224.22	223.35	135.4%	OPEN LINE FROM BUS 1590 [SAPUGA-1 132.00] TO BUS 1870 [K_NIYA-1 132.00] CKT 1	switching off lines: Sapugaskanda – Kelaniya
1110 N-LAX-1 132.00 1130 POLPI-1 132.00 1	41.98	56.05	56.05	124.6%	OPEN LINE FROM BUS 1110 [N-LAX-1 132.00] TO BUS 1130 [POLPI-1 132.00] CKT 2	switching off lines: Laxapana – N_Laxapana
1110 N-LAX-1 132.00 1130 POLPI-1 132.00 2	41.98	56.05	56.05	124.6%	OPEN LINE FROM BUS 1110 [N-LAX-1 132.00] TO BUS 1130 [POLPI-1 132.00] CKT 1	switching off lines: Laxapana – N_Laxapana
1710 TRINC-1 132.00 6140 GALENB 132.00 1	34.28	53.99	54.27	120.6%	OPEN LINE FROM BUS 1710 [TRINC-1 132.00] TO BUS 6140 [GALENB 132.00] CKT 2	switching off lines: Trincomalee – Galenbindunnuwewa
1710 TRINC-1 132.00 6140 GALENB 132.00 2	34.28	53.99	54.27	120.6%	OPEN LINE FROM BUS 1710 [TRINC-1 132.00] TO BUS 6140 [GALENB 132.00] CKT 1	switching off lines: Trincomalee – Galenbindunnuwewa
1570 BIYAG-1 132.00 1590 SAPUGA-1 132.00 1	108.05	197.46	195.86	118.7%	OPEN LINE FROM BUS 1570 [BIYAG-1 132.00] TO BUS 1590 [SAPUGA-1 132.00] CKT 2	switching off lines: Sapugaskanda – Biyagama
1570 BIYAG-1 132.00 1590 SAPUGA-1 132.00 2	108.05	197.46	195.86	118.7%	OPEN LINE FROM BUS 1570 [BIYAG-1 132.00] TO BUS 1590 [SAPUGA-1 132.00] CKT 1	switching off lines: Sapugaskanda – Biyagama
1680 KURUN-1 132.00 1770 KIRIB-1 132.00 1	25	49.77	49.34	109.6%	OPEN LINE FROM BUS 1680 [KURUN-1 132.00] TO BUS 1770 [KIRIB-1 132.00] CKT 2	switching over is effective
1680 KURUN-1 132.00 1770 KIRIB-1 132.00 2	25	49.77	49.34	109.6%	OPEN LINE FROM BUS 1680 [KURUN-1 132.00] TO BUS 1770 [KIRIB-1 132.00] CKT 1	switching over is effective
1640 DENY-1 132.00 5641 DENY-T1 132.00 1	20.96	42.02	42.81	107.0%	OPEN LINE FROM BUS 1640 [DENY-1 132.00] TO BUS 5642 [DENY-T2 132.00] CKT 2	switching over is effective
1640 DENY-1 132.00 5642 DENY-T2 132.00 2	20.96	42.02	42.81	107.0%	OPEN LINE FROM BUS 1640 [DENY-1 132.00] TO BUS 5641 [DENY-T1 132.00] CKT 1	switching over is effective
2580 KOTUG-2 220.00 5581 KOTU-DU1 220.00	180.48	266.43	266.43	106.6%	OPEN LINE FROM BUS 1580 [KOTUG-1 132.00] TO BUS 5582 [KOTU-DU2 220.00] CKT 1	switching over is effective
2580 KOTUG-2 220.00 5582 KOTU-DU2 220.00	180.48	266.43	266.43	106.6%	OPEN LINE FROM BUS 1580 [KOTUG-1 132.00] TO BUS 5581 [KOTU-DU1 220.00] CKT 1	switching over is effective
2580 KOTUG-2 220.00 5583 KOTU-DU3 220.00	180.48	266.43	266.43	106.6%	OPEN LINE FROM BUS 1580 [KOTUG-1 132.00] TO BUS 5581 [KOTU-DU1 220.00] CKT 1	switching over is effective
1130 POLPI-1 132.00 1510 SITHA-1 132.00 1	129.94	175.23	175.23	106.2%	OPEN LINE FROM BUS 1130 [POLPI-1 132.00] TO BUS 5502 [KOSG-IT2 132.00] CKT 1	switching over is effective
1670 MATARA-1 132.00 6010 WELIGA 132.00 1	90.67	165.69	165.69	100.4%	OPEN LINE FROM BUS 1670 [MATARA-1 132.00] TO BUS 6010 [WELIGA 132.00] CKT 2	switching over is effective
1670 MATARA-1 132.00 6010 WELIGA 132.00 2	90.67	165.69	165.69	100.4%	OPEN LINE FROM BUS 1670 [MATARA-1 132.00] TO BUS 6010 [WELIGA 132.00] CKT 1	switching over is effective
1650 GALLE-1 132.00 1990 BADDE 132.00 1	88.69	161.63	164.01	99.4%	-	-

4. Voltage
220kV

Bus	Voltage	Contingency	Countermeasures
Nothing			

132kV

Bus	Voltage	Contingency	Countermeasures
Nothing			

Generation Dispatch Schedule

Site	2010			2015			2020			2025			Year COM	Retirement Year	
	NP	DP	OP	NP	DP	OP	NP	DP	OP	NP	DP	OP			
	Old Laxapana	50	25	25	0	50	25	0	50	25	0	50			25
New Laxapana	100	50	50	0	100	50	0	100	50	0	100	50	0		
Wimalasurendra	25	0	0	25	25	0	0	25	25	0	0	0	0		
Polpitiya	75	37.5	37.5	0	75	37.5	0	75	37.5	0	75	37.5	37.5		
Canyon	0	0	0	0	30	0	0	30	0	0	0	0	0		
Ampara	75	0	0	75	75	0	0	75	0	0	75	0	0		
Samanalawewa	120	60	60	60	120	60	60	120	60	60	120	60	60		
Ukuwela	19	0	0	19	19	19	19	19	19	19	19	19	19		
Bowaterma	0	0	0	11	0	0	0	11	0	0	11	0	0		
Kelaniya_GT7	115	115	0	0	0	0	0	0	0	0	0	0	0		
Sapugaskanda Diesel_1-4	72	72	72	0	0	0	0	0	0	0	0	0	0		2013
Sapugaskanda Diesel_5-12	36	36	0	36	36	0	0	0	0	0	0	0	0		2023
Sapugaskanda Diesel_GT	0	0	0	0	0	0	0	0	0	0	0	0	0		
Kukule	70	35	35	35	70	35	35	70	35	35	70	35	35		2024
Lakdhanavi CEB	0	0	0	0	0	0	0	0	0	0	0	0	0		2024
Lakdhanavi IPP	22.5	0	0	0	51	0	0	0	0	0	0	0	0		2013
Asia Power (KHD)	51	0	0	51	0	0	0	0	0	0	0	0	0		2018
Galle	105	105	0	105	0	0	105	105	0	0	210	105	0	2009(105MW), 2021(105MW)	
ACE Embilipitiya	100	0	0	0	0	0	0	0	0	0	0	0	0		
CEB Matara	0	0	0	0	0	0	0	0	0	0	0	0	0		2015
Trincomalee GT	35	35	35	35	0	0	0	0	0	0	35	0	0		
Chunnakam	35	35	35	35	35	0	70	70	0	70	35	35	35	2010(105MW), 2020(105MW)	2009
Heladanavi IPP	100	100	0	0	0	0	0	0	0	0	0	0	0		2015
Heladanavi CEB	0	0	0	0	0	0	0	0	0	0	0	0	0		
Paddirippu	75	75	0	75	0	0	75	75	0	75	75	75	0		2010
Kotmale	130	65	65	130	65	65	130	65	65	130	65	65	0		
Colombo Power (Barge)	60	0	0	0	0	0	0	0	0	0	0	0	0		
Upper Kotmale	0	0	0	0	0	0	0	0	0	0	0	0	0		2011
Victoria	34.1	48	91.2	83.4	89	28.5	114.2	32.4	53.6	47.4	138	56.7	0		
Randenigala	60	60	60	60	60	60	60	60	60	60	60	60	0		
CEB Kelanitsa_CCGT	165	165	165	165	165	0	165	0	0	165	165	165	0		
AES Kelanitsa	163	163	0	0	0	0	0	0	0	0	0	0	0		2024
Kerawalapitiya_CCGT	300	300	300	300	300	150	300	300	150	300	300	150	2008(200MW), 2009(100MW)		
Kerawalapitiya_GT	210	105	0	210	105	0	210	105	0	315	105	0	2009(105MW), 2010(105MW), 2022(105MW)		
Pannupitiya	0	0	0	0	0	0	0	0	0	0	0	0	0		
ACE Horana	20	20	20	0	0	0	0	0	0	0	0	0	0		2013
ACE Matara	0	0	0	0	0	0	0	0	0	0	0	0	0		2012
Chunnakam CEB	0	0	0	0	0	0	0	0	0	0	0	0	0	2010(35MW), 2020(35MW)	
Ranembe	25	25	25	25	25	25	25	25	25	25	25	25	25		
Puttalam_Coal	0	0	0	600	600	550	1200	900	720	1800	900	1080	2011(600MW), 2012/2020/2021/2022/2023(300MW)		
Trincomalee_Coal	0	0	0	0	0	0	600	600	360	600	300	360	2017/2018/2019(300MW)		
Hambantota_Coal	0	0	0	900	600	550	1200	900	720	2100	1800	1200	2013/2014/2015/2016/2024(300MW), 2011(600MW)		

Reexamination of Construction Costs at New Hydro Power Project Sites

The projected construction costs at Moragolla, one of the candidate sites for a new hydro power project for the 2005-2019 long-term generation expansion plan (LTGEP), were reexamined in Chapter 6. Among the other candidate sites for development, Gin Ganga and Uma Oya are at the same pre-F/S survey stage as Moragolla. Although there is some need to reexamine the projected construction costs for these two sites in our survey, on the basis of the latest data, we have not discussed such reexaminations in this text, because we have chosen rather to emphasize the importance of changes in the development plan.

The CEB may, however conduct a comparative examination of construction costs in its internal review of and any resulting alterations to the Master Plan. We are therefore including as a reference the results of our reexamination of the projected construction costs for these two sites conducted as part of this survey.

(1) Method of Reexamination of Construction Costs

Our reexamination of the projected construction costs for the two sites used the construction cost estimates for the Broadlands site, made by JICA in its Hydro Power Optimization Study (Feb. 2004), in considering construction cost estimates for the two sites in the CEB's 1989 Master Plan survey. Both sites represent larger-scale developments than at the Broadlands site, and basic factors in calculating construction costs (construction methods, unit costs) may therefore differ, but we have not given this any special consideration.

(2) Results of Reexamination of Construction Costs

Our reexamination of costs found that construction costs for both projects will increase, but less than the escalation of costs in the 1992 calculations. This indicates that the increase in prices factored into the 1992 calculations was exaggerated relative to the real price base. In addition, local costs are affected by exchange rate fluctuations, and increases are therefore higher than foreign cost increases.

Construction cost for Ginganga Site (Basic Cost)				Units: million US\$
Year costs were calculated	Foreign	Local	Total	
1992	76.38	16.47	92.85	
2003	83.21	24.43	107.64	
Difference (%)	6.83(+8.4%)	7.96 (+48.3%)	14.79 (+15.9%)	

Note: "Local" represents the cost of the project multiplied by 0.9.

Construction cost for Uma Oya site (Basic Cost)				Units: million US\$
Year costs were calculated	Foreign	Local	Total	
1992	233.94	53.61	287.55	
2003	244.66	82.11	326.77	
Difference (%)	10.72(+4.6%)	28.5 (+53.2%)	39.22 (+13.6%)	

Note: "Local" represents the cost of the project multiplied by 0.9.

The costs of the LTGEP hydro power projects at the candidate sites are shown in the table below. In all cases the basic costs, including interest during the construction period, are lower than the previous estimates.

Plant	Source	Capacity (MW)	Construction Cost (mnUS\$)		Cost Basis	Exchange Rate (Rs/US\$)	New Exchange Rate (Rs/US\$)
			Foreign	Local			
Gin Ganga	[1]	49	83.21	24.43	Sep.2003	96	99.64
Broadlands	[2]	35	68.19	19.04	Sep.2003	96	99.64
Uma Oya	[3]	150	246.66	82.11	Sep.2003	96	99.64
Moragolla	[4]	27	58.69	15.89	Sep.2003	96	99.64

Source of information:

[1]** Masterplan project report GING074

[2] Hydro Power Optimization Study, February 2004

[3]** CECE Pre-feasibility Study July 1991

[4]** Masterplan project MAHW263

* updated in June 1992, Refer Page 10-2 of Kukule Feasibility Study Report(Vol-1)

** updated in this study, Refer Hydro Power Optimization Study, February 2004

Plant	Pure Capital Cost **(US\$/kW)			Constr. Period	IDC@10% (% of pure costs)	Cost Input WASP IV **(US\$/kW)		Total Cost **(US\$/kW)
	Foreign	Local	Total			Foreign	Incl.IDC	
Gin Ganga	1905.4	570.2	2475.7	5	23.78	2358.5	705.8	3064.4
Broadlands	2027.0	576.7	2603.7	4	18.53	2402.6	683.6	3086.2
Uma Oya	1761.1	597.5	2358.6	5	23.78	2179.9	739.6	2919.5
Moragolla	2438.9	673.2	3112.1	4	18.53	2890.8	797.9	3688.7

Uma Oya Cost Sheet(1/2)

September.2003

1US\$=96Rs.

Description	Unit	Quantity	Orice (US\$)		Amount (US\$)
			Foreign	Local	
A Preparatory Work					
1 Access Road				14,010,000	14,010,000
2 Brige across the river	L.S	1	9,649,000	3,217,000	12,866,000
3 Power Supply	L.S	1	668,000	222,000	890,000
4 Construction Camp	L.S	1		2,080,000	2,080,000
Total Prepartoty Work			10,317,000	19,529,000	29,846,000
B Environmental Mitigation					
3% of Civil Works			3,737,000	1,246,000	4,983,000
Total Environmental Mitigation			3,737,000	1,246,000	4,983,000
C Civil Works			124,562,000	41,522,000	166,084,000
1 Care of River					
Total			1,161,000	387,000	1,548,000
2 Dam					
Total			85,679,000	28,560,000	114,239,000
3 Intake					
Total			2,410,000	803,000	3,213,000
4 Headrace Tunnel					
4.1 Intake Tunnel					
Sub Total			193,000	64,000	257,000
4.2 Main Tunnnel					
Sub Total			23,479,000	7,826,000	31,305,000
Total			23,672,000	7,890,000	31,562,000
5 Surge Chamber					
Total			1,951,000	651,000	2,602,000
6 Penstock					
6.1 Tunnel					
Sub Total			2,068,000	690,000	2,758,000
6.2 Open					
Sub Total			1,343,000	448,000	1,791,000
Total			3,411,000	1,138,000	4,549,000
7 Powerhouse					
Total			5,173,000	1,725,000	6,898,000
8 Access tunnel					
Total			1,105,000	368,000	1,473,000

Uma Oya Cost Sheet(2/2)

D	Hydro-Mechanical Works			5,691,200	633,000	6,324,000
1	Intake Structure(sum)					
	Total			1,546,000	172,000	1,718,000
2	Penstock					
	Total			3,956,200	440,000	4,396,000
3	Draft Equipment					
	Total			189,000	21,000	210,000
E	Electro-Mechanical Work			58,148,000	6,461,000	64,609,000
F	132kV Transmission Line	km	10.0	1,018,000	255,000	1,273,000
	Grand Total (A to F)			203,473,200	69,646,000	273,119,000
	Adminstration	2% of Direct Cost			5,463,000	5,463,000
	Engineering Service	13% of Direct Cost		26,452,000	9,054,000	35,506,000
	Contingency	10%:Prep.Env.Civil 5% H		16,731,000	6,971,000	23,702,000
	Land Acquisition				100,000	100,000
	Grand Total			246,657,000	91,233,000	337,890,000

Ginganga Cost Sheet (1/2)

September.2003
1US\$=96Rs.

Description	Unit	Quantity	Orice (US\$)		Amount (US\$)
			Foreign	Local	
A Preparatory Work					
1 Access Road				1,716,000	1,716,000
2 Brige across the river	L.S	1	1,042,000	348,000	1,390,000
3 Power Supply	L.S	1	668,000	222,000	890,000
4 Construction Camp	L.S	1		2,080,000	2,080,000
Total Prepartoty Work			1,710,000	4,366,000	6,076,000
B Environmental Mitigation 3% of Civil Works			1,106,000	368,000	1,474,000
Total Environmental Mitigation			1,106,000	368,000	1,474,000
C Civil Works			36,837,000	12,277,000	49,114,000
1 Care of River					
Total			844,000	281,000	1,125,000
2 Dam					
Total			15,345,000	5,115,000	20,460,000
3 Intake					
Total			621,000	207,000	828,000
4 Headrace Tunnel					
4.1 Intake Tunnel					
Sub Total			278,000	92,000	370,000
4.2 Main Tunnel					
Sub Total			13,955,000	4,652,000	18,607,000
Total			14,233,000	4,744,000	18,977,000
5 Surge Chamber					
Total			1,400,000	467,000	1,867,000
6 Penstock					
6.1 Tunnel					
Sub Total			211,000	70,000	281,000
6.2 Open					
Sub Total			142,000	47,000	189,000
Total			353,000	117,000	470,000
7 Powerhouse					
Total			1,918,000	639,000	2,557,000
8 Tailrace					
Total			2,123,000	707,000	2,830,000

Ginganga Cost Sheet (2/2)

D	Hydro-Mechanical Works			4,866,000	541,000	5,407,000
1	Spillway Equipment Total			2,629,000	292,000	2,921,000
2	Intake Structure(sum) Total			1,060,000	118,000	1,178,000
3	Penstock Total			988,000	110,000	1,098,000
4	Draft Equipment Total			189,000	21,000	210,000
E	Electro-Mechanical Work			22,073,000	2,453,000	24,526,000
F	132kV Transmission Line	km	23.0	2,342,000	586,000	2,928,000
	Grand Total (A to F)			68,934,000	20,591,000	89,525,000
	Adminstration	2% of Direct Cost			1,791,000	1,791,000
	Engineering Service	13% of Direct Cost		8,961,000	2,677,000	11,638,000
	Contingency	10%:Prep.Env.Civil 5% H		5,319,000	1,990,000	7,309,000
	Land Acquisition				100,000	100,000
	Grand Total			83,214,000	27,149,000	110,363,000