

Detailed Report for Pressure Pipe: P-2

Scenario Summary									
Scenario	Improvement of Las Jaguitas Area								
Active Topology Alternative	Base-Active Topology								
Physical Alternative	Base-Physical								
Demand Alternative	Base-Demand								
Initial Settings Alternative	Base-Initial Settings								
Operational Alternative	Base-Operational								
Age Alternative	Base-Age Alternative								
Constituent Alternative	Base-Constituent								
Trace Alternative	Base-Trace Alternative								
Fire Flow Alternative	Base-Fire Flow								
Capital Cost Alternative	Base-Capital Cost								
Energy Cost Alternative	Base-Energy Cost								
User Data Alternative	Base-User Data								
Global Adjustments Summary									
	<None>	Roughness	<None>						
Pipe Characteristics									
Material	Ductile Iron	Hazen- Williams C	110.0						
Diameter	450.0 mm	Minor Loss Coefficient	0.00						
Check Valve?	false	Length	250.00 m						
From Node	J-1	To Node	J-2						
Elevations									
From Elevation	145.00 m	To Elevation	140.00 m						
Initial Status									
Initial Status	Open								
Calculated Results Summary									
Time (hr)	Control Status	Discharge (m³/day)	Velocity (m/s)	Upstream Structural Grade (m)	Downstream Structural Grade (m)	Calculated Friction Headloss (m)	Calculated Minor Headloss (m)	Pressure Headloss (m)	Headloss Gradient (m/km)
0.00	Open	5,177	0.38	176.34	176.22	0.12	0.00	0.12	0.47
1.00	Open	5,177	0.38	176.78	176.66	0.12	0.00	0.12	0.47
2.00	Open	5,421	0.39	177.11	176.98	0.13	0.00	0.13	0.51
3.00	Open	6,151	0.45	177.20	177.04	0.16	0.00	0.16	0.65
4.00	Open	10,354	0.75	174.98	174.56	0.42	0.00	0.42	1.70
5.00	Open	17,358	1.26	168.36	167.25	1.11	0.00	1.11	4.42
6.00	Open	20,647	1.50	163.89	162.37	1.52	0.00	1.52	6.10
7.00	Open	20,403	1.48	163.69	162.20	1.49	0.00	1.49	5.97
8.00	Open	19,855	1.44	163.90	162.48	1.42	0.00	1.42	5.67
9.00	Open	19,002	1.38	164.51	163.20	1.31	0.00	1.31	5.23
10.00	Open	17,480	1.27	165.94	164.81	1.12	0.00	1.12	4.48
11.00	Open	15,531	1.13	167.78	166.88	0.90	0.00	0.90	3.60
12.00	Open	14,739	1.07	168.39	167.58	0.82	0.00	0.82	3.27
13.00	Open	15,104	1.10	167.86	167.00	0.85	0.00	0.85	3.42
14.00	Open	14,495	1.05	168.29	167.50	0.79	0.00	0.79	3.17
15.00	Open	13,460	0.98	169.15	168.46	0.69	0.00	0.69	2.76
16.00	Open	13,034	0.95	169.47	168.82	0.65	0.00	0.65	2.60
17.00	Open	11,511	0.84	170.74	170.22	0.52	0.00	0.52	2.07
18.00	Open	9,684	0.70	172.18	171.80	0.38	0.00	0.38	1.50
19.00	Open	9,014	0.66	172.80	172.47	0.33	0.00	0.33	1.31
20.00	Open	8,588	0.62	173.28	172.97	0.30	0.00	0.30	1.20
21.00	Open	7,918	0.58	173.92	173.66	0.26	0.00	0.26	1.03
22.00	Open	6,700	0.49	174.86	174.67	0.19	0.00	0.19	0.76
23.00	Open	5,542	0.40	175.76	175.63	0.13	0.00	0.13	0.53
24.00	Open	5,177	0.38	176.34	176.22	0.12	0.00	0.12	0.47

Title: The Study on Improvement of Water Supply System in Managua

d:\...las jaguitas\las jaguitas.wcd

05/08/26 00:36:44

© Haestad Methods, Inc. 37 Brookside Road Waterbury, CT 06708 USA +1-203-755-1666

Nihon Suido Consultants Co Inc

Project Engineer: JICA Study Team

WaterCAD v8.5 [6.5120]

Page 1 of 1

Detailed Report for Pressure Pipe: P-3

Scenario Summary									
Scenario	Improvement of Las Jaguitas Area								
Active Topology Alternative	Base-Active Topology								
Physical Alternative	Base-Physical								
Demand Alternative	Base-Demand								
Initial Settings Alternative	Base-Initial Settings								
Operational Alternative	Base-Operational								
Age Alternative	Base-Age Alternative								
Constituent Alternative	Base-Constituent								
Trace Alternative	Base-Trace Alternative								
Fire Flow Alternative	Base-Fire Flow								
Capital Cost Alternative	Base-Capital Cost								
Energy Cost Alternative	Base-Energy Cost								
User Data Alternative	Base-User Data								
Global Adjustments Summary									
	<None>	Roughness	<None>						
Pipe Characteristics									
Material	Ductile Iron	Hazen-Williams C	110.0						
Diameter	300.0 mm	Minor Loss Coefficient	0.00						
Check Valve?	false	Length	900.00 m						
From Node	J-2	To Node	J-3						
Elevations									
From Elevation	140.00 m	To Elevation	140.00 m						
Initial Status									
Initial Status	Open								
Calculated Results Summary									
Time (hr)	Control Status	Discharge (m ³ /day)	Velocity (m/s)	Upstream Hydraulic Grade (m)	Downstream Hydraulic Grade (m)	Friction Headloss (m)	Minor Headloss (m)	Pipe Headloss (m)	Gradient (m/km)
0.00	Open	2,071	0.34	176.22	175.66	0.56	0.00	0.56	0.62
1.00	Open	2,071	0.34	176.66	176.10	0.56	0.00	0.56	0.62
2.00	Open	2,160	0.35	176.90	176.38	0.61	0.00	0.61	0.68
3.00	Open	2,460	0.40	177.04	176.27	0.77	0.00	0.77	0.86
4.00	Open	4,141	0.60	174.56	172.54	2.02	0.00	2.02	2.24
5.00	Open	6,943	1.14	167.25	162.00	5.26	0.00	5.26	5.84
6.00	Open	8,258	1.35	162.37	155.12	7.25	0.00	7.25	8.05
7.00	Open	8,161	1.34	162.20	155.11	7.09	0.00	7.09	7.88
8.00	Open	7,941	1.30	162.40	155.74	6.74	0.00	6.74	7.49
9.00	Open	7,600	1.24	163.20	156.99	6.21	0.00	6.21	6.91
10.00	Open	6,991	1.14	164.81	159.49	5.32	0.00	5.32	5.92
11.00	Open	6,212	1.02	166.88	162.60	4.28	0.00	4.28	4.75
12.00	Open	5,895	0.97	167.58	163.69	3.88	0.00	3.88	4.31
13.00	Open	6,041	0.99	167.00	162.94	4.06	0.00	4.06	4.51
14.00	Open	5,798	0.95	167.50	163.74	3.76	0.00	3.76	4.18
15.00	Open	5,384	0.88	168.46	165.18	3.28	0.00	3.28	3.65
16.00	Open	5,213	0.85	168.82	165.73	3.09	0.00	3.09	3.44
17.00	Open	4,604	0.75	170.22	167.76	2.46	0.00	2.46	2.73
18.00	Open	3,873	0.63	171.80	170.02	1.78	0.00	1.78	1.98
19.00	Open	3,605	0.59	172.47	170.91	1.56	0.00	1.56	1.74
20.00	Open	3,435	0.56	172.97	171.55	1.43	0.00	1.43	1.59
21.00	Open	3,167	0.52	173.66	172.43	1.23	0.00	1.23	1.36
22.00	Open	2,680	0.44	174.67	173.77	0.90	0.00	0.90	1.00
23.00	Open	2,217	0.36	175.63	175.00	0.63	0.00	0.63	0.70
24.00	Open	2,071	0.34	176.22	175.66	0.56	0.00	0.56	0.62

Title: The Study on Improvement of Water Supply System in Managua

d:\...las jaguitas\las jaguitas.wcd Nihon Suido Consultants Co Inc

05/06/26 00:37:24

© Haestad Methods, Inc.

37 Brookside Road

Waterbury, CT 06708 USA

+1-203-755-1666

Project Engineer: JICA Study Team

WaterCAD v6.5 [6.5120]

Page 1 of 1

Detailed Report for Pressure Pipe: P-4

Scenario Summary									
Scenario	Improvement of Las Jaguitas Area								
Active Topology Alternative	Base-Active Topology								
Physical Alternative	Base-Physical								
Demand Alternative	Base-Demand								
Initial Settings Alternative	Base-Initial Settings								
Operational Alternative	Base-Operational								
Age Alternative	Base-Age Alternative								
Constituent Alternative	Base-Constituent								
Trace Alternative	Base-Trace Alternative								
Fire Flow Alternative	Base-Fire Flow								
Capital Cost Alternative	Base-Capital Cost								
Energy Cost Alternative	Base-Energy Cost								
User Data Alternative	Base-User Data								
Global Adjustments Summary									
	<None>	Roughness	<None>						
Pipe Characteristics									
Material	PVC	Hazen-Williams C	110.0						
Diameter	250.0 mm	Minor Loss Coefficient	0.00						
Check Valve?	false	Length	1,100.00 m						
From Node	J-2	To Node	J-4						
Elevations									
From Elevation	140.00 m	To Elevation	125.00 m						
Initial Status									
Initial Status	Open								
Calculated Results Summary									
Time (hr)	Control Status	Discharge (m³/day)	Velocity (m/s)	Upstream Structure Hydraulic Grade (m)	Downstream Structure Hydraulic Grade (m)	Calculated Friction Headloss (m)	Calculated Minor Headloss (m)	Pressure Headloss (m)	Gradient (m/km)
0.00	Open	1,553	0.37	176.22	175.24	0.98	0.00	0.98	0.89
1.00	Open	1,553	0.37	176.66	175.68	0.97	0.00	0.97	0.89
2.00	Open	1,626	0.38	176.98	175.92	1.06	0.00	1.06	0.97
3.00	Open	1,845	0.44	177.04	175.70	1.34	0.00	1.34	1.22
4.00	Open	3,106	0.73	174.56	171.04	3.52	0.00	3.52	3.20
5.00	Open	5,207	1.23	167.25	158.09	9.16	0.00	9.16	8.33
6.00	Open	6,194	1.46	162.37	149.73	12.64	0.00	12.64	11.49
7.00	Open	6,120	1.44	162.20	149.83	12.36	0.00	12.36	11.24
8.00	Open	5,956	1.40	162.48	150.72	11.75	0.00	11.75	10.69
9.00	Open	5,700	1.34	163.20	152.37	10.84	0.00	10.84	9.85
10.00	Open	5,243	1.24	164.81	155.53	9.28	0.00	9.28	8.44
11.00	Open	4,659	1.10	166.88	159.42	7.46	0.00	7.46	6.78
12.00	Open	4,421	1.04	167.58	160.81	6.77	0.00	6.77	6.15
13.00	Open	4,531	1.07	167.00	159.92	7.08	0.00	7.08	6.44
14.00	Open	4,348	1.03	167.50	160.94	6.56	0.00	6.56	5.97
15.00	Open	4,038	0.95	168.46	162.74	5.72	0.00	5.72	5.20
16.00	Open	3,910	0.92	168.82	163.43	5.39	0.00	5.39	4.90
17.00	Open	3,453	0.81	170.22	165.94	4.28	0.00	4.28	3.89
18.00	Open	2,905	0.68	171.80	168.69	3.11	0.00	3.11	2.83
19.00	Open	2,704	0.64	172.47	169.75	2.72	0.00	2.72	2.48
20.00	Open	2,576	0.61	172.97	170.49	2.49	0.00	2.49	2.26
21.00	Open	2,375	0.56	173.66	171.52	2.14	0.00	2.14	1.95
22.00	Open	2,010	0.47	174.67	173.10	1.57	0.00	1.57	1.43
23.00	Open	1,863	0.39	175.63	174.52	1.11	0.00	1.11	1.01
24.00	Open	1,553	0.37	176.22	175.24	0.97	0.00	0.97	0.89

Detailed Report for Tank: Las Jaguitas Tank

Scenario Summary							
Scenario	Improvement of Las Jaguitas Area						
Active Topology Alternative	Base-Active Topology						
Physical Alternative	Base-Physical						
Demand Alternative	Base-Demand						
Initial Settings Alternative	Base-Initial Settings						
Operational Alternative	Base-Operational						
Age Alternative	Base-Age Alternative						
Constituent Alternative	Base-Constituent						
Trace Alternative	Base-Trace Alternative						
Fire Flow Alternative	Base-Fire Flow						
Capital Cost Alternative	Base-Capital Cost						
Energy Cost Alternative	Base-Energy Cost						
User Data Alternative	Base-User Data						
Global Adjustments Summary							
	<None>	Roughness	<None>				
Geometric Summary							
X	4,487.18 m	Elevation	175.00 m				
Y	3,021.14 m	Zone	Zone				
Demand Summary							
Type	Base Flow (m³/day)	Pattern					
Demand	0	Fixed					
Operating Range Summary							
Maximum Elevation	180.00 m	Maximum Level	5.00 m				
Initial HGL	177.50 m	Initial Level	2.50 m				
Minimum Elevation	175.00 m	Minimum Level	0.00 m				
Base Elevation	175.00 m						
Storage							
Section Type	Constant Area	Circular Tank Shape?	true				
Diameter	31.92 m	Average Area	800.0 m²				
Inactive Volume	0.00 m³	Total Active Volume	4,000.00 m³				
Calculated Results Summary							
Time (hr)	Calculated Hydraulic Grade (m)	Calculated Level (m)	Pressure (m H2O)	Calculated Percent Full (%)	Calculated Inflow Volume (m³/day)	Calculated Outflow Volume (m³/day)	Current Status
0.00	177.50	2.50	2.495	50.0	2,000.00	8,442 -8,442	Filling
1.00	177.94	2.94	2.934	58.8	2,351.74	8,442 -8,442	Filling
2.00	178.38	3.38	3.373	67.6	2,703.46	8,148 -8,148	Filling
3.00	178.80	3.80	3.796	76.1	3,042.96	7,267 -7,267	Filling
4.00	179.18	4.18	4.174	83.6	3,345.76	2,202 -2,202	Filling
5.00	179.30	4.30	4.288	85.9	3,437.51	-6,239 6,239	Draining
6.00	178.97	3.97	3.964	79.4	3,177.54	10,203 10,203	Draining
7.00	178.44	3.44	3.434	68.8	2,752.40	-9,910 9,910	Draining
8.00	177.92	2.92	2.918	58.5	2,339.50	-9,249 9,249	Draining
9.00	177.44	2.44	2.438	48.9	1,954.13	-8,221 8,221	Draining
10.00	177.01	2.01	2.010	40.3	1,611.57	-6,386 6,386	Draining
11.00	176.68	1.68	1.678	33.6	1,345.47	-4,037 4,037	Draining
12.00	176.47	1.47	1.469	29.4	1,177.26	-3,083 3,083	Draining
13.00	176.31	1.31	1.308	26.2	1,048.79	-3,523 3,523	Draining
14.00	176.13	1.13	1.125	22.5	901.99	-2,789 2,789	Draining

Title: The Study on Improvement of Water Supply System in Managua

d:\...las jaguitas\las jaguitas.wcd

05/08/26 00:41:18

© Haestad Methods, Inc. 37 Brookside Road Waterbury, CT 06708 USA


Project Engineer: JICA Study Team

WaterCAD v6.5 [6.5120]

Page 1 of 2

Detailed Report for Tank: Las Jaguitas Tank

Calculated Results Summary								
Time (hr)	Calculated Hydraulic Grade (m)	Calculated Level (m)	Pressure (m H ₂ O)	Calculated Percent Full (%)	Calculated Volume (m ³)	Inflow (m ³ /day)	Outflow (m ³ /day)	Current Status
15.00	175.98	0.98	0.980	19.6	785.77	-1,542	1,542	Draining
16.00	175.90	0.90	0.900	18.0	721.53	-1,028	1,028	Draining
17.00	175.85	0.85	0.847	17.0	678.71	807	-807	Filling
18.00	175.89	0.89	0.889	17.8	712.35	3,010	-3,010	Filling
19.00	176.05	1.05	1.045	20.9	837.75	3,817	-3,817	Filling
20.00	176.25	1.25	1.243	24.9	996.81	4,331	-4,331	Filling
21.00	176.47	1.47	1.469	29.4	1,177.26	5,138	-5,138	Filling
22.00	176.74	1.74	1.736	34.8	1,391.35	6,606	-6,606	Filling
23.00	177.08	2.08	2.079	41.7	1,666.62	8,001	-8,001	Filling
24.00	177.50	2.50	2.495	50.0	2,000.00	8,442	-8,442	Filling



Title: The Study on Improvement of Water Supply System in Managua

d:\...las jaguitas\las jaguitas.wcd

05/08/26 00:41:18

© Haestad Methods, Inc.

Nihon Suido Consultants Co Inc

37 Brookside Road

Waterbury, CT 06708 USA


+1-203-755-1666

Project Engineer: JICA Study Team

WaterCAD v6.5 [6.5120]

Page 2 of 2

Scenario: Improvement of San Cristobal Area



Detailed Report for Pressure Pipe: P-1

Scenario Summary									
Scenario	Improvement of San Cristobal Area								
Active Topology Alternative	Base-Active Topology								
Physical Alternative	Base-Physical								
Demand Alternative	Base-Demand								
Initial Settings Alternative	Base-Initial Settings								
Operational Alternative	Base-Operational								
Age Alternative	Base-Age Alternative								
Constituent Alternative	Base-Constituent								
Trace Alternative	Base-Trace Alternative								
Fire Flow Alternative	Base-Fire Flow								
Capital Cost Alternative	Base-Capital Cost								
Energy Cost Alternative	Base-Energy Cost								
User Data Alternative	Base-User Data								
Global Adjustments Summary									
	<None>	Roughness	<None>						
Pipe Characteristics									
Material	Ductile Iron	Hazen-Williams C	110.0						
Diameter	450.0 mm	Minor Loss Coefficient	0.00						
Check Valve?	false	Length	3,750.00 m						
From Node	J-1	To Node	J-2						
Elevations									
From Elevation	80.00 m	To Elevation	90.00 m						
Initial Status									
Initial Status	Open								
Calculated Results Summary									
Time (hr)	Control Status	Discharge (m ³ /day)	Velocity (m/s)	Upstream Hydraulic Grade (m)	Downstream Hydraulic Grade (m)	Friction Headloss (m)	Minor Headloss (m)	Pipe Headloss (m)	Pressure Gradient (m/km)
0.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
1.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
2.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
3.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
4.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
5.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
6.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
7.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
8.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
9.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
10.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
11.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
12.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
13.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
14.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
15.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
16.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
17.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
18.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
19.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
20.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
21.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
22.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
23.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07
24.00	Open	20,600	1.50	142.08	119.31	22.78	0.00	22.78	6.07

Title: The Study on Improvement of Water Supply System in Managua

d:\...san cristobal transmission.wcd

05/02/06 09:31:27

Nilson Suido Consultants Co Inc

© Haestad Methods, Inc. 37 Brookside Road Waterbury, CT 06708 USA

Project Engineer: JICA Study Team

WaterCAD v8.5 [6.5120]

Page 1 of 1

Detailed Report for Pump: PMP-1

Scenario Summary	
Scenario	Improvement of San Cristobal Area
Active Topology Alternative	Base-Active Topology
Physical Alternative	Base-Physical
Demand Alternative	Base-Demand
Initial Settings Alternative	Base-Initial Settings
Operational Alternative	Base-Operational
Age Alternative	Base-Age Alternative
Constituent Alternative	Base-Constituent
Trace Alternative	Base-Trace Alternative
Fire Flow Alternative	Base-Fire Flow
Capital Cost Alternative	Base-Capital Cost
Energy Cost Alternative	Base-Energy Cost
User Data Alternative	Base-User Data

Global Adjustments Summary			
	<None>	Roughness	<None>

Geometric Summary			
X	3,823.91 m	Upstream Pipe	P-6
Y	1,117.38 m	Downstream Pipe	P-7
Elevation	80.00 m		

Pump Definition Summary	
Pump Definition	Rafaela Herrera

Initial Status			
Initial Pump Status	On	Initial Relative Speed Factor	1.00

Calculated Results Summary							
Time (hr)	Control Status	Intake Pump Grade (m)	Discharge Pump Grade (m)	Discharge (m³/day)	Pump Head (m)	Relative Speed	Calculated Water Power (kW)
0.00	On	82.29	142.29	6,867	50.00	1.00	46.68
1.00	On	82.29	142.29	6,867	50.00	1.00	46.68
2.00	On	82.29	142.29	6,867	50.00	1.00	46.68
3.00	On	82.29	142.29	6,867	50.00	1.00	46.68
4.00	On	82.29	142.29	6,867	50.00	1.00	46.68
5.00	On	82.29	142.29	6,867	50.00	1.00	46.68
6.00	On	82.29	142.29	6,867	50.00	1.00	46.68
7.00	On	82.29	142.29	6,867	50.00	1.00	46.68
8.00	On	82.29	142.29	6,867	50.00	1.00	46.68
9.00	On	82.29	142.29	6,867	50.00	1.00	46.68
10.00	On	82.29	142.29	6,867	50.00	1.00	46.68
11.00	On	82.29	142.29	6,867	50.00	1.00	46.68
12.00	On	82.29	142.29	6,867	50.00	1.00	46.68
13.00	On	82.29	142.29	6,867	50.00	1.00	46.68
14.00	On	82.29	142.29	6,867	50.00	1.00	46.68
15.00	On	82.29	142.29	6,867	50.00	1.00	46.68
16.00	On	82.29	142.29	6,867	50.00	1.00	46.68
17.00	On	82.29	142.29	6,867	50.00	1.00	46.68
18.00	On	82.29	142.29	6,867	50.00	1.00	46.68
19.00	On	82.29	142.29	6,867	50.00	1.00	46.68
20.00	On	82.29	142.29	6,867	50.00	1.00	46.68
21.00	On	82.29	142.29	6,867	50.00	1.00	46.68
22.00	On	82.29	142.29	6,867	50.00	1.00	46.68
23.00	On	82.29	142.29	6,867	50.00	1.00	46.68
24.00	On	82.29	142.29	6,867	50.00	1.00	46.68

Title: The Study on Improvement of Water Supply System in Managua

d:\...san cristobal transmission.wcd

05/02/06 09:30:24

© Haestad Methods, Inc.

Nihon Suido Consultants Co Inc

37 Brookside Road Waterbury, CT 06708 USA


+1-203-755-1666

Project Engineer: JICA Study Team

WaterCAD v6.5 [6.5120]

Page 1 of 2

Detailed Report for Pump: PMP-1



Title: The Study on Improvement of Water Supply System in Managua

d:\...isan cristobal transmission.wcd

05/02/06 09:30:24

© Haestad Methods, Inc.

Nihon Suido Consultants Co Inc

37 Brookside Road Waterbury, CT 06708 USA +1-203-755-1666

Project Engineer: JICA Study Team

WaterCAD v6.5 [6.5120]

Page 2 of 2

Detailed Report for Tank: San Cristobal Tank

Scenario Summary	
Scenario	Improvement of San Cristobal Area
Active Topology Alternative	Base-Active Topology
Physical Alternative	Base-Physical
Demand Alternative	Base-Demand
Initial Settings Alternative	Base-Initial Settings
Operational Alternative	Base-Operational
Age Alternative	Base-Age Alternative
Constituent Alternative	Base-Constituent
Trace Alternative	Base-Trace Alternative
Fire Flow Alternative	Base-Fire Flow
Capital Cost Alternative	Base-Capital Cost
Energy Cost Alternative	Base-Energy Cost
User Data Alternative	Base-User Data

Global Adjustments Summary			
	<None>	Roughness	<None>

Geometric Summary			
X	882.11 m	Elevation	100.00 m
Y	174.99 m	Zone	Zone

Demand Summary		
Type	Base Flow (m³/day)	Pattern
Demand	0	Fixed


Operating Range Summary			
Maximum Elevation	105.10 m	Maximum Level	6.00 m
Initial HGL	102.10 m	Initial Level	3.00 m
Minimum Elevation	99.10 m	Minimum Level	0.00 m
Base Elevation	99.10 m		

Storage			
Section Type	Constant Area	Circular Tank Shape?	true
Diameter	63.37 m	Average Area	3,154.2 m²
Inactive Volume	0.00 m³	Total Active Volume	18,925.00 m³


Calculated Results Summary									
Time (hr)	Calculated Hydraulic Grade (m)	Calculated Level (m)	Pressure (kPa)	Calculated Percent Full (%)	Calculated Inflow Volume (m³/day)	Calculated Outflow Volume (m³/day)	Current Inflow (m³/day)	Current Outflow (m³/day)	Status
0.00	102.10	3.00	29.36	50.0	9,462.50	13,816	13,816		Filling
1.00	102.28	3.18	31.15	53.0	0,038.14	13,816	13,816		Filling
2.00	102.47	3.37	32.93	56.1	0,613.81	13,335	13,335		Filling
3.00	102.64	3.54	34.66	59.0	1,169.43	11,893	11,893		Filling
4.00	102.80	3.70	36.19	61.6	1,664.97	3,603	-3,603		Filling
5.00	102.85	3.75	36.66	62.4	1,815.13	10,213	10,213		Draining
6.00	102.71	3.61	35.34	60.2	1,309.57	16,701	16,701		Draining
7.00	102.49	3.39	33.18	56.5	0,693.70	16,221	16,221		Draining
8.00	102.28	3.18	31.08	52.9	0,017.84	15,139	15,139		Draining
9.00	102.08	2.98	29.13	49.6	9,387.04	13,457	13,457		Draining
10.00	101.90	2.80	27.39	46.6	8,826.31	10,454	10,454		Draining
11.00	101.76	2.66	26.04	44.3	8,390.74	-6,609	6,609		Draining
12.00	101.67	2.57	25.18	42.9	8,115.36	-5,047	5,047		Draining
13.00	101.61	2.51	24.53	41.0	7,905.08	-5,760	5,760		Draining
14.00	101.53	2.43	23.78	40.5	7,664.74	-4,567	4,567		Draining

Detailed Report for Tank: San Cristobal Tank

Calculated Results Summary								
Time (hr)	Calculated Hydraulic Grade (m)	Calculated Level (m)	Pressure (kPa)	Calculated Percent Full (%)	Calculated Volume (m³)	Inflow (m³/day)	Outflow (m³/day)	Current Status
15.00	101.47	2.37	23.19	39.5	7,474.47	-2,524	2,524	Draining
16.00	101.44	2.34	22.87	38.9	7,369.29	-1,683	1,683	Draining
17.00	101.41	2.31	22.65	38.6	7,299.17	1,321	-1,321	Filling
18.00	101.43	2.33	22.82	38.9	7,354.21	4,925	-4,925	Filling
19.00	101.50	2.40	23.46	39.9	7,559.41	6,247	-6,247	Filling
20.00	101.58	2.48	24.26	41.3	7,819.68	7,088	-7,088	Filling
21.00	101.67	2.57	25.18	42.9	8,115.01	8,409	-8,409	Filling
22.00	101.78	2.68	26.27	44.7	8,465.38	10,812	10,812	Filling
23.00	101.93	2.83	27.66	47.1	8,915.88	13,095	13,095	Filling
24.00	102.10	3.00	29.36	50.0	9,461.51	13,816	13,816	Filling



Scenario: Improvement of Nindiri Area



Title: The Study on Improvement of Water Supply System in Managua

d:\...—\CEv2\Nindiri\km14.5 cm - nindiri.wcd

05/02/06 11:10:21

© Haestad Methods, Inc.

Nihon Suido Consultants Co Inc

37 Brookside Road Waterbury, CT 06708 USA +1-203-755-1666

Project Engineer: JICA Study Team

WaterCAD v6.5 [6.5120]

Page 1 of 1

Detailed Report for Pressure Pipe: P-1

Scenario Summary									
Scenario	Improvement of Nindiri Area								
Active Topology Alternative	Base-Active Topology								
Physical Alternative	Base-Physical								
Demand Alternative	Base-Demand								
Initial Settings Alternative	Base-Initial Settings								
Operational Alternative	Base-Operational								
Age Alternative	Base-Age Alternative								
Constituent Alternative	Base-Constituent								
Trace Alternative	Base-Trace Alternative								
Fire Flow Alternative	Base-Fire Flow								
Capital Cost Alternative	Base-Capital Cost								
Energy Cost Alternative	Base-Energy Cost								
User Data Alternative	Base-User Data								
Global Adjustments Summary									
	<None>	Roughness	<None>						
Pipe Characteristics									
Material	Ductile Iron	Hazen- Williams C	110.0						
Diameter	350.0 mm	Minor Loss Coefficient	0.00						
Check Valve?	false	Length	600.00 m						
From Node	J-1	To Node	J-2						
Elevations									
From Elevation	201.00 m	To Elevation	220.00 m						
Initial Status									
Initial Status	Open								
Calculated Results Summary									
Time (hr)	Control Status	Discharge (m ³ /day)	Velocity (m/s)	Upstream Hydraulic Grade (m)	Downstream Hydraulic Grade (m)	Friction Headloss (m)	Minor Headloss (m)	Pipe Headloss (m)	Gradient (m/km)
0.00	Open	2,678	0.32	327.08	326.79	0.28	0.00	0.28	0.47
1.00	Open	2,678	0.32	327.64	327.35	0.28	0.00	0.28	0.47
2.00	Open	2,804	0.34	326.26	325.95	0.31	0.00	0.31	0.51
3.00	Open	3,183	0.38	320.46	320.07	0.39	0.00	0.39	0.65
4.00	Open	5,357	0.64	329.21	328.19	1.02	0.00	1.02	1.70
5.00	Open	8,900	1.08	292.99	290.33	2.66	0.00	2.66	4.44
6.00	Open	10,682	1.29	313.53	309.86	3.67	0.00	3.67	6.12
7.00	Open	10,556	1.27	313.69	310.10	3.59	0.00	3.59	5.99
8.00	Open	10,272	1.24	314.87	311.46	3.42	0.00	3.42	5.69
9.00	Open	9,831	1.18	317.02	313.87	3.15	0.00	3.15	5.25
10.00	Open	9,043	1.09	321.10	318.41	2.70	0.00	2.70	4.50
11.00	Open	8,035	0.97	300.93	298.76	2.17	0.00	2.17	3.61
12.00	Open	7,625	0.92	305.16	303.19	1.97	0.00	1.97	3.28
13.00	Open	7,814	0.94	302.91	300.85	2.06	0.00	2.06	3.43
14.00	Open	7,499	0.90	306.05	304.15	1.91	0.00	1.91	3.18
15.00	Open	6,964	0.84	311.29	309.63	1.66	0.00	1.66	2.77
16.00	Open	6,743	0.81	313.31	311.74	1.57	0.00	1.57	2.61
17.00	Open	5,955	0.72	320.24	319.00	1.24	0.00	1.24	2.07
18.00	Open	5,010	0.60	327.55	326.65	0.90	0.00	0.90	1.51
19.00	Open	4,663	0.56	330.10	329.30	0.79	0.00	0.79	1.32
20.00	Open	4,443	0.53	290.30	289.58	0.72	0.00	0.72	1.21
21.00	Open	4,096	0.49	298.88	298.25	0.62	0.00	0.62	1.04
22.00	Open	3,466	0.42	312.56	312.10	0.46	0.00	0.46	0.76
23.00	Open	2,867	0.34	323.61	323.29	0.32	0.00	0.32	0.54
24.00	Open	2,678	0.32	327.08	326.79	0.28	0.00	0.28	0.47

Title: The Study on Improvement of Water Supply System in Managua

d:\l\w\...0Ev22nindiri\m14.5 cm - nindir.wcd

05/02/06 10:54:29

© Haestad Methods, Inc.

Nihon Suido Consultants Co Inc

37 Brookside Road

Waterbury, CT 06708 USA

+1-203-755-1666

Project Engineer: JICA Study Team

WaterCAD v6.5 [6.5120]

Page 1 of 1

Detailed Report for Pump: PMP-1(D-Pump)

Scenario Summary	
Scenario	Improvement of Nindiri Area
Active Topology Alternative	Base-Active Topology
Physical Alternative	Base-Physical
Demand Alternative	Base-Demand
Initial Settings Alternative	Base-Initial Settings
Operational Alternative	Base-Operational
Age Alternative	Base-Age Alternative
Constituent Alternative	Base-Constituent
Trace Alternative	Base-Trace Alternative
Fire Flow Alternative	Base-Fire Flow
Capital Cost Alternative	Base-Capital Cost
Energy Cost Alternative	Base-Energy Cost
User Data Alternative	Base-User Data

Global Adjustments Summary		
	<None>	Roughness
		<None>

Geometric Summary			
X	926.35 m	Upstream Pipe	P-3
Y	4,017.56 m	Downstream Pipe	P-4
Elevation	201.00 m		

Pump Definition Summary	
Pump Definition	Distribution Pump

Initial Status			
Initial Pump Status	On	Initial Relative Speed Factor	1.00

Calculated Results Summary							
Time (hr)	Control Status	Intake Pump Grade (m)	Discharge Pump Grade (m)	Discharge (m³/day)	Pump Head (m)	Relative Speed	Calculated Water Power (kW)
0.00	On	104.49	327.09	2,678	22.60	1.00	37.20
1.00	On	105.05	327.65	2,678	22.60	1.00	37.20
2.00	On	105.60	326.27	2,804	20.67	1.00	38.34
3.00	On	106.14	320.48	3,183	14.34	1.00	41.23
4.00	On	106.62	329.23	2,678	22.60	1.00	37.20
5.00	On	106.75	293.03	4,490	86.28	1.00	43.89
6.00	On	106.35	313.56	3,561	07.21	1.00	43.25
7.00	On	105.67	313.71	3,519	08.04	1.00	43.07
8.00	On	105.02	314.89	3,424	09.87	1.00	42.62
9.00	On	104.41	317.04	3,277	12.63	1.00	41.82
10.00	On	103.87	321.12	3,014	17.25	1.00	40.04
11.00	On	103.44	300.96	4,018	97.52	1.00	44.39
12.00	On	103.17	305.18	3,813	02.01	1.00	44.06
13.00	On	102.97	302.93	3,907	99.97	1.00	44.25
14.00	On	102.73	306.08	3,750	03.34	1.00	43.90
15.00	On	102.55	311.31	3,482	08.76	1.00	42.90
16.00	On	102.45	313.32	3,372	10.87	1.00	42.35
17.00	On	102.39	320.25	2,978	17.87	1.00	39.76
18.00	On	102.45	327.56	2,505	25.12	1.00	35.51
19.00	On	102.65	330.11	2,332	27.46	1.00	33.67
20.00	On	102.88	290.33	4,443	87.46	1.00	44.02
21.00	On	103.17	298.90	4,096	95.73	1.00	44.43
22.00	On	103.51	312.58	3,466	09.06	1.00	42.83
23.00	On	103.96	323.63	2,867	19.67	1.00	38.88
24.00	On	104.49	327.09	2,678	22.60	1.00	37.20

Title: The Study on Improvement of Water Supply System in Managua
 d:\...-05\22\Nindiri\km14.5 cm - nindiri.wcd
 05/02/06 10:49:23

© Haestad Methods, Inc.

Nihon Suido Consultants Co Inc

37 Brookside Road

Waterbury, CT 06708 USA



+1-203-755-1666

Project Engineer: JICA Study Team

WaterCAD v6.5 [6.5120]

Page 1 of 2

Detailed Report for Pump: PMP-1(D-Pump)



Title: The Study on Improvement of Water Supply System in Managua

d:\...—\CEVZZ\Nindiri\km14.5 cm - nindiri.wcd

05/02/06 10:49:23

© Haestad Methods, Inc.

Nihon Suido Consultants Co Inc

37 Brookside Road Waterbury, CT 06708 USA

+1-203-755-1666

Project Engineer: JICA Study Team

WaterCAD v6.5 [6.5120]

Page 2 of 2

Detailed Report for Pump: PMP-2(D-Pump)

Scenario Summary	
Scenario	Improvement of Nindiri Area
Active Topology Alternative	Base-Active Topology
Physical Alternative	Base-Physical
Demand Alternative	Base-Demand
Initial Settings Alternative	Base-Initial Settings
Operational Alternative	Base-Operational
Age Alternative	Base-Age Alternative
Constituent Alternative	Base-Constituent
Trace Alternative	Base-Trace Alternative
Fire Flow Alternative	Base-Fire Flow
Capital Cost Alternative	Base-Capital Cost
Energy Cost Alternative	Base-Energy Cost
User Data Alternative	Base-User Data

Global Adjustments Summary		
<None>	Roughness	<None>

Geometric Summary			
X	995.48 m	Upstream Pipe	P-5
Y	3,910.12 m	Downstream Pipe	P-6
Elevation	201.00 m		

Pump Definition Summary	
Pump Definition	Distribution Pump

Initial Status			
Initial Pump Status	Off	Initial Relative Speed Facto	1.00

Simple Controls

Controls
On at time from start 4.00
Off at time from start 20.00

Calculated Results Summary

Time (hr)	Control Status	Intake Pump Grade (m)	Discharge Pump Grade (m)	Discharge (m ³ /day)	Pump Head (m)	Relative Speed	Calculated Water Power (kW)
0.00	Off	05.50	327.08	0	0.00	1.00	0.00
1.00	Off	05.06	327.64	0	0.00	1.00	0.00
2.00	Off	05.62	326.26	0	0.00	1.00	0.00
3.00	Off	06.16	320.46	0	0.00	1.00	0.00
4.00	On	06.62	329.23	2,678	22.60	1.00	37.20
5.00	On	06.75	293.03	4,490	86.28	1.00	43.89
6.00	On	06.35	313.56	3,561	07.21	1.00	43.25
7.00	On	05.67	313.71	3,519	08.04	1.00	43.07
8.00	On	05.02	314.89	3,424	09.87	1.00	42.62
9.00	On	04.41	317.04	3,277	12.63	1.00	41.82
10.00	On	03.87	321.12	3,014	17.25	1.00	40.04
11.00	On	03.44	300.96	4,018	97.52	1.00	44.39
12.00	On	03.17	305.18	3,813	02.01	1.00	44.06
13.00	On	02.97	302.93	3,907	99.97	1.00	44.25
14.00	On	02.73	306.08	3,750	03.34	1.00	43.90
15.00	On	02.55	311.31	3,482	08.76	1.00	42.90
16.00	On	02.45	313.32	3,372	10.87	1.00	42.35
17.00	On	02.39	320.25	2,978	17.87	1.00	39.76
18.00	On	02.45	327.56	2,505	25.12	1.00	35.51

Title: The Study on Improvement of Water Supply System in Managua

da... — DCEvZVnindirNkm14,5 cm - nindir,wcd

Nihon Suido Consultants Co Inc

05/02/06 10:51:12

© Haaslad Methods, Inc. 37 Brookside Road Waterbury, CT 06708 USA



Project Engineer: JICA Study Team

WaterCAD v8.5 [6.5120j]

Page 1 of 2

Detailed Report for Pump: PMP-2(D-Pump)

Calculated Results Summary							
Time (hr)	Control Status	Intake Pump Grade (m)	Discharge Pump Grade (m)	Discharge (m³/day)	Pump Head (m)	Relative Speed	Calculated Water Power (kW)
19.00	On	302.65	330.11	2,332	27.46	1.00	33.67
20.00	Off	302.91	290.30	0	0.00	0.00	0.00
21.00	Off	303.19	298.88	0	0.00	0.00	0.00
22.00	Off	303.53	312.56	0	0.00	0.00	0.00
23.00	Off	303.97	323.61	0	0.00	0.00	0.00
24.00	Off	304.50	327.08	0	0.00	0.00	0.00



Title: The Study on Improvement of Water Supply System in Managua

d:_U...CEv2Znindiri\km14.5 cm - nindiri.wcd

05/02/06 10:51:12

© Haestad Methods, Inc.

Nihon Suido Consultants Co Inc

37 Brookside Road Waterbury, CT 06708 USA +1-203-755-1666

Project Engineer: JICA Study Team

WaterCAD v8.5 [6.5120j]

Page 2 of 2