





I6 WATER SUPPLY TOWER





100

Tank W.L. $\frac{48.0}{0} + D.L. \frac{2.0}{2.0} = 50.0 \text{ [t]}$

Top Floor L.L. $\frac{0.20}{0} + D.L. \frac{0.10}{0.10} = 0.30 \text{ [t/m}^2\text{]}$

Staircase L.L. $\frac{0.20}{0} + D.L. \frac{0.10}{0.10} = 0.30 \text{ [t/m}^2\text{]}$

Column 0.15 [t/m] (including Brace)


Beam 0.15 [t/m] (including subbeam)

Wall 0.05 [t/m²]

Wind Force (At Bottom)

Max	Tank	$50.0 / 4$	12.5
	Top Floor	$0.30 \times 36.0 / 4$	2.7
	Staircase	$0.30 \times 6.0 \times 6 / 4$	2.7
	Column	0.15×36.4	5.4
	Beam	$0.15 \times 6.0 \times 7$	6.3
	Wall	$0.05 \times 9.2 \times 6$	1.6
		Σ	31.3 [t]

Min	Tank	$2.0 / 4$	0.5
	Top Floor	$0.10 \times 36.0 / 4$	0.9
	Staircase	$0.10 \times 6.0 \times 6 / 4$	0.9
	Column	5.4	5.4
	Beam	6.3	6.3
	Wall	1.6	1.6
		Σ	15.7 [t]



W	F	H	SH	SB	M	SM	NC	NG	NBY
5.2	0.2	1.0	1.0	5.2	5.2	5.2	0.4	0.5	0.7
74.6	"	14.9	15.9	4	82.7	87.9	7.3	8.0	10.6
8.5	"	1.7	17.6	"	91.5	179.4	15.0	8.6	11.4
"	"	"	19.3	"	100.4	279.8	23.3	9.7	12.8
"	"	"	21.0	"	109.2	389.0	32.4	10.5	13.9
"	"	"	22.7	"	118.0	507.0	42.3	11.4	15.1
"	"	"	24.4	"	126.9	633.9	52.9	12.2	16.1

4.74

32.2

27.0

21.8

16.91

11.4

6.2

1.6

3.6

5.0

10.0

15.0

20.0

25.0

30.0

1.8

3.1

4.4

5.7

7.0

8.3

9.6

10.9

12.2

13.5

14.8

16.1

1.8

3.1

4.4

5.7

7.0

8.3

9.6

10.9

12.2

13.5

14.8

16.1

17.4

18.7

20.0

21.3

22.6

23.9

25.2

26.5

27.8

29.1

30.4

31.7

33.0

34.3

35.6

36.9

38.2

39.5

40.8

42.1

43.4

44.7

46.0

47.3

48.6

49.9

51.2

52.5

53.8

55.1

56.4

57.7

59.0

60.3

61.6

62.9

64.2

65.5

66.8

68.1

69.4

70.7

72.0

73.3

74.6

75.9

77.2

78.5

79.8

81.1

82.4

83.7

85.0

86.3

87.6

88.9

90.2

91.5

92.8

94.1

95.4

96.7

98.0

99.3

100.6

101.9

103.2

104.5

105.8

107.1

108.4

109.7

111.0

112.3

113.6

114.9

116.2

117.5

118.8

120.1

121.4

122.7

124.0

125.3

126.6

127.9

129.2

130.5

131.8

133.1

134.4

135.7

137.0

138.3

139.6

140.9

142.2

143.5

144.8

146.1

147.4

148.7

150.0

151.3

152.6

153.9

155.2

156.5

157.8

159.1

160.4

161.7

163.0

164.3

165.6

166.9

168.2

169.5

170.8

172.1

173.4

174.7

176.0

177.3

178.6

179.9

181.2

182.5

183.8

185.1

186.4

187.7

189.0

190.3

191.6

192.9

194.2

195.5

196.8

198.1

199.4

200.7

202.0

203.3

204.6

205.9

207.2

208.5

209.8

211.1

212.4

213.7

215.0

216.3

217.6

218.9

220.2

221.5

222.8

224.1

225.4

226.7

228.0

229.3

230.6

231.9

233.2

234.5

235.8

237.1

238.4

239.7

241.0

242.3

243.6

244.9

246.2

247.5

248.8

250.1

251.4

252.7

254.0

255.3

256.6

257.9

259.2

260.5

261.8

263.1

264.4

265.7

267.0

268.3

269.6

270.9

272.2

273.5

274.8

276.1

277.4

278.7

280.0

281.3

282.6

283.9

285.2

286.5

287.8

289.1

290.4

291.7

293.0

294.3

295.6

296.9

298.2

299.5

300.8


302.1

303.4


304.7

306.0


</



K	W	K	H	S	M	SM	NC	NE	NR
37.4		0.2	1.0	5.2	5.2	5.2	0.6	0.4	0.5
32.2		"	14.9	"	82.7	89.9	10.3	5.7	7.5
27.0		"	17.6	"	94.5	109.4	21.2	6.1	8.1
21.8		"	19.3	"	100.4	279.8	33.0	6.9	9.1
16.6		"	21.0	"	109.2	389.0	45.8	7.4	9.8
11.4		"	22.7	"	118.0	507.0	59.8	8.1	10.7
7.9		"	24.4	"	126.9	633.9	74.8	8.6	11.4
Ratio for 0°		1.00	1.00		1.00	1.00	$\frac{100}{5.2} = 19.23$	$\frac{100}{0.6} = 166.67$	$\frac{100}{0.5} = 200$



R	Q	C	A	H	SH	SR	M	ZM	NC	NG	NBY
37.4	0.37	1.4 (0.856)	16.7	8.7	8.7	5.2	45.2	45.2	3.8	4.4	5.8
32.2	0.34	1.4	16.7	7.9	21.3	"	110.8	156.0	13.0	10.7	14.1
27.0	0.31	2.5	11.0	8.5	29.8	"	155.0	311.0	25.9	14.9	19.7
21.8	0.28	"	"	7.7	37.5	"	195.0	506.0	42.2	18.8	24.8
16.6	0.24	"	"	6.6	44.1	"	229.3	735.3	61.2	22.1	29.7
11.4	0.20	"	"	5.5	49.6	"	257.9	993.2	82.8	24.8	32.8
6.2	0.15	"	"	4.1	53.7	"	279.2	1272.4	106.0	26.9	35.6



5	6	C	A	H	3H	2H	M	2M	NG	NG	NG	NBY
37.4		1.7						6.7	3.9	5.1		
32.2		1.7						22.8	9.4	12.4		
		3.1										
27.0		3.1						45.4	13.1	17.3		
21.8		/						74.0	16.5	21.7		
16.6		/						107.3	19.4	26.0		
11.4		/						147.2	21.7	28.8		
6.2		/						185.9	23.6	31.2		
Ratio for 0°		$\frac{3.1}{25} = 1.24$						1.24 $\left(\frac{1.24}{6.7}\right)$	$\frac{1.754}{2}$	$\frac{1.034}{2}$		
								$\left(\frac{1.00}{6.7}\right)$	$= 1.754 = 0.877$	$= 0.877$		

Design of Foundation

Force from Upper Structure

Vertical Force

Max $31.3 \times 4 = 125.2 \text{ [t]}$

Min $15.7 \times 4 = 62.8 \text{ [t]}$

Horizontal Force

Wind Force


0° Direction $\left\{ \begin{array}{l} N = \pm 106.0 \times 2 \text{ [t]} \\ H = 53.17 \text{ [t]} \\ M = 1,272.4 \text{ [tm]} \end{array} \right.$

45° Direction $\left\{ \begin{array}{l} N = \pm 185.9 \times 2 \text{ [t]} \\ H = 66.6 \text{ [t]} \\ M = 1,517.8 \text{ [tm]} \end{array} \right.$

Seismic Force $\left\{ \begin{array}{l} N = \pm 93.0 \times 2 \text{ [t]} \\ H = 24.5 \text{ [t]} \\ M = 637.0 \text{ [tm]} \end{array} \right.$

Self Load Pump Room $\left[\begin{array}{l} \text{Roof } (0.10 + 0.46) \times 4.0 \times 4.0 \\ \text{Wall } 0.46 \times 2.39 \times 4 \end{array} \right. \left. \begin{array}{l} 9.0 \\ 4.3 \end{array} \right] 133$

Soil	$(0.8284 \times 14.0^2 - 6.0^2 - 4 \times 6.3 \times 3.14) \times 1.1 \times 1.6$	82.7	} 416.6	FULL 529.9 EMPTY 429.9
Slab	$(6.0^2 + 4 \times 6.3 \times 3.14) \times (0.06 + 0.48)$	62.3		
Base	$0.8284 \times 14.0^2 \times (0.06 + 0.96)$	165.6		
Wall	$(4 \times 3.9 + 4 \times 10.9) \times (0.19 + 1.37)$	89.9		
Column	$4 \times 1.9 \times (0.18 + 1.94)$	16.1		
Water	100.0 ~ 0	100.0 ~ 0		



$A = 0.8284 \times 14.0^2 = 162.4 \text{ [m}^2\text{]}$

$Z = 0.1099 \times 14.0^3 = 448.5 \text{ [m}^3\text{]}$

4th Direction — Soil Reaction

$$\sum N = (125.2 \sim 62.8) + (529.9 \sim 429.9) = 655.1 \sim 492.7 \text{ [t]}$$

$$M = 1,977.8 + (66.6 \times 2.5) = 1,744.3 \text{ [tm]}$$

$$\sigma'_L = \frac{655.1 \sim 492.7}{162.4} = 4.03 \sim 3.03 < \text{Lfr} = 8.4, > \text{W.L. max} = 1.50$$

$$\sigma'_S = \frac{655.1 \sim 492.7}{162.4} \pm \frac{1,744.3}{448.5}$$

$$= (4.03 \sim 3.03) \pm 3.89$$

$$= 8.02 \sim -0.86 < \text{sfr} = 16.8, > \div 0$$


$$e = \frac{1,744.3}{655.1 \sim 492.7} = 2.66 \sim 3.54, \quad 3\left(\frac{D}{2} - e\right) = \frac{13.02}{10.38} (= X_u)$$

$$\frac{e}{l} = \frac{2.66 \sim 3.54}{14.0} = 0.19 \sim 0.25$$

$$\alpha = 2.6 \sim 3.6$$

$$\sigma'_S = \frac{655.1 \sim 492.7}{162.4} \times 2.6 \sim 3.6$$

$$= 10.49 \sim 10.92 < \text{sfr} = 16.8$$



Foundation Beam

FB

$$\begin{aligned}
 q &= \left\{ \frac{10.92 + 10.11}{2} - (1.1 \times 1.6 + 1.02) \right\} \times 1.0 \\
 &+ \left\{ \frac{10.11 + (10.11 + 6.77)/2}{2} - 1.02 \right\} \times 1.5 \\
 &= 7.89 + 12.38 \\
 &= 20.27 \quad [\text{t/m}]
 \end{aligned}$$

$$\begin{aligned}
 M_0 &= 20.27 \times 6.0^2 / 8 = 93.5 \quad [\text{tm}] & \alpha &= 14.17 \quad [\text{cm}^2] > 3 - D25 \\
 Q &= \quad \quad \quad \times 6.0 / 2 = 62.3 \quad [\text{t}] & \phi &= 19.6 \quad [\text{cm}]
 \end{aligned}$$

$$\begin{aligned}
 b &= 30 \quad D &= 250 \quad j &= 211.77 & Q_{AS} &= 57.2 \quad [\text{t}] \\
 & & & & \alpha &= 2.0
 \end{aligned}$$

FCG

P = from FB 62.3



$$\begin{aligned}
 W &= \left\{ \frac{11.01 + 6.77}{2} - (1.1 \times 1.6 + 1.02) \right\} \times 3.0 \times 1.8 / 2 \\
 &= 16.5
 \end{aligned}$$

$$\begin{aligned}
 C &= 16.5 \times 3.0 = 49.5 \quad [\text{tm}] & & 3 - D25 \\
 Q &= 16.5 \quad [\text{t}]
 \end{aligned}$$

FG

$$\begin{aligned}
 q &= \left\{ \frac{(10.11 + 6.77)/2 + 6.77}{2} - 1.02 \right\} \times 1.5 + \left\{ \frac{6.77 + 3.43}{2} - 1.02 \right\} \times 3.0 \\
 &= 9.88 + 12.24 \\
 &= 22.12 \quad [\text{t/m}]
 \end{aligned}$$

$$\begin{aligned}
 C &= 22.12 \times 6^2 / 12 = 66.4 \quad [\text{tm}] > 3 - D25 \\
 M_0 &= \quad \quad \quad / 8 = 99.5 \quad [\text{t}] \\
 Q &= \quad \quad \quad 6 / 2 = 66.4 \quad [\text{t}]
 \end{aligned}$$

Opening Reinforcing $Q = \frac{Q_E}{2} = 33.2 \quad [\text{t}]$

Φ600

$$\tau = \frac{33,200}{211.77 \times 30} = 5.25 \quad [\text{t/cm}^2]$$

$$T = 5.25 \times 30 \times 30 \sqrt{2} = 6.65 \quad [\text{t}]$$

$$\rho_w = \frac{Q/2}{b_j \cdot 0.5 \text{ mft}} + 0.002 = \frac{33.2/2}{30 (95-8) \times \frac{17}{8} \times 1.5} + 0.002 = 0.0068$$

$$\rho_s = 2.2 \quad [\text{cm}^2] \quad 2 - D13$$

$$\square D13 - \textcircled{3} 100$$

Foundation Slab

D 40 j 28.9

Case 1. Cantilever $l = 0.87 \sim 1.80$

$$w_{NET} = 11.22 - (1.1 \times 1.6 + 1.02) = 8.44$$

$$M = 8.44 \times 1.8^2 / 2 = 13.67 \quad \text{at } 15.8$$

$$Q = 8.44 \times 1.8 = 15.19 \quad \text{at } 35.0$$

Case 2. 2 Edge Fix $l = 1.8$

$$w_s = 8.44$$

$$M = 8.44 \times 1.8^2 \times 0.279 = 7.93$$

$$Q = 8.44 \times 1.8 = 15.19$$

Case 3. $l_x = 3.0$ by 6.0 $\bar{w}_s = (11.01 + 6.27) / 2 - 1.02 = 7.87$ $\lambda = 2$

$$M = 7.87 \times 3.0^2 \times 0.083 = 5.88$$

$$Q = 7.87 \times 3.0 \times 0.51 = 12.04$$


Case 4. $l_x = l_y = 6.0$ $\lambda = 1$ $w_L = 3.95 - 1.02 = 2.83$

$$M = 2.83 \times 6.0^2 \times 0.072 = 5.30 \quad \text{at } 6.1$$

$$Q = 2.83 \times 6.0 \times 0.44 = 7.47 \quad \text{at } 17.2$$

$$FS \quad \left(\begin{array}{l} \text{TOP} \\ \text{BTM} \end{array} \right. \quad \begin{array}{l} D13 - @ 150 C. \\ D19 - @ 150 C. \end{array}$$

Soil Pressure for Outside Beam



$$w_{max} = K_a \gamma (C_s + Q)$$

$$= 0.3 \times 1.6 (0.3 + 1.1)$$

$$= 1.12 \quad [t/m]$$

$$Q = 1.12 \times 1.12 / 2 = 0.63 \quad [t/m]$$

$$M = 1.12 \times 1.12^2 / 6 = 0.27 \quad [tm]$$

$$D 30 \quad j \quad 19.25 \quad \square \quad D 13 - @ 150$$

Upper Slab

L.L. 0.30
 D.L. 0.06 Finish + 0.48 Slab = 0.54
 T.L. 0.84

$R_x = R_y = 6.0 \quad \lambda = 1 \quad D20 \text{ } \bar{J} 144$

$N \quad 0.84 \times 6^2 \times 0.052 \quad 1.57 \quad \text{at } 5.5 \quad D10 - @150 \text{ D.C.}$
 $Q \quad 6 \times 0.44 \quad 2.22 \quad \phi \quad 7.3$

Column

$N (31.3 \sim 15.7) \pm 185.9 = \text{MAX } 217.2 \quad [t]$
 $\text{MIN } -170.2$

$b = D = 90 \quad \sigma_c = 217,200 / 8,100$
 $= 26.8 < f_c = 100 \quad (f_c = 150)$
 $[F\%_{cm^2}]$

$\sigma_s = \frac{170.2}{3.0}$
 $= 56.7$

$P_g \quad 0.8$
 $q_g \quad 64.8$

12 - D25
 ↓
 16 - D25
 □ D13 @ 100

If Beam is'nt considered,

$N = 217.2 \sim -170.2$
 $Q = 26.9/2 = 13.5$
 $M = 13.5 \times (1.0 + 1.1) = 28.4$

$\frac{N}{bD} \quad 26.8 \sim -21.0$
 $\frac{M}{bD^2} \quad 3.9$

$QAS \quad 60.2 > 15.5$


$P_t \quad 0.50$
 $\text{at } 40.5$
 8 - D25

Total 28 - D25

Pump Roof

Roof Wall $D=150 \quad D10 @ 200 \text{ D.C.} \quad (M = 0.06 \times 4^2 / 16 = 0.66 \text{ at } 2.6)$
 $\bar{D} \quad \bar{J} \quad 10.9$

Beam



$\bullet D19 \quad W = 0.84 \times 6 \times 3/2 = 7.56$
 $M = 7.56 \times 6 \times 0.104 = 4.8$
 $Q = 7.56 / 2 = 3.78$

$D4R \quad \bar{J} \quad 3R \quad b2R$
 $\text{at } 6.9 \quad 3 - D19$
 $\phi \quad 5.1 \quad \text{BAL } 6.1$

Column

C1 (+1.000 Level) Φ 406.4 x 7.9

$$N = (31.3 \sim 15.17) \pm 185.9 = 217.2 \sim -170.2$$

$$C = 0.7, \rho = 0.28, A = 0.4 \quad c_p A = 0.0784 \text{ [cm]}^2$$

$$M_0 = 0.0784 \times 4.8^2 / 8 = 0.226 \text{ [tm]}^2$$

$$A = 98.9, I = 14.1, I_k = 520, \lambda = 36.9, f_c = 1.48 \text{ [t/cm}^2\text{]}$$

$$\frac{\sigma_c}{f} = \frac{217.2}{98.9 \times (1.48 \times 1.5)} = 0.99$$

$$\frac{\sigma_t}{f} = \frac{170.2}{98.9 \times 2.4} = 0.72$$

$$\geq 1.150 \quad \frac{\sigma_b}{f} = \frac{22.6}{1.150 \times 2.4} = 0.01$$

$$1.00 \leq 1.00$$



$$\text{JOINT} \quad N = (31.3 \sim 15.17) \pm 107.3 = 138.6 \sim -91.6$$

$$\sigma_c = \frac{107.300}{\frac{\pi}{4} \times 60^2} = 37.9 \text{ [kg/cm}^2\text{]}$$

$$\text{H.T.B.} \quad \Delta T = \frac{91.6}{8} = 11.5 \text{ [t]}$$

$$< M24 \quad R = 21.0$$

B.R.



BR 40 x 600

8 RIBS 9 x 200

8-M24

$$r_x = 9.7 \quad r_y = 19.8 > 2.0 \quad \omega = 37.9$$

$$M = 37.9 \times 9.7^2 \times 0.28 = 998.5 \text{ [kg cm/cm]}^2$$

$$Q = 37.9 \times 9.7 \times 1.00 = 367.6 \text{ [kg/cm]}^2$$

 $\Delta T = 11.5$

$$M = (11.5 \times 9.7 / 2) / 9.7 = 5.75 \text{ [t cm/cm]}^2$$

$$Q = 11.5 / 9.7 = 1.19 \text{ [t/cm]}^2$$

$$M_Z = \frac{5.75}{2.4} = 2.36$$

$$r_t = \sqrt{6 \times 2.36} = 3.79 \rightarrow R = 40$$

Welding

$$R = 0.79 \times 2.4 = 1.90 \text{ [t/cm]}^2 > Q = 1.19$$

Rib R



$$Q = 37.9 \times 9.7^2 = 3,566.0 \text{ [kg]}^2$$

$$M = 3,566.0 \times 7.7 \times 2/3 = 23,060.2 \text{ [kg cm]}^2$$

$$nZ = \frac{23,060.2}{2,400} = 9.61$$

$$nt = \frac{5 \times 9.61}{20^2} = 0.14 \rightarrow R9$$

Welding

$$Z = \frac{(0.7 \times 0.7 \times 2) \times 20^2}{6} = 65.3$$

$$A = 0.7 \times 0.7 \times 2 \times 20 = 19.6$$

$$\sigma'_M = 23,060.2 / 65.3 = 353.1$$

$$\sigma'_Q = 3,566.0 / 19.6 = 181.9$$

$$\sqrt{353.1^2 + 3 \times 181.9^2} = 473.2 < f = 1,200 \text{ [kg/cm}^2\text{]}$$

Bottom

$$N = 217.2 \sim -170.2, \quad Q = 11.8$$

$$\sigma_0 = \frac{217,200}{\frac{\pi}{4} \times 60^2} = 64.5 < f_c = 100 \text{ [kg/cm}^2\text{]}$$

$$A.B. \Delta T = \frac{170.2}{16} = 10.6 \text{ [t]}$$

$$A_n = \frac{10.6}{1.8} = 5.9$$

$$\Phi_n = \sqrt{4 \times 5.9 / \pi} = 2.74 \rightarrow 36\phi$$

$$z = \frac{11.8 / 16}{\left(\frac{\pi \times 3.6^2}{4}\right)} = 0.017 < f_s = 1.35 \text{ [kg/cm}^2\text{]}$$

$$f_{ts} = 1.4 f_{t0} - 1.6z$$



$$= 1.4 \times 1.8 - 1.6 \times 0.017$$

$$= 2.41 \text{ [kg/cm}^2\text{]} \rightarrow f_{t0} = 1.8$$


$$\frac{\sigma}{f} = \frac{10.6}{\left(\frac{\pi \times 3.6^2}{4}\right) \times 1.8} = 0.48 < 1.00$$

$$\text{Anchoring } f_b = \frac{6 \times 15}{100} F_c = 13.5 \text{ [kg/cm}^2\text{]}$$

$$l_n = \frac{10,600}{\pi \times 3.6 \times 13.5} = 69.4 \rightarrow 120 \text{ [cm]}$$



BPE 40 x 650 φ
8 RIB RES 9 x 300
A.B. 16 - 36 φ



BPE

$$R \times 12.2 \text{ Ry } \times 1.0 \text{ w } 65.5$$

$$M = 65.5 \times 12.2^2 \times 0.085 = 828.7 \text{ [kgcm/cm]}$$

$$Q = 12.2 \times 0.19 = 392.6 \text{ [kg/cm]}$$

ΔT 10.6

$$M = (10.6 \times 4.8) / 1.98 = 6.38 \text{ [tcm/cm]}$$

$$Q = 10.6 / 1.98 = 1.33 \text{ [t/cm]}$$

$$mz = 6.38 / 2.4 = 2.66$$

$$nt = \sqrt{6 \times 2.66} = 3.99 \rightarrow R40$$

Welding

$$R = 0.09 \times 2.4 = 1.90 \text{ [kg/cm]} > Q = 1.33$$

Rib R

$$\sigma_c = 65.5 \quad \left(\sigma_t = \frac{170,200}{\frac{\pi}{4} (65^2 - 40.64^2)} = 84.2 \right)$$

$$Q = 84.2 \times 12.2^2 = 12,532.3 \quad [\text{kg}]$$

$$M = 12,532.3 \times 12.2 \times \frac{2}{3} = 101,929.6 \quad [\text{kg cm}]$$

$$n\bar{z} = \frac{101,929.6}{2,400} = 42.417$$

$$n\bar{t} = \frac{6 \times 42.417}{20^2} = 0.64 \rightarrow \#9$$

Welding

$$\bar{z} = \frac{(0.7 \times 0.7 \times 2) \times 30^2}{6} = 147.0$$

$$A = 0.7 \times 0.7 \times 2 \times 25 = 29.4$$

$$\sigma_M = 101,929.6 / 147.0 = 693.4$$

$$\sigma_Q = 12,532.3 / 29.4 = 426.3$$

$$\sqrt{693.4^2 + 3 \times 426.3^2} = 1,012.9 < f = 1,200 \quad [\text{kg/cm}^2]$$

C2 (+21,800 Level) $\Phi 406.4 \times 6.4$

$$N = (31.3 \sim 15.7) \pm 45.4 = 76.7 \sim -29.7 \text{ (t)}$$

$$C = 0.7, \quad q = 0.37, \quad A = 0.4 \quad C \cdot q \cdot A = 0.1036 \quad [\text{t/m}]$$

$$M_D = 0.1036 \times 4.8^2 / 8 = 0.298 \quad [\text{t m}]$$

$$A = 80.4, \quad \bar{z} = 14.1, \quad \bar{z}_k = 520, \quad \lambda = 36.9, \quad f_C = 1.48$$

$$\frac{\sigma_c}{f} = \frac{76.7}{80.4 \times (1.48 \times 1.6)} = 0.43$$

$$\frac{\sigma_t}{f} = \frac{29.7}{80.4 \times 2.4} = 0.15$$

$$\bar{z} = 967 \quad \frac{\sigma'_b}{f} = \frac{29.8}{967 \times 2.4} = 0.02$$

$$0.45 < 1.00$$

Joint

$$\sigma_c = \frac{76,700}{\frac{\pi}{4} \times 60^2} = 27.1$$

H.T.B.

$$\Delta T = \frac{29.7}{8} = 3.7$$

$$< M20 \quad R = 14.6$$

$$M = (3.7 \times 9.7 / 2) / 9.7 = 1.85 \quad [\text{t cm/cm}]$$

$$n\bar{z} = 1.85 / 2.4 = 0.77$$

$$n\bar{t} = \sqrt{6 \times 0.77} = 2.15 \rightarrow \#25$$

Rib R

$$\#125 - 9 \times 200$$

Beam

G1

H-400x200x8x12 (Y=16)

N_{max} 26.9 [t]

Self Load 0.10 [t/m] M₀ 0.10 x 5.6²/8 0.39 [tm]
 Q 0.10 x 5.6/2 0.28 [t]

Wind Force for Surface

C = 2.0 q = 0.31 A = 0.2 ~ 0.4
 C_qA = 0.124 ~ 0.248

M₀ 0.124 ~ 0.248 x 5.6²/8 0.49 ~ 0.97
 Q 0.124 ~ 0.248 x 5.6/2 0.35 ~ 0.69

PK 560 Zy 4.54 λE 123.3 f_c 0.63 A 84.1
 PB 560 Zb 4.26 λE 106.5 η 2.09 C 1.00 f_b 1.10 Zx 1,190 Zy 174

$$\frac{\sigma}{f} = \frac{26.9}{84.1 \times (0.63 \times 1.5)} + \frac{39 + 49}{1,190 \times (1.10 \times 1.5)} + \frac{97}{174 \times (1.10 \times 1.5)}$$

$$= 0.34 + 0.04 + 0.34$$

$$= 0.72 < 1.00$$

$$\delta = \frac{5 \times 560^4}{384 \times 2,100} \sqrt{\frac{Jx \ 23,700 \quad Jy \ 1,740}{\left(\frac{0.001 + 0.00124}{23,700}\right)^2 + \left(\frac{0.00248}{1,740}\right)^2}}$$

$$= 0.817 \text{ [cm]}$$

$$\delta / \text{span} = 0.817 / 560 = 1/644$$

JOINT 2RS 9x165x260 4-M22

G2

H-390x300x10x16 (Y=22)

N_{max} 10.7 [t]

C = 0.8 q = 0.37 A = 1.5 ~ 2.8 0.8 x 0.37 x 1.5 ~ 2.8 = 0.444 ~ 0.829

M₀ 0.444 ~ 0.829 x 5.6²/8 1.74 ~ 3.25
 Q 0.444 ~ 0.829 x 5.6/2 1.24 ~ 2.32

PK 560 Zy 7.28 λE 76.9 f_c 1.13 A 136.0
 PB 560 Zb 8.10 λE 69.1 η 6.58 C 1.00 f_b 1.60 Zx 1,980 Zy 481

$$\frac{\sigma}{f} = \frac{10.7}{136.0 \times (1.13 \times 1.5)} + \frac{39 + 174}{1,980 \times (1.6 \times 1.5)} + \frac{325}{481 \times (1.6 \times 1.5)}$$

$$= 0.38 < 1.00$$

$$\delta = \frac{5 \times 560^4}{384 \times 2,100} \sqrt{\frac{Jx \ 38,700 \quad Jy \ 7,210}{\left(\frac{0.001 + 0.00444}{38,700}\right)^2 + \left(\frac{0.00829}{7,210}\right)^2}}$$

$$= 0.71 \text{ [cm]}$$

$$\delta / \text{span} = 0.71 / 560 = 1/798$$

Sub Beam

B1 ↓ D.L.

$$q = 0.05 \text{ [t/m]}$$

$$P = 0.05 \times 7.9 / 2 = 0.20 \text{ [t]}$$

W.L.

$$C = 2.0 \quad q = 0.31 \quad A = 0.2$$

$$q = 2.0 \times 0.31 \times 0.2 = 0.124 \text{ [t/m]}$$

$$P = 0.124 \times 7.9 / 2 = 0.49 \text{ [t]}$$

T.L.

$$q = 0.05 + 0.124 = 0.174 \text{ [t/m]}$$

$$P = 0.20 + 0.49 = 0.69 \text{ [t]}$$

$$M_0 = 0.174 \times 7.9^2 / 8 + 0.69 \times 7.9 / 4 = 2.72 \text{ [tm]}$$

$$Q = 0.174 \times 7.9 / 2 + 0.69 / 2 = 1.03 \text{ [t]}$$

$$Z_H = 2.72 / 2.4 = 113.3 \text{ [cm}^3\text{]}$$


$$J_H = \frac{5 \times 0.00174 \times 7.9^3 \times 300}{384 \times 2,100} + \frac{0.69 \times 7.9^2 \times 300}{48 \times 2,100} = 2,817.4 \text{ [cm}^4\text{]}$$

$$H - 400 \times 200 \times 6.0 \times 9.0 \quad Z_x 602, \quad J_x 16,500 \\ (C_y = 0)$$

B2

$$H - 400 \times 200 \times 4.5 \times 6.0 \quad Z_x 438, \quad J_x 11,500$$

B3



$$P_1 = P_2 = (0.10 \times 4.0) + 12.5 = 13.0 \\ \text{Fl. Tank}$$

$$M_0 = 13.0 \times 7.9 / 2 = 51.35 \text{ [tm]}$$

$$Q = 13.0 \times 1.6 = 19.5 \text{ [t]}$$

$$Z_H = 51.35 / 1.6 = 3,209.4 \text{ [cm}^3\text{]}$$

$$J_H = \frac{19 \times 13.0 \times 7.9^3 \times 300}{384 \times 2,100} = 57,348.5 \text{ [cm}^4\text{]}$$

$$H - 400 \times 400 \times 13 \times 21 \quad Z_x 3,030, \quad J_x 66,600$$

$$P = (0.10 \times 4.0) + 12.5 = 13.0$$



$$Z_H = \frac{13.0 \times 4.0 \times 100}{4 \times 1.6} = 812.5$$

$$J_H = \frac{13.0 \times 400^3 \times 300}{48 \times 2,100} = 6,190.5$$

$$H - 400 \times 200 \times 8 \times 13 \quad Z_x 1,190, \quad J_x 23,700$$

$$q = 0.30 \times 0.5 = 0.15$$

$$Z_H = 0.15 \times 4^2 \times 100 / 8 \times 1.6 = 18.8$$

$$J_H = 5 \times 0.0015 \times 400^3 \times 300 / 384 \times 2,100 = 178.6$$

$$H - 400 \times 200 \times 4.5 \times 6.0$$

B5

RACING

B11 Φ 165.2 x 5.0 (A 35.16, J 808, Z 74.3)

N max 35.6 [t] HTB $\frac{35.6}{17.1} = 3 - M22$ $A_n = \frac{35.6}{2.4} = 14.8$
14.1 3-M20 Φ 12 x 200
 Self load 0.02 [t/m] M_0 $0.02 \times 5.6^2/8$ 0.08 [t/m]
Q $\times 5.6/2$ 0.06 [t]

Wind Force for Side Surface

$C = 0.7$ $\gamma = 0.28$ $A = 0.1652$
 $CQA = 0.0324$ [t/m]
 $P = 0.0324 \times 7.3/2 = 0.1182$ [t]

M_0 $0.0324 \times 7.3^2/8 + 0.1182 \times 7.3/4 = 0.4315$ [t/m]
Q $\times 7.3/2 + \times 1/2 = 0.1774$ [t]

$\frac{\sigma}{f} = \frac{35.6}{25.16 \times 2.4} \pm \frac{(8.0 + 43.15)}{97.3 \times 2.4}$ ($\sqrt{0.7 \times 0.7 \times 1.2 = 0.42}$)
 $= 0.59 + 0.22$ ($P = 35.6/0.42 \times 2$)
 $= 0.81 < 1.00$ = 42.4 \rightarrow 25 x 2

$\delta = \frac{5 \times 0.000324 \times 730^4}{384 \times 2,100 \times 808} + \frac{0.1182 \times 730^3}{48 \times 2,100 \times 808}$
 $= 0.71 + 0.56$
 $= 1.27$ [cm]

$\delta/SPAN = 1.27/730 = 1/575$

B12 Φ 139.8 x 4.5 (A 19.13, J 438, Z 62.7)

N max 19.7 [t] HTB $\frac{19.7}{14.1} = 2 - M22$ $A_n = \frac{19.7}{2.4} = 8.2$
2-M20 Φ 9 x 150
 D.L. 0.02 M_0 0.08 Q 0.06
 CQA $0.7 \times 0.37 \times 0.1398 = 0.0362$

P $0.0362 \times 7.3/2 = 0.1322$
 M_0 $0.0362 \times 7.3^2/8 + 0.1322 \times 7.3/4 = 0.4824$
Q $\times 7.3/2 + \times 1/2 = 0.1982$


$\frac{\sigma}{f} = \frac{19.7}{19.13 \times 2.4} \pm \frac{8 + 48.2}{62.7 \times 2.4}$
 $= 0.43 + 0.37$
 $= 0.80 < 1.00$

$\delta = \frac{5 \times 0.000362 \times 730^4}{384 \times 2,100 \times 438} + \frac{0.1322 \times 730^3}{48 \times 2,100 \times 438}$
 $= 1.46 + 1.16$
 $= 2.62$ [cm]

$\delta/SPAN = 2.62/730 = 1/279$

Stair Case

Step CR 4.5



$w = 0.30$ [m^2]

\leftarrow $l = 30$ [cm]

$$z_n = \frac{0.3 \times 0.3^2 \times 100}{8 \times 1.6} = 0.211$$

$$t_n = \sqrt{6 \times 0.211 / 100} = 0.11$$

$$J_n = \frac{5 \times 0.003 \times 30^3 \times 300}{384 \times 2,100} = 0.151$$

$$t_n = \sqrt[3]{12 \times 0.151 / 100} = 0.26$$

\uparrow $l = 70$ [cm]

$$f = 0.3 \times 0.15 = 0.045$$

$$z_n = \frac{0.045 \times 0.7^2 \times 100}{8 \times 1.6} = 0.172$$

$$t_n = 6 \times 0.172 / 5^2 = 0.04$$

$$J_n = \frac{5 \times 0.00045 \times 70^3 \times 300}{384 \times 2,100} = 0.287$$

$$t_n = 12 \times 0.287 / 5^3 = 0.03$$

String RC

$f = 0.3 \times 0.35 = 0.105$ [m^2]

$$z_n = \frac{0.105 \times 4^2 \times 100}{8 \times 1.6} = 13.125$$

$$t_n = 6 \times 13.125 / 30^2 = 0.09$$

$$J_n = \frac{5 \times 0.00105 \times 400^3 \times 300}{384 \times 2,100} = 125.0$$

$$t_n = 12 \times 125.0 / 30^3 = 0.06$$

$Q = 0.105 \times 2 = 0.21$

Sub Beam

B5

P P = 0.21



H - 200 x 100 x 5.5 x 8

(END)

2. CALCULATION SHEET OF VENTILATION AND AIR CONDITIONING

C O N T E N T S

	PAGE
1 GENERAL	
2 DESIGN CONDITIONS	536
3 AIR CONDITIONING	538
(1) COOLING LOAD ESTIMATION ON "INJ. PUMP SHOP"	
(2) COOLING LOAD ESTIMATION ON "GENERAL MANAGER ROOMS & ADVISOR'S OFFICE ROOM"	
(3) TOTAL	
4 VENTILATION	540
5 AIR CONDITIONING EQUIPMENTS	542
(1) "INJECTION PUMP SHOP"	
(2) "GENERAL MANAGER ROOM"	
(3) "ADVISOR'S OFFICE ROOM"	
6 VENTILATION EQUIPMENTS	544
(1) DOUBLE SECTION CENTRIFUGAL FAN	
(2) TUBULAR ROOF FAN	
(3) ROOF FAN	
(4) CEILING TYPE VENTILATING FAN	
(5) FILTER AND THE LIFE	

APPENDIX X LOAD ESTIMATION

1 GENERAL

NAME OF CONSTRUCTION : THE SANITARY AND VENTILATION
EQUIPPING WORK IN BANGLADESH
CAR REPAIR SHOP

TOTAL FLOOR AREA : 18,000 M²

LOCATION : DACCA, BANGLADESH

THE NORTH LATITUDE - 23°45'

THE EAST LONGITUDE - 90°15'

8 m ABOVE THE SEA LEVEL

DESIGN CONDITIONS

CLIMATIC CONDITIONS

THE DESIGNING OUTDOOR TEMPERATURE IN
THE SUMMER SEASON (APR.) : 37.2°C (D.B.)

AVERAGE HUMIDITY : 78 %

DAILY TEMP. RANGE : 10°C

THE DESIGNING OUTDOOR TEMPERATURE IN
THE WINTER SEASON (FEB.) : 10°C (D.B.)

THE HIGHEST OUTDOOR TEMP. : 40.5°C (APR.)

THE LOWEST OUTDOOR TEMP. : 6.6°C (FEB.)

ANNUAL RAINFALL : 2012 MM/YEAR

THE HIGHEST RAINFALL IN 24
HOURS : 236 MM/DAY

THE RAINY SEASON : APR. THROUGH OCT.

WIND : 2.2 M/S

REFERENCE "THE CLIMATE OF ASIA"

AIR CONDITIONING

AIR CONDITIONING INSTALLATION ARE REQUIRED FOR THE FOLLOWING THREE ROOMS:

- (1) "INJ. PUMP SHOP", HEAVY REPAIR FACTORY
- (2) "GENERAL MANAGER ROOM", GENERAL OFFICE BLDG. (1F)
- (3) "ADVISOR'S OFFICE ROOM", GENERAL OFFICE BLDG. (2F)

THE STRUCTURE OF ROOM IS DIFFERENT AMONG (1), (2) AND (3).

(1) COOLING LOAD ESTIMATION ON "INJ. PUMP SHOP"

OUTDOOR 37.2°C (D.B.) 78%

INDOOR 26.0°C (D.B.) 55%

HEAT TRANSMISSION COEFFICIENT (KCAL/M²HR°C)

EXTERNAL WALL 1.6 (UP TO 1.5 M ABOVE THE FLOOR)

0.5 (OVER 1.5 M ABOVE THE FLOOR)

INTERNAL WALL 1.4 (UP TO 1.5 M ABOVE THE FLOOR)

0.4 (OVER 1.5 M ABOVE THE FLOOR)

ROOF 1.0

FLOOR NOT ESTIMATED DUE TO ITS DEFINITE POSITION WITHIN THE SAFETY RANGE.

TEMPERATURE DIFFERENCE

EQUIVALENT TEMP. DIFFERENCE I
ON EXTERNAL WALL (°C)

	10:00	12:00
N	6.9	7.2
E	11.2	11.0

EQUIVALENT TEMP. DIFFERENCE II
ON EXTERNAL WALL (°C)

	10:00	12:00
N	9.5	15.0
E	26.8	18.8

EQUIVALENT TEMP. DIFFERENCE
ON ROOF (°C)

	10:00	12:00
H	34	42.5

TEMP. DIFFERENCE ON INTERNAL WALL $37.2 - \frac{37.2 + 26.0}{2} = 5.6^\circ\text{C}$

CALORIFIC VALUE GENERATED IN ROOM

LIGHTING 20 W/M²

NUMBER OF PERSONS 3 PERSONS 71 KCAL/HR·PERSON S.H.G.

152 KCAL/HR·PERSON L.H.G.

AIR INFILTRATION THROUGH TWO-SIDED DOOR 30 M³/HR·PERSON

(2) COOLING LOAD ESTIMATION ON "GENERAL MANAGER ROOM" & "ADVISOR'S OFFICE ROOM"

INDOOR 26.0°C (D.B.) 78%

OUTDOOR 37.2°C (D.B.) 55%

HEAT TRANSMISSION COEFFICIENT (KCAL/M²HR.°C)

EXTERNAL WALL 1.6

WINDOW 5.5

INTERNAL WALL 2.5

FLOOR 1.7

CEILING 1.2

ROOF 1.4

TEMPERATUR DIFFERENCE AND SOLAR RADIATION

EQUIVALENT TEMP DIFFERENCE
ON EXTERNAL WALL (°C)

	16:00	18:00
N	5.7	6.2
S	8.8	9.6
W	9.3	13.1

SOLAR RADIATION THROUGH
ORDINARY WINDOWS (KCAL/M²HR)

	16:00	18:00
N	29	16
S	31	5
W	436	153

EQUIVALENT TEMP. DIFFERENCE
ON ROOF (°C)

	16:00	18:00
H	20.8	22.8

TEMP. DIFFERENCE FROM NON-AIR CONDITIONED SECTION $37.2 - \frac{37.2 + 26.0}{2} = 5.6$

CALORIFIC VALUE GENERATED IN ROOM

LIGHTING 20 W/M^2

NUMBER OF PERSON 1 PERSON 50 KCAL/HR·PERSON S.H.G
60 KCAL/HR·PERSON L.H.G

AIR INFILTRATION ROOM VOLUME X 0.7 N/HR.
(REFERENCE: AIR CONDITIONING HANDBOOK)

TOTAL	UNIT: KCAL/HR		
	S.H.G	L.H.G	TOTAL
INJ. PUMP SHOP	7,510	1,810	9,320
GENERAL MANAGER RM.	6,020	1,370	7,390
ADVISOR'S OFFICE RM.	7,840	1,570	9,410

REGARDING TO THE TYPE OF AIR CONDITIONING EQUIPMENTS, THE PACKAGE TYPE SHOULD BE CONSIDERED FOR "INJ. PUMP SHOP" DUE TO O.A. INSTALLATION AND A WINDOW TYPED COOLER FOR "GENERAL MANAGER ROOM" & "ADVISOR'S OFFICE RM."

4 VENTILATION

VENTILATION INSTALLATION IS REQUIRED FOR W.C. AND KETTLE ROOM THAT HAVE NO WINDOWS, AND KITCHEN, RELATED SECTIONS IN THE SHOP (PAINTING, WELDING, HEAT-GENERATING AND CEMENTING SECTIONS ETC.). A LIST ON THE FOLLOWING PAGE SHOWS THE VOLUME OF CHANGED AIR CALCULATED FROM NECESSARY NUMBERS OF AIR CHANGE,

EXAMPLE) NECESSARY NUMBERS OF AIR CHANGE

PAINTING WORKS : 30 - 60 N/HR. WELDING WORKS : 15 - 25 N/HR.
STORAGE : 5 N/HR.
KITCHEN : 40 - 80 N/HR. W.C. : 15 N/HR.

NAME OF BLDG.	FLOOR	NAME OF ROOM	RM. VOLUME m^3	NUMBER OF AIR CHANGE N/HR.	VOLUME OF CHANGED AIR $m^3/HR.$
PARTS STORAGE	GF	PARTS ROOM	11,270	5	56,400
PAINT & BODY FACTORY	GF	PAINT SHOP	3,570	45	160,650
RETREADING & METAL CASTING FACTORY	GF	METAL CASTING SHOP	1,044	20	20,900
	GF	BOILER	379	30	11,400
	GF	HOT WATER SYSTEM	592	20	11,800
	GF	CEMENT ROOM	164	20	3,280
CHECK GATE	GF	KETTLE ROOM	12	7	84
CAFETERIA	GF	KITCHEN	467	60	28,020
	GF	TOILET	12	14	168
DORMITORY	GF	KITCHEN	139	60	8,340
GENERAL OFFICE BUILDING	GF	SANITARY CLOSET	24	—	360
	1F	KETTLE ROOM	15	—	360

THE FIRST CLASS VENTILATION IS REQUIRED ONLY FOR PARTS STORAGE, AND FOR OTHERS, THE THIRD CLASS VENTILATION SHALL BE APPLIED.

5 AIR CONDITIONING EQUIPMENTS

(1) "INJ PUMP SHOP"

EQUIPMENTS: 2 UNITS OF AIR COOLED SPLIT TYPED AIR CONDITIONER

S.H.G. 3,760 KCAL/HR.

L.H.G. 910 KCAL/HR.

O.A. AIR VOLUME 150 M³/2

O.A. LOAD 240 KCAL/HR.

SUPPLY AIR VOLUME (OUTLET TEMPERATURE 17°C)

$$\frac{3,760}{0.29 \times 9} = 1,440 \text{ M}^3/\text{HR.}$$

$$24 \text{ M}^3/\text{MIN.}$$

SPECIFICATIONS OF EQUIPMENTS

REFERENCE EQUIPMENT: DP-34 V1, MITSUBISHI HEAVY INDUSTRY CO.

COOLING CAPACITY: 7,100 KCAL/HR. (OUTDOOR TEMP. 37.2°C)

SUPPLY AIR VOLUME: 1,440 M³/HR.

REFRIGERANT: R-22

POWER CONSUMPTION: 3 ϕ x 415 V x 50 HZ x 3.3 KW

(2) " GENERAL MANAGER ROOM "

EQUIPMENTS: 2 UNITS OF WINDOW TYPED AIR CONDITIONER

ROOM COOLING LOAD $7,390 \text{ KCAL/HR} / 2 = 3,700 \text{ KCAL/HR/UNIT}$

SPECIFICATIONS OF EQUIPMENTS

REFERENCE EQUIPMENT: CW-171PS235T, NATIONAL

COOLING CAPACITY: $4,020 \text{ KCAL/HR. (OUTDOOR TEMP. } 37.2^{\circ}\text{C)}$

VENTILATABLE TYPE

REFRIGERANT: R-22

POWER CONSUMPTION: $1\phi \times 240^{\text{V}} \times 50^{\text{Hz}} \times 2.4^{\text{KW}}$

(3) " ADVISOR'S OFFICE ROOM "

EQUIPMENTS: 2 UNITS OF WINDOW TYPED AIRCONDITIONER

ROOM COOLING LOAD: $9,410 \text{ KCAL/HR} / 2 = 4,710 \text{ KCAL/HR/UNIT}$

SPECIFICATIONS OF EQUIPMENTS

REFERENCE EQUIPMENT: CW-24/PS235T, NATIONAL

COOLING CAPACITY: $5,560 \text{ KCAL/HR. (OUTDOOR TEMP. } 37.2^{\circ}\text{C)}$

VENTILATABLE TYPE

REFRIGERANT: R-22

POWER CONSUMPTION: $1\phi \times 240^{\text{V}} \times 50^{\text{Hz}} \times 3.4^{\text{KW}}$

6 VENTILATION EQUIPMENTS

(1) DOUBLE SUCTION CENTRIFUGAL FAN

THIS FAN IS USED FOR SUPPLYING AIR TO PARTS STORAGE.
FAN ROOMS SHALL BE PROVIDED IN ONE POSITION ON THE DECK AND AT TWO POSITIONS ON THE MONITOR ROOF.

SPECIFICATIONS OF EQUIPMENTS

a) FAN ROOM (DECK)

REFERENCE EQUIPMENTS: DRM NO. 4, EBARA

SUPPLY AIR VOLUME : 27,000 M³/HR. (450 M³/MIN.)

STATIC PRESSURE : 45 MM Aq

POWER CONSUMPTION : 3 ϕ X 415 V X 50 HZ X 7.5 KW

b) FAN ROOM (2 POSITIONS ON THE MONITOR ROOF)

REFERENCE EQUIPMENTS: 2 UNITS OF DRM NO. 3, EBARA

SUPPLY AIR VOLUME : 16,200 M³/HR. (270 M³/MIN.)

STATIC PRESSURE : 40 MM Aq

POWER CONSUMPTION : 3 ϕ X 415 V X 50 HZ X 5.5 KW

(2) TUBULAR ROOF FAN

THIS FAN IS USED FOR DIRECT EXHAUST FROM HOOD IN TWO KITCHENS.

SPECIFICATIONS OF EQUIPMENTS

a) CAFETERIA HOOD 3600 X 2400

REFERENCE EQUIPMENTS : RTFKV-75, ASAHI

EXHAUST AIR VOLUME : 15,000 M³/HR.

STATIC PRESSURE : 30 MM Aq

POWER CONSUMPTION : 3 ϕ X 415^V X 50^{Hz} X 3.7^{KW}

b) CAFETERIA HOOD 2,800 X 2,400

REFERENCE EQUIPMENTS : RTFKV-75, ASAHI

EXHAUST AIR VOLUME : 13,000 M³/HR.

STATIC PRESSURE : 30 MM Aq

POWER CONSUMPTION : 3 ϕ X 415^V X 50^{Hz} X 3.7^{KW}

c) DORMITORY HOOD 2,000 X 1,400

REFERENCE EQUIPMENTS : RTFKV-70, ASAHI

EXHAUST AIR VOLUME : 8,400 M³/HR

STATIC PRESSURE : 30 MM Aq

POWER CONSUMPTION : 3 ϕ X 415^V X 50^{Hz} X 2.2^{KW}

ALL OF THE ABOVE MODELS SHALL BE SPECIFIED AS HEAT-RESISTANT AND OIL-RESISTANT.

(3) ROOF FAN

THE FOLLOWING THREE KINDS OF ROOF FAN SHALL BE USED FOR EXHAUST IN SHOPS

SPECIFICATIONS OF EQUIPMENTS

a) PAINT SHOP

REFERENCE EQUIPMENT : RF - 42 H, KAMAKURA

EXHAUST AIR VOLUME : 37,200 M³/HR.

POWER CONSUMPTION : 3 ϕ X 415^V X 50^{Hz} X 2.2^{KW}

b) METAL CASTING SHOP, BOILER, HOT WATER SYSTEM

REFERENCE EQUIPMENT : RF - 24 H, KAMAKURA

EXHAUST AIR VOLUME : 11,700 M³/HR

POWER CONSUMPTION : 3 ϕ X 415^V X 50^{Hz} X 0.75^{KW}

c) CEMENT ROOM

REFERENCE EQUIPMENT : RF - 16 H, KAMAKURA

EXHAUST AIR VOLUME : 2,580 M³/HR

STATIC PRESSURE : 10 MMHg

POWER CONSUMPTION : 3 ϕ X 415^V X 50^{Hz} X 0.25^{KW}

(4) CEILING TYPE VENTILATING FAN

THIS FAN IS USED FOR EXHAUST IN TOILET AND/OR KETTLE ROOM ETC WHICH DO NOT HAVE WINDOWS NOR FACE THE EXTERNAL WALL.

a) KETTLE ROOM : CHECK GATE

REFERENCE EQUIPMENTS : FV-14 BFT, NATIONAL

EXHAUST AIR VOLUME : 84 M³/HR.

STATIC PRESSURE : 5 MM Aq. (DUCT + VENT CAP)

POWER CONSUMPTION : $1 \phi \times 240^V \times 50^{HZ} \times 0.023^{KW}$

b) TOILET ; CAFETERIA

REFERENCE EQUIPMENTS : FV-18 BFT, NATIONAL

EXHAUST AIR VOLUME : 168 M³/HR.

STATIC PRESSURE : 5 MM Aq. (DUCT + VENT CAP)

POWER CONSUMPTION : $1 \phi \times 240^V \times 50^{HZ} \times 0.038^{KW}$

c) KETTLE ROOM, SANITARY CLOSET; GENERAL OFFICE BLDG.

REFERENCE EQUIPMENTS : FV-20 BFT

EXHAUST AIR VOLUME : 360 M³/HR.

STATIC PRESSURE : 5 MM Aq. (DUCT + VENT CAP)

POWER CONSUMPTION : $1 \phi \times 240^V \times 50^{HZ} \times 0.05^{KW}$

(5) FILTER AND THE LIKE

a) CA FILTER

FILTERS SHALL BE ATTACHED IN SUPPLYING AIR FROM LOUVRE. THE SPEED OF AIR PASSING THROUGH THE FILTERS WAS SELECTED AT 2 M/S

SPECIFICATIONS OF FILTER

FILEDON UNIT TYPED AIR FILTER, MODEL VA-25
500 MM X 500 MM X 25 MM

FAN ROOM 1 (DECK)

$$\frac{27,000 \text{ (M}^3\text{/HR)}}{3600 \times 2 \text{ (M/S)} \times 0.25 \text{ (M}^2\text{)}} = 15 \text{ (SHEETS)}$$

3 STEPS 5 LINES

FAN ROOM 2, 3 (MONITOR ROOM)

$$\frac{16,200 \text{ (M}^3\text{/HR)}}{3600 \times 2 \times 0.25} = 9 \text{ (SHEETS)}$$

3 STEPS 3 LINES

b) GREASE FILTER

GREASE FILTERS SHALL BE ATTACHED TO THE HOOD OF KITCHENS. THE SPEED OF AIR PASSING THROUGH WAS SELECTED BETWEEN 1.5 MM/S AND 2 MM/S.

SPECIFICATIONS OF FILTER

FIRE FIGHTER FN 2020, FN 1625
FN 2020 500 MM X 500 MM X 45 MM
FN 1625 400 MM X 630 MM X 45 MM

HOOD 3600 X 2400

FN 2020 X 12 SHEETS STATIC PRESSURE 21 MM Aq

HOOD 2800 X 2400

FN 2020 X 10 SHEETS STATIC PRESSURE 22 MM Aq

HOOD 2000 X 1400

FN 1625 X 6 SHEETS STATIC PRESSURE 24 MM Aq

ROOM NO.	ROOM NAME	GENERAL MANAGER		ROOM AREA	W x L = A m ²		ROOM VOLUME	A x H = V m ³		SYSTEM		
		ROOM			41.7			125				
SENSIBLE HEAT LOAD					SUMMER				WINTER			
GAIN & TRANS. GAIN THRU STRUCTURES					SUN TIME 16 H			SUN TIME 18 H			SENSIBLE HEAT LOSS	
DIREC.	W x H	AREA	K	TEMP. DIFF.	HEAT GAIN	TEMP. DIFF.	HEAT GAIN	DIREC. FACTOR	TEMP. DIFF.	HEAT LOSS		
	m x m	m ²	Kcal/h.m ² .°C	°C	Kcal/h	°C	Kcal/h		°C	Kcal/h		
W		26.8	1.6	9.3	400	13.1	560					
S		16.0	1.6	8.8	230	9.6	250					
N		4.6	1.6	5.7	40	6.2	50					
W		5.8	5.5	11.2	360	11.2	360					
S		5.8	5.5	11.2	360	11.2	360					
		25.5	2.5	5.6	360	5.6	360					
		41.7	1.7	5.6	400	5.6	400					
SUB TOTAL (I)					2150			2360			SUB TOTAL	
GAIN THRU GLASS					F	I _{GR}	I _{GR}	INFILTRATION				
W		5.8		436	2530	153	890	m ³ x R/h x 0.288				
S		5.8		31	180	5	30	x				
SUB TOTAL (II)					2710			920				
INTERNAL HEAT GAIN					TOTAL (SH)							
DE. LIGHT		KW x 860							LATENT HEAT LOSS			
RE. LIGHT	20 W/m ²	41.7 x 1,000		830					INFILTRATION			
					m ³ x R/h x 715					x		
PEOPLE	WALKING		x						TOTAL (LH)			
	SEATED		1 x 50	50								
VENTILATION	125	m ³ x 0.7 R/h x 0.288		11.2	280					GRAND TOTAL		
SUB TOTAL (III)					1160							
TOTAL OF SENSIBLE HEAT LOAD (I + II + III)					6020							
LATENT HEAT LOAD										REMARKS:		
PEOPLE	WALKING		x						DESIGN COND.			
	SEATED		1 x 60	60					26.0°C 55% (ROOM)			
VENTILATION	125	m ³ x 0.7 R/h x 715		0.0226 0.0116	1310					37.2°C 78% (OUT)		
TOTAL OF LATENT HEAT LOAD (IV)					1370							
TOTAL OF HEAT GAIN					7390							
HEAT FACTOR					%							
AIR QUANTITY					m ³ /h							
AIR QUANTITY					m ³ /h							

ROOM NAME		ADVISORS		ROOM AREA	W x L = A m ²	ROOM VOLUME	A x H = V m ³	SYSTEM		
OFFICE ROOM					48.1		144			
SENSIBLE HEAT LOAD				SUMMER				WINTER		
RADIANT & TRANS. GAIN THRU STRUCTURES				SUN. TIME 16 H	SUN. TIME 18 H	SENSIBLE HEAT LOSS				
DIREC.	W x H	AREA	K	TEMP. DIFF.	HEAT GAIN	TEMP. DIFF.	HEAT GAIN	DIREC. FACTOR	TEMP. DIFF.	HEAT LOSS
	m x m	m ²	Kcal/h-m ² -°C	°C	Kcal/h	°C	Kcal/h		°C	Kcal/h
W		26.8	1.6	9.3	400	12.1	560			
S		16.0	1.6	8.8	230	9.6	250			
N		16.0	1.6	5.7	150	6.2	160			
W		5.8	5.5	11.2	360	11.2	360			
S		5.8	5.5	11.2	360	11.2	360			
N		5.8	5.5	11.2	360	11.2	360			
		25.5	2.5	5.6	360	5.6	360			
		48.1	1.4	20.8	1400	22.8	1560			
SUB TOTAL (I)					3620		3950	SUB TOTAL		
RADIANT GAIN THRU GLASS				F	lgr	len	INFILTRATION			
W		5.8		436	2530	153	890	m ³ x	R/h x 0.288	
S		5.8		31	180	5	30	x		
N		5.8		29	170	6	90			
SUB TOTAL (II)					2880		1010			
INTERNAL HEAT GAIN							TOTAL (SH)			
DE. LIGHT		KW x 860				LATENT HEAT LOSS				
DE. LIGHT		20% x 48.1 x 1,000		960		INFILTRATION				
						m ³ x R/h x 715				
						x				
PEOPLE		WALKING x				TOTAL (LH)				
		SEATED 1 x 50		50						
INFILTRATION		144 m ³ x 0.7 R/h x 0.288		11.2		330		GRAND TOTAL		
SUB TOTAL (III)					1320		REMARKS:			
TOTAL OF SENSIBLE HEAT LOAD (I + II + III)							DESIGN COND. 26.0°C (55% ROOM) 37.2°C (78% OUT)			
NET HEAT LOAD										
PEOPLE		WALKING x								
		SEATED 1 x 60		60						
INFILTRATION		144 m ³ x 0.7 R/h x 715		0.0324 0.0118		1510				
TOTAL OF LATENT HEAT LOAD (IV)					1570					
TOTAL OF HEAT GAIN					9410					
HEAT FACTOR %										
AIR QUANTITY m ³ /h										
AIR QUANTITY m ³ /h										

3. CALCULATION SHEET OF WATER SUPPLY AND DRAINAGE

C O N T E N T S

1	OIL TANK	PAGE	554
2	OIL SERVICE TANK		554
3	OIL GEAR PUMP		554
4	DRAIN PUMP		554
	4-1 DRAIN PUMP OF STEAM CLEANER SYSTEM IN A HEAVY REPAIR FACTORY		
	4-2 DRAIN PUMP FOR INSPECTION FACTORY & RETREADING FACTORY		
5	COOLING TOWER FOR COMPRESSOR USE		556
6	COOLING WATER PUMP		
7	ELECTRIC BOILER FOR SHOWER USE IN A HEAVY REPAIR FACTORY		557
8	WATER SUPPLY INSTALLATION		558

1. OIL TANK

FUEL (C HEAVY) OIL

FUEL USED QUANTITY OF BOILER = 200 kg/HR

TANK CAPACITY = $200 \text{ kg/HR} \times 8 \text{ HR/DAY} \times 10 \text{ DAYS} / 0.9 \text{ kg/m}^3 = 17500 \text{ L}$ → $1,800 \phi \times 6,500 \text{ L}$ EFFECTIVE CAPACITY, 16,580 L

SYNOQUETTE SYSTEM

2. OIL SERVICE TANK

(1) (C HEAVY) OIL SYSTEM

TANK CAPACITY

SHALL BE THE VOLUME THAT COVERS 1 HOUR.

$$2000 \text{ kg} / 0.9 = 2200 \text{ L}$$

→ $750 \times 750 \times 850 \text{ mm}$ FLOAT SWITCH WITH A STEAM HEATER.

(2) (A HEAVY) OIL SYSTEM

THIS SHOULD BE USED ONLY WHEN THE BOILER IS STARTED TO BE SHUTTED.

$$500 \times 500 \times 650 \text{ mm}$$

3. OIL GEAR PUMP (C HEAVY OIL SYSTEM)

ASSUMING IT AS THREE TIMES AS MUCH AS FUEL USED QUANTITY OF BOILER.

$$200 \text{ kg/HR} \times 3 \div 60 \div 0.9 = 11 \text{ L/MIN}$$

→ REFERENCE MODEL NO.

GPE, EBARA $15 \phi \times 10 \text{ L (MIN.)} \times 3 \text{ kg/cm}^2 \times 0.4 \text{ KW}$

4 DRAIN PUMP

4-1 DRAIN PUMP OF STEAM CLEANER SYSTEM IN A HEAVY REPAIR FACTORY

4-1-1 VOLUME OF WATER

THE SIZE OF THE WATER TANK SHALL BE 1500 (L) X 1000 (W), AND THE DIFFERENCE OF THE WATER LEVEL BETWEEN ON AND OFF SHALL BE 600. THE ABOVE MENTIONED QUANTITY SHALL BE DRAINED IN 5 MINUTES.

$$1.5 \times 1 \times 0.6 \times 1000 \div 5 = 180 \text{ l/MIN} \longrightarrow 250 \text{ l/MIN.}$$

(STEAM CLEANER $1000 \text{ l/HR} \times 3 \div 60 = 50 \text{ l/MIN}$)

4-1-2 LIFT

REAL LIFT 1.4 M

PLUMBING, VALVING, ETC $\frac{2.0 \text{ M}}{3.4 \text{ M}} \longrightarrow 4 \text{ MAq}$

REFERENCE MODEL NO

50 DSS 5.75, EBARA — UNDERWATER GENERAL DRAIN PUMP

$$50 \phi \times 250 \text{ l/MIN.} \times 4 \text{ MAq} \times 0.75 \text{ KW} \times 2 \text{ UNITS}$$

4-2 DRAIN PUMP FOR INSPECTION FACTORY & RETREADING

4-2-1 VOLUME OF WATER

SAME AS IN 1-1 (250 l/MIN.)

4-2-2 LIFT

REAL LIFT 3.2 M

PLUMBING, VALVING, ETC $\frac{2.0 \text{ M}}{5.2 \text{ M}} \longrightarrow 6 \text{ MAq}$

REFERENCE MODEL NO

50 DSS 5.75, EBARA — UNDERWATER GENERAL DRAIN PUMP

$$50 \phi \times 250 \text{ l/MIN} \times 6 \text{ MAq} \times 0.75 \text{ KW} \times 2 \text{ UNITS}$$

X 2 SETS

5. COOLING TOWER FOR COMPRESSOR

40 l/MIN. + 6 UNITS = 240 l/MIN.

WATER TEMPERATURE : 50°C/40°C (IN/OUT)

CUTER AIR : 35°C 90% W.B 33.5°C

REFERENCE MODEL NO SBC-20 0.9 KW.

6 COOLING WATER PUMP

VOLUME OF WATER 240 l/MIN.

LIFT

REAL LIFT = 11 M_g

CRUISE VALVE 3

COMP. --- 6

PLUMBING, ETC $\frac{3}{14 MAg}$

REFERENCE MODEL NO

50 LPP-515, EBASA - LINE PUMP

50 ϕ x 240 l/MIN. x 14 MAg x 1.5 KW

7 ELECTRIC BOILER FOR SHOWER USE IN HEAVY REPAIR FACTORY

1. TYPE OF BOILER

THERE IS ONLY ONE SHOWER PLACE WHICH IS SUPPLIED WITH HOT WATER IN THE WHOLE SHOP. THEREFORE, A CONTINUOUS AND SUCCESSIVE USE OF THE SHOWER PLACE IS FORECASTED \longrightarrow AN INSTANTANEOUS TYPE SHALL BE EMPLOYED

2. CAPACITY

THE BOILER SHALL BE CAPABLE TO HEAT 13 l OF WATER FROM 15°C TO 45°C IN A MINUTE.

$$\text{OUTPUT} = 13 \text{ l/MIN} \times (45 - 15^\circ\text{C}) \times \frac{60}{860} \times 1.05 \approx 28.6 \text{ KW}$$

(LOSS)

REFERENCE MODEL NO

EI-30, NIKON ITOHIC $\approx 30 \text{ KW}$

1050 (W) x 1110 (H) x 190 (D)

INSTANTANEOUS AND DOUBLE TUBE TYPE

8. WATER SUPPLY

8-1 WATER SUPPLY QUANTITY FORECAST

[CENTRAL WORK SHOP]

WATER FOR LIVING

$$\text{DAILY SUPPLY FORECAST} \quad 950 \text{ PERSONS} \times 10 \text{ L/D PERSONS} = 95,000 \text{ L/D}$$

$$\text{HOURLY AVERAGE SUPPLY} \quad 95,000 \text{ L/D} \div 8 \text{ HR} = 11,875 \text{ L/HR}$$

$$\text{HOURLY MAXIMUM SUPPLY} \quad 11,875 \text{ L/D} \times 2 = 23,750 \text{ L/HR}$$

$$\text{MOMENTARY MAX. SUPPLY} \quad \frac{11,875 \text{ L/D} \times 3}{60 \text{ MIN/HR}} = 594 \text{ L/MIN}$$

WATER FOR CAR WASHING

$$\text{DAILY SUPPLY FORECAST} \quad 30 \text{ UNITS/D} \times 3,500 \text{ L/UNITS} = 105,000 \text{ L/D}$$

$$\text{HOURLY AVERAGE SUPPLY} \quad 105,000 \text{ L/D} \div 8 \text{ H/D} = 13,125 \text{ L/D}$$

$$\text{HOURLY MAX. SUPPLY} \quad \text{"} \text{"}$$

$$\text{MOMENTARY MAX SUPPLY} \quad 13,125 \text{ L/H} \div 60 = 219 \text{ L/MIN}$$

WATER FOR FLOOR CLEANING

$$\text{DAILY SUPPLY FORECAST} \quad 50 \text{ PCS} \times 30 \text{ L/MIN} \times 5 \text{ MIN} = 7,500 \text{ L/D}$$

$$\text{HOURLY AVERAGE SUPPLY} \quad \text{"} \text{"}$$

$$\text{HOURLY MAX. SUPPLY} \quad \text{"} \text{"}$$

$$\text{MOMENTARY MAX SUPPLY} \quad 7,500 \text{ L/MIN} \div 5 \text{ MIN} = 1,500 \text{ L/MIN}$$

STEAM CLEANER

$$\text{DAILY SUPPLY FORECAST} \quad 12 \text{ UNITS} \times 10 \text{ L/MIN} \times 60 \text{ MIN} \times 8 \text{ HR} = 57,600 \text{ L/D}$$

$$\text{HOURLY AVERAGE SUPPLY} \quad 57,600 \text{ L/D} \div 8 \text{ HR} = 7,200 \text{ L/HR}$$

$$\text{HOURLY MAX. SUPPLY} \quad \text{"} \text{"}$$

$$\text{MOMENTARY MAX SUPPLY} \quad 7,200 \text{ L/H} \div 60 \text{ MIN/H} = 120 \text{ L/MIN}$$

RETREADING

DAILY SUPPLY FORECAST	$2,500 \text{ l/HR} \times 8 \text{ HR} =$	20,000 l/d
HOURLY AVERAGE SUPPLY		2,500 l/d
HOURLY MAX SUPPLY		2,500 l/d
MOMENTARY MAX SUPPLY	$2,500 \text{ l/HR} \div 60 \text{ MIN} =$	42 l/MIN

[TRAINING INSTITUTE]

WATER FOR LIVING

DAILY SUPPLY FORECAST	$80 \text{ PERSONS} \times 200 \text{ l/d} + 30 \text{ PERSONS} \times 100 \text{ l/d} =$	19,000 l/d
HOURLY AVERAGE SUPPLY	$19,000 \text{ l/d} \div 8 \text{ HR} =$	2,375 l/H
HOURLY MAX SUPPLY	$2,375 \text{ l/HR} \times 2 =$	4,750 l/H
MOMENTARY MAX SUPPLY	$2,375 \text{ l/HR} \times 3 \div 60 \text{ MIN/HR} =$	119 l/H

WATER FOR CLEANING TRAINING RM

DAILY SUPPLY FORECAST	$5 \text{ PCS} \times 30 \text{ l/MIN} \times 5 \text{ MIN} =$	750 l/d
HOURLY AVERAGE SUPPLY		"
HOURLY MAX SUPPLY		"
MOMENTARY MAX SUPPLY	$750 \text{ l/d} \div 5 \text{ MIN/D} =$	150 l/MIN

[TOTAL]

DAILY SUPPLY FORECAST	$95,000 + 105,000 + 7,500 + 57,600 + 20,000 + 19,000 + 750 =$	304,850 l/d
HOURLY AVERAGE SUPPLY	$11,875 + 13,125 + 7,500 + 7,200 + 2,500 + 2,375 + 750 =$	45,325 l/H
HOURLY MAX SUPPLY	$23,750 + 13,125 + 7,500 + 7,200 + 2,500 + 4,750 + 750 =$	79,575 l/H
MOMENTARY MAX SUPPLY	$574 + 219 + 1,500 + 120 + 42 + 119 + 150 =$	2,744 l/H

8-2 ELEVATED WATER TANK

$$\text{CAPACITY } V_E = (Q_p - Q_{pu}) T_3 + Q_{pu} T_4$$

WHEREIN Q_p : MOMENTARY MAX. WATER SUPPLY (2,744 l/MIN)

Q_{pu} : PUMPING QUANTITY OF RAM (950 l/MIN)

T_3 : TIME OF CONTINUANCE OF MOMENTARY MAX. SUPPLY (20 MIN.)

T_4 : THE SHORTEST OPERATING TIME OF RAM (15 MIN.)

$$V_E = (2744 - 950) \times 20 + 950 \times 15 = 50,130 \text{ l}$$

∴ THE CAPACITY OF ELEVATED WATER TANK SHALL BE 50 M³.

HEIGHT $H = H_1 + H_2 + H_3$

WHEREIN H_1 : REAL LIFT (12.8 M)

H_2 : WATER HEAD LOSS (9.0 M)

H_3 : DISCHARGE WATER HEAD (10.0 M)

$$H = 12.8 + 9.0 + 10.0 = 31.8 \text{ M}$$

8-3 THE WATER RECEIVING TANK SHALL HAVE A CAPACITY FOR 2 HOURS OF HOURLY AVERAGE SUPPLY.

$$43,113 \times 2 = 86,226 \text{ l}$$

∴ THE CAPACITY SHALL BE 100 M³.

8-4 RAM

LIFTING QUANTITY (950 l/MIN)

$$\text{LIFT } H = (H_1 + H_2 + H_3) \times 1.1$$

WHEREIN H_1 : REAL LIFT (35.0 M)

H_2 : WATER HEAD LOSS (2.0 M)

H_3 : DISCHARGE WATER HEAD (3.0 M)

$$H = (35.0 + 2.0 + 3.0) \times 1.1 = 44 \text{ M}$$

SPECIFICATIONS OF PUMP 100^A X 4 STEPS X 950 l/MIN X 44 M X 15 KW

2 UNITS OPERATED AUTOMATICALLY AND ALTERNATIVELY.

8-5 WELL PUMP (UNDERWATER PUMP)

LIFTING WATER QUANTITY: SHALL BE THE HOURLY AVERAGE
SUPPLY.

$$(45,325 \text{ l/HR} \div 60 \text{ MIN}) = 755 \text{ l/MIN}$$

LIFT : THOUGH THE STATIC WATER LEVEL IS 6 M, THE
LIFT SHALL BE 35 M TAKING INTO CONSIDERATION
A LOWERING OF THE WATER LEVEL.

SPECIFICATIONS OF PUMP

$$100^{\wedge} \times 3 \text{ STEPS} \times 755 \text{ l/MIN} \times 35 \text{ M} \times 11 \text{ KW}$$

4. CALCULATION SCHEDULE OF FLOOR AREA


CALCULATION SCHEDULE OF FLOOR AREA

BUILDING		SCHEDULE OF FLOOR AREA (M ²)			
N.O	NAME	GROUND FLOOR	1st FLOOR	2st FLOOR	TOTAL
①	GENERAL OFFICE BLDG	473.94	461.29	461.29	1,396.52
②	CLASSROOM OFFICE BLDG	565.15	491.56		1,056.71
③	DORMITORY	590.24	287.55	287.55	1,161.34
④	CAFETERIA	754.95			754.95
⑤	TRAINING ROOM	1,161.38			1,161.38
⑥	CHECK GATE	129.92			129.92
⑦	AIR COMPRESSOR	88.94			88.94
⑧	PAINT GRESE OIL STORAGE	136.74			136.74
⑨	SUB STATION	117.50			117.50
⑩	HEAVY REPAIR FACTORY	4,003.62	192.39	87.45	4,283.46
⑪	PARTS STORAGE	1,717.20			1,717.20
	WATER SUPPLY TOWER	16.00			16.00
	WELL HOUSE	5.41			5.41
⑫	INSPECTION FACTORY	636.00	53.10		689.10
⑬	PERIODICAL REPAIR FACTORY	2,003.40	121.90		2,125.30
⑭	PAINT & BODY FACTORY	1,508.00	145.75		1,653.75
⑮	RETRADING & METAL CASTING FACTORY	1,311.75	141.30		1,453.05
	TOTAL	15,220.14	1,894.74	836.29	17,951.17

NOTE :

SHADED PORTION INDICATES AREA OF EAVES

FIGURE INDICATES LENGTH OF A SIDE




NUMBER IN ○ INDICATES A BUILDING NUMBER

NUMBER OR ALPHABET INDICATES STORY OF A BUILDING


NUMBER INDICATES PART OF A BUILDING

① GENERAL OFFICE 1:500




2ND FLOOR PLAN

① 2.1	$19810 \times 8490 = 168,1869$
① 2.2	$8490 \times 2830 = 24,0267$
① 2.3	$2830 \times 6550 = 18,5365$
① 2.4	$3730 \times 6550 = 24,4315$
① 2.5	$470 \times 5660 = 2,6602$
① 2.6	$8490 \times 1940 = 16,4706$
① 2.7	$19810 \times 8490 = 168,1869$
① 2.8	$8490 \times 4570 = 38,7993$
	$461,2986$



1ST FLOOR PLAN

① 1.1	$19810 \times 8490 = 168,1869$
① 1.2	$8490 \times 2830 = 24,0267$
① 1.3	$2830 \times 6550 = 18,5365$
① 1.4	$3730 \times 6550 = 24,4315$
① 1.5	$470 \times 5660 = 2,6602$
① 1.6	$8490 \times 1940 = 16,4706$
① 1.7	$19810 \times 8490 = 168,1869$
① 1.8	$8490 \times 4570 = 38,7993$
	$461,2986$




GROUND FLOOR PLAN

① G.1	$19810 \times 8490 = 168,1869$
① G.2	$8490 \times 11320 = 96,1069$
① G.3	$470 \times 5660 = 2,6602$
① G.4	$19810 \times 8490 = 168,1869$
① G.5	$8490 \times 4570 = 38,7993$
	$473,9402$


② CLASS ROOM

1:100



1ST FLOOR PLAN

②1.1	$11,180 \times 22,640 = 253,1152$
②1.2	$2,690 \times 11,320 = 30,4508$
②1.3	$11,1800 \times 16,980 = 189,8364$
②1.4	$3,490 \times 1,940 = 16,4706$
②1.5	$1,940 \times 870 = 1,6878$
	<hr/>
	491,5608




GROUND FLOOR PLAN


②G.1	$11,180 \times 11,320 = 126,5576$
②G.2	$9,643 \times 2,830 = 27,2897$
②G.3	$11,180 \times 36,790 = 411,3122$
	<hr/>
	565,1595

1056.71


③ DOMITOR 1:500



GROUND FLOOR PLAN



1ST FLOOR PLAN



2ND FLOOR PLAN

① G1 $11,000 \times 2,0520 = 2,390,320$

② G2 $2,320 \times 5,260 = 12,2032$

③ G3 $36,900 \times 7,730 = 285,2370$

④ G4 $4,100 \times 13,360 = 54,7960$

590,2482

③ 1.1 $36,900 \times 7,730 = 285,2370$

③ 1.2 $1,000 \times 2,320 = 2,3200$


287,5570

③ 2.1 $36,900 \times 7,730 = 285,2370$

③ 2.2 $1,000 \times 2,320 = 2,3200$

287,5570

④ CAFETERIA




④ 1.3	$16,240 \times 13,510 = 219,4024$
④ 1.2	$11,600 \times 7,960 = 92,3360$
④ 1.1	$27,840 \times 15,920 = 443,2128$
	$754,9512$

754.95

GROUND FLOOR PLAN

⑤ TRAINING ROOM




⑤ 1.2	$40,20 \times 57,480 = 231,0696$
⑤ 1.1	$14,940 \times 62,270 = 930,3139$
	$1,161,3834$

1161.38

GROUND FLOOR PLAN

⑥ CHECK GATE 1:500




GROUND FLOOR PLAN

⑥

$$5000 \times 23200 = 1299200$$

129.92

⑦ AIR COMPRESSOR HOUSE 1:500




GROUND FLOOR PLAN

⑦

$$6390 \times 13920 = 889488$$

88.94

⑧ PAINT GREASE OIL STORAGE 1:500




GROUND FLOOR PLAN

⑧

$$16240 \times 8420 = 1367408$$

136.74

⑨ SUB STATION 1:500




GROUND FLOOR PLAN

⑨


$$6800 \times 17280 = 1175040$$

117.50

⑩ HEAVY REPAIR FACTORY 1:1000




GROUND FLOOR PLAN



⑩11

1ST FLOOR PLAN



⑩21

2ND FLOOR PLAN

⑩G.1 116600 × 26850 = 3130.7100


⑩G.2 95400 × 9150 = 872.9100
 40 03.6200

⑩11 31800 × 6050 = 1923900
 192.3900

⑩21 21200 × 4125 = 87.4500
 87.4500

⑪ PARTS STORAGE 1:1000

4283.46




GROUND FLOOR PLAN

47700 × 36000 = 1717.2000


1717.20

⑫ INSPECTION FACTORY 1:1000



1ST FLOOR PLAN

$$\textcircled{12} \text{ II} \quad 10,000 \times 5,300 = 53,000$$




GROUND FLOOR PLAN

$$\textcircled{12} \text{ GI} \quad 20,000 \times 31,800 = 636,000$$


689,00

⑬ PERIODIC REPAIR FACTORY 1:1000



1ST FLOOR PLAN

$$\textcircled{13} \text{ II} \quad 11,500 \times 10,600 = 121,900$$





GROUND FLOOR PLAN

$$\textcircled{13} \text{ GI} \quad 27,000 \times 74,200 = 2,003,400$$

2125,30

⑭ PAINT AND BODY FACTORY 1:1000



GROUND FLOOR PLAN



1ST FLOOR PLAN

$$\begin{array}{r} \textcircled{14} \text{ G.I. } 52000 \times 29000 = 1,508,000 \\ \hline 1,508,000 \end{array}$$

⑭ 1.1	$17,900 \times 6,500 = 116,3500$
⑭ 1.2	$6,500 \times 3,360 = 21,8400$
⑭ 1.3	$1,800 \times 4,200 = 7,5600$
	<hr/>
	145,7500

1,653,75

⑮ RETREADING & METAL CASTING FACTORY 1:1000



GROUND FLOOR PLAN

1ST FLOOR PLAN

$$\textcircled{15} \text{ G.I. } 29150 \times 45000 = 1,311,7500$$

$$\textcircled{15} 1.1 \quad 18000 \times 7850 = 141,3000$$

1453,05

PUMP HOUSE
(WATER SUPPLY TOWER) 1:500



$$4000 \times 4000 = 16,0000$$

$$16,0000 = 16,000$$

16,00

WELL HOUSE 1:500



$$2032 \times 2667 = 5,4190$$

$$5,4190$$

5,41

JICA