

## 4.3 Groundwater Development Plan

### 4.3.1 Evaluation of Exploitable Amount of Groundwater

The mass balance of groundwater by the Tank Model Calculation and extraction of groundwater in each district is estimated in the following table.

Table 4.3-1: Potential Volume of Groundwater Exploitation and Extraction

Region	District	total	Recharge to Groundwater	*Extractable Groundwater	**Potential Discharge of Existing Hand Pump		***Potential Discharge of Existing Motorized Pump		****Planned Hand Pump Exploitation	*****Planned Motorized Pump Exploitation	Total Exploitation from Groundwater	Percentage in the Exploitable Amount
		m <sup>3</sup> /sec	m <sup>3</sup> /day	m <sup>3</sup> /day	Number	m <sup>3</sup> /day	Number	m <sup>3</sup> /day	m <sup>3</sup> /day	m <sup>3</sup> /day	m <sup>3</sup> /day	%
Mwanza	Missungwi	126.78	10,953,978	5476989	267	1922.4	59	1982.4	477	528	4909.8	0.0896441
	Sengerema	147.16	12,714,442	6357221	205	1476	5	168	2195	312	4151	0.0652958
	Kwimba	196.78	17,002,010	8501005	612	4406.4	18	604.8	1042	2016	8069.2	0.0949205
	Magu	195.39	16,881,811	8440905	791	5695.2	42	1411.2	885	388	8379.4	0.0992713
	Geita	270.59	23,378,909	11689454	198	1425.6	49	1646.4	3233	416	6721	0.0574963
	Ilemela-Nyamang	28.02	2,421,064	1210532	90	648	0	0	143	791	0.0653432	
Mara	Ukerewe	93.52	8,080,247	4040123	268	1929.6	0	0	75	0	2004.6	0.0496173
	Bunda	169.89	14,678,128	7339064	173	1245.6	3	100.8	795	70	2211.4	0.0301319
	Musoma	189.38	16,362,690	8181345	60	432	6	201.6	2207	696	3536.6	0.0432276
	Tarime	221.08	19,101,607	9550804	16	115.2	7	235.2	7117	623	8090.4	0.0847091
	Serengeti	733.38	63,364,255	31682128	521	374.4	8	268.8	1331	830	2804.2	0.008851

$$* \text{Extractable Groundwater} = \text{Groundwater Recharge} * 0.5$$

\*\* Assuming all wells have hand pumps with 15 l/min discharge operating 8 hours a day

\*\*\* Assuming all wells have functioning motorized pumps with 70 l/min discharge operating 8 hours a day

\*\*\*\* Planned hand pumps exploitation in year of 2015

\*\*\*\*\* Planned motorized pumps exploitation in year of 2015

The total of the existing and planned volume for the exploitation of groundwater and the ratio (percentage) to the total recharge is less than 0.1 %. The highest percentage is in Magu District, which has only a small catchment area.

### 4.3.2 Remarkable Points for the Groundwater Development Plan

#### a. Groundwater Development Plan for 428 Villages


Groundwater development is relatively difficult, especially estimating the yield and the depth to the water strike zones. Therefore, for villages within 9 km from Lake Victoria, the lake water will be used instead of groundwater.

Most of the facilities for groundwater extraction are boreholes drilled up to 50 meters and installed with a hand pump (as the yield of the well is very difficult to predict, a motorized pump is not planned unless certain data is available to assure a yield of more than 70 l/min).


#### b. Groundwater Development Plan for the Priority Project.

A total of 61 villages were surveyed in detail for the examination of the water development potential for groundwater source. The purpose of this detailed hydrogeological field reconnaissance was to identify a potential drilling site at each village within the village boundary. The surveyed villages are presented in Figure 4.3-2.

The method of the survey was; 1) Detailed hydrogeological field reconnaissance within the village boundary, 2) Interview with the village leaders to locate most appropriate site for water source, 3) Review respective point from the hydrogeological point of view with the rank of A (good), B (fair) and C (poor) 4) Additional recommended site are marked on the topographical map in case the requested site does not have good potential.



4-9



#### 4.4 Water Quality in Study Area

Water quality analysis was conducted on groundwater and surface water (lake water, river water, pond water, dam water, etc.) to confirm the nature and safeness of the water for potable purposes. In addition the seasonal fluctuation of water quality was also examined. Other than some bacterial contamination, none of the water sources exceeded the Upper Limit of Tanzanian Standard for drinking water.

##### 4.4.1 Methodology and Water Quality Items

The total number of the samples are 154, 68 samples taken in the dry season, 68 in the wet season and 18 samples from the test wells. The 14 parameters for on site and 40 parameters were analyzed in the laboratory. The parameters analyzed were compared with the drinking water standards of Tanzania with reference to the WHO, and major ions which may affect human health. An additional 19 samples from test well and lake were analyzed in the Phase II study.

##### 4.4.2 Characteristic of Water Quality

###### a. Characteristic of Water Quality by Water Source

Deep wells are not so much affected by bacteria but they contain a series of metal ions such as Fe, Pb, Cr, Se, Ba and F. Granite fissure type aquifers in Kwimba and Magu indicated a high content of Fluoride. Shallow Wells have a large variation by area. Some Neocene deposits, have an extremely high concentration of  $\text{Cl}^-$ ,  $\text{SO}_4^{2-}$ , Cd,  $\text{Na}^+$ , and  $\text{K}^+$ , and the EC value exceeds 40,000  $\mu\text{S}/\text{m}$ . Shallow wells also have a high concentration of coliform and bacteria, and also indicate a high EC value.

Lake Victoria water is safe in general. BOD is generally high and turbidity is high in some areas. Most of the locations are influenced by bacteriological contamination, such as general bacteria and coliform.

The river water indicates a high value for colour, turbidity, BOD,  $\text{SO}_4^{2-}$  and some bacteriological contamination. Mara and Grumeti Rivers contain Hg above the allowable value of the Tanzanian standard.

The water from the outlet of Schemes also varies. The high value of color and bacteriological contamination shows that the treatment procedure is not functioning adequately. The variation of the values also indicates the degree of maintenance. Dams and Ponds show the same tendency for river water quality.

###### b. Seasonal Deference of Water Quality by Source

Shallow wells have the most particular difference of reduction of EC, TSS, Ca,  $\text{Cl}^-$ ,  $\text{K}^+$ ,  $\text{PO}_4$  in wet season and an increase of coliform, bacteria, F,  $\text{NH}_4^+$ , B,  $\text{NO}_2^-$ ,  $\text{HCO}_3^-$  and  $\text{Na}^+$  in dry season. In the wet season, the value of Deep wells, EC, TDS, total hardness, Mg,  $\text{K}^+$ ,  $\text{PO}_4$  and F increased, and B was reduced. This fact suggests that even the deep boreholes are affected by seasonal deference.

The value varies by the sampling point at Piped Schemes, but in general, most of the substances tend to be reduced in the wet season. The tendency of seasonal change of Lakes is a reduction in value for most of the parameters but shows an increase of coliform, B, F, and  $\text{Na}^+$ . River water values tend to decrease. However, boron, color and turbidity increase in the

rainy season. Dams and ponds also fall in this category. Fe and Hg which categorized in the toxic substances are also found in river water in the dry season.

# Chapter 5

---

---

*Water Supply Plan*

## 5 Water Supply Plan

### 5.1 Villages and Piped Schemes, Population and Water Demand for Water Supply Plan

There are 205 selected target villages for water supply plan in the Mwanza region and 223 villages in the Mara region, totaling 428 villages in the study area. Also, the number of existing piped schemes for the water supply plan is identified as a total of 57 piped schemes, consisting of 37 in the Mwanza region and 20 in the Mara region. The priority project of the water supply plan, which is the construction of water supply facilities in the implementation phase, will be completed by the year 2010. The water supply facilities for the priority project will be designed to meet the water demand anticipated in the year 2015. The administrative population to be served by hand pump and spring is about 1,372,000 and by piped scheme about 2,521,000 in the year 2025 for water supply plan.

The unit water demand is calculated based on Tanzania's "Design Manual for Water Supply and Waste Water Disposal (1997)". The total water demand is estimated for the Mwanza and Mara regions of the year 2005 as approximately  $17.8 \times 10^3 \text{ m}^3/\text{day}$  and in the year 2015, the overall water demand is projected as approximately  $56.4 \times 10^3 \text{ m}^3/\text{day}$ .

### 5.2 Water Sources

The water sources existing in the Mwanza and Mara regions can generally be classified as surface water, groundwater and rain water. The surface water resources from which water is collected include rivers, streams, Lake Victoria, and small-scale dams, while the groundwater sources include springs, shallow wells, and deep wells (Boreholes). Finally, it was decided that water sources are available for groundwater, spring water and lake water from Lake Victoria in the Study area. The important factors in considering water sources are (1) Sustainability for water use, (2) Availability through out the year, and (3) Safety of water quality. Regarding the utilization of groundwater for water sources, the actual exploitable yield and number of wells is decided based on the groundwater potential according to the hydrogeological interpretation and analysis.

### 5.3 Water Supply Plan

The water supply plan for the 428 villages is shown in Table 5.3-1.

The water supply plan is grouped into the following types in study area.

- (1) Spring Protection
- (2) Medium and Deep Well with Hand Pump
- (3) Newly Installed Piped Scheme
- (4) Expanded Piped Scheme
- (5) Rehabilitated Piped Scheme

In regard to springs, protected springs for safety are planned at two spring sites. The total number of the Medium and Deep wells with Hand Pumps is 1,869 wells and the population served by hand pump is about 581,000 in 2025. The total number of piped schemes, such as the newly installed piped schemes, expanded and rehabilitated piped schemes is 121 sites with 368 villages and served population is about 1,260,000 in 2025.

Table 5.3-1: Water Supply Plan (1/5)

Region	DISTRICT	No. by District	Village	Population in 2025	Water Sources type					served coverage rate(%) in 2005	served coverage rate(%) in 2025	Served Population in 2025
					HP=Hand pump MP=Motor pump	No. of HP or MP	Additional Medium BH	Total (HP)	Water Sources			
Mwanza	MISUNGWI	6	Mapilinga	3,192	Newly Piped Scheme				Lake V.	11	77	2,455
	MISUNGWI	10	Ibongoya A	5,303	HP	4	4	8	Deep BH	31	69	3,644
	MISUNGWI	17	Mwasagela	3,455	HP	3	3	6	Medium BH	19	62	2,156
	MISUNGWI	21	Mwamagaha	3,462	HP	3	2	5	Deep BH	19	55	1,908
	MISUNGWI	22	Buhingo	2,754	Expanded Piped Scheme MP	1		1	BH	23	89	2,448
	MISUNGWI	23	Kabale	4,648	Expanded Piped Scheme MP	2		2	BH	7	73	3,389
	MISUNGWI	24	Nyamainza	5,677	HP	6	4	10	Medium BH	6	50	2,841
	MISUNGWI	25	Busongo	6,361	Newly Piped Scheme MP	2		2	BH	5	93	5,916
	MISUNGWI	26	Iseengeja	2,163	HP	2	2	4	Medium BH	15	61	1,324
	MISUNGWI	27	Mbarika	3,799	Expanded Piped Scheme				Lake V.	17	83	3,150
	MISUNGWI	28	Ngaya	4,974	Newly Piped Scheme				Lake V.	13	100	4,974
	MISUNGWI	30	Usagara	3,242	Expanded Piped Scheme MP	1		1	BH	28	94	3,045
	MISUNGWI	31	Kanyebele	5,253	HP	4	3	7	Medium BH	31	64	3,379
	MISUNGWI	33	Budutu	2,078	HP	2	1	3	Medium BH	16	52	1,082
	MISUNGWI	35	Isamilo	5,997	Newly Piped Scheme				Lake V.	16	82	4,912
	MISUNGWI	36	Mwalogwabagole	4,514	Expanded Piped Scheme				Lake V.	15	81	3,652
	SENGEREMA	5	Ibondo	9,921	Expanded Piped Scheme				Lake V.	0	59	5,845
	SENGEREMA	6	Iusunganghoho	4,699	HP	5	2	7	Medium BH	0	37	1,750
	SENGEREMA	7	Mwabaluhu	5,879	Expanded Piped Scheme				Lake V.	0	59	3,463
	SENGEREMA	8	Sima	10,821	Rehabilitated Piped S. MP	2		2	BH	16.9	76	8,204
	SENGEREMA	10	Igulumuki	4,480	HP	5	5	10	Medium BH	0	56	2,500
	SENGEREMA	11	Ijinga	3,639	HP	4	2	6	Medium BH	0	41	1,500
	SENGEREMA	12	Ishishang'hoho	3,489	HP	3	3	6	Medium BH	0	43	1,500
	SENGEREMA	13	Sogoso	7,306	HP	6	3	9	Deep BH	0	31	2,250
	SENGEREMA	14	Tabaruka	6,931	Expanded Piped Scheme				Lake V.	11.5	70	4,880
	SENGEREMA	15	Mayuga	3,160	HP	3	3	6	Medium BH	16.4	64	2,018
	SENGEREMA	16	Kishinda	8,255	HP	7	4	11	Medium BH	11.1	44	3,666
	SENGEREMA	17	Nyasenga	7,596	Newly Piped Scheme				Lake V.	23.5	82	6,260
	SENGEREMA	18	Nyampande	6,532	Newly Piped Scheme				Lake V.	9.2	68	4,449
	SENGEREMA	19	Busurumwangili	4,942	HP	5	4	9	Deep BH	6	52	2,547
	SENGEREMA	20	Tunyenyene	6,566	HP	6		6	Deep BH	0	23	1,500
	SENGEREMA	21	Mauri	2,047	HP	2	4	6	Medium BH	0	73	1,500
	SENGEREMA	22	Kahumulo	6,043	Newly Piped Scheme				Lake V.	11.2	70	4,237
	SENGEREMA	23	Nyamasale	4,279	Expanded Piped Scheme				Lake V.	0	59	2,521
	SENGEREMA	24	Nyitundu	3,864	Newly Piped Scheme				Lake V.	0	59	2,276
	SENGEREMA	26	Lubanda	4,545	Newly Piped Scheme				Lake V.	0	59	2,678
	SENGEREMA	30	Juma kisiwani	5,394	Newly Piped Scheme				Lake V.	0	59	3,178
	SENGEREMA	31	Kasomeko	6,467	Newly Piped Scheme				Lake V.	0	59	3,810
	SENGEREMA	32	Ilekanilo	7,829	Newly Piped Scheme				Lake V.	0	59	4,612
	SENGEREMA	36	Nyamizeze	7,452	Expanded Piped Scheme				Lake V.	37.3	96	7,170
	SENGEREMA	37	Mwaliga	2,741	Newly Piped Scheme				Lake V.	0	59	1,615
	SENGEREMA	38	Kijuka	5,938	Expanded Piped Scheme				Lake V.	0	59	3,498
	SENGEREMA	43	Nyamahona	8,838	Newly Piped Scheme				Lake V.	0	59	5,207
	SENGEREMA	44	Nyakahako	9,400	Newly Piped Scheme				Lake V.	0	59	5,538
	SENGEREMA	47	Ngoma B	5,240	Newly Piped Scheme				Lake V.	32.2	91	4,775
	SENGEREMA	48	Irunda	5,123	Newly Piped Scheme				Lake V.	12.8	72	3,674
	SENGEREMA	50	Karumo	7,174	Newly Piped Scheme				Lake V.	12.7	72	5,138
	SENGEREMA	56	Bulyihili	7,934	Newly Piped Scheme				Lake V.	16.6	76	5,991
	SENGEREMA	58	Igakamba	13,292	Newly Piped Scheme				Lake V.	7.8	67	8,868
	SENGEREMA	59	Bupandwa	26,219	Newly Piped Scheme				Lake V.	0	59	15,447
	SENGEREMA	61	Bilulumo	4,109	Newly Piped Scheme				Lake V.	0	59	2,421
	SENGEREMA	62	Luhorongoma	6,469	Newly Piped Scheme				Lake V.	0	59	3,811
	SENGEREMA	65	Ngoma A	11,141	HP	9	0	9	Medium BH	18.1	38	4,267
	SENGEREMA	66	Lubungo	3,537	Newly Piped Scheme				Lake V.	14.2	73	2,586
	SENGEREMA	67	Sotta	5,605	HP	5	2	7	Deep BH	0	31	1,750
	SENGEREMA	69	Isole	6,392	HP	5	2	7	Deep BH	17.8	45	2,888
	SENGEREMA	71	Bitoto	5,297	Newly Piped Scheme				Lake V.	0	59	3,121
	SENGEREMA	72	Kalangalanga	2,424	Newly Piped Scheme				Lake V.	0	59	1,428
	SENGEREMA	73	Miaga	3,616	Newly Piped Scheme				Lake V.	0	59	2,131
	SENGEREMA	75	Buswelu	4,812	Newly Piped Scheme MP	2		2	Deep BH	12.4	82	3,946
	SENGEREMA	76	Migukulama	3,892	Expanded Piped Scheme				Lake V.	11.3	70	2,733
	SENGEREMA	77	Nyanzenda	7,219	Expanded Piped Scheme				Lake V.	7.4	66	4,787
	SENGEREMA	78	Isaka	11,281	HP	7	5	12	Medium BH	33.4	60	6,768
	SENGEREMA	79	Ruharanyonda	6,288	HP	5	0	5	Deep BH	10	30	1,879
	SENGEREMA	80	Kayenze	6,574	HP	5	0	5	Deep BH	23.2	42	2,775
	SENGEREMA	81	Nyamadoke	7,346	Newly Piped Scheme				Lake V.	23.2	82	6,032
	SENGEREMA	83	Busekeseke	4,354	HP	4	3	7	Deep BH	0	40	1,750
	SENGEREMA	84	Katoma	5,151	HP	5	3	8	Deep BH	0	39	2,000
	SENGEREMA	86	Magulukenda	6,483	HP	6	2	8	Deep BH	0	31	2,000
	SENGEREMA	87	Buzilasoga	4,543	HP	4	1	5	Deep BH	10.7	38	1,736
	SENGEREMA	88	Ikoni	3,160	HP	3	0	3	Deep BH	17.3	41	1,297
	SENGEREMA	89	Igaka	4,865	HP	5	3	8	Medium BH	0	41	2,000
	SENGEREMA	90	Kanyebele	3,916	HP	4	0	4	Deep BH	0	26	1,000
	SENGEREMA	93	Bukokwa	13,908	Newly Piped Scheme				Lake V.	0	59	8,194
	SENGEREMA	94	Kagunga	8,028	HP	8	0	8	Medium BH	0	25	2,000
	SENGEREMA	95	Lwenge	4,024	HP	4	1	5	Medium BH	0	31	1,250
	SENGEREMA	96	Nyancheche	9,773	HP	5	4	9	Deep BH	0	23	2,250
	SENGEREMA	97	Nyanzumla	6,495	HP	6	3	9	Medium BH	0	35	2,250
	SENGEREMA	99	Nyamisiwi	4,156	Newly Piped Scheme				Lake V.	0	70	2,909
	SENGEREMA	100	Nyakasasa	7,267	Newly Piped Scheme				Lake V.	0	70	5,087
	SENGEREMA	102	Bugoro	7,271	Newly Piped Scheme				Lake V.	0	59	4,284
	SENGEREMA	103	Nyakabanga	4,768	Newly Piped Scheme				Lake V.	0	59	2,809
	SENGEREMA	104	Lugata	22,204	Newly Piped Scheme				Lake V.	0	59	13,081



Table 5.3-1: Water Supply Plan (2/5)

Region	DISTRICT	No. by District	Village	Population in 2025	Water Sources type					served coverage rate(%) in 2005	served coverage rate(%) in 2025	Served Population in 2025
					HP=Hand pump MP=Motor pump	No. of HP or MP	Additional Medium BH	Total (HP)	Water Sources			
Mwanza	SENGEREMA	106	Lushamba	19,250	Newly Piped Scheme				Lake V.	0	59	11,341
	SENGEREMA	108	Bulyaheke	9,382	Newly Piped Scheme				Lake V.	0	59	5,527
	SENGEREMA	110	Ilyamchele	3,093	Newly Piped Scheme				Lake V.	0	59	1,822
	SENGEREMA	114	Luharanyonga	6,288	Newly Piped Scheme				Lake V.	17.9	77	4,830
	SENGEREMA	115	Isengeng'he	5,575	Newly Piped Scheme				Lake V.	0	59	3,284
	SENGEREMA	118	Nyakasungwa	11,103	Expanded Piped Scheme				Lake V.	4.6	64	7,052
	SENGEREMA	119	Igwanzozu	2,641	Newly Piped Scheme				Lake V.	0	59	1,556
	KWIMBA	3	Iumba	3,893	Rehabilitated Piped S.MP	1		1	BH	29	90	3,513
	KWIMBA	22	Hungumalwa	8,711	Newly Piped Scheme MP	2		2	BH	35	100	8,711
	KWIMBA	24	Manayi	5,979	Rehabilitated Piped S.MP	1		1	BH	7	68	4,080
	KWIMBA	25	Iluha	5,158	Rehabilitated Piped S.MP	1		1	BH	16	77	3,984
	KWIMBA	31	Kijida	5,022	Rehabilitated Piped S.MP	1		1	BH	28	89	4,482
	KWIMBA	34	Igumangobo	3,103	HP	3	3	6	Deep BH	0	48	1,500
	KWIMBA	35	Shigongama	4,590	HP	5	0	5	Medium BH	0	27	1,250
	KWIMBA	40	Mwamitinje	1,580	HP	2	0	2	Medium BH	0	32	500
	KWIMBA	44	Izizimba A	6,097	Expanded Piped Scheme				Deep BH	0	61	3,734
	KWIMBA	45	Izizimba B	4,591	Expanded Piped Scheme				Deep BH	0	61	2,812
	KWIMBA	55	Sanga	5,536	Rehabilitated Piped S.MP	1		1	BH	0	61	3,390
	KWIMBA	61	Nyamikoma	2,681	HP	3	2	5	Medium BH	6	53	1,411
	KWIMBA	66	Mwampulu	4,799	HP	5	2	7	Medium BH	9	45	2,182
	KWIMBA	68	Ngulla	4,820	HP	5	3	8	Medium BH	9	50	2,434
	KWIMBA	69	Nyamatala	5,714	HP	5	3	8	Medium BH	7	42	2,400
	KWIMBA	70	Nyambuyi	3,348	HP	3	2	5	Medium BH	0	37	1,250
	KWIMBA	71	Mnulya	3,756	HP	4	4	8	Deep BH	0	53	2,000
	KWIMBA	72	Mwangika	3,381	HP	3	0	3	Deep BH	13	35	1,190
	KWIMBA	74	Ngogo	5,342	HP	4	1	5	Medium BH	32	55	2,960
	KWIMBA	82	Bungandando	6,254	Rehabilitated Piped S.MP	1		1	BH	34	95	5,956
	KWIMBA	83	Icheja	2,338	HP	2	2	4	Deep BH	14	57	1,327
	KWIMBA	84	Nqwaswengele	8,354	Rehabilitated Piped S.MP	2		2	BH	0	61	5,116
	KWIMBA	85	Nyamigamba	7,839	Newly Piped Scheme MP	2		2	Deep BH	22	83	6,525
	MAGU	1	Nyamahanga	3,523	Expanded Piped Scheme				Lake V.	32.2	96	3,367
	MAGU	6	Inolelo	3,127	HP	3	0	3	Medium BH	12	36	1,125
	MAGU	13	Kitongosima	6,219	HP	4	0	4	Deep BH	37	53	3,301
	MAGU	22	Bubinza	5,911	Newly Piped Scheme				Lake V.	12.5	76	4,484
	MAGU	26	Bugatu	6,595	HP	4	0	4	Medium BH	39.3	54	3,592
	MAGU	32	Mahaha	11,882	HP	9	2	11	Medium BH	21.6	45	5,316
	MAGU	33	Nyasoto	4,722	HP	4	4	8	Medium BH	23	65	3,086
	MAGU	37	Igekemaja	3,889	HP	4	0	4	Medium BH	9.6	35	1,373
	MAGU	38	Kitumba	6,367	Rehabilitated Piped S.MP	2		2	BH	14.2	78	4,939
	MAGU	43	Mwagulanja	4,426	Rehabilitated Piped S.MP	1		1	BH	34	97	4,310
	MAGU	44	Bulima	8,462	Rehabilitated Piped S.MP	1		1	BH	24.4	88	7,428
	MAGU	50	Ihayabuyaga B	4,679	HP	5	2	7	Medium BH	8	45	2,124
	MAGU	51	Lwagwe	2,273	HP	3	3	6	Medium BH	0	66	1,500
MAGU	55	Simanilwe	3,345	Expanded Piped Scheme				Lake V.	22.2	86	2,862	
MAGU	58	Badugu	7,097	HP	6	1	7	Medium BH	16	41	2,886	
MAGU	59	Manala	2,380	HP	3	3	6	Medium BH	6.2	69	1,648	
MAGU	66	Lukungu	4,384	Newly Piped Scheme				Lake V.	8.4	72	3,146	
MAGU	67	Mayenga	3,660	Expanded Piped Scheme				Lake V.	10.1	73	2,689	
MAGU	74	Mwakiloba	4,071	Newly Piped Scheme				Lake V.	9.1	72	2,950	
MAGU	75	Kijereshi	8,759	HP	8	2	10	Deep BH	8.4	37	3,236	
MAGU	78	Nyang'ii	3,715	Expanded Piped Scheme				Lake V.	0	63	2,354	
MAGU	80	Malli	2,530	HP	2	3	5	Medium BH	21.1	71	1,784	
MAGU	83	Mwamgomba	2,462	HP	2	3	5	Medium BH	15.4	66	1,629	
GEITA	2	Igate	8,376	HP	8	0	8	Deep BH	0	24	2,000	
GEITA	3	Idosero	7,324	HP	6	4	10	Deep BH	0	34	2,500	
GEITA	4	Lwenzera	21,354	Newly Piped Scheme				Lake V.	0	59	12,641	
GEITA	5	Nzera	13,599	Expanded Piped Scheme				Lake V.	20.2	79	10,798	
GEITA	6	Buligi	13,764	Newly Piped Scheme				Lake V.	0	59	8,148	
GEITA	8	Kakubilo	26,458	Newly Piped Scheme				Lake V.	0	59	15,663	
GEITA	9	Nyabalasana	10,102	Newly Piped Scheme				Lake V.	0	59	5,980	
GEITA	10	Kaseni	5,768	Newly Piped Scheme				Lake V.	0	59	3,414	
GEITA	14	Nyamboge	13,986	Expanded Piped Scheme				Lake V.	0	59	8,280	
GEITA	15	Katoma	12,917	Newly Piped Scheme				Lake V.	23	82	10,617	
GEITA	16	Nyakasenze	4,513	Newly Piped Scheme				Lake V.	0	59	2,672	
GEITA	17	Bugulala	11,440	HP	5	6	11	Deep BH	0	24	2,750	
GEITA	18	Kasota	12,942	HP,Spring	5	4	9	Deep BH	0	17	2,250	
GEITA	19	Nyamilongo	10,793	HP	6	2	8	Deep BH	0	19	2,000	
GEITA	20	Nyalwanzaja	9,590	HP	7	4	11	Deep BH	22.1	51	4,869	
GEITA	21	Imalampaka	4,388	HP	3	7	10	Medium BH	25	82	3,597	
GEITA	22	Kamera	10,966	HP	5	3	8	Deep BH	0	18	2,000	
GEITA	23	Bushishi	6,260	HP	4	5	9	Deep BH	0	36	2,250	
GEITA	24	Ndelema	5,537	HP	3	7	10	Deep BH	0	45	2,500	
GEITA	25	Nyashishima	2,616	HP	2	3	5	Deep BH	0	48	1,250	
GEITA	26	Bogogo	13,151	HP	6	2	8	Deep BH	13	28	3,710	
GEITA	27	Ikina	3,160	HP	2	5	7	Deep BH	0	55	1,750	
GEITA	28	Butombula	5,498	HP	5	5	10	Deep BH	0	45	2,500	
GEITA	29	Ntono	12,343	HP	6	4	10	Deep BH	0	20	2,500	
GEITA	30	Ihega	5,023	HP	3	8	11	Deep BH	0	55	2,750	
GEITA	31	Nyakangwe	6,117	HP	6	3	9	Deep BH	0	37	2,250	
GEITA	32	Nyaruyeye	7,347	HP	5	3	8	Deep BH	0	27	2,000	
GEITA	34	Mhama	3,130	HP	3	3	6	Medium BH	0	48	1,500	
GEITA	35	Rukarakata	8,715	HP	8	2	10	Medium BH	0	29	2,500	
GEITA	38	Kashishi	7,439	HP	5	0	5	Deep BH	36.7	54	3,980	
GEITA	40	Kasungamile	3,422	HP	3	3	6	Medium BH	0	44	1,500	
GEITA	42	Ibondo	9,713	HP	7	6	13	Deep BH	0	33	3,250	
GEITA	43	Inyara	9,928	HP	9	4	13	Medium BH	0	33	3,250	

Table 5.3-1: Water Supply Plan (3/5)

Region	DISTRICT	No. by District	Village	Population in 2025	Water Sources type					served coverage rate(%) in 2005	served coverage rate(%) in 2025	Served Population in 2025	
					HP=Hand pump MP=Motor pump	No. of HP or MP	Additional Medium BH	Total (HP)	Water Sources				
Mwanza	GEITA	45	Shilabela	3,648	HP	4	2	6	Medium BH	0	41	1,500	
	GEITA	51	Mabamba	8,314	HP	8	5	13	Medium BH	0	39	3,250	
	GEITA	52	Chikobe	7,919	Expanded Piped Scheme				Lake V.	37	96	7,618	
	GEITA	53	Kasangwa	12,095	Newly Piped Scheme				Lake V.	0	59	7,160	
	GEITA	54	Isima	5,357	Expanded Piped Scheme				Lake V.	0	59	3,171	
	GEITA	57	Lulama	2,711	HP	3	3	6	Medium BH	0	55	1,500	
	GEITA	59	Kharumwa	9,223	Expanded Piped Scheme				Lake V.	38.2	97	8,983	
	GEITA	61	Bukungu	5,291	Expanded Piped Scheme				Lake V.	33	92	4,878	
	GEITA	63	Ikangala	2,642	Expanded Piped Scheme				Lake V.	0	59	1,564	
	GEITA	64	Mwamakiliga	1,975	HP	2	0	2	Deep BH	26.8	52	1,029	
	UKEREWE	2	Chankamba	4,987	Newly Piped Scheme				Lake V.	15.6	76	3,803	
	UKEREWE	3	Bwasa	4,656	Expanded Piped Scheme				Lake V.	6.5	67	3,127	
	UKEREWE	5	Murutilima	8,284	Expanded Piped Scheme				Lake V.	0	61	5,025	
	UKEREWE	9	Busangu	6,049	Expanded Piped Scheme				Lake V.	31.5	92	5,574	
	UKEREWE	12	Namasabo	3,772	Newly Piped Scheme				Lake V.	0	61	2,288	
	UKEREWE	14	Bugala	11,446	Expanded Piped Scheme				Lake V.	27.4	88	10,078	
	UKEREWE	15	Itira	4,354	Expanded Piped Scheme				Lake V.	12.5	73	3,185	
	UKEREWE	16	Ihebo	4,591	Expanded Piped Scheme				Lake V.	6.8	67	3,096	
	UKEREWE	17	Igongo	4,267	Expanded Piped Scheme				Lake V.	0	61	2,588	
	UKEREWE	18	Muriti	4,374	Expanded Piped Scheme				Lake V.	31.3	92	4,022	
	UKEREWE	21	Nyamanga	4,974	HP	4	2	6	Medium BH	0	30	1,500	
	UKEREWE	22	Nyang'ombe	6,919	Newly Piped Scheme				Lake V.	21.1	82	5,656	
	UKEREWE	38	Masonga	9,478	Expanded Piped Scheme				Lake V.	5	66	6,222	
	UKEREWE	45	Bukonyo	2,832	Expanded Piped Scheme				Lake V.	25.7	86	2,445	
	UKEREWE	48	Malegea	5,835	Expanded Piped Scheme				Lake V.	29.5	90	5,260	
	UKEREWE	49	Mukasika	3,086	Expanded Piped Scheme				Lake V.	0	61	1,872	
	UKEREWE	50	Muhande	4,063	Expanded Piped Scheme				Lake V.	29.5	90	3,663	
	UKEREWE	51	Kweru	6,311	Newly Piped Scheme				Lake V.	0	61	3,828	
	UKEREWE	54	Sizu	3,663	Newly Piped Scheme				Lake V.	0	61	2,222	
	UKEREWE	58	Bulamba	6,675	Expanded Piped Scheme				Lake V.	0	61	4,048	
	UKEREWE	67	Bugombe	2,954	Expanded Piped Scheme				Lake V.	0	61	1,791	
	UKEREWE	68	Nantare	4,511	Newly Piped Scheme				Lake V.	0	61	2,736	
	UKEREWE	72	Halwego	8,750	Expanded Piped Scheme				Lake V.	7.6	68	5,972	
	UKEREWE	73	Buhima	9,094	Expanded Piped Scheme				Lake V.	0	61	5,515	
	UKEREWE	74	Chamuhunda	4,465	Newly Piped Scheme				Lake V.	24.3	85	3,793	
	NYAMAGANA & ILEMELA	2	Kishili	13,562	HP	9	2	11	Deep BH	25	45	6,141	
	Mara	BUNDA	9	Kinyambwiga	4,867	Expanded Piped Scheme				Lake V.	0	64	3,115
		BUNDA	16	Marambeka	4,584	HP	5	2	7	Medium BH	24.2	62	2,859
		BUNDA	17	Mugeta	2,995	HP	3	0	3	Medium BH	25	50	1,499
		BUNDA	18	Sanzate	4,258	HP	5	2	7	Medium BH	17.6	59	2,499
		BUNDA	19	Nyang'aranga	4,504	HP	6	2	8	Medium BH	0	44	2,000
		BUNDA	20	Kyandegede	5,131	HP	6	2	8	Medium BH	14.5	53	2,744
		BUNDA	23	Manchimweru	5,522	HP	6	2	8	Medium BH	20.7	57	3,143
		BUNDA	26	Ligamba B	2,319	HP	3	3	6	Deep BH	10	75	1,732
BUNDA		27	Misisi	3,476	Newly Piped Scheme MP	1		1	Deep BH	23.13	87	3,028	
BUNDA		30	Kangetutya	3,153	HP	4	2	6	Medium BH	10.87	58	1,843	
BUNDA		33	Mcharo	1,518	HP	4	1	5	Deep BH	11.36	94	1,422	
BUNDA		37	Nyamatoke	2,666	HP	4	3	7	Medium BH	0	66	1,750	
BUNDA		42	Kabasa	4,297	HP	4	3	7	Medium BH	27.69	68	2,940	
BUNDA		46	Hunyari	6,029	HP	6	2	8	Medium BH	24.88	58	3,500	
BUNDA		48	Mariwanda	6,201	HP	7	2	9	Medium BH	17.45	54	3,332	
BUNDA		51	Buzimbwe	3,171	Newly Piped Scheme				Lake V.	0	64	2,029	
BUNDA		52	Kabainja	2,572	Newly Piped Scheme				Lake V.	0	64	1,646	
BUNDA		62	Kiroreli	5,464	HP	5	0	5	Deep BH	34	57	3,108	
BUNDA		67	Karukekere	5,595	Expanded Piped Scheme				Lake V.	0	64	3,581	
BUNDA		68	Muranda	4,518	Expanded Piped Scheme				Lake V.	0	64	2,892	
BUNDA		69	Haruzale	2,000	Expanded Piped Scheme				Lake V.	0	64	1,280	
BUNDA		84	Nafuba	3,531	Newly Piped Scheme				Lake V.	0	64	2,260	
BUNDA		85	Igundu	4,812	Newly Piped Scheme				Lake V.	7.3	71	3,431	
BUNDA		88	Namalama	2,194	Newly Piped Scheme				Lake V.	0	64	1,404	
BUNDA		93	Sunsi	6,073	Newly Piped Scheme				Lake V.	0	64	3,887	
MUSOMA		1	Wegero	4,761	HP	6	0	6	Medium BH	10	42	1,976	
MUSOMA		2	Baranga	4,008	HP	5	2	7	Medium BH	12	56	2,231	
MUSOMA		5	Kitalamanka	4,666	HP	4	3	7	Medium BH	30	68	3,150	
MUSOMA		6	Sirorisimba	4,730	HP	4	4	8	Deep BH	0	42	2,000	
MUSOMA		8	Ryamisanga	5,644	HP	6	2	8	Deep BH	18	53	3,016	
MUSOMA		14	Mirwa	4,188	HP	5	0	5	Medium BH	17	47	1,962	
MUSOMA		15	Magunga	5,728	HP	8	0	8	Medium BH	0	35	2,000	
MUSOMA		17	Kinyariri	2,630	Expanded Piped Scheme				Lake V.	0	63	1,666	
MUSOMA		19	Ikibubwa	3,774	HP	5	5	10	Deep BH	0	66	2,500	
MUSOMA		20	Busegwe	7,223	HP	9	7	16	Deep BH	0	55	4,000	
MUSOMA		21	Kisamwene	5,239	HP	6	5	11	Deep BH	0	52	2,750	
MUSOMA		23	Bukabwa	4,333	Expanded Piped Scheme MP	1		1	BH	0	63	2,746	
MUSOMA		24	Mmazami	5,918	HP	7	4	11	Deep BH	0	46	2,750	
MUSOMA		25	Kirumi	3,662	Newly Piped Scheme				Lake V.	0	63	2,321	
MUSOMA		26	Mwiringo	4,106	Newly Piped Scheme				Lake V.	29	92	3,793	
MUSOMA		27	Bwaikwitururu	6,293	Newly Piped Scheme				Lake V.	25	88	5,561	
MUSOMA		28	Bwaikumsoma	7,794	Newly Piped Scheme				Lake V.	0	63	4,939	
MUSOMA		31	Chironwe	3,859	HP	5	3	8	Deep BH	0	52	2,000	
MUSOMA		32	Wanyere	4,587	HP	6	5	11	Deep BH	0	60	2,750	
MUSOMA		33	Bugoji	6,450	HP	7	3	10	Deep BH	22	61	3,919	
MUSOMA		35	Saragana	5,492	Newly Piped Scheme MP	2		2	Deep BH	9	72	3,975	
MUSOMA		36	Kaburabura	2,661	HP	4	3	7	Deep BH	0	66	1,750	
MUSOMA	42	Mwanzaburiga	3,572	HP	5	2	7	Deep BH	0	49	1,750		
MUSOMA	45	Kwigutu	4,112	HP	5	3	8	Medium BH	10	59	2,411		
MUSOMA	46	Nyasirori	4,989	Expanded Piped Scheme				Lake V.	21	84	4,210		
MUSOMA	47	Nyamikoma	6,206	HP	6	3	9	Medium BH	27.5	64	3,957		

Table 5.3-1: Water Supply Plan (4/5)

Region	DISTRICT	No. by District	Village	Population in 2025	Water Sources type					served coverage rate(%) in 2005	served coverage rate(%) in 2025	Served Population in 2025
					HP=Hand pump MP=Motor pump	No. of HP or MP	Additional Medium BH	Total (HP)	Water Sources			
Mara	MUSOMA	50	Nyankanga	7,951	HP	7	5	12	Deep BH	32	70	5,544
	MUSOMA	52	Nyarukoru	1,728	HP	2	2	4	Medium BH	0	58	1,000
	MUSOMA	53	Bisumwa	5,759	HP	8	3	11	Medium BH	0	48	2,750
	MUSOMA	54	Nyabekwabi	6,340	HP	8	3	11	Deep BH	0	43	2,750
	MUSOMA	55	Isaba	4,906	HP	3	7	10	Deep BH	20	71	3,481
	MUSOMA	56	Songora	8,726	HP	8	6	14	Deep BH	20	60	5,245
	MUSOMA	58	Ryamugabo	3,269	Expanded Piped Scheme				Lake V.	0	63	2,072
	MUSOMA	59	Bugwema	2,762	Newly Piped Scheme				Lake V.	0	63	1,750
	MUSOMA	60	Masinono	3,946	Newly Piped Scheme				Lake V.	0	63	2,501
	MUSOMA	61	Muhoji	2,655	HP	4	0	4	Medium BH	0	38	1,000
	MUSOMA	64	Mabuimerafu	2,962	Expanded Piped Scheme				Lake V.	0	63	1,877
	MUSOMA	65	Musanja	6,112	Newly Piped Scheme				Lake V.	0	63	3,873
	MUSOMA	67	Butata	7,666	Newly Piped Scheme				Lake V.	0	63	4,858
	MUSOMA	68	Buanga	3,851	Newly Piped Scheme				Lake V.	0	63	2,441
	MUSOMA	69	Rusoli	4,403	Newly Piped Scheme				Lake V.	0	63	2,790
	MUSOMA	70	Kwikerege	1,506	Newly Piped Scheme				Lake V.	0	63	954
	MUSOMA	72	Bukumi	3,527	Newly Piped Scheme				Lake V.	0	63	2,235
	MUSOMA	74	Maneke	5,132	Newly Piped Scheme				Lake V.	15	78	4,022
	MUSOMA	75	Tegeruka	3,463	Newly Piped Scheme				Lake V.	28	91	3,164
	MUSOMA	77	Katario	4,063	HP	4	3	7	Medium BH	26	69	2,806
	MUSOMA	80	Bulinga	5,571	Newly Piped Scheme				Lake V.	8	71	3,976
	MUSOMA	82	Chitare	5,447	Newly Piped Scheme				Lake V.	35	98	5,359
	MUSOMA	83	Chimati	3,153	Newly Piped Scheme				Lake V.	0	63	1,998
	MUSOMA	84	Makojo	3,277	Newly Piped Scheme				Lake V.	0	63	2,077
	MUSOMA	87	Seka	4,312	Newly Piped Scheme				Lake V.	0	63	2,733
	MUSOMA	88	Mikuyu	2,180	Expanded Piped Scheme				Lake V.	0	63	1,381
	MUSOMA	91	Mmahale	1,680	Expanded Piped Scheme				Lake V.	0	63	1,064
	MUSOMA	92	Mkirira	4,077	Newly Piped Scheme				Lake V.	0	63	2,583
	MUSOMA	93	Rubuka	2,597	Newly Piped Scheme				Lake V.	0	63	1,646
	MUSOMA	94	Kabegi	3,437	Newly Piped Scheme				Lake V.	23	86	2,969
	MUSOMA	97	Kiamba	4,971	Newly Piped Scheme				Lake V.	0	63	3,150
	MUSOMA	98	Kigera	8,844	Expanded Piped Scheme				Lake V.	0	63	5,604
	MUSOMA	99	Kwikuba	2,262	Newly Piped Scheme				Lake V.	21	84	1,908
	MUSOMA	103	Kiriba	4,309	Newly Piped Scheme				Lake V.	13	76	3,291
	TARIME	5	Kenyamanyori	6,619	HP	7	3	10	Deep BH	17.1	55	3,632
	TARIME	7	Nkende	5,352	HP	6	0	6	Deep BH	13.1	41	2,201
	TARIME	8	Mageni	3,968	HP	3	6	9	Deep BH	24.7	81	3,230
	TARIME	12	Mogabiri	9,073	HP	8	2	10	Deep BH	33.2	61	5,512
	TARIME	14	Nyasaricho	1,758	HP	2	3	5	Deep BH	17.6	89	1,559
	TARIME	15	Kemakorere	7,477	HP	9	3	12	Deep BH	0	40	3,000
	TARIME	16	Nyarero	4,707	HP	5	3	8	Deep BH	14.2	57	2,668
	TARIME	17	Soroneta	4,536	HP	6	3	9	Deep BH	0	50	2,250
	TARIME	18	Rosana	2,186	HP	3	1	4	Deep BH	8.3	54	1,181
	TARIME	19	Magoto	6,010	HP	8	2	10	Deep BH	0	42	2,500
	TARIME	20	Borega A	5,402	HP	6	0	6	Deep BH	9.6	37	2,019
	TARIME	21	Ganyango	4,791	HP	6	3	9	Deep BH	0	47	2,250
	TARIME	22	Kebweye	3,610	HP	3	9	12	Deep BH	0	83	3,000
	TARIME	23	Nyarwana	6,499	Rehabilitated Piped S.MP	2		2	BH	0	62	4,000
	TARIME	24	Nyankunguru	7,034	HP	5	4	9	Deep BH	0	32	2,250
	TARIME	25	Wegita	4,886	Newly Piped Scheme MP	2		2	Deep BH	0	62	3,007
	TARIME	29	Muriba	9,011	HP	11	4	15	Deep BH	6	48	4,291
	TARIME	30	Bungurere	4,246	HP	5	2	7	Deep BH	2.7	44	1,865
	TARIME	31	Kobari	3,152	HP	4	3	7	Deep BH	0	56	1,750
	TARIME	32	Nyantira	11,105	HP	13	2	15	Deep BH	7.2	41	4,550
	TARIME	33	Mangucha	8,946	HP	11	2	13	Deep BH	4.7	41	3,670
	TARIME	34	Itiryio	9,853	HP	12	0	12	Deep BH	0	30	3,000
	TARIME	35	Kegonga	7,324	HP	9	2	11	Deep BH	6.9	44	3,255
	TARIME	36	Gibasa	10,481	HP	12	3	15	Deep BH	5	41	4,274
	TARIME	37	Genkuru	8,867	HP	11	5	16	Deep BH	0	45	4,000
	TARIME	38	Kangariani	5,692	HP	7	2	9	Deep BH	0	40	2,250
	TARIME	39	Kitawasi	8,986	HP	10	2	12	Deep BH	8	41	3,719
	TARIME	40	Masanga	8,079	HP	10	5	15	Deep BH	0	46	3,750
	TARIME	41	Matongo	5,031	HP	4	2	6	Deep BH	0	30	1,500
	TARIME	43	Kerende	6,264	HP	7	2	9	Deep BH	8.2	44	2,764
	TARIME	44	Kiwanja	6,309	HP	4	1	5	Deep BH	24	44	2,764
	TARIME	45	Murito	6,127	HP	7	2	9	Deep BH	15	52	3,169
	TARIME	47	Remagwe	3,908	HP	5	4	9	Deep BH	8	66	2,563
	TARIME	49	Kitagasembe	2,699	HP	3	1	4	Deep BH	9.3	46	1,251
	TARIME	50	Ng'ereng'ere	3,605	HP	5	1	6	Deep BH	0	42	1,500
	TARIME	51	Getenga	5,637	HP	7	0	7	Deep BH	0	31	1,750
	TARIME	52	Kyoruba	4,369	HP	6	2	8	Deep BH	0	46	2,000
	TARIME	53	Pemba	3,361	HP	4	1	5	Deep BH	8.2	45	1,526
	TARIME	54	Nyabitocho	3,598	HP	4	2	6	Deep BH	10.6	52	1,881
	TARIME	55	Nyabisaga	7,089	HP	9	2	11	Deep BH	0	39	2,750
	TARIME	56	Borega B	3,699	HP	4	0	4	Deep BH	11.9	39	1,440
	TARIME	57	Kiongera	5,287	HP	7	2	9	Deep BH	0	43	2,250
	TARIME	58	Nyabirongo	5,642	HP	7	3	10	Deep BH	0	44	2,500
	TARIME	59	Kikomori	3,282	HP	4	2	6	Deep BH	0	46	1,500
	TARIME	60	Kubiterere	5,381	HP	7	3	10	Deep BH	0	46	2,500
	TARIME	61	Korotambe	5,554	HP	7	3	10	Deep BH	0	45	2,500
	TARIME	62	Nyamhunda	3,488	HP	5	2	7	Deep BH	0	50	1,750
	TARIME	63	Kewamamba	2,790	HP	4	2	6	Deep BH	0	54	1,500
	TARIME	64	Nkerege	4,256	HP	5	4	9	Deep BH	0	53	2,250
	TARIME	65	Nyagisya	3,099	HP	4	0	4	Deep BH	0	32	1,000
	TARIME	66	Gamasara	3,707	HP	4	3	7	Deep BH	11.9	59	2,191
	TARIME	67	Kemange	6,314	HP	7	3	10	Deep BH	8.1	48	3,011
	TARIME	68	Mtama	3,135	HP	4	2	6	Deep BH	14.2	62	1,945

Table 5.3-1: Water Supply Plan (5/5)

Region	DISTRICT	No. by District	Village	Population in 2025	Water Sources type				served coverage rate(%) in 2005	served coverage rate(%) in 2025	Served Population in 2025	
					HP=Hand pump MP=Motor pump	No. of HP or MP	Additional Medium BH	Total (HP)				Water Sources
Mara	TARIME	69	Sombanyasoko	1,452	HP	1	3	4	Deep BH	14.9	84	1,216
	TARIME	70	Surubu	4,378	HP	4	2	6	Deep BH	21	55	2,419
	TARIME	71	Bisanwi	4,489	HP	3	5	8	Deep BH	16.6	61	2,745
	TARIME	73	Nyamirambaro	2,540	HP	3	2	5	Deep BH	0	49	1,250
	TARIME	74	Kiterere	1,597	HP	2	0	2	Deep BH	0	31	500
	TARIME	75	Turgeti	2,937	HP	3	2	5	Deep BH	15.7	58	1,711
	TARIME	76	Kwisarara	3,925	HP	5	3	8	Deep BH	0	51	2,000
	TARIME	77	Kitenga	5,280	HP	7	4	11	Deep BH	0	52	2,750
	TARIME	78	Buganja	5,237	HP	6	0	6	Deep BH	10	39	2,024
	TARIME	79	Mika	4,263	HP	5	0	5	Deep BH	0	29	1,250
	TARIME	80	Nyasoro	3,759	HP	3	2	5	Deep BH	30	63	2,378
	TARIME	81	Utegi	3,452	HP	4	0	4	Deep BH	14.9	44	1,514
	TARIME	83	Mnag'ore	1,849	HP	2	0	2	Deep BH	28	55	1,018
	TARIME	84	Osiri	3,292	HP	3	1	4	Deep BH	27	57	1,889
	TARIME	85	Nyambogo	5,213	HP	7	4	11	Deep BH	0	53	2,750
	TARIME	86	Sakana	5,722	HP	7	3	10	Deep BH	0	44	2,500
	TARIME	87	Kitembe	3,769	HP	5	2	7	Deep BH	0	46	1,750
	TARIME	88	Roche	4,685	HP	6	0	6	Deep BH	7.8	40	1,865
	TARIME	89	Ng'ope	3,764	HP	5	2	7	Deep BH	0	46	1,750
	TARIME	90	Kogaja	4,448	HP	5	2	7	Deep BH	0	39	1,750
	TARIME	91	Nyamasanda	3,994	HP	5	0	5	Deep BH	0	31	1,250
	TARIME	92	Ikoma	5,457	HP	7	3	10	Deep BH	0	46	2,500
	TARIME	93	Kwibuse	4,297	HP	6	3	9	Medium BH	0	52	2,250
	TARIME	94	Kisumwa	3,279	HP	2	3	5	Deep BH	15.1	53	1,745
	TARIME	95	Nyanchabakenye	4,148	Rehabilitated Piped S.MP	1		1	BH	12.1	74	3,055
	TARIME	96	Mrasibora	3,539	Expanded Piped Scheme MP	1		1	BH	0	62	2,178
	TARIME	97	Nyanjagi	2,183	HP	3	3	6	Medium BH	0	69	1,500
	TARIME	108	Lolwe	2,504	HP	3	0	3	Deep BH	0	30	750
	TARIME	110	Minigo	3,970	Expanded Piped Scheme				Lake V.	0	62	2,443
	TARIME	111	Nyabikonda	3,322	Expanded Piped Scheme				Lake V.	0	62	2,044
	TARIME	112	Nyankonge	2,524	HP	2	3	5	Deep BH	0	50	1,250
	TARIME	113	Omoche	5,609	HP	5	6	11	Deep BH	0	49	2,750
	TARIME	114	Ryagati	3,363	Expanded Piped Scheme				Lake V.	15	77	2,574
	TARIME	116	Bwiri	3,431	Newly Piped Scheme				Lake V.	9.3	71	2,431
	TARIME	117	Kirongwe	6,141	Rehabilitated Piped S.				Lake V.	0	62	3,779
	TARIME	118	Nyambori	3,042	HP	3	2	5	Deep BH	15.1	56	1,709
	TARIME	119	Thabache	2,689	HP	2	7	9	Deep BH	0	84	2,250
	TARIME	120	Kyngasaga	7,538	Rehabilitated Piped S.				Lake V.	0	62	4,639
	TARIME	122	Muharago	6,069	Expanded Piped Scheme				Lake V.	0	62	3,735
	TARIME	127	Bureta	3,015	Newly Piped Scheme				Lake V.	0	62	1,855
	TARIME	128	Radienya	2,913	Newly Piped Scheme				Lake V.	0	62	1,793
	TARIME	129	Masike	4,045	HP	5	6	11	Deep BH	0	68	2,750
	TARIME	130	Randa	6,686	HP	8	5	13	Deep BH	0	49	3,250
	TARIME	131	Bukama	6,367	HP	4	7	11	Deep BH	0	43	2,750
	TARIME	133	Raranya	5,784	Expanded Piped Scheme				Lake V.	0	62	3,560
	TARIME	135	Busanga	5,520	Rehabilitated Piped S.				Lake V.	0	62	3,397
	TARIME	136	Manira	2,334	Expanded Piped Scheme				Lake V.	0	62	1,436
	TARIME	137	Nyarombo	3,248	HP	4	6	10	Deep BH	10.7	88	2,848
	TARIME	138	Rwang'enyi	5,095	Expanded Piped Scheme				Lake V.	11.7	73	3,731
	TARIME	143	Makongoro	5,848	HP	7	3	10	Medium BH	6.4	49	2,874
	TARIME	144	Oliyo	5,537	HP	5	4	9	Deep BH	0	41	2,250
	TARIME	146	Omuga	3,900	HP	5	0	5	Deep BH	0	32	1,250
	TARIME	148	Detti	2,579	HP	3	1	4	Medium BH	0	39	1,000
	TARIME	149	Ochuna	2,210	Rehabilitated Piped S.MP	1		1	BH	0	62	1,360
	TARIME	150	Chereche	5,439	HP	7	1	8	Medium BH	0	37	2,000
	TARIME	151	Ryagoro	4,599	HP	4	6	10	Deep BH	0	54	2,500
	TARIME	152	Balongo	2,896	HP	4	2	6	Deep BH	0	52	1,500
	TARIME	154	Sudi	7,434	Rehabilitated Piped S.MP	2		2	BH	0	62	4,575
	TARIME	155	Nyamsi	2,799	HP	2	7	9	Deep BH	0	80	2,250
	TARIME	156	Panyakoo	5,902	HP	7	2	9	Deep BH	9.4	48	2,805
	TARIME	157	Tatwe	6,477	HP	5	6	11	Deep BH	0	42	2,750
	SERENGETI	3	Nyamisingisi	2,727	HP	3	0	3	Medium BH	4.3	32	867
	SERENGETI	5	Kono	1,690	HP	2	1	3	Medium BH	0	44	750
	SERENGETI	6	Motukeri	3,364	HP	4	2	6	Deep BH	0	45	1,500
	SERENGETI	8	Makundusi	4,187	HP	4	3	7	Deep BH	22	64	2,671
	SERENGETI	13	Burunga	3,694	HP	4	0	4	Deep BH	14.5	42	1,536
	SERENGETI	15	Kyambahi	1,407	HP	2	1	3	Deep BH	0	53	750
	SERENGETI	23	Matare	3,436	Rehabilitated Piped S.MP	1		1	BH	23	83	2,854
	SERENGETI	27	Monuna	3,029	HP	4	4	8	Medium BH	4.98	71	2,151
	SERENGETI	28	Nyambureti	4,055	HP	4	0	4	Medium BH	17	42	1,689
	SERENGETI	30	Kenjana	3,504	HP	4	1	5	Medium BH	8.19	44	1,537
	SERENGETI	34	Magange	2,836	HP	4	1	5	Medium BH	0	44	1,250
	SERENGETI	35	Nyamitita	2,914	HP	4	2	6	Medium BH	6.05	58	1,676
	SERENGETI	37	Busawe	2,076	HP, Spring	3		3	Deep BH	0	73	1,516
	SERENGETI	38	Nyamakobiti	4,771	HP	6	3	9	Medium BH	0	47	2,250
	SERENGETI	42	Nyiboko	4,700	HP	5	1	6	Medium BH	22	54	2,534
	SERENGETI	46	Mesaga	4,090	HP	4	2	6	Medium BH	26	63	2,564
	SERENGETI	50	Bisarara	3,530	HP	3	0	3	Medium BH	25	46	1,633
SERENGETI	54	Merenga	5,348	HP	6	2	8	Medium BH	8.2	46	2,439	
SERENGETI	62	Kwitete	3,644	HP	4	6	10	Medium BH	14.6	83	3,032	
SERENGETI	66	Nyansurura	5,333	HP	3	6	9	Deep BH	4.72	47	2,502	
SERENGETI	67	Kebancha	8,615	HP	4	3	7	Deep BH	6.2	27	2,284	
SERENGETI	72	Bonchugu	8,375	HP	10	0	10	Medium BH	0	30	2,500	
SERENGETI	76	Nyamatare	3,930	HP	4	1	5	Medium BH	11.22	43	1,691	
SERENGETI	78	Nyamatoke	4,487	HP	4	2	6	Medium BH	27.4	61	2,729	

## 5.4 Design Criteria of Water Supply Plan

Since the design criteria of the water supply plan are the same as the preliminary design for the priority project, they are presented in Chapter 6. The design year of the piped scheme for the water supply plan is basically 2015, but the capacity of some facilities such as transmission pipelines will focus on 2020 from an economic aspect. In any event, the final completed year of the overall water supply plan is the year of 2025.

## 5.5 Water Supply Development Plan

### 5.5.1 Cost Estimation for Water Supply Plan

The estimated project cost for water supply plan is summarized in Table 5.5-1 in consideration with the compositions, conditions, and the feature of types.

Table 5.5-1: Summary of Project Cost for Water Supply Plan

P/J No.	Type of plan	Construction cost (US\$)	Engineering service (15%)	Administration expenses* (5%)	Contingency (10%)	Total (US\$)	Remarks
1	Priority Project (Piped scheme and HP)	15,156,000	2,273,000	151,000	-	17,580,000	45 villages (289 wells and 8 piped schemes)
2	Medium & Deep Wells with Hand Pump	20,231,000	3,035,000	1,011,000	2,023,000	26,300,000	1580 wells
3	New Installed Piped Schemes using Lake Victoria water	35,309,000	5,296,000	1,765,000	3,530,000	45,900,000	54 piped schemes
4	New Installed Piped Schemes using Groundwater	756,000	113,000	37,000	75,000	981,000	3 piped schemes
5	Rehabilitation and expansion plan for the existing piped schemes	107,580,000	16,137,000	5,379,000	10,758,000	139,854,000	56 piped schemes
	Total amount	179,032,000	26,854,000	8,343,000	16,386,000	230,615,000	

Source: Ministry of Water for % of "Engineering service", "Administration expenses" and "Contingency"

Note: Assuming that prioritized project is carried out by Japanese assistance, administration expenses and contingency are not included in its project.

\*The rate of administration expenses of Priority Project is estimated for 1% of Construction Cost.

### 5.5.2 Implementation Plan

The donors and NGO projects are required for the achievement of the implementation plan. The MoW requested the implementation of the priority project to the government of Japan. If this project is accepted, it is expected to commence in 2007. The MoW executes the NRWSSP based on the support of WB, IDA and AfDB which is budgeted with 150 and 80 million USD respectively for the four years starting from the year 2006. The prospects for the other donors in the Mwanza and Mara regions are that AFD, EU, UNICEF, GEF, SIDA, IFAD, and et al. are expected for the investment requirement in consideration with the results of the past conditions of support.

The implementation schedule is shown in Table 5.5-2 in accordance with the prediction of the total budget with donor and GoT in Tanzania.

Table 5.5-2: Implementation Schedule for Water Supply Plan

Type of Scheme	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
Priority Project																			
Medium & Deep Well with HP																			
Newly Installed Piped Scheme from Lake																			
Newly Installed Piped Scheme from BH																			
Expanded & Rehabilitated Piped Scheme																			

The planned implementation project for the water supply plan contributes to the achievement of water supply coverage in Tanzania's strategy. The priority project will be implemented by the year 2009, and the other implementation schedules are discussed regarding the possibility of the project in the Mwanza and Mara regions in terms of the overall budget in Tanzania.

### 5.5.3 Financial Plan

External and internal sub-RWSS sector funding is identified for 2005-2008, as shown in Table 5.5-3. The funding of sub-sectors for rural water supply increased from 15.3 million USD in fiscal year (FY) 2005/2006 to 24.4 million USD in FY 2007/2008. As shown in the table below, the donor's budget is showing a rising tendency from 2005.

Table 5.5-3: Summary of Funding Identified for NRWSS Sub-Projects Plan (UNIT:USD)

Source	2005/2006	2006/2007	2007/2008	Total
GoT	1,968,000	5,672,000	6,239,200	13,879,200
Donors	11,570,000	14,013,000	15,414,300	40,997,300
NGO	1,800,000	2,400,000	2,700,000	6,900,000
Total	15,338,000	22,085,000	24,353,500	61,776,500

Financial resources for the Project will be derived from the government budget and financial assistance from foreign countries and/or international lending institutions. The annual disbursement schedule of the project costs has been finalized in Table 5.5-4 in each type. The MoW has a draft plan for the funding of External Support Agencies (ESAs) until FY 2009/2010 and indicates the Investment Requirement Plan from 2007 to 2025 in NRWSSP 2006. Based on such ideas, the expected financing of ESAs is shown in Table 5.5-4 in parallel and the expected funding in the Mwanza and Mara regions is also estimated by the rate of investment in the Mwanza and Mara regions, which is approximately 12% of the entire investment in Tanzania. In any event, external assistance in term or loans will be necessary to be covered by the entire foreign currency portion (about 78% suggested in Table 5.5-3).

The initial plan was formulated for the water supply plan with 2015 as the year of completion. However, it is impossible to complete the implementation of the water supply plan by 2015 due to the high expenses for the implementation of the initial plan within the planned time frame (2015). Therefore progressive payment is needed of the necessary funds into the payment schedule until 2025 in terms of the annual disbursement of the project cost in the Mwanza and Mara regions.

Table 5.5-4: Annual Disbursement Schedule and Expected Financing of Donor, NGO and GoT (unit: USD million)

Type of Scheme	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	
Priority Project																				
Medium & Deep Well with HP																				
Newly Installed Piped Scheme from Lake																				
Newly Installed Piped Scheme from BH																				
Expanded & Rehabilitated Piped Scheme																				
Type of Scheme	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	Total
Priority Project		17.6																		17.6
Medium & Deep Well with HP		2.7	1.85	1.85	2.4	2.8	2.1	2.1	1.85	1.73	1.73	1.73	1.73	1.73						26.3
Newly Installed Piped Scheme from Lake			2.59	7.27	7.27	4.3	1.93	1.93	1.93	3.73	3.73	3.73	3.73	3.73						45.9
Newly Installed Piped Scheme from BH			0.98																	0.98
Expanded & Rehabilitated Piped Scheme		5.28	2.42			2.72	5.96	5.96	6.51	9.01	9.01	9.01	9.01	9.01	13.2	13.2	13.2	13.2	13.2	139.90
Total (Excluding Priority Project)		7.98	7.84	9.12	9.67	9.82	9.99	9.99	10.3	14.5	14.5	14.5	14.5	14.5	13.2	13.2	13.2	13.2	13.2	230.7
Expected Financing of External Support Agencies & NGO (USD million) by NRWSSP	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	
Assumed to be implemented as JGA		17.6																		
WB & IDA	20	20	20																	
AfDB	20	20	20																	
AFD, EU, UNICEF, GEF, SIDA, IFAD & Others	18	19	20	73	78	78	78	78	78	121	121	121	121	121	110	110	110	110	110	
Plan International & Others	3	3	3																	
GOT	6.2	6.7	7																	
Total	67	69	70																	
Expected Financing of External Support Agencies & NGO in Mwanza and Mara Regions (USD million)	7	8	8	9	10	10	10	10	10	14.5	14.5	14.5	14.5	14.5	13.2	13.2	13.2	13.2	13.2	

## **5.6 Operation and Maintenance Plan of Villages and Piped Schemes**

### **5.6.1 Establishment of Institutional Frameworks**

The institutional frameworks for the water supply plan of the Study have been formulated with due consideration of the national policy and strategies.

At regional level, the RWST will be formulated as a coordination body to provide support and guidance for water and sanitation promotion in the region. At district level, the DWST will be formulated to oversee implementation of the project within the district. DWEs will act as coordinators at the DWST. At community level, community-based water supply organizations such as VWCs, WUGs, and WUAs will be formulated for operation and maintenance of the water supply facilities. For hand pump facilities, a WUG shall be formulated at each water point under supervision of the relevant VWC. For piped schemes, a WUA should be established for each piped scheme for the overall management of the scheme, and a tap committee will be formulated under the WUA.

Roles and responsibilities of responsible bodies for operating and maintaining water facilities shall be clarified and understood at regional, district and community levels.

### **5.6.2 Cost Estimation for Operation and Maintenance**

Operation and maintenance (O&M) costs include the costs for O&M workers (e.g. pump attendants), spare parts and various supplies for periodical operation and maintenance and replacement of the equipment and facilities.

There are 4 categories of water supply facilities in the proposed plan: i.e. (a) protected springs; (b) boreholes with hand pumps; (c) newly designed piped schemes; and (d) rehabilitation and expansion of the existing piped schemes. O&M costs for these categories are: (a) Tsh 12; (b) Tsh 338 to 526; (c) Tsh 1,806 to 4,023; and (d) Tsh 1,208 to 4,255 per household per month, respectively.

### **5.6.3 Cost Collection Methods/Modes of Payment**

#### **a. Suggested Collection Methods for Water Fee**

There are many options for the practical management of users' payments. Collection methods depend on local circumstances and the type of water supply facilities. Modes of payment can be categorized into: (i) payment per bucket at water point; (ii) payment per month per household; (iii) annual or semi-annual payment per household. For both piped schemes and hand pump facilities, the modes of payment need to be carefully decided with timing of cash income in communities.

#### **b. Water Fee Collection and Management**

Water users' organizations such as VWCs, WUGs and WUAs are responsible for the collection of water fee for the recovery of O&M costs. In the case of protected spring or hand pump facilities, users will pay a water fee to a water fee collector or a treasurer of a WUG, who will manage the water fee and make monthly reports to the relevant VWC on the WUG's financial status.

For the piped scheme facility, in the case of payment per bucket, water users will pay a water fee to a water fee collector of the tap committee at a domestic point, and the treasurer of the WUA will manage the water fee and make monthly reports to the relevant VWC on the WUA's status. In the case of flat rates such as monthly, semi-annual and annual payments,



the water fee will be collected by a treasurer of the respective tap committee, and the treasurer of the WUA will manage the water fee and make a report to the relevant VWC on the WUA's status.

#### **5.6.4 Community Awareness Plan**

In due consideration of the fact that the existing community-based water supply organizations such as VWCs and WUGs have failed to meet expected roles and responsibilities due to the immature sense of ownership of water users, and limited support from the DWE offices, a structured community awareness plan has been formulated to strengthen the sense of ownership of the water users, and to increase awareness of the same on the benefits of using safe water.

One of the components for the proposed plan is the capacity development for water supply facility management to raise awareness among villagers on the benefits of using water supply facility and management through appropriate operation and maintenance as well as formulation and strengthening community water supply organizations. This component includes the training to be conducted at community level for strengthening managerial as well as technical capacity of community water supply organizations such as VWCs, WUGs and WUAs.

Another component is the awareness raising on the use of safe water and sanitary/hygiene practices. This component aims to foster the awareness on the benefits of using safe water based on the on-going PHAST approach promoted by the MoH in cooperation with water sector across the nation.

It is recommended to implement the community awareness plan before the commencement of the construction works of the water supply facilities.

### **5.7 Evaluation of Water Supply Plan**

#### **5.7.1 Economic Evaluation**

Economic Project costs are composed of the investment costs, comprising of the costs for construction of water supply facilities, administration, engineering services and physical contingency and recurrent costs, consisting of annual operation, maintenance and replacement costs for the equipment and facilities. On the other hand, economic benefits include the saved time benefits for water fetching and health improvement benefits.

As a result of comparison between the economic costs and benefits, the EIRR is calculated as 13.8 %, exceeding the opportunity cost of capital (10%), the NPV is positive and the B/C exceeds 1.0. Therefore the water supply plan in the Mwanza and Mara regions is economically feasible.

#### **5.7.2 Financial Aspects**

In regard to the financial sources for the project, the total capital costs are allocated in the annual disbursement schedule based on the expected financing of ESAs and NGO and the investment requirement plan by NRWSSP. The allocation for funding by ESAs, NGO and GoT is planned in consideration with the past tendency of funding. About 12% of the entire investment in Tanzania is occupied in that of the Mwanza and Mara regions depending on the investment requirement of the Tanzanian government by NRWSSP. The annual capital cost allocated is relevant in comparison with the expected funding of investment in the Mwanza and Mara regions.

The beneficiaries in the target communities are expected to organize their water supply organizations to conduct periodical operation and maintenance works and to collect water fees for the recovery of the operation and maintenance expenses. The water fee to be collected in each community is estimated at Tsh 0.50 or Tsh 1.00 per liter depending on the kind of the facilities. In the case of the recovery of O&M costs, a water rate of Tsh 0.50 per liter or Tsh 10 per bucket will be sufficient to cover the required OMR costs.

### **5.7.3 Organization/Institution Evaluation**

For the solution of current organizational/institutional issues in the Study area, the organizational/ institutional plan has been suggested. The plan includes: (1) Establishment of a coordination body for water and sanitation promotion to provide support and guidance at the regional level, (2) Clarification of the responsibilities of DWST to provide technical and financial support to communities in the villages and operating and maintaining water facilities, (3) Strengthening the capacity of District Water Department /District Water Engineer Office, and (4) Establishment of the responsible bodies of community water organizations, which are shown in the NRWSSP.

From those suggestions above the institutional/organizational plan is judged to be relevant and can be evaluated for the adequate and feasible plan in terms of the objectives of the national water policy.

### **5.7.4 Natural/Social Environment Evaluation**

An IEE study was conducted in order to consider the impact of project implementation on the natural and social environment. As the primary objective of the water supply plan is to improve water problems, it in essence should not have any negative environmental or social impact.

Although there are water venders in cities and towns near Lake Victoria, there are few such venders in villages. Therefore, the construction of facilities in the water supply plan is not likely to have a big impact on water venders.

There are also many benefits due to the construction of water supply facilities, particularly in regard to the gender issue of water fetching, which is the responsibility of women and children. The time and money saved by the construction of water facilities within villages will increase the opportunity to use such resources for other social activities, and so on. The facility construction by this water supply plan is not likely to have any negative impact in terms of the natural and social environment.

### **5.7.5 Technical Aspects**

In the case of the water supply plan from a technical point of view, it is necessary to consider not only “hard” factors, such as facility construction and equipment, but also “soft” factors, such as operation and maintenance. The piped schemes using lake water require filtration devices such as filters, and the technical monitoring and supervision of such devices will be an important technical issue. The repair of hand pumps, with the exception of breakdowns requiring major repairs, is generally easy and inexpensive. The operation and maintenance of hand pumps is also simple and as they have been used in the past, the implementation of hand pumps is appropriate. However regarding the piped scheme, it is necessary to conduct the technical support for the operation and maintenance of facility.

# Chapter 6

---

---

*Priority Project*

## 6 Priority Project

### 6.1 General

Finally 45 villages were selected as priority projects of which include 43 villages and 1 existing piped scheme containing 2 villages. The implementation of the Water Supply Plan for this priority project is supposed to be implemented by the Japanese Grant Aid Project

### 6.2 Selection and Criteria for Priority Project

#### 6.2.1 Selection Process

The process of the selection of villages and existing piped schemes for the priority project is executed separately, as shown in Figure 6.2-1.




Figure 6.2-1: Schematic Selection Flow of Priority Project for Village and Piped Scheme

#### 6.2.2 Selection Criteria

##### a. Village Selection

Seven criteria, categorized into three major points of; 1) the advantage of support for water supply, 2) better access to safe water, and 3) existence of unknown factors, were applied to screen the requested 929 villages down to 428 villages.

Then the 428 villages were narrowed down to 205 villages by scoring and prioritizing based on conditions such as; 1) accessibility to safe water, 2) effectiveness of project implementation, and 3) willingness and/or availability to participate in the water supply project. A socio economic survey was conducted in the 205 villages followed by a supplementary survey of 100 villages.

The 43 villages for the priority project were selected by the criteria of; 1) existence of O&M system, 2) Willingness to pay, 3) capacity to pay, 4) project experience, 5) capacity of DWD with some consideration of accessibility and potential of water source.

**b. Piped Scheme Selection**

The five selection criteria were applied to the 110 piped schemes for screening. The criteria are; 1) at least one village exists in the requested 929 villages, 2) at least one village classified as being in the rural area, 3) not included in on-going or proposed projects, 4) In villages where the population supplied by water using shallow and deep wells is less than 50% of the administrative population, the piped schemes should cover at least one village, and 5) Existing piped schemes that have been excluded by recent mid-to-large scale rehabilitation projects. The 57 villages were selected by such five criteria.

The 17 targets of the piped water scheme for the supplementary survey were selected by using criteria, such as functioning, partially functioning, changing pump after the year 2000, replacement of pipe after completion, served population (more than 50%), and the existence of inaccurate data.

1 piped which includes 2 villages for the priority project was selected by criteria such as demand for improved supply water, O&M capability of community, financial capability, and willing to pay from the result of the supplementary survey of socio-economy and O&M survey. The list of the selected priority projects is shown in Table 6.2-1 and the served population rate of the piped schemes and priority villages in 2015 is shown in Table 6.2-2. The location of the priority projects is presented in Figure 6.2-2.

The priority project of the water supply plan for 428 villages and 57 piped schemes is selected. It is impossible to confirm the next grant aid schedule which is assumed to be implemented by Japanese Government at this point in time. However, if the next priority project is planned, there is a high possibility that the remaining of 100 villages and 17 piped schemes from the supplementary survey may be selected for the next priority project.


Table 6.2-1: List of Piped Schemes and Wells with Hand Pumps for Priority Project

REGION	DISTRICT	Scheme Name	No. by District	Village	Population in 2015 =Served population	Type of piped scheme (MP=Motor pump)	Number of MP	Water Sources
MWANZA	MISUNGWI	Busongo	25	Busongo	5,590	Newly Piped Scheme MP	2	Deep BH
	MISUNGWI	Ngaya	28	Ngaya	4,371	Newly Piped Scheme		Lake V.
	SENGEREMA	Buswelu	75	Buswelu	3,780	Newly Piped Scheme MP	2	Deep BH
	SENGEREMA	Nyamiswi	99	Nyamiswi	3,264	Newly Piped Scheme		Lake V.
	SENGEREMA		100	Nyakasasa	5,709	Newly Piped Scheme		Lake V.
	SENGEREMA	Nyakahako	44	Nyakahako	7,384	Newly Piped Scheme		Lake V.
	KWIMBA	Hungumalwa	22	Hungumalwa	7,113	Newly Piped Scheme MP	3	Deep BH
	Ukerewe	Bukonyo	45	Bukonyo	2,290	Existing Piped Scheme		Lake V.
Ukerewe	-		Namilembe	3,793	Existing Piped Scheme		Lake V.	
MARA	MUSOMA	Saragana	35	Saragana	4,641	Newly Piped Scheme MP	2	Deep BH

REGION	DISTRICT	No. by District	Village	Population in 2015	Type of well (HP=Hand pump)	No of Deep BH	No of Additional Medium BH	Total BH No	Total Covered Population Rate(%)	Served Population in 2015
MWANZA	SENGEREMA	13	Sogoso	5,739	Deep & Medium HP	6	3	9	39	2,250
	SENGEREMA	67	Sotta	4,403	Deep & Medium HP	5	2	7	40	1,750
	SENGEREMA	69	Isole	5,021	Deep & Medium HP	5	2	7	53	2,644
	SENGEREMA	83	Busekeseke	3,420	Deep & Medium HP	4	3	7	51	1,750
	SENGEREMA	84	Katoma	4,046	Deep & Medium HP	5	3	8	49	2,000
	SENGEREMA	86	Magulukenda	5,092	Deep & Medium HP	6	2	8	39	2,000
	SENGEREMA	96	Nyancheche	7,677	Deep & Medium HP	5	4	9	29	2,250
	KWIMBA	71	Mhulya	3,067	Deep & Medium HP	4	4	8	65	2,000
	MAGU	75	Kijereshi	7,401	Deep & Medium HP	8	2	10	42	3,122
	GEITA	17	Bugulala	9,030	Deep & Medium HP	5	6	11	30	2,750
	GEITA	18	Kasota	10,216	Deep & Medium HP, Spring	5	4	9	39	3,984
	GEITA	22	Kamena	8,655	Deep & Medium HP	5	3	8	23	2,000
	GEITA	24	Ndelema	4,371	Deep & Medium HP	3	7	10	57	2,500
	GEITA	25	Nyashishima	2,065	Deep & Medium HP	2	3	5	61	1,250
	GEITA	26	Bogogo	10,380	Deep & Medium HP	6	2	8	32	3,349
	GEITA	27	Ikina	2,494	Deep & Medium HP	2	5	7	70	1,750
	GEITA	42	Ibondo	7,667	Deep & Medium HP	7	6	13	42	3,250
	MARA	BUNDA	33	Mcharo	1,295	Deep & Medium HP	4	1	5	100
MUSOMA		6	Sirorisimba	3,997	Deep & Medium HP	4	4	8	50	2,000
MUSOMA		8	Ryamisanga	4,769	Deep & Medium HP	6	2	8	60	2,858
MUSOMA		21	Kisamwene	4,427	Deep & Medium HP	6	5	11	62	2,750
MUSOMA		33	Bugoji	5,450	Deep & Medium HP	7	3	10	68	3,699
MUSOMA		55	Isaba	4,145	Deep & Medium HP	3	7	10	80	3,329
TARIME		24	Nyankunguru	5,772	Deep & Medium HP	5	4	9	39	2,250
TARIME		44	Kiwanja	5,177	Deep & Medium HP	4	1	5	48	2,492
TARIME		71	Bisarwi	3,684	Deep & Medium HP	3	5	8	71	2,612
TARIME		94	Kisumwa	2,690	Deep & Medium HP	2	3	5	62	1,656
TARIME		112	Nyankonge	2,071	Deep & Medium HP	2	3	5	60	1,250
TARIME		129	Masike	3,319	Deep & Medium HP	5	6	11	83	2,750
TARIME		131	Bukama	5,225	Deep & Medium HP	4	7	11	53	2,750
TARIME		144	Oliyo	4,543	Deep & Medium HP	5	4	9	50	2,250
TARIME		157	Tatwe	5,315	Deep & Medium HP	5	6	11	52	2,750
SERENGETI		37	Busawe	1,663	Deep HP, Spring	3		3	100	1,663
SERENGETI		66	Nyansurura	4,124	Deep & Medium HP	3	6	9	59	2,445
SERENGETI	67	Kebancha	6,899	Deep & Medium HP	4	3	7	32	2,178	

Table 6.2-2: Served Population Rate of Priority Project in 2015

Region	District	Hand Pump (HP)	HP +Spring	Piped Scheme (BH)	Piped Scheme (Lake)	Total Number	Served Population in 2015	Administrative Population of Priority Villages in 2015	Covered Population Rate (%) of Priority Village in 2015	Administrative Population of District in 2015	Covered Population Rate (%) of District in 2015
MWANZA	MISSUNGWI			1	1	2	9,961	9,961	100.0%	304,874	3.3%
	SENGEREMA	7		1	3	11	34,781	55,535	62.6%	799,082	4.4%
	KWIMBA	1		1		2	9,113	10,180	89.5%	454,104	2.0%
	MAGU	1				1	3,122	7,401	42.2%	545,368	0.6%
	GEITA	7	1			8	20,833	54,878	38.0%	1,115,502	1.9%
	UKEREWE				2	2	6,083	6,083	100.0%	385,198	1.6%
	<b>SUB TOTAL</b>	<b>16</b>	<b>1</b>	<b>3</b>	<b>6</b>	<b>26</b>	<b>83,893</b>	<b>144,038</b>	<b>58.2%</b>	<b>3,604,128</b>	<b>2.3%</b>
MARA	BUNDA	1				1	1,295	1,295	100.0%	330,359	0.4%
	MUSOMA	5		1		6	19,277	27,423	70.3%	434,049	4.4%
	TARIME	9				9	20,760	37,796	54.9%	693,313	3.0%
	SERENGETI	2	1			3	6,286	12,686	49.6%	266,693	2.4%
	<b>SUB TOTAL</b>	<b>17</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>19</b>	<b>47,618</b>	<b>79,200</b>	<b>60.1%</b>	<b>1,724,414</b>	<b>2.8%</b>
<b>GRAND TOTAL</b>	<b>33</b>	<b>2</b>	<b>4</b>	<b>6</b>	<b>45</b>	<b>131,511</b>	<b>223,238</b>	<b>58.9%</b>	<b>5,328,542</b>	<b>2.5%</b>	





## 6.3 Preliminary Design of Water Supply Facilities

### 6.3.1 General Notion of Preliminary Design

The water sources of piped schemes are lake water and groundwater. In the case of lake water, simple purification facilities such as slow sand filtration are proposed, and in the case of groundwater, only disinfection using chlorine is proposed. The water to be stored in service reservoirs using rising pumps will be supplied to dwellers by gravity.

### 6.3.2 Water Demand

Future water demand is based on domestic use and institutional use such as school, health center, etc. This is explained in Chapter 5 of the Main report.

### 6.3.3 Design Manual for Preliminary Design

Since the “Design Manual for Water Supply and Waste Water Disposal, Volume 1 July 1997” was applied for conventional water supply projects in Tanzania, this is also applicable for a preliminary design of water supply facilities in principle.

### 6.3.4 Design Criteria

The common conditions, such as service population covered by hand pump, etc. are as follows and the design criteria applied to the preliminary design are shown as follows.

- Service population: 250persons/placet
- Lift capacity of a hand pump: 0.015m<sup>3</sup>/min (7.2m<sup>3</sup>/day in pump lifting time of 8 hours a day)

In terms of the piped schemes, the common conditions, such as design flow, etc. for preliminary design are as follows.

- Public tap operation hours: 8hours
- Unaccounted for water : 20% of daily water demand
- Daily average flow: daily water demand + uncounted amount of water
- Daily maximum. flow: 120% of daily average flow
- Hourly maximum. flow: 360% of daily average flow (based on tap operation time of 8 hours a day)

In addition, the design criteria for piped schemes is categorized into intake, purification, transmission and distribution facilities and summarized in Table 6.3-1

Table 6.3-1: Design Criteria of Piped Scheme

Facilities		Specification	Design factor	Design criteria
Intake	Water source	Groundwater or lake water		
	Intake pump	Submersible for groundwater and lake sources	Daily operation hours	12 hours
			Capacity	Daily Max. flow <sup>**1</sup> (m <sup>3</sup> /day)/12 hours
	Power source	Generator with diesel engine		
Intake chamber	Concrete circular	Capacity	12 hours of Daily Max. flow <sup>**1</sup> (m <sup>3</sup> /day)	

	Pipes	Polyethylene	Design flow	Daily Max. flow <sup>※1</sup> (m <sup>3</sup> /day)/12 hours
Purification	Sedimentation basin	Plain sedimentation, Concrete	Capacity	Daily Max. flow (m <sup>3</sup> /day)
	Filtration	Slow sand filter	Capacity	Daily Max. flow (m <sup>3</sup> /day)
Transmission	Pump sump	Concrete circular	Capacity	12 hours Daily Max. flow (m <sup>3</sup> /day)
	Rising pump	Surface pump	Daily operation hours	12 hours
			Capacity	Daily Max. flow (m <sup>3</sup> /day)/12 hours
	Booster pump	Surface pump	Daily operation hours	12 hours
			Capacity	Daily Max. flow (m <sup>3</sup> /day)/12 hours
	Power source	Generator with diesel engine		
	Pipes	GI or DIP	Design flow	Daily Max. flow (m <sup>3</sup> /day)/12hours
Distribution	Service reservoir	Ground type: Stone masonry or concrete block	Capacity	16 hours of Daily Max. flow (m <sup>3</sup> /day)
		Riser type: Steel	Capacity	16 hours of Daily Max. flow (m <sup>3</sup> /day) , Max. 50m <sup>3</sup> , Height: 15m or less
	Pipes	GI or PVC	Design flow	Hourly Max. flow
	Water point	Mainly double taps (Public taps)	Number of water points	About 580 dwellers per water point

※1: An amount of 10% for washing use is included.

### 6.3.5 Facility Plan

Each water supply facility is designed based on the Design Manual. The specification of each water supply facility is summarized in Table 6.3-2 and Table 6.3-3. The main facilities, such as layouts of piped scheme are shown in Figure 6.3-1 to Figure 6.3-8.

#### a. Lake Victoria

Intake points should be located at least about 80m from the shore line of the lake and at least 3m from the water surface in depth to avoid the contamination from pollution. Slow sand filtration is proposed for the filtration of the water. The type of service reservoir (ground or riser) is proposed based on the topographic conditions. Galvanized pipes are used for both transmission and distribution facilities for ease of maintenance.

#### b. Groundwater

Groundwater can be used for the water supply facilities of boreholes with hand pumps and piped schemes. Specification of the facilities is according to hand pump and piped scheme system. Springs are protected to avoid contamination, and basically distributed by gravity.

Table 6.3-2: Facility Specifications of the Priority Project

No.	District	Village or Scheme	Water sources		Intake facility			Filtration facility		Transmission facility			Distribution facility		
			Lake water	Groundwater <sup>1</sup> (BH depth)	Conveyance pipes	Pump	Chamber	Sedimentation	Filter	Pump sump	Pump	Pipes	Service <sup>2</sup> reservoir	Pipes	Double Public taps
<b>Borehole with hand pump</b>															
1-35		35 villages	-	225 (100m)	-	-	-	-	-	-	-	-	-	-	-
<b>Newly piped scheme</b>															
36	Misungwi	Ngaya	1	-	Φ50mm×300m	9.3m <sup>3</sup> /hr×20m <sup>H</sup> ×1.5kW×1Ls.	V=60m <sup>3</sup>	Q=4.3m <sup>3</sup> /hr	Q=4.3m <sup>3</sup> /hr	V=60m <sup>3</sup>	8.5m <sup>3</sup> /hr×60mH×3.7kW	Φ80mm×1,100m	V=70m <sup>3</sup> (G)	Φ150mm×3,300m	15Ls.
37	Sengerema	Nyamisiwi	1	-	Φ80mm×300m	32m <sup>3</sup> /hr×20m <sup>H</sup> ×3.7kW×1Ls.	V=190m <sup>3</sup>	-	Q=16m <sup>3</sup> /hr	V=190m <sup>3</sup>	29m <sup>3</sup> /hr×70mH×11kW	Φ150mm×3,500m	V=150m <sup>3</sup> (G)	Φ40mm×3,200m Φ80mm×3,850m	35Ls.
													V=50m <sup>3</sup> (R)	Φ100mm×700m Φ150mm×2,650m	
38	Sengerema	Nyakahako	1	-	Φ80mm×300m	20m <sup>3</sup> /hr×20m <sup>H</sup> ×2.2kW×1Ls.	V=90m <sup>3</sup>	Q=9.2m <sup>3</sup> /hr	Q=9.2m <sup>3</sup> /hr	V=190m <sup>3</sup>	18m <sup>3</sup> /hr×50mH×5.5kW	Φ150mm×2,000m	V=150m <sup>3</sup> (G)	Φ150mm×3,800m	29Ls.
39	Misungwi	Busongo	-	2 (100m)	Φ50mm×100m	17m <sup>3</sup> /hr×60m <sup>H</sup> ×1.5kW×2Ls.	-	-	-	V=100m <sup>3</sup>	17m <sup>3</sup> /hr×94mH×1.5kW	Φ150mm×4,000m	V=140m <sup>3</sup> (G)	Φ40mm×2,700m Φ50mm×6,300m Φ80mm×500m	21Ls.
														Φ100mm×900m Φ150mm×800m	
40	Sengerema	Buswelu	-	2 (100m)	Φ50mm×100m	11m <sup>3</sup> /hr×60m <sup>H</sup> ×3.7kW×2Ls.	-	-	-	V=75m <sup>3</sup>	11m <sup>3</sup> /hr×93mH×5.5kW	Φ100mm×2,891m	V=90m <sup>3</sup> (G)	Φ40mm×2,100m Φ50mm×700m Φ80mm×2,900m	13Ls.
														Φ100mm×400m	
41	Kwimba	Hungmalwa	-	2 (100m)	Φ50mm×100m	18m <sup>3</sup> /hr×60m <sup>H</sup> ×5.5kW×2Ls.	-	-	-	V=110m <sup>3</sup>	18m <sup>3</sup> /hr×66mH×5.5kW	Φ150mm×7,583m	V=90m <sup>3</sup> (G)	Φ80mm×5,900m Φ100mm×400m	20Ls.
														Φ150mm×1,100m	
42	Musoma	Saragana	-	2 (100m)	Φ50mm×100m	14m <sup>3</sup> /hr×60m <sup>H</sup> ×5.5kW×2Ls.	-	-	-	V=90m <sup>3</sup>	14m <sup>3</sup> /hr×61mH×5.5kW	Φ80mm×803m	V=120m <sup>3</sup> (G)	Φ40mm×1,500m Φ50mm×700m Φ80mm×2,600m	12Ls.
														Φ100mm×500m	
<b>Rehabilitation and Expansion piped scheme</b>															
43	Ukerewe	Bukonyo	1	-	Φ50mm×300m	16m <sup>3</sup> /hr×20m <sup>H</sup> ×1.5kW×1Ls.	V=90m <sup>3</sup>	-	Q=7m <sup>3</sup> /hr	V=90m <sup>3</sup>	14m <sup>3</sup> /hr×64mH×5.5kW	Φ100mm×3,500m	V=110m <sup>3</sup> (G)	Φ40mm×800m Φ50mm×200m Φ80mm×2,400m	17Ls.
														Φ100mm×1,400m Φ150mm×1,800m	

N.B.

1. See Table on the borehole numbers with hand pump for each village, and this number was accumulated considering drilling success rate.

2. (G):Ground type reservoir,(R):Riser tank

Table 6.3-3: Borehole Structure

Item	Borehole with hand pump	Borehole for piped scheme
Borehole depth	100m	100m
Diameter for drilling	8 inches 3/4	10 inches
Casing and screen diameter	5 inch	6 inch
Casing and screen pipe material	PVC	GI
Filling between borehole and casing	Cementing in casing section Gravel packing in screen	Cementing in casing section Gravel packing in screen
Cylinder depth of hand pump	Less than 50m	-
Submersible pump position	-	Varies (Depends on operating water level)




Figure 6.3-1: Layout of Newly Installed Piped Scheme (Ngaya Scheme)




Figure 6.3-2: Layout of Newly Installed Piped Scheme (Nyamiswi Scheme)




Figure 6.3-3: Layout of Newly Installed Piped Scheme (Nyakahako Scheme)




Figure 6.3-4: Layout of Newly Installed Piped Scheme (Busongo Scheme)




Figure 6.3-5: Layout of Newly Installed Piped Scheme (Buswelu Scheme)




Figure 6.3-6: Layout of Newly Installed Piped Scheme (Hungmalwa Scheme)




Figure 6.3-7: Layout of Newly Installed Piped Scheme (Saragana Scheme)




Figure 6.3-8: Layout of Newly Installed Piped Scheme (Bukonyo Scheme)

#### 6.4 Cost Estimation for Priority Project

The construction cost was briefly estimated based on the implementation was supposed to be implemented by the Japanese Grant Aid Project. The total project cost including the engineering expenses of the priority project is estimated at approximately USD17.6 million. The project costs are summarized in Table 6.4-1.

Table 6.4-1: Cost Estimation of Priority Project

Unit: USD

Water supply system	Construction cost	Engineering expenses (15%)+others	Project cost	Remarks
Borehole with hand pump	5,116,000	818,000	5,934,000	35villages, two spring protections are included
Newly piped scheme	8,788,000	1,406,000	10,194,000	7 schemes (8 villages)
Rehabilitation and expansion piped scheme	1,252,000	200,000	1,452,000	1 scheme (2 villages)
<b>Total</b>	<b>15,156,000</b>	<b>2,424,000</b>	<b>17,580,000</b>	



# Chapter 7

---

---

*Project Plan*

## **7 Project Plan**

### **7.1 General**

The project plan, including the construction and implementation plan was formulated with the consideration of natural and social conditions for the priority project in this Chapter.

### **7.2 Construction Plan**

#### **7.2.1 Natural Conditions**

The period of the rainy season is November to April in the Study area. During this season, several obstructions shall be considered such as bad accessibility to the site and swampy site conditions. Undulation of the topography such as granite ridges shall also be carefully examined for the pipe layouts in relation with the intake point of lake water extraction.

As most of the well targets the deep fissure water, further surveys shall be conducted, such as geophysical sounding and lineament interpretation to locate the most promising site for groundwater extraction. Due to the possibility of various contaminations from toxic materials, the water quality of the source shall be carefully examined before the utilization of the water.

#### **7.2.2 Socio-economic Conditions**

The result of the Socio-economic and O&M survey confirmed that the establishment of village water committees will be initiated soon, and contribution of the users` workforce at the construction stage has also been confirmed. Therefore, the involvement of the villagers at the facility construction stage will be realized.

#### **7.2.3 Machinery and Material**

Conventional machinery and construction materials are utilized for ease of spare parts procurement to realize the sustainable operation and maintenance by the users. If the materials are imported, they should contact the local agent of such foreign manufactures.

#### **7.2.4 Local Contractor**

There are five types of contractors; Civil Works, Building, Mechanical, Electrical, and Specialist Contractor, registered in the “Contractor Registration Board (CRB)”. Those contractors are classified into local and foreign contractors. Moreover, there are seven classes for civil works, building, mechanical, and electrical contractors. For specialist contractors, there are only three classes.

#### **7.2.5 Implementation Schedule**

Assuming that the prioritized project is carried out for three years, the following time schedule shown in Table 7.2-1 is proposed.

Table 7.2-1: Implementation Schedule of Priority Project

Facility	Region	District	Name of Scheme	2007	2008	2009
Borehole with hand pumps	Mwanza	Sengerema	-			
		Kwimba	-			
		Magu	-			
		Geita	-			
	Mara	Bunda	-			
		Musoma (R)	-			
		Tarime	-			
		Serengeti	-			
Piped schemes	Mwanza	Misungwi	Ngaya			
		Misungwi	Busongo			
		Sengerema	Nyamiswi			
		Sengerema	Nyakahako			
		Sengerema	Buswelu			
		Kwimba	Hungumalwa			
		Ukerewe	Bukonyo			
	Mara	Musoma (R)	Saragana			

## 7.2.6 Financial Plan for the Priority Project

The total project cost for the priority project is calculated as 17.6 million USD in the three year term as shown in the following table which is supposed to be implemented by the Japanese Grant Aid Project.

Table 7.2-2: Annual Disbursement for Priority Project (Unit: USD)

Facility	District	Amount			
		Total	2007 1st	2008 2nd	2009 3rd
Borehole with hand pumps	Sengerema	1,273,000	1,273,000		
	Kwimba	162,000	162,000		
	Magu	261,000	261,000		
	Geita	1,364,000		1,364,000	
	Bunda	142,000		142,000	
	Musoma (R)	972,000			972,000
	Tarime	1,385,000			1,385,000
	Serengeti	375,000		375,000	
	<b>Sub Total</b>	<b>5,934,000</b>	<b>1,696,000</b>	<b>1,881,000</b>	<b>2,357,000</b>
Piped scheme	Missungwi	2,687,000		2,687,000	
	Sengerema	4,681,000	4,681,000		
	Kwimba	2,165,000		2,165,000	
	Ukerewe	1,452,000			1,452,000
	Musoma (R)	661,000			661,000
		<b>Sub total</b>	<b>11,646,000</b>	<b>4,681,000</b>	<b>4,852,000</b>
<b>Total</b>		<b>17,580,000</b>	<b>6,377,000</b>	<b>6,733,000</b>	<b>4,470,000</b>

The entire project which was formulated in the Study as the Water Supply Plan other than the priority project shall be executed by the fund prepared by the MoW and concerned donors and NGOs. The expected budget allocation to the Mwanza and Mara Water Supply Plan was formulated in reference with the budget of NRWSSP as shown in Table 7.2-3.

Table 7.2-3: Planned Budget for Rural Water Supply

Type of Scheme	2007	2008	2009
Priority Project			
Medium & Deep Well with HP			
Newly Installed Piped Scheme from Lake			
Newly Installed Piped Scheme from BH			
Expanded & Rehabilitated Piped Scheme			
Expected Financing of External Support Agencies & NGO (USD million) by NRWSSP	2007	2008	2009
Assumed to be implemented as JGA	17.6		
WB & IDA	20	20	20
AfDB	20	20	20
AFD, EU, UNICEF, GEF, SIDA, IFAD & Others	18	19	20
Plan International & Others	3	3	3
GOT	6.2	6.7	7
Total	67	69	70
Expected Financing of External Support Agencies & NGO in Mwanza and Mara Regions (USD million)	7	8	8

# Chapter 8

---

---

*Organization and Institutional Plan*

## **8 Organization and Institutional Plan**

### **8.1 General**

Overall institutional framework for the water supply plan in the Study is suggested in Chapter 5 (Water Supply Plan), considering future institutional frameworks proposed by the NAWAPO and NRWSSP, and current organizational problems in the Study area, and along the institutional frame work, the expected roles of responsible bodies for operation and maintenance at regional, district and community level are also clarified.

The Study on the Organization and Institution Plan in this chapter is carried out to formulate organizational and institutional arrangements for conducting appropriate operation and maintenance activities of the water supply facilities in the priority villages.

Analysis is given to the current activities for water supply in the priority villages in terms of organizational institutional arrangement, and the Organization and Institution plan is prepared taking consideration of the current conditions and problems relating to water supply facility management revealed by the supplementary field surveys and required tasks for practical operation and maintenance.

### **8.2 Current Activities for Water Supply at Community (45 Priority Villages)**

As a result of the supplementary survey, all of the priority villages have already established either a Village Water Committee (VWC) or a Water User Group. In particular, the VWCs have been established in 91% of the priority villages, and it was observed that the VWC is the most diffused community water organization in the priority villages. Almost all of the current VWCs and WUGs have the issues on financial and managerial capacity in order to carry out community based facility management. However, as for the maintenance of the existing hand pump facilities, the basic concepts underlying the HESAWA WUG such as the sense of ownership and community based water facility management remain active and diffused into some of the priority villages. The high diffusion rate and the central role of the current VWC in the priority villages are advantageous, although the activeness of the VWCs vary from community to community.

### **8.3 Organizational and Institutional Arrangement of Responsible Bodies**

#### **8.3.1 The Overviews of Suggested Organizational and Institutional Arrangement**

To establish appropriate institutional and organizational settings with key stakeholders in the priority villages, the basic principles underlying the arrangement are established: (1) Strengthening supporting systems to communities on community mobilization and technical maintenance by public offices (e.g. District Water Department); (2) Increasing self-help capacity on management, operation and maintenance by users at community level in order to sustain water facilities.

Based on the above understanding, the overall institutional framework and expected roles of the responsible bodies proposed in Chapter 5, advantages and issues on current community water organizations, the responsible bodies and relationship between the key institutions are suggested in the following tables and figures.

As for the hand pump facilities in the priority villages, a WUG shall be established at each hand pump facility and become the responsible body for operation and maintenance. A respective VWC, District Water Department and DWST in the targeted area will support the WUG based facility management as shown in Figure 8.3-1. After the newly established WUG receive training on community mobilization, management and technical repair and

maintenance from the public offices, the WUG take the responsibilities of the collection of water fees and water funds, repair and maintenance of the facility and other activities. To overcome the issue of the misuse of water funds within the village government, the financial management shall be independent from the VWC, but the WUG will report the financial status to the VWC for financial accountability. The District Water Department provides mainly technical support with the WUG and monitors the activities.

As for the piped scheme facilities, a tap committee shall be established at each domestic water point, and compose a WUA at each piped scheme (refer to Figure 8.3-2). The WUA will become a responsible body for operation and maintenance, and a respective VWC, the District Water Department and DWST will support the WUA based facility management. However, the current respective VWC in the priority village might take responsibilities of various operation and maintenance activities, until the newly established WUA functions substantially.

Figure 8.3-2 shows an institutional arrangement for a piped scheme covering more than one village. After the responsibilities are transferred from the VWC to the WUA, the WUA will submit financial reports to the VWC ensuring accountability. In the case of operation and maintenance of the piped scheme, the DWE and the water technician of the respective District Water Department especially provide training on technical aspects of the O&M, periodical monitoring of the facilities including pump, generator, and filtration, and data management of the facility conditions.

As for both types of the water supply facility, the regional coordination body shall support the community based facility management indirectly, by providing technical advice and support to the District Water Department, and coordinating trainings at the district level efficiently.

**Hand Pump Facility**




Figure 8.3-1: Institutional Arrangement for O&M of the Hand Pump in the Priority Villages




Figure 8.3-2: Suggested Institutional Arrangement for O&M on Piped Scheme in the Priority Villages

### 8.3.2 Village Level

As shown in Figure 8.3-1 and Figure 8.3-2, three types of community based water supply organizations, namely WUG, WUA, or VWC are required appropriately in the 45 priority villages. Institutional development of the responsible organizations at the community level is a key to operate and maintain the facilities in the priority villages in an effective and sustainable manner. The patterns of organizational development are various from the establishment of the organization to the entitlement of water right and legal status. Different institutional development patterns of the community based water supply facility management are identified for the priority villages by types of water supply facilities. As improvement plans to solve the common organizational issues at the community level, training on community mobilization skill, financial and technical skill for the facility management shall be along the institutional development.

### 8.3.3 District Level

To support community water organizations and sustain water supply facilities in the priority villages, organizational arrangement and training of personnel related to water supply and sanitation activities in the District Water Department are crucial. Based on the preventive maintenance manner, which expects and prevents trouble with the facility or machinery before it occurs, the following measures to be taken: (1) establishment of the periodical monitoring system for preventive maintenance at the community level, (2) training on water supply planning and data management targeted to the DWE, technical skills of the DWT, and



community awareness, gender and PHAST (Participation Hygiene and Sanitation Transformation) to all personnel of the District Water Department and the DWST to facilitate the priority villages.

#### **8.3.4 Regional level**

At the regional level, a coordination body for water and sanitation promotion shall be established to support all responsible bodies entirely in order to provide technical advice on operation and maintenance activities in the priority villages and will become a coordinator to promote water and sanitation activities in all districts. As for the PHAST programme, the regional organizations need to receive training programmes as a future facilitative organization.

# Chapter 9

---

---

*Operation and Maintenance  
and Community Awareness Plan*

## 9 Operation and Maintenance and Community Awareness Plan

### 9.1 Operation and Maintenance Plan

The following examines in detail the O&M cost by water facility types for 45 villages, water fee collection, methods of facility repairs, and spare parts procurement. The exchange rate applied in this chapter is based on the rate of May 2006 (1USD= Tsh 1,181, 1USD=JY 114.58).

#### 9.1.1 Operation and Maintenance Cost

The O&M costs for hand pump facilities include personnel expenses of O&M workers, and the costs of spare parts and supplies for periodical O&M activities. The same costs for piped scheme include: running costs, personnel expenses of O&M workers, and various supplies for periodical operation and maintenance activities, and the future replacement cost of the water supply facilities.

There are 4 categories of water supply facilities in the proposed plan: i.e. (a) protected springs; (b) boreholes with hand pumps; (c) newly designed piped schemes; and (d) rehabilitation and expansion of the existing piped schemes. O&M costs for these categories are converted into a monthly O&M amount to be covered by the water users, i.e. (a) Tsh 12; (b) Tsh 924; (c) Tsh 1,019 to 2,503; and (d) Tsh 1,775, respectively, per household per month.

#### 9.1.2 Cost Collection

There are many options for the practical management of users' payments. Collection methods depend on local circumstances and the type of water supply facilities. Modes of payment can be categorized into: (i) payment per bucket at water point; (ii) payment per month per household; (iii) annual or semi-annual payments per household. For both piped schemes and hand pump facilities, the modes of payment need to be carefully decided with the timing of cash income in the communities.

The following table illustrates different options for methods of collection/payment and timing of cash income for hand pumps and piped schemes of the priority project.

Table 9.1-1: Suggested Water Fee for the Priority Project

Type of facility	No. of villages classified by timing of cash income		Minimum amount for recovery of O&M costs		Suggested water fee		Mode of payment
	all year round	seasonal (e.g. tree crops)	Tsh per month per HH	Tsh per bucket	Tsh per month per HH	Tsh per bucket	
1. Hand pump		32 villages	924	4.4	1,000	5	Monthly, annual or semi-annual
2. Hand pump	3 villages		924	4.4	1,000	5	Payment per bucket or per month
3. Piped scheme		7 villages	1,775 to 2,503	8.4 to 11.9	1,800 to 2,500	10 or 15	Monthly, annual or semi-annual
4. Piped scheme	3 villages		1,019 to 1,887	4.8 to 8.9	1,000 to 2,000	5 or 10	Payment per bucket or per month

### 9.1.3 Collection Structure of Water Fee

Water users organizations such as VWCs, WUGs and WUAs are responsible for the collection of water fees for the recovery of O&M costs. For hand pump facilities, a WUG will be formulated at each water point under the supervision of the relevant VWC. For piped schemes, the existing VWCs will be responsible for the management of the piped schemes at the initial stage of the project implementation. In future, however, it is recommendable that a WUA should be established for each piped scheme for the overall management of the scheme. In the piped schemes, a tap committee will be formulated under the VWC or WUA.




Figure 9.1-1: Suggested Collection Structure of Water Fee for Hand Pump Facility




Figure 9.1-2: Suggested Collection Structure of Water Fee for Piped Scheme

#### 9.1.4 Method of Repairing Facilities

Major repairs for communal water supply facilities, regardless of the type of technology used or type of water supply facility, are currently assisted by the Water Technician of the district water engineer office in response to requests from the community. On the other hand, minor repairs are supposed to be carried out by the water users themselves.

For enabling minor repair works of the water supply facilities by the water users, provision of a technical training program would be needed for the O&M personnel of the VWCs, WUGs or tap committees. Provision of a tool kit for each O&M personnel is also required.

The estimated training cost for technical maintenance for 45 villages will be approximately Tsh 25,456,000 (=USD 21,555).

#### 9.1.5 Method of Spare Parts Delivery and Procurement System

It is recommended that a 'Spare Parts Centre for O&M' be established by using the O&M funds collected from water users organizations such as VWCs and WUGs.

It is suggested that about 5% of the collected water funds shall be saved and contributed for the fund to establish the spare parts centre. The spare parts centre shall be in fact started by using empty containers which are readily available from the district water department; therefore the cost of establishment is only for the spare parts to start with.

It is possible that villagers would make an order for spare parts by phone or letter to the DWEO (district spare parts centre) and they can receive the items by the DWEO sending

them. In delivery, such as Mohamed Trans, private bus company which widely covers the Mwanza and Mara regions can be used as a delivery option. All the WUGs are supposed to open their bank accounts; therefore payment by cheque would be possible for them.

## 9.2 Community Awareness Plan

### 9.2.1 Objectives

The community awareness plan can be categorized into two components, i.e. 1) capacity development for water supply facility management; and 2) awareness raising on use of safe water and sanitary/hygiene practices.

The objectives of the former component are to: (i) strengthen O&M capacity at district and community levels; (ii) strengthen the sense of ownership by community for water supply facility; (iii) operate and maintain water supply facility appropriately; and (iv) increase villagers' access to safe water.

The objectives of the latter component are to: (i) raise awareness on importance and benefit of using safe water at community; (ii) increase use of safe water from water supply facility; (iii) collect water fee as designed and planned; (iv) improve hygiene and sanitary practices among villagers; (v) decrease incidence of water-borne diseases; and (v) improve health standard among villagers.

### 9.2.2 Outputs of Community Awareness Plan

Direct outputs to be produced through implementation of the Community Awareness Plan are summarized in the following table.

Table 9.2-1: Direct Outputs to Be Achieved

Components	Outputs
Capacity Development for Water Supply Facility Management	<ul style="list-style-type: none"> <li>• VWC, WUA and WUG, are organized and activated</li> <li>• Their articles and by- laws are defined</li> <li>• Demarcation of roles/tasks among all the stakeholders are identified and fulfilled (VWC, WUG, WUA, DWST, RWST)</li> <li>• Daily check-up, maintenance and repair of water supply facility shall be implemented in appropriate manner</li> <li>• Fee collection, financial record keeping and cash management shall be implemented by Water Committees in appropriate and timely manners</li> <li>• Procurement of necessary fuels and spare parts shall be implemented in appropriate and timely manners</li> </ul>
Awareness Raising on Use of Safe Water and Sanitary/Hygiene Practices	<ul style="list-style-type: none"> <li>• Use of safe water among villagers is increased, so as to villager using unprotected water is decreased.</li> <li>• User of water supply facility is increased.</li> <li>• Water fee is collected as planned.</li> <li>• Knowledge of hygiene/sanitation is increased among villagers.</li> </ul>

### 9.2.3 Capacity Development at Community Level

Capacity development for water supply facility management will include: (i) establishment of village water facility organization (before construction), (ii) general guidance (before construction); (iii) financial management training (during construction); (iv) O&M technical training for hand pump (after construction); and (v) O&M technical training on the piped

scheme facilities (after construction). General technical guidance will be conducted for the water users in general. Financial management training will be conducted for the leaders of the water supply organizations such as secretaries and treasurers. Technical training on the O&M activities will mainly be conducted for the technical personnel (e.g. pump attendants) in the water supply organizations.

### 9.2.4 Awareness Raising on Use of Safe Water and Sanitary/Hygiene Practices

Major activities of this component are:

- Delivery of information and training on the benefits of safe water, appropriate water use and hygiene/sanitary practices
- The benefits of new water supply facility shall be acknowledged by villagers through organizing training.
- Awareness creation of the importance of the O&M activities for water supply facility management in order to sustain the benefits of the water supply facility, use of safe water and hygiene/sanitary practice

### 9.2.5 Suggested Trainings

Suggested training items for the two components are summarized in the following table.

Table 9.2-2: Needs for Training and Target of the Training at Village Level

Types of Training		Target	Required Duration	Training Content	Responsible Bodies for Capacity Development/Training	
Management	1) WWC	a Village Assembly	0.5 Day	● General guidance	DWST	●... Community Development Dep. □... Water Dep.
		b WWC members	2 Days	● Community Mobilization intra-village □ Finance		
	2) WUG for hand pump	a WUG Assembly	0.5 Day	● General guidance		
		b WUG Committee (12)	3 Days	● Community Mobilization □ Finance		
	3) WUA for piped scheme	a WUA Assembly	0.5 Day	● General guidance		
		b WUA Committee (12)	3 Days	● Community Mobilization intra-village & inter-villages □ Finance		
Technical Repair & Maintenance	1) Boreholes with Hand Pump	a WUG Committee(All)+WWC	1 Day	General technical guidance □ O&M of borehole with hand pump	□... Water Dep.	
		b WUG Committee (Technical sub-committee)(4)	3 Days	O&M of borehole with hand pump		
	2) WUA for Piped Scheme	a WUA Committee(All)+WWC	1 Day	General technical guidance □ O&M of piped scheme		
		b WUA Committee (Technical sub-committee)(4)	3 Days	O&M of piped scheme		
PHAST	1) Environmental Health	a Village Assembly	0.5 Day	● General guidance	◎... Health Dep. ●... Community Development Dep. □... Water Dep.	
		b WWC, Village Government, WUG and WUA committee (9+12)	3 Days	◎ PHAST workshop ● PHAST workshop □		

### **9.2.6 Manuals for Community Awareness**

Based on the existing manuals, revised manuals shall be prepared for the respective training needs. However, there are no guidelines and manuals for WUA formulation and technical maintenance for piped scheme water facilities. Therefore it is necessary to make them newly for mobilizing community and sustain the piped scheme facility to ensure sustainability of the piped scheme facility and community based management group for the piped scheme facility.



# Chapter 10

---

---

*Evaluation of Priority Project*

## **10 Evaluation of Priority Project**

### **10.1 General**

The priority project is evaluated based on the economical conditions, financial aspects, organization /institutional situations, natural/social conditions, and technical aspects of Tanzania.

### **10.2 Economic Evaluation**

#### **10.2.1 Benefit Cost Analysis**

The viability of the priority project has been evaluated in terms of the benefit cost analysis on the basis of the economic costs and benefits.

##### **a. Basic Assumptions**

Basic assumptions used for the benefit cost analysis include: (i) the official exchange rate as of May 2006, i.e. US\$ 1.00 = Tsh 1,181 = 114.58 Yen; (ii) project life of 20 years; (iii) inclusion of only direct and tangible benefits; (iv) opportunity cost of capital at 10 %; and (v) exclusion of transfer payments such as interest and taxes.

##### **b. Economic Project Cost**

The Economic Project costs include the investment costs and recurrent costs. The investment costs comprise the costs for the construction of water supply facilities and engineering services. Recurrent costs consist of annual operation, maintenance and replacement costs for the equipment and other facilities. Taxes and price contingency are not included in the economic costs.

##### **c. Economic Benefits**

Out of several economic benefits of the Project, only saved time benefits for water fetching and health improvement benefits have been included in the calculation of economic benefits.

##### **c.1 Saved Time Benefits of Water Fetching**

The average time spent for water fetching under the “without the Project” situation is 3.7 hours per household per day, while the same under the “with the Project” situation is estimated at 2.1 hours per day. The saved time between “with” and “without” the Project is equivalent to Tsh 73,000 (USD 61.80) per household per year in terms of economic labor cost. The save time value is multiplied by the total number of beneficiary households to obtain the annual benefits of the saved time.

##### **c.2 Health Improvement Benefits**

The health improvement benefits are derived as a result of improvement in water quality and increased supply of water. The benefits can be measured from the difference of medical expenses between “with” and “without” installation of improved water supply systems. It is estimated that the provision of a clean water supply will lead to 20% reduction in medical expenses every year in the target communities. The saved amount of medical expenses is estimated at Tsh 42,598 (USD 36.07) per household per year.

#### **10.2.2 Result of Economic Evaluation**

Three economic indicators have been calculated as a result of the benefit cost analysis, i.e.

Economic Internal Rate of Return (EIRR) – 10.5 %; Net Present Value (NPV) - USD 467,416 and Benefit Cost Ratio (B/C) - 1.03. These results indicate that the proposed Project is economically feasible as the EIRR exceeds the opportunity of capital, the NPV is positive and the B/C is more than 1.0.

### **10.2.3 Financial Evaluation**

One of the most important issues mentioned in the National Water Policy 2002 is full cost recovery for operation and maintenance by the water users. The beneficiaries in the target communities are expected to organize the water supply organizations to conduct periodical operation and maintenance works and to collect water fees for the recovery of the operation and maintenance expenses. The results of the Socio-economic Survey in 2005 indicated that 41 villages out of the 45 target villages in the Priority Project showed a willingness to pay a water fee of Tsh 10 or more per bucket of 20 liters. The comparison of the expected water fee to be collected from the water users at Tsh 10 per bucket and the amount of operation, maintenance and replacement (OMR) costs required each year has indicated that the former exceeds the latter every year. The computation also indicates that even if the water fee recovery rate will be 55 %, the collected water fee will be sufficient to cover the annual OMR costs. It is concluded that the proposed Project is financially feasible in terms of recovery of OMR costs.

### **10.3 Organization /Institutional Evaluation**

For conducting the priority projects effectively and sustaining the facilities, the organizational and institutional plan has been proposed. The plan includes: (i) institutional arrangement and relations of responsible bodies according to each type of technologies applied to the priority projects, (ii) organizational arrangement of the Water User Group (WUG), the Water User Association (WUA), and the Village Water Committee (VWC) as responsible bodies of operation and maintenance at community level, (iii) trainings for the district water department on managerial and technical capacity, (iv) establishment of regional coordination body to support community based facility management.

It is expected that the roles and responsibilities of the stakeholders at regional, district and communal levels will be clarified, leading to a well established organizational network for effective and sustainable management of the improved water supply systems in the target communities. The proposed plan is therefore adequate in terms of attainment of the national water policy objectives.

### **10.4 Natural /Social Environment Evaluation**

Based on the application submitted to NEMC, it was concluded that the applied project would not have any major adverse impact on targeted areas and the study team was not required to conduct any further EIA study. NEMC, however, requested the study team to prepare a checklist of social and environmental criteria concerning the listed environmental factors.

It is required by NEMC that close monitoring of ambient environmental conditions in the project area be securely conducted regularly with the focus on environmental items by implementing agent / organization and findings be reflected on the revision of the implementation plan to be more technically and environmentally sound.

The water supply plan for the priority project will contribute, in all aspects, to the improvement of the water situation by implementation of the proposed activities.

## **10.5 Technical Aspects**

The proposed water supply facilities in this priority project consist of boreholes with hand pumps and piped schemes using ground water, and lake water. Technical appropriateness is essential when considering not only the “hard components” but also the “soft components”. Namely, technical appropriateness was evaluated by components such as construction, operation & maintenance, and material procurement. For building both boreholes with hand pumps and piped schemes, there are no special issues such as construction, etc., because such systems, with the exception of filtration facilities, have already been used in the target area. However regarding piped scheme, it is necessary to conduct the technical support for the operation and maintenance of facility.

# Chapter 11

---

---

*Conclusion and Recommendation*

## 11 Conclusion and Recommendation

### 11.1 Conclusion

- (1) The 2002 population census indicated that the biggest region by population size was Mwanza with a population of about 3 million including 712 villages, Mara was ranked 13th among the 21 regions in the country with a population of about 1.4 million including 414 villages.
- (2) Economic activities were mainly conducted in the agricultural sector including crop farming, livestock, forestry and fishery and the GDP of Mwanza region ranks in the top 5 in Tanzania (2003, Mara ranks 12th).
- (3) The water sources to be used for water supply consist of groundwater with medium and deep wells, lake water from Lake Victoria, and springs from three points of view, for example 1) Sustainability for water use, 2) Availability throughout the year and 3) Safety of water quality. The water quality is safe in general; however lake water shall be simply treated and filtered for potable purposes.
- (4) The water supply plan was formulated for the 428 villages and 57 existing piped schemes were selected from the requesting villages and the existing piped schemes in accordance with the selection criteria. The spring protection, medium and deep wells with hand pumps, and new and existing piped schemes were planned as scheme types.
- (5) The total number of the medium and deep wells with hand pumps including two springs is 1,869 wells of which the served population will be 581,100 people with 247 villages in 2025.
- (6) In regard to the piped scheme, a total of 64 newly installed piped schemes are planned in 98 villages, and a total of 57 expanded and rehabilitated piped schemes will be installed in 270 villages. The served population by piped schemes will be 1,265,900 in total in 2025.
- (7) In regard to the target year of the Tanzanian side for the water supply plan, the increase of the coverage of water supply has three time-specific goals: 65% coverage by 2010, 74% coverage by 2015, and 90% coverage by 2025 (NRWSSP, 2006). The initial plan was formulated for the water supply plan with 2015 as the year of completion. However, it is impossible to complete the implementation of the water supply plan by 2015 due to the high expenses for the implementation of the initial plan within the planned time frame (2015). Therefore progressive payment is needed of the necessary funds into the payment schedule until 2025. If the water supply plan is implemented completely, it will improve the served ratio for water supply which will contribute to the target strategy of Tanzanian side in 2025.
- (8) Out of 428 villages and 57 existing piped schemes, 45 villages including 289 wells with hand pumps and 8 piped schemes were selected for the priority project which is assumed to be implemented by the Japanese Grant Aid project. The total cost for priority project is estimated at approximately USD17.6 million including the engineering expenses..
- (9) Financial resources for the project costs of the water supply plan shall be derived from not only the government budget, but financial assistance from foreign countries and/or international lending institutions. According to the assistance of donor and the Investment Requirement Plan on NRWSSP 2006, it is probably possible to be realized with the annual disbursement schedule of the project costs. In any event, the final

completed year of water supply plan is the year of 2025.

- (10) The frameworks of organization/institutional conditions in each facility were clarified and the O&M plan was formulated by the clarification of the role of each institutional level, such as region, district, and community, in particular, VWC, WUA, and WUG.
- (11) The water fee, composing of the operation and maintenance cost and replacement cost, was calculated for piped schemes facilities, which were equivalent to about 1.5% of the project cost. An economic evaluation was carried out based on this idea, and the NPV was positive and the B/C exceeds 1.0. Therefore, the priority project is economically feasible.
- (12) The water fee to be collected within the range of the willingness to pay and the affordability in the villages exceeds the recovering of O&M and replacement costs in priority project villages. Thus the priority project is financially feasible
- (13) Based on the application submitted to NEMC, it was concluded that the applied project would not have any major adverse impact on targeted areas and the study team was not required to conduct any further EIA study. In any case the water supply plan for the priority project will contribute, in all aspects, to the improvement of the water supply condition by implementation of the proposed follow-up activities.

## 11.2 Recommendation

### (1) Institutional Development and Supervising Structure

In the implementation of rural water supply works, among the Local Government Authorities (LGAs) , the District Council (DC) in particular will have an important role in the provision of technical support to villages. The NRWSSP strongly urges the establishment of a District Water Supply and Sanitation Team (DWST) as a subordinate organ of the DC, and the establishment of such teams will be a key institutional issue. The DWST will serve as the direct contact with villages and play an important role in community development, education, health (hygiene), rural planning and rural water supply, and its establishment will put in place a supervising structure for villages. Among the members of the DWST, the District Water Engineer (DWE) will play a leading technical role in terms of water supply and management of water supply works. The DWE should also play a central role in strengthening the link with village communities through coordinating with education and hygiene officers within the DWST and establishing a comprehensive system for the operation and maintenance of rural water supply works. Here, therefore, the recommendation for institutional structure is indicated that the DWE should be strengthened through injecting manpower into the DWE. Also, it is important that the DWST has power through legal, institutional and budgetary support.

### (2) Establishment of Basic System for Water Resources Management

The National Water Policy (2002) mentions data and information as one of the policy issues of water resources management. For an effective integrated Water Resources Management System, accurate and timely information on water volume, water quality and water resource use must be provided. To achieve the goals of the water supply coverage, formation of a Water Supply Plan is essential. However, if accurate information on the critical issue of water supply coverage cannot be obtained, the formation of a plan is unlikely. Therefore, it is recommended that the well inventory information, etc. of each village be managed on a database, with new data updated one by one as it is obtained. LGAs do not have the capacity

to input the information onto a computer quickly enough under the present system. Therefore, initially a system for preparing handwritten documents should be established in the DWE's Office, etc. That data should then be periodically collected and input into a database by computer in the DWE gradually. The input data should be stored in files at the MoW. The files should be updated every half year or annually. The first step to implement this should be the creation of a Database Management Team in the MoW. In any case, a conscious effort needs to be made to strengthen organization at the central level.

### (3) For Formation of Yearly Plan for Water Supply

Implementation of the goal to achieve a water supply coverage of 90% by 2025 in rural area is to be begin soon. The district level will play a leading role in implementation. The role of the DWE is particularly important and it is necessary to raise the level of DWE personnel. In the implementation of the water supply plan, it is necessary for the DWE to obtain technical support from the Water Engineer of RAS. Guidance at the central level and the securing of personnel capable of providing guidance is also strongly recommended. Fundamental tasks also need to be implemented. In the implementation of water supply plans, such fundamental works will be necessary. Although the formation of programs and strategies is important, measures to implement such programs and strategies also need to be examined. The DWE' role here is also vital. It is not too much to say that the securing of DWE personnel will determine the feasibility of the water supply plans. Therefore, DWE personnel should be immediately secured.

### (4) At the Time of Water Supply Plan Implementation

The Initial Plan was formulated for the Water Supply Plan as the final completed year of 2015. However, it was found that expenses to complete the Initial Plan were too high referring to the expected internal and external budget plan mentioned in the NRWSSP in 2006. Therefore, the Team suggests the implementation schedule of the Water Supply Plan to achieve the final year of 2025 in accordance with the annual disbursement for the project cost in the Mwanza and Mara regions. However, the following alternative items will be considered and suggested in consideration with the condition of Tanzanian side.

- 1) Increase the budget by double or 2.5 times the size for the two regions from 2007 to 2015, so that the achievement of the coverage rate in 2015 shall be about 68% (428 villages).
- 2) Start with the water supply plan, and review the achievement of the coverage rate in 2015 and implementation schedule. Take necessary measures by the NRWSSP and make necessary discussions (amendment) to achieve the National Millennium Target.
- 3) After formulating the Water Supply Plan, the study team investigated three water supply concepts. The three concepts are (1) Sustainability for water use, (2) Availability throughout the year, and (3) Safety of water quality. These concepts conform to Tanzania's National Water Policy. However, in practice, the Tanzanian side is also in support of the protected shallow well and Charcos Dam which, from the previously mentioned concepts, is discouraged as water sources by the Japanese side. These water sources will not be used in this Water Supply Plan, however the Tanzanian side is not prohibited from using these sources in addition to the potential sources in this plan.