

M31.2 Opa Water Supply Scheme

M31.2.1 Observations for Water Treatment Plant

The Opa facility has been augmented over the years and currently consists of 4 river intakes (one for each self contained WTP). The original site contains Plant I, 8MLD commissioned in 1957 and Plant II, 12 MLD commissioned in 1967. Plant III, 52MLD commissioned in 1972 (later increased to 72 MLD by adding an extra filter bed) and Plant IV, 40 MLD commissioned in 2004 are both sited at Curti, approximately 2.0 km away.

Table M31.2.1 lists the summary of asset data for the WTP and Table M31.2.2 contains detailed asset data for the WTP. The plant schematic is shown on Figure M31.2.1.

Both compounds, Opa and Curti, are adequately gated, fenced and secured by 24 hour on-site security personnel. All plants are operated and maintained 24 hours a day, using a three shift system.

Except for the newest plant, flow measurement devices are not installed. Therefore, the amount of raw water supplied to the plants and the clean water fed to reservoirs was estimated based on pump design capacities and hours of operation.

The original compound has a process control laboratory for the 8 MLD and 12 MLD plants. These plants are manually controlled. Considering the respective ages of the plants, most of the equipment appears to be in good working order, except for the alum and lime mixers. These mixers appear to be in poor order or out of service. Both plants have good maintenance standards.

Disinfection is achieved using gas chlorination. The chlorination is delivered using one tonne cylinders. Maintenance, installation standards and operation practices for chlorine use are poor. There are no facilities for adequately detecting or containing gas leaks. Personal breathing apparatus is available in the laboratory but is not used or maintained. Records of chemical usage and treatment parameters are logged by the laboratory staff.

Records of pump running hours, load, filter backwashing and clear water reservoir levels are logged. However records of repairs and maintenance/breakdown problems are not logged. The high speed pump couplings/shafts are not guarded.

The 40 MLD plant has its own process control laboratory. Records of the chemical usage and treatment parameters are logged by the laboratory staff. “M/S Environ Control Associates Private Ltd – Surat” built, operated and maintained the plant for 18 months before handing it over to the PHE⁶. A basic operation and maintenance manual was provided to the PHE at this time outlining basic operating, maintenance and H&S instructions. On the job training was provided by the contractors during the operation and maintenance period.

The plant appears to be in good working order and maintenance standards are good. The plant is manually operated but electrical valve actuators are in use. It is understood that a proposal to install a SCADA system has been prepared.

Records of pump running hours, load, filter backwashing and clear water reservoir levels are logged. However records of maintenance, repairs and maintenance/breakdown problems are not maintained.

Disinfection is achieved using gas chlorination. The chlorination is delivered using three, one tonne cylinders. Maintenance, installation standards and operation practices for chlorine use are poor. There are no facilities to adequately detect or contain gas leaks. Personal breathing apparatus is available in the laboratory but is not used or maintained.

The 52 MLD plant has its own process control laboratory. Records are logged by the laboratory staff for chemical usage and treatment parameters. Records are kept for pump running hours, load, filter backwashing and clear water reservoir levels. However records of maintenance, repairs and breakdown problems are not maintained.

An Electro-chlorination system is used for disinfection. This appears to be in good working order and maintenance standards are generally good (except for the chlorination room). Gas chlorination using one tonne cylinders is available for back-up purposes but appears to be in relatively poor condition. There are no facilities to detect or contain leaks.

Tables M31.2.3 and M31.2.4 and Figure M31.2.2 show the flow rate data for Opa/Curti Treatment Plants. Table M31.2.5 and Figure M31.2.3 show the data on monthly water quality at Curti Water Treatment Plant. Table M31.2.6 shows records on power outages at Opa Water Treatment Plant.

Table M31.2.1

Summary of Asset Register of Opa Water Treatment Plant (1/2)

Name of Facility		8 MLD (1.76 MGD)		12 MLD (2.5 MGD)		Remarks
		Contents of Facility		Contents of Facility		Remarks
Raw Water Intake & Raw Water Transmission Facility	Intake Well & Connecting Pipe	D400mm × 1 Line, D300mm × 1 Line		D400mm × 1 Line,		Khandepar River
	Pump & Motor	Horizontal Centrifugal Pump: 9334m ³ /hr × 1160m × 215kw × 3 units (1 or 2 – Standby)		Horizontal Centrifugal Pump: 9552m ³ /hr × 1168m × 450kw × 3 units (1 or 2 – Standby)		Design Cap. of Intake Pump = 13.2~26.5MLD
Treatment Facility	Raw Water Transmission Main	D350mm × 55m × C.I.P. × 1 Line		D450mm × 45m × C.I.P. × 1 Line		
	Aerator	Not Provided		Cascade Type: 1 unit		
Clariflocculator	Flash Mixer & Weir	Not Provided		1 unit (for Chemical Dosing)		
	Clariflocculator	Circular Horizontal Flow Type with Center Feed/Peripheral Collection		Circular Horizontal Flow Type with Center Feed/Peripheral Collection		1): 2~2.5 hrs 2): 30~40m ³ /m ² /d
	Flocculation & Clarifier	1) 12.5m (Floc. Zone ?)m × w5.00m × 1 unit Detention Period: Flocculation - ?min Clarifier - ? hrs ¹⁾ Overall - 1.75 hrs		Flocculation & Clarifier: 1) 22.73m (Floc. Zone ?)m × w5.00m × 1 unit Detention Period: Flocculation - ?min Clarifier - ? hrs ¹⁾ Overall - 3.86 hrs		
	Filter	Gravity Rapid Sand Filter Type w2.5m × l7.5m × 2cells/basin × 5 basins Effective Size of Sand: 0.71mm, Depth of Sand: ?m Filter Area: 9.4 m ² /cell, 18.8 m ² /basin Filtration Rate: 3.75 m/hr ³⁾ (90 m/d) Air Scouring Rate: ?m/hr/cell ⁴⁾ (? m ³ /min/m ² /cell) Backwash Rate: 38.4 m/hr/cell ⁵⁾ (0.64 m ³ /min/m ² /cell)		Gravity Rapid Sand Filter Type w5.5m × l5.0m × 2cells/basin × 4 basins Effective Size of Sand: 0.71mm, Depth of Sand: ?m Filter Area: 13.75 m ² /cell, 27.5 m ² /basin Filtration Rate: 4.8 m/hr ³⁾ (115 m/d) Air Scouring Rate: ?m/hr/cell ⁴⁾ (? m ³ /min/m ² /cell) Backwash Rate: 33 m/hr/cell ⁵⁾ (0.55 m ³ /min/m ² /cell) - (150m ³ Backwash Tank)		Based on Specifications of Air Blower & Backwash Pump 3): 4.8~6.0m/hr 4): 36~54m/hr 5): 24~36m/hr
Chemical Feeding Facility	Alum Feeding Facility	Dry Aluminum Sulfate Solution Tank: 2 units Using 12 MLD facility		Dry Aluminum Sulfate Solution Tank: 2 units Powder Lime Solution Tank: 5 units		
	Lime Feeding Facility			Liquid Chlorine (1 tone Container – net 900kg) Chlorinator: 1 unit		
Laboratory	Disinfection Facility	Liquid Chlorine (1 tone Container – net 900kg) Chlorinator: 1 unit		Liquid Chlorine (1 tone Container – net 900kg) Chlorinator: 1 unit		
	Frequency of Sampling & Analysis			In-Service, Jar Test: Not in Service Every Hour: pH, Turbidity, R-CI Daily: Turbidity, pH, Alkalinity, Hardness, Chlorine, Mn, Fe, D.O., R-CI		
Clear Water Transmission Facility	Clear Water Sump	Volume=175 m ³ × 1 unit, Retention Time: 0.5 hr		Volume=1,350 m ³ × 1 unit, unit, Retention Time: 2.57 hr		
	Transmitted Pump & Motor	Horizontal Centrifugal Pump: 9334m ³ /hr × 1160m × 215kw × 3 units (1 or 2 – Standby)		Horizontal Centrifugal Pump: 9545m ³ /hr × 1168m × 450kw × 3 units (1 or 2 – Standby)		Design Cap. of Pump = 13~26MLD
	Transmission Line	D350mm × 800m × (C.I.P. + M.S.P.) × 1 Line		D400mm × 1,600m × (C.I.P. & M.S.P.) × 1 Line D500mm × 1,600m × (C.I.P. & M.S.P.) × 1 Line		
Clear Water Reservoir (MBR)				Volume=800 m ³ × 4 units, Total Volume = 3,200 m ³ Retention Time: ? hr		

Note: 1) ~ 4) are referring to "Manual on Water Supply and Treatment, Third Edition – Revised and Updated, May 1999"

Table M31.2.1

Summary of Asset Register of Opa Water Treatment Plant (2/2)

Name of Facility		72 MLD (16 MGD)		40 MLD	
		Contents of Facility		Contents of Facility	
		Remarks		Remarks	
Raw Water Intake & Raw Water Transmission Facility	Intake Well & Connecting Pipe	D450mm × 6 Lines, D450mm × 1 Line	Common for 2 Plants	Jack Well & pump House: Dia. 9.0m	Khandepar River
	Pump & Motor	Horizontal Centrifugal Pump: 864m ³ /hr × 1176m × 550kw × 2 units 648m ³ /hr × 1176m × 550kw × 2 units 648m ³ /hr × 1176m × 475kw × 3 units (2 or 3 – Standby)	Khandepar River	Vertical Pump: 1,250m ³ /hr × 1190.5m × 875kw × 3 units (1 – Standby)	Design Cap. of Intake Pump for 2 Plants = 122 ~148MLD
Treatment Facility	Raw Water Rising Main	D750mm × 1,600m × C.I.P. × 2 Lines		D750mm × 1,900m × C.I.P. × 1 Line	
	Stilling Chamber	Not Provided		3.0m × 3.0m × 3.0m × 1 basin	
	Aerator	Cascade Type: 1 unit		Each 1 unit (for Chemical Dosing)	
	Flash Mixer & Parshall Flume	Each 1 unit (for Chemical Dosing)			
Contact Aeration Tank	Contact Aeration Tank	Not Provided		17.5m × 5.0m × 1 basin	
	Clarifier / Settling tank (Clariflocculator)	Circular Horizontal Flow Type with Center Feed/Peripheral Collection Flocculation & Clarifier: 40.0m (Floc. Zone ?m) × 5.00m × 2 units Detention Period: Flocculation - ?min Clarifier - ? hrs ¹⁾ Overall – 4.0 hrs		Reactor Clarifier Type with Center Feed / Peripheral Collection Flocculation & Clarifier: 30.0m (Floc. Zone 11.0m) × 5.00m × 1 unit Detention Period: Flocculation - 18min Clarifier – 1.9 hrs ¹⁾ Surface Loading: 68.7 m ³ /m ² /d (47.7 mm/min) ²⁾	1): 1~1.5 hrs 2): 40~50m ³ /m ² /d
Filter	Filter	Gravity Rapid Sand Filter Type 12.2m × 7.6m × 2cells/basin × 6 basins: Filter Area=92.7m ² /basin 9.92m × 6.98m × 2cells/basin × 1 basin: Filter Area=69.1m ² /basin 10.88m × 7.6m × 2cells/basin × 1 basin: Filter Area=82.7m ² /basin Effective Size of Sand: 0.71mm, Depth of Sand: ? ?m Filtration Rate: 4.46 m/hr ³⁾ (107 m/d) Air Scouring Rate: ? ?m/hr/cell ⁴⁾ (? ? m ³ /min/m ² /cell) Backwash Rate: ? ? m/hr/cell ⁵⁾ (0.?? m ³ /min/m ² /cell)		Gravity Rapid Sand Filter Type 4.5m × 9.5m × 2cells/basin × 4 basins Effective Size of Sand: 0.71mm, Depth of Sand: ? ?m Filter Area: 21.4 m ² /cell, 42.8 m ² /basin Filtration Rate: 10.2 m/hr ³⁾ (245 m/d) Air Scouring Rate: ? ?m/hr/cell ⁴⁾ (? ? m ³ /min/m ² /cell) Backwash Rate: 34.8 m/hr/cell ⁵⁾ (0.58 m ³ /min/m ² /cell) - (600m ³ Backwash Tank)	Based on Specifications of Air Blower & Backwash Pump 3): Higher than Standard(4.8~6.0m/hr) 4): 36~54m/hr 5): 24~36m/hr
	Dirty Water Sump	Not Provided		13.0m × 1.5m × 1 basin, Volume:199 m ³	
Chemical Feeding Facility	Alum Feeding Facility	Dry Aluminum Sulfate Solution Tank: 3 units		Dry Aluminum Sulfate Solution Tank: 3 units	
	Lime Feeding Facility	Powder Lime Solution Tank: 2 units		Powder Lime Solution Tank: 3 units	
Laboratory	Disinfection Facility	Liquid Chlorine (1 tone Container – net 900kg) Chlorinator: 1 unit		Liquid Chlorine (1 tone Container – net 900kg) Chlorinator: 1 unit	
	Frequency of Sampling & Analysis	In-Service, Jar Test: Not in Service Every Hour: pH, Turbidity, R-CI Daily: Turbidity, pH, Alkalinity, Hardness, Chlorine, Mn, Fe, D.O., R-Cl		In-Service, Jar Test: Not in Service Every Hour: pH, Turbidity, R-CI Daily: Turbidity, pH, Alkalinity, Hardness, Chlorine, Mn, Fe, D.O., R-Cl	
Clear Water	Clear Water Reservoir	Volume= 3,030 m ³ × 3 units,		Volume= 5,000 m ³ × 2 units,	




Figure M31.2.1 Schematic Sequence of Opa Water Treatment Plant

Table M31.2.2

Present Conditions of Opa Water Treatment Plant (1/8)

Item		Contents											
Background													
Covered Area for Water Supply		Tahlikha											
Name of Plant		Ponda & Part of Tiswadi (Panaji)											
Number & Name of W.T.P.		Opa W.T.P.				Curti W.T.P.				Total			
Capacity of Plant		(1) : 8 MLD	Remark	(2) : 12 MLD	Remark	(3) : 72 MLD	Remark	(4) : 40 MLD	Remark				
		1.76	Imperial	2.5	Imperial	16	Imperial						
		8.00	Gallon=4,546	11.37	Gallon=4,546	72.74	Gallon=4,546						
		8	Nominal	12	Nominal	72	Assigned from 55 MLD to 72 MLD	40	Nominal				
Raw Water Resources		8,000	River	12,000	River	72,000	Khandepar	40,000	Khandepar				
Year of Construction		1987		1967		1972		2002-03					
Year of Commission								2004					
Name of Facility													
Design Capacity of Raw Water Intake & Treatment Facility		Opa W.T.P.				Curti W.T.P.				Total			
		(1) : 8 MLD	Remark	(2) : 12 MLD	Remark	(3) : 72 MLD	Remark	(4) : 40 MLD	Remark				
		8.40	: 5% Loss	12.60	: 5% Loss	75.60	: 5% Loss	42.00	: 5% Loss				
		8,400		12,600		75,600		42,000					
Head Water Works : Raw Water Intake													
Intake Well / Jack Well & Pump House		Intake Well				Intake Well				Intake Well & Jack Well			
Diameter													
Width		4.50				6.0				9.0			
Length		2.00				2.0				4.0			
H.W.L. : Design		2.42				2.42				2.42			
L.W.L. : Design		400				400				450			
Connecting Pipe		1				1				2			
Number of Line		1				1				2			
Length													
Material													
Raw Water Pump										Jack Well			
Capacity		92.8				153.3				180			
		5,566.7				9,200				10,800			
		5.57				9.20				10.80			
		334.0				552.0				648.0			
		8,016				13,248				15,552			
Number		2				1				2			
Stand-by		2				2				3			
Total Capacity		8,000				13,200				60,000			
Head		22.0				27.5				176.0			
Type of Pump		Centrifugal				Centrifugal				Vertical			
Maker		KSB				M & P				KBL			
Year of Manufacture		1985				1992				1972			
Assessment of Condition		Working / Required Replacement				Working / Required Replacement				Working			
Motor Output		50				101				738			
Number		37				75				550			
Maker		CG				Jyoti				KEL			
Year of Manufacture		1985				1994				1972			
Assessment of Condition		Working / Required Replacement				Working / Required Replacement				Retrofitted			
										①②③④⑤⑥⑦⑧⑨⑩⑪⑫⑬⑭⑮⑯⑰⑱⑲⑳㉑㉒㉓㉔㉕㉖㉗㉘㉙㉚㉛㉜㉝㉞㉟㊱㊲㊳㊴㊵㊶㊷㊸㊹㊺㊻㊼㊽㊾㊿			

Table M31.2.2

Present Conditions of Opa Water Treatment Plant (2/8)

Name of Facility		Contents of Facility														
		Opa W.T.P.						Curfi W.T.P.								
		(1) : 8 MLD	Remark	(2) : 12MLD	Remark	(3) : 72MLD	Remark	(4) : 40MLD	Remark	Total						
Raw Water Transmission Line to Aerator	Diameter	350		450		750	750	750		750		750				
	Length	55		45		1,600	1,600	1,600		1,900		1,900		Raw Water Rising Main		
	Material	CIP		CIP		CIP	CIP	CIP		CIP		CIP		Raw Water Rising Main		
	Velocity															
	Head Loss															
Assessment of Condition	Pipe	Working		Working		Working	Working	Working		Working		Working				
	Valve	Need Replacement		Leakage through Gland		Leakage through Gland, NRB&SIV to be Replaced	Leakage through Gland	Leakage through Gland, NRB&SIV to be Replaced		Working		Working				
Water Treatment Plant																
Stilling Chamber	Design Capacity	m ³ /min/unit	-	-	-	-	-	-	-	-	-	-	-	-	29.17	
		m ³ /hr/unit	-	-	-	-	-	-	-	-	-	-	-	-	1,750	
	Number	m ³ /d/unit	-	-	-	-	-	-	-	-	-	-	-	-	42,000	
		Unit	-	-	-	-	-	-	-	-	-	-	-	-	1	
	Width	m	-	-	-	-	-	-	-	-	-	-	-	-	3.00	
		m	-	-	-	-	-	-	-	-	-	-	-	-	3.00	
	Water Depth	m	-	-	-	-	-	-	-	-	-	-	-	-	3.10	
		m ³	-	-	-	-	-	-	-	-	-	-	-	-	27.9	
	Retention Time	min	-	-	-	-	-	-	-	-	-	-	-	-	0.96	
		m	-	-	-	-	-	-	-	-	-	-	-	-	175.6	
Assessment of Condition	m ³ /hr	-	-	-	-	-	-	-	-	-	-	-	-	Working		
	m ³ /d	-	-	525.0	-	-	-	-	-	Not Provided	-	-	-	1,750.0		
Aerator	Capacity	m	-	-	-	-	-	-	-	-	-	-	-	-	-	
		m ³ /d	-	-	12,600	-	-	-	-	-	-	-	-	-	42,000	
	Number	Unit	-	-	5.0	-	-	-	-	-	-	-	-	-	8.0	
		m	-	-	1	-	-	-	-	-	-	-	-	-	1	
Assessment of Condition	El. of Top Aerator	-	-	Working	-	-	-	-	-	-	-	-	-	175.50		
	Assessment of Condition	-	-	Working	-	-	-	-	-	-	-	-	-	Working		
Parshall Flume/Weir	Assessment of Condition	-	-	Working	-	-	-	-	-	-	-	-	-	Working		
	Assessment of Condition	-	-	Working	-	-	-	-	-	-	-	-	-	Working		
Contact Aeration Tank	Design Capacity	m ³ /min/unit	-	-	-	-	-	-	-	-	-	-	-	-	29.2	
		m ³ /hr/unit	-	-	-	-	-	-	-	-	-	-	-	-	1,750	
	Number	m ³ /d/unit	-	-	-	-	-	-	-	-	-	-	-	-	42,000	
		Unit	-	-	-	-	-	-	-	-	-	-	-	-	1	
	Diameter	m	-	-	-	-	-	-	-	-	-	-	-	-	17.50	
		m	-	-	-	-	-	-	-	-	-	-	-	-	5.00	
	Retention Time	m ³	-	-	-	-	-	-	-	-	-	-	-	-	1,202.6	
min		-	-	-	-	-	-	-	-	-	-	-	-	41.2		
Assessment of Condition	Water Level	-	-	-	-	-	-	-	-	-	-	-	-	173.50		
	Assessment of Condition	-	-	-	-	-	-	-	-	-	-	-	-	Working		
Flash Mixer	Assessment of Condition	-	-	Working	-	-	-	-	-	-	-	-	-	Working		
	Assessment of Condition	-	-	Working	-	-	-	-	-	-	-	-	-	Working		

Table M31.2.2

Present Conditions of Opa Water Treatment Plant (3/8)

Name of Facility	Contents of Facility						Total
	Opa W.T.P.			Curti W.T.P.			
	(1) :8 MLD	Remark (2) : 12MLD	Remark	(3) : 72MLD	Remark (4) : 40MLD	Remark	
Clarifiers / Settling Tank (Coagulation Basin)	Design Capacity	m ³ /min/unit	5.8	8.8	26.3	29.2	
		m ³ /hr/unit	350.0	525.0	1,575.0	1,750.0	
		m ³ /d/unit	8,400	12,600	37,800	42,000	
	Number	Unit	1	1	2	1	
	Type of Clarifier		Circular Horizontal Flow Type with Center Feed/Peripheral Collection				
	Overall Diameter	m	12.50	22.73	40.00	30.00	Reactor Clarifier Type with Center Feed/Peripheral Collection
	Floccul. Zone Dia.	m				11.00	
	Water Depth	m	5.00	5.00	5.00	5.50	
	Frequency of Desludging		Using for By-pass General Season : Once a Day Monsoon Season: Twice a Day				
	Volume						General Season : Once a Day Monsoon Season: Twice a Day
Flocculator	Overall	m ³ /unit	613.6	2,028.9	6,283.2	3,887.7	
	Floccul. Zone	m ³ /unit	0.0	0.0	0.0	522.7	
	Clarifying Zone	m ³ /unit	613.6	2,028.9	6,283.2	3,365.0	
	Retention Time						
	Overall	hr	1.8	3.9	4.0	2.2	
	Floccul. Zone	hr	0.00	0.00	0.00	0.30	
	Clarifying Zone	hr	1.75	3.86	3.99	1.92	
	Surface Area	m ² /unit	122.7	405.8	1,256.6	611.8	
	Surface Loading	mm/min	47.5	21.6	20.9	47.7	
	W.L. of Clarifier	m				173.20	Working
Drive Arrangement	Assessment of Condition		Required Overhauling / Replacement Working				
	Number	unit					Working
	Assessment of Condition		Required Overhauling / Replacement Working				
	Number	unit					Working
	Assessment of Condition		Required Overhauling / Replacement Working				
	Number	unit					Working
	Assessment of Condition		Required Overhauling / Replacement Working				
	Number	unit	5	4	6	1	4
	Type of Filter		Rapid Sand Filter				
	Filter	Design Capacity	m ³ /hr/unit	70.0	131.3		437.5
		m ³ /d/unit	1,680	3,150		10,500	
Width		m	7.50	5.50	12.20	9.90	10.88
Length		m	2.50	5.00	7.60	6.98	7.60
Filtered Area		m ² /unit	18.8	27.5	92.7	69.1	82.7
Velocity		m ³ /d/m ²	89.6	114.5	106.8	106.8	708.1
Filter Media			OK				
E.S. of Sand		mm	Standard Size : 0.71mm				
Depth of Sand		mm	Standard Size : 0.71mm				
Type of Underdrain			Plastic Nozzle				
Year Replacement of Media	Year Replacement of Media		Plastic Nozzle				
			30mm Partial Replacement in '97-'98				
			Upper Media Layer Topped up in '01				
W.L. of Filter	m					172.40	
Assessment of Condition		Working					

Table M31.2.2

Present Conditions of Opa Water Treatment Plant (4/8)

Name of Facility		Contents of Facility						Total	
		Opa W.T.P.			Curti W.T.P.				
		(1) : 8 MLD	Remark (2) : 12MLD	Remark	(3) : 72MLD	Remark (4) : 40MLD	Remark		
Filter Washing	Air Scouring Rate	m ³ /min/m ²							
	Air Scouring Time	min	5	Act.: 3	5		5	Act.: 3	
	Backwash Rate	m ³ /min/m ²	0.64	OK	0.55	OK	0.58	250m ³ /time	OK
	Back Wash Drain	m ³ /Unit	93.8	0.5m ³ /min/m ²	137.5	0.5m ³ /min/m ²	442.6	213.8	0.5m ³ /min/m ²
	Backwashing Time	min	10	Act.: 4	10		10		Act.: 7
	Frequency of Washing			General Season : Once a Day	General Season : Once a Day	General Season : Once a Day	General Season : Once a Day	General Season : Once a Day	General Season : Once a Day
Backwash or Lifting Pump & Motor	Capacity	m ³ /min	6.0	Monsoon Season : 1~2 Times a Day	Monsoon Season : 1~2 Times a Day	Monsoon Season : 1~2 Times a Day	Monsoon Season : 1~2 Times a Day	Monsoon Season : 1~2 Times a Day	
		m ³ /hr	360	7.6	Lifting Pump & Motor	0.0	300.0	Lifting Pump & Motor	
	Number	unit	2	456.0	Motor	2	2	Motor	
	Stand-by	unit	1	1	150m ³ Back Wash Water Tank	1	1	600m ³ Back Wash Water Tank	
	Total Capacity	m ³ /min	6.0	7.6		0.0	15.0		
	Head	m	20	20.0		20.0			
Air Blower	Type of Pump			Centrifugal		Centrifugal		Centrifugal	
	Motor Output	HP	20	25.0		50.0		24.8	
		KW	15	18.6		37.3		18.5	
	Assessment of Condition		Working	Working		Working		Working	
Clear Water Sump	Capacity	m ³ /min							
		m ³ /hr				900			
	Number	unit	3			2		2	
	Stand-by	unit	2			1		1	
	Total Capacity	m ³ /min							
	Head	m							
Clear Water Sump	Motor Output	HP	20			20			
		KW	15					30	
	Assessment of Condition								
	Width	m	15.00		27.5				
	Length	m	6.00		18.0				
	Water Depth	m	1.94		2.73				
	Number	Unit	1		1				
	Volume	m ³	175		1,350				
	Last Date of Cleaning				Pediodical				
	Total	m ³	175		1,350				
Detention Time	hr	0.50		2.57					
Assessment of Condition		Working		Need Plastering					

Table M31.2.2

Present Conditions of Opa Water Treatment Plant (5/8)

Name of Facility	Contents of Facility						Total		
	Opa W.T.P.			Curti W.T.P.					
	(1) :8 MLD	Remark	(2) : 12MLD	Remark	(3) : 72MLD	(4) : 40MLD		Remark	
Transmitted (Clear Water) Pump	Capacity	93	151.4	-	-	-	-	-	
	Ø/sec	-	-	-	-	-	-	-	
	m ³ /min	5.57	9.08	-	-	-	-	-	
	m ³ /hr	334.0	545.0	-	-	-	-	-	
	m ³ /d	8,016	13,080	-	-	-	-	-	
	Number	3	3	-	-	-	-	-	
	Stand-by	2	2	-	-	-	-	-	
	Total Capacity	8,000	13,000	-	-	-	-	-	
	Head	160.0	168.0	-	-	-	-	-	
	Type of Pump	Centrifugal		-	-	-	-	-	
Maker	KSB	Mather Platt	-	-	-	-	-		
Year of Manufacture	1958	1967	-	-	-	-	-		
Assessment of Condition	Working	Working	-	-	-	-	-		
Motor Output	HP	288	603.45	-	-	-	-		
(Clear Water)	KW	215	450	-	-	-	-		
Motor	Unit	3	3	-	-	-	-		
Maker	Siemens	CG	-	-	-	-	-		
Year of Manufacture		2000	-	-	-	-	-		
Assessment of Condition	Working	Working	Replaced	-	-	-	-		
Transmission Lines	Diameter	350	350	400	500	-	-	-	
	Length	800	800	1,600	1,600	-	-	-	
	Material	CIP	MS	CIP, MS	CIP, MS	-	-	-	
	Velocity	m/sec				-	-	-	
	Head Loss	m				-	-	-	
	Assessment of Condition	Working	Working	MS Line Need Replacement		-	-	-	
	Valve	Working	Working	Non-Return Valve Need Replacement		-	-	-	
	Assessment of Condition	N.A.	-	N.A.	-	N.A.	-	Working	
	Diameter	m		28.0		40.0			
	Water Depth	m		5.0		4.0			
Clear Water Reservoir (MBR)	Number	4	4	3	3	RCC, MBR	2	RCC, MBR	
	Volume	800	800	3,079	3,030	3,030	5,027	5,000	
	Last Date of Cleaning	Periodical				Periodical			
	Total	m ³	3,200			9,236		10,053	10,000
	Detention Time	hr							22,290
	Assessment of Condition	Working	Working	Working		Working		Working	3,86
	Number	Unit	-	-	-	-	-	-	1
	Diameter	m	-	-	-	-	-	-	13.00
	Water Depth	m	-	-	-	-	-	-	1.50
	Volume	m ³ /unit	-	-	-	-	-	-	199.1
Retention Time	min	-	-	-	-	-	-	213.8 Wash Drain	
Water Level	m	-	-	-	-	-	-	168.50	
Assessment of Condition		-	-	-	-	-	-		

Table M31.2.2

Present Conditions of Opa Water Treatment Plant (6/8)

Name of Facility		Contents of Facility					
		Opa W.T.P.			Curti W.T.P.		
		(1) : 8 MLD	Remark (2) : 12MLD	Remark (3) : 72MLD	Remark (4) : 40MLD	Remark	Total
Chemical Facility							
Alum Feeding Facility	kg/hr						
	m ³ /unit						
Diameter	m						
Width	m	3.50	2.5	2.4	2.5		
Length	m	1.70	2.7	2.5	2.5		
Height	m	2.30	2.0	2.3			
Volume	m ³	13.7	13.5	13.8	0.0		
Number	Unit	2	2	3	3		
Stand-by							
Assessment of Condition		Working	Working	Working	Working		
Lime Feeding Facility	kg/hr	-					
	m ³ /unit	-					
Diameter	m			2.4	2.0		
Width	m			2.5	2.0		
Length	m			2.3			
Height	m			13.8			
Volume	m ³			2	3		
Number	Unit						
Stand-by							
Assessment of Condition		Working	Working	Working	Working		
Disinfection System							
Chemical Used		Liquid Chlorine / Bleaching Powder	Liquid Chlorine / Bleaching Powder	Liquid Chlorine / Bleaching Powder	Liquid Chlorine / Bleaching Powder		
Type of Plant & Machinery		Aquatapura Make	Aquatapura Make	Aquatapura Chlorinator	Vacuom Operated		
Capacity	kg/hr	1.0	7.0	6.0	10.0		
Number	Unit	1	1	1	1		
Stand-by							
Safety Measures Taken		Safety Mask/Oxygen Cylinder/Gloves Available	Safety Mask/Oxygen Cylinder/Gloves Available	Safety Mask/Oxygen Cylinder/Gloves Available	Safety Mask/Oxygen Cylinder/Gloves Available		
Commissioned		1997		1999/2003	2,003		
Assessment of Condition		Need Replacement	Need Replacement	Need Replacement	Good		
Substation (Transformers)							
Number of Transformer							
Pole Mounted / Pad Mounted		Pad	Pad	Pad	Pad	Pad	Pad
Capacity	KVA	1,000	3,150	3,150	2,500	350 for Cultri	
Number	Unit	2	1	1	1	1	
Stand-by		1	Nil	Nil	Nil	Nil	
Commissioned		1972	1972	2002	1996		
Likely Design Life	Year			15	15		
Last Replacement							
Assessment of Condition		Overhauled	Working	Good	Working	Working	Working

Table M31.2.2

Present Conditions of Opa Water Treatment Plant (7/8)

Name of Facility	Contents of Facility				Total
	Opa W.T.P.		Curti W.T.P.		
	(1) : 8 MLD	Remark (2) : 12MLD	Remark (3) : 72MLD	Remark (4) : 40MLD	
Laboratory					
Chemical Testing Laboratory		In-service (Exist)		Exist at Curti	
Jar Testing					
Availability of Skilled Chemists	Available	Available	Available	Available	
Availability of Required Chemicals	Available	Available	Available	Available	
Use of Test Reports	As per Format	As per Format	As per Format	As per Format	
Frequency of Sampling	Residual Cl - Hourly & Other Tests Daily	Residual Cl - Hourly & Other Tests Daily	Residual Cl - Hourly, Min Fortnightly & Other Tests Daily	pH, Turb., R-Cl - Hourly, other Tests Alternate Day	
General Quality of Water	Good	Good	Good	Good	
Raw Water Quality	Turbid., Low pH	Turbid., Low pH	Turbid., Low pH	Turbid., Low pH	
Clear Water Quality	Good	Good	Good	Good	
Equipment Status					
Flow Meters	-	No Flow Meter		Ultrasonic	
Other Operating Valves	working	Working		Working	
Other Important Assets					
Valve's Condition	Working	Leakage through Gland		Working	
Visible Leakage and Locations	Filter Valves from Grand	Nil	Leakage through Filter & Drain Valves	Nil	
Building Condition		Good	Good	Good	
Wastewater Disposal Arrangements	Sludge Chamber to River	Sludge Chamber to River	Through Drainage System	Good Curti Quarters, Gdown Requir Recirculation	

Table M31.2.2

Present Conditions of Opa Water Treatment Plant (8/8)

Present Condition of Opa & Curti Water Treatment Plant Organization & Staff Deployed (Common for 4 - Treatment Plant)										No. 6
General Shift		Working Hour : 10:00 am → 05:45 pm		Assistant Engineer		1 Person				
Staff Deployed :		Technical Assistant		1 Person		4 Persons				
		Junior Engineer		Person		Person				
		Chemist		Person		Person				
		Electrician		0		Person				
		Total		0		Person				
Shift in Plant Operation		2 - Shifting System Covering 24 Hours								
Working Hour :		①: 08:30 am → 05:30 pm, ②: 05:30 pm → 08:30 am								
		(1) : 8 MLD		(2) : 12MLD		(3) : 72MLD		(4) : 40MLD		(5) : Intake
Grouping Staff Deployed		3 Groupe		3 Groupe		3 Groupe		3 Groupe		3 Groupe
Number of Groupe		3 Persons		4 Persons		4 Persons		6 Persons		6 Persons
Number of Staff per Groupe		3		3		3		3		6
Maintenance Staff		12		15		21		21		24
Total										
Item										
Staff Deployed at the Plant										
Common for 4 Plants at Opa Waterworks										
Management Staff - Engineers										
Person	Qualification	Year of Service	Service at plant							
1	B.E.(Mech)	18	5							
1	B.E.(Civil)	17	5							
4	DEE/DME	17 Ave.	10 Ave.							
1	L.D.C	S.S.C.	12							
4	S.S.C.	5 Ave.	5 Ave.							
Sub-total										
Sub-total										
Skilled Staff - Operators / Quality Testing										
4	M. Sc/B. Sc	15 Ave.	15 Ave.							
4	ITI	20 Ave.	20 Ave.							
4	Electrician	23 Ave.	15 Ave.							
5	S.S.C./ITI	29 Ave.	29 Ave.							
1	S.S.C.	2 Ave.	2 Ave.							
8	S.S.C./ITI	22 Ave.	22 Ave.							
3	8 th	20 Ave.	20 Ave.							
2	ITI	2 Ave.	2 Ave.							
2	Certificate	2 Ave.	2 Ave.							
1	7 th	32 Ave.	32 Ave.							
3	4 th	16 Ave.	16 Ave.							
3	S.S.C./ITI	20 Ave.	17 Ave.							
2	7 th / ITI	15 Ave.	15 Ave.							
4	7 th / S.S.C.	17 Ave.	17 Ave.							
2	ITI	23 Ave.	19 Ave.							
Sub-total										
Sub-total										
Unskilled Staff										
33 - Workman, Labourer, Khalashi, Watchman, Helper, etc.										
Total Number										
92										




Figure M31.2.2 Flow Rate of Opa Water Treatment Plant in 2003

Table M31.2.4 Flow Rate of Opa Water Treatment Plant in 2004 (5/5)

MONTH : Sep-04													
DATE	72 MLD					12 MLD		8 MLD		VT		TOTAL MLD	10% LESS
	648 m ³ /hr		864 m ³ /hr		Total (MLD)	473 m ³ /hr		333 m ³ /hr		1250 m ³ /hr			
	TOTAL HRS	MLD	TOTAL HRS	MLD		TOTAL HRS	MLD	TOTAL HRS	MLD	TOTAL HRS	MLD		
1-Sep	17.58	11.39	44.33	38.30	49.70	24.00	11.35	22.33	7.44	48.00	60.00	128.49	115.64
2-Sep	32.67	21.17	30.75	26.57	47.74	22.25	10.52	9.17	3.05	48.00	60.00	121.31	109.18
3-Sep	24.00	15.55	45.25	39.10	54.65	23.83	11.27	10.75	3.58	48.00	60.00	129.50	116.55
4-Sep	45.33	29.38	23.67	20.45	49.82	23.67	11.19	19.50	6.49	47.17	58.96	126.47	113.82
5-Sep	48.00	31.10	24.00	20.74	51.84	22.42	10.60	17.25	5.74	48.00	60.00	128.19	115.37
6-Sep	42.75	27.70	24.08	20.81	48.51	23.67	11.19	23.42	7.80	46.50	58.13	125.63	113.06
7-Sep	20.92	13.55	31.08	26.86	40.41	10.58	5.01	23.33	7.77	46.50	58.13	111.31	100.18
8-Sep	44.17	28.62	24.00	20.74	49.36	17.83	8.44	21.83	7.27	48.00	60.00	125.06	112.56
9-Sep	43.75	28.35	24.00	20.74	49.09	24.00	11.35	6.33	2.11	48.00	60.00	122.55	110.29
10-Sep	47.08	30.51	24.00	20.74	51.25	21.58	10.21	12.92	4.30	48.00	60.00	125.76	113.18
11-Sep	50.58	32.78	24.00	20.74	53.51	20.58	9.74	23.08	7.69	43.50	54.38	125.31	112.78
12-Sep	34.75	22.52	19.08	16.49	39.01	24.00	11.35	15.00	5.00	48.00	60.00	115.35	103.82
13-Sep	43.25	28.03	19.83	17.14	45.16	22.67	10.72	24.00	7.99	48.00	60.00	123.88	111.49
14-Sep	38.33	24.84	24.00	20.74	45.58	18.75	8.87	21.25	7.08	48.00	60.00	121.52	109.37
15-Sep	45.00	29.16	20.08	17.35	46.51	20.58	9.74	20.08	6.69	47.25	59.06	122.00	109.80
16-Sep	48.00	31.10	24.00	20.74	51.84	18.92	8.95	10.25	3.41	48.00	60.00	124.20	111.78
17-Sep	48.00	31.10	24.00	20.74	51.84	24.00	11.35	7.75	2.58	48.00	60.00	125.77	113.20
18-Sep	47.68	30.90	23.93	20.68	51.58	22.18	10.49	23.35	7.78	47.53	59.42	129.26	116.34
19-Sep	47.50	30.78	23.92	20.66	51.44	23.33	11.04	11.08	3.69	47.33	59.17	125.34	112.80
20-Sep	40.67	26.35	24.00	20.74	47.09	23.50	11.12	23.50	7.83	48.00	60.00	126.03	113.43
21-Sep	39.23	25.42	24.00	20.74	46.16	23.83	11.27	24.00	7.99	48.00	60.00	125.42	112.88
22-Sep	42.50	27.54	24.00	20.74	48.28	24.00	11.35	24.00	7.99	48.00	60.00	127.62	114.86
23-Sep	33.42	21.65	24.92	21.53	43.18	24.00	11.35	24.00	7.99	48.00	60.00	122.53	110.27
24-Sep	28.42	18.41	34.08	29.45	47.86	24.00	11.35	21.50	7.16	48.00	60.00	126.37	113.74
25-Sep	40.33	26.14	23.08	19.94	46.08	20.17	9.54	18.33	6.11	46.00	57.50	119.22	107.30
26-Sep	42.08	27.27	24.00	20.74	48.01	21.83	10.33	24.00	7.99	48.00	60.00	126.33	113.69
27-Sep	34.17	22.14	28.75	24.84	46.98	18.50	8.75	23.42	7.80	46.58	58.23	121.76	109.58
28-Sep	42.42	27.49	24.00	20.74	48.22	19.00	8.99	21.58	7.19	48.00	60.00	124.40	111.96
29-Sep	48.50	31.43	16.08	13.90	45.32	24.00	11.35	16.58	5.52	48.00	60.00	122.20	109.98
30-Sep	57.25	37.10	12.83	11.09	48.19	19.17	9.07	21.92	7.30	47.33	59.17	123.72	111.35
Total	1218.33	789.48	757.77	654.71	1444.19	650.85	307.85	565.52	188.32	1425.70	1782.13	3722.48	3350.24
Average		26.32		21.82	48.14		10.26		6.28		59.40	124.08	111.67
		Average raw water pumped per day :					124.08	MLD					
		Average clear water pumped per day :					111.67	MLD					




Figure M31.2.3 Monthly Water Quality of Opa WTP (Curti 72MLD) Analysed by PWD's Laboratory from January 2003 to May 2005 (1/2)




Figure M31.2.3 Monthly Water Quality of Opa WTP (Curti 72MLD) Analysed by PWD's Laboratory from January 2003 to May 2005 (2/2)

Table M31.2.6 Records on Power Interruption at Opa WTP in 2004

Year	2004	Ave.	4.4	Max.	350.0	Min.	1.0	Unit: min.				
Date	Jan.	Feb.	Mar.	Apr.	May	Jun.	Jul.	Aug.	Sep.	Oct.	Nov.	Dec.
1						1.0		20.0			1.0	20.0
2												
3		2.0		10.0		20.0	2.0					
4						25.0			5.0		7.0	20.0
5		15.0	2.0		5.0	27.0		10.0		5.0		85.0
6								2.0	5.0			
7									10.0	5.0		
8	3.0				350.0						5.0	
9						79.0						
10						9.0				2.0	75.0	
11	1.0			5.0		5.0						
12				2.0								
13		2.0				1.0						
14							2.0			44.0		
15				5.0								
16						7.0		1.0		18.0	6.0	
17				125.0		2.0		1.0		10.0		
18			60.0	147.0					2.0			4.0
19			18.0	1.0				5.0	2.0			
20				6.0							2.0	
21	15.0	5.0		20.0								
22						10.0						
23		15.0				10.0						
24					25.0					2.0		
25				2.0	15.0	5.0			40.0			3.0
26		9.0										
27	2.0								7.0			
28	13.0	2.0										
29	3.0	-		22.0							27.0	
30		-					10.0	10.0	3.0		5.0	
31		-		-		-	2.0	1.0	-		-	
Total (min./month)	37.0	50.0	80.0	345.0	395.0	201.0	16.0	50.0	74.0	86.0	128.0	132.0
Ave. (min./day)	1.2	1.8	2.6	11.5	12.7	6.7	0.5	1.6	2.5	2.8	4.3	4.4
Max. (min./day)	15.0	15.0	60.0	147.0	350.0	79.0	10.0	20.0	40.0	44.0	75.0	85.0
Min. (min./day)	1.0	2.0	2.0	1.0	5.0	1.0	2.0	1.0	2.0	2.0	1.0	3.0

Note: Average interruption period means the interruption minutes per day per month .




Table M31.2.7

List of Reservoirs for the Opa Water Supply Scheme (1/3)

Series No.	System	Tapping Main Dia. Material (mm)	Name of GLR / OHR / Sump (Name of Location)	Type	Capacity (m ³)		GLR/OHR/Sump Elevation (m)		Supply Area		Remarks
					RL	HWL	RL	HWL	Taluka	Village Name	
O- 1	WTP		Opa 8MLD	GLR	175						
O- 2			Opa 12MLD	GLR	1,350						
			Sub-Total		1,525						
C- 1	Curti		Curti 72MLD	GLR	3,030	154.00	159.00				
C- 2	MBR			GLR	3,030	154.00	159.00				
C- 3				GLR	3,030	154.00	159.00				
C- 4			Opa 8MLD & 12MLD	GLR	800	154.00	158.00				
C- 5				GLR	800	154.00	158.00				
C- 6				GLR	800	154.00	158.00				
C- 7				GLR	800	154.00	158.00				
C- 8			Curti 40MLD	GLR	5,000	164.00	168.00				
C- 9				GLR	5,000	164.00	168.00				
			Sub-Total		22,290						
W- 1	White Line	200	Marwaswada	GLR	800	60.00	63.80		Ponda Usgaol(13)		
W- 2		100	Khandepar	GLR	300	40.00	43.00		Bicholim Pale(26)		
W- 3		200	Prabhunagar	GLR	800	58.00	61.80		Ponda Vagurbent(11), Candepar(14)		
W- 4		80	St. Mary Convent, Ponda	GLR	300	42.00	45.00		Betora(22), Curti(CT)(32)		
		200		GLR	300	42.00	45.00		Ponda(MCI)(31), Curti(CT)(32)		
W- 5		150	Bethoda	GLR	300	60.00			Betora(22), Curti(CT)(32), Ponda(MCI)(31)		
W- 6		200	Shanti Nagar, Ponda	GLR	800	58.00			Ponda(MCI)(31)		
W- 7		150	Upper Tank, Forest Dept.	GLR	300	45.00			Queual(30), Durbhat(19), Telaulim(20), Vadi(21), Ponda(MCI)(31)		
W- 8		150	Middle Tank, Forest Dept.	GLR	800	42.00			Queual(30), Bandora(CT)(29)		
W- 9		80	Lower Tank, Forest Dept.	Sump	300	40.00			Ponda(MCI)(31)		
W- 10		150	Khandpatband	GLR	300	65.00			Ponda(MCI)(31)		GL=82.0
W- 11		200		GLR	800	65.00			Ponda(MCI)(31), Queual(30), Bandora(CT)(29)		
W- 12		200	Kashi Matt	GLR	300	38.00			Bandora(CT)(29)		
W- 13		200	Fernagudi	GLR	800	80.00			Bandora(CT)(29), Queual(CT)(30)		GL=110.0
W- 14		200	Borim Batthakol	GLR	800	55.00			Borim(26), Queual(CT)(30)		
W- 15		200	Borim Paniwada (1991)	GLR	300	75.00			Borim(26)		
W- 16		80	Borim Paniwada (1975)	GLR	100	58.00			Borim(26)		
W- 17		200	Shiroda (2000)	GLR	800	45.00			Borim(26)		
W- 18		200	Shiroda (1980)	GLR	300	45.00			Siroda(27)		
W- 19		100	Curti (Middle Quarter)	GLR	150	80.00	83.00		Codra(23), Candepar(14)		
			Sub-Total		9,350						
R- 1	Red Line	150	Keriyem	GLR	300	65.00			Ponda Candepar(14), Usgaol(13), Vagurbent(11)		
R- 2		200	Usago	GLR	800	52.00			Usgaol(13)		
R- 3		150	Near MRF Factory	OHR	50	38.00			Pilem(1)		
R- 4		200	Usago Forest Area	OHR	150	50.00	53.00		Ponda Usgaol(13)		GL=63.0, Not in use
R- 5		150	Curti	GLR	300	42.00			Usgaol(13), Curti(32)		
R- 6		150	Apewal (1991)	GLR	300	50.00			Curti(32)		w/Pump-limit: 3hrs/d
R- 7		250	Military Ponda	GLR	400	75.00			Curti(32)		
R- 8		150	Bhoot Khamb Keri	GLR	200	160.00			Querim(10), Savoi-Verant(6)		GL=156.0
R- 9		200	Gaanga Nagar Ponda (1999)	GLR	800	70.00			Curti(32)		
R- 10		100	Simepain	GLR	75	45.00			Velinga(16)		
R- 11		150	Madkai	GLR	300	45.00			Maraim(18)		
		225	HIDPE								
R- 12		150	Mardol	GLR	300	45.00			Prio(15), Velingat(16)		
R- 13		200	Kundaim Near IDC Gate	GLR	300	40.00			Cundaim(17), Cuncolent(9), Bomat(8)		

Table M31.2.7 List of Reservoirs for the Opa Water Supply Scheme (2/3)

Series No.	System	Tapping Main Dia. (mm)	Material	Name of GLR / OHR / Sump (Name of Location)	Type	Capacity (m ³)		GLR/OHR/Sump Elevation (m)		Taluka	Supply Area		Remarks
						RI	HWL	RI	LWL		Village Name		
R- 14	Red Line	150	CIP	Kundaim Near Kundil	GLR	200	78.00			-ditto-	Boni(8), Industry		
R- 15		150	CIP	Volla Wada	Sump	65	67.00			-ditto-	Boni(8), Industry	GL=67.0	
R- 16		150	CIP	Adeona	Sump	32	45.00			-ditto-	Adcolna(7)		
R- 17		150	CIP	Tivrem	GLR	150	42.00			-ditto-	Tivrem(3), Orgao(2)		
R- 18		150	CIP	Wadiwada Betqui	GLR	300	44.00			-ditto-	Betqui(4), Candolal(1)		
R- 19		150	CIP		Sump	25	40.00			-ditto-	Betqui(4)	w/Pump- limit×5hrs/d	
R- 20		150	CIP	Betqui Near Health Center	Sump	50	75.00			-ditto-	Betqui(4)	GL=87.0	
R- 21		150	CIP	Betqui	GLR	100	55.00			-ditto-	Betqui(4)	GL=58.0	
R- 22		150	CIP	Marcel (1975)	GLR	300	40.25			-ditto-	Tivrem(3)		
R- 23		150	CIP	Cumbharjua (1992)	OHR	150	23.00		40.00	Tiswadi	Cumbharjua(10), Gandaulim(11)		
R- 24		150	ACP	St. Estavam (1990)	GLR	300	47.91			-ditto-	Jua(9)		
R- 25		100	CIP	Ameywada (1975)	GLR	150	40.00			-ditto-	Candolal(1)		
R- 26		150	CIP	Corlim	GLR	150	30.00	33.80		Tiswadi	Corlim(12)		
R- 27		150	CIP	Carambolim (2004)	GLR	300	37.00	40.80		-ditto-	Carambolim(17)		
R- 28		150	CIP	Mallar - Diwar	GLR	300	51.00	54.80		-ditto-	Navelim(5), Gollim(6), Malat(7), Naroa(8)		
R- 29		150	CIP	St. Mathais Diwar	GLR	300	50.00			-ditto-	Navelim(5), Gollim(6), Malat(7), Naroa(8)	GL=50.0, Not in use	
R- 30		100	ACP	Carambolim Peth	GLR	300	50.00	53.80		-ditto-	Carambolim(17)		
R- 31		100	ACP	Dongri Neura	GLR	300	42.00	45.80		-ditto-	Neura-O-Pequeno(24), Neura-O-Grande(25)		
R- 32		100	ACP	Mandur (1975)	GLR	150	32.00	35.80		-ditto-	Azossim(18), Mandur(19)		
R- 33		200	ACP	Pillar	GLR	800	40.00	43.80		-ditto-	Neura-O-Pequeno(24), Neura-O-Grande(25), Mercurim(26), Goa Velhat(37)		
R- 34		150	CIP	Old Goa (1985)	GLR	800	49.00	52.80		-ditto-	Gandaulim(11), Elia(13), Baingunim(14)		
R- 35		150	CIP	Old Goa (1965)	GLR	300	56.00	59.80		-ditto-	Not in Use		
R- 36		150	CIP	Riabandar (1975)	GLR	150	55.00	58.80		-ditto-	Panelim (OG)-Ward(29)		
R- 37		150	CIP	Riabandar (1994)	GLR	300	55.00	58.80		-ditto-	Panelim (OG)-Ward(29)		
R- 38		150	CIP	Riabandar	OHR	650	55.00			-ditto-	Panelim (OG)-Ward(29)		
R- 39		150	CIP	Chimbel	GLR	300	58.00	61.80		-ditto-	Chimbel(CT)(27)		
R- 40		150	CIP	Mercees	GLR	300	12.00	15.80		-ditto-	Morambi-O-Grande(Mercees)(OG)(30), Renovadi(OG)-Ward No. 19(31), Morambi-O-Pequeno(Mercees)(OG)-Ward No.20(32)	w/Pump- limit×8hrs/d	
				Sub-Total		11,497							

Table M31.2.7 List of Reservoirs for the Opa Water Supply Scheme (3/3)

Series No.	System	Tapping Main Dia. (mm)	Material	Name of GLR / OHR / Sump (Name of Location)	Type	GLR/OHR/Sump Elevation (m)			Supply Area		Remarks
						Capacity (m ³)	RL	HWL	LWL	Taluka	
G-1	Green Line	150	CIP	Fernagudi	GLR	800	85.00	80.00	Ponda	Bandora(CT)(29), Queuilat(CT)(30)	
G-2		150	CIP		GLR	300	82.00	80.00	-ditto-	Bandora(CT)(29)	w/Pump- limit<4hrs/d
G-3		400	CIP	Bambolim	GLR	100	57.00	60.80	Tiswadi	Cujira(OG)-Ward No.2(33), Murdat(OG)-Ward(34), Calapor(CT)(35),	
G-4		400	CIP		GLR	800	57.00	60.80	-ditto-	Bambolim(CT)(36)	w/Pump- limit<8hrs/d
G-5		250	CIP	GMC Complex, Bambolim	OHR	650	73.00	77.00	-ditto-	Bambolim(CT)(36)	
G-6		250	CIP	Curca	GLR	300	40.00	43.80	-ditto-	Curca(22)	
G-7		250	CIP	Siridao	GLR	300	55.00	58.80	-ditto-	Siridao(23), Goa Velha(CT)(37)	
G-8		500	CIP	Taligao	GLR	800	42.00	46.00	-ditto-		w/Pump- limit<2hrs/d
G-9		500	CIP		GLR	800	42.00	46.00	-ditto-		
G-10		500	CIP		OHR	650	46.00	72.00	-ditto-		
G-11		250	CIP	Nagali	Sump	50	43.00		-ditto-		w/Pump
G-12					OHR	150	55.00	76.00	-ditto-		
G-13		500	CIP	Altinho (1960) - R6	OHR	450	60.00	82.00	-ditto-		
G-14				Altinho - R1	GLR	800	59.00	63.00	-ditto-	Panaji(M C+OG)(28)	w/Pump Pumping to OHR
G-15				Altinho - R2	GLR	800	59.00	63.00	-ditto-		
G-16				Altinho - R3	GLR	800	59.00	63.00	-ditto-		w/Pump Pumping to OHR
G-17				Altinho - R4	GLR	800	59.00	63.00	-ditto-		
G-18				Altinho - R5	GLR	800	59.00	63.00	-ditto-		
G-19				Altinho - R7	OHR	650	59.00	85.00	-ditto-		
G-20				Altinho - R8	GLR	5,000	59.00	64.00	-ditto-		
G-21				CABO (Ras Bhavan)	GLR	800	45.00	48.80	-ditto-		
				Sub-Total		15,800					
91				Total		60,462					
				Retention Time		11.0 hrs					

Note: RL=Reduced Level, GL=Ground Level, HWL=High Water Level in Reservoir, LWL=Low Water Level in Reservoir, GLR=Ground Level Reservoir, OHR=Over Head Reservoir, Sump=Pumping Suction Well, MBR=Master Balancing Reservoir

M31.3 Chandel Water Supply Scheme

The Chandel facility consists of a 15 MLD plant commissioned in 2002. Raw water is sourced from the Kalana River which is pumped approximately 150m to the plant. The site contains a clear water sump from which water is pumped to the MBR approximately 800m away for onward gravity feed to the distribution system. We understand that prior to commissioning of the plant, a number of rural water supply schemes were in operation and the networks for these schemes are now interconnected with the Chandel plant. We understand that the rural schemes serve to augment the regional scheme at peak demand times.

Table M31.3.1 lists the summary of asset data for the WTP and Table M31.3.2 contains detailed asset data for the WTP. The plant schematic is shown on Figure M31.3.1.

The raw water pump house and treatment plant are located in separate compounds. The study team found these compounds to be adequately gated, fenced and secured by 24 hour on-site security personnel. The plant is manually operated. The plant operates 24 hours a day, and using a three shift system. The distribution network currently needs to be enhanced, therefore the plant operates at only 8.5 MLD.

Raw water supplied to the plant is measured at the par shall flume. This flume has a working flow measuring device. Flow measurement devices are not installed at the MBR or beyond. Therefore, transmission via the clean water reservoirs is estimated based on pump design capacities and hours of operation. The raw water pump house has four pumps (two duty) each with a capacity of 200 l/s. Maintenance standards are good and the drive couplings/shafts are well guarded.

Maintenance is generally reactive, except for regular oiling and greasing. There is no operation and maintenance manual (although some equipment catalogues are available) and training for new staff is only provided on the job by existing experienced staff. There are no written or formal safety systems for plant operation.

The treatment plant is controlled manually. Most equipment appears to be in good working order, except for the alum and lime mixers. The lime mixers were not functioning at the time of the site visit, which meant lime was added by hand at the flash mixer point. Generally, good maintenance standards are evident and the water pumps are well guarding. Currently there are no logs maintained at the plant.

The plant does not have an on-site laboratory, although equipment for measuring residual chlorine and pH levels is available. Residual chlorine and pH are measured hourly by the plant operators to inform the process control, however records of the measurements are not kept. Staff from the Panaji laboratory visit the site and take samples for analysis once a week.

Gas chlorination is used to disinfect the water. Chlorination is achieved using one tonne cylinders. Normally there is one cylinder in the chlorine house at any one time. There is only one vacuum type chlorinator, meaning there are no standby chlorinators. The study team was advised that another chlorinator will be installed. Maintenance of the chlorinator is undertaken in-house, but periodic calibration is not undertaken and no maintenance records are kept. No spare parts for the chlorine facility are kept on-site. Maintenance, installation standards and operation practices for chlorination are poor. Ammonia solution is used to detect leaks from the pipes and the connection joints. The only facility to detect or contain gas leaks is an immersion tank, however it is not easily accessible during an emergency. The feeder pipe to the contact tanks is made of poor quality flexible plastic hose and it is unprotected. This is not safe and should be rectified immediately. Personal breathing apparatus is not provided and staff are not aware of the safety procedures / measures required during the chlorination process.

Table M31.3.3 and Figures M31.3.2 show the data on monthly water quality at Chandel Water Treatment Plant. Table M31.3.4 shows a list of existing reservoirs for Chandel Water Supply Scheme.

Table M31.3.1 Summary of Asset Register of Chandel Water Treatment Plant

Name of Facility		Contents of Facility	Remarks
Raw Water Intake & Raw Water Transmission Facility	Jack Well & Connecting Pipe	^D 9.0 m × ^H 21.0m D600mm × CIP × 10.0m × 1 Line	Kalana River
	Pump & Motor	Vertical Turbine Self Water Lubricated Pump: ^Q 417.6m ³ /hr × ^H 28.0m × 45kw × 4 units (2 – Standby)	Design Cap. of Intake Pump = 20MLD
	Raw Water Transmission Main	D400mm × 157m × CIP × 1 Line	
Treatment Facility	Aerator	Cascade Type: 1 unit	
	Parshal Flume & Flash Mixer	Each 1 unit (for Chemical Dosing)	
	Clariflocculator	Circular Horizontal Flow Type with Center Feed/Peripheral Collection Flocculation & Clarifier: ^D 32.0m (Flocc. Zone 12.0m) × ^{WD} 4.0m × 1 units Detention Period: Flocculation – 34.7min Clarifier – 3.5hrs ¹⁾ Surface Loading for Clarifier: 27 m ³ /m ² /d (18.8 mm/min) ²⁾	1): 2~2.5 hrs 2): 30~40m ³ /m ² /d
Filter	Gravity Rapid Sand Filter Type ^W 4.35m × ^L 9.00m × 4 basins Effective Size of Sand: 0.45~0.60mm, Depth of Sand: 0.60~0.70m Filter Area: 19.6 m ² /basin, 39.2 m ² /basin Filtration Rate: 5.0 m/hr ³⁾ (120 m/d) Air Scouring Rate: ??m/hr/cell ⁴⁾ (0.??m ³ /min/m ² /cell) Backwash Rate: 10.2m/hr/cell ⁵⁾ (0.17m ³ /min/m ² /cell)	Based on Specifications of Air Blower & Backwash Pump 3): 4.8~6.0m/hr 4): 36~54m/hr 5): 24~36m/hr	
Clear Water Facility	Clear Water Reservoir	^W 20.5m × ^L 13.0m × ^{WD} 3.0m × 1 unit Total Volume=800 m ³ Retention Time: 1.3 hr	
Chemical Feeding Facility	Alum Feeding Facility	Dry Aluminum Sulfate Solution Tank: 2 units	
	Lime Feeding Facility	Powder Lime Solution Tank: 2 units	
	Disinfection Facility	Liquid Chlorine (1 tone Container – net 900kg) Chlorinator: 2 units	
Laboratory	Frequency of Sampling & Analysis	Not In-Service, Jar Test: Not in Service Daily test: pH, Turbidity, R-Cl	
Clear Water Transmission Facility	Transmission Pump & Motor	Horizontal Centrifugal Pump: ^Q 360m ³ /hr × ^H 115m × 179kw × 4 units (2 – Standby)	Design Cap. of Pump = 17MLD
	Rising Main	D400mm × DIP × 775m × 1 Line	
	Clear Water Reservoir (MBR)	^W 20.0m × ^L 20.0m × ^{WD} 4.0m × 1 unit Total Volume=1,600 m ³	
Note: 1) ~ 4) are referring to “Manual on Water Supply and Treatment, Third Edition – Revised and Updated, May 1999”			




Figure M31.3.1 Schematic Sequence of Chandel Water Treatment Plant

Table M31.3.2 Present Conditions of Chandel Water Treatment Plant (1/5)

Item		Contents		Remarks	
Background					
Covered Area for Water Supply		Taluka	Pernem		
Name of Plant		Chandel W.T.P.			
Number of W.T.P.		Number	(1)		
Capacity of Plant		MLD	15		
		m ³ /d	15,000		
Raw Water Resources		River	Kalana		
		Dam			
Year of Construction		Year	2001-2002		
Year of Commission		Year	2002		
Expected Augmentation Plan (Tillari Irrigation Project)			35 MLD		
Name of Facility		Contents of Facility		Remarks	
Capacity of Raw Water Intake & Water Treatment Plant		MLD	18.75		
		m ³ /d	18,750		
Head Water Works : Raw Water Intake					
Intake Well	Diameter	m	6.00		
	Height	m	5.00		
	Water Depth	m	?		
	Volume	m ³ /unit	0.0		
	Water Level of River				
		H.W.L.	m	?	
	L.W.L.	m	?		
Connecting Pipe	Diameter	mm	600		
	Length	m	10.00		
	Material		CIP		
	Velocity	m/sec	0.768		
	Loss of Head	m	0.013		
Jack Well & Pump House	Diameter	m	9.00		
	Height	m	21.00		
	Water Depth	m	?		
	Volume	m ³ /unit	0		
	Detention Time	min	0.00		
Control Room	Width	m	6.00		
	Length	m	6.00		
	Area of Floor	m ²	36.00		
Raw Water Pump	Capacity	ℓ/sec	116		
		m ³ /min	6.96		
		m ³ /hr	417.6		
		m ³ /d	10,022		
	Number	unit	4		
	Stand-by	unit	2		
	Total Capacity	m ³ /d	20,000		
	Head	m	28.0		
Maker		WPIL Ltd.			
Year of Manufacture		2002			
Assessment of Condition		Working			
Raw Water Motor	Motor Output	HP	60		
		kW	45		
	Number	Unit	4		
	Maker		Kirlosker		
	Year of Manufacture		2002		
Assessment of Condition		Working			
Raw Water Transmission Line	Diameter	mm	400		
	Length	m	157		
	Material		CIP "B"		
	Velocity	m/sec	0.543		
	Loss of Head	m	1.438		
	Assessment of Condition	Pipe	Good		
Valve		Good			
: Hazen-Williams Formula					
OK					
: Hazen-Williams Formula					

Table M31.3.2 Present Conditions of Chandel Water Treatment Plant (2/5)

Item		Contents		Remarks	
Water Treatment Plant					
Aerator	Capacity	m ³ /hr	781.3	625	
		m ³ /d	18,750	15,000	
	Number	Unit	1		
	Diameter	m	9.0		
	Height	m	?		
	EL. of Top Aerator	m	?		
Assessment of Condition		Good			
Parshal Flume / Weir	Number	Unit	1		
	Assessment of Condition		Good		
Flash Mixer	Number	Unit	1		
	Assessment of Condition		Good		
Clarifiers / Settling Tank (Coagulation Basin)	Design Capacity	m ³ /min/unit	13.0		
		m ³ /hr/unit	781.3		
		m ³ /d/unit	18,750		
	Number	Unit	1		
	Water Depth	m	4.00		
	Overall Diameter	m	32.00		
	Flocc. Zone Dia.	m	12.00		
	Frequency of Desludging		General Season: 1 Time/48 hrs Monsoon Season: 1 Time/24 hrs		
	Volume				
	Overall	m ³ /unit	3,217.0		
	Flocculation Zone	m ³ /unit	452.4		
	Clarifying Zone	m ³ /unit	2,764.6		
	Retention Time				
	Flocculation Zone	min	34.7	OK	
	Clarifying Zone	min	212.3	OK	
	Overall	min	247.1		
Surface Area	m ² /unit	691.2			
Surface Loading	mm/min	18.8	Ok		
W.L. of Clarifier	m	?			
Assessment of Condition		Working Condition			
Flocculator & Drive Arrangement	Number	unit	1		
	Assessment of Condition		Working Condition		
Filter	Design Capacity	m ³ /hr/unit	195.3		
		m ³ /d/unit	4,687.5		
	Number	Unit	4		
	Type		Rapid Sand Gravity Filter		
	Width	m	4.35		
	Length	m	9.00		
	Height	m	?		
	Water Depth	m	2.15		
	Filtered Area	m ² /unit	39.2		
	Velocity	m ³ /d/m ²	119.7 OK		
	Filter Media		Standard Size		
	E.S. of Sand	mm	0.45~0.60	: E.S. = Effective Size	
	Depth of Sand	mm	600~700	: U. C. E. = 1.3~1.7	
	Type of Underdrain System		CIP with Header Tee		
	Year Replacement of Media		No Replacement		
Water Level of Filter	m	?			
Assessment of Condition		Working Condition			
Filter Washing Criteria & Method	Air Scouring Rate	m ³ /min/m ²			
	Air Scouring Time	min	5		
	Backwash Rate	m ³ /min/m ²	0.34	NO	
	Backwashing Time	min	15~20		
	Frequency of Washing		General : 1 Time/72 hrs Maximum : 1 Time/24 hrs		

Table M31.3.2 Present Conditions of Chandel Water Treatment Plant (3/5)

Name of Facility			Contents of Facility			Remarks
Backwash Pump & Motor	Capacity	m ³ /min	6.71			
		m ³ /hr	402.77			
	Number	unit	2			
	Stand-by	unit	1			
	Total Capacity	m ³ /min	6.71			
	Head	m	12.0			
	Type of Pump	Centrifugal				
	Motor Output	HP	100			
		kW	75			
	Assessment of Condition	Working				
Air Blower	Capacity	m ³ /min				
		m ³ /hr				
		m ³ /d				
	Number	unit				
	Stand-by	unit				
	Total Capacity	m ³ /min				
		m ³ /d				
	Head	mm WG				
	Motor Output	HP	40.0			
		kW	30.0			
Assessment of Condition	Working					
Clear Water Reservoir (Sump)	Width	m	20.5			
	Length	m	13.0			
	Water Depth	m	3.0			
	Number	Unit	1			
	Volume	m ³	800			
	Total	m ³	800			
	Detention Time	hr	1.3			
	Last Date of Cleaning	Periodical				
	Water Level	m	12.70			
			10.00			
Assessment of Condition	Working					
Chemical Facility						
Alum Feeding Facility	Capacity	kg/hr				
		m ³ /unit	9.2			
	Diameter	m				
	Width	m				
	Length	m				
	Height	m				
	Volume	m ³				
	Number	Unit	2			
	Stand-by					
	Assessment of Condition	Working				
Lime Feeding Facility	Capacity	kg/hr				
		m ³ /unit	27.0			
	Diameter	m				
	Width	m				
	Length	m				
	Height	m				
	Volume	m ³				
	Number	Unit	4			
	Stand-by					
	Assessment of Condition	Working				
Disinfection System	Chemical Used	Liquid Chlorine				
	Type of Plant & Machinery	Vaccum Type				
	Capacity	kg/hr				
	Number	Unit	2			
	Stand-by					
	Safety Measures Taken	-				
	Commissioned	2002				
Assessment of Condition	Working					

Table M31.3.2 Present Conditions of Chandel Water Treatment Plant (4/5)

Name of Facility		Contents of Facility		Remarks	
Laboratory					
Chemical Testing Laboratory		Not in-service		?	
Jar Testing		-			
Availability of Skilled Chemists		-			
Availability of Required Chemicals		From Assonora Store			
Use of Test Reports		As per Format			
Frequency of Sampling & Analysis		20 Parameters Tests Fortnightly			
		Daily Test: Turb., pH, R-CL			
General Quality of Water		Treatable with Water Treatment Process			
	Raw Water Quality	Turbid., Low pH			
	Clear Water Quality	Excellent			
Transformers					
Number of Transformer		(1)	(2)		
Pole Mounted / Pad Mounted		Floor	Floor		
Capacity	kVA	630	630		
Number	Unit				
	Standby				
Commissioned		2002	2002		
Likely Design Life	Year	30	30		
Last Replacement		-	-		
Assessment of Condition		Good	Good		
Equipment Status					
Flow Meters		No Flow Meters			
Other Operating Valves		Working			
Other Important Assets					
Valve's Condition		Working Condition			
Visible Leakage and Locations					
Building Condition		Good			
Wastewater Disposal Arrangements		Sludge Chamber with Disposal			
Transmission (Clear Water) Facility					
Transmission (Clear Water) Pump	Capacity	ℓ/sec	100		
		m ³ /min	6.00		
		m ³ /hr	360.0		
		m ³ /d	8,640		
	Number	unit	4		
		Stand-by	2		
	Total Capacity	m ³ /d	17,000		
	Head	m	115.0		
	Type of Pump		Vertical		
	Maker		Kirlosker		
Year of Manufacture		2002			
Assessment of Condition	Pump	Working Condition			
	Valve	Working Condition			
Transmission (Clear Water) Motor	Motor Output	HP	240		
		kW	179		
	Number	Unit	4		
	Maker		Crompton		
	Year of Manufacture		2002		
Assessment of Condition		Working Condition			
Raising Main (Transmission Lines)	Diameter	mm	400		
	Length	m	775		
	Material		DIP (K-9)		
	Velocity	m/sec	1.382		
	Loss of Head	m	4.698		
	Assessment of Condition	Pipe	Working		: Hazen-Williams Formula
Valve		Working			

Table M31.3.2 Present Conditions of Chandel Water Treatment Plant (5/5)

Name of Facility		Contents of Facility			Remarks
Master Balancing Reservoir (M.B.R.)	Width	m	20.00		
	Length	m	20.00		
	Water Depth	m	4.00		
	Number	Unit	1		
	Volume	m ³	1,600		
	Total	m ³	1,600		
	Detention Time	hr	2.6		
	Last Date of Cleaning		Pediodical		
	Water Level	m	104.00	: Inlet	
	Assessment of Condition		Working		

Present Condition of Chandel Water Treatment Plant

N0.3

Organization & Staff Deployed

General Shift	Working Hour :	05:00 → 19:00 (12:30 → 13.30 : Lunch Time)			
		Night Duty : 16:00 ~ 09:00 : 8 Persons			
Shift in Plant Operation	Shifting System	2 Shifting System Covering 24 Hours			
	Working Hour :	①: 08:00 → 20:00 , ②: 20:00 → 08:00			
Staff Deployed at the Plant		Person	Qualification	Year of Service	Service at plant
Management Staff - Engineers					
	Assistant Engineer	1	M.E.(P.H.E.)	20	2
	Sub-total	1			
Skilled Staff - Operators / Quality Testing					
	Mechanics	2	I.T.I.	2	2
	Electrician	2	I.T.I.	2	2
	Operator	8	I.T.I.	2	2
	Sub-total	12			
Unskilled Staff		17	- Helper, Sweeper, Security Guards		
Total Number		30			




Figure M31.3.2

Monthly Water Quality of Chandel Water Treatment Plant Analysed by PWD's Laboratory from January 2003 to May 2005 (1/2)




Figure M31.3.2 Monthly Water Quality of Chandel Water Treatment Plant Analysed by PWD's Laboratory from January 2003 to May 2005 (2/2)

Table M31.3.4 List of Reservoirs for the Chandel Water Supply Scheme

Serial No.	Inlet Pipe		Name of GLR / OHR (Name of Location)	Type	Capacity (m3)	GLR/OHR Elevation (m)			Supply Area (Village Name)	Remarks
	Dia. (mm)	Material				RL	HWL	LWL		
1	400	DIP	Casarvarem MBR	GLR	1,600	100.00	104.00			Outlet:600CIP
2	100	DIP	Casarvarem	GLR	50	66.00	70.00		Casarvorem(18)	
3	100	DIP	Chandel	GLR	100	54.00	58.00		Chandel(15)	
4	100	PVC	Alorna	GLR	100	54.00	58.00		Alorna(16)	
5	100	PVC	Ibrampur	GLR	100	54.00	58.00		Ibrampur(16)	
6	100	PVC	Ozari	GLR	100	71.00	75.00		Ozari(19)	
7	100	PVC	Varcond	GLR	50	59.00	63.00		Varconda(9)	
8	100	PVC	Ambernem	GLR	100	54.00	58.00		Cancem(8), Ambernem(10)	
9	100	PVC	Naiabag	GLR	50	54.00	58.00		Porosodem(7)	
10	100	DIP	Ugvem	GLR	100	54.00	58.00		Ugvem(11)	
11	150	DIP	Tamboxem	GLR	100	54.00	58.00		Tamboxem(12)	
12	100	PVC	Torshem	GLR	50	54.00	58.00		Torxem(13)	
13	100	PVC	Patradevi	GLR	100	54.00	58.00		Torxem(13)	
14	200	DIP	Dhargal	GLR	800	44.00	48.00		Dargalim(20)	
15	100	PVC	Virnoda	GLR	70	54.00	58.00		Virnoda(21)	
16	100	PVC		GLR	50	54.00	58.00			
17	200	DIP	Malpe	GLR	800	54.00	58.00		Pernem(M CI)(27), Pernem(Rural)(6)	
18	150	DIP	Pernem	GLR	150	44.00	48.00		Pernem(M CI)(27), Pernem(Rural)(6)	
19	150	DIP	Parastem	GLR	50	54.00	58.00			
20	150	DIP		GLR	100	54.00	58.00		Pernem(M CI)(27)	
21	200	DIP	Tuem	GLR	50	55.00	59.00			
22	200	DIP		GLR	150	55.00	59.00		Tuem(22)	
23	200	DIP		GLR	400	55.00	59.00			
24	150	DIP	Parcem	GLR	70	54.00	58.00		Parcem(CT)(28)	
25	100	PVC	Agarwada	GLR	50	54.00	58.00		Chopdem(25), Agarvado(26)	
26	150	DIP	Morjim	GLR	100	54.00	58.00		Morgim(24)	
27	150	DIP		GLR	100	54.00	58.00			
28	150	DIP	Mandrem	GLR	100	54.00	58.00		Mandrem(23)	
29	150	DIP	Dandoswada	GLR	50	57.00	61.00		Mandrem(23)	
30	150	DIP	Korgao	GLR	70	60.00	64.00		Corgao(5)	
31	200	DIP	Kerim	GLR	150	44.00	48.00		Querim(2)	
32	200	DIP	Harmal	GLR	250	34.00	38.00		Arambol(4)	
33	150	DIP	Paliyem	GLR	70	67.00	71.00		Paliem(3)	
			Total		6,230					
			Detention Time		10.0 hrs					

Note: RL=Reduced Level (Base Elevation of Reservoir), HWL=High Water Level in Reservoir, LWL=Low Water Level in Reservoir, GLR=Ground Level Reservoir, OHR=Over Head Reservoir, MBR=Master Balancing Reservoir

M31.4 Assonora Water Supply Scheme

The Assonora facility consists of a 12 MLD plant commissioned in 1968 and a 30 MLD planned commissioned in 1992. The 12 MLD plant sources water from the Amthane Dam by gravity feed approximately 10 km from the plant as well as a supplementary supply from the Assonora River via a jack well. The river source supply line is interconnected with the 30 MLD plant to supplement the main incoming raw water supply from Podocem (20 km's away) which provides 25 MLD to the plant. The site also contains a clear water sump for the approximately 15 MLD treated water received from Podocem WTP for onward distribution to the Assonora supply area.

We understand that a proposal for an additional 40 MLD plant has been prepared and submitted to PWD for approval.

Table M31.4.1 lists the summary of asset data for the WTP and Table M31.4.2 contains detailed asset data for the WTP. The plant schematic is shown on Figure M31.4.1.

The raw water pump house and the treatment plant are located within the same compound. The compound is adequately gated, fenced and secured by 24 hour on-site security personnel. The plant is manually operated and operates for 24 hours a day, using a three shift system.

Flow measurement devices are not installed. Therefore, raw water supplied to the plant (from the dam, river and Podocem), clean water fed to the plant from the Podocem WTP, and onward transmission via the clean water reservoir was estimated using pump design capacities and pump operating hours.

The raw water pump house has three pumps (one duty) each of 15 MLD capacity. Maintenance standards are good, however the drive couplings/shafts are not adequately guarded.

Records of pumping hours, loads etc are logged, however maintenance records are not kept. Maintenance is generally reactive to rectify problems as they become apparent, except for oiling and greasing which is undertaken regularly. There are no operation and maintenance manuals available and training for new staff is only provided on the job by existing experienced staff. There are no written or formal safety systems.

The treatment plants are manually controlled. Most equipment appears to be in good working

order (considering the age of the plant) except for the alum and lime mixers which do not work. Since the alum and lime mixers are out of service lime and alum are added by hand at the flash mixer point. Generally, good maintenance was evident and the treated water pumps were well guarding. This plant should be used as an example of good practice for the other sites.

Records of pump running hours, load, filter backwashing, and clear water reservoir levels are logged. However repairs to assets, maintenance and responses to breakdown problems are not recorded. The laboratory staff keep records of chemical usage and treatment parameters.

Disinfection is achieved using gas chlorination. Chlorination is achieved using one tonne cylinders. There are usually eight cylinders in the chlorine house at any one time (five are empty). There are four vacuum type chlorinators (two are for standby). Maintenance of the chlorinators is performed in-house, however periodic calibration of the chlorinators does not occur and records of maintenance are not kept.

Maintenance, installation standards and operation practices for chlorine use are poor. Ammonia solution is used as a means of detecting leaks along pipes and at the connection joints. Immersion tanks are the only facilities available to detect or contain gas leaks, however they are not easily accessible during an emergency and were empty when the study team visited the site.

During the site visit, flexible copper pipes were noted to be trailing on the platform, presenting a trip hazard and placing the pipes in danger of being damaged. This is not a safe practice. The feeder pipe to the contact tanks is PVC and unprotected, which is not a safe practice. Personal breathing apparatus is available in the laboratory but is not used or maintained. This facility is probably in the poorest condition of all the facilities visited and presents a serious health hazard.

The clean water reservoirs are cleaned every six months by PHE staff. There are no safety precautions, safety equipment, or safety systems implemented during the work. The cleaning procedure consists of removing the covers to provide fresh air to the workers and to allow the workers to enter. The desludging is undertaken manually by hosing/flushing down the internal surfaces.

Tables M31.4.3 and M31.4.4 and Figures M31.4.2 and M31.4.3 show the data on monthly water quality at Chandel Water Treatment Plant. Table M31.4.5 shows a list of existing reservoirs for Assonora Water Supply Scheme.

Table M31.4.1

Summary of Asset Register of Assonora Water Treatment Plant

Name of Facility	12 MLD		30 MLD		Remarks
	Contents of Facility		Contents of Facility		
Raw Water Intake & Raw Water Transmission Facility	Intake Well & Connecting Pipe	D400mm × CIP × 1 Line,	Assonora River	D400mm (from 12 MLD Intake)	Assonora River
	Pump & Motor	Horizontal Centrifugal Pump: $9625\text{m}^3/\text{hr} \times \text{H}17.0\text{m} \times 55\text{kw} \times 3 \text{ units (2 - Standby)}$	Design Cap. of Intake Pump = 15MLD	Vertical Pump: 700kw × 2 units	Valvant River
Treatment Facility	Raw Water Transmission Main	D450mm × 10,000m × ACP × 1 Line	Amthane Dam	D600mm/D500mm × 120.12km × 1 Line (25 MLD: from Podozem Intake)	Valvant River
	Aerator	Cascade Type: 2 units Weir × 1 unit (for Chemical Dosing), Flash Mixer × 1 unit		Cascade Type: 2 units Parshal Flume × 2 units (for Chemical Dosing), Flasha Mixer × 1 unit	
Chemical Feeding Facility	Flash Mixer & Weir / Parshal Flume				
	Clariflocculator	Circular Horizontal Flow Type with Center Feed/Peripheral Collection Flocculation & Clarifier: $\text{D}22.9\text{m (Flocc. Zone }^{\text{D}} 10.2\text{m)} \times \text{W}3.75\text{m} \times 1 \text{ unit}$ Detention Period: Flocculation - 35min Clarifier - 2.4 hrs Surface Loading: $38.2 \text{ m}^3/\text{m}^2/\text{d} (26.5 \text{ mm}/\text{min})^2$	1): 2~2.5 hrs 2): 30~40m ³ /m ² /d	Circular Horizontal Flow Type with Center Feed/Peripheral Collection Flocculation & Clarifier: $\text{D}41.2\text{m (Flocc. Zone }^{\text{D}} 18.4\text{m)} \times \text{W}4.0\text{m} \times 1 \text{ unit}$ Detention Period: Flocculation - 48 min Clarifier - 3.2 hrs Surface Loading: $29.5 \text{ m}^3/\text{m}^2/\text{d} (20.5 \text{ mm}/\text{min})^2$	1): 2~2.5 hrs 2): 30~40m ³ /m ² /d
Chemical Feeding Facility	Filter	Gravity Rapid Sand Filter Type $\text{W}6.0\text{m} \times \text{L}5.0\text{m} \times 2\text{cells}/\text{basin} \times 4 \text{ basins}$ Effective Size of Sand: 0.60mm~0.80mm, Depth of Sand: 0.55m Filter Area: 15.0 m ² /cell, 30.0 m ² /basin Filtration Rate: 4.4 m/hr ³⁾ (105 m/d) Air Scouring Rate: 39.6m/hr/cell ⁴⁾ (0.66 m ³ /min/m ² /cell) Backwash Rate: 26.4 m/hr/cell ⁵⁾ (0.44 m ³ /min/m ² /cell) - using 200m ³ Backwash tank	Based on Specifications of Air Blower & Backwash Pump 3): 4.8~6.0m/hr 4): 36~54m/hr 5): 24~36m/hr	Gravity Rapid Sand Filter Type $\text{W}4.0\text{m} \times \text{L}8.6\text{m} \times 2\text{cells}/\text{basin} \times 6 \text{ basins}$ Effective Size of Sand: 0.60mm~0.80mm, Depth of Sand: 0.75m Filter Area: 17.2 m ² /cell, 34.4 m ² /basin Filtration Rate: 6.4 m/hr ³⁾ (153 m/d) Air Scouring Rate: 33.6m/hr/cell ⁴⁾ (0.56 m ³ /min/m ² /cell) Backwash Rate: 17.4 m/hr/cell ⁵⁾ (0.29 m ³ /min/m ² /cell)	Based on Specifications of Air Blower & Backwash Pump 3): 4.8~6.0m/hr 4): 36~54m/hr 5): 24~36m/hr
	Alum Feeding Facility	Dry Aluminum Sulfate Solution Tank: 2 units		Dry Aluminum Sulfate Solution Tank: 2 units Using 12 MLD's Facility	Non-Function from Commissioning
Laboratory	Lime Feeding Facility				
	Disinfection Facility				
Clear Water Transmission Facility	Frequency of Sampling & Analysis				
	Clear Water Pump	Volume=1,200 m ³ × 1 unit, Retention Time: 2.7 hr		Volume=1,000m ³ × 2 units, Volume=2,000m ³ × 1 unit Retention Time: 3.3 hr	
Clear Water Reservoir (MBR)	Transmitted Pump & Motor	Horizontal Centrifugal Pump: $9684\text{m}^3/\text{hr} \times \text{H}13.6\text{m} \times 400\text{kw} \times 3 \text{ units (1 or 2 - Standby)}$	Design Cap. of Pump = 16 ~32MLD	Horizontal Centrifugal Pump: $9684\text{m}^3/\text{hr} \times \text{H}13.6\text{m} \times 400\text{kw} \times 4 \text{ units (1 - Standby)}$	Design Cap. of Pump = 49 MLD
	Transmission Line	D400mm × 800m × C.I.P. × 1 Line, D600mm × 800m × C.I.P. × 1 Line, D900mm × 800m × C.I.P. × 1 Line	Volume=800 m ³ × 4 units & Volume=5,000 m ³ × 1 unit, Total Volume = 7,400 m ³ in Assonora MBR		

Note: 1) ~ 4) are referring to "Manual on Water Supply and Treatment, Third Edition - Revised and Updated, May 1999"




Figure M31.4.1 Schematic Sequence of Assonora Water Treatment Plant

Table M31.4.2

Present Conditions of Assonora Water Treatment Plant (1/9)

Item		Contents			Remarks
Background					
Covered Area for Water Supply	Taluka	Bardez & Part of Bicholim			
Name of Plant		Assonora W.T.P.			
Number of W.T.P.	Number	(1) 12 MLD Assonora w.T.P.	(2) 30 MLD Assonora W.T.P.	Total	
	MLD	12	30	15	57
Capacity of Plant	m ³ /d	12,000	30,000	15,000	57,000
				15 MLD Clear Water Received from Padocem W.T.P.(40 MLD)	
Raw Water Resources	River	Assonora	Assonora		
			25 MLD Raw Water Received from Raw Water Reservoir via Valvant River Intake Pump Station		
	Dam	Anthane			
Year of Construction	Year				
Year of Commission	Year			1967	
Expected Augmentation Plan (Tillari Irrigation Project)					1992
					40 MLD

Table M31.4.2

Present Conditions of Assonora Water Treatment Plant (2/9)

Name & Number of W.T.P.	Number	(1) 12 MLD Assonora w.T.P.		(2) 30 MLD Assonora W.T.P. from Podocem W.T.P.		Total	Remarks	
		12	12,000	30	30,000			15
Capacity of Plant (Transmitted Water Supply from Plant)	MLD m ³ /d	12,000		30,000	15,000	57,000		
Capacity of Raw Water Intake & Water Treatment Plant	MLD m ³ /d	12.6		31.5	15	59.1	: Estimated 5% losses of Nominal Capacity	
Name of Facility								
Contents of Facility								
(1) 12 MLD (2) 30 MLD								
Total								
Head Water Works : Raw Water Intake								
Intake Well	Width	m	?	-	-	-	<input type="checkbox"/> One additional pump (9.0 m ³ /min X 20 m) for 12 MLD Plant in case of insufficient raw water.	
	Length	m	?	-	-	-		
	Height	m	?	-	-	-		
	Water Depth	m	?	-	-	-		
	Design Water Level		?	-	-	-		
	H.W.L.	m	?	-	-	-		
	L.W.L.	m	?	-	-	-		
	Volume	m ³ /unit		-	-	-		
	Retention Time	min		-	-	-		
	Diameter	mm	400	-	-	-		
Connecting Pipe	Number of Line	No.	1	-	-	-	D= 0.4	
	Length	m		-	-	-	C= 110	
	Material		CIP	-	-	-	Q= 0.146	
Raw Water Pump & Motor	Note		Assonora River	-	-	-		
	Velocity	m/sec	1.161	-	-	-		
	Loss of Head	m	0	-	-	-		
	Capacity	l/sec		173.6	-	-	-	
		m ³ /min		10.42	-	-	-	
		m ³ /hr		625	-	-	-	
	Number	m ³ /d	15,000	-	-	-		
	Stand-by	unit	3	-	-	-		
	Total Capacity	unit	2	-	-	-		
	Head	m ³ /d	15,000	-	-	-		
Maker	m	17.0	-	-	-			
Year of Manufacture		M & P	-	-	-			
Assessment of Condition		1992	-	-	-			
Motor Output	HP	Working	74	-	-	-		
	KW		55	-	-	-		
	Unit		3	-	-	-		
Number								
Maker		Kirtosker						
Year of Manufacture		1992						
Assessment of Condition		Working						

Table M31.4.2

Present Conditions of Assonora Water Treatment Plant (3/9)

Name of Facility		Contents of Facility			Remarks	
		(1) 12 MLD	(2) 30 MLD	Total		
Raw Water Transmission Line	Source of Raw Water	25 MLD Raw Water Received from Raw Water Reservoir via Valvant River Intake Pump Station				
	Diameter	mm	450	600/500		
	Length	m	10,000	120	20,000	D= 0.6
	Material		ACP	CIP / MS	CIP	C= 110
	Velocity	m/sec		1.023		Q= 0.289
	Loss of Head	m		43.561		
	Assessment of Condition	Pipe	-	Good		
	Assessment of Condition	Valve	-	Leakage		
	Water Treatment Plant					
	Aerator	Capacity	m ³ /hr/unit	262.5	656.3	
		m ³ /d/unit	6,300	15,750		
Number		Unit	2	2		
Width		m	6.5	9.5		
Length		m	3.4	1.5		
El. of Top Aerator		m				
Assessment of Condition			Working	Working		
Assessment of Condition		Weir	Working	2 × Parshal Flume		
Assessment of Condition			Working	Working		
Assessment of Condition			1 × Flash Mixer	1 × Flash Mixer		
Clarifiers / Settling Tank (Coagulation Basin)	Assessment of Condition		Working	Working		
	Design Capacity	m ³ /min/unit	8.8	21.9		
		m ³ /hr/unit	525.0	1,312.5		
		m ³ /d/unit	12,600	31,500		
	Number	Unit	1	1		
	Water Depth	m	3.75	4.00		
	Overall Diameter	m	22.90	25.00		
	Flocc. Zone Dia.	m	10.20	18.40		
	Frequency of Desludging		Once a Day : General	Once a Day : General		
			Twice a Day : Monsoon Sea	Twice a Day : Monsoon Season		
Parshal Flume / Weir	Volume					
	Overall	m ³ /unit	1,544.5	5,332.7		
	Flocculation Zone	m ³ /unit	306.42	1,063.62		
	Clarifying Zone	m ³ /unit	1,238.09	4,269.05		
	Retention Time					
	Flocculation Zone	min	35.0	48.6		
	Clarifying Zone	min	141.5 OK	195.2 OK		
	Overall	min	176.5	243.8		
	Surface Area	m ² /unit	330.2	1,067.3		
	Surface Loading	mm/min	26.5 OK	20.5 OK		
W.L. of Clarifier	m					
Assessment of Condition		Working	Working			

Table M31.4.2

Present Conditions of Assonora Water Treatment Plant (4/9)

Name of Facility		Contents of Facility		Remarks
		(1) 12 MLD	(2) 30 MLD	
Flocculator & Drive Arrangement	Number	1	1	
	Assessment of Condition	Working	Working	
	Design Capacity	131.25	218.8	
	Unit	m ³ /hr/unit	m ³ /d/unit	
	Number	3,150	5,250.0	
	Type	4	6	
	Width	6.00	8.60	
	Length	5.00	4.00	
	Height	3.00	3.00	
	Water Depth			
	Filtered Area	30.0	34.4	
	Velocity	105.0	152.6	
	Filter Media			
	E.S. of Sand	0.60 ~ 0.80	?	
	Depth of Sand	550	too thin	
Type of Underdrain				
Year Replacement of Media	2003	Replace New	2003 Replace New	
Water Level of Filter				
Assessment of Condition	Working	Working		
Air Scouring Rate	0.66	Generally OK	0.56 NO	
Air Scouring Time	10		10	
Backwash Rate	0.44	Generally OK	0.29 NO	
Backwashing Time		Depend on	Depend on	
Frequency of Washing	15 turb. of wash	water drain	15 turb. of wash	
Capacity	Once a Day : General	water drain	water drain	
Number	Twice a Day : Maximum		Once a Day : General	
Stand-by	2.08 Lifting Pump		Twice a Day : Maximum	
Total Capacity	125 to Back Wash		5.00	
Head	3,000 Water Tank =		300	
Type of Pump	2 200m ³		7,200	
Motor Output	1		2	
Assessment of Condition	2.08		1	
	3,000		5.00	
			7,200	
	Centrifugal Pump		Centrifugal Pump	
	20		40	
	14.9		29.8	
	Working		Working	

Table M31.4.2

Present Conditions of Assonora Water Treatment Plant (5/9)

Name of Facility		Contents of Facility			Remarks
		(1) 12 MLD	(2) 30 MLD	Total	
Air Blower	Capacity	m ³ /min	9.58	9.58	
		m ³ /hr	575	575	
		m ³ /d	14,304	13,800	
	Number	unit	2	2	
	Stand-by	unit	0	0	
	Total Capacity	m ³ /min	19.87	19.17	
		m ³ /d	28,608	27,600	
	Head	mm WG	5,000		
	Motor Output	HP	20	20	
		kW	15	15	
Maker		USHA/Kirlosker	EVEREST/CROMPTON GREVES		
Assessment of Condition		Working	2001 Working		
Clear Water Reservoir	Number of C.W.R.	Unit	(1)	(2)	
	Width	m	18.0	26.0	
	Diameter	m	-	21.0	
	Length	m	25.0	26.0	
	Water Depth	m	3.0	3.0	
	Number	Unit	1	2	
	Volume	m ³	1,350	1,039	2,028
	Total	m ³	1,350 (1,200 m ³)	4,106	(4,000 m ³)
	Detention Time	hr	2.7	3.3	
	Last Date of Cleaning		Pediodical	Pediodical	
Water Level	m				
Assessment of Condition		Slab Damaged	Slab Damaged	Under Construction	
Transmission (Clear Water) Facility					
Transmission (Clear Water) Pump	Capacity	ℓ/sec	190.0	190.0	
		m ³ /min	11.40	11.40	
		m ³ /hr	684.0	684.0	
		m ³ /d	16,416	16,416	
	Number	unit	3	4	
	Stand-by	unit	2	1	
	Total Capacity	m ³ /d	16,000	49,000	
	Head	m	136.0	136.0	
	Type of Pump		Centrifugal Pump	Centrifugal Pump	
	Maker		M & P	M & P	
Year of Manufacture		1993	1993		
Assessment of Condition		Working	Working		
Condition		Working	Working		

Table M31.4.2

Present Conditions of Assonora Water Treatment Plant (6/9)

Name of Facility		Contents of Facility		Remarks	
		(1) 12 MLD	(2) 30 MLD		
Transmission (Clear Water) Motor	Motor Output	HP	536	Total	
		kW	400		
	Number	Unit	4		
	Maker	GEC	GEC		
Raising Main (Transmission in Lines)	Year of Manufacture	1993	1993	Common for 2 Plants	
	Assessment of Condition	Working	Working		
	Diameter	mm	400		600
	Length	m	800		900
Chemical Facility	Material	CIP "B"	CIP "B"	800 GLR at Assonora M.B.R.	
	Velocity	m/sec			
	Assessment of Condition	Working	Working		
	Valve	Working	Working		
Alum Feeding Facility	Capacity	kg/hr	-	-	
		m ³ /unit			
	Diameter	m			
	Width	m			
	Length	m			
	Height	m			
	Volume	m ³			
	Number	Unit	2		
	Stand-by				
	Assessment of Condition	Functional	Non-Function : from Commissioning		
Lime Feeding Facility	Capacity	kg/hr	-	-	
		m ³ /unit			
	Diameter	m			
	Width	m			
	Length	m			
	Height	m			
	Volume	m ³			
	Number	Unit	2		
	Stand-by				
	Assessment of Condition	Non-Function	Non-Function : from Commissioning		
Disinfection System	Chemical Used	Liquid Chlorine / Bleaching Powder		Common for 2 Plants	
	Type of Plant & Machinery	Chlorinators			
	Capacity	kg/hr	2.5		
	Number	Unit	4 : 2 for 12 MLD & 2 for 30 MLD		
	Stand-by		1		
	Safety Measures Taken	Neutralization (Caustic Soda)			
Commissioned	1993				
Assessment of Condition	Working				

Table M31.4.2

Present Conditions of Assonora Water Treatment Plant (7/9)

Name of Facility	Contents of Facility		Remarks
	(1) 12 MLD	(2) 30 MLD	
Laboratory			
	Common for 2 Plants		
Chemical Testing Laboratory	In-service (Exist)		
Jar Testing	In-service (Exist)		
Availability of Skilled Chemists	Available		
Availability of Required Chemicals	Available		
Use of Test Reports	Average 2 Months Storage for Chemicals of Alum, Lime & Cl		
Frequency of Sampling & Analysis	As per Format		
	12 Parameters Tests Daily		
	Every Hour: pH, Turb. R.-Cl,		
	Daily : Other (Turb., pH, Alkalinity, Hardness, Chloride, Mn, Fe, D.O., R.-Cl, Color, Odor, Bacteriological)Test		
	Bacteriological (once a day) : Raw Water -		
	: Clear water -		
General Quality of Water	Good		
Raw Water Quality	Turbid:(Max:250NTU, Ave:35 - 40NTU, Min:10NTU),		
Clear Water Quality	Low pH (Max:6.97, Ave:6.80, Mun:6.50)		
	Good		
Transformers			
	Common for 2 Plants		
Number of Transformer	(1)	(2)	(3)
Pole Mounted / Pad Mounted	Pad	Pad	Pad
Capacity	1,600	2,500	500
Number	1	1	2
Standby			1
Commissioned	1993	1972	1993
Likely Design Life			
Last Replacement			
Assessment of Condition	Working		
Equipment Status			
Flow Meters	Non-Functional	Not Provided	
Other Operating Valves	Need Replacement	Need Replacement	
Other Important Assets			
Valve's Condition	Working Condition		
Visible Leakage and Locations	Nil		
Building Condition			
Wastewater Disposal Arrangements	River Down Stream		
			Total
			(2) Borrowed from Opa

Table M31.4.2


Present Conditions of Assonora Water Treatment Plant (8/9)

Organization & Staff Deployed	
General Shift	2 Plants (12 MLD & 30 MLD)
Working Hour :	08:30 → 17:30 (12:30 → 13:30 : Lunch Time)
Staff Deployed :	Management Staff - Engineers
	Assistant Engineer 1 Person
	Junior Engineer 3 Persons
	L.D.C 1 Person
	Peon 1 Person
	Watchman 2 Persons
	Drivers 4 Persons
	Others 19 Persons
	Total 31 Persons
Shift in Plant Operation	3 Shifting System Covering 24 Hours
Working Hour :	①: 08:00 → 14:00 , ②: 14:00 → 21:00 , ③: 21:00 → 08:00
Grouping Staff Deployed :	2 Plants (12 MLD & 30
	Shift in Charge
	Electrician, Operator, Security, etc.
	Total 13 ~ 14 Persons

Table M31.4.2

Present Conditions of Assonora Water Treatment Plant (9/9)

Staff Deployed at the Plant	2 Plants (12 MLD & 30 MLD)		
	Person	Qualification	Year of Service
Management Staff - Engineers			Service at plant
Assistant Engineer	1		
Junior Engineer	3		
Assistant Chemist	1		
Lab. Technician	1		
L.D.C	1		
Peon	1		
Watchman	1		
Drivers	4		
Sub-total	13		
Skilled Staff - Operators / Quality Testing			
Work Assistant	2		
Electrician	3		
Pump Operator	1		
Plumber	2		
Assist. Plumber	1		
Assistant Operator	2		
Lab - Technician	1		
Mechanic G - II	3		
Lab - Attendant	2		
Filter Operator	1		
Chlorine Operator	1		
Highly Skilled Labour	2		
Skilled Worker	8		
Assist. Mason	1		
Senior Operator	1		
Sub-total	31		
Unskilled Staff	43	- Junior Operator, Watchman, Sweeper, Khalashi, Labour, Unskilled Worker, Helper, Workman	
Total Number	87		



**Figure M31.4.2 Monthly Water Quality of Assonora Water Treatment Plant, 12MLD
Analysed by PWD's Laboratory from January 2003 to May 2005 (1/2)**




Figure M31.4.2 Monthly Water Quality of Assonora Water Treatment Plant, 12MLD
Analysed by PWD's Laboratory from January 2003 to May 2005 (2/2)

**Table M31.4.4 Monthly Water Quality of Assonora Water Treatment Plant, 30MLD
Analysed by PWD’s Laboratory from January 2003 to May 2005 (1/2)**


	Color			Odor			Taste			Turbidity (NTU)			pH			Specific Conductivity (/u mhos/cm)		
	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated
Jan-03	0	0		Unobj			Unobj			2.3	1.5		6.9	7.1		41.1	49.4	
Feb-03	0	0		Unobj			Unobj			0.8	0.3		6.7	7.1		44.3	53.8	
Mar-03	0	0		Unobj			Unobj			3.2	1.2		6.3	7.3		51.0	72.4	
Apr-03	0	0		Unobj			Unobj			3.0	1.5		6.7	6.8		58.4	59.8	
May-03	0	0		Unobj			Unobj			3.2	2.0		6.8	6.8		56.6	58.9	
Jun-03	0	0		Unobj			Unobj			13.6	2.5		6.1	7.6		46.5	73.7	
Jul-03	0	0		Unobj			Unobj			3.8	1.5		6.7	7.2		43.3	62.7	
Aug-03	0	0		Unobj			Unobj			2.8	1.0		6.4	6.8		38.8	47.7	
Sep-03	0	0		Unobj			Unobj			3.3	0.9		6.9	7.1		47.4	56.0	
Oct-03	0	0		Unobj			Unobj			1.0	0.6		6.9	7.2		39.9	53.2	
Nov-03	0	0		Unobj			Unobj			1.3	0.8		6.8	7.0		42.4	53.8	
Dec-03	0	0		Unobj			Unobj			0.9	0.5		7.0	7.9		47.3	63.0	
Jan-04	0	0		Unobj			Unobj			1.4	0.5		7.0	8.8		46.7	60.8	
Feb-04	0	0		Unobj			Unobj			1.4	0.3		7.3	7.5		41.2	47.6	
Mar-04	0	0	0	Unobj			Unobj			2.0	0.7	0.7	6.8	7.2	7.0	47.1	56.0	56.7
Apr-04	0	0	0	Unobj			Unobj			2.9	0.5	0.5	6.8	7.9	7.5	48.6	70.3	71.4
May-04	0	0	0	Unobj			Unobj			6.3	1.6	1.5	7.3	7.1	7.1	102.4	101.4	109.5
Jun-04	0	0	0	Unobj			Unobj			2.6	1.3	1.0	6.8	7.0	7.1	53.1	56.3	56.0
Jul-04	0	0	0	Unobj			Unobj			6.2	1.4	1.0	6.7	7.9	7.7	55.2	64.7	64.9
Aug-04	0	0	0	Unobj			Unobj			4.8	1.5	1.4	7.0	7.2	7.2	48.1	52.1	53.5
Sep-04	0	0	0	Unobj			Unobj			4.8	2.0	1.4	6.9	7.3	7.2	50.8	51.2	52.2
Oct-04	0	0	0	Unobj			Unobj			1.0	0.5	0.4	7.1	7.3	7.2	48.8	40.0	40.4
Nov-04	0	0	0	Unobj			Unobj			1.0	0.8	0.9	6.7	6.8	6.8	44.3	50.8	53.6
Dec-04	0	0	0	Unobj			Unobj			2.0	1.2	1.5	7.2	7.5	8.1	44.6	56.0	56.9
Jan-05	0	0	0	Unobj			Unobj			1.8	1.0	1.0	7.2	7.5	7.5	45.8	54.6	56.5
Feb-05	0	0	0	Unobj			Unobj			2.0	1.7	1.7	6.9	7.1	7.1	44.5	56.3	57.0
Mar-05	0	0	0	Unobj			Unobj			2.5	1.3	1.3	6.7	7.1	7.0	45.9	58.6	58.5
Apr-05	0	0	0	Unobj			Unobj			3.0	1.5	1.3	6.5	7.1	7.1	53.2	65.5	65.7
May-05	0	0	0	Unobj			Unobj			3.4	1.9	2.0	7.1	7.2	7.2	50.3	59.8	62.2
Max	0	0								13.6	2.5	2	7.3	8.8	8.1	102.4	101.4	109.5
Min	0	0		Unobj			Unobj			0.8	0.3	0.4	6.1	6.8	6.8	38.8	40.0	40.4
Average	0.0	0.0	0.0							3.0	1.2	0.6	6.8	7.3	3.8	49.2	58.8	31.6

	Total Solids (mg/L)			Total Dissolved Solids (TDS) (mg/L)			Suspended Solids (mg/L)			Total Hardness as CaCO ₃ (TALK) (mg/L)			Ca ²⁺ (mg/L)			Mg ²⁺ (mg/L)		
	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated
Jan-03	26.0	31.0		26.0	31.0		0.0	0.0		12.0	14.0		3.6	4.4		0.8	0.3	
Feb-03	29.0	35.0		29.0	35.0		0.0	0.0		13.0	16.0		3.6	4.8		1.0	1.0	
Mar-03	33.0	45.0		32.0	46.0		1.5	0.0		17.0	28.0		3.6	8.4		2.0	2.0	
Apr-03	38.0	39.0		37.0	39.0		1.0	0.0		23.0	24.0		4.0	4.4		3.3	3.3	
May-03	38.0	37.0		36.0	37.0		2.0	0.0		25.0	25.0		4.8	4.8		3.3	3.3	
Jun-03	34.0	47.0		30.0	47.0		4.0	0.0		19.0	37.0		3.6	9.6		2.5	3.3	
Jul-03	29.5	40.0		28.0	40.0		1.5	0.0		15.0	23.0		3.6	6.0		1.5	2.0	
Aug-03	26.0	31.0		25.0	31.0		1.0	0.0		16.0	20.0		3.2	4.8		2.0	2.0	
Sep-03	31.5	36.0		30.0	36.0		1.5	0.0		16.0	23.0		3.2	6.0		2	2.0	
Oct-03	26.0	34.5		26.0	34.5		0.0	0.0		16.0	20.0		3.2	5.6		2.0	1.0	
Nov-03	27.0	34.0		27.0	34.0		0.0	0.0		16.0	22.0		3.6	5.6		1.8	2.0	
Dec-03	30.0	39.0		30.0	39.0		0.0	0.0		17.0	26.0		3.6	6.4		2.0	2.5	
Jan-04	30.0	39.0		30.0	39.0		0.0	0.0		16.0	25.0		3.6	6.4		1.8	2.3	
Feb-04	26.0	30.0		26.0	30.0		0.0	0.0		14.0	19.0		3.6	5.2		1.3	1.5	
Mar-04	29.5	36.0	36.0	30.0	36.0	36.0	0.5	0.0	0.0	15.0	20.0	20.0	3.6	5.6	5.6	1.5	1.5	1.5
Apr-04	31.5	45.0	45.5	31.0	45.0	45.5	0.5	0.0	0.0	15.0	25.0	25.0	3.2	7.2	7.2	1.8	1.8	1.8
May-04	67.0	65.0	70.0	65.0	65.0	70.0	2.0	0.0	0.0	40.0	40.0	40.0	10.0	10.0	10.0	3.8	3.8	3.8
Jun-04	34.0	36.0	36.0	33.5	36.0	36.0	0.5	0.0	0.0	14.0	16.0	16.0	3.2	4.0	4.0	1.5	1.5	1.5
Jul-04	37.5	41.5	41.5	35.5	41.5	41.5	2.0	0.0	0.0	18.0	26.0	26.0	4.4	7.2	7.2	1.8	2.0	2.0
Aug-04	32.0	33.0	34.0	31.0	33.0	34.0	1.0	0.0	0.0	17.0	20.0	20.0	4.0	4.8	4.8	1.8	2.0	2.0
Sep-04	33.0	33.0	33.5	32.0	33.0	33.5	1.0	0.0	0.0	15.0	19.0	19.0	4.0	4.8	4.8	1.3	1.8	1.8
Oct-04	31.0	31.5	31.5	31.0	31.5	31.5	0.0	0.0	0.0	17.0	17.0	17.0	4.8	4.8	4.8	1.3	1.3	1.3
Nov-04	28.0	32.5	34.0	28.0	32.5	34.0	0.0	0.0	0.0	14.0	18.0	18.0	3.6	4.8	4.8	1.3	1.5	1.5
Dec-04	29.5	36.0	36.5	28.5	36.0	36.5	0.0	0.0	0.0	15.0	20.0	21.0	3.6	5.6	6.0	1.5	1.5	1.5
Jan-05	29.5	35.0	36.0	29.0	35.0	36.0	0.5	0.0	0.0	14.0	17.0	17.0	3.6	4.8	4.8	1.2	1.3	1.3
Feb-05	28.0	36.0	36.0	28.0	36.0	36.0	0.0	0.0	0.0	13.0	17.0	17.0	3.2	4.8	4.8	1.3	1.3	1.3
Mar-05	29.0	37.5	37.5	29.0	37.5	37.5	0.0	0.0	0.0	14.0	18.0	18.0	3.2	4.8	4.8	1.5	1.5	1.5
Apr-05	35.0	42.0	42.0	34.0	42.0	42.0	1.0	0.0	0.0	19.0	25.0	25.0	5.2	7.2	7.2	1.5	1.8	1.8
May-05	33.0	38.0	40.0	32.0	38.0	40.0	1.0	0.0	0.0	17.0	20.0	20.0	4.0	5.2	5.2	1.8	1.8	1.8
Max	67.0	65.0	70.0	65.0	65.0	70.0	4.0	0.0	0.0	40.0	40.0	40.0	10.0	10.0	10.0	3.8	3.8	3.8
Min	26.0	30.0	31.5	25.0	30.0	31.5	0.0	0.0	0.0	12.0	14.0	16.0	3.2	1.8	4.0	0.8	0.3	1.3
Average	32.1	37.8	20.3	31.4	37.8	20.3	0.8	0.0	0.0	17.0	22.1	11.0	3.9	5.7	3.0	1.8	1.9	0.9


**Table M31.4.4 Monthly Water Quality of Assonora Water Treatment Plant, 30MLD
Analysed by PWD's Laboratory from January 2003 to May 2005 (2/2)**

	Cl ⁻ (mg/L)			Total Alkalinity as CaCO ₃ (mg/L)			SO ₄ ⁻ (mg/L)			Fe ²⁺ (mg/L)			Mn ²⁺ (mg/L)			NO ₃ ⁻ (mg/L)			KMnO ₄ oxidizability as O ₂ (mg/L)		
	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated
Jan-03	6.0	6.0		12.0	13.0		0.0	0.0		0.05	0.05		0.00	0.00		0.6	0.0		0.2	0.0	
Feb-03	6.0	6.0		13.0	16.0		0.0	0.0		0.05	0.05		0.24	0.00		0.4	0.0		0.2	0.0	
Mar-03	6.0	6.0		16.0	29.0		0.0	0.0		0.06	0.05		0.00	0.00		1.3	0.0		0.2	0.0	
Apr-03	6.0	6.0		21.0	23.0		0.0	0.0		0.30	0.05		0.00	0.00		0.7	0.0		0.2	0.0	
May-03	6.0	6.0		23.0	23.0		0.0	0.0		0.06	0.05		0.00	0.00		0.4	0.0		0.2	0.0	
Jun-03	4.0	4.0		20.0	32.0		0.0	0.0		0.45	0.06		0.00	0.00		0.8	0.0		0.4	0.0	
Jul-03	6.0	6.0		16.0	20.0		0.0	0.0		0.10	0.05		0.00	0.00		0.9	0.0		0.3	0.0	
Aug-03	6.0	6.0		17.0	17.0		0.0	0.0		0.20	0.05		0.00	0.00		0.4	0.0		0.3	0.0	
Sep-03	6.0	6.0		17	20.0		0.0	0.0		0.05	0.05		0.00	0.00		0.8	0.0		0.2	0.0	
Oct-03	6.0	6.0		23.0	25.0		0.0	0.0		0.10	0.05		0.00	0.00		0.9	0.0		0.2	0.0	
Nov-03	6.0	6.0		20.0	23.0		0.0	0.0		0.05	0.05		0.10	0.00		0.4	0.0		0.2	0.0	
Dec-03	6.0	6.0		18.0	24.0		0.0	0.0		0.06	0.05		0.08	0.00		0.8	0.0		0.4	0.0	
Jan-04	6.0	6.0		18.0	26.0		0.0	0.0		0.10	0.05		0.00	0.00		1.9	0.0		0.4	0.0	
Feb-04	6.0	6.0		18.0	22.0		0.0	0.0		0.05	0.05		0.00	0.00		1.5	0.0		0.3	0.0	
Mar-04	6.0	6.0	6.0	20.0	23.0	23.0	0.0	0.0	0.0	0.12	0.05	0.05	0.00	0.00	0.00	1.2	0.0	0.0	0.3	0.0	0.0
Apr-04	6.0	6.0	6.0	21.0	35.0	32.0	0.0	0.0	0.0	0.08	0.05	0.05	0.00	0.00	0.00	1.0	0.0	0.0	0.3	0.0	0.0
May-04	7.0	7.0	9.0	44.0	44.4	44.0	0.0	0.0	0.0	0.60	0.10	0.10	0.00	0.00	0.00	1.4	0.0	0.0	0.6	0.0	0.0
Jun-04	7.0	7.0	7.0	15.0	18.0	18.0	0.0	0.0	0.0	0.06	0.05	0.05	0.00	0.00	0.00	0.6	0.0	0.0	0.2	0.0	0.0
Jul-04	7.0	7.0	7.0	17.0	28.0	28.0	0.0	0.0	0.0	0.30	0.05	0.05	0.12	0.00	0.00	0.8	0.0	0.0	0.4	0.0	0.0
Aug-04	6.0	6.0	7.0	17.0	18.0	18.0	0.0	0.0	0.0	0.20	0.10	0.10	0.00	0.00	0.00	0.5	0.0	0.0	0.3	0.0	0.0
Sep-04	6.0	6.0	7.0	16.0	21.0	21.0	0.0	0.0	0.0	0.06	0.06	0.06	0.00	0.00	0.00	0.4	0.0	0.0	0.2	0.0	0.0
Oct-04	6.0	6.0	6.0	18.0	19.0	19.0	0.0	0.0	0.0	0.06	0.05	0.05	0.00	0.00	0.00	0.0	0.0	0.0	0.0	0.0	0.0
Nov-04	6.0	6.0	7.0	16.0	19.0	19.0	0.0	0.0	0.0	0.06	0.05	0.05	0.10	0.00	0.00	0.2	0.0	0.0	0.0	0.0	0.0
Dec-04	6.0	6.0	6.0	19.0	24.0	25.0	0.0	0.0	0.0	0.06	0.05	0.05	0.00	0.00	0.00	0.0	0.0	0.0	0.2	0.0	0.0
Jan-05	6.0	7.0	8.0	18.0	19.0	19.0	0.0	0.0	0.0	0.40	0.06	0.06	0.00	0.00	0.00	0.0	0.0	0.0	0.0	0.0	0.0
Feb-05	6.0	6.0	6.0	17.0	21.0	21.0	0.0	0.0	0.0	0.06	0.05	0.05	0.00	0.00	0.00	0.6	0.0	0.0	0.3	0.0	0.0
Mar-05	7.0	7.0	7.0	16.0	20.0	20.0	0.0	0.0	0.0	0.10	0.06	0.06	0.00	0.00	0.00	0.4	0.0	0.0	0.2	0.0	0.0
Apr-05	7.0	7.0	8.0	17.0	25.0	25.0	0.0	0.0	0.0	0.10	0.06	0.06	0.12	0.00	0.00	0.5	0.0	0.0	0.3	0.0	0.0
May-05	6.0	8.0	10.0	17.0	18.0	18.0	0.0	0.0	0.0	0.20	0.10	0.10	0.00	0.00	0.00	0.8	0.0	0.0	0.3	0.0	0.0
Max	7.0	8.0	10.0	44.0	44.4	44.0	0.0	0.0	0.0	0.60	0.10	0.10	0.24	0.00	0.00	1.9	0.0	0.0	0.6	0.0	0.0
Min	4.0	4.0	6.0	12.0	13.0	18.0	0.0	0.0	0.0	0.05	0.05	0.05	0.00	0.00	0.00	0.0	0.0	0.0	0.0	0.0	0.0
Average	6.1	6.2	3.7	18.6	22.9	12.1	0.0	0.0	0.0	0.14	0.06	0.03	0.03	0.00	0.00	0.7	0.0	0.0	0.3	0.0	0.0

	BOD at 27°C and 3days (mg/L)			DO (mg/L)			F ⁻ (mg/L)			Al ³⁺ (mg/L)			Plate Count on nutrient agar no/100mL			MPN of Coliform no/100mL			MPN of E. Coli. no/100mL		
	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated
Jan-03	0.5	0.0					0.0	0.0		0.0	0.00		0	0		0	0		0	0	
Feb-03	0.5	0.0					0.0	0.0		0.0	0.00		0	0		0	0		0	0	
Mar-03	0.5	0.0					0.0	0.0		0.0	0.00		86	2		1100	0		150	0	
Apr-03	0.5	0.0					0.0	0.0		0.0	0.00		0	0		0	0		0	0	
May-03	0.5	0.0					0.0	0.0		0.0	0.00		0	0		0	0		0	0	
Jun-03	1.0	0.0					0.0	0.0		0.0	0.33		0	0		0	0		0	0	
Jul-03	1.0	0.0					0.0	0.0		0.0	0.21		0	0		0	0		0	0	
Aug-03	0.5	0.0					0.0	0.0		0.0	0.04		127	3		150	0		93	0	
Sep-03	0.5	0.0					0.0	0.0		0.0	0.02		140	1		93	0		43	0	
Oct-03	0.5	0.0		7.1	7.2		0.0	0.0		0.0	0.04		137	0		460	0		240	0	
Nov-03	0.5	0.0		7.1	7.2		0.0	0.0		0.0	0.04		70	28	1	430	0		230	0	
Dec-03	1.9	0.0		7.2	7.4		0.0	0.0		0.0	0.05		82	13	0	460	23		460	0	
Jan-04	1.2	0.0		7.3	7.4		0.0	0.0		0.0	0.00		82	13	0	460	23		460	0	
Feb-04	0.8	0.0		7.3	7.4		0.0	0.0		0.0	0.00		88	40	0	460	460		460	240	
Mar-04	0.8	0.0	0.0	7.2	7.3	7.3	0.0	0.0	0.0	0.0	0.00	0.00	104	4	2	43	0	0	23	0	0
Apr-04	0.6	0.0	0.0	7.2	7.4	7.5	0.0	0.0	0.0	0.0	0.00	0.00	135	75	2	240	93	0	9	7	0
May-04	1.2	0.0	0.0	6.9	7.0	7.2	0.0	0.0	0.0	0.0	0.00	0.00	107	67	2	1100	460	0	460	93	0
Jun-04	0.6	0.0	0.0	6.9	7.5	7.5	0.0	0.0	0.0	0.0	0.00	0.00	87	12	1	240	4	0	240	0	0
Jul-04	1.1	0.0	0.0	7.1	7.2	7.2	0.0	0.0	0.0	0.0	0.10	0.1	220	140	3	93	93	0	43	21	0
Aug-04	0.5	0.0	0.0	7.0	7.3	7.4	0.0	0.0	0.0	0.0	0.05	0.05	123	12	0	240	43	0	93	0	0
Sep-04	0.5	0.0	0.0	7.0	7.4	7.4	0.0	0.0	0.0	0.0	0.05	0.05	192	15	0	240	21	0	21	0	0
Oct-04	0.0	0.0	0.0	7.2	7.4	7.4	0.0	0.0	0.0	0.0	0.04	0.04	180	4	0	460	9	0	240	0	0
Nov-04	0.0	0.0	0.0	7.1	7.3	7.4	0.0	0.0	0.0	0.0	0.01	0.01	140	25	2	460	39	0	21	7	0
Dec-04	0.5	0.0	0.0	7.5	7.6	7.6	0.0	0.0	0.0	0.0	0.01	0.01	71	12	2	1100	23	0	240	4	0
Jan-05	0.0	0.0	0.0	7.5	7.6	7.6	0.0	0.0	0.0	0.0	0.01	0.01	88	5	3	93	0	0	28	0	0
Feb-05	0.5	0.0	0.0	7.3	7.5	7.5	0.0	0.0	0.0	0.0	0.00	0.00	45	35	2	93	4	0	0	0	0
Mar-05	0.5	0.0	0.0	7.5	7.8	7.8	0.0	0.0	0.0	0.0	0.00	0.00	112	12	0	93	15	0	23	0	0
Apr-05	0.5	0.0	0.0	7.4	7.6	7.6	0.0	0.0	0.0	0.0	0.00	0.00	178	15	2	460	4	0	240	0	0
May-05	0.6	0.0	0.0	7.0	7.2	7.2	0.0	0.0	0.0	0.0	0.02	0.02	120	35	0	1100	3	0	23	0	0
Max	1.9	0.0	0.0	7.5	7.8	7.8	0.0	0.0	0.0	0.3	0.1	0.1	220	140	3	1100	460	0	460	240	0
Min	0.0	0.0	0.0	6.9	7.0	7.2	0.0	0.0	0.0	0.0	0.0	0.0	0	0	0	0	0	0	0	0	0
Average	0.6	0.0	0.0	5.0	4.8	3.8	0.0	0.0	0.0	0.0	0.0	0.0	93.6	19.6	0.8	333.4	45.4	0.0	132.4	12.8	0.0



**Figure M31.4.3 Monthly Water Quality of Assonora Water Treatment Plant, 30MLD
Analysed by PWD's Laboratory from January 2003 to May 2005 (1/2)**



**Figure M31.4.3 Monthly Water Quality of Assonora Water Treatment Plant, 30MLD
Analysed by PWD's Laboratory from January 2003 to May 2005 (2/2)**

Table M31.4.5

List of Reservoirs for the Assonora Water Supply Scheme (1/3)

Series No.	System	Name of GLR / OHR (Name of Location)	GLR/OHR			Elevation (m)		Supply Area		Remarks	
			Type	Capacity (m3)	RL	HWL	LWL	Taluka	Village Name		
1	Assonora WTP	Assonora WTP	GLR	1,200							
2			GLR	1,000	15.00						
3			GLR	1,000							
4			GLR	2,000							
		Sub-Total		5,200							
5	Assonora MBR	Assonora MBR	GLR	800							
6			GLR	800							
7			GLR	800	120.00	124.00	120.00				
8			GLR	800							
9			GLR	5,000							
		Sub-Total		8,200							
10	350 (Old)	Sirsaim	GLR	300	48.60	52.60	48.90	Bardez	Sirsaim(8)		
11		Cansa-Bodiem	GLR	50	46.80	49.30	47.10	-ditto-	Tivim(9)		
12		Colvale	GLR	150	50.00	54.00	50.30	-ditto-	Colvale(CT)(35)		
13		Tivim-IDC	OHR	150	50.00	69.00	65.00	-ditto-	Tivim(9), Mapusa(M CT)(36)		
14		Verla-Canca	GLR	150	65.00	69.00	65.30	-ditto-	Verka(16), Canca(17)		
15			GLR	800	65.00	69.00	65.30	-ditto-			
16		Parra	GLR	150	42.00	46.00	42.30	-ditto-	Parra(15)		
			Sub-Total		1,750						
17			Quitula	GLR	50	47.00	49.50	47.30	Bardez	Aldona(CT)(44)	
18			Aldona	GLR	50	33.46	37.46	33.76	-ditto-		
19			GLR	300	33.46	37.46	33.76	-ditto-	Ponolem(25), Calvim(26), Aldona(CT)(44)		
20		Khorjuem	GLR	150	29.10	33.10	29.40	-ditto-	Corjuem(24)		
21		Nachimola	OHR	50	25.20	44.20	41.20	-ditto-			
22			OHR	150	48.45	67.45	64.45	-ditto-	Nachimola(23)		
23			GLR	300	25.20	29.20	25.20	-ditto-			
24	400	Moirra	OHR	150	47.00	66.00	63.00	-ditto-	Moirra(22)		
25		Lakuem	GLR	300	38.15	42.15	38.45	-ditto-	Aldona(CT)(44)		
26		Olaulim	GLR	150	66.00	70.00	66.00	-ditto-	Olaulim(27),		
27		Pomburpa	GLR	300	53.11	57.11	53.41	-ditto-	Pomburpa(28)		
28		Ecoxim	GLR	300	38.15	42.15	38.45	-ditto-	Pomburpa(28)		
29		Salai	GLR	150	56.42	60.42	56.72	-ditto-	Salvador do Mundo(33)		
30			GLR	800	56.42	60.42	56.72	-ditto-			
			Sub-Total		3,200						

Table M31.4.5 List of Reservoirs for the Assonora Water Supply Scheme (2/3)

Series No.	System	Name of GLR / OHR (Name of Location)	Capacity (m3)		Elevation (m)			GLR/OHR		Supply Area		Remarks
			Type	(m3)	RL	HWL	LWL	Taluka	Village Name			
31		Assonora	GLR	150	80.00	84.00	80.30	Bardez	Moitem(6), Assonora(7)			
32		Tivim	GLR	350	51.00	55.00	51.00	-ditto-	Tivim(9)			
33		Accoi	OHR	150	47.00	66.00	63.00	-ditto-	Mapusa(MCI)(36)			
34		Khorlim	GLR	300	78.00	82.00	78.30	-ditto-	Mapusa(MCI)(36)			
35		Bastora	GLR	250	46.00	50.00	46.30	-ditto-	Bastora(18), Palitem(19), Punolat(20), Ucassaim(21)			
36		Anjuna	GLR	800	49.00	53.00	49.30	-ditto-	Assagaol(11)			
37		Girim	GLR	150	42.00	46.00	42.30	-ditto-	Guirim(CT)(37)			
38			OHR	650	42.00	71.00	68.00	-ditto-	Guirim(CT)(37)			
39		Calangute	OHR	150	25.00	44.00	40.00	-ditto-	Calangute(CT)(39)			
40		Torda	OHR	800	60.00	84.00	80.00	-ditto-	Salvador do Mundo(33), Penha-de-Franca(CT)(42), Socorro(Serula)(CT)(43)		w / Pump	
41	700		GLR	300	60.00	64.00	60.30	-ditto-				
42		Porvolim	OHR	150	58.00	77.00	73.00	-ditto-	Pilerne(32), Socorro(Serula)(CT)(43)		w / Pump	
43			GLR	800	58.00	62.00	58.00	-ditto-				
44		Pilerna	GLR	150	50.00	54.00	50.30	-ditto-	Marra(31), Pilerne(32)			
45		Verem	GLR	250	70.00	74.00	70.30	-ditto-	Reis Magos(CT)(41)			
46		Alto-Betim	GLR	150	55.00	59.00	55.30	-ditto-	Reis Magos(CT)(41)			
47		Pundalik Nagar	GLR	300	55.00	59.00	55.30	-ditto-	Penha-de-Franca(CT)(42)		w / Pump	
48			OHR	300	55.00	74.00	70.00	-ditto-				
49		Secretariate Complex	GLR					-ditto-	≈200 m ³ /day			
50		Nerul	GLR	150	55.00	59.00	55.30	-ditto-	Nerul(30)			
		Sub-Total		6,300								
51		Pirna	GLR	50	41.00	45.00	41.30	Bardez				
52			GLR	150	41.00	45.00	41.30	-ditto-	Pirna(5)			
53			GLR	300	41.00	45.00	41.30	-ditto-				
54		Nadora	GLR	100	48.00	52.00	48.30	-ditto-				
55			GLR	300	48.00	52.00	48.30	-ditto-	Nadora(4)			
56		Revora	GLR	50	49.00	53.00	49.30	-ditto-	Revora(3)			
57			GLR	300	49.00	53.00	49.30	-ditto-				
58	1100	Colvale	GLR	300	48.00	52.00	48.30	-ditto-	Colvale(CT)(35)			
59		Chicalim	GLR	150	50.00	54.00	50.30	-ditto-	Camurlim(2)			
60		Camurlim	GLR	300	48.00	52.00	48.30	-ditto-	Camurlim(2)			
61		Cuchelim	GLR	150	49.00	53.00	49.30	-ditto-	Mapusa(MCI)(36)			
62		Sodiem	GLR	300	51.00	55.00	51.30	-ditto-	Siolim(CT)(34), Oxel(1)			
63		Oxel	GLR	300	49.00	53.00	49.30	-ditto-				
64		Peddem	OHR	300	50.00	69.00	66.00	-ditto-	Mapusa(MCI)(36)			
65		Marna	GLR	150	78.00	82.00	78.30	-ditto-	Marna(10)			

Table M31.4.5 List of Reservoirs for the Assonora Water Supply Scheme (3/3)

Series No.	System	Name of GLR / OHR (Name of Location)	GLR/OHR			Elevation (m)		Supply Area		Remarks
			Type	Capacity (m3)	RL	HWL	LWL	Taluka	Village Name	
66	1100	Siolim	GLR	150	50.00	54.00	50.30	-ditto-	Siolim(CT)(34),	
67		GLR	800	50.00	54.00	50.30	-ditto-			
68		GLR	300	47.00	51.00	47.30	-ditto-	Uassaim(21)		
69		GLR	800	48.00	52.00	48.30	-ditto-	Assagao(11)		
70		GLR	800	40.00	44.00	40.30	-ditto-	Arjuna(12)		
71		GLR	250	50.00	54.00	50.30	-ditto-	Arpora(13), Nagoa(14)		
72		GLR	800	30.00	34.00	30.30	-ditto-	Calangute(CT)(39)		
73		GLR	150	40.00	44.00	40.30	-ditto-	Candolim(CT)(40)		
74		GLR	800	40.00	44.00	40.30	-ditto-			
75		GLR	800	48.00	52.00	48.30	-ditto-	Candolim(CT)(40)		
76		GLR	150	30.00	34.00	30.30	-ditto-			
77	GLR	800	48.00	52.00	48.30	-ditto-	Saligao(CT)(38)			
78	GLR	300	48.00	52.00	48.30	-ditto-	Sangolda(29)			
79	GLR	150	50.00	54.00	50.30	-ditto-	Socorro(Serula)(CT)(43)			
80	OHR	150	55.00	74.00	70.00	-ditto-	Socorro(Serula)(CT)(43), Sangolda(29)			
81	GLR	150	55.00	59.00	55.30	-ditto-				
82	Sump	300	55.00					w / Pump		
		Sub-Total		10,850						
83	Housing Board	OHR	100	87.00	106.00	103.00	Bardez			
84		OHR	150	85.00	104.00	101.00	-ditto-			
85		OHR	300	87.00	107.00	103.00	-ditto-			
86	1200 P/Main	GLR	2,000	75.00	79.00	75.30	-ditto-	Mapusa(M CI)(36)		
87		GLR	800	80.00	84.00	80.30	-ditto-			
88		GLR	650	67.00	71.00	67.30	-ditto-			
89		GLR	650	67.00	71.00	67.30	-ditto-			
90		GLR	300	85.00	89.00	85.30	-ditto-			
91	GLR	800	85.00	89.00	85.30	-ditto-				
92	GLR	150	66.00	70.00	66.30	-ditto-	Assagao(11), Parra(15), Verla(16), Canca(17), Mapusa(M CI)(36)			
93	OHR	3,000	80.00	84.00	80.00	-ditto-	P'leme(32), Reis Magos(CT)(41), Penha-de-Franca(CT)(42)			
		Sub-Total		8,900						
94	Assonora North	GLR	50	51.00	55.00	51.30	Bicholim	Sirigao(6), Maam(12)		
95	(Bicholim Taluka)	GLR	800	41.00	45.00	41.30	-ditto-	Adwalpale(5), Sirigao(6)		
		Sub-Total		850						
		Total		45,250						
				19.1 hrs						

Note: RL=Reduced Elevation, HWL=High Water Level in Reservoir, LWL=Low Water Level in Reservoir, GLR=Ground Level Reservoir, OHR=Over Head Reservoir, MBR=Master Balancing Reservoir

M31.5 Sanquelim Water Supply Scheme

Table M31.5.1 lists the summary of asset data for the WTP and Table M31.5.2 contains detailed asset data for the WTP. The plant schematic is shown on Figure M31.5.1. Tables M31.5.3 and M31.5.4 and Figures M31.5.2 and M31.5.3 show the data on monthly water quality at Chandel Water Treatment Plant. Table M31.5.5 shows a list of existing reservoirs for Sanquelim Water Supply Scheme.

Podocem WTP

The Podocem WTP was built recently (2003) and has a design capacity of 40 MLD. The newly constructed raw water pump house supplies the plant with water from the Valvant River. The water is pumped approximately 0.6 km from the river. There are three pumps (two duty). These pumps are not adequately guarded. A record of running hours, loads etc. is logged. The operation and maintenance of the pump house and treatment plant has been contracted to a local company (run by a retired PHE engineer) on a three monthly basis. This may be revised to be a longer contract (2-5 years).

The pump house compound also contains a pump house that was commissioned in 1992. It contains two pumps (one duty). These pumps are not adequately guarded. This pump house supplies 25 MLD to the Assonora WTP via a short rising main to a reservoir. The water is fed by gravity from the reservoir to the Assonora WTP which is located approximately 20 km away. A log of running hours, loads etc. is maintained.

A third pump house, which contains two pumps (one duty) was commissioned in 1972. This pump house supplies water to the 12 MLD Sanquelim WTP via a 0.6 km rising main. This pump house is untidy and the pumps are not adequately guarded. A log of running hours, loads etc. is maintained.

Both the raw water pumping compound and the treatment plant compound are adequately gated, fenced and secured by 24 hour on-site security personnel. The plant is in operation 24 hours a day using a three shift system.

Flow measurement devices are not provided on-site. Therefore, the amount of raw water supplied to the plant, as well as the amount of clean water fed to the transmission system via the clean water reservoirs, is estimated based on pump design capacities and hours of operation.

Logs are maintained for pump running hours, loads etc, however maintenance records are not

kept. There is a well established system of monthly oiling and greasing. However, other maintenance is reactive. No operation and maintenance manuals are available. Training for new staff is only provided on the job by existing experienced staff. There are no written or formal safety systems for plant operation.

The treatment plant is manually controlled but the valves are operated remotely by pneumatic actuators. The plant is new and appears to be in good working order, including the alum and lime mixers. Generally, the maintenance standards are good, however the pump couplings/shafts are not adequately guarded.

Logs are kept for pump running hours, load, filter backwashing, and clear water reservoir levels. However, there are no maintenance logs recording repairs to assets or maintenance/breakdown problems. Logs are kept by the laboratory staff for chemical usage and treatment parameters.

Disinfection is achieved using gas chlorination. The chlorination uses one tonne cylinders. There are usually two cylinders in the chlorine house at any one time. There are two vacuum type chlorinators (Metito Mach4). Maintenance of the chlorinators is performed in-house, however the chlorinators are not periodically calibrated and records of maintenance are not kept. Operation and maintenance practices for chlorine use are poor. Ammonia solution is used to detect leaks from the pipe and from the connection joints. There are no facilities to adequately detect or contain gas leaks, in particular, no immersion tank is available. Personal breathing apparatus is available in the laboratory but is not used or maintained. The copper connection pipes are repaired locally and appear to be in poor condition. These existing pipes should be discarded and not repaired. The galvanised iron feed pipe to the contact tank is badly corroded and should be replaced.

The clean water reservoirs are cleaned annually. During cleaning, the covers are removed to aid natural ventilation and to allow the workers to enter. The workers undertake the sludge removal and flushing. There are no safety precautions, safety equipment or safety systems.

Sanquelim WTP

The WTP consists of a 7 MLD plant and a 5 MLD plant. Both of these plants were commissioned around 1972. The plants are manually operated. Despite their age, the plants appear to be in good working condition. Maintenance standards appear to be reasonable across the site, except for the chemical mixing areas. The chlorine house is equipped with a one tonne cylinder and one vacuum type chlorinator. There are no standbys. Logs are maintained for pump run hours, load, chemical use and treatment parameters.

Table M31.5.1 Summary of Asset Register of Sanquelim Water Treatment Plant

(1) Sanquelim Plant, 5MLD and 7MLD

Name of Facility		5 MLD	7 MLD	Remarks
Raw Water Intake & Raw Water Transmission Facility	Connecting Pipe & Jack Well	D500mm × CIP × 1 Line, Jack Well: D6.2 m		Valvant River
	Pump & Motor	Vertical Pump: 9216m ³ /hr × 17.5m × 75kw × 1 unit, 9324m ³ /hr × 17.5m × 100kw × 2 units, 9375m ³ /hr × 110kw × 1 unit (1 or 2 – Standby)	D450mm × 600m × C.I.P./M.S.P. × 1 Line	Design Cap. of Intake Pump = 13~16MLD
Treatment Facility	Raw Water Transmission Main	D350mm × 600m × C.I.P. × 1 Line		
	Aerator	Cascade Type: 1 unit	Cascade Type: 1 unit	
	Parshal Flume	1 unit (for Chemical Dosing)	1 unit (for Chemical Dosing)	
	Clariflocculator	Circular Horizontal Flow Type with Center Feed/Peripheral Collection Flocculation & Clarifier: 13.6m (Flocc. Zone 3.4m) × WD3.2m × 1 unit Detention Period: Flocculation – 8.0min Clarifier – 2.0 hrs Surface Loading: 38.6 m ³ /m ² /d (26.8 mm/min) ²⁾	Circular Horizontal Flow Type with Center Feed/Peripheral Collection Flocculation & Clarifier: 20.0m (Flocc. Zone 5.0m) × WD3.35m × 1 unit Detention Period: Flocculation – 12.9min Clarifier – 3.2hrs Surface Loading: 24.9 m ³ /m ² /d (17.3 mm/min) ²⁾	1): 2~2.5 hrs 2): 30~40m ³ /m ² /d
Filter	Gravity Rapid Sand Filter Type 5.55m × 15.0m × 2cells/basin × 2 basins Effective Size of Sand: 0.7?mm, Depth of Sand: 0.65m Filter Area: 13.9 m ² /cell, 27.8 m ² /basin Filtration Rate: 3.9 m/hr ³⁾ (94.6 m/d) Air Scouring Rate: ?m/hr/cell ⁴⁾ (? m ³ /min/m ² /cell) Backwash Rate: 8.4 m/hr/cell ⁵⁾ (0.14 m ³ /min/m ² /cell)	Gravity Rapid Sand Filter Type 5.1m × 12.6m × 2cells/basin × 3 basins Effective Size of Sand: 0.7?mm, Depth of Sand: 0.65m Filter Area: 6.65 m ² /cell, 13.3 m ² /basin Filtration Rate: 7.7 m/hr ³⁾ (185 m/d) Air Scouring Rate: ?m/hr/cell ⁴⁾ (? m ³ /min/m ² /cell) Backwash Rate: 12 m/hr/cell ⁵⁾ (0.20 m ³ /min/m ² /cell)	Based on Specifications of Air Blower & Backwash Pump 3): 4.8~6.0m/hr 4): 36~54m/hr 5): 24~36m/hr	
Chemical Feeding Facility	Alum Feeding	Dry Aluminum Sulfate Solution Tank: 3 units Powder Lime	Dry Aluminum Sulfate Solution Tank: 3 units Powder Lime	
	Lime Feeding	Solution Tank: 3 units	Solution Tank: 3 units	
	Disinfection Facility	Liquid Chlorine (1 tone Container – net 900kg) Chlorinator: 2 units	Liquid Chlorine (1 tone Container – net 900kg) Chlorinator: 2 units	
Laboratory	Frequency of Sampling Analysis &	Not In-Service, Jar Test: Not in Service Every Hour: pH, R-CI Fortnightly: Turbidity, pH, Alkalinity, Hardness, Chlorine, Mn, Fe, D.O., R-CI		
Clear Water Transmission Facility	Water Reservoir	Volume=800 m ³ × 1 unit, Retention Time: 3.8 hr	Volume=1,000 m ³ × 1 unit, Retention Time: 3.4 hr	
	(Note: 1) ~ 4) are referring to "Manual on Water Supply and Treatment, Third Edition – Revised and Updated, May 1999"			

(2) Podocem Plant, 40MLD

Name of Facility		Contents of Facility	Remarks
Raw Water Intake & Raw Water Transmission Facility	Intake Well	D8.0m × H 3.5m × 1 unit	Valvant River
	Connecting Pipe	D900mm × H 13m × 1 unit	
	Jack Well & P. H.	D8.0m × H 21.0m × 1 Line	
	Pump & Motor	Vertical Pump: Q 835m ³ /hr × H 140.0m × 456kw × 3 units (1 – Standby)	Design Cap. of Intake Pump = 40MLD/system
	Rising Main	D750mm × 636m × M.S.P. × 1 Line	
Treatment Facility	Stilling Chamber	W 3.0m × L 3.0m × W^H 3.1m × Vol 27.9m ³ × 1 unit × RP 1min	RP: Retention period
	Aerator	Cascade Type: 1 unit	
	Parshal Flume	1 unit (for Chemical Dosing)	
	Contact Aeration Tank	D 17.0m × W^H 5.0m × Vol 1,135m ³ × 1 unit × RP 38.9min	RP: Retention period
	Flash Mixer	1 unit with Flocculation Channel	
	Clarifier	Sludge Blanket Lamella Clarifier with PVC Tube Modules: W 14.0m × L 14.0m × W^H 5.0m × 2 units Detention Period: Clarifier – 1.1 hrs ¹⁾ Surface Loading for Clarifier: 107.1 m ³ /m ² /d (74.4 mm/min) ²⁾	1): 2~2.5 hrs 2): 30~40m ³ /m ² /d
	Filter	Gravity Rapid Sand Filter Type W 4.5m × L 9.5m × 2cells/basin × 4 basins Effective Size of Sand: 0.??mm, Depth of Sand: 0.??m Filter Area: 21.4 m ² /cell, 42.8 m ² /basin Filtration Rate: 10.2 m/hr ³⁾ (245 m/d) Air Scouring Rate: 7.2m/hr/cell ⁴⁾ (0.12m ³ /min/m ² /cell) Backwash Rate: 28.2m/hr/cell ⁵⁾ (0.47m ³ /min/m ² /cell) – using 600m ³ Backwash Tank	Based on Specifications of Air Blower & Backwash Pump 3): Higher than Standard(4.8 ~ 6.0m/hr) 4): 36~54m/hr 5): 24~36m/hr
Dirty Water Sump	D 13.0m × W^H 1.5m × Vol 199m ³ × 1 unit		
Clear Water Transmission Facility	Parshal Flume	1unit for Post-Chlorination	
	Clear Water Reservoir	Total Volume=5,000 m ³ × 2units Retention Time: 4.6 hr	
Chemical Feeding Facility	Alum Feeding Facility	Dry Aluminum Sulfate Solution Tank: 3 units	
	Lime Feeding Facility	Powder Lime Solution Tank: 3 units	
	Disinfection Facility	Liquid Chlorine (1 tone Container – net 900kg) Chlorinator: 3 units	
Laboratory	Frequency of Sampling & Analysis	In-Service, Jar Test: Not in Service Every Hour: pH, Turbidity, R-Cl, D.O. Fortnightly: 20 Parameters	
Note: 1) ~ 4) are referring to “Manual on Water Supply and Treatment, Third Edition – Revised and Updated, May 1999”			




Figure M31.5.1 Schematic Sequence of Sanquelim Water Treatment Plant

Table M31.5.2

Present Conditions of Sanquelim Water Treatment Plant (1/9)

Item		Contents						Remarks
Background								
Covered Area for Water Supply	Taluka	Part of Bicholim, Liswadi & Sattari						
Name of Plant	Sanquelim W.T.P.	Sanquelim W.T.P.						
Number of W.T.P.	(1)	(2)	Podocem W.T.P.		(3)		TOTAL	
Capacity of Plant	5 MLD	7,000 m ³ /d	40,000		52		52 to Assonara	
Raw Water Resources	Valvant	Valvant	Valvant		Valvant			
Year of Construction	1975	1994	2001 - 2002		2003			
Year of Commission								
Name & Number of W.T.F Number								
Design Capacity of Raw Water Intake & Treated Facility	MLD	7.35	12.60		42.00		54.60 ; 5% Losses of Nominal Capacity	
	m ³ /d	7,350	12,600		42,000		54,600	
Name of Facility								
Sanquelim W.T.P.								
Podocem W.T.P.								
(1) 5 MLD (2) 7 MLD (3) 40 MLD								
TOTAL								
Head Water Works : Raw Water Intake								
Intake Well	Diameter	m	-	-	-	8.0	-	
	Height	m	-	-	-	3.5	-	
	Water Level	m	-	-	-	-	-	
	HWL	m	-	-	-	7.20	-	
	MWL	m	-	-	-	3.00	-	
Connecting Pipe	Volume	m ³ /unit	-	-	-	175.9	-	
	Diameter	mm	500	-	-	900	-	
	Length	m	-	-	-	13.0	-	
	Material		CIP	-	-	-	-	
	Velocity	m/sec	0.155	-	-	0.688	-	
	Loss of Head	m	0.000	-	-	0.010	-	
Jack Well & Pump House	Diameter	m	6.20	-	-	8.00	-	
	Water Depth	m	-	-	-	10.70	-	
	Height	m	-	-	-	21.50	-	
	Inlet Gate	unit	3	-	-	-	-	
	Volume	m ³ /unit	-	-	-	537.8	-	
	Detention Time	min	-	-	-	18.4	-	
M.C.C. & Store Room	Width	m	3.00	-	-	-	-	
	Length	m	7.00	-	-	-	-	
	Area of Floor	m ²	21.0	-	-	96.0	-	
Raw Water Pump	Capacity	l/sec	60.0	90.0	104.2	231.9	Raw Water to Assonara WT	
		m ³ /min	3.60	5.40	6.25	13.92		
		m ³ /hr	216.0	324.0	375.0	835.0		
		m ³ /d	5,184	7,776	9,000	20,040		
	Number	unit	1	2	1	3	2	
	Stand-by	unit	0	1	1	2	Raw Water Res. 800m ³	
	Total Capacity	m ³ /d	12,960	75.0	75.0	140.0		
	Head	m	75.0	75.0	75.0	140.0		
	Maker		Worthington	Worthington	Worthington	N.G.E.F.		
	Year of Manufacture		1994	1994	1994	2003	1993	
	Assessment of Condition		Working, Valves Leakage			Working		

Table M31.5.2

Present Conditions of Sanquelim Water Treatment Plant (2/9)

Name of Facility		Contents of Facility						Remarks	
		Sanquelim W.T.P.			Podocem W.T.P.				
		(1) 5 MLD	(2) 7 MLD	Total	(3) 40 MLD	Raw Water to Assonora WT			
Raw Water Motor	Motor Output	HP	101	134	148		611	938	
		kW	75	100	110		456	700	
	Number	Unit	1	2	1		3	2	
	Maker		Kirlosker	Kirlosker	Kirlosker		Kirlosker	CROMPTON	
	Year of Manufacture		1994	1994	1994		2003	1993	
	Assessment of Condition		Working			Working	Working		
Raw Water Rising Main	Diameter	mm	350		450		750		
	Length	m	600		600		636		
	Material		CIP		MS + CI		DIP K - 9		
	Velocity	m/sec	0.221		0.241		0.825		
	Loss of Head	m	0.999		0.548		1.213		
	Assessment of Condition		Good		Good		Good		
	Valve		Good		Good		Good		
Stilling Chamber	Design Capacity	m ³ /min/unit	-	-	-		29.17		
		m ³ /hr/unit	-	-	-		1,750.0		
		m ³ /d/unit	-	-	-		42,000		
	Number	Unit	-	-	-		1		
	Width	m	-	-	-		3.00		
	Length	m	-	-	-		3.00		
	Water Depth	m	-	-	-		3.10		
	Volume	m ³	-	-	-		27.9		
	Retention Time	min	-	-	-		0.96		
	Water Level	m	-	-	-		126.20		
	Assessment of Condition		-	-		Working			
Aerator	Capacity	m ³ /hr/unit	218.8		306.3		1,750.0		
		m ³ /d/unit	5,250		7,350		42,000.0		
	Number	Unit	1		1		1		
	Diameter	m	4.40		5.00		8.00		
	Height	m	4.00		4.00		2.90		
	El. of Top Aerator					125.70			
	Assessment of Condition		Working		Working		Working		
Parshal Flume									
	Assessment of Condition		Working		Working		Working		
TOTAL									

Table M31.5.2

Present Conditions of Sanquelim Water Treatment Plant (3/9)

Name of Facility	Contents of Facility						Remarks
	Sanquelim W.T.P.			Podocem W.T.P.			
	(1) 5 MLD	(2) 7 MLD	Total	(3) 40 MLD	TOTAL		
Contact Aeration Tank	Design Capacity	m ³ /min/unit	-	-	-	29.17	
		m ³ /hr/unit	-	-	-	1,750.0	
		m ³ /d/unit	-	-	-	42,000	
	Number	Unit	-	-	-	1	
	Diameter	m	-	-	-	17.00	
	Water Depth	m	-	-	-	5.0	
	Volume	m ³	-	-	-	1,134.9	
	Retention Time	min	-	-	-	38.9	
	Water Level	m	-	-	-	123.60	
	Assessment of Condition		-	-	-	Working	
Flash Mixing Basin	Design Capacity	m ³ /min/unit	-	-	-	29.17	
		m ³ /hr/unit	-	-	-	1,750.0	
		m ³ /d/unit	-	-	-	42,000	
	Number	Unit	-	-	-	1	
	Width	m	-	-	-	3.00	
	Length	m	-	-	-	3.00	
	Water Depth	m	-	-	-	3.10	
	Volume	m ³	-	-	-	27.9	
	Retention Time	min	-	-	-	0.96	
	Water Level	m	-	-	-	123.20	
Assessment of Condition		-	-	-	Working		
Flash Mixer	Assessment of Condition		-	-	Working		

Table M31.5.2

Present Conditions of Sanquelim Water Treatment Plant (4/9)

Name of Facility		Contents of Facility					Remarks
		Sanquelim W.T.P.		Podocem W.T.P.		TOTAL	
		(1) 5 MLD	(2) 7 MLD	Total	(3) 40 MLD		
Clarifiers / Settling Tank (Coagulation Basin)	Design Capacity	m ³ /min/unit	3.6	5.1		14.6	
		m ³ /hr/unit	218.8	306.3		875.0	
		m ³ /d/unit	5,250	7,350		21,000	
	Number	Unit	1	1		2	
	Type of Clarifier		Circular Horizontal Flow Type with Center Feed/Peripheral Collection				Sludge Blanket Lamella Clarifier with PVC Tube Modules
	Width	m	-	-		14.00	20.00
	Length	m	-	-		14.00	10.50
	Water Depth	m	3.20	3.35		5.00	4.50
	Overall Diameter	m	13.60	20.00		-	
	Flocc. Zone Dia.	m	3.40	5.00		-	
Frequency of Desludging		General season: Once a day					
		Monsoon Season: Twice a day at Monsoon					
Volume							
Overall	m ³ /unit	464.9	1,052.4		980.0	945.0	
Flocculation Zone	m ³ /unit	29.1	65.8		-		
Clarifying Zone	m ³ /unit	435.8	986.7		-		
Retention Time							
Flocculation Zone	min	8.0	12.9		-		
Clarifying Zone	min	119.5 OK	193.3 OK		-		
Overall	min	127.5	206.2		67.2 OK		
Surface Area	m ² /unit	136.2	294.5		196.0		
Surface Loading	mm/min	26.8 OK	17.3 OK		74.40 ?		
W.L. of Clarifier	m				122.50		
Assessment of Condition		Working	Working		Working		
Flocculator	Number	unit			-		
	Assessment of Condition		Working				
Drive Arrangement	Number	unit			-		
	Assessment of Condition	Working	Working		Working		

Table M31.5.2

Present Conditions of Sanquelim Water Treatment Plant (5/9)

Name of Facility	Contents of Facility					Remarks
	Sanquelim W.T.P.		Podocem W.T.P.		TOTAL	
	(1) 5 MLD	(2) 7 MLD	Total	(3) 40 MLD		
Filter	Design Capacity	m ³ /hr/unit	109.4	102.1	437.5	
		m ³ /d/unit	2,625	2,450	10,500	
	Number	Unit	2	3	4	
	Type		Rapid Sand Gravity	Rapid Sand Gravity	Rapid Sand Gravity	
			w/20 m3 Backwash Tank	w/15 m3 Backwash Tank	w/600 m3 Backwash Tank	
	Width	m	5.55	5.10	9.50	
	Length	m	5.00	2.60	4.50	
	Water Depth	m	1.75	2.05	?	
	Filtered Area	m ² /unit	27.8	13.3	42.8	
	Velocity	m ³ /d/m ²	94.6 OK	184.8	OK	High Rate
	Filter Media					
	E.S. of Sand		Effective Size -	Effective Size -	Standard Size	
	Depth of Sand	mm	650	650.0		
	Type of Underdrain System		Pipe with Slit	Pipe with Slit		
	Year Replacement of Media		1996		No Replacement	
W. L. of Filter	m			121.00		
Assessment of Condition		Working	Working	Working		
Filter Washing Method	Air Scouring Rate	m ³ /min/m ²	0.00	0.00	0.12 NO	
	Air Scouring Time	min	10	10	10	
	Backwash Rate	m ³ /min/m ²	0.14 NO	0.2 NO	0.47 OK	600 m3/30 min
			Using Back Wash Tank	Using Back Wash Tank + Pump ?	Using Back Wash Tank	
	Backwashing Time	min	10	10	30	?
	Frequency of Washing					
Backwash Pump & Motor	General Season : each basin - 1 time/day Monsoon Season : each basin - 2 times/day					
	Capacity	m ³ /min	0.00	0.0	5.0	
		m ³ /hr	Lifting Pump & Motor	Lifting Pump & Motor	Lifting Pump & Motor	
		m ³ /d	0	0.0	299.9	
	Number	unit	1	2	7,197.1	
	Stand-by	unit				
	Total Capacity	m ³ /min	0.00	0.00	0.0	
		m ³ /d	0	0.0	0.0	
	Head	m				
	Type of Pump		Centrifugal	Centrifugal	Centrifugal	
Motor Output	HP	7.5	5.0	24.8		
	KW			18.5		
Assessment of Condition		Working	Working	Working		

Table M31.5.2

Present Conditions of Sanquelim Water Treatment Plant (6/9)

Name of Facility		Contents of Facility						Remarks
		Sanquelim W.T.P.			Podocem W.T.P.			
		(1) 5 MLD	(2) 7 MLD	Total	(3) 40 MLD	TOTAL		
Air Blower	Capacity	m ³ /min	0.0	0.0		2.5		
		m ³ /hr			150.0			
		m ³ /d	0	0.0	3,600			
	Number	unit	2	2	2			
	Stand-by	unit	1	1	1			
Total Capacity	m ³ /min	0.0	0.0		2.5			
	m ³ /d	0	0.0		3,600.0			
Head								
Motor Output	HP	15.0	20.0		40.2			
	kW	11.0			30.0			
Assessment of Condition		Working	Working		Working			
Clear Water Collection Reservoir	Number of C.W.R.	Unit				M.B.R.		
	Diameter	m	16.0	18.0		40.0		
	Water Depth	m	4.0	4.0		4.0		
	Number	Unit	1	1		2		
	Volume	m ³	800	1,000		5,000		
	Total	m ³	800	1,000	1,800	10,000		
	Detention Time	hr	3.8	3.4	#DIV/0!	4.6		
	Last Date of Cleaning		Pediodical	Pediodical		Pediodical		
Water Level					117.00			
					113.00			
Assessment of Condition		Good	Good		Good			
Dirty Water Sump	Number	Unit	-	-	-	-		
	Diameter	m	-	-	-	13.00		
	Water Depth	m	-	-	-	1.50		
	Volume	m ³ /unit	-	-	-	199.1		
	Retention Time	min	-	-	-	-		
Water Level			-	-	-	117.50		
			-	-	-	116.00		
Assessment of Condition		-	-	-	Working			

Table M31.5.2

Present Conditions of Sanquelim Water Treatment Plant (7/9)

Name of Facility		Contents of Facility					Remarks
		Sanquelim W.T.P.		Podocem W.T.P.		TOTAL	
		(1) 5 MLD	(2) 7 MLD	Total	(3) 40 MLD		
Chemical Facility							
Alum Feeding Facility	Capacity	kg/hr					
		m ³ /unit	2.0	2.0			
	Width	m					
	Length	m					
	Height	m					
	Volume	m ³	0.0	0.0		12.50 w/ Poly-Electrolite Solution Tank 8 m ³	
	Number	Unit	3	3		3	
	Stand-by	1	1				
	Assessment of Condition	Working	Working		Working		
Lime Feeding Facility	Capacity	kg/hr					
		m ³ /unit	2.0	2.0			
	Diameter	m					
	Width	m					
	Length	m					
	Height	m					
	Volume	m ³				8.00 w/ Poly-Electrolite Solution Tank 8 m ³	
	Number	Unit	3	3		3	
	Stand-by		1	1			
	Assessment of Condition	Working	Working		Working		
Disinfection System	Chemical Used		Liquid Chlorine/Bleaching Powder	Liquid Chlorine/Bleaching Powder		Liquid Chlorine	
	Type of Plant & Machinery		Chlorinator	Chlorinator		w/ Booster Pump 6m ³ /hr×50m Head	
	Capacity	kg/hr	2.5	2.5		10.0	
	Number	Unit	2	2		3	
		Stand-by					
	Safety Measures Taken		Neutralization Tank(Caustic Soda)				
	Commissioned		1994	1994		2003	
Assessment of Condition		Working	Working		Working		

Table M31.5.2

Present Conditions of Sanquelim Water Treatment Plant (8/9)

Name of Facility	Contents of Facility				Remarks
	Sanquelim W.T.P.		Podocem W.T.P.		
	(1) 5 MLD	(2) 7 MLD	Total	(3) 40 MLD	
Laboratory					
Chemical Testing Laboratory	Nil	Nil		Commissioned	
Jar Testing	Nil	Nil		Nil	
Availability of Skilled Chemists	Nil	Nil		-	
Availability of Required Chemicals	Alum & Lime	Alum & Lime		Alum & Lime	
	From Assonara Store	From Assonara Store		From Assonara Store	
Use of Test Reports	Check Quality of Filter/Tre	Check Quality of Filter/Treatment		As per Format	
Frequency of Sampling	Hourly (pH, R-Cl)	Hourly (pH, R-Cl)		Hourly (pH, Turb., R-Cl, D.O.)	
Frequency of Sampling & Analysis	Monthly : Other (Turb., pH, Alkalinity, Hardness, Chloride, Mn, Fe, D.O., Fe, R-Cl) Test	Monthly : Other (Turb., pH, Alkalinity, Hardness, Chloride, Mn, Fe, D.O., Fe, R-Cl) Test		20 Parameter Tests Forninghtly	
General Quality of Water	Good	Good		Treatable Water Treatment Process	
Raw Water Quality	Turbid., Low pH	Turbid., Low pH		Turbid., Low pH	
Clear Water Quality	Good(0.8NTU)	Good(0.8NTU)		Good	
Transformers					
Number/Name of Transformer	Raw Water Intake	Sanquelim WTP			
Pole Mounted / Pad Mounted	Pole	Pole		Pad	
Capacity	200 kVA	200		200	
Number	2	1		1	
Commissioned	1994	1994		2003	
Likely Design Life	20	20		30	
Last Replacement	-	-		-	
Stand-by	-	-		-	
Assessment of Condition	Good	Good		Good	
Equipment Status					
Flow Meters	-	-		Ultrasonic	
Other Operating Valves	-	-		Working	
Other Important Assets					
Valve's Condition	Working	Working		Working	
Visible Leakage and Locations	Nil	Nil		Nil	
Building Condition				Good	
Wastewater Disposal Arrangements		Discharge in Nata through Sludge Chamber		Recycling w/Pumping Arrangement	
		TOTAL			

Table M31.5.2

Present Conditions of Sanquelim Water Treatment Plant (9/9)

Present Condition of Sanquelim / Podocem Water Treatment Plant											
Organization & Staff Deployed											No.3
General Shift	2 Plants (5 MLD & 7 MLD)		Plant of 40 MLD								
	08:30 am → 05:30 pm										
	Junior Engineer	1 Person									
	Electriciann	1 Person									
	Helper	5 Persons									
	Total	7 Persons		0 Persons							
Shift in Plant Operation	2 Plants (5 MLD & 7 MLD)		Plant of 40 MLD								
	3 Shifting System Covering 24 Hours										
	Working Hour :										
	ⓐ: 08:00 am → 02:00 pm, ⓑ: 02:00 pm → 08:00 pm, ⓒ: 08:00 pm → 08:00 am										
	Raw Water Intake: 2 Persons/Each Shift		Raw Water Intake: 2 Persons/Shift × 3 Groups								
W.T.P. : 2 Persons/Each Shift		W.T.P. : 8 Persons/Shift × 3 Groups									
		Additional Staff : 4 Persons									
		Shift in Charge : 2 Persons									
Staff Deployed at the Plant											
2 Plants (5 MLD & 7 MLD)											
	Person	Qualification	Year of Service	Service at plant		Person	Qualification	Year of Service	Service at plant		
Management Staff - Engineers											
Assistant Engineer						1	D.C.E.	26			1
Technical Assistant						1	B.E.	20			1
Junior Engineer	1	D.E.E.	23	16							
Sub-total	1					2					
Skilled Staff - Operators / Quality Testing											
Supervisor	-	-	-	-		2	SSLC				
Chemist	-	-	-	-		3	BSC(Chem)				
Chlorine Operator	-	-	-	-		3	X th Science				
Filter Operator	1					-					
Pump Operator	2					9	I.T.I.				
Electrician	1	I.T.I.				3	I.T.I. (Elec)				
Mechanics G-II	3	I.T.I.				3	I.T.I. (Mech)				
Work Assistant	2					-					
Operator	4					-					
Assistant Operator	2					-					
Plumber	1					-					
Sub-total	16					23					
Unskilled Staff	4	Workman 1, Labour 2, Sweeper 1				13	Helper-10, Sweeper-2, Gardener-1				
Total Number	21					38					

**Table M31.5.3 Monthly Water Quality of Sanquelim Water Treatment Plant
Analysed by PWD's Laboratory from January 2003 to May 2005 (1/2)**

	Color			Odor			Taste			Turbidity (NTU)			pH			Specific Conductivity (/u mhos/cm)			Total Solids (mg/L)		
	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated
Jan-03	0.0	0.0		Unobjectable			Unobjectable			8.9	2.7		7.2	7.8		53.0	57.3		37.0	38.0	
Feb-03	0.0	0.0		Unobjectable			Unobjectable			5.3	1.2		7.0	7.1		54.9	66.3		36.0	42.0	
Mar-03	0.0	0.0		Unobjectable			Unobjectable			5.2	1.4		6.6	7.1		55.1	61.1		37.0	39.0	
Apr-03	0.0	0.0		Unobjectable			Unobjectable			7.0	1.8		6.3	6.9		51.9	55.9		34.0	36.0	
May-03	0.0	0.0		Unobjectable			Unobjectable			2.2	0.5		6.5	6.8		64.1	69.9		44.0	45.0	
Jun-03	0.0	0.0		Unobjectable			Unobjectable			7.5	1.5		6.3	7.2		68.5	80.5		46.5	52.0	
Jul-03	0.0	0.0		Unobjectable			Unobjectable			7.8	2.2		6.2	7.4		43.8	72.4		31.0	46.0	
Aug-03	0.0	0.0		Unobjectable			Unobjectable			7.8	2.4		6.7	7.4		39.1	50.3		27.5	32.0	
Sep-03	0.0	0.0		Unobjectable			Unobjectable			5.7	2.8		6.8	7.2		43.0	56.5		30.0	36.5	
Oct-03	0.0	0.0		Unobjectable			Unobjectable			7.4	1.1		7.0	7.4		50.2	59.6		34.5	38.0	
Nov-03	0.0	0.0	0.0	Unobjectable			Unobjectable			11.2	2.0	2.0	6.6	7.3	7.3	58.7	76.0	76.6	41.5	49.0	49.0
Dec-03	0.0	0.0	0.0	Unobjectable			Unobjectable			3.8	0.6	0.6	6.8	7.0	7.0	59.3	77.0	77.2	39.5	49.0	49.0
Jan-04				Unobjectable			Unobjectable														
Feb-04	0.0	0.0	0.0	Unobjectable			Unobjectable			5.2	2.0	2.1	6.9	7.2	7.2	58.1	65.2	65.4	38.5	42.0	42.0
Mar-04	0.0	0.0	0.0	Unobjectable			Unobjectable			4.1	1.1	1.1	6.8	7.1	7.0	62.3	61.8	61.2	41.0	39.0	39.0
Apr-04	0.0	0.0	0.0	Unobjectable			Unobjectable			4.2	0.9	1.0	6.7	6.9	7.0	62.7	62.9	61.8	41.0	40.0	40.0
May-04	0.0	0.0	0.0	Unobjectable			Unobjectable			2.9	0.6	0.5	6.7	7.2	7.2	65.8	88.4	88.1	42.5	56.5	56.0
Jun-04	0.0	0.0	0.0	Unobjectable			Unobjectable			24.2	6.4	7.4	6.5	8.0	8.0	48.7	96.2	97.3	39.0	63.5	64.0
Jul-04	0.0	0.0	0.0	Unobjectable			Unobjectable			23.2	2.9	2.5	7.1	8.2	7.2	43.0	61.7	61.2	34.0	39.5	39.0
Aug-04	0.0	0.0	0.0	Unobjectable			Unobjectable			32.2	4.9	2.4	7.1	7.2	7.2	43.7	46.3	46.5	37.0	31.0	29.0
Sep-04	0.0	0.0	0.0	Unobjectable			Unobjectable			12.0	2.4	2.0	7.3	7.4	7.5	52.9	54.6	54.8	37.5	35.0	35.0
Oct-04	0.0	0.0	0.0	Unobjectable			Unobjectable			1.0	1.0	1.0	7.0	7.3	7.3	56.0	63.4	63.5	39.0	40.5	40.5
Nov-04	0.0	0.0	0.0	Unobjectable			Unobjectable			4.1	2.0	2.0	6.8	7.0	7.0	72.2	76.1	78.8	47.0	50.0	51.0
Dec-04				Unobjectable			Unobjectable														
Jan-05	0.0	0.0	0.0	Unobjectable			Unobjectable			9.1	1.5	1.8	6.7	7.1	7.2	49.7	51.2	51.3	35.0	33.0	33.0
Feb-05	0.0	0.0	0.0	Unobjectable			Unobjectable			5.7	2.3	1.9	6.5	6.6	6.8	59.8	60.1	64.0	40.0	38.0	40.0
Mar-05	0.0	0.0	0.0	Unobjectable			Unobjectable			3.9	2.0	2.0	6.9	7.0	7.0	59.4	64.1	65.3	39.0	41.0	41.0
Apr-05	0.0	0.0	0.0	Unobjectable			Unobjectable			4.6	1.9	2.0	6.6	6.8	7.0	60.6	61.5	61.8	40.5	39.0	39.0
May-05	0.0	0.0	0.0	Unobjectable			Unobjectable			4.8	2.0	2.2	6.7	7.4	8.2	69.5	71.0	70.5	45.5	45.0	45.0
Max	0.0	0.0	0.0							32.2	6.4	7.4	7.3	8.2	8.2	72.2	96.2	97.3	47.0	63.5	64.0
Min	0.0	0.0	0.0	Unobjectable			Unobjectable			1.0	0.5	0.5	6.2	6.6	6.8	39.1	46.3	46.5	27.5	31.0	29.0
Average	0.0	0.0	0.0							8.2	2.0	2.0	6.8	7.2	7.2	55.8	65.5	67.4	38.3	42.1	43.0

	Total Dissolved Solids(TDS) (mg/L)			Suspended Solids (mg/L)			Total Hardness as CaCO ₃ (TA) (mg/L)			Ca ²⁺ (mg/L)			Mg ²⁺ (mg/L)			Cl ⁻ (mg/L)			Total Alkalinity as CaCO ₃ (mg/L)		
	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated
Jan-03	35.0	38.0		2.0	0.0		18.0	21.0		4.0	6.0		2.0	1.5		6.0	6.0		18.0	22.0	
Feb-03	34.0	42.0		2.0	0.0		10.0	28.0		4.8	8.4		1.8	1.8		6.0	6.0		14.0	15.0	
Mar-03	35.0	39.0		2.0	0.0		20.0	23.0		5.2	6.4		1.8	1.8		6.0	6.0		20.0	24.0	
Apr-03	32.0	36.0		2.0	0.0		17.0	20.0		4.4	5.6		1.5	1.5		6.0	6.0		23.0	27.0	
May-03	43.0			2.0	0.0		22.0	25.0		4.4	6.0		2.8	2.5		8.0	8.0		23.0	27.0	
Jun-03	44.0	52.0		2.5	0.0		23.0	33.0		4.8	8.8		2.8	2.8		6.0	6.0		22.0	28.0	
Jul-03	28.0	46.0		3.0	0.0		19.0	33.0		3.6	9.2		2.5	2.5		4.0	4.0		20.0	28.0	
Aug-03	25.0	32.0		2.5	0.0		16.0	24.0		3.6	6.4		1.8	2.0		6.0	6.0		12.0	18.0	
Sep-03	28.0	36.0		2.0	0.5		21.0	25.0		4.0	6.0		2.8	2.5		4.0	22.0		18.0	0.0	
Oct-03	32.0	38.0		2.5	0.0		21.0	26.0		4.0	6.0		2.8	2.8		6.0	6.0		23.0	28.0	
Nov-03	38.0	49.0	49.0	3.5	0.0	0.0	25.0	32.0	32.0	6.0	8.8	8.8	2.5	2.5	2.5	6.0	6.0	6.0	26.0	33.0	33.0
Dec-03	38.0	49.0	49.0	1.5	0.0	0.0	18.0	26.0	26.0	5.6	6.8	6.8	1.0	2.3	2.3	6.0	8.0	8.0	22.0	24.0	24.0
Jan-04																					
Feb-04	37.0	42.0	42.0	1.5	0.0	0.0	13.0	20.0	20.0	4.8	5.2	5.2	1.5	1.8	1.8	8.0	8.0	8.0	21.0	24.0	24.0
Mar-04	39.5	39.0	39.0	1.5	0.0	0.0	20.0	20.0	20.0	5.2	5.2	5.2	1.8	1.8	1.8	6.0	7.0	7.0	25.0	25.0	25.0
Apr-04	40.0	40.0	40.0	1.0	0.0	0.0	19.0	19.0	19.0	4.3	4.8	4.8	1.8	1.8	1.8	6.0	6.0	6.0	24.0	24.0	25.0
May-04	42.0	56.5	56.0	0.5	0.0	0.0	22.0	34.0	34.0	5.6	9.2	9.2	2.0	2.8	2.8	7.0	12.0	12.0	27.0	30.0	30.0
Jun-04	31.0	61.5	62.0	8.0	2.0	2.0	15.0	43.0	43.0	3.6	12.8	12.8	1.5	2.8	2.8	7.0	10.0	10.0	14.0	46.0	46.0
Jul-04	27.5	39.0	39.0	6.5	0.5	0.0	13.0	23.0	23.0	3.2	6.0	6.0	1.3	2.0	2.0	6.0	9.0	9.0	14.0	25.0	25.0
Aug-04	28.0	29.5	29.0	9.0	1.5	0.0	15.0	18.0	18.0	3.6	4.4	4.4	1.5	1.8	1.8	6.0	6.0	6.0	18.0	19.0	19.0
Sep-04	34.0	35.0	35.0	3.5	0.0	0.0	16.0	18.0	18.0	4.0	4.8	4.8	1.5	1.5	1.5	6.0	6.0	6.0	19.0	22.0	22.0
Oct-04	36.0	40.5	40.5	3.0	0.0	0.0	19.0	24.0	24.0	5.6	6.4	6.4	1.3	2.0	2.0	6.0	6.0	6.0	22.0	26.0	26.0
Nov-04	46.0	50.0	51.0	1.0	0.0	0.0	23.0	30.0	30.0	6.0	7.6	7.6	2.5	2.8	2.8	7.0	9.0	9.0	29.0	32.0	32.0
Dec-04																					
Jan-05	32.0	33.0	33.0	3.0	0.0	0.0	14.0	15.0	15.0	4.0	4.4	4.4	1.0	1.0	1.0	6.0	6.0	6.0	20.0	22.0	22.0
Feb-05	38.0	38.0	40.0	2.0	0.0	0.0	20.0	20.0	20.0	4.8	4.8	4.8	2.0	2.0	2.0	7.0	7.0	7.0	21.0	21.0	21.0
Mar-05	38.0	41.0	41.0	1.0	0.0	0.0	18.0	29.0	29.0	4.4	8.4	8.4	1.8	1.8	1.8	8.0	10.0	10.0	20.0	26.0	26.0
Apr-05	39.0	39.0	39.0	1.5	0.0	0.0	22.0	22.0	22.0	4.8	4.8	4.8	2.0	2.0	2.0	8.0	8.0	8.0	23.0	23.0	23.0
May-05	44.0	45.0	45.0	1.5	0.0	0.0	24.0	24.0	24.0	6.0	6.0	6.0	2.3	2.3	2.3	7.0	7.0	7.0	24.0	24.0	24.0
Max	46.0	61.5	62.0	9.0	2.0	2.0	25.0	43.0	43.0	6.0	12.8	12.8	2.8	2.8	2.8	8.0	22.0	12.0	29.0	46.0	46.0
Min	25.0	29.5	29.0	0.5	0.0	0.0	10.0	15.0	15.0	3.2	4.4	4.4	1.0	1.0	1.0	4.0	4.0	6.0	12.0	0.0	19.0
Average	35.7	41.8	42.9	2.7	0.2	0.1	18.6	25.0	24.5	4.6	6.6	6.5	1.9	2.1	2.0	6.3	7.7	7.7	20.8	24.6	26.3

Table M31.5.3 Monthly Water Quality of Sanquelim Water Treatment Plant
Analysed by PWD's Laboratory from January 2003 to May 2005 (2/2)

	SO ₄ ⁻ (mg/L)			Fe ²⁺ (mg/L)			Mn ²⁺ (mg/L)			NO ₃ ²⁻ (mg/L)			KMnO ₄ oxidizability as O ₂ (mg/L)			BOD at 27°C and 3days (mg/L)			DO (mg/L)			
	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	
Jan-03	0.0	0.0		0.64	0.10		0.00	0.00		0.6	0.0		0.3	0.0		0.5	0.0					
Feb-03	0.0	0.0		0.76	0.05		0.00	0.00		0.7	0.0		0.3	0.0		0.8	0.0					
Mar-03	0.0	0.0		1.00	0.06		0.00	0.00		0.8	0.0		0.3	0.0			0.0					
Apr-03	0.0	0.0		0.00	0.10		0.00	0.00		0.4	0.0		0.2	0.0		0.5	0.0					
May-03	0.0	0.0		0.30	0.05		0.00	0.00		0.5	0.0		0.3	0.0		0.6	0.0					
Jun-03	0.0	4.0		0.76	0.05		0.00	0.00		0.6	0.4		0.4	0.2		0.8	0.5					
Jul-03	0.0	0.0		0.75	0.60		0.00	0.00		0.6	0.0		0.3	0.0		0.8	0.0					
Aug-03	0.0	0.0		1.00	0.05		0.00	0.00		0.8	0.0		0.4	0.0		1.2	0.0					
Sep-03	0.0	0.1		1.15	0.00		0.00	0.00		0.8	0.0		0.4	0.2		1.0	0.0					
Oct-03	0.0	0.0		0.80	0.05		0.00	0.00		0.8	0.0		0.4	0.0		0.9	0.0					
Nov-03	0.0	0.0	0.0	1.50	0.20	0.20	0.00	0.00	0.00	1.2	0.4	0.0	0.6	0.2	0.0	1.5	0.5	0.0	7.2	7.4	7.4	
Dec-03	0.0	0.0	0.0	0.64	0.06	0.06	0.00	0.00	0.00	0.8	0.0	0.0	0.3	0.0	0.0	1.0	0.0	0.0	7.4	7.5	7.5	
Jan-04																						
Feb-04	0.0	0.0	0.0	0.50	0.10	0.10	0.00	0.00	0.00	0.8	0.0	0.0	0.4	0.0	0.0	1.0	0.0	0.0	7.1	7.4	7.5	
Mar-04	0.0	0.0	0.0	0.45	0.10	0.10	0.00	0.00	0.00	0.6	0.0	0.0	0.0	0.0	0.0	0.5	0.0	0.0	6.9	7.4	7.4	
Apr-04	0.0	0.0	0.0	0.45	0.60	0.60	0.00	0.00	0.00	0.6	0.0	0.0	0.2	0.0	0.0	0.5	0.0	0.0	6.9	7.3	7.4	
May-04	0.0	0.0	0.0	0.35	0.05	0.05	0.00	0.00	0.00	0.4	0.0	0.0	0.2	0.0	0.0	0.5	0.0	0.0	6.9	7.2	7.3	
Jun-04	0.0	0.0	0.0	3.90	0.30	0.30	0.00	0.00	0.00	1.6	0.0	0.0	1.0	0.2	0.0	2.4	0.5	0.0	6.5	6.9	7.1	
Jul-04	0.0	0.0	0.0	1.50	0.30	0.10	0.00	0.00	0.00	1.8	0.0	0.0	0.9	0.2	0.0	2.0	0.5	0.0	7.0	7.2	7.2	
Aug-04	0.0	0.0	0.0	1.80	0.30	0.20	0.00	0.00	0.00	1.8	0.1	0.0	0.9	0.2	0.0	2.0	0.5	0.0	7.3	7.3	7.4	
Sep-04	0.0	0.0	0.0	0.65	0.10	0.10	0.00	0.00	0.00	0.6	0.0	0.0	0.4	0.0	0.0	0.8	0.0	0.0	7.1	7.4	7.4	
Oct-04	0.0	0.0	0.0	0.50	0.10	0.10	0.00	0.00	0.00	0.6	0.0	0.0	0.4	0.0	0.0	1.0	0.0	0.0	7.1	7.3	7.3	
Nov-04	0.0	0.0	0.0	0.40	0.15	0.15	0.00	0.00	0.00	0.3	0.0	0.0	0.4	0.0	0.0	0.8	0.0	0.0	7.1	7.2	7.3	
Dec-04																						
Jan-05	0.0	0.0	0.0	0.60	0.10	0.10	0.00	0.00	0.00	0.6	0.0	0.0	0.8	0.0	0.0	1.5	0.0	0.0	7.3	7.4	7.5	
Feb-05	0.0	0.0	0.0	0.40	0.10	0.10	0.00	0.00	0.00	1.2	0.0	0.0	0.8	0.0	0.0	1.5	0.0	0.0	7.3	7.4	7.4	
Mar-05	0.0	0.0	0.0	0.30	0.10	0.10	0.00	0.00	0.00	0.5	0.0	0.0	0.3	0.0	0.0	0.8	0.0	0.0	7.5	7.7	7.7	
Apr-05	0.0	0.0	0.0	0.25	0.10	0.10	0.00	0.00	0.00	0.6	0.0	0.0	0.4	0.0	0.0	0.8	0.0	0.0	7.6	7.6	7.7	
May-05	0.0	0.0	0.0	0.25	1.00	0.10	0.00	0.00	0.00	0.7	0.0	0.0	0.4	0.0	0.0	1.0	0.0	0.0	6.9	7.4	7.4	
Max	0.0	4.0	0.0	3.90	1.00	0.60	0.00	0.00	0.00	1.8	0.4	0.0	1.0	0.2	0.0	2.4	0.5	0.0	7.6	7.7	7.7	
Min	0.0	0.0	0.0	0.00	0.00	0.05	0.00	0.00	0.00	0.3	0.0	0.0	0.0	0.0	0.0	0.5	0.0	0.0	6.5	6.9	7.1	
Average	0.0	0.2	0.0	0.80	0.18	0.15	0.00	0.00	0.00	0.8	0.0	0.0	0.4	0.0	0.0	1.0	0.1	0.0	7.1	7.4	7.4	

	F ⁻ (mg/L)			Al ³⁺ (mg/L)			Plate Count on nutrient agar no/100mL			MPN of Coliform no/100mL			MPN of E.Coli. no/100mL		
	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated
	Jan-03	0.0	0.0		0.00	0.00		168	54	4	2,400	1,100	0	210	150
Feb-03	0.0	0.0		0.00	0.00		312	36	1	2,400	240	0	460	95	0
Mar-03	0.0	0.0		0.00	0.00		288	195	0	4,600	2,400	0	1,100	93	0
Apr-03	0.0	0.0					25	12	0	2,400	1,100	0	150	93	0
May-03	0.0	0.0		0.00	0.00		128	39	3	1,100	39	0	240	43	0
Jun-03	0.0	0.0		0.00	0.00		590	130	0	4,600	2,400	0	1,100	460	0
Jul-03	0.0	0.0		0.45	0.00		380	270	2	4,600	460	0	1,100	240	0
Aug-03	0.0	0.0		0.20	0.00		328	81	2	4,600	460	0	1,100	150	0
Sep-03	0.0	0.0		0.20	0.00		153	62	2	2,400	1,100	0	1,100	240	0
Oct-03	0.0	0.0		0.04	0.00		140	48	3	1,100	1,100	0	460	240	0
Nov-03	0.0	0.0	0.0	0.06	0.06	0.06	224	72	3	2,400	1,100	0	240	210	0
Dec-03	0.0	0.0	0.0	0.01	0.01	0.01	112	36	0	1,100	240	0	240	43	0
Jan-04															
Feb-04	0.0	0.0	0.0	0.00	0.00	0.00	129	72	2	460	460	0	240	93	0
Mar-04	0.0	0.0	0.0	0.00	0.00	0.00	188	78	4	2,400	1,100	0	1,100	460	0
Apr-04	0.0	0.0	0.0	0.00	0.00	0.00	217	40	1	2,400	93	0	1,100	230	0
May-04	0.0	0.0	0.0	0.00	0.00	0.00	190	75	2	2,400	460	0	1,200	93	0
Jun-04	0.0	0.0	0.0	0.00	0.40	0.40	186	82	2	2,400	1,100	0	210	93	0
Jul-04	0.0	0.0	0.0	0.00	0.08	0.08	172	90	1	4,600	460	0	2,100	93	0
Aug-04	0.0	0.0	0.0	0.00	0.01	0.01	390	102	0	4,600	1,100	0	2,400	460	0
Sep-04	0.0	0.0	0.0	0.01	0.01	0.01	190	90	2	1,100	460	0	460	240	0
Oct-04	0.0	0.0	0.0	0.00	0.04	0.04	108	49	0	1,100	460	0	240	210	0
Nov-04	0.0	0.0	0.0	0.00	0.01	0.01	178	54	2	2,400	240	0	1,100	210	0
Dec-04															
Jan-05	0.0	0.0	0.0	0.00	0.01	0.01	145	42	4	2,400	240	0	1,100	93	0
Feb-05	0.0	0.0	0.0	0.00	0.00	0.00	177	132	1	2,400	1,100	0	400	210	0
Mar-05	0.0	0.0	0.0	0.00	0.00	0.00	92	39	1	460	33	0	460	9	0
Apr-05	0.0	0.0	0.0	0.00	0.00	0.00	87	49	4	1,100	460	0	240	93	0
May-05	0.0	0.0	0.0	0.00	0.00	0.00	128	72	3	1,100	240	0	93	93	0
Max	0.0	0.0	0.0	0.00	0.45	0.40	590	270	4	4,600	2,400	0	2,400	460	0
Min	0.0	0.0	0.0	0.00	0.00	0.00	25	12	0	460	33	0	93	9	0
Average	0.0	0.0	0.0	0.00	0.06	0.04	201	78	2	2,408	731	0	739	175	0




Figure M31.5.2 Monthly Water Quality of Sanquelim Water Treatment Plant
Analysed by PWD's Laboratory from January 2003 to May 2005 (1/2)




Figure M31.5.2 Monthly Water Quality of Sanquelim Water Treatment Plant
Analysed by PWD's Laboratory from January 2003 to May 2005 (2/2)

**Table M31.5.4 Monthly Water Quality of Podosem Water Treatment Plant
Analysed by PWD's Laboratory from January 2003 to May 2005 (1/2)**

	Color			Odor			Taste			Turbidity (NTU)			pH			Specific Conductivity (/u mhos/cm)			Total Solids (mg/L)			
	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	
Jan-03				Unobjectable			Unobjectable															
Feb-03				Unobjectable			Unobjectable															
Mar-03				Unobjectable			Unobjectable															
Apr-03				Unobjectable			Unobjectable															
May-03				Unobjectable			Unobjectable															
Jun-03	0.0	0.0		Unobjectable			Unobjectable			8.9	1.8		7.0			67.3	69.5		46.0		44.0	
Jul-03	0.0	0.0		Unobjectable			Unobjectable			7.1	0.0		6.5			46.4			33.0			
Aug-03	0.0	0.0		Unobjectable			Unobjectable			7.5	0.8		6.7	6.8		48.0	49.9		34.0		32.0	
Sep-03	0.0	0.0		Unobjectable			Unobjectable			8.2	0.0		7.0	7.3		39.6			29.0			
Oct-03	0.0	0.0		Unobjectable			Unobjectable			7.0	1.0		7.0	7.3		49.5	54.8		34.0		35.0	
Nov-03	0.0	0.0	0.0	Unobjectable			Unobjectable			11.5	1.2	1.4	7.1	7.1	7.2	65.4	68.7	69.2	45.0		43.0	
Dec-03	0.0	0.0	0.0	Unobjectable			Unobjectable			4.3	0.0	0.5	7.1	7.1	7.1	57.5		62.8	39.0		40.0	
Jan-04	0.0	0.0	0.0	Unobjectable			Unobjectable			10.7	0.0	1.8	7.0	7.3	7.3	57.5		65.2	40.0		42.0	
Feb-04	0.0	0.0	0.0	Unobjectable			Unobjectable			5.1	0.6	0.0	7.1	7.1		57.5	62.0		38.5		40.0	
Mar-04	0.0	0.0	0.0	Unobjectable			Unobjectable			3.5	1.0	1.0	7.1	7.2	7.2	59.4	60.6	58.1	39.0		38.0	
Apr-04	0.0	0.0	0.0	Unobjectable			Unobjectable			4.2	1.2	1.1	7.0	7.3	7.3	59.7	63.4	63.9	39.5		40.5	
May-04	0.0	0.0	0.0	Unobjectable			Unobjectable			5.5	1.1	1.0	7.2	7.3	7.3	62.9	63.1	63.3	42.0		40.0	
Jun-04	0.0	0.0	0.0	Unobjectable			Unobjectable			29.0	1.0	1.2	6.6	6.5	6.9	46.9	50.9	52.5	39.0		32.5	
Jul-04	0.0	0.0	0.0	Unobjectable			Unobjectable			26.0	2.2	0.5	7.2	7.2	7.0	40.8	44.4	45.0	33.0		28.0	
Aug-04	0.0	0.0	0.0	Unobjectable			Unobjectable			24.7	3.2	2.0	7.2	7.2	7.2	43.6	45.5	45.6	35.0		29.5	
Sep-04	0.0	0.0	0.0	Unobjectable			Unobjectable			10.3	1.3	0.4	7.3	7.5	7.5	52.7	53.8	53.7	36.5		34.0	
Oct-04	0.0	0.0	0.0	Unobjectable			Unobjectable			10.0	1.2	1.0	7.1	7.1	7.1	58.0	59.2	59.4	39.5		38.0	
Nov-04	0.0	0.0	0.0	Unobjectable			Unobjectable			4.7	2.0	1.0	7.0	7.3	7.4	68.7	74.5	74.4	45.5		47.5	
Dec-04	0.0	0.0	0.0	Unobjectable			Unobjectable			6.3	1.5	1.5	7.1	7.4	7.5	62.8	63.6	63.7	42.0		41.0	
Jan-05	0.0	0.0	0.0	Unobjectable			Unobjectable			9.7	1.2	1.0	7.0	7.2	7.2	49.0	79.8	48.8	35.0		32.0	
Feb-05	0.0	0.0	0.0	Unobjectable			Unobjectable			6.0	1.4	1.4	6.5	6.7	6.7	57.4	58.9	60.4	39.0		38.5	
Mar-05	0.0	0.0	0.0	Unobjectable			Unobjectable			3.1	1.2	1.2	6.9	7.0	7.1	58.4	60.7	60.3	38.5		39.0	
Apr-05	0.0	0.0	0.0	Unobjectable			Unobjectable			5.2	1.9	1.9	6.8	7.2	7.2	61.9	62.0	65.5	41.0		39.5	
May-05	0.0	0.0	0.0	Unobjectable			Unobjectable			4.8	2.0	2.2	7.0	7.1	8.2	64.6	64.9	64.7	43.0		41.5	
Max	0.0	0.0	0.0							29.0	3.2	2.2	7.3	7.5	8.2	68.7	79.8	74.4	46.0		47.5	
Min	0.0	0.0	0.0	Unobjectable			Unobjectable			3.1	0.0	0.0	6.5	6.5	6.7	39.6	44.4	45.0	29.0		28.0	
Average	0.0	0.0	0.0							9.3	1.2	1.2	7.0	7.1	7.2	55.6	60.5	59.8	38.6		37.7	

	Total Dissolved Solids(TDS) (mg/L)			Suspended Solids (mg/L)			Total Hardness as CaCO ₃ (T) (mg/L)			Ca ²⁺ (mg/L)			Mg ²⁺ (mg/L)			Cl ⁻ (mg/L)			Total Alkalinity as CaCO ₃ (mg/L)			
	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	
Jan-03																						
Feb-03																						
Mar-03																						
Apr-03																						
May-03																						
Jun-03	43.0	44.0		3.0			23.0	24.0		4.8	5.2		2.8	2.8		6.0	8.0		21.0		19.0	
Jul-03	30.0			3.0			17.0			3.6			2.0			4.0			19.0			
Aug-03	31.0	32.0		3.0			18.0	18.0		4.0	4.0		2.0	2.3		6.0	6.0		10.0		9.0	
Sep-03	26.0			3.0			17.0			3.6			2.0			4.0			19.0			
Oct-03	32.0	35.0		2.0	0.0		20.0	24.0		4.0	5.6		2.5	2.5		6.0	6.0		20.0		20.0	
Nov-03	41.0	43.0	43.0	4.0	0.0	0.0	24.0	25.0	25.0	6.0	6.4	6.4	2.3	2.3	2.3	6.0	8.0		26.0		26.0	
Dec-03	37.0			2.0	0.0	0.0	18.0		18.0	4.4		4.4	1.8		1.8	6.0		6.0	21.0		20.0	
Jan-04	37.0			3.0	0.0	0.0	19.0		23.0	4.4		6.0	2.0		2.0	6.0		6.0	23.0		23.0	
Feb-04	37.0	40.0		1.5	0.0		20.0	20.0		4.8	4.8		2.0	2.0		6.0	8.0		23.0		23.0	
Mar-04	38.0	38.0	38.0	1.0	0.0	0.0	20.0	23.0	23.0	5.2	6.0	6.0	1.8	2.0	2.0	6.0	7.0	7.0	26.0		27.0	
Apr-04	38.0	40.5	40.5	1.5	0.0	0.0	20.0	20.0	20.0	5.6	5.6	5.6	1.5	1.5	1.5	6.0	6.0	6.0	24.0		24.0	
May-04	40.0	40.0	40.0	2.0	0.0	0.0	20.0	20.0	20.0	4.8	4.8	4.8	2.0	2.0	2.0	7.0	7.0	7.0	24.0		24.0	
Jun-04	30.0	32.5	33.5	9.0	0.0	0.0	11.0	15.0	15.0	2.8	4.0	4.0	1.0	1.3	1.3	7.0	7.0	7.0	12.0		15.0	
Jul-04	26.0	28.0	28.0	7.0	0.0	0.0	12.0	14.0	14.0	2.8	3.6	3.6	1.3	1.3	1.3	6.0	6.0	6.0	14.0		16.0	
Aug-04	28.0	29.0	29.0	7.0	0.5	0.0	15.0	17.0	17.0	3.6	4.0	4.0	1.5	1.8	1.8	6.0	6.0	6.0	17.0		17.0	
Sep-04	33.5	34.0	34.0	3.0	0.0	0.0	18.0	18.0	18.0	4.8	4.8	4.8	1.5	1.5	1.5	7.0	7.0	7.0	20.0		22.0	
Oct-04	37.0	38.0	38.0	2.5	0.0	0.0	19.0	20.0	20.0	4.4	4.8	4.8	2.0	2.0	2.0	6.0	6.0	6.0	21.0		21.0	
Nov-04	44.0	47.5	47.5	1.5	0.0	0.0	24.0	26.0	26.0	5.6	6.4	6.4	2.5	2.5	2.5	7.0	7.0	7.0	25.0		28.0	
Dec-04	40.0	41.0	41.0	2.0	0.0	0.0	20.0	21.0	21.0	4.8	5.2	5.2	2.0	2.0	2.0	7.0	7.0	7.0	23.0		24.0	
Jan-05	32.0	32.0	32.0	3.0	0.0	0.0	14.0	15.0	15.0	4.0	4.4	4.4	1.0	1.0	1.0	7.0	7.0	7.0	19.0		20.0	
Feb-05	37.0	38.0	38.5	2.0	0.0	0.0	18.0	19.0	19.0	4.4	4.8	4.8	1.8	1.8	1.8	7.0	7.0	7.0	20.0		20.0	
Mar-05	37.5	39.0	39.0	1.0	0.0	0.0	18.0	22.0	22.0	4.4	5.6	5.6	1.8	2.0	2.0	8.0	8.0	8.0	20.0		21.0	
Apr-05	39.5	39.5	42.0	1.5	0.0	0.0	20.0	20.0	20.0	4.8	4.8	5.2	2.0	2.0	2.0	8.0	8.0	9.0	22.0		22.0	
May-05	41.5	41.5	41.5	1.5	0.0	0.0	21.0	21.0	21.0	4.8	4.8	4.8	2.3	2.3	2.3	7.0	7.0	7.0	22.0		22.0	
Max	44.0	47.5	47.5	9.0	0.5	0.0	24.0	26.0	26.0	6.0	6.4	6.4	2.8	2.8	2.8	8.0	8.0	9.0	26.0		28.0	
Min	26.0	28.0	28.0	1.0	0.0	0.0	11.0	14.0	14.0	2.8	3.6	3.6	1.0	1.0	1.0	4.0	6.0	6.0	10.0		16.0	
Average	35.7	37.6	38.2	2.9	0.0	0.0	18.6	20.1	19.8	4.4	5.0	5.0	1.9	1.9	1.8	6.3	7.0	6.8	20.5		21.8	

**Table M31.5.4 Monthly Water Quality of Podosem Water Treatment Plant
Analysed by PWD's Laboratory from January 2003 to May 2005 (2/2)**

	SO ₄ ⁻			Fe ²⁺			Mn ²⁺			NO ₃ ²⁻			KMnO ₄ oxidizability as O ₂			BOD at 27°C and 3days			DO			
	(mg/L)			(mg/L)			(mg/L)			(mg/L)			(mg/L)			(mg/L)						
	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	
Jan-03																						
Feb-03																						
Mar-03																						
Apr-03																						
May-03																						
Jun-03	0.0			0.50	0.06		0.00			0.6			0.4			0.8						
Jul-03	0.0			0.64			0.00			0.8			0.4			1.0						
Aug-03	0.0	0.0		0.80	0.05		0.00	0.00		0.9	0.0		0.4	0.0		1.0	0.0					
Sep-03	0.0			1.30			0.00			1.2			0.4			1.2						
Oct-03	0.0	0.0		0.76	0.05		0.00	0.00		0.6	0.0		0.4	0.0		0.8	0.0					
Nov-03	0.0	0.0	0.0	1.60	0.10	0.10	0.00	0.00	0.00	1.2	0.0	0.0	0.8	0.0	0.0	1.6	0.0	0.0	7.3	7.4	7.5	
Dec-03	0.0	0.0	0.0	0.75		0.06	0.00	0.00	0.00	0.8	0.0		0.4	0.0		1.0	0.0	0.0	7.3		7.4	
Jan-04	0.0			0.60		0.05	0.00		0.00	1.2			0.4			1.0		0.0	7.1		7.5	
Feb-04	0.0	0.0		0.40	0.05		0.00	0.00		0.6	0.0		0.2	0.0		0.5	0.0		7.1	7.5		
Mar-04	0.0	0.0	0.0	0.40	0.06	0.06	0.00	0.00	0.00	0.6	0.0	0.0	0.2	0.0	0.0	0.5	0.0	0.0	6.0	7.3	7.3	
Apr-04	0.0	0.0	0.0	0.45	0.06	0.06	0.00	0.00	0.00	0.7	0.0	0.0	0.3	0.0	0.0	0.6	0.0	0.0	6.9	7.2	7.4	
May-04	0.0	0.0	0.0	0.60	0.05	0.05	0.00	0.00	0.00	0.8	0.0	0.0	0.4	0.0	0.0	0.9	0.0	0.0	6.9	7.3	7.3	
Jun-04	0.0	0.0	0.0	2.60	0.10	0.10	0.00	0.00	0.00	1.8	0.0	0.0	1.2	0.0	0.0	3.0	0.0	0.0	6.5	6.9	7.0	
Jul-04	0.0	0.0	0.0	1.40	0.12	0.10	0.00	0.00	0.00	1.9	0.0	0.0	1.0	0.0	0.0	2.1	0.0	0.0	7.0	7.2	7.2	
Aug-04	0.0	0.0	0.0	1.40	0.20	0.10	0.00	0.00	0.00	1.5	0.0	0.0	0.8	0.0	0.0	1.6	0.0	0.0	7.1	7.2	7.2	
Sep-04	0.0	0.0	0.0	0.50	0.10	0.10	0.00	0.00	0.00	0.5	0.0	0.0	0.4	0.0	0.0	0.8	0.0	0.0	7.1	7.4	7.4	
Oct-04	0.0	0.0	0.0	0.55	0.06	0.06	0.00	0.00	0.00	0.6	0.0	0.0	0.4	0.0	0.0	0.9	0.0	0.0	7.2	7.4	7.4	
Nov-04	0.0	0.0	0.0	0.35	0.15	0.15	0.00	0.00	0.00	0.3	0.0	0.0	0.4	0.0	0.0	0.8	0.0	0.0	6.9	7.3	7.3	
Dec-04	0.0	0.0	0.0	0.55	0.10	0.10	0.00	0.00	0.00	0.4	0.0	0.0	0.4	0.0	0.0	1.0	0.0	0.0	7.1	7.3	7.3	
Jan-05	0.0	0.0	0.0	0.65	0.10	0.10	0.00	0.00	0.00	0.6	0.0	0.0	0.8	0.0	0.0	1.0	0.0	0.0	7.2	7.4	7.4	
Feb-05	0.0	0.0	0.0	0.50	0.10	0.10	0.00	0.00	0.00	0.5	0.0	0.0	0.4	0.0	0.0	1.0	0.0	0.0	7.3	7.5	7.5	
Mar-05	0.0	0.0	0.0	0.35	0.05	0.05	0.00	0.00	0.00	0.4	0.0	0.0	0.2	0.0	0.0	0.6	0.0	0.0	7.5	7.7	7.7	
Apr-05	0.0	0.0	0.0	0.40	0.10	0.10	0.00	0.00	0.00	0.7	0.0	0.0	0.4	0.0	0.0	1.0	0.0	0.0	7.5	7.6	7.6	
May-05	0.0	0.0	0.0	0.40	0.10	0.10	0.00	0.00	0.00	0.6	0.0	0.0	0.4	0.0	0.0	0.9	0.0	0.0	7.0	7.3	7.3	
Max	0.0	0.0	0.0	2.60	0.20	0.15	0.00	0.00	0.00	1.9	0.0	0.0	1.2	0.0	0.0	3.0	0.0	0.0	7.5	7.7	7.7	
Min	0.0	0.0	0.0	0.35	0.05	0.05	0.00	0.00	0.00	0.3	0.0	0.0	0.2	0.0	0.0	0.5	0.0	0.0	6.0	6.9	7.0	
Average	0.0	0.0	0.0	0.77	0.09	0.09	0.00	0.00	0.00	0.8	0.0	0.0	0.5	0.0	0.0	1.1	0.0	0.0	7.1	7.3	7.4	

	F ⁻			Al ³⁺			Plate Count on nutrient agar			MPN of Coliform			MPN of E.Coli.		
	(mg/L)			(mg/L)			no/100mL			no/100mL			no/100mL		
	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated
Jan-03															
Feb-03															
Mar-03															
Apr-03															
May-03															
Jun-03	0.0	0.0		0.05			524	5	3	4,600	0	0	2,400	0	0
Jul-03	0.0	0.0		0.01			315	5	0	2,400	0	0	1,100	0	0
Aug-03	0.0	0.0					293	68	3	2,400	240	0	460	43	0
Sep-03	0.0	0.0					103	48	0	2,400	460	0	460	240	0
Oct-03	0.0	0.0		0.01			156	51	2	2,400	93	0	460	23	0
Nov-03	0.0	0.0	0.0	0.02	0.02		235	42	4	2,400	93	0	150	23	0
Dec-03	0.0	0.0	0.0	0.02	0.04		204	4	2	4,600	0	0	210	0	0
Jan-04	0.0	0.0	0.0				83	21	1	1,100	93	0	75	0	0
Feb-04	0.0	0.0		0.00	0.00										
Mar-04	0.0	0.0	0.0	0.00	0.00	0.00	179	34	3	2,400	93	0	460	23	0
Apr-04	0.0	0.0	0.0	0.00	0.00	0.00	119	24	3	2,400	43	0	460	23	0
May-04	0.0	0.0	0.0	0.00	0.00	0.00	127	66	1	2,400	460	0	150	93	0
Jun-04	0.0	0.0	0.0	0.00	0.00	0.00	188	34	0	4,600	75	0	2,400	20	0
Jul-04	0.0	0.0	0.0	0.00	0.01	0.01	194	59	0	2,400	240	0	1,100	93	0
Aug-04	0.0	0.0	0.0	0.00	0.01	0.01	308	12	0	4,600	23	0	1,100	0	0
Sep-04	0.0	0.0	0.0	0.00	0.00	0.00	121	5	0	2,400	9	0	460	0	0
Oct-04	0.0	0.1	0.1	0.00	0.08	0.08	223	9	1	2,400	43	0	1,100	15	0
Nov-04	0.0	0.0	0.0	0.00	0.04	0.04	162	16	1	2,400	93	0	210	15	0
Dec-04	0.0	0.0	0.0	0.00	0.02	0.02	102	18	4	1,100	43	0	210	4	0
Jan-05	0.0	0.0	0.0	0.00	0.01	0.01	122	18	0	2,400	43	0	1,100	23	0
Feb-05	0.0	0.0	0.0	0.00	0.00	0.00	162	18	1	2,400	150	0	1,100	4	0
Mar-05	0.0	0.0	0.0	0.00	0.00	0.00	112	12	0	2,400	9	0	210	0	0
Apr-05	0.0	0.0	0.0	0.00	0.00	0.00	93	15	3	2,400	150	0	240	23	0
May-05	0.0	0.0	0.0	0.00	0.04	0.04	120	74	3	2,400	240	0	240	93	0
Max	0.0	0.1	0.1	0.00	0.08	0.08	524	74	4	4,600	460	0	2,400	240	0
Min	0.0	0.0	0.0	0.00	0.00	0.00	83	4	0	1,100	0	0	75	0	0
Average	0.0	0.0	0.0	0.00	0.02	0.01	185	29	2	2,670	117	0	689	33	0




Figure M31.5.3 Monthly Water Quality of Podosem Water Treatment Plant
Analysed by PWD's Laboratory from January 2003 to May 2005 (1/2)




Figure M31.5.3 Monthly Water Quality of Podosem Water Treatment Plant
Analysed by PWD's Laboratory from January 2003 to May 2005 (2/2)

Table M31.5.5

List of Reservoirs for the Sanquelim Water Supply Scheme

Series No.	System	Inlet Pipe		Name of GLR / OHR (Name of Location)	GLR/OHR			Supply Area		Remarks	
		Dia. (mm)	Material		Type	Capacity (m ³)	RL	HWL	LWL		Taluka
1	Sanquelim			Sanquelim WTP	MBR	800	56.00				
2					MBR	1,000	56.00				
3			250 ACP	Sanquelim	GLR	300	30.00				
4			250 ACP		GLR	300	30.00			Carapur(CT)(24)	w/Pumping Station, Pumping to Series
5			250 CIP	Sanquelim	GLR	800	95.00		Bicholim	Sanquelim(M CI)(25)	
6			50 CIP	Virdi	GLR	300	65.00		-ditto-	Sanquelim(M CI)(25)	
7			150 ACP	Pariem (?)	OHR	150	68.00		-ditto-	Sanquelim(M CI)(25)	
			Sub-Total		3,650						
8	Podocem-1			Podocem WTP	MBR	5,000	113.00	117.00	113.00	-ditto-	
9					MBR	5,000	113.00	117.00	113.00	-ditto-	
10				Curchirem	GLR	100	54.00		Bicholim	Curchirem(10)	
11			350 DIP	Sarvana	GLR	800	62.00		-ditto-	Bicholim(M CI)(23), Sarvona(11)	
12			350 DIP	Bicholim	GLR	800	35.00				w/Pumping Station, Pumping to Mayem
13			350 DIP		GLR	150	22.00		Bicholim	Bicholim(M CI)(23)	
14			350 DIP		GLR	300	42.00		-ditto-	Ona(8)	
15			300 CIP	Mayem	GLR	800	84.00		-ditto-	Maemt(12), Vainguinim(13), Anurli(14), Naroa(15)	
16			300 CIP		GLR	800	84.00		-ditto-	Ambarim(1), Choraoc(2), Caraim(3), Capao(4)	
17			100 CIP	Pilgao	GLR	100	50.00		-ditto-	Pilgao(16)	
18			150 DIP	Mulgao	GLR	300	54.00		-ditto-	Milgao(7)	
19					OHR		45.00				
20		100 PVC	Maulinguem North	GLR	50	35.00		-ditto-	Maulinguem North(9)		
21		100 CIP	Ladfem	GLR	50	35.00		-ditto-	L.atambarcem(4)		
			Sub-Total		14,250						
22	Podocem-2	150 DIP	Navelim	GLR	300	54.00		Bicholim	Navelim(19)		
23		150 DIP	Honda	GLR	300	68.00		Satari	Onda(21)		
24		150 ACP	Pisurlem	GLR	150	61.00		-ditto-	Pissurlem(43)		
25		150 DIP	Dignem	GLR	300	90.00		Bicholim	Cudnem(17)		
26		150 DIP	Amona	GLR	150	70.00		-ditto-	Amone(18)		
27		250 CIP	Surla	GLR	800	87.00		-ditto-	Cotombi(20), Surla(21), Pale(CT)(26)		
28		150 DIP	Velgem	GLR	300	62.00		-ditto-	Velguem(22)		
29		200 CIP	Pali	GLR	300	130.00		-ditto-		w/Pumping Station	
30		200 CIP		GLR	300	130.00		-ditto-	Pale(CT)(26)	Not in Operation	
				Sub-Total		2,900					
	Total				17,150						
					11.1						

Note: RL=Reduced Level (Base Elevation of GLR), HWL=High Water Level in Reservoir, LWL=Low Water Level in Reservoir, GLR=Ground Level Reservoir, OHR=Over Head Reservoir, MBR=Master Balancing Reservoir

M31.6 Dabose Water Supply Scheme

The scheme consists of a 5 MLD plant, commissioned around 1992. We are told that the plant is currently running at 7 MLD to help meet demand.

The raw water pump house contains two pumps (one duty) and takes water from the Madei River. The pumps are well guarded.

The plant is manually operated. The plant appears to be in good working condition despite its age. There are no flow measuring devices. Security arrangements at the site are good. Maintenance standards are very good, except for at the chemical mixing areas. The chlorine house is equipped with two No. 1 tonne cylinders and one vacuum type chlorinator. There is no standby chlorinator. An immersion tank is available. The chlorination system appears to be well maintained and tidy.

A standby generator is available at the site for use during power failures. Records of pump operating hours, loads, chemical use and treatment parameters are logged.

Table M31.6.1 lists the summary of asset data for the WTP and Table M31.6.2 contains detailed asset data for the WTP. The plant schematic is shown on Figure M31.6.1.

Table M31.6.3 and Figure M31.6.2 show the data on monthly water quality at Dabose Water Treatment Plant. Table M31.6.4 shows a list of existing reservoirs for Dabose Water Supply Scheme.

Table M31.6.1 Summary of Asset Register of Dabose Water Treatment Plant

Name of Facility		Contents of Facility	Remarks
Raw Water Intake & Raw Water Transmission Facility	Jack Well & Connecting Pipe	^D 6.0 m × ^H 17.0m D400mm × CIP × 7.0m × 1 Line	Manderi River
	Pump & Motor	Vertical Pump: ^Q 260m ³ /hr × ^H 42m × 45kw × 2 units (1 – Standby) Submersible Pump: ^Q 100m ³ /hr × ^H 42m × 20kw × 1 unit	Design Cap. of Intake Pump = 6.5MLD
	Raw Water Transmission Main	D350mm × 300m × CIP × 1 Line	
Treatment Facility	Aerator	Cascade Type: 1 unit	
	Parshal Flume & Flash Mixer	Each 1 unit (for Chemical Dosing)	
	Clariflocculator	Circular Horizontal Flow Type with Center Feed/Peripheral Collection Flocculation & Clarifier: ^D 26.0m (Flocc. Zone 3.0m) × ^{WD} 4.0m × 1 unit Detention Period: Flocculation – 7.8min Clarifier – 9.6hrs ¹⁾ Surface Loading for Clarifier: 10 m ³ /m ² /d (7.0 mm/min) ²⁾	1): 2~2.5 hrs 2): 30~40m ³ /m ² /d
Filter	Gravity Rapid Sand Filter Type ^W 4.7m × ^L 5.00m × 2cells/basin × 3 basins Effective Size of Sand: 0.??mm, Depth of Sand: 0.??m Filter Area: 11.75 m ² /cell, 23.5 m ² /basin Filtration Rate: 5.0 m/hr ³⁾ (74.5 m/d) Air Scouring Rate: 22.2 m/hr/cell ⁴⁾ (0.37m ³ /min/m ² /cell) Backwash Rate: 12 m/hr/cell ⁵⁾ (0.20m ³ /min/m ² /cell)	Based on Specifications of Air Blower & Backwash Pump 3): 4.8~6.0m/hr 4): 36~54m/hr 5): 24~36m/hr	
Clear Water Facility	Clear Water Sump	^D 11.5m × × ^{WD} 4.0m × 1 unit Total Volume=415 m ³ Retention Time: 2.0 hr	
Chemical Feeding Facility	Alum Feeding Facility	Dry Aluminum Sulfate Solution Tank: 2 units	
	Lime Feeding Facility	Powder Lime Solution Tank: 2 units	
	Disinfection Facility	Liquid Chlorine (1 tone Container – net 900kg) Chlorinator: 2 units	
Laboratory	Frequency of Sampling & Analysis	Not In-Service, Jar Test: Not in Service Daily test: pH, R-Cl Fortnightly: 20 Parameters	
Clear Water Transmission Facility	Transmission Pump & Motor	Horizontal Centrifugal Pump: ^Q 230m ³ /hr × ^H 95m × 110kw × 3 units (1 or 2 – Standby)	Design Cap. of Pump = 11MLD
	Rising Main	D300mm × CIP × 15m × 1 Line D350mm × CIP × 800m × 1 Line	
	Clear Water Reservoir (MBR)	^D 16.0m × × ^{WD} 4.0m × 1 unit Total Volume=800 m ³	

Note: 1) ~ 4) are referring to “Manual on Water Supply and Treatment, Third Edition – Revised and Updated, May 1999”




Figure M31.6.1 Schematic Sequence of Dabose Water Treatment Plant

Table M31.6.2 Present Conditions of Dabose Water Treatment Plant (1/6)

Item		Contents		Remarks
Background				
Covered Area for Water Supply		Taluka	Part of Sattari	
Name of Plant				
Number of W.T.P.		Number	(1)	
Capacity of Plant		MLD	5	
		m ³ /d	5,000	
Raw Water Resources		River	Madei	
		Dam		
Year of Construction		Year	1990 - 1992	
Year of Commission		Year	1992	
Expected Augmentation Plan			10 MLD	

Table M31.6.2 Present Conditions of Dabose Water Treatment Plant (2/6)

Name of Facility		Contents of Facility		Remarks	
Capacity of Raw Water Intake & Water Treatment Plant	MLD	5.25		: 5% Loss of Nominal Capacity	
	m ³ /d	5,250			
Head Water Works : Raw Water Intake					
Intake Well	Diameter	m	6.00		
	Height	m	8.00		
	Water Depth	m	?		
	Volume	m ³ /unit	0.0		
	Water Level of River				
		H.W.L.	m	?	
	L.W.L.	m	?		
Connecting Pipe	Diameter	mm	400		
	Length	m	7.0		
	Material	CIP			
	Velocity	m/sec	0.484		
	Loss of Head	m	0.006		
	: Hazen-Williams Formula				
Jack Well & Pump House	Diameter	m	6.00		
	Height	m	17.00		
	Water Depth	m	?		
	Volume	m ³ /unit	0		
	Detention Time	min	0.00		
Control Room	Width	m	4.0		
	Length	m	4.0		
	Area of Floor	m ²	16.0		
Raw Water Pump	Capacity	ℓ/sec	72.2	27.8	
		m ³ /min	4.33	1.67	
		m ³ /hr	260	100	
		m ³ /d	6,240	2,400	
	Number	unit	2	1	
	Stand-by	unit	0	1	
	Total Capacity	m ³ /d	12,480		
	Head	m	42.0	42.0	
	Type of Pump	Centrifugal Submersible			
	Maker	Jyoti (V.T.)			
Year of Manufacture	1992	1996			
Assessment of Condition	Working Condition				
Raw Water Motor	Motor Output	HP	60	27	
		kW	45	20	
	Number	Unit	2	1	
	Maker	Kirlosker -			
	Year of Manufacture	1992	1996		
Assessment of Condition	Working Condition				
Raw Water Transmission Line	Diameter	mm	350		
	Length	m	300		
	Material	CIP			
	Velocity	m/sec	0.174		
	Loss of Head	m	0.500		
	Assessment of Condition	Pipe	Good		
	Valve	Good			
Water Treatment Plant					
Aerator	Capacity	m ³ /hr	218.8	208	
		m ³ /d	5,250	4,992	
	Number	Unit	1		
	Diameter	m	3.65		
	Height	m	?		
	EL. of Top Aerator	m	?		
	Assessment of Condition	Working			
Parshal Flume	Number	Unit	1		
	Assessment of Condition	Working			

Table M31.6.2 Present Conditions of Dabose Water Treatment Plant (3/6)

Name of Facility			Contents of Facility	Remarks
Flash Mixer	Number	Unit	1	
	Assessment of Condition		Working	
Clarifiers / Settling Tank (Coagulation Basin)	Design Capacity	m ³ /min/unit	3.6	
		m ³ /hr/unit	218.8	
		m ³ /d/unit	5,250	
	Number	Unit	1	
	Type of Clarifier		Circular Horizontal Flow Type with Center Feed /Peripheral Collection	
	Water Depth	m	4.00	
	Overall Diameter	m	26.00	
	Flocc. Zone Dia.	m	3.00	
	Frequency of Desludging		Once a Day : General Season Twice a Day : Monsoon Season	
	Volume			
	Overall	m ³ /unit	2,123.7	
	Flocculation Zone	m ³ /unit	28.3	
	Clarifying Zone	m ³ /unit	2095.4423	
	Retention Time			
	Flocculation Zone	min	7.8	
	Clarifying Zone	min	574.7 OK	
	Overall	min	582.5	
Surface Area	m ² /unit	523.9		
Surface Loading	mm/min	7.0 OK		
W.L. of Clarifier	m	?		
Assessment of Condition		Working		
Flocculator & Drive Arrangement	Number	unit	1	
	Assessment of Condition		Working	
Filter	Design Capacity	m ³ /hr/unit	72.9	
		m ³ /d/unit	1,750	
	Number	Unit	3	
	Type		Rapid Sand Gravity Filter	
	Width	m	5.00	
	Length	m	4.70	
	Water Depth	m	?	
	Filtered Area	m ² /unit	23.5	
	Velocity	m ³ /d/m ²	74.5 OK	
	Filter Media		Standard Size	
	E.S. of Sand	mm	?	
	Depth of Sand	mm	?	
	Type of Underdrain System		?	
	Year Replacement of Media		Replacement (Year: Jun. '05)	
	W. L. of Filter	m	?	
	Assessment of Condition		Working	
	Filter Washing Criteria & Method	Air Scouring Rate	m ³ /min/m ²	0.37 NO
Air Scouring Time		min	5	
Backwash Rate		m ³ /min/m ²	0.2 NO	
Backwashing Time		min	10	
Frequency of Washing		General : Once a Day Maximum : Once a Day		

: E.S. = Effective Size

Table M31.6.2 Present Conditions of Dabose Water Treatment Plant (4/6)

Name of Facility			Contents of Facility	Remarks
Backwash Pump & Motor	Capacity	m ³ /min	5.46	
		m ³ /hr	327.6	
		m ³ /d	7,862	
	Number	unit	2	
	Stand-by	unit	1	
	Total Capacity	m ³ /min	5.46	
		m ³ /d	7,862.4	
	Head	m	17.0	
	Type of Pump	Centrifugal		
	Motor Output	HP		
		kW	26.0	
Assessment of Condition			Working	
Air Blower	Capacity	m ³ /min	8.80	
		m ³ /hr	528.0	
		m ³ /d	12,672	
	Number	unit	2	
	Stand-by	unit	1	
	Total Capacity	m ³ /min	8.80	
		m ³ /d	12,672	
	Head	mm WG		
	Motor Output	HP		
		kW	9.3	
	Maker			
Assessment of Condition			Working	
Clear Water Reservoir (Sump)	Diameter	m	11.50	
	Water Depth	m	4.00	
	Number	Unit	1	
	Volume	m ³	415	
	Total	m ³	415	
	Detention Time	hr	2.0	
	Last Date of Cleaning			Pediodical
	Water Level	m	?	
			?	
	Assessment of Condition			Working
Chemical Facility				
Alum Feeding Facility	Capacity	kg/hr		
		m ³ /unit	2.0	
	Diameter	m		
	Width	m		
	Length	m		
	Height	m		
	Volume	m ³		
	Number	Unit	2	
	Stand-by			
	Assessment of Condition			Working

Table M31.6.2 Present Conditions of Dabose Water Treatment Plant (5/6)

Name of Facility		Contents of Facility			Remarks
Lime Feeding Facility	Capacity	kg/hr			
		m ³ /unit	1.0		
	Diameter	m			
	Width	m			
	Length	m			
	Height	m			
	Volume	m ³			
	Number	Unit		2	
	Stand-by				
	Assessment of Condition	Working			
Disinfection System	Chemical Used		Liquid Chlorine		
	Type of Plant & Machinery		Pre & Post		
	Capacity	kg/hr	2.0		
	Number	Unit	2		
	Stand-by				
	Safty Measures Taken		Clynder Emercing Tank		
	Commissioned		1992		
Assessment of Condition		Working Condition			
Laboratory					
Chemical Testing Laboratory		Not Provided			: ? month store
Jar Testing		?			
Availability of Skilled Chemists		3 Persons			
Availability of Required Chemicals		From Assonora Store			
Use of Test Reports		As per Format			
Frequency of Sampling & Analysis		pH & Residual Cl : 3 Times/Day 20 Parameters Test : 2 Times/Month			
General Quality of Water		Treatable with conventional Water Treatment Process			
Raw Water Quality		Turbid., Low pH			
Clear Water Quality		Excellent			
Transformers					
Number of Transformer		(1)	(2)	(3)	: Diesel Generator: 250 kVA
Pole Mounted / Pad Mounted		Pole	Pole	Floor	
Capacity	kVA	200	200	630	
Number	Unit	1	1	1	
Stand-by		1			
Commissioned		1992	1992	Old Set	
Likely Design Life	Year	30	30	-	
Last Replacement		Nil	Nil	Nil	
Assessment of Condition		Good	Good	Good	
Equipment Status					
Flow Meters		No Flow Meters			
Other Operating Valves		Working			
Other Important Assets					
Valve's Condition		Working Condition			
Visible Leakage and Locations					
Building Condition		Good			
Wastewater Disposal Arrangements		Sludge Chamber Connected to Nalla			

Table M31.6.2 Present Conditions of Dabose Water Treatment Plant (6/6)

Name of Facility			Contents of Facility		Remarks	
Transmission (Clear Water) Facility						
Transmission (Clear Water) Pump	Capacity	ℓ/sec	63.9	63.9		
		m ³ /min	3.83	3.83		
		m ³ /hr	230.0	230.0		
		m ³ /d	5,520	5,520		
	Number	unit	2	1		
	Stand-by		1	1		
	Total Capacity	m ³ /d	5,520			
	Head	m	95.0	95.0		
	Type of Pump	Centrifugal Pump				
	Maker	M & Platt				
Year of Manufacture	1992	Old				
Assessment of Condition	Pump	Working Condition				
	Valve	Working Condition				
Transmission (Clear Water) Motor	Motor Output	HP	135	135		
		kW	110	110		
	Number	Unit	2	1		
	Maker	Kirlosker				
	Year of Manufacture	1992	Old			
Assessment of Condition	Working Condition					
Raising Main (Transmission Lines)	Diameter	mm	350	300		
	Length	m	800	15		
	Material		CIP	CIP		
	Velocity	m/sec	0.601	0.819	Total	
	Loss of Head	m	1.217	0.048	1.266 : Hazen-Williams Formula	
	Assessment of Condition	Pipe	Working Condition			
	Valve	Working Condition				
Master Balancing Reservoir (M.B.R.)	Diameter	m	16.00			
	Water Depth	m	4.00			
	Number	Unit	1			
	Volume	m ³	804			
	Total	m ³	804			
	Detention Time	hr	3.9			
	Last Date of Cleaning	Pedioidal				
	Water Level	m	?			
Assessment of Condition	Working Condition					
Organization & Staff Deployed						
General Shift	Working Hour :	08:30 → 17:30 (13:00 → 14:00 : Lunch Time)				
	Staff Deployed :	Management Staff - Engineers				
		Manager	1 Person			
		Mechanics	1 Person			
		Sweeper	2 Persons			
	Helper	5 Persons				
	Total	9 Persons				
Shift in Plant Operation	Shifting System	3 Shifting System Covering 24 Hours				
	Working Hour :	①: 08:00 → 14:00 , ②: 14:00 → 20:00 , ③: 20:00 → 08:00				
	Grouping Staff Deployed :	Manager, Electrician, Lab - Assistant, Operator, Helper & Security	Total 10 Persons/Group			
Staff Deployed at the Plant		Person	Qualification	Year of Service at		
Management Staff - Engineers					PWD's Staff	
	Assistant Engineer	1	D.C.E.	32		1
	Junior Engineer	1	D.C.E.	15		8
	Sub-total	2				
Skilled Staff - Operators / Quality Testing					Goa PWD Labour Society's Staff (Yearly Contract Basis)	
	Manager	2 Graduate	6	6		
	Mechanics	1 I.T.I.	12	12		
	Electrician	3 I.T.I.	12	12		
	Lab - Assistant	3 I.T.I.	12	12		
	Operator	9 I.T.I.	12	12		
	Sub-total	18				
Unskilled Staff		19 - Helper, Sweeper, Security Guards				
Total Number		39				

**Table M31.6.3 Monthly Water Quality of Dabose Water Treatment Plant
Analysed by PWD's Laboratory from January 2003 to May 2005 (1/2)**

	Color			Odor			Taste			Turbidity (NTU)			pH			Specific Conductivity (/u mhos/cm)			Total Solids (mg/L)		
	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated
Jan-03	0.0	0.0		Unobjectable			Unobjectable			6.0	1.4		6.8	7.2		77.4	78.0		52.0	51.0	
Feb-03	0.0	0.0		Unobjectable			Unobjectable			2.3	0.5		7.0	7.1		92.2	93.5		60.0	60.0	
Mar-03	0.0	0.0		Unobjectable			Unobjectable			4.6	1.4		6.7	7.0		107.9	113.8		71.0	73.0	
Apr-03	0.0	0.0		Unobjectable			Unobjectable			4.5	0.8		7.0	7.2		108.0	108.9		72.0	71.0	
May-03	0.0	0.0		Unobjectable			Unobjectable			4.9	1.8		6.8	6.9		130.8	137.9		86.0	88.0	
Jun-03	0.0	0.0		Unobjectable			Unobjectable			6.0	1.3		6.8	7.0		84.7	90.3		56.0	58.0	
Jul-03	0.0	0.0		Unobjectable			Unobjectable			35.5	2.4		6.7	7.1		47.6	69.7		42.0	45.0	
Aug-03	0.0	0.0		Unobjectable			Unobjectable			16.2	3.5		6.8	7.1		48.3	52.2		35.0	33.5	
Sep-03	0.0	0.0		Unobjectable			Unobjectable			10.0	1.2		7.2	7.4		52.2	58.2		38.0	38.0	
Oct-03	0.0	0.0	0.0	Unobjectable			Unobjectable			8.1	0.9	0.5	7.3	7.4	7.4	59.1	61.3	61.6	40.0	39.0	39.0
Nov-03	0.0	0.0	0.0	Unobjectable			Unobjectable			4.0	1.6	1.3	7.3	7.4	7.2	75.2	75.3	75.6	50.0	48.0	48.0
Dec-03	0.0	0.0	0.0	Unobjectable			Unobjectable			3.0	1.2	1.2	7.3	7.5	7.5	72.2	74.4	74.3	47.0	47.0	47.0
Jan-04	0.0	0.0	0.0	Unobjectable			Unobjectable			3.5	0.8	0.5	7.2	7.3	7.2	82.7	82.9	82.8	54.0	53.0	53.0
Feb-04	0.0	0.0	0.0	Unobjectable			Unobjectable			1.8	0.2	0.2	7.1	7.3	7.2	91.6	95.5	95.8	58.5	61.0	61.0
Mar-04	0.0	0.0	0.0	Unobjectable			Unobjectable			3.6	0.4	0.4	7.3	7.4	7.1	114.1	116.7	115.8	74.0	74.0	74.0
Apr-04	0.0	0.0	0.0	Unobjectable			Unobjectable			4.0	0.6	0.6	7.2	7.4	7.4	123.8	124.0	124.2	80.5	79.0	79.0
May-04	0.0	0.0	0.0	Unobjectable			Unobjectable			7.4	1.2	1.0	7.2	7.4	7.4	130.8	141.6	141.8	85.0	90.5	90.5
Jun-04	0.0	0.0	0.0	Unobjectable			Unobjectable			72.0	1.9	1.4	6.9	6.9	6.9	48.0	101.2	101.7	55.0	70.0	68.5
Jul-04	0.0	0.0	0.0	Unobjectable			Unobjectable			8.0	2.3	1.5	7.2	7.2	6.0	58.1	58.4	58.0	39.5	37.0	37.0
Aug-04	0.0	0.0	0.0	Unobjectable			Unobjectable			70.7	3.5	2.5	7.4	7.5	7.1	39.3	68.5	75.7	43.5	45.0	48.0
Sep-04	0.0	0.0	0.0	Unobjectable			Unobjectable			9.2	2.3	2.0	7.3	7.5	7.5	54.6	60.1	60.2	38.0	38.0	38.0
Oct-04	0.0	0.0	0.0	Unobjectable			Unobjectable			7.7	1.4	1.2	7.2	7.4	7.4	71.0	73.1	73.4	47.0	46.5	46.5
Nov-04	0.0	0.0	0.0	Unobjectable			Unobjectable			4.4	1.6	1.5	7.3	7.4	7.4	76.5	76.9	76.9	50.0	49.0	49.0
Dec-04	0.0	0.0	0.0	Unobjectable			Unobjectable			2.9	1.3	1.1	7.4	7.5	7.3	80.5	80.6	80.7	52.0	52.0	52.0
Jan-05	0.0	0.0	0.0	Unobjectable			Unobjectable			6.7	1.7	1.5	6.9	7.1	7.0	87.3	89.3	88.8	58.0	57.0	57.0
Feb-05	0.0	0.0	0.0	Unobjectable			Unobjectable			3.9	1.2	1.2	6.8	7.0	7.0	90.7	92.6	92.6	59.0	59.0	59.0
Mar-05	0.0	0.0	0.0	Unobjectable			Unobjectable			5.2	1.7	1.6	6.9	7.1	7.0	110.0	112.0	111.9	72.0	71.5	71.5
Apr-05	0.0	0.0	0.0	Unobjectable			Unobjectable			7.0	1.8	1.8	6.9	7.2	7.2	124.0	130.0	130.0	81.0	83.0	83.0
May-05	0.0	0.0	0.0	Unobjectable			Unobjectable			5.8	1.7	1.8	6.9	7.1	7.1	118.2	119.5	120.0	77.0	76.0	76.0
Max	0.0	0.0	0.0							72.0	3.5	2.5	7.4	7.5	7.5	130.8	141.6	141.8	86.0	90.5	90.5
Min	0.0	0.0	0.0	Unobjectable			Unobjectable			1.8	0.2	0.2	6.7	6.9	6.0	39.3	52.2	58.0	35.0	33.5	37.0
Average	0.0	0.0	0.0							11.3	1.5	1.2	7.1	7.2	7.2	84.7	90.9	92.1	57.7	58.4	58.9

	Total Dissolved Solids(TDS)			Suspended Solids			Total Hardness as CaCO ₃ (TA)			Ca ²⁺			Mg ²⁺			Cl ⁻			Total Alkalinity as CaCO ₃		
	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated
Jan-03	50.0	51.0		2.0			33.0	34.0		8.8	9.2		2.75	2.75		6.0	6.0		34.0	35.0	
Feb-03	59.0	60.0		1.0			33.0	33.0		10.4	10.4		1.75	1.75		6.0	6.0		17.0	17.0	
Mar-03	69.0	73.0		2.0			48.0	50.0		11.6	12.0		4.75	5.00		6.0	6.0		40.0	48.0	
Apr-03	70.0	71.0		2.0			48.0	48.0		12.8	12.8		4.00	4.00		6.0	6.0		58.0	58.0	
May-03	84.0	88.0		2.0			57.0	59.0		13.6	14.4		5.57	5.75		8.0	8.0		63.0	63.0	
Jun-03	54.0	58.0		2.0			37.0	39.0		8.4	9.2		4.00	6.40		6.0	6.0		35.0	35.0	
Jul-03	31.0	45.0		11.0			18.0	31.0		4.0	8.8		2.00	2.25		20.0	28.0		4.0	4.0	
Aug-03	30.0	33.5		5.0			17.0	17.0		4.4	4.4		1.50	1.50		4.0	4.0		22.0	22.0	
Sep-03	35.0	38.0		3.0			21.0	24.0		4.8	5.6		2.25	2.25		6.0	6.0		23.0	25.0	
Oct-03	38.0	39.0	39.0	2.0			25.0	25.0	25.0	5.6	5.6	5.6	2.75	2.75	2.75	6.0	6.0	6.0	28.0	28.0	28.0
Nov-03	48.0	48.0	48.0	2.0			29.0	29.0	29.0	6.8	6.8	6.8	3.00	3.00	3.00	6.0	6.0	6.0	35.0	33.0	33.0
Dec-03	46.0	47.0	47.0	1.0			32.0	32.0	32.0	8.0	8.0	8.0	3.00	3.00	3.00	6.0	6.0	6.0	35.0	35.0	35.0
Jan-04	52.5	53.0	53.0	1.5			34.0	34.0	34.0	8.0	8.0	8.0	3.50	3.50	3.50	6.0	6.0	6.0	36.0	36.0	36.0
Feb-04	58.5	61.0	61.0	0.0	0.0	0.0	39.0	39.0	39.0	9.6	10.0	10.0	3.50	3.50	3.50	6.0	6.0	6.0	41.0	41.0	41.0
Mar-04	73.0	74.0	74.0	1.0	0.0		48.0	48.0	48.0	11.6	11.6	11.6	4.75	4.75	4.75	6.0	6.0	6.0	55.0	55.0	55.0
Apr-04	79.0	79.0	79.0	1.5	0.0	0.0	52.0	52.0	52.0	8.0	8.0	8.0	5.00	5.00	5.00	6.0	6.0	6.0	58.0	58.0	58.0
May-04	83.0	90.5	90.5	2.0	0.0	0.0	55.0	66.0	66.0	16.0	17.6	17.6	3.75	5.50	5.50	7.0	7.0	7.0	58.0	65.0	66.0
Jun-04	30.5	64.5	65.0	24.5	5.5	3.5	16.0	40.0	40.0	3.6	13.2	13.2	1.75	1.75	1.75	8.0	8.0	8.0	12.0	15.0	15.0
Jul-04	37.0	37.0	37.0	2.5	0.0	0.0	21.0	21.0	21.0	5.2	5.2	5.2	2.00	2.00	2.00	6.0	6.0	6.0	23.0	23.0	23.0
Aug-04	25.5	44.0	48.0	20.0	1.0	0.0	16.0	25.0	25.0	4.0	6.0	6.0	1.50	2.50	2.50	5.0	5.0	5.0	19.0	19.0	19.0
Sep-04	35.0	38.0	38.0	3.0	0.0	0.0	21.0	23.0	23.0	4.8	5.6	5.6	2.25	2.25	2.25	5.0	5.0	5.0	24.0	26.0	26.0
Oct-04	45.0	46.5	46.5	2.0	0.0	0.0	26.0	28.0	28.0	6.0	6.8	6.8	2.75	2.75	2.75	5.0	5.0	5.0	20.0	30.0	30.0
Nov-04	49.0	49.0	49.0	1.0	0.0	0.0	29.0	29.0	29.0	6.8	7.2	7.2	2.75	2.75	2.75	7.0	7.0	7.0	32.0	33.0	33.0
Dec-04	51.5	52.0	52.0	0.5	0.0	0.0	30.0	30.0	30.0	7.6	7.6	7.6	2.75	2.75	2.75	7.0	7.0	7.0	33.0	34.0	34.0
Jan-05	56.0	57.0	57.0	2.0	0.0	0.0	38.0	39.0	39.0	10.4	10.8	10.8	3.00	3.00	3.00	7.0	7.0	7.0	40.0	40.0	40.0
Feb-05	58.0	59.0	59.0	1.0	0.0	0.0	40.0	43.0	43.0	10.8	12.0	12.0	3.25	3.25	3.25	6.0	6.0	6.0	46.0	46.0	46.0
Mar-05	70.0	71.5	71.5	2.0	0.0	0.0	44.0	45.0	45.0	11.6	12.0	12.0	3.75	3.75	3.75	7.0	7.0	7.0	50.0	52.0	52.0
Apr-05	79.0	83.0	83.0	2.0	0.0	0.0	55.0	57.0	57.0	14.4	15.2	15.2	4.75	4.75	4.75	7.0	8.0	8.0	53.0	55.0	55.0
May-05	75.5	76.0	76.0	1.5	0.0	0.0	52.0	52.0	52.0	13.6	13.6	13.6	4.50	4.50	4.50	7.0	7.0	7.0	52.0	49.0	49.0
Max	84.0	90.5	90.5	24.5	5.5	3.5	57.0	66.0	66.0	16.0	17.6	17.6	5.57	6.40	6.40	20.0	28.0	28.0	65.0	66.0	66.0
Min	25.5	33.5	37.0	0.0	0.0	0.0	16.0	17.0	21.0	3.6	4.4	5.2	1.50	1.50	1.75	4.0	4.0	5.0	4.0	4.0	15.0
Average	54.2	58.2	58.7	3.6	0.4	0.2	35.0	37.7	37.9	8.7	9.6	9.5	3.20	3.40	3.35	6.7	7.0	6.4	36.1	37.2	38.7

**Table M31.6.3 Monthly Water Quality of Dabose Water Treatment Plant
Analysed by PWD's Laboratory from January 2003 to May 2005 (2/2)**

	SO ₄ ²⁻ (mg/L)			Fe ²⁺ (mg/L)			Mn ²⁺ (mg/L)			NO ₃ ²⁻ (mg/L)			KMnO ₄ oxidizability as O ₂ (mg/L)			BOD at 27°C and 3days (mg/L)			DO (mg/L)			
	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	
Jan-03				0.64	0.10					0.6				0.3		0.5						
Feb-03				0.56	0.10					0.6				0.2		0.5						
Mar-03				0.70	0.10					0.4				0.2		0.5						
Apr-03				0.40	0.10			0.00		0.4				0.3		0.6						
May-03				0.25	0.06					0.4				0.2		0.5						
Jun-03				0.40	0.10			0.60		0.4				0.8								
Jul-03		0.0		1.20	0.10					0.8			0.2		1.8							
Aug-03				1.40	0.30					0.7			0.2		1.0							
Sep-03				0.45	0.10					0.5				0.5		0.9				7.3	7.4	
Oct-03				1.00	0.05	0.05				0.9				0.5		1.2				7.0	7.1	7.1
Nov-03				0.64	0.05	0.05				1.0				0.4		0.8				7.2	7.3	7.5
Dec-03				0.55	0.10					0.8				0.4		1.2				7.5	7.6	7.6
Jan-04				0.30	0.10	0.10				1.2				0.4		1.0				7.1	7.4	7.4
Feb-04	0.0	0.0	0.0	0.30	0.05	0.05	0.00	0.00	0.00	1.0	0.0	0.0	0.3	0.0	0.0	0.8	0.0	0.0	7.1	7.4	7.5	
Mar-04	0.0	0.0	0.0	0.25	0.05	0.05	0.00	0.00	0.00	1.0	0.0	0.0	0.3	0.0	0.0	0.6	0.0	0.0	7.0	7.4	7.4	
Apr-04	0.0	0.0	0.0	0.30	0.05	0.05	0.00	0.00	0.00	0.9	0.0	0.0	0.3	0.0	0.0	0.8	0.0	0.0	6.8	7.2	7.3	
May-04	0.0	0.0	0.0	0.50	0.06	0.06	0.00	0.00	0.00	1.1	0.0	0.0	0.4	0.0	0.0	1.0	0.0	0.0	7.0	7.2	7.2	
Jun-04	0.0	0.0	0.0	3.60	0.60	0.50	0.00	0.00	0.00	2.1	0.8	0.0	1.2	0.4	0.0	2.8	1.0	0.0	6.8	6.9	7.0	
Jul-04	0.0	0.0	0.0	0.50	0.20	0.10	0.00	0.00	0.00	0.9	0.0	0.0	0.4	0.0	0.0	1.0	0.0	0.0	6.9	7.1	7.1	
Aug-04	0.0	0.0	0.0	4.10	0.30	0.20	0.00	0.00	0.00	3.2	0.3	0.0	1.0	0.2	0.0	2.2	0.5	0.0	7.2	7.3	7.3	
Sep-04	0.0	0.0	0.0	0.50	0.10	0.10	0.00	0.00	0.00	0.6	0.0	0.0	0.4	0.0	0.0	0.8	0.0	0.0	7.3	7.4	7.4	
Oct-04	0.0	0.0	0.0	0.60	0.60	0.60	0.00	0.00	0.00	0.5	0.0	0.0	0.4	0.0	0.0	1.0	0.0	0.0	7.1	7.3	7.3	
Nov-04	0.0	0.0	0.0	0.35	0.35	0.35	0.00	0.00	0.00	0.2	0.0	0.0	0.3	0.0	0.0	0.6	0.0	0.0	7.1	7.3	7.3	
Dec-04	0.0	0.0	0.0	0.30	0.10	0.10	0.00	0.00	0.00	0.2	0.0	0.0	0.2	0.0	0.0	0.5	0.0	0.0	7.1	7.4	7.4	
Jan-05	0.0	0.0	0.0	0.50	0.10	0.10	0.00	0.00	0.00	0.4	0.0	0.0	0.5	0.0	0.0	1.0	0.0	0.0	7.3	7.5	7.5	
Feb-05	0.0	0.0	0.0	0.25	0.10	0.10	0.00	0.00	0.00	0.0	0.0	0.0	0.2	0.0	0.0	0.5	0.0	0.0	7.3	7.4	7.4	
Mar-05	0.0	0.0	0.0	0.50	0.08	0.08	0.00	0.00	0.00	0.7	0.0	0.0	0.4	0.0	0.0	0.8	0.0	0.0	7.5	7.7	7.7	
Apr-05	0.0	0.0	0.0	0.60	0.10	0.10	0.00	0.00	0.00	0.8	0.0	0.0	0.6	0.0	0.0	1.3	0.0	0.0	7.5	7.6	7.6	
May-05	0.0	0.0	0.0	0.25	0.05	0.05	0.00	0.00	0.00	0.8	0.0	0.0	0.4	0.0	0.0	1.0	0.0	0.0	7.0	7.3	7.3	
Max	0.0	0.0	0.0	4.10	0.60	0.60	0.60	0.00	0.00	3.2	0.8	0.0	1.2	0.4	0.0	2.8	1.0	0.0	7.5	7.7	7.7	
Min	0.0	0.0	0.0	0.25	0.05	0.05	0.00	0.00	0.00	0.0	0.0	0.0	0.2	0.0	0.0	0.5	0.0	0.0	6.8	6.9	7.0	
Average	0.0	0.0	0.0	0.75	0.15	0.15	0.03	0.00	0.00	0.8	0.1	0.0	0.4	0.1	0.0	1.0	0.1	0.0	7.1	7.3	7.4	

	F ⁻ (mg/L)			Al ³⁺ (mg/L)			Plate Count on nutrient agar no/100mL			MPN of Coliform no/100mL			MPN of E.Coli. no/100mL		
	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated
Jan-03							146	48	2	460	240		240	43	
Feb-03							510	125	3	1,100	43		460	23	
Mar-03							306	86	1	2,400	1,100		1,100	210	
Apr-03							296	47	6	1,100	75		210	15	
May-03							218	93	4	460	43		150	15	
Jun-03							320	189	28	4,600	1,100		2,400	240	
Jul-03					0.52		170	51	12	1,100	93		240	23	
Aug-03					0.26		184	44	2	2,400	460		1,100	93	
Sep-03					0.03		210	93	2	2,400	460		460	210	
Oct-03					0.02		225	72	4	2,400	240		1,100	21	
Nov-03					0.02	0.00	158	39	1	1,100	240		1,100	21	
Dec-03					0.01	0.01	136	43	4	2,400	1,100		210	150	
Jan-04					0.00	0.00	144	38	1	2,400	240		2,460	43	
Feb-04	0.0	0.0	0.0	0.00	0.00	0.00	137	22	1	2,400	460	0	240	75	0
Mar-04	0.0	0.0	0.0	0.00	0.00	0.00	117	42	0	1,100	240	0	240	93	0
Apr-04	0.0	0.0	0.0	0.00	0.00	0.00	188	72	3	1,100	240	0	240	43	0
May-04	0.0	0.0	0.0	0.00	0.00	0.00	205	35	2	2,400	240	0	1,100	21	0
Jun-04	0.0	0.0	0.0	0.00	0.18	0.18	205	61	1	2,400	460	0	750	240	0
Jul-04	0.0	0.0	0.0	0.00	0.04	0.04	230	71	3	4,600	460	0	1,500	240	0
Aug-04	0.0	0.0	0.0	0.00	0.12	0.12	350	118	0	4,600	1,100	0	1,100	210	0
Sep-04	0.0	0.0	0.0	0.00	0.05	0.05	118	45	2	2,400	1,100	0	1,100	240	0
Oct-04	0.0	0.0	0.0	0.00	0.04	0.04	206	63	0	2,400	1,100	0	2,400	1,100	0
Nov-04	0.0	0.0	0.0	0.00	0.01	0.01	160	120	4	2,400	460	0	460	0	0
Dec-04	0.0	0.0	0.0	0.00	0.00	0.00	124	15	4	1,100	240	0	460	21	0
Jan-05	0.0	0.0	0.0	0.00	0.00	0.00	163	29	1	2,400	240	0	43	23	0
Feb-05	0.0	0.0	0.0	0.00	0.00	0.00	176	92	0	2,400	460	0	120	23	0
Mar-05	0.0	0.0	0.0	0.00	0.00	0.00	149	48	0	1,100	460	0	93	43	0
Apr-05	0.0	0.0	0.0	0.00	0.00	0.00	82	27	3	150	23	0	93	0	0
May-05	0.0	0.0	0.0	0.00	0.00	0.00	58	17	2	460	240	0	28	21	0
Max	0.0	0.0	0.0	0.02	0.52	0.18	510	189	28	4,600	1,100	0	2,460	1,100	0
Min	0.0	0.0	0.0	0.00	0.00	0.00	58	15	0	150	23	0	28	0	0
Average	0.0	0.0	0.0	0.00	0.06	0.02	196	64	3	1,991	447	0	731	121	0




Figure M31.6.2 Monthly Water Quality of Dabose Water Treatment Plant
Analyzed by PWD's Laboratory from January 2003 to May 2005 (1/2)




Figure M31.6.2 Monthly Water Quality of Dabose Water Treatment Plant
Analyzed by PWD's Laboratory from January 2003 to May 2005 (2/2)

Table M31.6.4 List of Reservoirs for the Dabose Water Supply Scheme

Series No.	Inlet Pipe		Name of GLR / OHR (Name of Location)	GLR/OHR			Remarks		
	Dia. (mm)	Material		Type	Capacity (m ³)	Elevation (m)			
						RL		HWL	LWL
1	350	CIP	Dabose WTP	GLR	400	40.00	44.00	40.00	
2			Dabose MBR	GLR	800	120.00	124.00	120.00	
3	100	ACP	Kudshe	GLR	300	60.00	64.00	60.00	
4	150	DIP		GLR	300	120.00	124.00	120.00	
5	100	ACP	Nagargao	GLR	150	60.00	64.00	60.00	
6	100	DIP		GLR	150	130.00	134.00	130.00	
7	100	PVC	Dabe	GLR	300	60.00	64.00	60.00	
8	100	DIP			150	120.00	124.00	120.00	
9	100	DIP	Zarme	GLR	50	85.00	89.00	85.00	
10	100	DIP		GLR	50	160.00	164.00	160.00	
11	150	ACP	Pali	GLR	300	60.00	64.00	60.00	
12	150	DIP		GLR	300	160.00	164.00	160.00	
13	150	ACP	Hivre	GLR	150	60.00	64.00	60.00	
14	100	DIP		GLR	150	105.00	109.00	105.00	
15	350	CIP	Vapoi Town	GLR	800	90.00	94.00	90.00	
16	100	ACP	Cottorem	GLR	300	60.00	64.00	60.00	
17	150	DIP		GLR	300	130.00	134.00	130.00	
18	150	ACP	Padeli	GLR	300	60.00	64.00	60.00	
19	100	DIP		GLR	300	115.00	119.00	115.00	
20	200	ACP	Bhuipal	GLR	300	70.00	74.00	70.00	
21	200	DIP		GLR	800	135.00	139.00	135.00	
22	100	ACP	Morley Colony	GLR	150	60.00	64.00	60.00	
23	100	ACP		OHR	100				
24	100	ACP	Davem	GLR	150	65.00	69.00	65.00	
25	150	DIP		GLR	150	220.00	224.00	220.00	
26	-	-	Kalambolim BK	GLR	150	55.00	59.00	55.00	
	Total				7,350				
					27.1 hrs				

Note: RL=Reduced Level (Elevation of Basement of Reservoir), HWL=High Water Level in Reservoir, LWL=Low Water Level in Reservoir, GLR=Ground Level Reservoir, OHR=Over Head Reservoir, MBR=Master Balancing Reservoir

M31.7 Canacona Water Supply Scheme

The Canacona facility consists of a 5 MLD plant commissioned in 1983. Raw water is sourced from the Tapona River as well as the Chapoli Dam which came into operation in 1997. The river intake has a jack well with 3 pumps (this was locked at the time of visit and therefore we could not assess the condition). The Dam intake pump house was equipped with 3 number 100HP pumps and a small submersible pump (not adequately guarded). The rising main to the plant is approximately 8.5km long.

Table M31.7.1 lists the summary of asset data for the WTP and Table M31.7.2 contains detailed asset data for the WTP. The plant schematic is shown on Figure M31.7.1.

The raw water pump house and treatment plant are situated in separate compounds. Both compounds were adequately gated, fenced and secured by 24 hour on-site security personnel. The plant is manually operated. The plants operate 24 hours a day, using a three shift system.

Measurement of water supplied to and leaving the plant does not occur.

The pump house for the dam raw water intake has three pumps (one duty). Each pump has a capacity of 100HP. A small submersible pump is used to augment supplies rather than operating a second large pump. Site maintenance is good, except that the drive couplings/shafts are not guarded.

Apart from regular oiling and greasing, maintenance tends to be reactive. No operation and maintenance manuals are available and training for new staff is only provided on the job by existing experienced staff. There are no written or formal safety systems for plant operation.

The treatment plant is manually operated. Most equipment appears to be in good working order with the exception of the flash mixer and the clarifier. These two items were not working at the time of the visit. Generally, site maintenance is good. A record of run hours, loads, etc is maintained. Maintenance records are not logged.

The plant has a small on-site laboratory and a log is kept of the usual treatment parameters as well as chemical usage.

Disinfection is achieved using gas chlorination. Bleaching powder is added manually as a

back-up. The chlorination facilities are not fully contained. Chlorination is achieved using one tonne cylinders. There are usually two cylinders in the chlorination facilities at any one time. There is one vacuum type chlorinator (no standby). Chlorinator maintenance is performed in-house, however the chlorinators are not periodically calibrated and maintenance records are not kept. Spare parts for the chlorination facilities are not kept on-site. Chlorination maintenance, installation methods and operation practices are poor. The only facility to detect or contain gas leaks is an immersion tank. The immersion tank was empty at the time of the site visit. Flexible rubber hose (not copper tubing) is used to connect the cylinders to the chlorinator. This is not a safe practice. A poor quality flexible plastic hose was used as the feeder pipe to the contact tanks. The hose was unprotected. This is not a safe practice and should be rectified immediately. Gas masks are provided (canister type). However, in general, there was a poor understanding and awareness of the safety issues associated with the chlorination process.

Table M31.7.3 and Figure M31.7.2 show the data on monthly water quality at Canacona Water Treatment Plant. Table M31.7.4 shows a list of existing reservoirs for Canacona Water Supply Scheme.

Table M31.7.1 Summary of Asset Register of Canacona Water Treatment Plant

Name of Facility		Contents of Facility	Remarks
Raw Water Intake & Raw Water Transmission Facility	Jack Well & Raw water Sump	Jack Well: $\text{D}12.0\text{ m} \times \text{H}3.5\text{ m} \times 1\text{ unit}$ Raw Water Sump: Volume= 400 m^3	Talapona River Chapoli Dam
	Pump & Motor	Jack Well - Vertical Pump: $^{\text{Q}}180\text{ m}^3/\text{hr} \times \text{H}87.0\text{ m} \times 75\text{ kw} \times 3\text{ units}$ (2 – Under Installation), Raw Water Sump; Horizontal Centrifugal Pump: $^{\text{Q}}190\text{ m}^3/\text{hr} \times \text{H}82.0\text{ m} \times 45\text{ kw} \times 3\text{ units}$ (2 – Standby) Submersible Pump: $^{\text{Q}}60\text{ m}^3/\text{hr} \times 1\text{ unit}$	Design Cap. of Intake Pump = 8.8MLD
		Rising Main	D350mm \times 2,700m \times CIP \times 1 Line : Talapona D400mm \times 5,870m \times CIP \times 1 Line : Chapoli
	Treatment Facility	Aerator	Cascade Type: 1 unit
Parshal Flume		1 unit (for Chemical Dosing)	
Clariflocculator		Circular Horizontal Flow Type with Center Feed/Peripheral Collection Flocculation & Clarifier: $\text{D}14.0\text{ m}$ (Flocc. Zone 7.0m) \times $\text{W}^{\text{D}}3.5\text{ m} \times 2\text{ unit}$ Detention Period: Flocculation – 38.8min Clarifier – 1.9 hrs ¹⁾ Surface Loading for Clarifier: $43.3\text{ m}^3/\text{m}^2/\text{d}$ ($30.1\text{ mm}/\text{min}$) ²⁾	1): 2~2.5 hrs 2): $30\sim 40\text{ m}^3/\text{m}^2/\text{d}$
Filter		Gravity Rapid Sand Filter Type $\text{W}^{\text{L}}4.80\text{ m} \times \text{L}4.80\text{ m} \times 2\text{ cells}/\text{basin} \times 2\text{ basins}$ Effective Size of Sand: $0.??\text{ mm}$, Depth of Sand: $0.??\text{ m}$ Filter Area: $11.5\text{ m}^2/\text{cell}$, $23.0\text{ m}^2/\text{basin}$ Filtration Rate: $4.5\text{ m}/\text{hr}$ ³⁾ ($108\text{ m}/\text{d}$) Air Scouring Rate: $51\text{ m}/\text{hr}/\text{cell}$ ⁴⁾ ($0.??\text{ m}^3/\text{min}/\text{m}^2/\text{cell}$) Backwash Rate: $25.8\text{ m}/\text{hr}/\text{cell}$ ⁵⁾ ($0.43\text{ m}^3/\text{min}/\text{m}^2/\text{cell}$)- Using 50 m^3 Backwash Tank	Based on Specifications of Air Blower & Backwash Pump 3): $4.8\sim 6.0\text{ m}/\text{hr}$ 4): $36\sim 54\text{ m}/\text{hr}$ 5): $24\sim 36\text{ m}/\text{hr}$
Clear Water Transmission Facility	Clear Water Reservoir (MBR)	GLR-Volume= $800\text{ m}^3 \times 2\text{ units}$, OGR- Volume= $300\text{ m}^3 \times 1\text{ unit}$ Retention Time: 7.7 hr	
	Lifting Pump to OHR	Horizontal Centrifugal Pump: $^{\text{Q}}169.2\text{ m}^3/\text{hr} \times \text{H}30.0\text{ m} \times 22\text{ kw} \times 2\text{ units}$ (1 – Standby)	
Chemical Feeding Facility	Alum Feeding Facility	Dry Aluminum Sulfate Solution Tank: 1 unit	
	Lime Feeding Facility	Powder Lime Solution Tank: 1 unit	
	Disinfection Facility	Liquid Chlorine (1 tone Container – net 900kg) Chlorinator: 1 unit	
Laboratory	Frequency of Sampling & Analysis	In-Service, Jar Test: Not in Service Every Hour: pH, Turbidity, R-Cl Fortnightly: 20 Parameters	
Note: 1) ~ 4) are referring to “Manual on Water Supply and Treatment, Third Edition – Revised and Updated, May 1999”			




Figure M31.7.1 Schematic Sequence of Canacona Water Treatment Plant

Table M31.7.2 Present Conditions of Canacona Water Treatment Plant (1/4)

Item		Contents		Remarks	
Background					
Covered Area for Water Supply	Taluka	Canacona			
Number of W.T.P.	Number	(1)			
Capacity of Plant	MLD	5			
	m ³ /d	5,000			
Raw Water Resources	River	Talapona			
	Dam	Chapoli			
Year of Construction	Year	1980 - 81			
Year of Commission	Year	1983			
Expected Augmentation Plan		10 MLD			
		Under Tendering			
		3 MLD Pressurized Filter (from Opa)			
Name of Facility		Contents of Facility		Remarks	
Capacity of Raw Water Intake & Water Treatment Plant	MLD	5.00			
	m ³ /d	5,000			
Head Water Works : Raw Water Intake					
Name of Raw Water		Talapona	Chapoli	C=110 : Hazen-Williams Formula	
Intake Well	Diameter	m	10.0		
	Height	m	7.0		
	Water Depth	m			
	Volume	m ³ /unit	0.0		
	Water Level of River				
	H.W.L.	m			
	L.W.L.	m			
Connecting Pipe	Diameter	mm			
	Length	m			
	Material				
	Velocity	m/sec	#DIV/0!		
Loss of Head	m	#DIV/0!			
Jack Well & Pump House/Raw Water Sump			Jack Well Pump House	Raw Water Sump	
	Diameter	m	12.0		
	Height	m	3.5		
	Water Depth	m			
	Volume	m ³ /unit	0	400	
Detention Time	min	0.00			
Control Room	Width	m			
	Length	m			
	Area of Floor	m ²	50.00		
Raw Water Pump			Chapoli	Talapona	
	Capacity	ℓ/sec	53	16.67	50
		m ³ /min	3.17	1.00	3.00
		m ³ /hr	190	60	180
		m ³ /d	4,560	1,440	4,320
	Number	unit	3	1	3
	Stand-by	unit	2	0	2
	Total Capacity	m ³ /d	5,000		4,000
	Head	m	82.0		87.0
	Type of Pump		Centrifugal	Submersible	Centrifugal
Maker		KBL		KBL	
Year of Manufacture		2003		1997	
Assessment of Condition		Working, Valves Need Replacement		Working	
Raw Water Motor	Motor Output	HP	60	100	
		kW	45	75	
	Number	Unit	3		3
	Maker		KBL		KBL
	Year of Manufacture		2003		1997
Assessment of Condition		Working			
Raw Water Transmission Line	Diameter	mm	350	400	
	Length	m	2,700	5,870	
	Material		CIP	CIP	
	Velocity	m/sec	0.165	0.145	
	Loss of Head	m	4.109	4.662	
	Assessment of Condition	Pipe	Working Condition		
	Valve	Working Condition			
Transformers					
Number of Transformer		(1) Talapona	(2) Chapoli	WTP's Transformer belong to Electric Dep.	
Pole Mounted / Pad Mounted		Pad	Pad		
Capacity	kVA	200	300		
Number	Unit	2	2		
Stand-by		-	-		
Commissioned		1997	1997		
Likely Design Life	Year	15	15		
Last Replacement		-	-		
Assessment of Condition		Working	Working		

Table M31.7.2 Present Conditions of Canacona Water Treatment Plant (2/4)

Name of Facility		Contents of Facility		Remarks	
Water Treatment Plant					
Aerator	Capacity	m ³ /hr	208.3		
		m ³ /d	5,000		
	Number	Unit	1		
	Diameter	m	3.0		
	Height	m	5.0		
	EL of Top Aerator	m	?		
Assessment of Condition		Working			
Parshal Elume w/ Clarifiers / Settling Tank (Coagulation Basin)	Number	Unit	1		
	Assessment of Condition		Working		
	Design Capacity	m ³ /min/unit	3.5		
		m ³ /hr/unit	208.3		
		m ³ /d/unit	5,000		
	Number	Unit	1		
	Type of Clarifier		Circular horizontal Flow Type with Center Feed/Peripheral Collection		
	Water Depth	m	3.50		
	Overall Diameter	m	14.00		
	Flocc. Zone Dia.	m	7.00		
	Frequency of Desludging		Once a Day : General Season Twice a Day : Monsoon Season		
	Volume				
	Overall	m ³ /unit	538.8		
	Flocculation Zone	m ³ /unit	134.7		
	Clarifying Zone	m ³ /unit	404.1		
	Retention Time				
	Flocculation Zone	min	38.8 OK		
	Clarifying Zone	min	116.4 Less Time		
	Overall	min	155.2		
	Surface Area	m ² /unit	115.5		
Surface Loading	mm/min	30.1 OK			
W.L. of Clarifier	m				
Assessment of Condition		Working Condition			
Flocculator & Drive Arrangement	Number	unit	1		
	Assessment of Condition		Working		
Filter	Design Capacity	m ³ /hr/unit	104.2		
		m ³ /d/unit	2,500		
	Number	Unit	2		
	Type		Rapid Sand Gravity Filter		
	Width	m	4.80	Twin of Size	
	Length	m	4.80		
	Water Depth	m	?		
	Filtered Area	m ² /unit	23.0		
	Velocity	m ³ /d/m ²	108.5 OK		
	Filter Media		Standard Size - Good Condition		
	E.S. of Sand	mm	?		
	Depth of Sand	mm	?		
	Type of Underdrain System		?		
	Year Replacement of Media		2004 (Every 2 Year)		
	W. L. of Filter	m	?		
Assessment of Condition		Working Condition			
Filter Washing Criteria & Method	Air Scouring Rate	m ³ /min/m ²			
	Air Scouring Time	min	5.0		
	Backwash Rate	m ³ /min/m ²	0.43 OK		
	Backwashing Time	min	10 ~ 15		
	Frequency of Washing		General : Once a Day Monsoon : 2 ~ 3 Times/Day		

with 50 m3 Back Wash Tank

: E.S. = Effective Size

Table M31.7.2 Present Conditions of Canacona Water Treatment Plant (3/4)

Name of Facility			Contents of Facility		Remarks	
Backwash Pump & Motor	Capacity	m ³ /min	Lifting Pump & Motor			
		m ³ /hr				
		m ³ /d				
	Number	unit	2			
	Stand-by	unit	1			
	Total Capacity	m ³ /min				
		m ³ /d				
	Head	m	21/30			
	Type of Pump			Centrifugal		
	Motor Output	HP				
kW		5.5				
Assessment of Condition			Working			
Air Blower	Capacity	m ³ /min				
		m ³ /hr				
		m ³ /d				
	Number	unit	2			
	Stand-by	unit	1			
	Total Capacity	m ³ /min				
		m ³ /d				
	Head	mm WG				
	Motor Output	HP	30.0			
		kW	20.0			
Assessment of Condition			Working			
Master Balancing Reservoir (M.B.R.) / O.H.R. : Clear Water Reservoir	Diameter	m	16.0			
	Water Depth	m	4.0			
	Number	Unit	2			
	Volume	m ³	800			
		Total	m ³	1,600		
	Detention Time	hr	7.7			
	Last Date of Cleaning			Periodical		
	Water Level	m				
	Assessment of Condition			Working Working		
	Lifting to O.H.R. Pump & Motor	Capacity	m ³ /min			
m ³ /hr			169.2			
		m ³ /d				
Number		unit	2			
Stand-by		unit	1			
Total Capacity		m ³ /min				
		m ³ /d				
Head		m	30.0			
Type of Pump				Centrifugal		
Motor Output		HP	30.0			
	kW	22.0				
Assessment of Condition			Working			
Chemical Facility						
Alum Feeding Facility	Capacity	kg/hr				
		m ³ /unit				
	Diameter	m				
	Width	m				
	Length	m				
	Height	m				
	Volume	m ³				
	Number	Unit	1			
	Stand-by	Unit				
	Assessment of Condition			Working		

Table M31.7.2 Present Conditions of Canacona Water Treatment Plant (4/4)

Name of Facility		Contents of Facility		Remarks
Lime Feeding Facility	Capacity	kg/hr		
		m ³ /unit		
	Diameter	m		
	Width	m		
	Length	m		
	Height	m		
	Volume	m ³		
	Number	Unit	1	
	Stand-by			
	Assessment of Condition	Working		
Disinfection System	Chemical Used	Liquid Chlorine		
	Type of Plant & Machinery	Chlorinator		
	Capacity	kg/hr	2.0	
	Number	Unit	1	
		Stand-by		
	Safety Measures Taken	Emersion Tank		
	Commissioned	1983		
	Assessment of Condition	Working		
Laboratory				
Chemical Testing Laboratory		In-service (Exists)		
Jar Testing		Nil		
Availability of Skilled Chemists		Lab. Technician & Chemical Operators		
Availability of Required Chemicals		Required Alum, Lime & Liquid Chlorine		
Use of Test Reports		As per Format		
Frequency of Sampling & Analysis		Hourly (pH, Turb., R-Cl) 20 Parameter Tests Monthly		
General Quality of Water		Good		
	Raw Water Quality	Turbid., Low pH		
	Clear Water Quality	Good		
Equipment Status				
Flow Meters		Not Provided		
Other Operating Valves		Working		
Other Important Assets				
Valve's Condition		Working		
Visible Leakage and Locations		Nil		
Building Condition				
Wastewater Disposal Arrangements		Nalla		
Organization & Staff Deployed				
Shift in Plant Operation	Shifting System	3 Shifting System Covering 24 Hours		
	Working Hour :	①: 07:00 → 15:00 , ②: 15:00 → 18:00 , ③: 18:00 → 08:00		
	Grouping Staff Deployed :	① : Morning Shift-	2 Persons	
		② : General Shift-	4 Persons	
③ : Night Shift-		3 Persons		
Staff Deployed at the Plant		Person	Qualification	Year of Service
Management Staff - Engineers				Service at plant
	Assistant Engineer	1	D.C.E.	25
	Junior Engineer	1	D.C.E.	23
	Sub-total	2		
Skilled Staff - Operators / Quality Testing				
	Lab - Technician	1	B.Sc	10
	Chemical Operator	1	S.S.C.	10
	Assist. Plumber	2	Certificate	15
	Lacour	2	I.T.I.	15
	Watchman	3	S.S.C.	15
	Sub-total	9		
Unskilled Staff		9 - Other Labourers, Watchman, Security Guards		
Total Number		20		

**Table M31.7.3 Monthly Water Quality of Canacona Water Treatment Plant
Analysed by PWD's Laboratory from January 2003 to May 2005 (1/2)**

	Color			Odor			Taste			Turbidity (NTU)			pH			Specific Conductivity (/u mhos/cm)			Total Solids (mg/L)		
	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated
Jan-03				Unobjectable			Unobjectable														
Feb-03				Unobjectable			Unobjectable														
Mar-03				Unobjectable			Unobjectable														
Apr-03				Unobjectable			Unobjectable														
May-03				Unobjectable			Unobjectable														
Jun-03				Unobjectable			Unobjectable														
Jul-03				Unobjectable			Unobjectable														
Aug-03				Unobjectable			Unobjectable														
Sep-03				Unobjectable			Unobjectable														
Oct-03				Unobjectable			Unobjectable														
Nov-03				Unobjectable			Unobjectable														
Dec-03	0.0	0.0	0.0	Unobjectable			Unobjectable			8.2	1.0	1.5	7.2	6.9	7.1	62.6	63.0	64.5	43.0	40.0	41.0
Jan-04	0.0	0.0	0.0	Unobjectable			Unobjectable			2.8	0.7	0.5	6.8	7.0	7.1	64.9	66.4	57.1	42.5	42.0	43.0
Feb-04	0.0	0.0	0.0	Unobjectable			Unobjectable			2.8	0.7	0.5	7.7	7.3	7.2	64.9	70.2	70.0	41.3	45.0	45.0
Mar-04	0.0	0.0	0.0	Unobjectable			Unobjectable			1.6	0.4	0.4	6.9	7.0	7.1	72.5	72.4	76.5	46.0	46.0	48.0
Apr-04				Unobjectable			Unobjectable														
May-04	0.0	0.0	0.0	Unobjectable			Unobjectable			3.2	1.7	1.5	7.1	6.9	6.6	71.6	72.3	73.3	47.0	47.0	48.0
Jun-04	0.0	0.0	0.0	Unobjectable			Unobjectable			30.2	4.9	2.5	6.7	6.4	6.5	75.1	100.9	88.2	58.0	66.0	56.5
Jul-04	0.0	0.0	0.0	Unobjectable			Unobjectable			12.0	1.5	1.6	7.0	6.8	7.0	67.5	81.7	69.6	46.0	52.0	44.5
Aug-04	0.0	0.0	0.0	Unobjectable			Unobjectable			9.0	2.1	2.0	7.0	7.0	7.0	68.8	69.1	70.5	46.5	44.0	45.0
Sep-04	0.0	0.0	0.0	Unobjectable			Unobjectable			9.5	2.5	2.5	7.0	7.0	6.9	68.8	69.7	70.4	47.0	44.5	45.0
Oct-04	0.0	0.0	0.0	Unobjectable			Unobjectable			5.5	2.0	2.5	6.9	6.9	7.1	67.2	68.8	69.3	45.0	44.0	45.0
Nov-04	0.0	0.0	0.0	Unobjectable			Unobjectable			4.8	2.3	2.2	6.0	6.0	7.1	69.4	70.7	72.3	45.5	44.5	45.0
Dec-04	0.0	0.0	0.0	Unobjectable			Unobjectable			8.1	2.5	1.7	7.3	7.3	7.3	69.2	69.6	69.4	46.5	46.5	44.5
Jan-05	0.0	0.0	0.0	Unobjectable			Unobjectable			3.0	2.0	1.7	7.3	7.1	7.1	62.8	63.0	66.0	41.0	40.0	42.0
Feb-05	0.0	0.0	0.0	Unobjectable			Unobjectable			3.0	1.5	1.0	6.8	7.0	7.1	64.8	65.1	65.2	42.0	41.5	41.5
Mar-05	0.0	0.0	0.0	Unobjectable			Unobjectable			2.8	1.4	1.3	6.8	7.0	7.0	68.5	68.9	70.5	44.5	44.0	45.0
Apr-05	0.0	0.0	0.0	Unobjectable			Unobjectable			9.0	2.0	1.8	7.2	6.8	6.8	75.9	78.9	79.1	51.5	50.0	50.0
May-05	0.0	0.0	0.0	Unobjectable			Unobjectable			4.4	2.0	2.1	7.3	7.2	7.2	76.9	78.0	78.5	50.5	50.5	50.0
Max	0.0	0.0	0.0							30.2	4.9	2.5	7.7	7.3	7.3	76.9	100.9	88.2	58.0	66.0	56.5
Min	0.0	0.0	0.0	Unobjectable			Unobjectable			1.6	0.4	0.4	6.0	6.0	6.5	62.6	63.0	57.1	41.0	40.0	41.0
Average	0.0	0.0	0.0							7.1	1.8	1.6	7.0	6.9	7.0	68.9	72.3	71.2	46.1	46.3	45.8

	Total Dissolved Solids(TDS)			Suspended Solids			Total Hardness as CaCO ₃ (TA)			Ca ²⁺			Mg ²⁺			Cl ⁻			Total Alkalinity as CaCO ₃			
	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	
Jan-03																						
Feb-03																						
Mar-03																						
Apr-03																						
May-03																						
Jun-03																						
Jul-03																						
Aug-03																						
Sep-03																						
Oct-03																						
Nov-03																						
Dec-03	40.0	40.0	41.0	3.0	0.0	0.0	20.0	20.0	20.0	4.8	4.8	4.8	2.00	2.00	2.00	6.0	6.0	7.0	26.0	21.0	22.0	
Jan-04	41.5	42.0	43.0	1.0	0.0	0.0	23.0	24.0	24.0	4.3	5.2	5.2	2.75	2.75	2.75	6.0	6.0	6.0	25.0	26.0	26.0	
Feb-04	40.5	45.0	45.0	1.0	0.0	0.0	22.0	22.0	22.0	4.4	4.8	4.8	2.50	2.50	2.50	6.0	8.0	8.0	30.0	29.0	29.0	
Mar-04	46.0	46.0	48.0	0.0	0.0	0.0	23.0	23.0	23.0	5.2	5.2	5.2	2.50	2.50	2.50	6.0	6.0	6.0	27.0	28.0	28.0	
Apr-04																						
May-04	46.0	47.0	48.0	1.0	0.0	0.0	24.0	24.0	24.0	5.2	5.2	5.2	2.75	2.75	2.75	7.0	7.0	9.0	28.0	28.0	28.0	
Jun-04	48.0	65.0	56.5	10.0	1.0	0.0	28.0	38.0	31.0	6.4	9.2	7.2	3.00	3.75	3.25	7.0	8.0	12.0	30.0	42.0	35.0	
Jul-04	43.0	52.0	44.5	3.0	0.0	0.0	21.0	24.0	22.0	4.8	5.6	5.2	2.25	2.50	2.25	7.0	7.0	7.0	22.0	23.0	24.0	
Aug-04	44.0	44.0	45.0	2.5	0.0	0.0	23.0	23.0	23.0	5.2	5.2	5.2	2.50	2.50	2.50	6.0	6.0	10.0	25.0	25.0	25.0	
Sep-04	44.0	44.5	45.0	3.0	0.0	0.0	23.0	24.0	24.0	6.0	6.4	6.4	2.00	2.00	2.00	7.0	7.0	8.0	24.0	25.0	25.0	
Oct-04	43.0	44.0	45.0	2.0	0.0	0.0	22.0	24.0	24.0	5.6	6.0	6.0	2.00	2.25	2.25	6.0	6.0	9.0	25.0	26.0	26.0	
Nov-04	44.0	44.5	45.0	1.5	0.0	0.0	22.0	22.0	22.0	4.8	4.8	4.8	2.50	2.50	2.50	7.0	7.0	8.0	26.0	26.0	26.0	
Dec-04	44.0	44.5	45.0	2.5	0.0	0.0	23.0	23.0	23.0	4.8	4.8	4.8	2.75	2.75	2.75	7.0	7.0	7.0	26.0	26.0	24.0	
Jan-05	40.0	40.0	42.0	1.0	0.0	0.0	19.0	19.0	19.0	4.4	4.4	4.4	2.75	2.00	2.00	7.0	7.0	7.0	22.0	22.0	22.0	
Feb-05	41.0	41.5	41.5	1.0	0.0	0.0	21.0	21.0	21.0	4.8	4.8	4.8	2.75	2.25	2.25	8.0	8.0	8.0	0.0	0.0	0.0	
Mar-05	44.0	44.0	44.0	0.5	0.0	0.0	22.0	22.0	22.0	5.6	5.6	5.6	2.75	2.00	2.00	7.0	7.0	9.0	23.0	24.0	24.0	
Apr-05	48.5	50.0	50.0	3.0	0.0	0.0	20.0	22.0	22.0	4.8	5.6	5.6	2.75	2.00	2.00	9.0	10.0	10.0	27.0	24.0	24.0	
May-05	49.0	50.0	50.0	1.5	0.0	0.0	27.0	27.0	27.0	5.6	5.6	5.6	2.75	3.25	3.25	8.0	8.0	8.0	25.0	26.0	24.0	
Max	49.0	65.0	56.5	10.0	1.0	0.0	28.0	38.0	31.0	6.4	9.2	7.2	3.00	3.75	3.25	9.0	10.0	12.0	30.0	42.0	35.0	
Min	40.0	40.0	41.0	0.0	0.0	0.0	19.0	19.0	19.0	4.3	4.4	4.4	2.00	2.00	2.00	6.0	6.0	6.0	0.0	0.0	0.0	
Average	43.9	46.1	45.8	2.2	0.1	0.0	22.5	23.6	23.1	5.1	5.5	5.3	2.54	2.49	2.44	6.9	7.1	8.2	24.2	24.8	24.2	

**Table M31.7.3 Monthly Water Quality of Canacona Water Treatment Plant
Analysed by PWD's Laboratory from January 2003 to May 2005 (2/2)**

	SO ₄ ⁻			Fe ²⁺			Mn ²⁺			NO ₃ ²⁻			KMnO ₄ oxidizability as O ₂			BOD at 27°C and 3days			DO			
	(mg/L)			(mg/L)			(mg/L)			(mg/L)			(mg/L)			(mg/L)						
	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	
Jan-03																						
Feb-03																						
Mar-03																						
Apr-03																						
May-03																						
Jun-03																						
Jul-03																						
Aug-03																						
Sep-03																						
Oct-03																						
Nov-03																						
Dec-03	0.0	0.0	0.0	2.00	0.40	0.40	0.00	0.00	0.00	1.7	0.6	0.0	1.2	0.2	0.0	1.6	0.5	0.0	7.0	6.8	7.2	
Jan-04	0.0	0.0	0.0	0.45	0.10	0.10	0.00	0.00	0.00	0.8	0.0	0.0	0.3	0.0	0.0	0.5	0.0	0.0	7.3	7.5	7.5	
Feb-04	0.0	0.0	0.0	0.20	0.06	0.06	0.00	0.00	0.00	0.8	0.0	0.0	0.2	0.0	0.0	0.6	0.0	0.0	7.4	7.5	7.5	
Mar-04	0.0	0.0	0.0	0.12	0.05	0.05	0.00	0.00	0.00	0.6	0.0	0.0	0.2	0.0	0.0	0.5	0.0	0.0	6.8	7.8	7.4	
Apr-04																						
May-04	0.0	0.0	0.0	0.40	0.08	0.08	0.00	0.00	0.00	0.6	0.0	0.0	0.3	0.0	0.0	0.8	0.0	0.0	6.9	7.1	7.3	
Jun-04	0.0	0.0	0.0	3.00	0.15	0.10	0.35	0.00	0.00	1.6	0.0	0.0	1.0	0.0	0.0	2.2	0.0	0.0	6.5	7.0	7.3	
Jul-04	0.0	0.0	0.0	0.65	0.10	0.10	0.00	0.00	0.00	1.0	0.0	0.0	0.5	0.0	0.0	1.2	0.0	0.0	7.0	7.1	7.1	
Aug-04	0.0	0.0	0.0	0.50	0.15	0.15	0.00	0.00	0.00	0.9	0.0	0.0	0.4	0.0	0.0	1.0	0.0	0.0	7.2	7.4	7.4	
Sep-04	0.0	0.0	0.0	1.00	0.20	0.20	0.00	0.00	0.00	0.5	0.0	0.0	0.6	0.0	0.0	1.2	0.0	0.0	7.4	7.5	7.5	
Oct-04	0.0	0.0	0.0	0.40	0.10	0.10	0.00	0.00	0.00	0.4	0.0	0.0	0.4	0.0	0.0	0.8	0.0	0.0	7.3	7.4	7.4	
Nov-04	0.0	0.0	0.0	0.40	0.20	0.20	0.00	0.00	0.00	0.4	0.0	0.0	0.4	0.0	0.0	1.2	0.0	0.0	7.1	7.2	7.3	
Dec-04	0.0	0.0	0.0	0.65	0.15	0.12	0.00	0.00	0.00	0.5	0.0	0.0	0.4	0.2	0.0	0.8	0.0	0.0	7.2	7.2	7.3	
Jan-05	0.0	0.0	0.0	0.35	0.15	0.15	0.00	0.00	0.00	0.4	0.0	0.0	0.4	0.0	0.0	0.8	0.0	0.0	7.2	7.3	7.3	
Feb-05	0.0	0.0	0.0	0.35	0.06	0.06	0.00	0.00	0.00	0.7	0.0	0.0	0.4	0.0	0.0	0.9	0.0	0.0	7.2	7.4	7.4	
Mar-05	0.0	0.0	0.0	0.40	0.10	0.10	0.00	0.00	0.00	0.6	0.0	0.0	0.4	0.0	0.0	0.8	0.0	0.0	7.4	7.5	7.5	
Apr-05	0.0	0.0	0.0	0.60	0.06	0.06	0.00	0.00	0.00	0.9	0.0	0.0	0.6	0.0	0.0	1.4	0.0	0.0	7.4	7.6	7.6	
May-05	0.0	0.0	0.0	0.30	0.10	0.10	0.00	0.00	0.00	0.6	0.0	0.0	0.4	0.0	0.0	0.8	0.0	0.0	6.9	7.2	7.3	
Max	0.0	0.0	0.0	3.00	0.40	0.40	0.35	0.00	0.00	1.7	0.6	0.0	1.2	0.2	0.0	2.2	0.5	0.0	7.4	7.8	7.6	
Min	0.0	0.0	0.0	0.12	0.05	0.05	0.00	0.00	0.00	0.4	0.0	0.0	0.2	0.0	0.0	0.5	0.0	0.0	6.5	6.8	7.1	
Average	0.0	0.0	0.0	0.69	0.13	0.13	0.02	0.00	0.00	0.8	0.0	0.0	0.5	0.0	0.0	1.0	0.0	0.0	7.1	7.3	7.4	

	F ⁻			Al ³⁺			Plate Count on nutrient agar			MPN of Coliform			MPN of E.Coli.		
	(mg/L)			(mg/L)			no/100mL			no/100mL			no/100mL		
	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated	Raw	Filtered	Treated
Jan-03															
Feb-03															
Mar-03															
Apr-03															
May-03															
Jun-03															
Jul-03															
Aug-03															
Sep-03															
Oct-03															
Nov-03															
Dec-03	0.0	0.0	0.0				288	83	0	240	43	0	93	23	0
Jan-04	0.0	0.0	0.0		0.00	0.00									
Feb-04	0.0	0.0	0.0				192	140	4	460	240	0	240	93	0
Mar-04	0.0	0.0	0.0		0.00	0.00	213	108	3	2,460	460	0	460	150	0
Apr-04															
May-04	0.0	0.0	0.0		0.00	0.00	220	118	4	2,400	1,100	0	460	460	0
Jun-04	0.0	0.0	0.0	0.00	0.00	0.00	198	120	5	2,400	1,100	0	1,100	210	0
Jul-04	0.0	0.0	0.0		0.00	0.00	98	61	5	2,400	240	0	930	93	0
Aug-04	0.0	0.0	0.0	0.00	0.01	0.01	138	45	2	460	240	0	240	93	0
Sep-04	0.0	0.0	0.0	0.00	0.01	0.01	274	170	1	2,400	1,100	0	460	460	0
Oct-04	0.0	0.0	0.0	0.00	0.01	0.01	128	45	3	1,100	240	0	460	240	0
Nov-04	0.0	0.0	0.0	0.00	0.01	0.01	84	65	2	1,100	460	0	64	11	0
Dec-04	0.0	0.0	0.0	0.01	0.01	0.01	68	52	4	2,400	1,100	0	460	150	0
Jan-05	0.0	0.0	0.0	0.00	0.01	0.01	160	24	1	2,400	240	0	240	23	0
Feb-05	0.0	0.0	0.0	0.00	0.00	0.00	226	31	4	2,400	43	0	1,100	23	0
Mar-05	0.0	0.0	0.0	0.00	0.00	0.00	42	32	4	150	93	0	43	23	0
Apr-05	0.0	0.0	0.0	0.00	0.00	0.00	38	7	1	43	0	0	23	0	0
May-05	0.0	0.0	0.0	0.00	0.00	0.00	112	63	6	1,100	460	0	93	210	0
Max	0.0	0.0	0.0	0.00	0.01	0.01	288	170	6	2,460	1,100	0	1,100	460	0
Min	0.0	0.0	0.0	0.00	0.00	0.00	38	7	0	43	0	0	23	0	0
Average	0.0	0.0	0.0	0.00	0.00	0.00	155	73	3	1,495	447	0	404	141	0




Figure M31.7.2 Monthly Water Quality of Canacona Water Treatment Plant
Analysed by PWD's Laboratory from January 2003 to May 2005 (1/2)




Figure M31.7.2 Monthly Water Quality of Canacona Water Treatment Plant
Analysed by PWD's Laboratory from January 2003 to May 2005 (2/2)

Table M31.7.4

List of Reservoirs for the Canacona Water Supply Scheme

Series No.	System	Inlet Pipe		Name of GLR/OHR/Sump (Name of Location)	Type	Capacity (m3)	GLR/OHR/Sump Elevation (m)			Supply Area (Village Name)	Remarks	
		Dia. (mm)	Material				RL	HWL	LWL			
1	Canacona			Canacona WTP	GLR	800	67.00	63.00	Canacona(4), Canacona(M CD)(9)	w/ Pumping Station		
2					GLR	800	67.00	63.00				
3					OHR	300	85.00	81.00				
				Sub-Total		1,900						
4	Canacona1			Godkamol (2000)	GLR	50		30.00	Poinguinim(6)	Old		
5				Sadolxem	GLR	50		30.00				
6				Sadolxem (2000)	GLR	100		32.00				
7				Talpona	GLR	100		15.00				
8				Gajibaga	GLR	100		25.00				
9				Mahalwada	GLR	50		30.00				
10				Maxem	GLR	400		22.00				
				Sub-Total		850						
11		Canacona2	150	ACP	Hattipal	Sump	10	16.00				w/Pump Station (SHP)
12			150	ACP		GLR	50				100.00	
				Sub-Total		60						
13	Canacona5	350	DIP	Agonda MBR (2001)	GLR	500		59.00	from OHR(Series No.3) of WTP			
14		200	PVC	Agonda (2000)	GLR	400		44.00				
				Sub-Total		900						
15	Canacona7	80	ACP	Shristhal	GLR	50		90.00	w/Pump Station (SHP), GL=54.0			
				Sub-Total		50						
	Total					3,760						
						18.0	hrs					

Note : RL=Reduced Level (Base Elevation of GLR), HWL=High Water Level in Reservoir, LWL=Low Water Level in Reservoir, GLR=Ground Level Reservoir, OHR=Over Head Reservoir, MBR=Master Balancing Reservoir, Sump=Pump Suction Well

M31.8 Rural Water Supply Scheme

During the Reconnaissance Survey as part of Phase I of this study, the water supply scheme in Canacona taluka was selected and assessed as a representative small scale water supply scheme. The Canacona scheme was selected based on recommendations from PWD staff. There are approximately 40 rural water supply schemes operating in the Canacona taluka and the networks for these schemes are completely independent from each other as well as from the regional scheme. The rural supply scheme at Matve, which supplies water to Parekatta, was visited.

The Matve scheme consists of a pump house (manned 24 hours a day) with a small (five HP) submersible pump suspended in a bore well, which is approximately 160m deep. The scheme was commissioned in 1991. Bore wells in Goa are constructed by the Central Ground Water Board on behalf of the PHE. The pump feeds a 25m³ OHR which feeds water to the village under gravity flow. A chlorine solution (5%) is added to the OHR (from 25 litre plastic containers) to maintain residual levels. The study team could not determine whether residual chlorine levels are regularly tested. There is no standby pump which means villagers can go without water for days at a time if the pump breaks down.

The study team understood that the scheme supplies a population of approximately 1000 people. Water is supplied for approximately two to three hours each day. The supply valves are controlled by PHE staff. There are approximately 25 private connections and 25 public stand posts. There is no charge for water consumed from stand posts in rural or urban areas and consumption is not measured.

Table M31.8.1 lists the small scale (rural) water supply schemes in each taluka, which data are mentioned in “Sector Status Study – WSS Goa, 2004”. Table M31.8.2 also shows the rural water supply schemes, which are based on the information from PWD during the study period.

Table M31.8.1 List of Rural Water Supply Scheme (1/2)

Sr.No.	ID No.	Taluka	Town/Village	Type	Population	Household	H. Size	W. Scheme
1	101001	Pernem	Tiracol	Rural	221	46	4.8	Groundwater
87	103015	Tiswadi	Talaulim	Rural	667	139	4.8	Groundwater
88	103016	Tiswadi	Goalim Moula	Rural	385	74	5.2	Groundwater
92	103020	Tiswadi	Gancim	Rural	571	112	5.1	Groundwater
94	103022	Tiswadi	Curca	Rural	2,078	424	4.9	Groundwater
110	104001	Bicholim	Mencurem	Rural	1,386	252	5.5	Groundwater
111	104002	Bicholim	Dumacem	Rural	325	55	5.9	Groundwater
112	104003	Bicholim	Salem	Rural	2,770	577	4.8	Groundwater
113	104004	Bicholim	Latambarcem	Rural	6,268	1,229	5.1	Groundwater
119	104010	Bicholim	Curchirem	Rural	1,914	368	5.2	Groundwater
129	104020	Bicholim	Cotombi	Rural	985	197	5.0	Groundwater
136	105001	Satari	Podocem	Rural	994	216	4.6	Groundwater
138	105003	Satari	Ravona	Rural	1,204	223	5.4	Groundwater
139	105004	Satari	Gonteli	Rural	1,424	303	4.7	Groundwater
140	105005	Satari	Siroli	Rural	634	122	5.2	Groundwater
141	105006	Satari	Ponsuli	Rural	4	1	4.0	Groundwater
145	105010	Satari	Golauli	Rural	288	60	4.8	Groundwater
146	105011	Satari	Surla	Rural	423	92	4.6	Groundwater
147	105012	Satari	Satrem	Rural	140	26	5.4	Groundwater
148	105013	Satari	Derodem	Rural	112	22	5.1	Groundwater
149	105014	Satari	Codal	Rural	140	31	4.5	Groundwater
150	105015	Satari	Rivem	Rural	141	30	4.7	Groundwater
153	105018	Satari	Gululem	Rural	42	10	4.2	Groundwater
154	105019	Satari	Querim	Rural	2,063	421	4.9	Groundwater
155	105020	Satari	Morlem	Rural	3,210	655	4.9	Groundwater
164	105029	Satari	Xelopo-Buzruco	Rural	237	55	4.3	Groundwater
165	105030	Satari	Sigonem	Rural	170	34	5.0	Groundwater
166	105031	Satari	Maloli	Rural	384	80	4.8	Groundwater
167	105032	Satari	Nanorem	Rural	271	59	4.6	Groundwater
168	105033	Satari	Vainguinim	Rural	25	5	5.0	Groundwater
169	105034	Satari	Ustem	Rural	332	65	5.1	Groundwater
177	105042	Satari	Cumarconda	Rural	477	90	5.3	Groundwater
180	105045	Satari	Vaguriem	Rural	277	47	5.9	Groundwater
187	105052	Satari	Codvol	Rural	6	1	6.0	Groundwater
188	105053	Satari	Caranzol	Rural	806	152	5.3	Groundwater
189	105054	Satari	Carambolim-Buzruco	Rural	473	83	5.7	Groundwater
194	105059	Satari	Ponocem	Rural	470	84	5.6	Groundwater
201	105066	Satari	Xelopo-Curdo	Rural	254	47	5.4	Groundwater
202	105067	Satari	Siranguli	Rural	77	15	5.1	Groundwater
203	105068	Satari	Sirsodem	Rural	257	45	5.7	Groundwater
204	105069	Satari	Assodem	Rural	136	23	5.9	Groundwater
205	105070	Satari	Govanem	Rural	204	40	5.1	Groundwater
207	105072	Satari	Ambeli	Rural	101	21	4.8	Groundwater
235	106025	Ponda	Conxem	Rural	202	43	4.7	Groundwater
323	203019	Quepem	Quitol	Rural	1,404	312	4.5	Groundwater
324	203020	Quepem	Naquerim	Rural	740	185	4.0	Groundwater
325	203021	Quepem	Morpila	Rural	2,631	446	5.9	Groundwater
326	203022	Quepem	Tiloi	Rural	615	123	5.0	Groundwater
327	203023	Quepem	Bendordem	Rural	621	109	5.7	Groundwater
328	203024	Quepem	Cavorem	Rural	778	162	4.8	Groundwater
329	203025	Quepem	Maina	Rural	388	68	5.7	Groundwater

Source: Sector Status Study – WSS Goa, 2004

Table M31.8.1 List of Rural Water Supply Scheme (2/2)

Sr.No.	ID No.	Taluka	Town/Village	Type	Population	Household	H. Size	W. Scheme
330	203026	Quepem	Cordem	Rural	1,747	312	5.6	Groundwater
331	203027	Quepem	Padi	Rural	471	76	6.2	Groundwater
332	203028	Quepem	Quedem	Rural	372	60	6.2	Groundwater
333	203029	Quepem	Barcem	Rural	2,179	283	7.7	Groundwater
334	203030	Quepem	Gocoldem	Rural	484	78	6.2	Groundwater
335	203031	Quepem	Quisconda	Rural	441	70	6.3	Groundwater
336	203032	Quepem	Pirla	Rural	488	106	4.6	Groundwater
337	203033	Quepem	Sulcorna	Rural	646	91	7.1	Groundwater
338	203034	Quepem	Corla	Rural	183	29	6.3	Groundwater
339	203035	Quepem	Cazur	Rural	461	96	4.8	Groundwater
340	203036	Quepem	Mangal	Rural	304	76	4.0	Groundwater
343	204001	Sanguen	Piliem	Rural	4,163	925	4.5	Groundwater
344	204002	Sanguen	Darbandora	Rural	3,137	682	4.6	Groundwater
345	204003	Sanguen	Sancordem	Rural	1,077	291	3.7	Groundwater
346	204004	Sanguen	Aglote	Rural	1,700	340	5.0	Groundwater
347	204005	Sanguen	Surla	Rural	1,050	210	5.0	Groundwater
348	204006	Sanguen	Molem	Rural	1,551	330	4.7	Groundwater
349	204007	Sanguen	Caranzol	Rural	27	17	1.6	Groundwater
350	204008	Sanguen	Colem	Rural	3,794	843	4.5	Groundwater
351	204009	Sanguen	Sigao	Rural	1,633	355	4.6	Groundwater
352	204010	Sanguen	Sangod	Rural	977	222	4.4	Groundwater
353	204011	Sanguen	Cormonem	Rural	750	163	4.6	Groundwater
354	204012	Sanguen	Codli	Rural	3,822	780	4.9	Groundwater
355	204013	Sanguen	Camarconda	Rural	804	164	4.9	Groundwater
356	204014	Sanguen	Moissal	Rural	82	7	11.7	Groundwater
357	204015	Sanguen	Bandoli	Rural	1,382	271	5.1	Groundwater
358	204016	Sanguen	Rumbrem	Rural	924	149	6.2	Groundwater
359	204017	Sanguen	Antoriem	Rural	17	3	5.7	Groundwater
360	204018	Sanguen	Santona	Rural	1,049	233	4.5	Groundwater
361	204019	Sanguen	Calem	Rural	2,605	521	5.0	Groundwater
362	204020	Sanguen	Sonauli	Rural	78	30	2.6	Groundwater
364	204022	Sanguen	Patiem	Rural	315	63	5.0	Groundwater
365	204023	Sanguen	Maulinguem	Rural	227	42	5.4	Groundwater
366	204024	Sanguen	Dudal	Rural	572	110	5.2	Groundwater
369	204027	Sanguen	Comproi	Rural	637	130	4.9	Groundwater
375	204033	Sanguen	Tudou	Rural	194	54	3.6	Groundwater
376	204034	Sanguen	Potrem	Rural	141	32	4.4	Groundwater
377	204035	Sanguen	Bati	Rural	1,963	409	4.8	Groundwater
378	204036	Sanguen	Cumbari	Rural	221	45	4.9	Groundwater
379	204037	Sanguen	Viliena	Rural	547	114	4.8	Groundwater
380	204038	Sanguen	Dongor	Rural	29	8	3.6	Groundwater
381	204039	Sanguen	Naiquinim	Rural	230	56	4.1	Groundwater
382	204040	Sanguen	Porteem	Rural	2,560	483	5.3	Groundwater
386	204044	Sanguen	Curpem	Rural	882	180	4.9	Groundwater
387	204045	Sanguen	Vichundrem	Rural	726	165	4.4	Groundwater
388	204046	Sanguen	Netorli	Rural	1,787	397	4.5	Groundwater
389	204047	Sanguen	Nundem	Rural	408	102	4.0	Groundwater
390	204048	Sanguen	Verlem	Rural	886	206	4.3	Groundwater
393	205002	Canacon	Cola	Rural	5,114	947	5.4	Groundwater
396	205005	Canacon	Gaodongrem	Rural	5,168	891	5.8	Groundwater
399	205008	Canacon	Cotigao	Rural	2,703	575	4.7	Groundwater

Source: Sector Status Study – WSS Goa, 2004

Table M31.8.2 List of Rural Water Supply Scheme (1/7)

Taluka	Name of Scheme	Source	Pump Capacity	Capacity of Tank	Population covered	Supply Amount	Remarks		
			(HP)	(m ³)		(m ³ /day)			
Quepem	Barcem								
	Gokuldem	open/bore well	5	25 GLR	471	-	chlorination		
	Barcem (Rawapan)	spring/bore well	5	50 GLR	2,079	-			
	(Valipwada)		5	25 GLR		-			
	Paddi	borewell	5	50 GLR	400	-			
	Voili-Paddi	borewell	5	25 GLR	463	-			
	Khedem-Assodem	spring/borewell	5	-	379	-			
	Subdolem	borewell	5	25 GLR	560	-			
	Quiscond	spring	-	-	440	-			
	Sirlim	spring	-	-	275	-			
	Balli								
	Bondordem	2borewells	5	25 GLR	575	-	chlorination		
	Cordem	borewell	5	50 GLR	1,723	-			
	Fatorpa								
	Quittol	borewell/Jackwell	6	25 GLR	1,393	-	chlorination		
	Ventem	borewell	5	25 GLR	260	-			
	Morppila								
	Dhabem	borewell	5	50 GLR	445	-	chlorination		
	Morppila	spring/Salaulimwat	5	50 GLR	2,066	-			
	Betul								
	Naqueri	borewell	5	-	90	-	chlorination		
	Dessaiwada	openwell	10	25 GLR	480	-			
	Betul(Bapsora)	openwell	20	50 GLR	640	-			
	Betul	spring	12.5	25 GLR	450	-			
	Khana	spring	4.5	25 GLR	612	-			
	Tembi	openwell	6	25 GLR	315	-			
	Ollir	spring	5	25 GLR	280	-			
	Cavrem-Pirla								
	Pirla	borewell	5	25 GLR	443	-	chlorination		
	Sulcorna	borewell/spring	5	25 GLR	638	-			
	Cazur	borewell	6	50 GLR	462	-			
	Mangal	openwell	5	10 GLR	313	-			
	Maina	spring	-	25 GLR	297	-			
	Cavrem	spring	-	700 GLR	777	-			
	Nanagotov	spring	-	35 GLR	50	-			
	Corla	openwell	2	2 tanks	184	-			
	Sanguem	Sancorda							
		Tamoisurla	borewell	3.5	-	4,031	30	chlorination	
		Butter	borewell	3.5	-		25		
		Panas	river	15+15=30	100		100		pressure filters and chlorination
		Satpal	river	3.5	50 GLR		30		chlorination(pressure filters proposed)
		Dongarwada	openwell	3.5	30		25		chlorination
		Mollem							
		Mollem	borewell	7.5+3=10.5	50 OHR	2,685	50	chlorination(pressure filters proposed)	
		Sangod	borewell	5	-		40		
		Barkatem	openwell	3.5	50 GLR		25		
		Casaulim	openwell	3.5	-		25		

Source: PWD Goa - as of May 2006

Table M31.8.2 List of Rural Water Supply Scheme (2/7)

Taluka	Name of Scheme	Source	Pump Capacity	Capacity of Tank	Population covered	Supply Amount	Remarks	
			(HP)	(m ³)		(m ³ /day)		
Sanguem	Collem							
		Collem	borewell	3.5	50 OHR	5,648	-	chlorination(pressure filters shall be installed shortly)
		Near bridge	river	10	-		-	chlorination(pressure filters shall be installed shortly)
		Dudhsagar	river	17.5 (Repaired pump)	50 OHR		-	chlorination(pressure filters shall be installed shortly)
		Hospital	borewell	3.5	50 OHR		-	
		Shigao	borewell	5	50 GLR		-	
	Dharbandora							
		Gurkhem	borewell	5+3=8	50 GLR	3,994	40	Around 3,200 souls is from Pilliem,Dhadem,Pratnagar,Occamb are covered under Opa water works.
		Talsai	borewell	3	-		25	
		Tisk	borewell	5	-		40	
		Davcond	borewell	5	-		40	
	Kirlapal-Dabal							
		Cormone	borewell	5	-	6,545	40	
		Dabal	borewell	5	25 GLR		25	
		Codli	borewell	5	-		40	
		Kamarkhand	borewell	5	50 GLR		40	
		Vagona	borewell	5	100 GLR		40	
		Kirlapal	borewell	5	50 GLR		40	
		Sandol	borewell	5	-		40	
		Haluliwada	borewell	7.5	50 GLR		40	pressure filter+chlorination
		Molerimoi	borewell	5	-		40	
	Sanvordem							
		Dhadem	borewell	20	300 GLR	7,407	250	
		Gandhinagar	borewell	5	-		32	
		Guddemol	borewell	5	50 GLR		32	
		Ambeudoc	borewell	5	-		32	
	Others							
		Uguem	tubewell	12.5	-	-	144	
		Valkinim II	tubewell	5	-	-	160	
		Valkinim III	openwell	3	-	-	40	
		Bhati	openwell	12.5	-	-	150	
	Portem	openwell	5	-	-	60		
	Cumbari(Cumbari, Val she, Volliana)	tubewell	5	-	-	80		
	Cumbari(Cumbari)	tubewell	5	-	-	80		
	Vaddem I	openwell	20	-	-	340		
	Vaddem II	tubewell	7.5	-	-	120		
	Natravalim	tubewell	10	-	-	120		
	Nundem	spring	-	-	-	60		
	Veriem	openwell	5	-	-	80		
	Tadou	spring	-	-	-	60		
	Mascavorem	openwell	4	-	-	24		
	Curpem I	openwell	6	-	-	60		
	Curpem II	openwell	6	-	-	60		
	Vichundrem	tubewell	5	-	-	120		
	Rivona	river	15	-	-	150		
	Keneriwada	openwell	6	-	-	60		

Source: PWD Goa - as of May 2006

Table M31.8.2 List of Rural Water Supply Scheme (3/7)

Taluka	Name of Scheme	Source	Pump Capacity	Capacity of Tank	Population covered	Supply Amount	Remarks	
			(HP)	(m ³)		(m ³ /day)		
Canacona	Loliem-Polem							
		Polem	sump	5	8 GLR	3,187	13	
		Sheli	sump	5	20 GLR		40	
		Tanshiwada	sump	7.5	20 GLR		40	
		Loliem	sump	5	50 GLR		40	
		Deptamol	borewell	5	50 OHR		30	
		Panskhande	borewell	5	8 GLR		16	
		Poinginim						
		Muthal	borewell	3	20 GLR	2,727	20	
		Sadolxem	sump	5	50 GLR		50	
		Ammona	borewell	5	20 GLR		30	
		Shishewal	sump	5	20 GLR		20	
		Aug to Deptamol	sump	5	50 GLR		40	
		Tirwal	sump	5	20 GLR		-	
		Cotiago						
		Eda	borewell	3	20 GLR	1,845	20	
		Avem	borewell	3	50 GLR		40	
		Badsorem	spring	-	20 GLR		30	
		Aveli	spring	-	-		-	
		Gaondongrem						
		Tudal	borewell	5	8 GLR	2,903	8	
		Bhuper	borewell	5	20 GLR		30	
		Baras	spring	-	10 GLR		25	
		Zitawadi	borewell	5	50 GLR		60	
		Karvem	borewell	5	20 GLR		40	
		Tallem	sump	3	10 GLR		10	
		Shristal						
		Asali	sump	5	20 GLR	3,785	20	
		Gullem	borewell	5	20 GLR		30	
		Chapoli	sump	5	20 GLR		20	
		Aug to Shristal	boosterpump	5	20 GLR		20	
		Agonda						
		Agonda Mudkud	sump	17.5	80 GLR	3,231	-	
		Pervem	sump	7.5	-		100	
		Shelpewal	sump	5	-		-	
		Aug to Agonda	sump	30	350 OHR		700	
		Cola						
		Solyem	sump	5	20	3,515	15	
		Saleri	sump	5	20		30	
		Parikatta	borewell	5	20		30	
		Molloreem	sump	5	20		30	
		Gavai	borewell	5	20		20	
		Nuven	spring	5	20		20	
		Paremol	stream	5	20		20	
		Popoidanda	stream	5	20		20	
		Cabo-De-Rama	borewellstream	5	50		-	

Source: PWD Goa - as of May 2006

Table M31.8.2 List of Rural Water Supply Scheme (4/7)

Taluka	Name of Scheme	Source	Pump Capacity	Capacity of Tank	Population covered	Supply Amount	Remarks	
			(HP)	(m ³)		(m ³ /day)		
Pernem	Tiracol							
		Near Check post	tubewell	-	-	-	Nil	
		Near Fort	tubewell	-	-	-	85 LPM	
			openwell	-	-	-	-	Scheme is in operation
	Keri							
		Talwada	tubewell	-	-	-	345 LPM	
		Gadechawada	tubewell	-	-	-	473 LPM	
		Talwada near Temple	tubewell	-	-	-	333 LPM	
		Harijan wada	tubewell	-	-	-	250 LPM	
			openwell	-	-	-	-	Scheme is in operation
	Paliem							
		Bhandarwada	tubewell	-	-	-	165 LPM	
		Tilvewada	tubewell	-	-	-	107 LPM	
			openwell	-	-	-	-	Scheme is in operation
		Kiranpani	tubewell	-	-	-	250 LPM	
	Arambol							
		Thakurwada	tubewell	-	-	-	105 LPM	
		Parsekarwada	tubewell	-	-	-	75 LPM	
			openwell	-	-	-	-	Scheme is in operation
		Madhalawada	tubewell	-	-	-	105 LPM	
			openwell	-	-	-	-	Scheme is in operation
		Near school	tubewell	-	-	-	88 LPM	
		Near church	tubewell	-	-	-	10 LPM	
		Deulwada	tubewell	-	-	-	-	
	Mandrem							
		Askawada	tubewell	-	-	-	88 LPM	
		Marathwada	tubewell	-	-	-	25 LPM	
			openwell	-	-	-	-	Scheme is in operation
		Madhalamaz	tubewell	-	-	-	88 LPM	
		Salgaonkawada	tubewell	-	-	-	15 LPM	
			openwell	-	-	-	-	Scheme is in operation
		Varchawada	tubewell	-	-	-	25 LPM	
		Mhamalwada	tubewell	-	-	-	25 LPM	
		Askawada	tubewell	-	-	-	88 LPM	
		Naikwaqda near	tubewell	-	-	-	20 LPM	
		Dandoswada near school	tubewell	-	-	-	25 LPM	
		Kmarwada	tubewell	-	-	-	25 LPM	
		Dandoswada Mandrem(2nd)	tubewell	-	-	-	273 LPM	
		Mandrem Madhalamaz(New)	tubewell	-	-	-	65 LPM	
		Gawadewada near temple	tubewell	-	-	-	25 LPM	
			Asvem near temple	tubewell	-	-	-	20 LPM
			openwell	-	-	-	-	Scheme is in operation
		Madhalamaz near market	tubewell	-	-	-	15 LPM	
		Malarbhat	tubewell	-	-	-	25 LPM	
		Gawadewada	tubewell	-	-	-	25 LPM	
		Junaswada	tubewell	-	-	-	225 LPM	
		Junaswada	tubewell	-	-	-	65 LPM	
		Junaswada	tubewell	-	-	-	Nil	
		Askawada	tubewell	-	-	-	88 LPM	
		Madhalawada	tubewell	-	-	-	15 LPM	

Source: PWD Goa - as of May 2006

Table M31.8.2 List of Rural Water Supply Scheme (5/7)

Taluka	Name of Scheme	Source	Pump Capacity	Capacity of Tank	Population covered	Supply Amount	Remarks	
			(HP)	(m ³)		(m ³ /day)		
Pernem	Bidurbag	tubewell	-	-	-	25 LPM		
	Junaswada	tubewell	-	-	-	-		
	Ashvem	tubewell	-	-	-	382 LPM		
	Madhalamaz near existing pump house	tubewell	-	-	-	88 LPM		
	Deulwada	tubewell	-	-	-	65 LPM		
	Corgao							
		Petechawanda	tubewell	-	-	-	-	
		Petechawanda	tubewell	-	-	-	65 LPM	
		Mainwada	tubewell	-	-	-	165 LPM	
		Conadiwada	tubewell	-	-	-	335 LPM	
		Conadiwada	tubewell	-	-	-	276 LPM	
		Deulwada	tubewell	-	-	-	365 LPM	
		Gawadewada	tubewell	-	-	-	65 LPM	
		Bhatwadi	tubewell	-	-	-	65 LPM	
		Bhatwadi	tubewell	-	-	-	65 LPM	
		Bhaidwada	tubewell	-	-	-	Dry	
			tubewell	-	-	-	Dry	
			openwell	-	-	-	-	Scheme is in operation
		Harijianwada	tubewell	-	-	-	65 LPM	
	Morijim							
		Murdiwada	tubewell	-	-	-	15 LPM	
		Newwada	tubewell	-	-	-	65 LPM	
		Deulwadaa near panchayat	tubewell	-	-	-	400 LPM	
			openwell	-	-	-	-	Scheme is abandoned due to salinity
		Warchawada	tubewell	-	-	-	114 LPM	
		Khinwada	tubewell	-	-	-	65 LPM	
		Khin-Kumbarwada	tubewell	-	-	-	65 LPM	
		Newwada	tubewell	-	-	-	65 LPM	
		Madhalawada	tubewell	-	-	-	50 LPM	
		Dabholkarwada	tubewell	-	-	-	-	
	Agarwada-Chopdem							
		Near school Agarwada	tubewell	-	-	-	180 LPM	
		Checkpost Agarwada	tubewell	-	-	-	50 LPM	
		Chopdem	tubewell	-	-	-	85 LPM	
			openwell	-	-	-	-	Scheme is abandoned due to salinity
		Agarwada near school	tubewell	-	-	-	85 LPM	
	Parcem							
		Deulwada	tubewell	-	-	-	180 LPM	
		Deulwada	tubewell	-	-	-	400 LPM	
		Chaweddwada	tubewell	-	-	-	185 LPM	
		Vaidonger near church	tubewell	-	-	-	180 LPM	
		Vaidonger junction	tubewell	-	-	-	65 LPM	
		Madhalawada	tubewell	-	-	-	380 LPM	
		Naiginwada	tubewell	-	-	-	335 LPM	
	Tuem							
	Yuem village	tubewell	-	-	-	330 LPM		
	Zolurem	tubewell	-	-	-	743 LPM		
	Deulwada	tubewell	-	-	-	308 LPM		
		openwell	-	-	-	-	Scheme is in operation	

Source: PWD Goa - as of May 2006

Table M31.8.2 List of Rural Water Supply Scheme (6/7)

Taluka	Name of Scheme	Source	Pump Capacity	Capacity of Tank	Population covered	Supply Amount	Remarks	
			(HP)	(m ³)		(m ³ /day)		
Pernem	Vimoda							
		Near panchaiyat	tubewell	-	-	-	360 LPM	
		Valpem	tubewell	-	-	-	-	
			openwell	-	-	-	-	Scheme is in operation
		Malpem	tubewell	-	-	-	-	
		Warchawada	tubewell	-	-	-	-	
	Amberem							
		Amberem	tubewell	-	-	-	430 LPM	
	Ugvem							
		Deulwada	tubewell	-	-	-	250 LPM	
			openwell	-	-	-	-	Scheme is in operation
	Mopa							
		Mopa	tubewell	-	-	-	165 LPM	
	Torxem							
		Naikwada	tubewell	-	-	-	160 LPM	
			openwell	-	-	-	-	Scheme is abandoned due to salinity
		Fakirpotto	tubewell	-	-	-	15 LPM	
		Harijanwada	tubewell	-	-	-	380 LPM	
		Patradevi checkpost	tubewell	-	-	-	210 LPM	
		Patradevi	tubewell	-	-	-	640 LPM	
	Varcond							
		Naer school	tubewell	-	-	-	540 LPM	
		Near pump house	tubewell	-	-	-	96 LPM	
		Near Vithaladevi temple	tubewell	-	-	-	-	
			openwell	-	-	-	-	Scheme is in operation
		Near open well of Arijun	tubewell	-	-	-	-	
	Casarvenem							
		Deulwada	tubewell	-	-	-	150 LPM	
			openwell	-	-	-	-	Scheme is in operation
		Purva	tubewell	-	-	-	-	
		Bodgul	tubewell	-	-	-	-	
		Bailpat	tubewell	-	-	-	25 LPM	
	Chandel							
		Chandel village	tubewell	-	-	-	200 LPM	
		Near temple	tubewell	-	-	-	86 LPM	
		Hali Chadel	tubewell	-	-	-	190 LPM	
		Kumarwada Chandel	tubewell	-	-	-	86 LPM	
	Ibrampur Hankhane							
		Hedus	tubewell	-	-	-	34 LM	
		Ibrampur near existing pump house	tubewell	-	-	-	65 LPM	
			openwell	-	-	-	-	Scheme is in operation
		Angadwada HANKHANE	tubewell	-	-	-	25 LPM	
		Near culvert	tubewell	-	-	-	743 LPM	
		Hankhane near pump house	tubewell	-	-	-	743 LPM	
		Harijan wada	tubewell	-	-	-	15 LPM	
	Hassapur							
		In the field	tubewell	-	-	-	273 LPM	

Source: PWD Goa - as of May 2006

Table M31.8.2 List of Rural Water Supply Scheme (7/7)

Taluka	Name of Scheme	Source	Pump Capacity	Capacity of Tank	Population covered	Supply Amount	Remarks	
			(HP)	(m ³)		(m ³ /day)		
Pernem	Pernem							
		Mauswada pump house	tubewell	-	-	-	273 LPM	
		Nanerwada	openwell	-	-	-	-	Scheme is in operation
		Surbanwada	tubewell	-	-	-	182 LPM	
		Kotkarwada	tubewell	-	-	-	-	
		Surbanwada II	tubewell	-	-	-	182 LPM	
		Sarmale	tubewell	-	-	-	182 LPM	
		Bhirondem near public tap	tubewell	-	-	-	-	
		Parastem near school	tubewell	-	-	-	25 LPM	
		Parastem bedko	tubewell	-	-	-	182 LPM	
		Harijanwada	tubewell	-	-	-	25 LPM	
		Porascadem						
		Near pump house(1)	tubewell	-	-	-	85 LPM	
			openwell	-	-	-	-	Scheme is in operation
		Near pump house(2)	tubewell	-	-	-	85 LPM	
		Caznem near temple	tubewell	-	-	-	-	
		Naibag (1) near spring	tubewell	-	-	-	85 LPM	
		Naibag near bridge	tubewell	-	-	-	85 LPM	
		Near pump house	tubewell	-	-	-	85 LPM	
		Casanem	tubewell	-	-	-	385 LPM	
		Dhargai						
		Oxelbag	tubewell	-	-	-	-	
			openwell	-	-	-	-	Scheme is in operation
		Macazana	tubewell	-	-	-	25 LPM	
		Ozarim						
		Madkaiwada	openwell	-	-	-	-	Scheme is in operation

Source: PWD Goa - as of May 2006

Appendix M32

**Data Concerning Number of Connection and
Water Consumption Provided by PWD Goa**

Contents for Appendix M32

M32.1 Data Concerning Number of Connection and Water
Consumption Provided by PWD Goa M32-1

**Appendix M32.1 Data Concerning Number of Connection and Water Consumption
Provided by PWD Goa**

Taluka: Pernem

Data Source: Sub-Division office II of Division office XVII, data from Oct 2004 to Jun 2005

Number of Customers (Number of Connections) Unit: Nos.

Category	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total
1 Domestic	5,808	6,305	6,670	6,792	7,029	7,402	7,589	7,832	8,000	
2 Commercial	47	48	51	51	51	52	52	55	55	
3 Government										
4 Industries	2	2	3	3	3	3	3	3	3	
5 Municipality										
6 V. Panchayat										
7 Defense										
8 Temporary Sup.										
9 Inst. Bills										
10 Public Stand Post	1,100	1,100	1,100	1,100	1,100	800	650	520	370	
Total	6,957	7,455	7,824	7,946	8,183	8,257	8,294	8,410	8,428	

Water Consumption Billed per Monthe Unit: m3/month

Category	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total
1 Domestic	66,295	60,747	53,669	36,889	42,337	83,929	38,892	44,348	101,987	
2 Commercial	1,954	4,206	284	540	540	1,268	963	751	770	
3 Government	1,953	1,754	1,873	1,473	1,475	1,993	1,812	1,749	2,000	
4 Industries	2,400	899	1,105	1,924	1,924	2,114	1,763	1,710	875	
5 Municipality										
6 V. Panchayat										
7 Defense										
8 Temporary Sup.										
9 Inst. Bills										
10 Public Stand Post	165,000	165,000	165,000	165,000	165,000	120,000	97,500	78,000	55,500	
Total	237,602	232,606	221,931	205,826	211,276	209,304	140,930	126,558	161,132	

PER NEM

Table 4 Year 2004 Total water consumption billed per month Unit:3 (Table 5 + table 6)

Total water Quantity billed per month Unit :m3

Category	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Total
1) Domestic	66295	60747	53669	38889	42337	83929	38992	44348	101987				
2) Commercial	1854	4206	284	540	540	1268	963	751	770				
3) Government	1853	1754	1873	1473	1475	1993	1812	1749	2000				
4) Industries	2400	899	1105	1924	1924	2114	1763	1710	875				
5) Municipality	***	***	***	***	***	***	***	***	***				
6) V. Panchayat	***	***	***	***	***	***	***	***	***				
7) Defense	***	***	***	***	***	***	***	***	***				
8) Tempory Sup.	***	***	***	***	***	***	***	***	***				
9) Inst. Bills	***	***	***	***	***	***	***	***	***				
10) Public stand pos	165000	165000	165000	165000	165000	120000	97500	78000	55500				
Totals	237602	232606	221931	205626	211276	209304	140930	126556	161132				

Table 1 Year 2004 Number of customers(Number of connections) Unit:Nos (Table 2 + table 3)

Category	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Total
1) Domestic	5808	6305	6670	6792	7029	7402	7589	7632	8000				
2) Commercial	47	48	51	51	51	52	52	55	55				
3) Government	***	***	***	***	***	***	***	***	***				
4) Industries	2	2	3	3	3	3	3	3	3				
5) Municipality	***	***	***	***	***	***	***	***	***				
6) V. Panchayat	***	***	***	***	***	***	***	***	***				
7) Defense	***	***	***	***	***	***	***	***	***				
8) Tempory Sup.	***	***	***	***	***	***	***	***	***				
9) Inst. Bills	***	***	***	***	***	***	***	***	***				
10) Public stand pos	1100	1100	1100	1100	1100	800	650	520	370				

Taluka: Bardez

Data Source: Division office XVII, data of June 2005

Number of Customers (Number of Connections) Unit: Nos. 2005

Category	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total
1 Domestic									42,248	
2 Commercial									739	
3 Government									141	
4 Industries									17	
5 Municipality										
6 V. Panchayat										
7 Defense									1	
8 Temporary Sup.									5	
9 Inst. Bills										
10 Public Stand Post										
Total									43,151	

Water Consumption Billed per Month Unit: m3/month

Category	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total
1 Domestic									848,745	
2 Commercial									48,373	
3 Government									2,903	
4 Industries									14,449	
5 Municipality										
6 V. Panchayat										
7 Defense										
8 Temporary Sup.									103	
9 Inst. Bills										
10 Public Stand Post										
Total									914,573	

WORK DIVISION: XVII(PHE-N), PUBLIC WORKS DEPARTMENT, PORVORIM GOA.

STATEMENT SHOWING DEMAND, COLLECTION AND BALANCE FOR THE MONTH OF JUNE 2005

SUB DIVISION: III, MAPUSA
SUB DIVISION: V, PORVORIM.

Name of the Scheme : Assonora Water Supply Scheme.

Quantity of water pumped: 1560000 m³

Sr.N o.	Category	Number of Consumers	Opening balance	Units billed	Water charges	Meter Rent	Sundry charges (Inst. Bill)	D.P.C.	Total	Amount collected including arrears	Closing balance	Remarks
1	2	3	4	5	6	7	8	9	10	11	12	13
I	1) Domestic	42248	8626429	848745	2537062.00	344663.00			2881725.00	3044099.00	8464055.00	
	2) Government	141	92491	2903	12567.00	606.00			13173.00	12518.00	93146.00	
	3) Municipality											
	4) Village Panchayat											
	5) Defence	1	15045							155045.00		
II	6) Commercial	739	4366079	48373	1324377.00	5734.00			1330111.00	665320.00	5030870.00	
	7) Temporary Supply	5	105918	103	3090.00	34.00			3124.00	7347.00	101695.00	
III	8) Industrial	17	1471567	14449	288458.00	545.00			289003.00	1699154.00	61416.00	
IV	9) Institutional											
	10) Others											
	Total	43151	14817529	914573	4165554.00	351582.00		0.00	4517136.00	5583483.00	13751182.00	

Taluka: Tiswadi

Data Source: Sub Division office I of Division office III, data of average in 2004

Number of Customers (Number of Connections) Unit: Nos. 2004

Category	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total
1 Domestic			27,228							
2 Commercial			575							
3 Government			270							
4 Industries			12							
5 Municipality			29							
6 V. Panchayat										
7 Defense			14							
8 Temporary Sup.										
9 Inst. Bills										
10 Public Stand Post										
Total			28,128							

Water Consumption Billed per Month Unit: m3/month

Category	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total
1 Domestic			599,368							
2 Commercial			34,908							
3 Government			4,050							
4 Industries			42,194							
5 Municipality			290							
6 V. Panchayat										
7 Defense			28,389							
8 Temporary Sup.										
9 Inst. Bills										
10 Public Stand Post										
Total			709,199							

No. PWD/PHE-N/SD I/WD-III/F³⁹/2005-06/ 796

Government of Goa,
Office of the Assistant Engineer,
Sub. Div. I, Div. III, (PHE-N),
Public Works Department,
St.- Inez, Panaji – Goa.

Dated :- 15/07/2005.

To,
JICA,
C/o SIDCL, Ishari Building,
Panaji – Goa.


Sub :- Details on water supply.

Ref :- AWSSG – 0011 dated 20/6/2005.

Sir,

Please find enclosed herewith the details of consumers, quantity of water supplied and billed etc., in response to your letter cited above, forwarded to this office under the cover of letter No. PWD/CE-I/F-1/19/05-06/74 dated 23/6/2005.

Yours faithfully,



Assistant Engineer

Copy to The Executive Engineer, W. Div. III , P.W.D. Panaji, Goa.

Division Number :- III Division Name :- Public Works DepartmentSub-Division Number :- I Sub-Division Name :- _____

Name of Officer filled in this form :- _____

Tel. Number _____

*Tiswadi:
Panaji*

Name of Service Area under jurisdiction of this Sub-Division

	Taluka	City	Town	Village
1	Tiswadi	Panaji		
2			Goa Velha	
3			Bambolim	
4			Calapur	
5			Chimbel	
6				Capao
7				Navelim
8				Goltim
9				Malar
10				Maroa
11				Corlim
12				Ella
13				Baiguinim
14				Carambolim
15				Azossim
16				Mandur
17				Batim
18				Siridao
19				Neura-O-Pequeno
20				Neura-O-Grande
21				Mercurim
22				Morambi-O-Grande
23				Morambi-O-Pequeno
24				Cujira
25				Murda
26				
27				
28				
29				
30				

Table - 1 Year 2004 Number of Customers (Number of Connections) Unit : Nos. Table - 2 + Table - 3

Category	Number of Customers (Number of Connections) Unit : Nos.												
	Jan.	Feb.	Mar.	Apr.	May	Jun.	Jul.	Aug.	Sep.	Oct.	Nov.	Dec.	Total
1 Domestic												27228	
2 Commercial												575	
3 Government												270	
4 Industries												12	
5 Municipality												29	
6 V. Panchayat												14	
7 Defense													
8 Temporary Sup.													
9 Inst Bills													
10 Public Stand Post													
Total													28128

Table - 2 Year 2004 Number of Customers (Number of Connections) with GOOD WORKING WATER METERS Unit Nos.

Category	Number of Customers (Number of Connections) with GOOD WORKING WATER METERS Unit : Nos.												
	Jan.	Feb.	Mar.	Apr.	May	Jun.	Jul.	Aug.	Sep.	Oct.	Nov.	Dec.	Total
1 Domestic												23336	
2 Commercial												505	
3 Government												192	
4 Industries												11	
5 Municipality													
6 V. Panchayat													
7 Defense													
8 Temporary Sup.												2	
9 Inst Bills													
10 Public Stand Post													
Total													24046

Table - 3 Year 2004 Number of Customers (Number of Connections) with MALFUNCTIONED/BROKEN WATER METERS Unit Nos.

Category	Number of Customers (Number of Connections) with MALFUNCTIONED/BROKEN WATER METERS Unit : Nos.												
	Jan.	Feb.	Mar.	Apr.	May	Jun.	Jul.	Aug.	Sep.	Oct.	Nov.	Dec.	Total
1 Domestic												3892	
2 Commercial												70	
3 Government												78	
4 Industries												1	
5 Municipality												29	
6 V. Panchayat													
7 Defense													
8 Temporary Sup.													
9 Inst Bills													
10 Public Stand Post													
Total													4082

Tiswadi
Panaji

Table - 4 Year 2004 Total Water Consumption Billed per Month Unit : m3 (Table - 5 + Table - 6)

Category	Total Water Quantity Billed per Month												Total
	Jan.	Feb.	Mar.	Apr.	May	Jun.	Jul.	Aug.	Sep.	Oct.	Nov.	Dec.	
1 Domestic													599368
2 Commercial													34908
3 Government													4050
4 Industries													42194
5 Municipality													290
6 V. Panchayat													
7 Defense													28389
8 Temporary Sup.													
9 Inst Bills.													
10 Public Stand Post													
Total													709199

Table - 5 Year 2004 Water Consumption Billed Based on Meter Reading (by Good Meter) Unit : m3

Category	Water Consumption Billed Based on Meter Reading (by Good Meter)												Total
	Jan.	Feb.	Mar.	Apr.	May	Jun.	Jul.	Aug.	Sep.	Oct.	Nov.	Dec.	
1 Domestic													540988
2 Commercial													33508
3 Government													2880
4 Industries													41944
5 Municipality													
6 V. Panchayat													
7 Defense													28149
8 Temporary Sup.													
9 Inst Bills.													
10 Public Stand Post													
Total													647469

Table - 6 Year 2004 Water Consumption Billed Based on Estimation (because of malfunctioned/ broken meter) Unit : m3

Category	Water Consumption Billed Based on Estimation (because of malfunctioned/ broken meter)												Total
	Jan.	Feb.	Mar.	Apr.	May	Jun.	Jul.	Aug.	Sep.	Oct.	Nov.	Dec.	
1 Domestic													58380
2 Commercial													1400
3 Government													1170
4 Industries													250
5 Municipality													290
6 V. Panchayat													
7 Defense													240
8 Temporary Sup.													
9 Inst Bills.													
10 Public Stand Post													
Total													61730

Taluka: Bicholim

Data Source: Division office XVII , data of June 2005

Number of Customers (Number of Connections) Unit: Nos. 2005

Category	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total
1 Domestic									11,223	
2 Commercial									270	
3 Government									28	
4 Industries									9	
5 Municipality									33	
6 V. Panchayat									15	
7 Defense										
8 Temporary Sup.										
9 Inst. Bills									65	
10 Public Stand Post										
Total									11,643	

Water Consumption Billed per Month Unit: m3/month

Category	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total
1 Domestic									291,325	
2 Commercial									10,998	
3 Government									6,504	
4 Industries									6,955	
5 Municipality									2,455	
6 V. Panchayat									604	
7 Defense										
8 Temporary Sup.										
9 Inst. Bills									4,684	
10 Public Stand Post										
Total									323,525	

WORK DIVISION: XV(PHE-N), PUBLIC WORKS DEPARTMENT, PORVORIM GOA.

STATEMENT SHOWING DEMAND, COLLECTION AND BALANCE FOR THE MONTH OF JUNE 2005

Name of the Scheme : Podocem Water Supply Scheme, Sanquelim.

SUB DIVISION: L BICHOLIM

Quantity of water pumped: 405000m³

Sr.N o.	Category	Number of Consumers	Opening balance	Unit billed	Water charges	Meter Rent	Sundry charges (Inst. Bill)	D.P.C.	Total	Amount collected including arrears	Closing balance	Remarks
1	2	3	4	5	6	7	8	9	10	11	12	13
I	1) Domestic	11223	983126	291325	955600.00	108016.00	43880.00		1107496.00	1079516.00	1011106.00	
	2) Government	28	123287	6504	31259.00	290.00	580.00		32129.00	8151.00	147265.00	
	3) Municipality	33		2455	9548.00	321.00			9969.00	9969.00		
	4) Village Panchayat	15	6367	604	2271.00	178.00			2449.00	240.00	8576.00	
	5) Defence								0.00			
II	6) Commercial	270	743614	10998	296530.00	2664.00	460.00		303654.00	221824.00	825444.00	
	7) Temporary Supply			0					0.00			
III	8) Industrial	9	298560	6955	139100.00	174.00			139274.00	131908.00	305926.00	
IV	9) Institutional	65		4684	22414.00	692.00			23106.00	20817.00		
	10) Others								0.00			
	Total	11643	2154954	323525	1456822.00	112335.00	48920.00		1618077.00	1472425.00	2298317.00	

Taluka: Satari

Data Source: Sub-Division office II of Division office XVII, data from March 2006 to April 2006

Number of Customers (Number of Connections) Unit: Nos.

Category	2006										Total	
	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun			
1 Domestic						6,068	6,111					
2 Commercial						72	72					
3 Government						125	126					
4 Industries						13	13					
5 Municipality						5	5					
6 V. Panchayat						19	19					
7 Defense												
8 Temporary Sup.												
9 Inst. Bills												
10 Public Stand Post						517	517					
Total						6,819	6,863					

Water Consumption Billed per Month Unit: m3/month

Category	2006										Total	
	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun			
1 Domestic						106,894	115,589					
2 Commercial						1,793	1,737					
3 Government						5,159	6,851					
4 Industries						2,821	3,073					
5 Municipality						199	219					
6 V. Panchayat						293	361					
7 Defense												
8 Temporary Sup.												
9 Inst. Bills												
10 Public Stand Post						80,135	80,135					
Total						197,294	207,965					

STATEMENT SHOWING DEMAND COLLECTION AND BALANCE FOR THE MONTH OF : APRIL-06

Villages	Total Water Distributed	No. of Consumers wise	Population Covered	No. of Public taps PSP	Qty. supplied through PSP	Qty. of water billed	Total NRW ³ 2-(6+7)	NRW %	UFW 2-(6=7)	LPCD per son day	Faulty meters category wise	No. of meters replaced category wise	No. of disconnections category wise	Dearnd (billing) Category wise in Rs.	Opening balance category wise in Rs.		Amount collected wise in Rs.	Closing balance category wise in Rs.		Name of meter reader for concerne Zone
															15	16		17	18	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19		
All Villages of Pernem Taluak	223200	DO-6111 GT-41 MC-5 VP-19 COM-72 IND-13 INST. 85	30555	517	80135	115589	15235	6.83	15235	122	608	8	6	564747	763522	509715	818554			
	250200			517	80135	3252	15235	6.83	15235	122	608	8	6	63427	48349	39993	71783			
						219						1		3776	1228	196	4808			
						361								2519	50	849	1720			
						1737								42225	81667	24379	99513			
						3073								68396	2816	67579	3633			
						3599					18	1		28650	-162	4979	23509			
	223200	6346	30555	517	80135	127830	15235	6.83	15235	122	626	9	6	874420	1278560	647690	1505290			

Col. 19 Name of the Meter Reader for concerned Zone

- 1) Gurudas F. Gawas
- 2) Datta D. Naik
- 3) Rajendra Gaonkar
- 4) Tulshidas S. Gaonkar
- 5) Gopal G. Saleikar
- 6) Dattaram Gaonkar
- 7) Subhash F. Gawas

- Valpoi/Sawardem
- Valpoi/Morlem
- Hondal/Pissurlem
- Mauxi/Bhioronde
- Thane/Nagargao
- Khotode/Guleli
- Parye/Kerim

W. D. ...

In this table, name of Taluka is shown as "Pernem", but it is mistype and this talbe is for "Satari" Taluka.

STATEMENT SHOWING DEMAND COLLECTION AND BALANCE FOR THE MONTH OF : MARCH-06

Name of Villages	Total Water Distribution	No. of Consumers Category wise	Population Covered	No. of Public taps PSP	Qty. supplied through PSP	Qty. of water billed	Total NRW ³ 2-(6+7)	NRW %	UFW 2-(6=7)	LPCD per Liter/Per son day	Faulty meters category wise	No. of meters replaced category wise	No. of disconnections category wise	Deamnd (billing) Category wise in Rs.	Opening balance category wise in Rs.	Amount collected category wise in Rs.	Closing balance category wise in Rs.	Name of meter reader for concerne Zone
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19
All Villages of Pernem Taluak	223200	DO-6068 GT-40 MC-5 VP-19 COM-72 IND-13 INST. 85	30340	30340	106894	1699	25906	11.60	25906	114	623	15	1	535274	766797	538549	763522	
						199					1	1		11729	51119	14499	48349	
						293								3023	1086	2881	1228	
						1793							1	1819	1769	50	
						2821								43439	82491	44263	81667	
						3460								62936	7405	67525	2816	
						...								21471	24400	46033	-162	
				517	80135	...	25906	11.60	25906	114	19	1	2	105461	275629	381090	
	223200	6302	30340	517	80135	117159	25906	11.60	25906	114	643	17	2	785152	1208927	715519	1278560	

Col. 19 Name of the Meter Reader for concerned Zone

- 1) Gurudas F. Gawas
 - 2) Datta D. Naik
 - 3) Rajendra Gaonkar
 - 4) Tulshidas S. Gaonkar
 - 5) Gopal G. Saleikar
 - 6) Dattaram Gaonkar
 - 7) Subhash F. Gawas
- Valpoi
Morlem
Honda/Pissurlem
Mauxi/Bhioronde
Thane/Nagargao
Sawardem/Khotode/Guleli
Parye/Kerim

In this table, name of Taluka is shown as "Pernem", but it is mistype and this talbe is for "Satari" Taluka.

Taluka: Ponda

Data Source: Division office III, data of July 2005

Number of Customers (Number of Connections) Unit: Nos. 2005

Category	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Total
1 Domestic										16471	
2 Commercial										344	
3 Government										110	
4 Industries										59	
5 Municipality										6	
6 V. Panchayat											
7 Defense											
8 Temporary Sup.											
9 Inst. Bills											
10 Public Stand Post											
Total			0							16990	

Water Consumption Billed per Month Unit: m3/month

Category	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Total
1 Domestic										471097	
2 Commercial										11163	
3 Government										10440	
4 Industries										70430	
5 Municipality										71	
6 V. Panchayat											
7 Defense											
8 Temporary Sup.											
9 Inst. Bills											
10 Public Stand Post											
Total			0							563201	

Sub-Division **IV**

Division **III**

Ponda Only

STATEMENT SHOWING DEMAND, COLLECTION AND BALANCE FOR THE MONTH OF July 2005

(Name of the Scheme (e.g.) **OPA** Water Works
Quantity of Water Furnished: **M3**)

Sr. No.	Category	Number of Consumers	Opening Balance	Units Billed & Amount	Meter Rent	Sundry Charges	D.P.C. Total	Amount Collected including arrears	Closing Balance	Remarks	
1	2	3	4	5	6	7	8	9	10	11	12
I	(1) Domestic	16471	-	171097 1524270	179346	-	-	866985/-	4357526/-		
	(2) Government	77	-	4709 20686/-	997/-	-	-	4540/-	22726/-		
	(3) Municipality	6	-	211/-	-	-	-	-	707/-		
	(4) Village Panchayat	-	-	-	-	-	-	-	-		
	(5) Police	-	-	-	-	-	-	-	-		
II	(6) Commercial	344	-	11163 256060/-	3765/-	-	-	144593/-	592263/-		
	(7) Temporary Supply	-	-	-	-	-	-	-	-		
III	(8) Industries	59	-	70430 1576400/-	2406/-	-	-	1649401/-	15756/-		
IV	(9) Institutions	33	-	5731 23299/-	623/-	-	-	22567/-	4592534/-		
V	(10) Others Installation	-	-	-	-	-	-	4754/-	-		
	Total	16987	-	563291 3400617/-	187140	-	-	2729942	6498549/-		

ASSISTANT ENGINEER,
ERTY, WDIII (PBB) PWD,
MAAG, PONDA - GOA.

Taluka: Mormugao

Data Source: Private Firm (Megasoftware), data of 2004

Number of Customers (Number of Connections) Unit: Nos.

Category	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
1 Domestic	14,730	14,788	14,858	14,982	15,147	15,224	15,407	15,330	15,536	15,668	15,761	15,887	
2 Commercial	255	262	264	266	268	266	266	262	263	264	263	261	
3 Government	125	124	124	125	126	128	128	128	132	133	133	134	
4 Industries	320	314	310	307	304	301	299	298	297	298	293	298	
5 Municipality	0	0	0	0	0	0	0	0	0	2	2	5	
6 V. Panchayat	0	0	0	0	0	0	0	0	0	0	0	0	
7 Defense	12	12	12	12	12	12	12	12	12	12	12	12	
8 Temporary Sup.	20	22	24	24	19	20	19	18	16	15	14	14	
9 Inst. Bills	0	0	0	0	0	0	0	0	0	0	0	0	
10 Public Stand Post	135	135	135	135	135	135	135	135	135	134	134	134	
Total	15,597	15,657	15,727	15,851	16,011	16,086	16,266	16,183	16,391	16,526	16,612	16,745	

Water Consumption Billed per Month Unit: m3/month

Category	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
1 Domestic	0	678,306	276,283	974,418	454,719	399,618	356,908	165,588	440,659	369,920	538,927	383,270	5,038,616
2 Commercial	0	16,559	3,084	22,251	6,886	9,509	6,770	5,859	7,004	8,565	9,401	4,537	100,425
3 Government	0	28,219	19,256	39,781	18,612	20,178	19,127	8,990	21,460	17,796	29,479	21,667	244,565
4 Industries	0	72,012	19,768	85,477	29,539	45,149	10,548	31,304	6,701	56,082	23,964	47,383	427,927
5 Municipality	0	0	0	0	0	0	0	0	0	45	0	3,881	3,926
6 V. Panchayat	0	0	0	0	0	0	0	0	0	0	0	0	0
7 Defense	0	16,843	6,639	23,116	5,819	16,926	10,954	7,429	15,565	4,624	3,746	19,105	130,766
8 Temporary Sup.	0	3,416	21,638	36,640	1,567	26,743	815	1,379	26,749	1,068	42,513	412	162,940
9 Inst. Bills	0	0	0	0	0	0	0	0	0	0	0	0	0
10 Public Stand Post	0	4,797	737	6,086	2,393	2,306	1,466	1,262	1,464	2,945	2,305	2,734	28,495
Total	0	820,152	347,405	1,187,769	519,535	520,429	406,588	221,811	519,602	461,045	650,335	482,989	6,137,660

Taluka: Salcete

Data Source: Private Firm (Megasoftware), data of 2004

Number of Customers (Number of Connections) Unit: Nos.

Category	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
1 Domestic	41,640	41,845	41,988	42,150	42,266	42,326	42,362	42,620	42,893	43,183	43,419	43,409	
2 Commercial	315	319	327	331	331	335	335	337	342	346	346	349	
3 Government	313	319	323	335	341	366	366	397	403	408	409	481	
4 Industries	502	508	510	514	516	516	518	518	525	531	541	544	
5 Municipality	2	2	2	2	2	2	2	2	2	3	3	3	
6 V. Panchayat	0	0	0	0	0	0	0	0	0	0	0	0	
7 Defense	4	3	3	3	2	3	2	3	2	5	3	3	
8 Temporary Sup.	84	86	89	92	89	84	86	88	88	87	81	85	
9 Inst. Bills	0	0	0	0	0	0	0	0	0	0	0	0	
10 Public Stand Post	83	83	83	83	83	83	83	83	86	86	86	86	
Total	42,943	43,165	43,325	43,510	43,630	43,715	43,754	44,048	44,341	44,649	44,888	44,960	

Water Consumption Billed per Month Unit: m3/month

Category	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
1 Domestic	1,005,207	1,314,746	1,528,709	1,407,886	1,189,174	881,517	900,190	918,858	976,368	968,020	816,275	437,238	12,344,188
2 Commercial	69,513	84,608	79,450	74,918	70,722	70,720	54,231	69,658	68,485	66,153	63,479	65,857	837,794
3 Government	50,650	78,513	64,393	86,617	67,236	66,140	44,404	68,229	78,316	70,486	30,758	42,382	748,124
4 Industries	62,862	90,023	76,034	68,730	71,149	63,821	48,669	59,000	71,854	70,664	64,474	56,429	803,709
5 Municipality	66	0	59	37	0	36	0	48	0	305	75	0	626
6 V. Panchayat	0	0	0	0	0	0	0	0	0	0	0	0	0
7 Defense	151,846	1,860	139,440	76,860	990	73,204	870	97,434	870	133,508	960	870	678,712
8 Temporary Sup.	7,727	12,837	9,423	11,864	11,477	5,988	7,730	9,174	7,269	7,563	4,496	6,007	101,555
9 Inst. Bills	0	0	0	0	0	0	0	0	0	0	0	0	0
10 Public Stand Post	962	2,299	1,687	2,319	1,767	1,754	804	1,967	2,245	1,241	813	616	18,474
Total	1,348,833	1,584,886	1,899,195	1,729,231	1,412,515	1,163,180	1,056,898	1,224,368	1,205,407	1,317,940	981,330	609,399	15,533,182

Taluka: Quepem

Data Source: Private Firm (Megasoftware), data of 2004

Number of Customers (Number of Connections) Unit: Nos.

Category	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
1 Domestic	9,669	9,932	10,078	10,162	10,169	10,225	9,805	9,845	10,332	10,420	10,496	10,542	
2 Commercial	93	95	97	99	102	102	102	102	103	106	107	108	
3 Government	73	73	73	73	73	74	68	68	75	74	74	74	
4 Industries	78	76	75	76	76	77	76	75	76	77	78	78	
5 Municipality	0	0	0	0	0	0	0	0	0	0	0	0	
6 V. Panchayat	0	0	0	0	0	0	0	0	0	0	0	0	
7 Defense	0	0	0	0	0	0	0	0	0	0	0	0	
8 Temporary Sup.	11	10	12	12	12	12	14	11	11	11	14	12	
9 Inst. Bills	0	0	0	0	0	0	0	0	0	0	0	0	
10 Public Stand Post	224	224	224	224	224	224	224	224	224	224	224	224	
Total	10,148	10,410	10,559	10,646	10,656	10,714	10,289	10,325	10,821	10,912	10,993	11,038	

Water Consumption Billed per Month Unit: m3/month

Category	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
1 Domestic	179,536	288,712	158,836	226,230	233,108	348,456	167,022	217,483	126,032	181,436	226,645	148,470	2,501,966
2 Commercial	2,687	2,465	2,210	2,198	2,974	4,486	2,194	3,089	1,149	3,418	3,299	1,070	31,239
3 Government	10,526	8,078	8,081	1,449	8,065	8,677	7,553	9,425	1,614	10,689	9,178	854	84,189
4 Industries	2,133	10,386	1,706	12,275	1,850	9,529	1,247	8,592	297	1,720	3,848	6,690	60,273
5 Municipality	0	0	0	0	0	0	0	0	0	0	0	0	0
6 V. Panchayat	0	0	0	0	0	0	0	0	0	0	0	0	0
7 Defense	0	0	0	0	0	0	0	0	0	0	0	0	0
8 Temporary Sup.	748	658	1,319	448	1,249	1,485	751	654	0	914	743	0	8,969
9 Inst. Bills	0	0	0	0	0	0	0	0	0	0	0	0	0
10 Public Stand Post	828	882	4,563	0	5,847	1,079	4,446	897	0	4,577	843	4,723	28,685
Total	196,458	311,181	176,715	242,600	253,093	373,712	183,213	240,140	129,092	202,754	244,556	161,807	2,715,321

Taluka: Sanguem

Data Source: Private Firm (Megasoftware), data of 2004

Number of Customers (Number of Connections) Unit: Nos.

Category	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
1 Domestic	2,424	2,427	2,442	2,449	2,445	2,475	2,480	2,490	2,493	2,577	2,578	2,588	
2 Commercial	18	17	17	17	17	17	16	17	17	17	17	17	
3 Government	13	13	14	14	14	14	14	14	14	14	14	16	
4 Industries	2	2	2	2	2	4	4	4	4	6	6	6	
5 Municipality	1	1	1	1	1	1	1	1	1	1	1	1	
6 V. Panchayat	0	0	0	0	0	0	0	0	0	0	0	0	
7 Defense	0	0	0	0	0	0	0	0	0	0	0	0	
8 Temporary Sup.	0	1	2	1	4	4	4	3	3	4	4	3	
9 Inst. Bills	0	0	0	0	0	0	0	0	0	0	0	0	
10 Public Stand Post	49	49	49	49	49	49	49	49	49	49	49	49	
Total	2,507	2,510	2,527	2,533	2,532	2,564	2,568	2,578	2,581	2,668	2,669	2,680	

Water Consumption Billed per Month Unit: m3/month

Category	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
1 Domestic	40,303	63,484	46,606	53,208	19,184	82,923	20,682	77,738	8,456	101,126	5,868	89,916	609,494
2 Commercial	193	709	350	764	20	692	81	839	97	988	21	847	5,601
3 Government	226	565	404	534	231	605	169	649	0	1,027	0	1,926	6,336
4 Industries	0	821	0	301	0	415	0	353	323	833	0	215	3,261
5 Municipality	23	0	31	0	0	141	0	107	0	39	0	31	372
6 V. Panchayat	0	0	0	0	0	0	0	0	0	0	0	0	0
7 Defense	0	0	0	0	0	0	0	0	0	0	0	0	0
8 Temporary Sup.	0	28	87	0	225	111	491	0	0	582	0	500	2,024
9 Inst. Bills	0	0	0	0	0	0	0	0	0	0	0	0	0
10 Public Stand Post	969	384	1,015	262	1,311	569	1,504	565	0	1,597	0	1,364	9,540
Total	41,714	65,991	48,493	55,069	20,971	85,456	22,927	80,251	8,876	106,192	5,889	94,799	636,628

Taluka: Canacona

Data Source: Private Firm (Megasoft), data of 2004

Number of Customers (Number of Connections) Unit: Nos.

Category	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
1 Domestic	3,020	3,038	3,081	3,110	3,139	3,178	3,176	3,181	3,192	3,207	3,230	3,246	
2 Commercial	92	94	93	93	92	92	93	94	93	91	91	90	
3 Government	48	48	48	53	53	55	55	57	57	57	56	56	
4 Industries	12	13	12	12	12	11	11	11	12	15	15	16	
5 Municipality	0	0	0	0	0	0	0	0	0	0	0	0	
6 V. Panchayat	0	0	0	0	0	0	0	0	0	0	0	0	
7 Defense	0	0	0	0	0	0	0	0	0	0	0	0	
8 Temporary Sup.	5	5	5	3	3	3	3	3	3	3	3	3	
9 Inst. Bills	0	0	0	0	0	0	0	0	0	0	0	0	
10 Public Stand Post	18	18	18	18	18	18	18	18	18	18	18	20	
Total	3,195	3,216	3,257	3,289	3,317	3,357	3,356	3,364	3,375	3,391	3,413	3,431	

Water Consumption Billed per Monthe Unit: m3/month

Category	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
1 Domestic	13,369	102,833	37,276	112,197	35,229	105,412	49,193	86,231	35,671	75,497	36,774	80,121	769,803
2 Commercial	330	4,896	501	4,852	474	4,425	552	3,810	461	3,211	509	3,539	27,560
3 Government	50	3,741	74	4,182	46	4,405	387	3,574	216	4,731	173	4,421	26,000
4 Industries	0	1,112	0	1,342	0	960	0	852	204	1,230	55	1,782	7,537
5 Municipality	0	0	0	0	0	0	0	0	0	0	0	0	0
6 V. Panchayat	0	0	0	0	0	0	0	0	0	0	0	0	0
7 Defense	0	0	0	0	0	0	0	0	0	0	0	0	0
8 Temporary Sup.	0	931	0	1,265	0	303	0	310	0	300	0	265	3,374
9 Inst. Bills	0	0	0	0	0	0	0	0	0	0	0	0	0
10 Public Stand Post	0	6,242	0	6,233	0	6,257	0	6,478	0	6,485	0	6,065	37,760
Total	13,749	119,755	37,851	130,071	35,749	121,762	50,132	101,255	36,552	91,454	37,511	96,193	872,034