

---

**Appendix M63:**

**Master Plan for Sewerage Facilities**

### **Contents for Appendix M63**

M63.1	Flow Calculation Sheets (Year of 2025) .....	M63-1
M63.2	Longitudinal Profile of Trunk Sewer (Year of 2025) .....	M63-9
M63.3	Capacity Calculation of Sewerage Treatment Facilities .....	M63-21
M63.4	Comparison Study for Allocation of Sewerage Facilities .....	M63-67

**Appendix M63.1 Flow Calculation Sheets (Year of 2025)**  
**(1) Flow Calculation Sheet for Panaji Surroundings (Taleigao, Dona Paula and Caranzarem) (Year of 2025)**

Node	Area (ha)		Population		Average Flow (lps)		Peak Factor	Peak Flow (lps)	Diameter (mm)	Length (m)	Gradient (1/X)	Ground level (m)		Invert level (m)		Covering (m)		Velocity at 80% depth (m/sec)	Flow Capacity at 80% depth (lps)	Remarks	
	From	To	Increment	Cumulative	Increment	Cumulative						Increment	Cumulative	Upstream	Downstream	Upstream	Downstream				Upstream
MP-1(1)	2	18.4	1,683	1,683	7.1	7.1	3.00	21.4	150	50	PM	15.00	20.97	13.270	19.240	1.50	1.50				
	3	0.0	18.4	0	1,683	0.0	1,683	21.4	200	700	165	20.97	19.98	19.190	14.948	1.50	4.75	0.80	21.7		
	7	18.4	36.8	1,683	3,366	7.1	14.3	42.9	300	750	280	19.98	4.17	14.848	2.290	4.75	1.50	0.81	49.0		
	5	33.3	33.3	1,588	1,588	3.2	3.2	3.00	150	1,100	110	45.00	4.82	43.770	3.590	1.00	1.00	0.81	12.3	Branch sewer	
	MP-2(6)	0.0	33.3	0	1,588	0.0	1,588	3.00	150	400	110	4.82	4.17	3.570	-0.066	1.02	4.01	0.81	12.3	Branch sewer	
	MP-2(6)	7	0.0	33.3	0	1,588	0.0	3.2	75	50	PM	4.17	4.17	3.020	3.020	1.00	1.00			Branch sewer	
	7	18.4	88.5	1,683	6,637	7.1	24.7	3.00	400	650	410	4.57	4.57	2.190	0.605	1.50	3.49	0.81	87.3		
	8	97.7	842	7,478	3.6	28.2	3.00	84.7	400	800	410	4.57	4.91	0.585	-1.366	3.51	5.80	0.81	87.3		
	PS-1(9)	10	42.5	140.2	2,830	10,308	9.5	37.7	3.00	113.1	500	850	5.60	4.91	3.70	2.830	1.312	1.50	1.81	0.80	135.4
	10	STP(27)	9.2	149.4	842	11,149	3.6	41.3	3.00	500	800	560	3.70	3.11	1.292	-0.137	1.83	2.67	0.80	135.4	
	MP-3(11)	12	9.3	9.3	441	441	0.9	0.9	75	500	PM	5.00	46.42	3.350	45.270	1.50	1.00			Branch sewer	
	12	0.0	9.3	0	441	0.0	0.9	2.7	150	1,100	110	46.42	39.58	45.190	35.190	1.00	4.16	0.81	12.3	Branch sewer	
	MP-4(13)	14	55.5	55.5	2,646	2,646	5.4	5.4	150	500	PM	3.81	39.58	2.080	37.850	1.50	1.50				
	14	0.0	64.8	0	3,087	0.0	6.3	3.00	200	800	165	39.58	28.60	37.330	26.820	1.97	1.50	0.80	21.7		
	15	24.1	88.9	1,147	4,234	2.3	8.6	3.00	250	500	220	28.60	4.22	24.560	2.390	3.71	1.50	0.81	34.0		
	16	19	0.0	88.9	0	4,234	0.0	8.6	250	350	220	4.22	4.21	2.370	0.779	1.52	3.10	0.81	34.0		
	MP-5(18)	17	25.9	25.9	1,235	1,235	2.5	2.5	150	800	110	5.70	4.21	4.470	-2.803	1.00	6.78	0.81	12.3	Branch sewer	
	19	0.0	25.9	0	1,235	0.0	2.5	3.00	75	50	PM	4.21	4.21	3.060	3.060	1.00	1.00			Branch sewer	
	19	23	22.2	137.0	1,058	6,527	2.1	13.3	300	200	280	4.21	4.44	0.729	0.015	3.10	4.05	0.81	49.0		
	20	24.1	24.1	1,147	1,147	2.3	2.3	3.00	150	750	110	7.90	5.52	6.670	-0.148	1.00	5.44	0.81	12.3	Branch sewer	
	MP-6(21)	22	13.0	13.0	617	617	1.3	1.3	75	600	PM	2.27	5.52	1.120	4.370	1.00	1.00			Branch sewer	
	22	37.0	74.1	1,764	3,528	3.6	7.2	3.00	200	250	165	5.52	4.44	3.740	2.225	1.50	1.94	0.80	21.7		
	23	PS-2(24)	29.6	240.7	1,411	11,467	2.9	23.3	3.00	400	410	4.44	4.18	-0.080	-1.056	4.04	4.76	0.81	87.3		
	PS-2(24)	25	25.9	266.6	1,235	12,701	2.5	25.8	300	600	PM	4.18	7.90	2.300	6.020	1.50	1.50				
	25	48.0	314.6	2,293	14,995	4.7	30.4	3.00	450	700	490	7.90	3.11	5.390	1.080	1.98	1.50	0.80	109.3		
	26	STP(27)	0.0	314.6	0	14,995	0.0	30.4	3.00	450	550	490	3.11	3.11	1.060	-0.062	1.52	2.64	0.80	109.3	

**(2) Flow Calculation Sheet for St.Crus Area (Year of 2025)**

Node	Area (ha)		Population		Average Flow (lps)		Peak Factor	Peak Flow (lps)	Diameter (mm)	Length (m)	Gradient (1/x)	Ground level (m)		Invert level (m)		Covering (m)		Velocity at 80% depth (m/sec)	Flow Capacity at 80% depth (lps)	Remarks
	From	To	Increment	Cumulative	Increment	Cumulative						Increment	Cumulative	Upstream	Downstream	Upstream	Downstream			
1		3	12.0	12.0	1,637	1,637	2.8	8.5	150	400	110	50.00	10.00	48.770	8.770	1.00	1.00	0.81	12.3	Branch Sewer
2		3	12.0	12.0	1,637	1,637	2.8	8.5	150	400	110	10.00	10.00	8.770	5.134	1.00	4.64	0.81	12.3	Branch Sewer
3		6	19.0	43.0	2,592	5,867	4.5	30.6	250	450	220	10.00	4.00	4,850	2,170	4.82	1.50	0.81	34.0	
4	MP-1(5)		9.0	9.0	1,228	1,228	2.1	6.4	150	400	110	3.00	4.00	1,770	-1,866	1.00	5.64	0.81	12.3	Branch Sewer
5	MP-1(5)	6	0.0	9.0	0	1,228	0.0	6.4	75	50	PM	4.00	4.00	2,850	2,850	1.00	1.00	0.81		Branch Sewer
6		9	25.0	77.0	3,411	10,506	5.9	54.7	350	650	350	4.00	3.00	2,070	0,213	1.50	2.36	0.80	66.2	
7	MP-2(8)		14.0	14.0	1,910	1,910	3.3	9.9	150	200	110	3.00	3.00	1,770	-0,048	1.00	2.82	0.81	12.3	Branch Sewer
8	MP-2(8)	9	0.0	14.0	0	1,910	0.0	9.9	75	50	PM	3.00	3.00	1,850	1,850	1.00	1.00	0.81		Branch Sewer
9		9	14.0	105.0	1,910	14,326	3.3	74.6	400	600	410	3.00	3.00	0,163	-1,300	2.36	3.82	0.81	87.3	
10	MP-3(11)		4.0	4.0	546	546	0.9	2.8	150	400	110	4.00	3.00	2,770	-0,866	1.00	3.64	0.81	12.3	Branch Sewer
11	MP-3(11)	12	15.0	19.0	2,047	2,592	3.6	13.5	200	750	165	3.00	3.00	1,220	-3,325	1.50	6.05	0.80	21.7	
12		12	0.0	124.0	0	16,918	0.0	88.1	450	500	490	3.00	2.00	0,970	-0,050	1.50	1.52	0.80	109.3	

### (3) Flow Calculation Sheet for Porvorim (Year of 2025)

Node	Area (ha)		Population		Average Flow (lps)		Peak Flow Factor	Peak Flow (lps)	Diameter (mm)	Length (m)	Gradient (1/x)	Ground level (m)		Invert level (m)		Covering (m)		Velocity at 80% depth (m/sec)	Flow Capacity at 80% depth (lps)	Remarks	
	Increment	Cumulative	Increment	Cumulative	Increment	Cumulative						Upstream	Downstream	Upstream	Downstream	Upstream	Downstream				
1																					
PS-1(3)	70.7	70.7	5,681	5,681	10.5	10.5	3.00	31.4	250	1,100	220	58.00	50.00	55.897	48.170	1.77	1.50	0.808	34.0		
MP-1(2)																					
PS-1(3)	95.9	95.9	7,709	7,709	14.2	14.2	3.00	42.6	200	1,000	PM	30.00	50.00	28.220	48.220	1.50	1.50				
PS-1(3)	0.0	166.6	0	13,390	0.0	24.6	3.00	73.9	250	1,100	PM	50.00	58.00	48.170	56.170	1.50	1.50				
4																					
MP-3(6)	18.4	18.4	1,478	1,478	2.7	2.7	3.00	8.2	150	1,100	110	58.00	50.00	56.770	48.770	1.00	1.00	0.813	12.3	Branch sewer	
MP-2(5)																					
MP-3(6)	10.1	10.1	810	810	1.5	1.5	3.00	4.5	75	600	PM	30.00	50.00	28.850	48.850	1.00	1.00			Branch sewer	
MP-3(6)	0.0	28.5	0	2,288	0.0	4.2	3.00	12.6	150	1,100	PM	50.00	58.00	48.270	56.270	1.50	1.50				
MP-4(7)																					
PS-2(18)	15.4	15.4	1,239	1,239	2.3	2.3	3.00	6.8	100	1,000	PM	30.00	58.00	28.820	56.820	1.00	1.00			Branch sewer	
PS-2(18)	15.6	226.1	1,253	18,171	2.3	33.4	3.00	100.3	450	300	490	58.00	50.00	53.508	47.970	3.96	1.50	0.801	109.3		
MP-5(9)																					
10	25.3	25.3	2,030	2,030	3.7	3.7	3.00	11.2	100	450	PM	50.00	60.00	48.820	58.820	1.00	1.00			Branch sewer	
11	48.0	73.3	3,857	5,887	7.1	10.8	3.00	32.5	250	450	220	60.00	57.00	57.959	55.170	1.71	1.50	0.81	34.0		
11	27.8	101.1	2,233	8,120	4.1	14.9	3.00	44.8	300	450	280	57.00	57.00	55.120	53.513	1.50	3.11	0.81	49.0		
MP-6(12)																					
13	28.5	28.5	2,292	2,292	4.2	4.2	3.00	12.7	100	650	PM	50.00	57.00	48.820	55.820	1.00	1.00			Branch sewer	
MP-7(14)																					
15	22.2	151.8	1,778	12,190	3.3	22.4	3.00	67.3	400	800	410	57.00	56.00	53.413	51.462	3.11	4.06	0.81	87.3		
MP-7(14)	8.9	8.9	715	715	1.3	1.3	3.00	3.9	75	750	PM	50.00	56.00	48.850	54.850	1.00	1.00			Branch sewer	
16	10.8	10.8	864	864	1.6	1.6	3.00	4.8	150	550	110	62.00	58.00	60.270	55.270	1.50	2.50	0.81	12.3	Branch sewer	
17	45.5	56.3	3,654	4,519	6.7	8.3	3.00	24.9	250	350	220	58.00	56.00	55.170	53.579	2.50	2.09	0.81	34.0		
PS-2(18)	10.1	227.1	812	18,236	1.5	33.6	3.00	100.7	450	400	490	56.00	50.00	51.412	47.970	4.06	1.50	0.80	109.3		
PS-2(18)	7.5	460.7	597	37,003	1.1	68.1	2.50	170.2	350	1,300	PM	50.00	62.00	48.070	60.070	1.50	1.50				
19	8.1	468.8	643	37,646	1.2	69.3	2.50	173.2	600	350	720	62.00	60.00	59.447	57.820	1.87	1.50	0.80	194.1		
20	37.9	506.7	3,045	40,691	5.6	74.9	2.50	187.2	600	500	720	60.00	50.00	56.018	47.820	3.30	1.50	0.80	194.1		
MP-8(21)																					
22	16.3	16.3	1,332	1,332	2.5	2.5	3.00	7.4	100	600	PM	30.00	50.00	28.850	48.850	1.00	1.00			Branch sewer	
STP(29)	0.0	523.0	0	42,023	0.0	77.3	2.50	193.3	600	550	720	50.00	5.00	43.828	2.820	5.49	1.50	0.80	194.1		
MP-9(24)																					
MP-9(24)	4.0	4.0	630	630	1.2	1.2	3.00	3.5	150	550	110	3.00	3.00	1.770	-3.230	1.00	6.00	0.81	12.3	Branch sewer	
MP-10(25)																					
MP-10(25)	4.0	8.0	630	1,259	1.2	2.3	3.00	7.0	150	550	110	3.00	3.00	1.770	-3.230	1.00	6.00	0.81	12.3	Branch sewer	
MP-11(26)																					
MP-11(26)	7.0	15.0	1,102	2,361	2.0	4.3	3.00	13.0	200	700	165	3.00	3.00	1.220	-3.022	1.50	5.74	0.80	21.7	Branch sewer	
MP-11(26)																					
MP-11(26)	7.0	22.0	1,102	3,464	2.0	6.4	3.00	19.1	200	700	165	3.00	3.00	1.220	-3.022	1.50	5.74	0.80	21.7	Branch sewer	
MP-12(28)																					
MP-12(28)	7.0	7.0	1,102	1,102	2.0	2.0	3.00	6.1	150	550	110	3.00	3.00	1.770	-3.230	1.00	6.00	0.81	12.3	Branch sewer	
MP-12(28)																					
STP(29)	8.0	37.0	1,259	5,825	2.3	10.7	3.00	32.2	150	500	PM	3.00	5.00	1.270	3.270	1.50	1.50				



**(5) Flow Calculation Sheet for Ponda (Year of 2025)**

Node	Area (ha)		Population		Average Flow (lps)		Peak Factor	Peak Flow (lps)	Diameter (mm)	Length (m)	Gradient (1/X)	Ground level (m)		Invert level (m)		Covering (m)		Velocity at 80% depth (m/sec)	Flow Capacity at 80% depth (lps)	Remarks
	From	To	Increment	Cumulative	Increment	Cumulative						Increment	Cumulative	Upstream	Downstream	Upstream	Downstream			
<b>Left Bank Main</b>																				
1	2	56.6	4,703	4,703	9.7	9.7	3.00	29.1	250	300	220	109.90	102.80	107.077	100.970	2.49	1.50	0.81	34.0	
2	MP-I(3)	37.5	94.2	3,070	7,773	6.3	16.0	48.1	300	50	280	102.80	100.00	98.290	98.120	4.13	1.50	0.81	49.0	
3	4	1.7	95.9	148	7,921	0.3	16.3	49.0	200	250	PM	100.00	104.50	98.220	102.720	1.50	1.50	0.80		
4	5	1.3	97.2	139	8,060	0.3	16.6	49.9	350	100	350	104.50	103.00	101.965	101.070	2.11	1.50	0.80	66.2	
5	6	16.9	114.1	1,808	9,868	3.7	20.3	61.0	350	100	350	103.00	100.00	99.715	98.070	2.86	1.50	0.80	66.2	
6	7	7.8	121.9	835	10,703	1.7	22.1	66.2	400	100	410	100.00	99.50	97.890	97.520	1.63	1.50	0.81	87.3	
7	PS-I(8)	5.2	127.1	556	11,259	1.1	23.2	69.6	400	50	410	99.50	99.20	97.340	97.220	1.68	1.50	0.81	87.3	
8	9	0.0	127.1	0	11,259	0.0	23.2	69.6	250	450	PM	99.20	102.95	97.370	101.120	1.50	1.50			
9	10	1.7	128.8	138	11,397	0.3	23.5	70.5	400	300	410	102.95	102.00	100.957	100.020	1.51	1.50	0.81	87.3	
10	11	6.7	135.5	552	11,949	1.1	24.6	73.9	400	50	410	102.00	101.83	99.995	99.850	1.53	1.50	0.81	87.3	
11	12	16.8	152.4	1,381	13,330	2.8	27.5	82.5	400	100	410	101.83	100.98	99.570	99.000	1.78	1.50	0.81	87.3	
12	13	3.4	155.7	276	13,606	0.6	28.1	84.2	400	150	410	100.98	101.90	98.980	98.614	1.52	2.81	0.81		
13	14	1.7	157.4	138	13,745	0.3	28.3	85.0	400	200	410	101.90	101.90	98.594	98.106	2.83	3.31	0.81		
14	15	6.7	164.1	552	14,297	1.1	29.5	88.4	450	250	490	101.90	97.00	98.086	94.970	3.28	1.50	0.80	109.3	
15	STP(22)	0.0	164.1	0	14,297	0.0	29.5	88.4	450	250	490	97.00	96.00	94.872	93.970	1.60	1.50	0.80	109.3	
Branch	STP(22)	3.4	3.4	276	276	0.6	0.6													
<b>Right Bank Main</b>																				
16	17	25.2	25.2	3,377	3,377	7.0	7.0	20.9	250	200	220	101.53	101.53	99.700	98.791	1.50	2.41	0.81	34.0	
17	18	2.4	27.6	415	3,791	0.9	7.8	23.4	250	150	220	101.53	102.00	98.771	98.089	2.43	3.58	0.81	34.0	
18	19	1.2	28.7	207	3,999	0.4	8.2	24.7	250	100	220	102.00	103.30	98.069	97.614	3.60	5.36	0.81	34.0	
19	20	1.2	29.9	207	4,206	0.4	8.7	26.0	250	50	220	103.30	101.40	97.594	97.367	5.38	3.70	0.81	34.0	
20	21	3.6	33.5	622	4,828	1.3	10.0	29.9	250	100	220	101.40	96.50	97.347	94.670	3.72	1.50	0.81	34.0	
21	STP(22)	0.0	33.5	0	4,828	0.0	10.0	29.9	250	50	220	96.50	96.00	92.670	92.443	3.50	3.23	0.81	34.0	

**(6) Flow Calculation Sheet for Mapusa (Year of 2025)**

Node	Area (ha)		Population		Average Flow (lps)		Peak Factor	Peak Flow (lps)	Diameter (mm)	Length (m)	Gradient (1/x)	Ground level (m)		Invert level (m)		Covering (m)		Velocity at 80% depth (m/sec)	Flow Capacity at 80% depth (lps)	Remarks	
	From	To	Increment	Cumulative	Increment	Cumulative						Increment	Cumulative	Upstream	Downstream	Upstream	Downstream				Upstream
1																					
2		29.7	29.7	7,673	7,673	14.0	14.0	3.00	42.1	300	280	125.00	108.00	121.174	106.120	3.45	1.50	0.81	49.0		
3		38.3	68.0	11,918	19,591	21.8	35.8	3.00	107.4	450	490	108.00	103.00	105.265	100.970	2.21	1.50	0.80	109.3		
4		21.3	89.3	4,224	23,815	7.7	43.5	2.50	108.8	450	490	103.00	100.00	100.507	97.970	1.96	1.50	0.80	109.3		
5		16.5	105.8	4,674	28,489	8.5	52.0	2.50	130.1	500	560	100.00	98.50	97.729	96.420	1.69	1.50	0.80	135.4	Trenchless	
11		35.3	141.1	6,756	35,245	12.3	64.4	2.50	161.0	600	720	98.50	97.00	96.084	94.820	1.74	1.50	0.80	194.1	Trenchless	
MP-1(6)	7	5.8	5.8	739	739	1.4	1.4	3.00	4.1	75	PM	102.00	115.00	100.850	113.850	1.00	1.00			Branch Sewer	
7	8	46.1	51.9	5,910	6,649	10.8	12.1	3.00	36.4	300	280	115.00	110.00	112.811	108.120	1.81	1.50	0.81	49.0		
8	PS-1(9)	4.2	56.1	620	7,269	1.1	13.3	3.00	39.8	300	280	110.00	104.50	107.102	102.620	2.52	1.50	0.81	49.0		
PS-1(9)	10	61.3	117.4	11,468	18,737	21.0	34.2	3.00	102.7	300	PM	104.50	135.00	102.620	133.120	1.50	1.50				
10	11	17.0	134.4	2,822	21,559	5.2	39.4	2.50	98.5	450	490	135.00	97.00	130.358	94.970	4.11	1.50	0.80	109.3		
11	12	17.3	292.8	3,175	59,979	5.8	109.6	2.25	246.6	700	880	97.00	99.50	94.720	93.584	1.50	5.14	0.80	264.8		
12	13	0.0	292.8	0	59,979	0.0	109.6	2.25	246.6	700	880	99.50	98.50	93.564	93.280	5.16	4.44	0.80	264.8		
13	STP(19)	4.9	297.7	2,482	62,461	4.5	114.1	2.25	256.8	700	880	98.50	96.00	93.260	92.635	4.46	2.58	0.80	264.8		
MP-2(14)	15	3.2	3.2	1,655	1,655	3.0	3.0	3.00	9.1	100	PM	103.00	125.00	101.820	123.820	1.00	1.00			Branch Sewer	
15	16	0.0	3.2	0	1,655	0.0	3.0	3.00	9.1	150	110	125.00	122.50	123.770	121.270	1.00	1.00	0.81	12.3		
16	17	4.9	8.1	2,482	4,137	4.5	7.6	3.00	22.7	250	220	122.50	100.00	118.085	98.170	4.09	1.50	0.81	34.0		
17	18	0.0	8.1	0	4,137	0.0	7.6	3.00	22.7	250	220	100.00	100.00	98.150	94.514	1.52	5.16	0.81	34.0		
18	STP(19)	3.2	11.3	1,655	5,792	3.0	10.6	3.00	31.7	250	220	100.00	96.00	94.494	91.312	5.18	4.36	0.81	34.0		




**(7) Flow Calculation Sheet for South Coastal Belt (Year of 2025)**

Node		Area (ha)		Population		Average Flow (lps)		Peak Factor	Peak Flow (lps)	Length (m)	C-Length (m)	Gradient (1/x)	Ground level (m)		Invert level (m)		Covering (m9)		Velocity at 80% depth (m/sec)	Flow Capacity at 80% depth (lps)	Remarks		
From	To	Increment	Cumulative	Increment	Cumulative	Increment	Cumulative						Upstream	Downstream	Upstream	Downstream	Upstream	Downstream				Upstream	Downstream
1	2	5.1	5.1	200	200	0.9	0.9	3.00	2.8	300		110	3.00	3.00									
2	3	17.0	22.1	667	867	3.1	4.1	3.00	12.3	450		110	3.00	2.50									
3	MP-1(4)	17.0	39.1	667	1,533	3.1	7.2	3.00	21.7	500	500	165	2.50	2.00	0.720	-2.310	1.50	4.03	0.80	21.7		Branch Sewer	
MP-1(4)	5	9.8	48.9	384	1,918	1.8	9.1	3.00	27.2	300	800	PM	2.00	4.00	0.270	2.270	1.50	1.50					
5	6	26.3	75.2	1,031	2,949	4.9	13.9	3.00	41.8	500	1,300	280	4.00	4.00	2.120	0.334	1.50	3.29	0.81	49.0			
6	PS-1(10)	10.2	85.4	400	3,349	1.9	15.8	3.00	47.5	500	1,800	280	4.00	4.00	0.314	-1.472	3.31	5.09	0.81	49.0			
7	MP-2(8)	15.3	15.3	1,200	1,200	5.7	5.7	3.00	17.0	500	1,000	165	4.00	3.00	2.220	-0.810	1.50	3.53	0.80	21.7			
MP-2(8)	9	0.0	15.3	0	1,200	0.0	5.7	3.00	17.0	500	500	PM	3.00	4.00	1.270	2.270	1.50	1.50					
9	PS-1(10)	9.3	24.6	729	1,930	3.4	9.1	3.00	27.3	350		220	4.00	4.00	2.170	0.579	1.50	3.09	0.81	34.0			
PS-1(10)	STP(11)	0.0	110.0	0	5,279	0.0	24.9	3.00	74.8	500	2,300	410	4.00	3.00	2.020	0.800	1.50	1.72	0.81	87.3			


**(8) Flow Calculation Sheet for North Coastal Belt (Year of 2025)**

Node	Area (ha)		Population		Average Flow (lps)		Peak Factor	Peak Flow (lps)	C-Length (m)	C-Length (m)	Gradient (1/x)	Ground level (m)		Invert level (m)		Covering (m9)		Velocity at 80% depth (m/sec)	Flow Capacity at 80% depth (lps)	Remarks
	From	To	Increment	Cumulative	Increment	Cumulative						Increment	Cumulative	Upstream	Downstream	Upstream	Downstream			
<b>Candolim</b>																				
1	2	77.4		5,306	5,306	19.2	19.2	57.5	1,100	13,750	350	17.04	13.99	15.110	11.967	1.50	1.59	0.80	66.2	
2	PS-1(3)	40.5	117.9	2,775	8,081	10.0	29.2	87.6	2,500	31,250	490	13.99	9.53	11.846	7.500	1.61	1.50	0.80	109.3	
PS-1(3)	4	0.0	117.9	0	8,081	0.0	29.2	87.6	5,000	62,500	PM	9.53	17.06	7.700	15.230	1.50	1.50			
4	5	39.3	157.3	2,694	10,775	9.7	38.9	116.8	5,700	71,250	560	17.06	17.27	14.980	13.730	1.50	2.96	0.80	135.4	
5	6	35.7	193.0	2,449	13,224	8.8	47.8	143.3	6,100	76,250	720	17.27	16.50	13.630	13.074	2.96	2.75	0.80	194.1	
<b>Calangute</b>																				
6	8	89.8	282.8	5,868	19,092	18.3	66.1	198.3	7,000	87,500	880	16.50	16.36	12.974	11.951	2.75	3.63	0.80	564.7	
7	8	35.9	35.9	2,347	2,347	7.3	7.3	22.0	700	8,750	220	19.41	16.36	17.580	14.398	1.50	1.63	0.81	34.0	
8	PS-2(9)	33.5	352.3	2,191	23,631	6.8	80.2	200.6	7,700	96,250	880	16.36	13.41	11.925	11.130	3.66	1.50	0.80	264.8	
PS-2(9)	10	28.7	381.0	1,878	25,509	5.9	86.1	215.3	8,700	102,500	PM	13.41	19.00	11.430	17.020	1.50	1.50			
10	13	67.1	448.1	4,382	29,890	13.7	99.8	249.4	9,100	113,750	880	19.00	16.30	16.534	14.020	1.69	1.50	0.80	264.8	
11	MP-1(12)	76.6	76.6	5,008	5,008	15.6	15.6	46.9	1,300	16,250	280	17.63	6.89	15.281	5.010	1.97	1.50	0.81	49.0	
MP-1(12)	13	0.0	76.6	0	5,008	0.0	15.6	46.9	2,500	31,250	PM	6.89	16.30	5.110	14.520	1.50	1.50			
13	14	68.3	593.0	4,460	39,358	13.9	129.3	323.3	10,300	128,750	1,050	16.30	8.27	13.346	5.890	2.07	1.50	0.80	346.1	
14	STR(15)	0.0	593.0	0	39,358	0.0	129.3	323.3	10,900	136,250	1,050	8.27	7.00	5.774	4.620	1.62	1.50	0.80	346.1	


Appendix M63.2 Longitudinal Profile of Trunk Sewer (Year of 2025) (1) Panaji Surrounding (1/2)




(1) Panaji Surrounding (2/2)



(2) St. Cruz (1/1)




(3) Poryorim (1/2)






(4) Margao (1/1)







(5) Ponda (1/1)




(6) Mapusa (1/2)




(6) Mapusa (2/2)




(7) South Coastal Belt (1/1)



(8) North Coastal Belt (1/2)



(8) North Coastal Belt (2/2)



### **Appendix M63.3 Capacity Calculation of Sewerage Treatment Facilities**

- (1) Panaji**
- (2) St. Cruz**
- (3) Porvorim**
- (4) Ponda**
- (5) Colva (South Coastal Belt)**

See Volume V Appendix for Chapter 5 for the F/S areas such as Margao, Mapusa, North Coastal Belt.

## (1) Panaji

### CAPACITY CALCULATION OF SEWAGE TREATMENT FACILITIES

#### 1 BASIC CONDITIONS

##### 1-1 Basic Items

- (1) Name : **Panaji (Tonca) Sewage Treatment Plant**
- (2) Land Area : Approximately 30,000 m<sup>2</sup>
- (3) Elevation : + 3.00 m
- (4) Inlet Pipe Level : - m
- (5) Pipe Diameter : - mm
- (6) Land Use : Exclusively for Sewage Treatment Plant
- (7) Collection System : Combined System • Separate System
- (8) Treatment Method :
- Sewage Treatment : Pre-treatment + SBR Tank + Sand Filtration (future) + Disinfection Tank
- Sludge Treatment : Sludge Thickening Tank + Sludge Digestion Tank + Dewatering (Drying Beds as stand-by)
- (9) Effluent Point : Mandovi river
- (10) Effluent Point Water Level : High Level = + 2.50m
- (11) Target Year : 2025 Year

##### 1-2 Design Population and Area

- Design Population : 56,600 Persons (Residents)
- Design Area : 943 ha Panaji City, Taleigao, Dona Paula and Caranzalem

##### 1-3 Design Sewage Flow

Item	m <sup>3</sup> /day	m <sup>3</sup> /hr	m <sup>3</sup> /min	m <sup>3</sup> /sec	Remarks
Daily Average	21,400	891.7	14.86	0.248	
Peak Flow	48,150	2,006.3	33.44	0.557	Peak factor = 2.25


##### 1-4 Design Sewage Quality

Item	Influent	T.R.R	Effluent	Remarks
	(mg/L)	(%)	(mg/L)	
BOD	210	86	30	Effluent Quality Regulation = 30 mg/l
SS	180	72	50	Effluent Quality Regulation = 100 mg/l

T.R.R. : Total Removal Ratio



1-5 Flow Chart (SBR Method)



### 1-6 Design Criteria for SBR Method

Items	Unit	Figure *1	Figure *2	Adoption
<b>1-6-1 Grit Chamber</b>				
(1) Water surface load	m <sup>3</sup> /m <sup>2</sup> /sec	1,800	2,160	2,160
(2) Average velocity	m/sec	0.3	0.15 - 0.30	0.3
<b>1-6-2 Wet Well with Pump Facilities</b>				
(1) Pump inflow velocity	m/sec	1.5 - 3.0	-	1.5 - 3.0
(2) Retention time in wet well	min	-	> 5.0	9.0
<b>1-6-3 SBR Tank</b>				
(1) BOD-SS load	kgBOD/kgSS·day	0.2 - 0.4	-	0.3
(2) MLSS concentration	mg/L	1,500 - 2,000	-	1,750
(3) Cycle	cycle/day	3 - 4	-	4
(4) Hydraulic retention time	hour	12 - 24	-	12.0
(5) Water depth	m	4 - 6	-	4.0
(6) Pull-out ratio	1/P	2 - 4	-	3
<b>1-6-4 Disinfection Tank</b>				
(1) Retention time	min	15.0	-	15.0
(2) Dosage	mg/L	2 - 8	-	3.0
<b>1-6-5 Sludge Thickening Tank</b>				
(1) Sludge surface load	kg/m <sup>2</sup> /day	60 - 90	25 - 30	30.0
(2) Depth	m	4.0	3.0	3.0
<b>1-6-6 Sludge Digestion Tank</b>				
(1) Solids retention time	days	15.0 - 20.0	14.0	14.0
(2) Operating temperature	°C	-	30.0	30.0
(3) Depth	m	> 7.5	6.0 - 12.0	8.0
(4) Digestion rate	%	35.0	-	35.0
<b>1-6-7 Sludge Dewatering</b>				
(1) Operation time	hr/day	-	-	8.0
<b>1-6-8 Sludge Drying Bed</b>				
(1) Retention time	day	10 - 15	< 2 weeks	10
(2) Depth of sludge bed	m	0.20 - 0.30	max 0.30	0.3
<b>1-6-9 Sand Filtration (future)</b>				
(1) Filtration rate	m/day	max 300	-	200

\*1: Design Criteria in Japanese standard and "Wastewater Engineering" by Metcalf & Eddy

\*2: Design Criteria in India named "Manual on Sewerage and Sewage Treatment"



## 2 CAPACITY CALCULATION

### 2-1 Wet Well with Pump Equipment

Item	Sign	Unit	Calculation	Result
<b>2-1-1 Wet Well</b>				
Design sewage flow	Q1	m <sup>3</sup> /day	Peak Flow	48,150
	Q2	m <sup>3</sup> /min	Peak Flow	33.44
Basin number	BN	basin		1
Retention time	RT	min		9.0
Required volume	RV	m <sup>3</sup>	Q2×RT	300.9
Depth	H	m		5.0
Required area	RA	m <sup>2</sup>	RV/H	60.19
Well diameter	D1	m	$(4 \times RA / 3.14)^{0.5}$	8.8
Diameter of existing well	D2	m		15.0
Area of existing well	A	m <sup>2</sup>	$D2^2 \times 3.14 / 4$	176.6
Area of existing well = 176.6 m <sup>2</sup> > Required area = 60.19 m <sup>2</sup> Therefore, the existing wet well is useful against the design flow (= 48,150 m <sup>3</sup> /day, peak flow)				
<b>2-1-2 Pump Equipment</b>				
Design sewage flow	Q1	m <sup>3</sup> /day	Peak flow	48,150
	Q2	m <sup>3</sup> /min	Peak flow	33.44
Specification of the existing pump equipment				
150mm × 261.0m <sup>3</sup> /hr = 4.35m <sup>3</sup> /min × 16.0m × 22kw × 2units				
200mm × 586.0m <sup>3</sup> /hr = 9.77m <sup>3</sup> /min × 16.0m × 55kw × 3(1)units				
Pump discharging flow	DF1	m <sup>3</sup> /min/unit		4.35
	DF2	m <sup>3</sup> /min/unit		9.77
Pump discharging flow total	DFT	m <sup>3</sup> /min	(DF1×2)+(DF2×2)	28.24
Discharging flow of existing pump = 28.24m <sup>3</sup> /min < Design flow = 33.44m <sup>3</sup> /min. Required additional discharging capacity = 33.44 - 28.24 = 5.20 m <sup>3</sup> /min				
Design sewage flow	Q3	m <sup>3</sup> /min	Q2-DFT	5.20
Pump unit number	UN	unit		1
Pump discharging flow	DF3	m <sup>3</sup> /min/unit	=Q3	5.20
Pump inflow velocity	PV	m/sec		1.5 - 3.0
Required pump diameter	D3-1	mm	$146 \times (DF1 / 3.0)^{0.5}$	192
	D3-2	mm	$146 \times (DF1 / 1.5)^{0.5}$	272
	D3	mm	<i>Therefore</i>	200
Pump total head	H	m		16.0
Pump efficiency	PE	-		0.60
Axis power	AP	kw	$0.163 \times DF3 \times H / PE$	22.59
Motor allowance	MA	-		0.15
Pump power	P	kw	$AP1 \times (1 + MA)$	25.98
		kw	<i>Therefore</i>	26.0
<b>Pump Specification (New Facility)</b>		200 mmdia × 5.20 m <sup>3</sup> /min × 16.0 m × 26.0 kW × 1 unit		

### 2-2 Screen and Grit Chamber

Item	Sign	Unit	Calculation	Result
<b>2-2-1 Grit Chamber</b>				
Type	-	-	Parallel flow type	
Design sewage flow	Q1	m <sup>3</sup> /day	Peak flow	48,150
	Q2	m <sup>3</sup> /sec	Peak flow	0.557
Water surface load	SL	m <sup>3</sup> /m <sup>2</sup> /day		2,160

Required surface area	RA	m <sup>2</sup>	Q1/SL	22.3
Number of existing chamber	BN	basin		1
Width of existing chamber	W	m		4.80
Length of existing chamber	L	m		4.80
Surface area of existing	A	m <sup>2</sup>	W×L	23.0
Area of existing grit chamber = 23.0 m <sup>2</sup> > Required area = 22.3 m <sup>2</sup> Therefore, the existing grit chamber is useful against the design flow (= 48,150 m <sup>3</sup> /day, peak flow)				
<b>2-2-2 Fine Screen</b>				
Type	-	-	One rake type intermittent rake-up	
Set number	SSN	set	1 set = Manual screen	1
Screen opening	-	mm	10 to 20	20
The existing screens are useful for the design flow (= 45,700 m <sup>3</sup> /day, peak flow)				
Unit removed screenings	RS	m <sup>3</sup> /1,000m <sup>3</sup>		0.010
Design sewage flow	Q	m <sup>3</sup> /day	Daily average	21,400
Volume of screenings	VS	m <sup>3</sup> /day	Q×RS/1,000	0.214
				↓
				<b>Carry out</b>

### 2-3 SBR Tank

Item	Sign	Unit	Calculation	Result
Type			Sequencing Batch Aeration Tank	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	21,400
	Q2	m <sup>3</sup> /hr	Daily average	891.7
BOD-SS load	BS	kgBOD/kgSS·day		0.30
Inlet BOD	BD	mg/l		210
MLSS concentration	MLSS	mg/l		1,750
Cycle	CY	cycle/day		4
Pull-out ratio	PR	-		3
Aeration time	AT	hr/cycle	24×BD/(BS×PR×MLSS)	3.2
Water depth	H	m		4.0
Clearance depth of tank	H1	m		0.5
Settling velocity	SV	m/hr		3.0
Settling time	ST	hr/cycle	(H×(1/PR)+H1)/SV	0.61
Aeration time ratio	e	-	CY×AT/24	0.53
Required volume	RV	m <sup>3</sup>	Q1×BD/(e×MLSS×BS)	16,050
Width of existing tank	W	m		22.0
Length of existing tank	L	m		40.0
Basin number	EBN	basin		2
Volume of existing tank	EV	m <sup>3</sup>	W×L×H×EBN	7,040
Required additional tank volume = 16,050 - 7,040 = 9,010 m <sup>3</sup>				
Required additional tank	RA	m <sup>3</sup>	RV-EV	9,010
Basin number of new tank	NBN	basin		2
Water depth of new tank	NH	m		4.0
Width of new tank	NW	m		24.0
Length of new tank	NL	m	RA/(NH×NW×NBN)	46.9
	L2	m	<i>Therefore</i>	47.0
<b>Dimension (width)</b>	W	m	<b>New Facility</b>	<b>24.0</b>
<b>(Depth)</b>	H	m		<b>4.0</b>
<b>(Length)</b>	L2	m		<b>47.0</b>
<b>(Basin)</b>	BN	basin		<b>2</b>

#### 2-4 Sand Filtration Tank (future)

Item	Sign	Unit	Calculation	Result
Type	-	-	Gravity Upflow Filter Type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	21,400
	Q2	m <sup>3</sup> /sec	Daily average	0.248
Filtration rate	FR	m/day		200.0
Required surface area	RA	m <sup>2</sup>	Q1/FR	107.0
Basin number	BN	basin		4
Width	W	m		5.0
Length	L1	m	RA/(W×BN)	5.35
	L2	m	<i>Therefore</i>	5.5
Dimension	(Width)	W	New Facility	5.0
	(Length)	L		5.5
	(Basin)	N		basin

#### 2-5 Disinfection Tank

Item	Sign	Unit	Calculation	Result
Chemical type	-	-	Chlorination Type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	21,400
	Q2	m <sup>3</sup> /min	Daily average	14.86
Retention time	RT	min		15.0
Required volume	RV	m <sup>3</sup>	Q2×RT	222.9
Width of existing tank	W	m		2.6
Length of existing tank	L	m		9.5
Depth of existing tank	H	m		1.0
Pass number	PN	pass		9
Volume of existing tank	EV	m <sup>3</sup>	W×L×H×PN	222.3
Volume of existing tank = 222.3 m <sup>3</sup> ≈ Required volume = 222.9 m <sup>3</sup>				
Therefore, the existing disinfection tank is useful against the design flow (= 21,400 m <sup>3</sup> /day, daily average)				

#### 2-6 Sludge Thickening Tank

Item	Sign	Unit	Calculation	Result
Type	-	-	Radial Flow Circular Type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	21,400
	Q2	m <sup>3</sup> /hr	Daily average	891.7
Basin number	BN	basin		2
Influent SS quality	ISQ	mg/L		180
Effluent SS quality	ESQ	mg/L		50
Generated sludge	GS	kg/day	Q1×(ISQ-ESQ)×10 <sup>-3</sup>	2,782
Sludge surface load	SL	kg/m <sup>2</sup> /day		30.0
Required surface area	RA	m <sup>2</sup>	GS/SL	92.7
Required tank diameter	D1	m	(RA×4/(3.14×BN)) <sup>0.5</sup>	7.7
	D2	m	<i>Therefore</i>	8.0
Water depth	H	m		3.0
Dimension	(Diameter)	D	New Facility	8.0
	(Depth)	H		3.0
	(Basin)	BN		basin

### 2-7 Sludge Digestion Tank

Item	Sign	Unit	Calculation	Result
Type	-	-	Anaerobic Tank	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	21,400
	Q2	m <sup>3</sup> /hr	Daily average	891.7
Generated sludge weight	GS1	kg/day	refer to 2-6	2,782
	GS2	ton/day	GS1/1000	2.78
Sludge moisture rate	MR	%	Thickened sludge	97.0
Sludge volume	SV	m <sup>3</sup> /day	GS2×100/(100-MR)	92.7
Solid retention time	T	day		14.0
Basin number	BN	basin		2
Required tank volume	RV1	m <sup>3</sup> /basin	SV×T/BN	649.1
Water depth	H	m		8.0
Required surface area	RA	m <sup>2</sup> /basin	RV1/H	81.1
Required tank diameter	D1	m	(RA×4/3.14) <sup>0.5</sup>	10.2
	D2	m	<i>Therefore</i>	10.5
<b>Dimension (Diameter)</b>	D	m	<b>New Facility</b>	<b>10.5</b>
<b>(Depth)</b>	H	m		<b>8.0</b>
<b>(Basin)</b>	BN	basin		<b>2</b>

### 2-8 Digestion Gas Tank

Item	Sign	Unit	Calculation	Result
Generated sludge weight	GS	kg/day	refer to 2-7	2,782
Organic matter ratio	OM	%		70
Generation ratio of gas	GR	%		35
Retention time	RT	day		1
Required tank volume	RV	m <sup>3</sup>	GS×OM×GR×RT/10 <sup>4</sup>	341
Depth of tank	H	m		5.0
Basin number	BN	basin		1
Required tank diameter	D1	m	2×(RV/(3.14×H×BN)) <sup>0.5</sup>	9.3
	D2			9.5
<b>Dimension (Diameter)</b>	D	m	<b>New Facility</b>	<b>9.5</b>
<b>(Depth)</b>	H	m		<b>5.0</b>
<b>(Number)</b>	BN	basin		<b>1</b>

### 2-9 Sludge Dewatering Equipment

Item	Sign	Unit	Calculation	Result
Type	-	-	Centrifugal type	
Digestion rate	DR	%		35.0
Thickened sludge weight	GSW	ton/day	refer to 2-7	2.78
Digested sludge weight	DSW	ton/day	$GSW \times (100 - DR) / 100$	1.81
Sludge moisture rate	MR	%	digested sludge	97.0
Generated sludge volume	GSV	m <sup>3</sup> /day	$DSW \times 100 / (100 - MR)$	60.3
Existing capacity	EC	m <sup>3</sup> /hr		20.0
Existing unit number	UN	unit	including stand-by (=1 unit)	2
Operation time	OT	hr/day		8.0
Required capacity	RC	m <sup>3</sup> /hr	$GSV / ((UN - 1) \times OT)$	7.5
Treatment capacity of existing dewatering = 20.0 m <sup>3</sup> /hr > Required capacity = 7.5 m <sup>3</sup>				
Therefore, the existing equipment is useful against the design flow (= 21,400 m <sup>3</sup> /day, daily average)				
Digested sludge weight	DSW	ton/day		1.81
Sludge moisture ratio	DM	%	dewatered sludge	80.0
Dewatered sludge volume	DV	m <sup>3</sup> /day	$DSW \times 100 / (100 - DM)$	<b>9.0</b>
				↓
				<b>Carry out</b>

### 2-9 Sludge Drying Bed

Item	Sign	Unit	Calculation	Result
Digested sludge volume	DV	m <sup>3</sup> /day	Refer to the above 2-8	60.3
Retention time	RT	day		10.0
Sludge thickness in bed	H	m		0.3
Required area	RA	m <sup>2</sup>	$DV \times RT / H$	2,009.2
Width of existing bed	W	m		7.5
Length of existing bed	L	m		15.0
Number of existing bed	BN	basin		18
Area of existing facility	AE	m <sup>2</sup>	$W \times L \times BN$	2,025.0
Existing drying bed area = 2,025 m <sup>2</sup> > Required area = 2,009.2 m <sup>2</sup>				
Therefore, the existing facility will be used for an additional sewage flow.				



### 3 SUMMARY OF STP FACILITIES

facility	Existing Facility	Additional Facility
Wet well	15.0 mdia. × 5.0 mH × 1 basin	-
Pump equipment	150mm × 261.0m <sup>3</sup> /hr = 4.35m <sup>3</sup> /min × 16.0m × 22kw × 2units 200mm × 586.0m <sup>3</sup> /hr = 9.77m <sup>3</sup> /min × 16.0m × 55kw × 3(1)units	200 mm dia × 5.20 m <sup>3</sup> /min × 16.0 m × 26.0 kW × 1 unit
Grit chamber	4.8 mW × 4.8 mL × 1 basin	-
Mechanical screen	Type : One rake type intermittent rake-up	-
	Mechanical screen × 1 unit with 20mm bar opening	-
SBR tank	22.0 mW × 40.0 mL × 4.0 mH × 2 basin	24.0 mW × 47.0 mL × 4.0 mH × 2 basin
Sand Filtration (Future Plan)	-	Type : Gravity upflow filter type
Disinfection tank	Type : Hypochlorite type	5.0 mW × 5.5 mL × 4 basin
	2.6 mW × 9.5 mL × 1.0 mH × 9 pass	-
Sludge thickening tank	-	Type : Radial flow circular type
	-	8.0 mdia. × 3.0 mH × 2 basin
Sludge digestion tank	-	Type : Anaerobic digestion
	-	10.5 mdia. × 8.0 mH × 2 basin
Digestion gas tank	-	9.5 mdia. × 5.0 mH × 1 basin
Sludge dewatering	Centrifugal type 20.0 m <sup>3</sup> /hr × 2 (1) unit	-
Sludge drying bed	7.5 mW × 15.0 mL × 0.3 mH × 18 basin	-

## (2) St. Cruz

### CAPACITY CALCULATION OF SEWAGE TREATMENT FACILITIES

#### 1 BASIC CONDITIONS

##### 1-1 Basic Items

- (1) Name : **St. Cruz Sewage Treatment Plant**
- (2) Land Area : Approximately  $m^2$
- (3) Elevation : + m
- (4) Inlet Pipe Level : - m
- (5) Pipe Diameter : - mm
- (6) Land Use :
- (7) Collection System : Combined System • Separate System
- (8) Treatment Method :
- Sewage Treatment : Pre-treatment + OD + Final Sedimentation  
+ Sand Filtration (future) + Disinfection Tank
- Sludge Treatment : Sludge Thickening + Sludge Digestion  
+ Dewatering
- (9) Effluent Point :
- (10) Effluent Point Water Level : + m
- (11) Target Year : 2025 Year

##### 1-2 Design Population and Area

- Design Population : 16,900 Persons (Residents)
- Design Area : 124 ha

##### 1-3 Design Sewage Flow


Item	$m^3/day$	$m^3/hr$	$m^3/min$	$m^3/sec$	Remarks
Daily Average	2,500	104.2	1.74	0.029	
Peak Flow	7,500	312.5	5.21	0.087	Peak factor = 3.00

##### 1-4 Design Sewage Quality

Item	Influent	T.R.R	Effluent	Remarks
	(mg/L)	(%)	(mg/L)	
BOD	300	90	30	Effluent Quality Regulation = 30 mg/l
SS	250	80	50	Effluent Quality Regulation = 100 mg/l

T.R.R. : Total Removal Ratio

1-5 Flow Chart (OD Method)



## 2 Design Criteria for STP

Items	Unit	CPHEEO	Japanese Standards	Metcalf&Eddy	Adoption
2.1 Screen and Grit Chamber					
(1) Screen	mm	Less than 20	-	15	20
Openings of screen bars					
(2) Grit Chamber	m <sup>3</sup> /m <sup>2</sup> /day	2,160	-	1,382 - 1,814	2,160
Water surface loading	m/sec	0.15 - 0.30	-	0.24 - 0.39	0.3
Horizontal velocity					
2.2 Pump Equipment					
Pump inflow velocity	m/sec	-	-	1.5 - 3.0	1.5 - 3.0
Retention time in wet well	min	> 5.0	-	-	9.0
2.3 Oxidation Ditch Reactor Tank					
Hydraulic retention time	hr	12 - 24	24 - 48	8.0 - 36.0	15.0
MLSS concentration	mg/l	3,000 - 5,000	3,000 - 4,000	3,000 - 6,000	3,500
BOD-SS load	kgBOD/kgSS/day	0.10 - 0.18	0.03 - 0.05	0.05 - 0.30	0.15
Depth	m	-	1.0 - 3.0	-	3.0
Width	m	-	2.0 - 6.0	-	4.0
2.4 Final Sedimentation Tank					
Overflow rate	m <sup>3</sup> /m <sup>2</sup> /day	8.0 - 15.0	8.0 - 12.0	16.3 - 32.6	15.0
Depth	m	3.5 - 4.5	3.0 - 4.0	3.7 -	4.0
2.5 Sand Filtration (future)					
Filtration rate	m/day	-	max. 300	176	200.0
2.6 Disinfection Tank					
Detention time	min	-	15.0	-	15.0
2.7 Sludge Thickening Tank					
Solid surface load	kg/m <sup>2</sup> /day	25 - 30	60 - 90	12.2 - 34.2	30.0
Depth	m	3.0	4.0	-	3.0
2.8 Sludge Digestion Tank					
Solids retention time	days	14.0	20.0	15.0 - 20.0	14.0
Operating temperature	°C	30.0	30.0	-	30.0
Digestion rate	%	-	35.0	-	35.0
Depth	m	6.0 - 12.0	> 4.0	> 7.5	6.0
2.9 Sludge Dewatering Equipment					
Operation time	hr/day	-	-	-	8.0

CPHEEO: Central Public Health and Environmental Engineering Organization, Ministry of Urban Development, New Delhi, 1993

### 3 CAPACITY CALCULATION

#### 3-1 Wet Well with Pump Equipment

Item	Sign	Unit	Calculation	Result
<b>3-1-1 Wet Well</b>				
Design sewage flow	Q1	m <sup>3</sup> /day	Peak Flow	7,500
	Q2	m <sup>3</sup> /min	Peak Flow	5.21
Basin number	BN	basin		1
Retention time	RT	min		9.0
Required volume	RV	m <sup>3</sup>	Q2×RT	46.9
Depth	H	m		2.5
Required area	RA	m <sup>2</sup>	RV/RA	18.75
Width	W	m		4.0
Length	L1	m	RA/W	4.69
	L2	m	Therefore	4.7
<b>Dimension (Width)</b>	W	m		<b>4.0</b>
<b>(Length)</b>	L	m		<b>4.7</b>
<b>(Depth)</b>	H	m		<b>2.5</b>
<b>(Basin)</b>	N	basin		<b>1</b>
<b>3-1-2 Pump Equipment</b>				
Design sewage flow	Q1	m <sup>3</sup> /day	Peak flow	7,500
	Q2	m <sup>3</sup> /min	Peak flow	5.21
Pump unit number	UN	unit	including stand-by (=1 unit)	4
Pump discharging flow	DF1	m <sup>3</sup> /min/unit	Q2/4	1.30
	DF2	m <sup>3</sup> /min/unit	Q2/2	2.60
Pump inflow velocity	PV	m/sec		1.5 - 3.0
Required pump diameter	D1-1	mm	$146 \times (DF1/3.0)^{0.5}$	96
	D1-2	mm	$146 \times (DF1/1.5)^{0.5}$	136
	D1	mm	Therefore	100
	D2-1	mm	$146 \times (DF2/3.0)^{0.5}$	136
	D2-2	mm	$146 \times (DF2/1.5)^{0.5}$	192
	D2	mm	Therefore	150
Pump total head	H	m	assumption	15.0
Pump efficiency	PE	-		0.60
Axis power	AP1	kw	$0.163 \times DF1 \times H/PE$	5.31
	AP2	kw	$0.163 \times DF2 \times H/PE$	10.61
Motor allowance	MA	-		0.15
Pump power	P1	kw	$AP1 \times (1+MA)$	6.10
		kw	Therefore	7.0
	P2	kw	$AP2 \times (1+MA)$	12.20
		kw	Therefore	13.0
<b>Pump Specification</b>	100 mmdia × 1.30 m <sup>3</sup> /min × 15 m × 7.0 kW × 2 units 150 mmdia × 2.60 m <sup>3</sup> /min × 15 m × 13.0 kW × 2(1) units			

#### 3-2 Screen and Grit Chamber

Item	Sign	Unit	Calculation	Result
<b>3-2-1 Grit Chamber</b>				
Type	-	-	Parallel flow type	
Design sewage flow	Q1	m <sup>3</sup> /day	Peak flow	7,500
	Q2	m <sup>3</sup> /sec	Peak flow	0.087
Water surface load	SL	m <sup>3</sup> /m <sup>2</sup> /day		2,160

Item	Sign	Unit	Calculation	Result
Required surface area	RA	m <sup>2</sup>	Q1/SL	3.5
Basin number	BN	basin		2
Average velocity	V	m/sec		0.3
Water depth	H	m		0.3
Width	W1	m	Q2/(V×H×BN)	0.48
	W2	m	<i>Therefore</i>	0.6
Length	L1	m	RA/(W2×BN)	2.89
	L2	m	<i>Therefore</i>	2.9
<b>Dimension (Width)</b>	W	m	W2	<b>0.6</b>
<b>(Length)</b>	L	m	L2	<b>2.9</b>
<b>(Depth)</b>	H	m	H	<b>0.3</b>
<b>(Basin)</b>	N	basin		<b>2</b>
<b>3-2-2 Fine Screen</b>				
Type	-	-	One rake type intermittent rake-up	
Set number	SSN	set	1 set = Manual screen	1
Screen opening	-	mm	10 to 20	20
Unit removed screenings	RS	m <sup>3</sup> /1,000m <sup>3</sup>		0.010
Design sewage flow	Q	m <sup>3</sup> /day	Daily average	2,500
Volume of screenings	VS	m <sup>3</sup> /day	Q×RS/1,000	0.025
				↓
				<b>Carry out</b>

### 3-3 Oxidation Ditch Reactor Tank

Item	Sign	Unit	Calculation	Result
Type			Endless ditch flow type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	2,500
	Q2	m <sup>3</sup> /hr	Daily average	104.2
BOD-SS load	BS	kgBOD/kgSS·day		0.15
Inlet BOD	BD	mg/l		300
MLSS concentration	MLSS	mg/l		3,500
Required volume -1	RV1	m <sup>3</sup>	BD×Q1/(MLSS×BS)	1,429
Hydraulic retention time	HT	hr		15.0
	RV2	m <sup>3</sup>	Q2×HT	1,563
	RV	m <sup>3</sup>	RV2 > RV1 <i>Therefore</i>	1,600
Basin number	BN	basin		2
Water depth	H	m		3.0
Width	W	m		4.0
Length	L1	m	RV/(H×W×BN)	66.7
	L2	m	<i>Therefore</i>	67.0
<b>Dimension (width)</b>	W	m		<b>4.0</b>
<b>(Depth)</b>	H	m		<b>3.0</b>
<b>(Length)</b>	L2	m		<b>67.0</b>
<b>(Basin)</b>	BN	basin		<b>2</b>

### 3-4 Final Sedimentation Tank

Item	Sign	Unit	Calculation	Result
Type			Radial Flow Circular Type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	2,500
	Q2	m <sup>3</sup> /hr	Daily average	104.2

Item	Sign	Unit	Calculation	Result
Required surface area	RA	m <sup>2</sup>	Q1/SL	3.5
Basin number	BN	basin		2
Average velocity	V	m/sec		0.3
Water depth	H	m		0.3
Width	W1	m	Q2/(V×H×BN)	0.48
	W2	m	<i>Therefore</i>	0.6
Length	L1	m	RA/(W2×BN)	2.89
	L2	m	<i>Therefore</i>	2.9
<b>Dimension (Width)</b>	W	m	W2	<b>0.6</b>
<b>(Length)</b>	L	m	L2	<b>2.9</b>
<b>(Depth)</b>	H	m	H	<b>0.3</b>
<b>(Basin)</b>	N	basin		<b>2</b>
<b>3-2-2 Fine Screen</b>				
Type	-	-	One rake type intermittent rake-up	
Set number	SSN	set	1 set = Manual screen	1
Screen opening	-	mm	10 to 20	20
Unit removed screenings	RS	m <sup>3</sup> /1,000m <sup>3</sup>		0.010
Design sewage flow	Q	m <sup>3</sup> /day	Daily average	2,500
Volume of screenings	VS	m <sup>3</sup> /day	Q×RS/1,000	0.025
				↓
				<b>Carry out</b>

### 3-3 Oxidation Ditch Reactor Tank

Item	Sign	Unit	Calculation	Result
Type			Endless ditch flow type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	2,500
	Q2	m <sup>3</sup> /hr	Daily average	104.2
BOD-SS load	BS	kgBOD/kgSS·day		0.15
Inlet BOD	BD	mg/l		300
MLSS concentration	MLSS	mg/l		3,500
Required volume -1	RV1	m <sup>3</sup>	BD×Q1/(MLSS×BS)	1,429
Hydraulic retention time	HT	hr		15.0
	RV2	m <sup>3</sup>	Q2×HT	1,563
	RV	m <sup>3</sup>	RV2 > RV1 <i>Therefore</i>	1,600
Basin number	BN	basin		2
Water depth	H	m		3.0
Width	W	m		4.0
Length	L1	m	RV/(H×W×BN)	66.7
	L2	m	<i>Therefore</i>	67.0
<b>Dimension (width)</b>	W	m		<b>4.0</b>
<b>(Depth)</b>	H	m		<b>3.0</b>
<b>(Length)</b>	L2	m		<b>67.0</b>
<b>(Basin)</b>	BN	basin		<b>2</b>

### 3-4 Final Sedimentation Tank

Item	Sign	Unit	Calculation	Result
Type			Radial Flow Circular Type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	2,500
	Q2	m <sup>3</sup> /hr	Daily average	104.2

Item	Sign	Unit	Calculation	Result
Overflow rate	OR	m <sup>3</sup> /m <sup>2</sup> /day		15.0
Required area	RA	m <sup>2</sup>	Q1/OR	166.7
Basin number	BN	basin		2
Required tank diameter	D1	m	$(RA \times 4 / (3.14 \times BN))^{0.5}$	10.3
	D2	m	<i>Therefore</i>	10.5
Water depth	H	m		4.0
<b>Dimension (Diameter)</b>	W	m		<b>10.5</b>
<b>(Depth)</b>	H	m		<b>4.0</b>
<b>(Basin)</b>	BN	basin		<b>2</b>

### 3-5 Sand Filtration Tank (future)

Item	Sign	Unit	Calculation	Result
Type	-	-	Gravity Upflow Filter Type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	2,500
	Q2	m <sup>3</sup> /sec	Daily average	0.029
Filtration rate	FR	m/day		200.0
Required surface area	RA	m <sup>2</sup>	Q1/FR	12.5
Basin number	BN	basin		2
Width	W	m		3.0
Length	L1	m	RA/(W×BN)	2.08
	L2	m	<i>Therefore</i>	2.5
<b>Dimension (Width)</b>	W	m	W2	<b>3.0</b>
<b>(Length)</b>	L	m	L2	<b>2.5</b>
<b>(Basin)</b>	N	basin		<b>2</b>

### 3-6 Disinfection Tank

Item	Sign	Unit	Calculation	Result
Chemical type	-	-	Chlorination Type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	2,500
	Q2	m <sup>3</sup> /min	Daily average	1.74
Retention time	RT	min		15.0
Required volume	RV	m <sup>3</sup>	Q2×RT	26.0
Width	W	m		1.0
Water depth	H	m		1.0
Pass number	N	pass		6
Length	L1	m	RV/(W×H×N)	4.3
	L2	m	<i>Therefore</i>	4.5
<b>Dimension (Width)</b>	W	m		<b>1.0</b>
<b>(Length)</b>	L	m	L2	<b>4.5</b>
<b>(Depth)</b>	H	m		<b>1.0</b>
<b>(Pass Number)</b>	N	pass		<b>6</b>

### 3-7 Sludge Thickening Tank

Item	Sign	Unit	Calculation	Result
Type	-	-	Radial Flow Circular Type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	2,500
	Q2	m <sup>3</sup> /hr	Daily average	104.2
Basin number	BN	basin		2
Influent SS quality	ISQ	mg/L		250



Item	Sign	Unit	Calculation	Result
Effluent SS quality	ESQ	mg/L		50
Generated sludge	GS	kg/day	$Q1 \times (ISQ - ESQ) \times 10^{-3}$	500
Sludge surface load	SL	kg/m <sup>2</sup> /day		30.0
Required surface area	RA	m <sup>2</sup>	GS/SL	16.7
Required tank diameter	D1	m	$(RA \times 4 / (3.14 \times BN))^{0.5}$	3.3
	D2	m	<i>Therefore</i>	3.5
Water depth	H	m		3.0
<b>Dimension (Diameter)</b>	D	m		<b>3.5</b>
<b>(Depth)</b>	H	m		<b>3.0</b>
<b>(Basin)</b>	BN	basin		<b>2</b>

### 3-8 Sludge Digestion Tank

Item	Sign	Unit	Calculation	Result
Type	-	-	Anaerobic Tank	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	2,500
	Q2	m <sup>3</sup> /hr	Daily average	104.2
Generated sludge weight	GS1	kg/day	refer to 3-7	500
	GS2	ton/day	GS1/1000	0.50
Sludge moisture rate	MR	%	Thickened sludge	97.0
Sludge volume	SV	m <sup>3</sup> /day	$GS2 \times 100 / (100 - MR)$	16.7
Solid retention time	T	day		14.0
Basin number	BN	basin		1
Required tank volume	RV1	m <sup>3</sup> /basin	SV×T/BN	233.3
Water depth	H	m		6.0
Required surface area	RA	m <sup>2</sup> /basin	RV1/H	38.9
Required tank diameter	D1	m	$(RA \times 4 / 3.14)^{0.5}$	7.0
	D2	m	<i>Therefore</i>	7.0
<b>Dimension (Diameter)</b>	D	m		<b>7.0</b>
<b>(Depth)</b>	H	m		<b>6.0</b>
<b>(Basin)</b>	BN	basin		<b>1</b>

### 3-9 Digestion Gas Tank

Item	Sign	Unit	Calculation	Result
Generated sludge weight	GS	kg/day	refer to 3-8	500
Organic matter ratio	OM	%		70
Generation ratio of gas	GR	%		35
Retention time	RT	day		0.5
Required tank volume	RV	m <sup>3</sup>	$GS \times OM \times GR \times RT / 10^4$	61
Depth of tank	H	m		3.0
Basin number	BN	basin		1
Required tank diameter	D1	m	$2 \times (RV / (3.14 \times H \times BN))^{0.5}$	5.1
	D2	m		5.5
<b>Dimension (Diameter)</b>	D	m	<b>New Facility</b>	<b>5.5</b>
<b>(Depth)</b>	H	m		<b>3.0</b>
<b>(Number)</b>	BN	basin		<b>1</b>

### 3-10 Sludge Dewatering Equipment

Item	Sign	Unit	Calculation	Result
Type	-	-	Centrifugal type	
Generated sludge weight	GSW	ton/day	refer to 3-8	0.50
Digestion rate	DR	%		35.0
Digested sludge weight	DSW	ton/day	$GSW \times (100 - DR) / 100$	0.33
Sludge moisture rate	MR	%	digested sludge	97.0
Generated sludge volume	GSV	m <sup>3</sup> /day	$DSW \times 100 / (100 - MR)$	10.8
Unit number	UN	unit	including stand-by (=1 unit)	2
Operation time	OT	hr/day		8.0
Required capacity	RC1	m <sup>3</sup> /hr	$GSV / ((UN - 1) \times OT)$	1.4
	RC2	m <sup>3</sup> /hr		2.0
<b>Specification</b>	<b>2.0 m<sup>3</sup>/hr × 2 (1) units</b>			
Digested sludge weight	DSW	ton/day		0.33
Sludge moisture ratio	DM	%	dewatered sludge	80.0
Dewatered sludge volume	DV	m <sup>3</sup> /day	$DSW \times 100 / (100 - DM)$	<b>1.6</b>
				↓
				<b>Carry out</b>

## 5 SUMMARY OF PROPOSED FACILITIES

<b>5-1 Wet Well</b>
4.0 m(W) × 4.7 m(L) × 2.5 m(H) × 1 basin
<b>5-2 Pump Equipment</b>
100 mmdia × 1.30 m <sup>3</sup> /min × 15 m × 7.0 kW × 2 units
150 mmdia × 2.60 m <sup>3</sup> /min × 15 m × 13.0 kW × 2(1) units
<b>5-3 Grit Chamber</b>
0.6 m(W) × 2.9 m(L) × 0.3 m(H) × 2 basin
<b>5-4 Oxidation Ditch Reactor Tank</b>
4.0 m(W) × 67.0 m(L) × 3.0 m(H) × 2 basin
<b>5-5 Final Sedimentation Tank</b>
10.5 m(dia) × 4.0 m(H) × 2 basin
<b>5-6 Sand Filtration Tank (Future Plan)</b>
3.0 m(W) × 2.5 m(L) × 2 basin
<b>5-7 Disinfection Tank</b>
1.0 m(W) × 4.5 m(L) × 1.0 m(H) × 6 pass
<b>5-8 Sludge Thickening Tank</b>
3.5 m(dia) × 3.0 m(H) × 2 basin
<b>5-9 Sludge Digestion Tank</b>
7.0 m(dia) × 6.0 m(H) × 1 basin
<b>5-10 Digestion Gas Tank</b>
5.5 m(dia) × 3.0 m(H) × 1 basin
<b>5-11 Sludge Dewatering Equipment</b>
2.0 m <sup>3</sup> /hr × 2 units (including 1 stand-by)

### (3) Porvorim

#### CAPACITY CALCULATION OF SEWAGE TREATMENT FACILITIES

##### 1 BASIC CONDITIONS

###### 1-1 Basic Items

- (1) Name : **Porvorim Sewage Treatment Plant**
- (2) Land Area : Approximately  $\text{m}^2$
- (3) Elevation : + m
- (4) Inlet Pipe Level : - m
- (5) Pipe Diameter : - mm
- (6) Land Use :
- (7) Collection System : Combined System • **Separate System**
- (8) Treatment Method :
- Sewage Treatment : Pre-treatment + OD + Final Sedimentation  
+ Sand Filtration (future) + Disinfection Tank
- Sludge Treatment : Sludge Thickening + Sludge Digestion  
+ Dewatering
- (9) Effluent Point :
- (10) Effluent Point Water Level : + m
- (11) Target Year : 2025 Year

###### 1-2 Design Population and Area

- Design Population : 47,800 Persons (Residents)
- Design Area : 560 ha

###### 1-3 Design Sewage Flow


Item	$\text{m}^3/\text{day}$	$\text{m}^3/\text{hr}$	$\text{m}^3/\text{min}$	$\text{m}^3/\text{sec}$	Remarks
Daily Average	7,600	316.7	5.28	0.088	
Peak Flow	19,000	791.7	13.19	0.220	Peak factor = 2.50

###### 1-4 Design Sewage Quality

Item	Influent	T.R.R	Effluent	Remarks
	(mg/L)	(%)	(mg/L)	
BOD	300	90	30	Effluent Quality Regulation = 30 mg/l
SS	250	80	50	Effluent Quality Regulation = 100 mg/l

T.R.R. : Total Removal Ratio

2 Flow Chart (OD Method)



3 Design Criteria for STP

Items	Unit	CPHEEO	Japanese Standards	Metcalf&Eddy	Adoption
3.1 Screen and Grit Chamber (1) Screen Openings of screen bars (2) Grit Chamber Water surface loading Horizontal velocity	mm m <sup>3</sup> /m <sup>2</sup> /day m/sec	Less than 20 2,160 0.15 - 0.30	- - -	15 1,382 - 1,814 0.24 - 0.39	20 2,160 0.3
3.2 Pump Equipment Pump inflow velocity Retention time in wet well	m/sec min	- > 5.0	- -	1.5 - 3.0 -	1.5 - 3.0 9.0
3.3 Oxidation Ditch Reactor Tank Hydraulic retention time MLSS concentration BCOD-SS load Depth Width	hr mg/l kgBOD/kgSS/day m m	12 - 24 3,000 - 5,000 0.10 - 0.18 - -	24 - 48 3,000 - 4,000 0.03 - 0.05 1.0 - 3.0 2.0 - 6.0	8.0 - 36.0 3,000 - 6,000 0.05 - 0.30 - -	15.0 3,500 0.15 3.0 4.0
3.4 Final Sedimentation Tank Overflow rate Depth	m <sup>3</sup> /m <sup>2</sup> /day m	8.0 - 15.0 3.5 - 4.5	8.0 - 12.0 3.0 - 4.0	16.3 - 32.6 3.7 -	15.0 4.0
3.5 Sand Filtration (future) Filtration rate	m/day	-	max. 300	176	200.0
3.6 Disinfection Tank Detention time	min	-	15.0	-	15.0
3.7 Sludge Thickening Tank Solid surface load Depth	kg/m <sup>2</sup> /day m	25 - 30 3.0	60 - 90 4.0	12.2 - 34.2 -	30.0 3.0
3.8 Sludge Digestion Tank Solids retention time Digestion rate Operating temperature Depth	days % °C m	14.0 - 30.0 6.0 - 12.0	20.0 35.0 30.0 > 4.0	15.0 - 20.0 - - > 7.5	14.0 35.0 30.0 8.0
3.9 Sludge Dewatering Equipment Operation time	hr/day	-	-	-	8.0

CPHEEO: Central Public Health and Environmental Engineering Organization, Ministry of Urban Development, New Delhi, 1993

#### 4 CAPACITY CALCULATION

##### 4-1 Wet Well with Pump Equipment

Item	Sign	Unit	Calculation	Result
<b>4-1-1 Wet Well</b>				
Design sewage flow	Q1	m <sup>3</sup> /day	Peak Flow	10,500
	Q2	m <sup>3</sup> /min	Peak Flow	7.29
Basin number	BN	basin		1
Retention time	RT	min		9.0
Required volume	RV	m <sup>3</sup>	Q2×RT	65.6
Depth	H	m		2.5
Required area	RA	m <sup>2</sup>	RV/RA	26.25
Width	W	m		4.5
Length	L1	m	RA/W	5.83
	L2	m	<i>Therefore</i>	6.0
<b>Dimension (Width)</b>	W	m		<b>4.5</b>
<b>(Length)</b>	L	m		<b>6.0</b>
<b>(Depth)</b>	H	m		<b>2.5</b>
<b>(Basin)</b>	N	basin		<b>1</b>
<b>4-1-2 Pump Equipment</b>				
Design sewage flow	Q1	m <sup>3</sup> /day	Peak flow	10,500
	Q2	m <sup>3</sup> /min	Peak flow	7.29
Pump unit number	UN	unit	including stand-by (=1 unit)	4
Pump discharging flow	DF1	m <sup>3</sup> /min/unit	Q2/4	1.82
	DF2	m <sup>3</sup> /min/unit	Q2/2	3.65
Pump inflow velocity	PV	m/sec		1.5 - 3.0
Required pump diameter	D1-1	mm	$146 \times (DF1/3.0)^{0.5}$	114
	D1-2	mm	$146 \times (DF1/1.5)^{0.5}$	161
	D1	mm	<i>Therefore</i>	150
	D2-1	mm	$146 \times (DF2/3.0)^{0.5}$	161
	D2-2	mm	$146 \times (DF2/1.5)^{0.5}$	228
	D2	mm	<i>Therefore</i>	200
Pump total head	H	m	assumption	15.0
Pump efficiency	PE	-		0.60
Axis power	AP1	kw	$0.163 \times DF1 \times H/PE$	7.43
	AP2	kw	$0.163 \times DF2 \times H/PE$	14.86
Motor allowance	MA	-		0.15
Pump power	P1	kw	AP1×(1+MA)	8.54
		kw	<i>Therefore</i>	9.0
	P2	kw	AP2×(1+MA)	17.09
		kw	<i>Therefore</i>	18.0
<b>Pump Specification</b>	150 mmdia × 1.82 m <sup>3</sup> /min × 15 m × 9.0 kW × 2 units 200 mmdia × 3.65 m <sup>3</sup> /min × 15 m × 18.0 kW × 2(1) units			

##### 4-2 Screen and Grit Chamber

Item	Sign	Unit	Calculation	Result
<b>4-2-1 Grit Chamber</b>				
Type	-	-	Parallel flow type	
Design sewage flow	Q1	m <sup>3</sup> /day	Peak flow	10,500
	Q2	m <sup>3</sup> /sec	Peak flow	0.122
Water surface load	SL	m <sup>3</sup> /m <sup>2</sup> /day		2,160
Required surface area	RA	m <sup>2</sup>	Q1/SL	4.9
Basin number	BN	basin		2

Item	Sign	Unit	Calculation	Result
<b>4-2-1 Grit Chamber</b>				
Type	-	-	Parallel flow type	
Design sewage flow	Q1	m <sup>3</sup> /day	Peak flow	19,000
	Q2	m <sup>3</sup> /sec	Peak flow	0.220
Water surface load	SL	m <sup>3</sup> /m <sup>2</sup> /day		2,160
Required surface area	RA	m <sup>2</sup>	Q1/SL	8.8
Basin number	BN	basin		2
Average velocity	V	m/sec		0.3
Water depth	H	m		0.3
Width	W1	m	Q2/(V×H×BN)	1.22
	W2	m	<i>Therefore</i>	1.3
Length	L1	m	RA/(W2×BN)	3.38
	L2	m	<i>Therefore</i>	3.5
<b>Dimension</b>	<b>(Width)</b>	W	W2	<b>1.3</b>
	<b>(Length)</b>	L	L2	<b>3.5</b>
	<b>(Depth)</b>	H	H	<b>0.3</b>
	<b>(Basin)</b>	N		<b>2</b>
<b>4-2-2 Fine Screen</b>				
Type	-	-	One rake type intermittent rake-up	
Set number	SSN	set	1 set = Manual screen	1
Screen opening	-	mm	10 to 20	20
Unit removed screenings	RS	m <sup>3</sup> /1,000m <sup>3</sup>		0.010
Design sewage flow	Q	m <sup>3</sup> /day	Daily average	7,600
Volume of screenings	VS	m <sup>3</sup> /day	Q×RS/1,000	0.076
				↓
				<b>Carry out</b>

#### 4-3 Oxidation Ditch Reactor Tank

Item	Sign	Unit	Calculation	Result
Type			Endless ditch flow type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	7,600
	Q2	m <sup>3</sup> /hr	Daily average	316.7
BOD-SS load	BS	kgBOD/kgSS·day		0.15
Inlet BOD	BD	mg/l		300
MLSS concentration	MLSS	mg/l		3,500
Required volume -1	RV1	m <sup>3</sup>	BD×Q1/(MLSS×BS)	4,343
Hydraulic retention time	HT	hr		15.0
Required volume -2	RV2	m <sup>3</sup>	Q2×HT	4,750
	RV	m <sup>3</sup>	RV2 > RV1 <i>Therefore</i>	4,750
Basin number	BN	basin		4
Water depth	H	m		3.0
Width	W	m		4.0
Length	L1	m	RV/(H×W×BN)	99.0
	L2	m	<i>Therefore</i>	100.0
<b>Dimension</b>	<b>(width)</b>	W		<b>4.0</b>
	<b>(Depth)</b>	H		<b>3.0</b>
	<b>(Length)</b>	L2		<b>100.0</b>
	<b>(Basin)</b>	BN		<b>4</b>



<b>Dimension (Diameter)</b>	W	m		<b>12.5</b>
<b>(Depth)</b>	H	m		<b>4.0</b>
<b>(Basin)</b>	BN	basin		<b>2</b>

#### 4-5 Sand Filtration Tank (future)

Item	Sign	Unit	Calculation	Result
Type	-	-	Gravity Upflow Filter Type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	3,500
	Q2	m <sup>3</sup> /sec	Daily average	0.041
Filtration rate	FR	m/day		200.0
Required surface area	RA	m <sup>2</sup>	Q1/FR	17.5
Basin number	BN	basin		2
Width	W	m		3.0
Length	L1	m	RA/(W×BN)	2.92
	L2	m	<i>Therefore</i>	3.0
<b>Dimension (Width)</b>	W	m	W2	<b>3.0</b>
<b>(Length)</b>	L	m	L2	<b>3.0</b>
<b>(Basin)</b>	N	basin		<b>2</b>

#### 4-6 Disinfection Tank

Item	Sign	Unit	Calculation	Result
Chemical type	-	-	Chlorination Type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	3,500
	Q2	m <sup>3</sup> /min	Daily average	2.43
Retention time	RT	min		15.0
Required volume	RV	m <sup>3</sup>	Q2×RT	36.5
Width	W	m		1.0
Water depth	H	m		1.0
Pass number	N	pass		8
Length	L1	m	RV/(W×H×N)	4.6
	L2	m	<i>Therefore</i>	5.0
<b>Dimension (Width)</b>	W	m		<b>1.0</b>
<b>(Length)</b>	L	m	L2	<b>5.0</b>
<b>(Depth)</b>	H	m		<b>1.0</b>
<b>(Pass Number)</b>	N	pass		<b>8</b>

#### 4-7 Sludge Thickening Tank

Item	Sign	Unit	Calculation	Result
Type	-	-	Radial Flow Circular Type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	3,500
	Q2	m <sup>3</sup> /hr	Daily average	145.8
Basin number	BN	basin		2
Influent SS quality	ISQ	mg/L		240
Effluent SS quality	ESQ	mg/L		50
Generated sludge	GS	kg/day	Q1×(ISQ-ESQ)×10 <sup>-3</sup>	665
Sludge surface load	SL	kg/m <sup>2</sup> /day		30.0
Required surface area	RA	m <sup>2</sup>	GS/SL	22.2
Required tank diameter	D1	m	(RA×4/(3.14×BN)) <sup>0.5</sup>	3.8
	D2	m	<i>Therefore</i>	4.0
Water depth	H	m		3.0
<b>Dimension (Diameter)</b>	D	m		<b>4.0</b>
<b>(Depth)</b>	H	m		<b>3.0</b>
<b>(Basin)</b>	BN	basin		<b>2</b>

Item	Sign	Unit	Calculation	Result
Basin number	BN	basin		2
Influent SS quality	ISQ	mg/L		250
Effluent SS quality	ESQ	mg/L		50
Generated sludge	GS	kg/day	$Q1 \times (ISQ - ESQ) \times 10^{-3}$	1,520
Sludge surface load	SL	kg/m <sup>2</sup> /day		30.0
Required surface area	RA	m <sup>2</sup>	GS/SL	50.7
Required tank diameter	D1	m	$(RA \times 4 / (3.14 \times BN))^{0.5}$	5.7
	D2	m	<i>Therefore</i>	6.0
Water depth	H	m		3.0
<b>Dimension (Diameter)</b>	D	m		<b>6.0</b>
<b>(Depth)</b>	H	m		<b>3.0</b>
<b>(Basin)</b>	BN	basin		<b>2</b>

#### 4-8 Sludge Digestion Tank

Item	Sign	Unit	Calculation	Result
Type	-	-	Anaerobic Tank	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	7,600
	Q2	m <sup>3</sup> /hr	Daily average	316.7
Generated sludge weight	GS1	kg/day	refer to 4-7	1,520
	GS2	ton/day	GS1/1000	1.52
Sludge moisture rate	MR	%	Thickened sludge	97.0
Sludge volume	SV	m <sup>3</sup> /day	$GS2 \times 100 / (100 - MR)$	50.7
Solid retention time	T	day		14.0
Basin number	BN	basin		1
Required tank volume	RV1	m <sup>3</sup> /basin	SV × T / BN	709.3
Water depth	H	m		8.0
Required surface area	RA	m <sup>2</sup> /basin	RV1 / H	88.7
Required tank diameter	D1	m	$(RA \times 4 / 3.14)^{0.5}$	10.6
	D2	m	<i>Therefore</i>	11.0
<b>Dimension (Diameter)</b>	D	m		<b>11.0</b>
<b>(Depth)</b>	H	m		<b>8.0</b>
<b>(Basin)</b>	BN	basin		<b>1</b>

#### 4-9 Digestion Gas Tank

Item	Sign	Unit	Calculation	Result
Generated sludge weight	GS	kg/day	refer to 4-8	1,520
Organic matter ratio	OM	%		70
Generation ratio of gas	GR	%		35
Retention time	RT	day		0.5
Required tank volume	RV	m <sup>3</sup>	$GS \times OM \times GR \times RT / 10^4$	186
Depth of tank	H	m		4.0
Basin number	BN	basin		1
Required tank diameter	D1	m	$2 \times (RV / (3.14 \times H \times BN))^{0.5}$	7.7
	D2			8.0
<b>Dimension (Diameter)</b>	D	m	<b>New Facility</b>	<b>8.0</b>
<b>(Depth)</b>	H	m		<b>4.0</b>
<b>(Number)</b>	BN	basin		<b>1</b>

#### 4-10 Sludge Dewatering Equipment

Item	Sign	Unit	Calculation	Result
Type	-	-	Centrifugal type	
Digestion rate	DR	%		35.0
Generated sludge weight	GSW	ton/day	refer to 4-8	1.52
Digested sludge weight	DSW	ton/day	$GSW \times (100 - DR) / 100$	0.99
Sludge moisture rate	MR	%	digested sludge	97.0
Generated sludge volume	GSV	m <sup>3</sup> /day	$DSW \times 100 / (100 - MR)$	32.9
Unit number	UN	unit	including stand-by (=1 unit)	2
Operation time	OT	hr/day		8.0
Required capacity	RC1	m <sup>3</sup> /hr	$GSV / ((UN - 1) \times OT)$	4.1
	RC2	m <sup>3</sup> /hr		4.5
<b>Specification</b>	<b>4.5 m<sup>3</sup>/hr × 2 (1) units</b>			
Digested sludge weight	DSW	ton/day		0.99
Sludge moisture ratio	DM	%	dewatered sludge	80.0
Dewatered sludge volume	DV	m <sup>3</sup> /day	$DSW \times 100 / (100 - DM)$	<b>4.9</b>
				↓
				<b>Carry out</b>

## 5 SUMMARY OF PROPOSED FACILITIES

<b>5-1 Wet Well</b>
4.5 m(W) × 5.5 m(L) × 2.5 m(H) × 2 basin
<b>5-2 Pump Equipment</b>
125 mmdia × 1.65 m <sup>3</sup> /min × 15 m × 8.0 kW × 2 units
200 mmdia × 3.30 m <sup>3</sup> /min × 15 m × 16.0 kW × 1 unit
250 mmdia × 6.60 m <sup>3</sup> /min × 15 m × 31.0 kW × 2(1) units
<b>5-3 Grit Chamber</b>
1.3 m(W) × 3.5 m(L) × 0.3 m(H) × 2 basin
<b>5-4 Oxidation Ditch Reactor Tank</b>
4.0 m(W) × 100.0 m(L) × 3.0 m(H) × 4 basin
<b>5-5 Final Sedimentation Tank</b>
13.0 m(dia) × 4.0 m(H) × 4 basin
<b>5-6 Sand Filtration Tank (Future Plan)</b>
2.5 m(W) × 4.0 m(L) × 4 basin
<b>5-7 Disinfection Tank</b>
1.5 m(W) × 7.0 m(L) × 1.0 m(H) × 8 pass
<b>5-8 Sludge Thickening Tank</b>
6.0 m(dia) × 3.0 m(H) × 2 basin
<b>5-9 Sludge Digestion Tank</b>
11.0 m(dia) × 8.0 m(H) × 1 basin
<b>5-10 Digestion Gas Tank</b>
8.0 m(dia) × 4.0 m(H) × 1 basin
<b>5-11 Sludge Dewatering Equipment</b>
4.5 m <sup>3</sup> /hr × 2 units (including 1 stand-by)

#### (4) Ponda

### CAPACITY CALCULATION OF SEWAGE TREATMENT FACILITIES

#### 1 BASIC CONDITIONS

##### 1-1 Basic Items

- (1) Name : Ponda Sewage Treatment Plant
- (2) Land Area : Approximately m<sup>2</sup>
- (3) Elevation : + m
- (4) Inlet Pipe Level : - m
- (5) Pipe Diameter : - mm
- (6) Land Use :
- (7) Collection System : Combined System • Separate System
- (8) Treatment Method :
- Sewage Treatment : Pre-treatment + OD + Final Sedimentation  
+ Sand Filtration (future) + Disinfecti
- Sludge Treatment : Sludge Thickening + Sludge Digestion  
+ Dewatering
- (9) Effluent Point :
- (10) Effluent Point Water Level : + m
- (11) Target Year : 2025 Year

##### 1-2 Design Population and Area

- Design Population : 19,400 Persons (Residents)
- Design Area : 201 ha

##### 1-3 Design Sewage Flow


Item	m <sup>3</sup> /day	m <sup>3</sup> /hr	m <sup>3</sup> /min	m <sup>3</sup> /sec	Remarks
Daily Average	3,500	145.8	2.43	0.041	
Peak Flow	10,500	437.5	7.29	0.122	Peak factor = 3.00

##### 1-4 Design Sewage Quality

Item	Influent	T.R.R	Effluent	Remarks
	(mg/L)	(%)	(mg/L)	
BOD	280	89	30	Effluent Quality Regulation = 30 mg/l
SS	240	79	50	Effluent Quality Regulation = 100 mg/l

T.R.R. : Total Removal Ratio

2 Flow Chart (OD Method)



### 3 Design Criteria for STP

Items	Unit	CPHEEO	Japanese Standards	Metcalf&Eddy	Adoption
3.1 Screen and Grit Chamber					
(1) Screen	mm	Less than 20	-	15	20
Openings of screen bars					
(2) Grit Chamber	m <sup>3</sup> /m <sup>2</sup> /day	2,160	-	1,382 - 1,814	2,160
Water surface loading	m/sec	0.15 - 0.30	-	0.24 - 0.39	0.3
Horizontal velocity					
3.2 Pump Equipment					
Pump inflow velocity	m/sec	-	-	1.5 - 3.0	1.5 - 3.0
Retention time in wet well	min	> 5.0	-	-	9.0
3.3 Oxidation Ditch Reactor Tank					
Hydraulic retention time	hr	12 - 24	24 - 48	8.0 - 36.0	15.0
MLSS concentration	mg/l	3,000 - 5,000	3,000 - 4,000	3,000 - 6,000	3,500
BOD-SS load	kgBOD/kgSS/day	0.10 - 0.18	0.03 - 0.05	0.05 - 0.30	0.15
Depth	m	-	1.0 - 3.0	-	3.0
Width	m	-	2.0 - 6.0	-	4.0
3.4 Final Sedimentation Tank					
Overflow rate	m <sup>3</sup> /m <sup>2</sup> /day	8.0 - 15.0	8.0 - 12.0	16.3 - 32.6	15.0
Depth	m	3.5 - 4.5	3.0 - 4.0	3.7 -	4.0
3.5 Sand Filtration (future)					
Filtration rate	m/day	-	max 300	176	200.0
3.6 Disinfection Tank					
Detention time	min	-	15.0	-	15.0
3.7 Sludge Thickening Tank					
Solid surface load	kg/m <sup>2</sup> /day	25 - 30	60 - 90	12.2 - 34.2	30.0
Depth	m	3.0	4.0	-	3.0
3.8 Sludge Digestion Tank					
Solids retention time	days	14.0	20.0	15.0 - 20.0	14.0
Operating temperature	°C	30.0	30.0	-	30.0
Digestion rate	%	-	35.0	-	35.0
Depth	m	6.0 - 12.0	> 4.0	> 7.5	8.0
3.9 Sludge Dewatering Equipment					
Operation time	hr/day	-	-	-	8.0

CPHEEO: Central Public Health and Environmental Engineering Organization, Ministry of Urban Development, New Delhi, 1993

#### 4 CAPACITY CALCULATION

##### 4-1 Wet Well with Pump Equipment

Item	Sign	Unit	Calculation	Result
<b>4-1-1 Wet Well</b>				
Design sewage flow	Q1	m <sup>3</sup> /day	Peak Flow	10,500
	Q2	m <sup>3</sup> /min	Peak Flow	7.29
Basin number	BN	basin		1
Retention time	RT	min		9.0
Required volume	RV	m <sup>3</sup>	Q2×RT	65.6
Depth	H	m		2.5
Required area	RA	m <sup>2</sup>	RV/RA	26.25
Width	W	m		4.5
Length	L1	m	RA/W	5.83
	L2	m	<i>Therefore</i>	6.0
<b>Dimension (Width)</b>	W	m		<b>4.5</b>
<b>(Length)</b>	L	m		<b>6.0</b>
<b>(Depth)</b>	H	m		<b>2.5</b>
<b>(Basin)</b>	N	basin		<b>1</b>
<b>4-1-2 Pump Equipment</b>				
Design sewage flow	Q1	m <sup>3</sup> /day	Peak flow	10,500
	Q2	m <sup>3</sup> /min	Peak flow	7.29
Pump unit number	UN	unit	including stand-by (=1 unit)	4
Pump discharging flow	DF1	m <sup>3</sup> /min/unit	Q2/4	1.82
	DF2	m <sup>3</sup> /min/unit	Q2/2	3.65
Pump inflow velocity	PV	m/sec		1.5 - 3.0
Required pump diameter	D1-1	mm	$146 \times (DF1/3.0)^{0.5}$	114
	D1-2	mm	$146 \times (DF1/1.5)^{0.5}$	161
	D1	mm	<i>Therefore</i>	150
	D2-1	mm	$146 \times (DF2/3.0)^{0.5}$	161
	D2-2	mm	$146 \times (DF2/1.5)^{0.5}$	228
	D2	mm	<i>Therefore</i>	200
Pump total head	H	m	assumption	15.0
Pump efficiency	PE	-		0.60
Axis power	AP1	kw	$0.163 \times DF1 \times H/PE$	7.43
	AP2	kw	$0.163 \times DF2 \times H/PE$	14.86
Motor allowance	MA	-		0.15
Pump power	P1	kw	AP1×(1+MA)	8.54
		kw	<i>Therefore</i>	9.0
	P2	kw	AP2×(1+MA)	17.09
		kw	<i>Therefore</i>	18.0
<b>Pump Specification</b>	150 mmdia × 1.82 m <sup>3</sup> /min × 15 m × 9.0 kW × 2 units 200 mmdia × 3.65 m <sup>3</sup> /min × 15 m × 18.0 kW × 2(1) units			

##### 4-2 Screen and Grit Chamber

Item	Sign	Unit	Calculation	Result
<b>4-2-1 Grit Chamber</b>				
Type	-	-	Parallel flow type	
Design sewage flow	Q1	m <sup>3</sup> /day	Peak flow	10,500
	Q2	m <sup>3</sup> /sec	Peak flow	0.122
Water surface load	SL	m <sup>3</sup> /m <sup>2</sup> /day		2,160
Required surface area	RA	m <sup>2</sup>	Q1/SL	4.9
Basin number	BN	basin		2



Average velocity	V	m/sec		0.3
Water depth	H	m		0.3
Width	W1	m	$Q2/(V \times H \times BN)$	0.68
	W2	m	<i>Therefore</i>	0.7
Length	L1	m	$RA/(W2 \times BN)$	3.47
	L2	m	<i>Therefore</i>	3.5
<b>Dimension (Width)</b>	W	m	W2	<b>0.7</b>
<b>(Length)</b>	L	m	L2	<b>3.5</b>
<b>(Depth)</b>	H	m	H	<b>0.3</b>
<b>(Basin)</b>	N	basin		<b>2</b>
<b>4-2-2 Fine Screen</b>				
Type	-	-	One rake type intermittent rake-up	
Set number	SSN	set	1 set = Manual screen	1
Screen opening	-	mm	10 to 20	20
Unit removed screenings	RS	$m^3/1,000m^3$		0.010
Design sewage flow	Q	$m^3/day$	Daily average	3,500
Volume of screenings	VS	$m^3/day$	$Q \times RS/1,000$	0.035
				↓
				<b>Carry out</b>

#### 4-3 Oxidation Ditch Reactor Tank

Item	Sign	Unit	Calculation	Result
Type			Endless ditch flow type	
Design sewage flow	Q1	$m^3/day$	Daily average	3,500
	Q2	$m^3/hr$	Daily average	145.8
BOD-SS load	BS	$kgBOD/kgSS \cdot day$		0.15
Inlet BOD	BD	$mg/l$		280
MLSS concentration	MLSS	$mg/l$		3,500
Required volume -1	RV1	$m^3$	$BD \times Q1 / (MLSS \times BS)$	1,867
Hydraulic retention time	HT	hr		15.0
Required volume -2	RV2	$m^3$	$Q2 \times HT$	2,188
	RV	$m^3$	$RV2 > RV1$ <i>Therefore</i>	2,200
Basin number	BN	basin		2
Water depth	H	m		3.0
Width	W	m		4.0
Length	L1	m	$RV/(H \times W \times BN)$	91.7
	L2	m	<i>Therefore</i>	92.0
<b>Dimension (width)</b>	W	m		<b>4.0</b>
<b>(Depth)</b>	H	m		<b>3.0</b>
<b>(Length)</b>	L2	m		<b>92.0</b>
<b>(Basin)</b>	BN	basin		<b>2</b>

#### 4-4 Final Sedimentation Tank

Item	Sign	Unit	Calculation	Result
Type			Radial Flow Circular Type	
Design sewage flow	Q1	$m^3/day$	Daily average	3,500
	Q2	$m^3/hr$	Daily average	145.8
Overflow rate	OR	$m^3/m^2/day$		15.0
Required area	RA	$m^2$	$Q1/OR$	233.3
Basin number	BN	basin		2
Required tank diameter	D1	m	$(RA \times 4 / (3.14 \times BN))^{0.5}$	12.2
	D2	m	<i>Therefore</i>	12.5
Water depth	H	m		4.0

<b>Dimension (Diameter)</b>	W	m		<b>12.5</b>
<b>(Depth)</b>	H	m		<b>4.0</b>
<b>(Basin)</b>	BN	basin		<b>2</b>

#### 4-5 Sand Filtration Tank (future)

Item	Sign	Unit	Calculation	Result
Type	-	-	Gravity Upflow Filter Type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	3,500
	Q2	m <sup>3</sup> /sec	Daily average	0.041
Filtration rate	FR	m/day		200.0
Required surface area	RA	m <sup>2</sup>	Q1/FR	17.5
Basin number	BN	basin		2
Width	W	m		3.0
Length	L1	m	RA/(W×BN)	2.92
	L2	m	<i>Therefore</i>	3.0
<b>Dimension (Width)</b>	W	m	W2	<b>3.0</b>
<b>(Length)</b>	L	m	L2	<b>3.0</b>
<b>(Basin)</b>	N	basin		<b>2</b>

#### 4-6 Disinfection Tank

Item	Sign	Unit	Calculation	Result
Chemical type	-	-	Chlorination Type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	3,500
	Q2	m <sup>3</sup> /min	Daily average	2.43
Retention time	RT	min		15.0
Required volume	RV	m <sup>3</sup>	Q2×RT	36.5
Width	W	m		1.0
Water depth	H	m		1.0
Pass number	N	pass		8
Length	L1	m	RV/(W×H×N)	4.6
	L2	m	<i>Therefore</i>	5.0
<b>Dimension (Width)</b>	W	m		<b>1.0</b>
<b>(Length)</b>	L	m	L2	<b>5.0</b>
<b>(Depth)</b>	H	m		<b>1.0</b>
<b>(Pass Number)</b>	N	pass		<b>8</b>

#### 4-7 Sludge Thickening Tank

Item	Sign	Unit	Calculation	Result
Type	-	-	Radial Flow Circular Type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	3,500
	Q2	m <sup>3</sup> /hr	Daily average	145.8
Basin number	BN	basin		2
Influent SS quality	ISQ	mg/L		240
Effluent SS quality	ESQ	mg/L		50
Generated sludge	GS	kg/day	Q1×(ISQ-ESQ)×10 <sup>-3</sup>	665
Sludge surface load	SL	kg/m <sup>2</sup> /day		30.0
Required surface area	RA	m <sup>2</sup>	GS/SL	22.2
Required tank diameter	D1	m	(RA×4/(3.14×BN)) <sup>0.5</sup>	3.8
	D2	m	<i>Therefore</i>	4.0
Water depth	H	m		3.0
<b>Dimension (Diameter)</b>	D	m		<b>4.0</b>
<b>(Depth)</b>	H	m		<b>3.0</b>
<b>(Basin)</b>	BN	basin		<b>2</b>

#### 4-8 Sludge Digestion Tank

Item	Sign	Unit	Calculation	Result
Type	-	-	Anaerobic Tank	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	3,500
	Q2	m <sup>3</sup> /hr	Daily average	145.8
Generated sludge weight	GS1	kg/day	refer to 4-7	665
	GS2	ton/day	GS1/1000	0.67
Sludge moisture rate	MR	%	Thickened sludge	97.0
Sludge volume	SV	m <sup>3</sup> /day	GS2×100/(100-MR)	22.2
Solid retention time	T	day		14.0
Basin number	BN	basin		1
Required tank volume	RV1	m <sup>3</sup> /basin	SV×T/BN	310.3
Water depth	H	m		8.0
Required surface area	RA	m <sup>2</sup> /basin	RV1/H	38.8
Required tank diameter	D1	m	(RA×4/3.14) <sup>0.5</sup>	7.0
	D2	m	<i>Therefore</i>	7.0
<b>Dimension (Diameter)</b>	D	m		<b>7.0</b>
<b>(Depth)</b>	H	m		<b>8.0</b>
<b>(Basin)</b>	BN	basin		<b>1</b>

#### 4-9 Digestion Gas Tank

Item	Sign	Unit	Calculation	Result
Generated sludge weight	GS	kg/day	refer to 4-8	665
Organic matter ratio	OM	%		70
Generation ratio of gas	GR	%		35
Retention time	RT	day		0.5
Required tank volume	RV	m <sup>3</sup>	GS×OM×GR×RT/10 <sup>4</sup>	81
Depth of tank	H	m		3.0
Basin number	BN	basin		1
Required tank diameter	D1	m	2×(RV/(3.14×H×BN)) <sup>0.5</sup>	5.9
	D2			6.0
<b>Dimension (Diameter)</b>	D	m	<b>New Facility</b>	<b>6.0</b>
<b>(Depth)</b>	H	m		<b>3.0</b>
<b>(Number)</b>	BN	basin		<b>1</b>

#### 4-10 Sludge Dewatering Equipment

Item	Sign	Unit	Calculation	Result
Type	-	-	Centrifugal type	
Digestion rate	DR	%		35.0
Generated sludge weight	GSW	ton/day	refer to 4-8	0.67
Digested sludge weight	DSW	ton/day	GSW×(100-DR)/100	0.43
Sludge moisture rate	MR	%	digested sludge	97.0
Generated sludge volume	GSV	m <sup>3</sup> /day	DSW×100/(100-MR)	14.4
Unit number	UN	unit	including stand-by (=1 unit)	2
Operation time	OT	hr/day		8.0
Required capacity	RC1	m <sup>3</sup> /hr	GSV/((UN-1)×OT)	1.8
	RC2	m <sup>3</sup> /hr		2.0
<b>Specification</b>	<b>2.0 m<sup>3</sup>/hr×2 (1) units</b>			
Digested sludge weight	DSW	ton/day		0.43
Sludge moisture ratio	DM	%	dewatered sludge	80.0
Dewatered sludge volume	DV	m <sup>3</sup> /day	DSW×100/(100-DM)	<b>2.2</b>
				↓
				<b>Carry out</b>

## 5 SUMMARY OF PROPOSED FACILITIES

<b>5-1 Wet Well</b>
4.5 m(W) × 6.0 m(L) × 2.5 m(H) × 1 basin
<b>5-2 Pump Equipment</b>
150 mmdia × 1.82 m <sup>3</sup> /min × 15 m × 9.0 kW × 2 units
200 mmdia × 3.65 m <sup>3</sup> /min × 15 m × 18.0 kW × 2(1) units
<b>5-3 Grit Chamber</b>
0.7 m(W) × 3.5 m(L) × 0.3 m(H) × 2 basin
<b>5-4 Oxidation Ditch Reactor Tank</b>
4.0 m(W) × 92.0 m(L) × 3.0 m(H) × 2 basin
<b>5-5 Final Sedimentation Tank</b>
12.5 m(dia) × 4.0 m(H) × 2 basin
<b>5-6 Sand Filtration Tank (Future Plan)</b>
3.0 m(W) × 3.0 m(L) × 2 basin
<b>5-7 Disinfection Tank</b>
1.0 m(W) × 5.0 m(L) × 1.0 m(H) × 8 pass
<b>5-8 Sludge Thickening Tank</b>
4.0 m(dia) × 3.0 m(H) × 2 basin
<b>5-9 Sludge Digestion Tank</b>
7.0 m(dia) × 8.0 m(H) × 1 basin
<b>5-10 Digestion Gas Tank</b>
6.0 m(dia) × 3.0 m(H) × 1 basin
<b>5-11 Sludge Dewatering Equipment</b>
2.0 m <sup>3</sup> /hr × 2 units (including 1 stand-by)

## (5) Colva (South Coastal Belt)

### CAPACITY CALCULATION OF SEWAGE TREATMENT FACILITIES

#### 1 BASIC CONDITIONS

##### 1-1 Basic Items

- (1) Name : **Colva Sewage Treatment Plant**
- (2) Land Area : Approximately  $\text{m}^2$
- (3) Elevation : + m
- (4) Inlet Pipe Level : - m
- (5) Pipe Diameter : - mm
- (6) Land Use :
- (7) Collection System : Combined System • **Separate System**
- (8) Treatment Method :
- Sewage Treatment ; Pre-treatment + OD + Final Sedimentation  
+ Sand Filtration + Disinfection Tank
- Sludge Treatment ; Sludge Thickening + Sludge Digestion  
+ Dewatering
- (9) Effluent Point :
- (10) Effluent Point Water Level : + m
- (11) Target Year : 2025 Year

##### 1-2 Design Population and Area

- Design Population : 5,300 Persons (Residents)
- Design Area : 110 ha

##### 1-3 Design Sewage Flow


Item	$\text{m}^3/\text{day}$	$\text{m}^3/\text{hr}$	$\text{m}^3/\text{min}$	$\text{m}^3/\text{sec}$	Remarks
Daily Average	2,200	91.7	1.53	0.025	
Peak Flow	6,600	275.0	4.58	0.076	Peak factor = 3.00

##### 1-4 Design Sewage Quality

Item	Influent	T.R.R	Effluent	Remarks
	(mg/L)	(%)	(mg/L)	
BOD	220	86	30	Effluent Quality Regulation = 30 mg/l
SS	190	74	50	Effluent Quality Regulation = 100 mg/l

T.R.R. : Total Removal Ratio

2 Flow Chart (OD Method)



### 3 Design Criteria for STP

Items	Unit	CPHEEO	Japanese Standards	Metcalf&Eddy	Adoption
3.1 Screen and Grit Chamber					
(1) Screen	mm	Less than 20	-	15	20
Openings of screen bars					
(2) Grit Chamber	m <sup>3</sup> /m <sup>2</sup> /day	2,160	-	1,382 - 1,814	2,160
Water surface loading	m/sec	0.15 - 0.30	-	0.24 - 0.39	0.3
Horizontal velocity					
3.2 Pump Equipment					
Pump inflow velocity	m/sec	-	-	1.5 - 3.0	1.5 - 3.0
Retention time in wet well	min	> 5.0	-	-	9.0
3.3 Oxidation Ditch Reactor Tank					
Hydraulic retention time	hr	12 - 24	24 - 48	8.0 - 36.0	15.0
MLSS concentration	mg/l	3,000 - 5,000	3,000 - 4,000	3,000 - 6,000	3,500
BOD-SS load	kgBOD/kgSS/day	0.10 - 0.18	0.03 - 0.05	0.05 - 0.30	0.15
Depth	m	-	1.0 - 3.0	-	3.0
Width	m	-	2.0 - 6.0	-	4.0
3.4 Final Sedimentation Tank					
Overflow rate	m <sup>3</sup> /m <sup>2</sup> /day	8.0 - 15.0	8.0 - 12.0	16.3 - 32.6	15.0
Depth	m	3.5 - 4.5	3.0 - 4.0	3.7 -	4.0
3.5 Sand Filtration					
Filtration rate	m/day	-	max. 300	176	200.0
3.6 Disinfection Tank					
Detention time	min	-	15.0	-	15.0
3.7 Sludge Thickening Tank					
Solid surface load	kg/m <sup>2</sup> /day	25 - 30	60 - 90	12.2 - 34.2	30.0
Depth	m	3.0	4.0	-	3.0
3.8 Sludge Digestion Tank					
Solids retention time	days	14.0	20.0	15.0 - 20.0	14.0
Operating temperature	°C	30.0	30.0	-	30.0
Digestion rate	%	-	35.0	-	35.0
Depth	m	6.0 - 12.0	> 4.0	> 7.5	6.0
3.9 Sludge Dewatering Equipment					
Operation time	hr/day	-	-	-	8.0

CPHEEO: Central Public Health and Environmental Engineering Organization, Ministry of Urban Development, New Delhi, 1993

#### 4 CAPACITY CALCULATION

##### 4-1 Wet Well with Pump Equipment

Item	Sign	Unit	Calculation	Result
<b>4-1-1 Wet Well</b>				
Design sewage flow	Q1	m <sup>3</sup> /day	Peak Flow	6,600
	Q2	m <sup>3</sup> /min	Peak Flow	4.58
Basin number	BN	basin		1
Retention time	RT	min		9.0
Required volume	RV	m <sup>3</sup>	Q2×RT	41.3
Depth	H	m		2.5
Required area	RA	m <sup>2</sup>	RV/RA	16.50
Width	W	m		4.0
Length	L1	m	RA/W	4.13
	L2	m	<i>Therefore</i>	4.5
<b>Dimension (Width)</b>	W	m		<b>4.0</b>
<b>(Length)</b>	L	m		<b>4.5</b>
<b>(Depth)</b>	H	m		<b>2.5</b>
<b>(Basin)</b>	N	basin		<b>1</b>
<b>4-1-2 Pump Equipment</b>				
Design sewage flow	Q1	m <sup>3</sup> /day	Peak flow	6,600
	Q2	m <sup>3</sup> /min	Peak flow	4.58
Pump unit number	UN	unit	including stand-by (=1 unit)	4
Pump discharging flow	DF1	m <sup>3</sup> /min/unit	Q2/4	1.15
	DF2	m <sup>3</sup> /min/unit	Q2/2	2.29
Pump inflow velocity	PV	m/sec		1.5 - 3.0
Required pump diameter	D1-1	mm	$146 \times (DF1/3.0)^{0.5}$	90
	D1-2	mm	$146 \times (DF1/1.5)^{0.5}$	128
	D1	mm	<i>Therefore</i>	100
	D2-1	mm	$146 \times (DF2/3.0)^{0.5}$	128
	D2-2	mm	$146 \times (DF2/1.5)^{0.5}$	180
	D2	mm	<i>Therefore</i>	150
Pump total head	H	m	assumption	15.0
Pump efficiency	PE	-		0.60
Axis power	AP1	kw	$0.163 \times DF1 \times H/PE$	4.67
	AP2	kw	$0.163 \times DF2 \times H/PE$	9.34
Motor allowance	MA	-		0.15
Pump power	P1	kw	AP1×(1+MA)	5.37
		kw	<i>Therefore</i>	6.0
	P2	kw	AP2×(1+MA)	10.74
		kw	<i>Therefore</i>	11.0
<b>Pump Specification</b>	100 mmdia × 1.15 m <sup>3</sup> /min × 15 m × 6.0 kW × 2 units 150 mmdia × 2.29 m <sup>3</sup> /min × 15 m × 11.0 kW × 2(1) units			

##### 4-2 Screen and Grit Chamber

Item	Sign	Unit	Calculation	Result
<b>4-2-1 Grit Chamber</b>				
Type	-	-	Parallel flow type	
Design sewage flow	Q1	m <sup>3</sup> /day	Peak flow	6,600
	Q2	m <sup>3</sup> /sec	Peak flow	0.076
Water surface load	SL	m <sup>3</sup> /m <sup>2</sup> /day		2,160
Required surface area	RA	m <sup>2</sup>	Q1/SL	3.1
Basin number	BN	basin		2



Average velocity	V	m/sec		0.3
Water depth	H	m		0.3
Width	W1	m	$Q2/(V \times H \times BN)$	0.42
	W2	m	<i>Therefore</i>	0.6
Length	L1	m	$RA/(W2 \times BN)$	2.55
	L2	m	<i>Therefore</i>	2.6
<b>Dimension (Width)</b>	W	m	W2	<b>0.6</b>
<b>(Length)</b>	L	m	L2	<b>2.6</b>
<b>(Depth)</b>	H	m	H	<b>0.3</b>
<b>(Basin)</b>	N	basin		<b>2</b>
<b>4-2-2 Fine Screen</b>				
Type	-	-	One rake type intermittent rake-up	
Set number	SSN	set	1 set = Manual screen	1
Screen opening	-	mm	10 to 20	20
Unit removed screenings	RS	m <sup>3</sup> /1,000m <sup>3</sup>		0.010
Design sewage flow	Q	m <sup>3</sup> /day	Daily average	2,200
Volume of screenings	VS	m <sup>3</sup> /day	$Q \times RS / 1,000$	0.022
				↓
				<b>Carry out</b>

#### 4-3 Oxidation Ditch Reactor Tank

Item	Sign	Unit	Calculation	Result
Type			Endless ditch flow type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	2,200
	Q2	m <sup>3</sup> /hr	Daily average	91.7
BOD-SS load	BS	kgBOD/kgSS·day		0.15
Inlet BOD	BD	mg/l		220
MLSS concentration	MLSS	mg/l		3,500
Required volume -1	RV1	m <sup>3</sup>	$BD \times Q1 / (MLSS \times BS)$	922
Hydraulic retention time	HT	hr		15.0
Required volume -2	RV2	m <sup>3</sup>	$Q2 \times HT$	1,375
	RV	m <sup>3</sup>	$RV2 > RV1$ <i>Therefore</i>	1,400
Basin number	BN	basin		2
Water depth	H	m		3.0
Width	W	m		4.0
Length	L1	m	$RV / (H \times W \times BN)$	58.3
	L2	m	<i>Therefore</i>	59.0
<b>Dimension (width)</b>	W	m		<b>4.0</b>
<b>(Depth)</b>	H	m		<b>3.0</b>
<b>(Length)</b>	L2	m		<b>59.0</b>
<b>(Basin)</b>	BN	basin		<b>2</b>

#### 4-4 Final Sedimentation Tank

Item	Sign	Unit	Calculation	Result
Type			Radial Flow Circular Type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	2,200
	Q2	m <sup>3</sup> /hr	Daily average	91.7
Overflow rate	OR	m <sup>3</sup> /m <sup>2</sup> /day		15.0
Required area	RA	m <sup>2</sup>	$Q1 / OR$	146.7
Basin number	BN	basin		2
Required tank diameter	D1	m	$(RA \times 4 / (3.14 \times BN))^{0.5}$	9.7
	D2	m	<i>Therefore</i>	10.0
Water depth	H	m		4.0

<b>Dimension (Diameter)</b>	W	m		<b>10.0</b>
<b>(Depth)</b>	H	m		<b>4.0</b>
<b>(Basin)</b>	BN	basin		<b>2</b>

#### 4-5 Sand Filtration Tank

Item	Sign	Unit	Calculation	Result
Type	-	-	Gravity Upflow Filter Type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	2,200
	Q2	m <sup>3</sup> /sec	Daily average	0.025
Filtration rate	FR	m/day		200.0
Required surface area	RA	m <sup>2</sup>	Q1/FR	11.0
Basin number	BN	basin		2
Width	W	m		3.0
Length	L1	m	RA/(W×BN)	1.83
	L2	m	<i>Therefore</i>	2.0
<b>Dimension (Width)</b>	W	m	W2	<b>3.0</b>
<b>(Length)</b>	L	m	L2	<b>2.0</b>
<b>(Basin)</b>	N	basin		<b>2</b>

#### 4-6 Disinfection Tank

Item	Sign	Unit	Calculation	Result
Chemical type	-	-	Chlorination Type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	2,200
	Q2	m <sup>3</sup> /min	Daily average	1.53
Retention time	RT	min		15.0
Required volume	RV	m <sup>3</sup>	Q2×RT	22.9
Width	W	m		1.0
Water depth	H	m		1.0
Pass number	N	pass		4
Length	L1	m	RV/(W×H×N)	5.7
	L2	m	<i>Therefore</i>	6.0
<b>Dimension (Width)</b>	W	m		<b>1.0</b>
<b>(Length)</b>	L	m	L2	<b>6.0</b>
<b>(Depth)</b>	H	m		<b>1.0</b>
<b>(Pass Number)</b>	N	pass		<b>4</b>

#### 4-7 Sludge Thickening Tank

Item	Sign	Unit	Calculation	Result
Type	-	-	Radial Flow Circular Type	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	2,200
	Q2	m <sup>3</sup> /hr	Daily average	91.7
Basin number	BN	basin		1
Influent SS quality	ISQ	mg/L		190
Effluent SS quality	ESQ	mg/L		50
Generated sludge	GS	kg/day	Q1×(ISQ-ESQ)×10 <sup>-3</sup>	308
Sludge surface load	SL	kg/m <sup>2</sup> /day		30.0
Required surface area	RA	m <sup>2</sup>	GS/SL	10.3
Required tank diameter	D1	m	(RA×4/(3.14×BN)) <sup>0.5</sup>	3.6
	D2	m	<i>Therefore</i>	4.0
Water depth	H	m		3.0
<b>Dimension (Diameter)</b>	D	m		<b>4.0</b>
<b>(Depth)</b>	H	m		<b>3.0</b>
<b>(Basin)</b>	BN	basin		<b>1</b>

#### 4-8 Sludge Digestion Tank

Item	Sign	Unit	Calculation	Result
Type	-	-	Anaerobic Tank	
Design sewage flow	Q1	m <sup>3</sup> /day	Daily average	2,200
	Q2	m <sup>3</sup> /hr	Daily average	91.7
Generated sludge weight	GS1	kg/day	refer to 4-7	308
	GS2	ton/day	GS1/1000	0.31
Sludge moisture rate	MR	%	Thickened sludge	97.0
Sludge volume	SV	m <sup>3</sup> /day	GS2×100/(100-MR)	10.3
Solid retention time	T	day		14.0
Basin number	BN	basin		1
Required tank volume	RV1	m <sup>3</sup> /basin	SV×T/BN	143.7
Water depth	H	m		6.0
Required surface area	RA	m <sup>2</sup> /basin	RV1/H	24.0
Required tank diameter	D1	m	(RA×4/3.14) <sup>0.5</sup>	5.5
	D2	m	<i>Therefore</i>	6.0
<b>Dimension (Diameter)</b>	D	m		<b>6.0</b>
<b>(Depth)</b>	H	m		<b>6.0</b>
<b>(Basin)</b>	BN	basin		<b>1</b>

#### 4-9 Digestion Gas Tank

Item	Sign	Unit	Calculation	Result
Generated sludge weight	GS	kg/day	refer to 4-8	308
Organic matter ratio	OM	%		70
Generation ratio of gas	GR	%		35
Retention time	RT	day		0.5
Required tank volume	RV	m <sup>3</sup>	GS×OM×GR×RT/10 <sup>4</sup>	38
Depth of tank	H	m		3.0
Basin number	BN	basin		1
Required tank diameter	D1	m	2×(RV/(3.14×H×BN)) <sup>0.5</sup>	4.0
	D2			4.0
<b>Dimension (Diameter)</b>	D	m	<b>New Facility</b>	<b>4.0</b>
<b>(Depth)</b>	H	m		<b>3.0</b>
<b>(Number)</b>	BN	basin		<b>1</b>

#### 4-10 Sludge Dewatering Equipment

Item	Sign	Unit	Calculation	Result
Type	-	-	Centrifugal type	
Digestion rate	DR	%		35.0
Generated sludge weight	GSW	ton/day	refer to 4-8	0.31
Digested sludge weight	DSW	ton/day	GSW×(100-DR)/100	0.20
Sludge moisture rate	MR	%	digested sludge	97.0
Generated sludge volume	GSV	m <sup>3</sup> /day	DSW×100/(100-MR)	6.7
Unit number	UN	unit	including stand-by (=1 unit)	2
Operation time	OT	hr/day		8.0
Required capacity	RC1	m <sup>3</sup> /hr	GSV/((UN-1)×OT)	0.8
	RC2	m <sup>3</sup> /hr		1.0
<b>Specification</b>	<b>1.0 m<sup>3</sup>/hr×2 (1) units</b>			
Digested sludge weight	DSW	ton/day		0.20
Sludge moisture ratio	DM	%	dewatered sludge	80.0
Dewatered sludge volume	DV	m <sup>3</sup> /day	DSW×100/(100-DM)	<b>1.00</b>
				↓
				<b>Carry out</b>

## 5 SUMMARY OF PROPOSED FACILITIES

<b>5-1 Wet Well</b>
4.0 m(W) × 4.5 m(L) × 2.5 m(H) × 1 basin
<b>5-2 Pump Equipment</b>
100 mmdia × 1.15 m <sup>3</sup> /min × 15 m × 6.0 kW × 2 units
150 mmdia × 2.29 m <sup>3</sup> /min × 15 m × 11.0 kW × 2(1) units
<b>5-3 Grit Chamber</b>
0.6 m(W) × 2.6 m(L) × 0.3 m(H) × 2 basin
<b>5-4 Oxidation Ditch Reactor Tank</b>
4.0 m(W) × 59.0 m(L) × 3.0 m(H) × 2 basin
<b>5-5 Final Sedimentation Tank</b>
10.0 m(dia) × 4.0 m(H) × 2 basin
<b>5-6 Sand Filtration Tank</b>
3.0 m(W) × 2.0 m(L) × 2 basin
<b>5-7 Disinfection Tank</b>
1.0 m(W) × 6.0 m(L) × 1.0 m(H) × 4 pass
<b>5-8 Sludge Thickening Tank</b>
4.0 m(dia) × 3.0 m(H) × 1 basin
<b>5-9 Sludge Digestion Tank</b>
6.0 m(dia) × 6.0 m(H) × 1 basin
<b>5-10 Digestion Gas Tank</b>
4.0 m(dia) × 3.0 m(H) × 1 basin
<b>5-11 Sludge Dewatering Equipment</b>
1.0 m <sup>3</sup> /hr × 2 units (including 1 stand-by)

## Appendix M63.4 Comparison Study for Allocation of Sewerage Facilities


### (1) Taleigao, Dona Paula and Caranzalem Area, Panaji

**Alternative 1:** Wastewater will be treated at existing Tonca STP with augmentation

**Alternative 2:** Wastewater will be treated at new STP in lowland in Taleigao

#### Comparison Sheet of Alternative

	Alternative 1	Alternative 2
Sewage Treatment Plant	Existing Tonca STP Augmentation required (6.2 MLD) Existing site area is sufficient for Additional facilities	New STP (6.2 MLD) Land acquisition required
Sewer and Pressure Main	14.7 km	14.4 km
Pumping Station	Conventional type PS: 2	Conventional type PS: 1
Advantage / Disadvantage	Advantage: - Land acquisition is not required - High treatment reliability of STP by less manpower due to centralization of STP operation	
Conclusion	<b>Alternative 1</b> should be adopted, because - Existing SBR type Tonca STP has been working well, and better O&M performance is expected in future also - Area of the existing STP site is sufficient for augmentation of treatment capacity - Length of sewer is almost same	



**(2) St. Crus**

No alternative study is required for this scheme.

**(3) Porvorim**


**Alternative 1:** Wastewater will be treated at one new STP near Mondovi River

**Alternative 2:** Wastewater will be treated at two new STP, one is same as Alternative 1, and other is located in the northern part of service area

**Comparison Sheet of Alternative**

	<b>Alternative 1</b>	<b>Alternative 2</b>
Sewage Treatment Plant	New STP near Mondovi River (7.6 MLD) - Land acquisition required	New STP near Mondovi River (4.6 MLD) New STP for northern area (3.0 MLD) - Land acquisition required (both site)
Sewer and Pressure Main	17.9 km	16.9 km
Pumping Station	Conventional type PS: 3	Conventional type PS: 1
Advantage / Disadvantage	Advantage: - High treatment reliability of STP by less manpower due to centralization of STP operation	Advantage: - Less number of pumping stations - Shorter sewer  Disadvantage: - Receiving water body is far from site of STP at northern area, therefore long pressure main and pumping facility for effluent is necessary
Conclusion	<b>Alternative 1</b> should be adopted, because - High treatment reliability of STP by less manpower due to centralization of STP Operation - STP site is close to receiving water body	







**(4) Margao**


**Alternative 1:** Wastewater will be treated at existing Margao STP  
Railway crossing site is at west edge of municipality, in rural area

**Alternative 2:** Wastewater will be treated at existing Margao STP (same as Alternative 1)  
Railway crossing site is near “Old Station” in congested area

**Comparison Sheet of Alternative**

	<b>Alternative 1</b>	<b>Alternative 2</b>
Sewage Treatment Plant	Existing Margao STP Augmentation required (10 MLD) Existing site area is sufficient for additional facilities	Same as Alternative 1
Sewer and Pressure Main	9.0 km	9.8 km
Railway crossing site	- Rural area - Space for shaft for jacking is available - No residential receiving adverse affect From laying sewer	- Congested area - Congested are, difficult to lay sewer crossing under railway track by jacking method
Pumping Station	Conventional type PS: 2	Conventional type PS: 2
Evaluation	Advantage: - Shorter trunk sewer	Disadvantage: - Difficult to lay sewer crossing under railway track by jacking method
Adoption	<b>Alternative 1</b> should be adopted, because - Shorter trunk sewer - Construction of sewer crossing under railway track is possible	

**Margao City (South Zone)**  
**Year of 2025**  
**Alternative 2**



**(5) Ponda**


**Alternative 1:** Wastewater will be treated at new STP at just down stream of service area  
Trunk sewers will be laid under main roads running parallel to the main drainage

**Alternative 2:** Wastewater will be treated at same new STP as Alternative 1  
Trunk sewers will be laid in drainage area or very close to the drainage

**Comparison Sheet of Alternative**

	<b>Alternative 1</b>	<b>Alternative 2</b>
Sewage Treatment Plant	New STP at riverside area (3.5 MLD) Land acquisition required	Same as Alternative 1
Sewer and Pressure Main	3.3 km	4.0 km
Pumping Station	Conventional type PS: 1	Conventional type PS: 1
Evaluation	Advantage: - Shorter trunk sewer Disadvantage: - Many small manhole type pumps for lowland area is necessary	Disadvantage: -Difficult to lay trunk sewers along the drainage
Adoption	<b>Alternative 1</b> should be adopted, because - In practice, it is impossible to lay trunk sewers in drainage area or close to the Drainage due to many residential facing or close to the drainage - Shorter trunk sewer	

**Ponda City**  
Year of 2025  
Alternative 2



**(6) Mapusa**

**Alternative 1:** Wastewater will be treated at new STP at east edge of sewerage service area


**Alternative 2:** Wastewater will be treated at new STP at 1.2 km south of Municipal Market

**Comparison Sheet of Alternative**

	<b>Alternative 1</b>	<b>Alternative 2</b>
Sewage Treatment Plant	New STP at riverside area (11 MLD) Land acquisition required Land is used for semi public purpose	New STP at riverside area (11 MLD) Land acquisition required
Sewer and Pressure Main	10.3 km	11.1 km
Pumping Station	Conventional type PS: 1	Conventional type PS: 2
Evaluation	Advantage: - Shorter trunk sewer - Less number of pumping stations	
Adoption	<b>Alternative 1</b> should be adopted, because - Shorter trunk sewer - Less number of pumping stations	



**Mapusa City**  
Year of 2025  
Alternative 2



**(7) South Coastal Belt**


**Alternative 1:** Wastewater will be treated at new STP at south edge of sewerage service area

**Alternative 2:** Wastewater will be treated at new STP north edge of sewerage service area

**Comparison Sheet of Alternative**

	<b>Alternative 1</b>	<b>Alternative 2</b>
Sewage Treatment Plant	New STP at south edge (2.2 MLD) Land acquisition required	New STP at north edge (2.2 MLD) Land acquisition required
Effluent pipe	About 3 km to receiving water body (Sal River)	About 4 km to receiving water body (Sal River)
Sewer and Pressure Main	3.9 km	5.1 km
Pumping Station	Conventional type PS: 1	Conventional type PS: 0
Evaluation	Advantage: - Shorter trunk sewer / effluent pipe Disadvantage: - One conventional type pumping station is necessary, but it worked as main pump of STP, therefore it is not disadvantage in practice	
Adoption	<b>Alternative 1</b> should be adopted, because - Shorter trunk sewer / effluent pipe	

**South Coastal**  
**Belt**  
**(Year of 2025)**  
**Alternative 2**





**(8) North Coastal Belt**

**Alternative 1:** Wastewater will be treated at one new STP at north edge of Calangute Village

**Alternative 2:** Wastewater will be treated at two new STP, one is same as Alternative 1, and other is located at south end of Candolim Village

**Comparison Sheet of Alternative**

	<b>Alternative 1</b>	<b>Alternative 2</b>
Sewage Treatment Plant	New STP at Calangute (11.2 MLD) Land acquisition required	New STP at Candolim (2.5 MLD) New STP at Calangute (8.7 MLD) Land acquisition required (both)
Sewer and Pressure Main	14.1 km	11.6 km
Pumping Station	Conventional type PS: 2	Conventional type PS: 1
Evaluation	Advantage: - High treatment reliability of STP by less manpower due to centralization of STP operation	Advantage: - Less number of pumping station and shorter pressure main
Adoption	<b>Alternative 1</b> should be adopted, because - High treatment reliability of STP by less manpower due to centralization of STP Operation	

# North Coastal Belt

Year of 2025

Alternative 2

