



*1: 66 kV Distribution (Operated by 11kV)





G-G01 GENERAL ARRANGEMENT キングトム発電所全体配置図













44 AUXILIARY TRANSFORMER	2					
43 CONTROL PANELS	1 lot					
42 BATTERY AND CHARGER PANEL	1 lot					
41 MCC AND LY PANEL	1 lot					
40 SWITCHGEARS	1 lot					
39 PUMP STATION (*1)	1 lot					
38 INCINERATOR UNIT	1					
37 OILY WATER SEPARATOR TANK	1					
	2					
36 TREATED WATER PUNP	100	1000 L				
35 TREATED WATER TANK	1	1000 L				
34 WATER TREATMENT UNIT	1					
33 WASTE OIL TANK	1	2000 L				
32 HEAVY OIL WASHING UNIT	1					
31 INTAKE AIR SILENCER	2					
30 FUEL OIL DRAIN PUMP	1					
29 FUEL OIL DRAIN TANK	1	200 L				
28 AIR BLOWER & DUCT						
27 SLUDGE PUMP						
26 SLUDGE TANK	1	1000 L				
25 OILY WATER SEPARATION UNIT	1					
24 OLY WATER PUMP	1					
23 WASTE OF PUMP	1					
22 LUBE OIL COOLER	2					
7	1	2500 L				
21 HEAVY OIL BUFFER TANK						
20 LT WATER EXPANSION TANK	2	500 L				
19 STACK	2					
18 OVERHEAD CRANE	1	5 TONS				
17 HT WATER CIRCULATING PUMP	2					
16 HEAVY OIL SERVICE TANK	2	2500 L				
15 INTAKE AIR FILTER	2					
14 ENGINE LOCAL PANEL	2					
13 LUBE OIL PURIFIER	3 LUBE OIL PURFIER 1					
12 HEAVY OIL PURIFIER	2					
11 EXHAUST GAS SILENCER	2					
10 LT WATER CIRCULATING PUMP	2					
9 RADIATOR	2	344.5				
8 HT WATER EXPANSION TANK	2 2	500 L				
7 DIESEL OIL SERVICE TANK 5 T/C LUBE OIL UNIT	2	2500 L				
5 LUBE OIL PRIMING PUMP	2					
4 AIR COMPRESSOR UNIT	2					
3 FUEL OIL SKID	2	PURIFIER, PUMPS				
2 LUBE OIL SKID 1 ENGINE & GENERATOR	2	PURIFIER, FILTERS				
	1000	BDIMBAC				
No. EQUIPMENT NAME	O,LA	REMARKS				

REMARK


(41): PUMP STATION CONSISTS OF HEAVY OIL, DIESEL OIL, CITY WATER TRANSFER PUMPS AND LOCAL CONTROL PANEL.




G-A05 NEW POWERHOUSE ELEVATION キングトム発電建屋 立面図




G-E01 KINGTOM POWER STATION KEY SINGLE LINE DIAGRAM キングトム発電所全体単線図






G-M05 COMPRESSED AIR FLOW DIAGRAM キングトム発電所圧縮空気系統図





G-M06 AIR INTAKE AND EXHAUST GAS FLOW DIAGRAM キングトム発電所吸気・排気系統図




G-M07 SLUDGE TREATMENT FLOW DIAGRAM キングトム発電所廃油処理系統図

D-G01 33 kV Route Map between Wilberforce and Regent S/S 33kV ケーブルルート図 ウイルバーフォース変電所~リージェント変電所







D-G11 Regent S/S: General Arrangement リージェント変電所配置図

This Project: Procurement and installtion

This Project: Procurement (installation by NPA)

Abbreviations

- VCB Vacuum circuit breaker
- LA Lightning arrester with counter
- Earthing switch ES
- Voltage transformer Ammeter

- V Volt meter MCC8 Molded case circuit breaker
- RMU Ring Main Unit

D-E11 SINGLE LINE DIAGRAM REGENT S/S 全体単線図 : リージェント変電所

6. DEMAND FORECAST IN FREETOWN POWER SYSTEM

Demand Forecast in Freetwon Power System

	Manufacturing	Capacity	Estimate	Forecast												
	Year	(MW)	2005	2006	2007	2008	2009	2010	2011年	2012	2013	2014	2015	2016	2017	2018
1. Peak Demand (MW)			43.0	45.0	46.8	48.7	50.6	52.6	54.7	56.9	59.2	61.6	64.0	66.6	69.3	72.0
Growth Rate (%)					4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%	4.0%
2. Generating Capacity (MW)			25.5	31.5	55.8	68.7	78.4	64.4	64.1	63.9	63.7	63.5	63.2	57.3	57.1	56.9
2.1 Kingtom P/S			25.5	31.5	31.3	31.2	41.0	27.1	27.0	26.8	26.7	26.6	26.4	20.6	20.5	20.4
(1) Mirrlees 3	2001	6.3	5.5	5.5	5.5	5.4	5.4	5.4	5.4	5.3	5.3	5.3	5.3	5.2	5.2	5.2
(2) Sulzer 4	1977	9.2	7.0	7.0	7.0	6.9	6.9	Retire								
(3) Sulzer 5	1980	9.2	7.0	7.0	7.0	6.9	6.9	Retire								
(4) Mitsubishi 6	1995	5.0	4.0	4.0	4.0	4.0	3.9	3.9	3.9	3.9	3.9	3.8	3.8	3.8	3.8	3.8
(5) Caterpillar-1	2000	1.2	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	0.9	0.9
(6) Caterpillar-2	2000	1.2	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	0.9	0.9
(7) New DEG-2 (ESKOM)	(1974)	7.0		6.0	6.0	5.9	5.9	5.9	5.9	5.8	5.8	5.8	5.7	Retire		
(8) New DEG-7 (Japan's Grant)	2009	5.0					5.0	5.0	5.0	4.9	4.9	4.9	4.9	4.8	4.8	4.8
(9) New DEG-8 (Japan's Grant)	2009	5.0					5.0	5.0	5.0	4.9	4.9	4.9	4.9	4.8	4.8	4.8
2.2 Blackhall Road P/S					6.5	19.5	19.4	19.3	19.2	19.1	19.0	18.9	18.8	18.7	18.6	18.5
(1) New DEG-1 (BADEA-I)		7.56			6.5	6.5	6.4	6.4	6.4	6.3	6.3	6.3	6.2	6.2	6.2	6.2
(2) New DEG-2 (BADEA-II)		7.56				6.5	6.5	6.4	6.4	6.4	6.3	6.3	6.3	6.2	6.2	6.2
(3) New DEG-3 (BADEA-II)		7.56				6.5	6.5	6.4	6.4	6.4	6.3	6.3	6.3	6.2	6.2	6.2
2.3 Bumbuna Hydroelectric P/S					18.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0
(1) Unit 1		25.0			9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0
(2) Unit 2		25.0			9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0	9.0
(2) Omit 2		23.0			9.0	9.0	9.0	9.0	9.0	9.0	7.0	7.0	9.0	9.0	7.0	9.0
3. Power Balance(MW) (1 2.)			-17.5	-13.5	9.0	20.0	27.8	11.7	9.4	7.0	4.5	1.9	-0.8	-9.3	-12.2	-15.1
4. Capacity of the largest generator (MW)			7.0	7.0	7.0	6.9	6.9	6.4	6.4	6.4	6.3	6.3	6.3	6.2	6.2	6.2
5. Firm capacity (MW) (2 4.)			18.5	24.5	48.8	61.8	71.5	58.0	57.7	57.5	57.4	57.2	56.9	51.1	50.9	50.7
6. Reserve margine (MW) (1 5.)			-24.5	-20.5	2.0	13.1	20.9	5.3	3.0	0.6	-1.8	-4.4	-7.1	-15.5	-18.4	-21.3
7. Capacity of second largest Generator (MW)			7.0	7.0	7.0	6.9	6.9	6.4	6.4	6.4	6.3	6.3	6.3	6.2	6.2	6.2
8. Safe reserve margine (MW) (6	7.)		-31.5	-27.5	-5.0	6.2	14.0	-1.1	-3.4	-5.8	-8.1	-10.7	-13.4	-21.7	-24.6	-27.5

Source: NPA

Commissioning of Japan's Grant Aid Project

Target Year

Remarks: 4%/year is applied as the growth rate of peak demand based on the power demand forecast of NPA.

During dry season, generating capacity of Bumbuna decreases up to 18MW and this number is used in calculating power balance.

Decreasing factor for each engine are supposed as about 0.5 % per annum.