


C. Final Disposal:

C3 Complement Information for
Final Disposal Plan

C3 COMPLEMENT INFORMATION FOR FINAL DISPOSAL PLAN

1. New Guanabacoa Landfill Design by C/P side



Note : Source by DPPF

Figure 1.1 Location Map of Authorized area for New Guanabacoa Landfill




Figure 1.2 General Plan of New Guanabacoa Landfill , designed by C/P side

2. Estimated Volume of Covering Soil

Table 2.1 Estimated Volume of Covering Soil at Calle 100 Landfill

(Unit: 1000m³)

	Total	Clay	Top soil and sand	Soft rock and waste construction	Note
Rate of Volume		35%	60%	5%	
1. Cutting Earth Volume in expansion Calle 100 Landfill	2,050	720	1,230	100	
2. Using excavated soil					
2.1 Use in site of expansion area					
Mounding	195	80	195	10	
Protection layer for Liner sheet	0	0	71	0	
Dairy Covering Soil	692	0	692	0	
Facility of landfill				50	
Sub total	887	80	958	60	
2.2 Use for Closure Landfill					
Special Period Landfill	110	55	55	0	* 10km on the average
GUANABACOA Landfill	118	59	59	0	* 17km
Existing area of Calle 100 Landfill	400	200	200	0	* Less than 1km
Expansion of Calle 100 Landfill	120	52	52	0	* Less than 1km
Sub total	748	366	366	0	
Total of 2.1 + 2.2	1,635	446	1,324	60	
1 – 2 Surplus Soil	415	274	-94	40	

Note: * Moving Distance from Calle 100 landfill

3. Breakdown of Quantities Estimation

3.1 New Site 1 Landfill

New Site 1 Landfill

A. Calculate of Earth Work

	Waste volume with cover soil compaction (m3)	(A) Cover soil volume before compaction			(B) Compacted Volume (A)/0.9		(C) Portage Volume (B)x1.2	
		m3/day	m3/year	m3/year	m3	Roundup (m3)	m3	Roundup (m3)
Y2011	718,000	429	156,585	156,600	173,983	174,000	208,780	208,800
Y2012	713,000	425	155,125	155,200	172,361	172,400	206,833	206,900
Y2013	672,000	401	146,365	146,400	162,628	162,700	195,153	195,200
Y2014	669,000	399	145,635	145,700	161,817	161,900	194,180	194,200
Y2015	665,000	397	144,905	145,000	161,006	161,100	193,207	193,300
Total	3,437,000	-	748,615	748,900	831,794	832,100	998,153	998,200

Note : (B) and (C) are Volume of Natural ground condition

	1st Stage	2nd Stage	Total	Situation
Require volume of waste and cover soil	2,275,000	1,400,000	3,675,000	Compaction
Necessary Volume	2,388,750	1,470,000	3,858,750	Compaction
Cover Soil Volume	515,110	316,990	832,100	Natural ground

		1st Stage	2nd Stage	Total	
		m3	m3		
Earth Work	Excavated Volume	1st Layer	635,660	403,160	1,038,820
	Mounding	1st dike	0	0	0
		2nd dike	76,100	68,600	144,700
		3rd dike	52,500	46,700	99,200
		4th dike	50,400	44,300	94,700
		5th dike	48,300	42,000	90,300
		sub-total	227,300	201,600	428,900
		Protective layer for Liner Seat	41,170	26,160	67,330
	Road bed work	13,020	2,480	15,500	
	Total of filling and mounding work	281,490	230,240	511,730	
Cover Soil	use excavated soil on site	515,110	316,990	832,100	
	surplus soil	120,550	86,170	206,720	
Final Cover Soil Layer		Gravel, t=30cm	39,072	24,272	63,344
		Clay, t=60cm	78,144	48,544	126,688
		Top Soil, t=30cm	39,072	24,272	63,344
		Total	156,288	97,088	253,376
Liner Sheet	m2	PE sheet + Geocomposite	140,000	89,000	229,000
Geo composite	m3	use excavated on site	41,170	26,160	67,330

Leachate Treatment Pond	Excavate volume	Anaerobic pond	7,410	5,170	12,580
		Aerobic Lagoon	7,260	4,670	11,930
		Maturation Pond	16,620	10,740	27,360
		Total	31,290	20,580	51,870
	existing clay	Anaerobic pond	3,530	2,440	5,970
		Aerobic Lagoon	2,570	1,790	4,360
		Maturation Pond	16,620	9,660	26,280
		Total	22,720	13,890	36,610
	Sheet Anchorage ditch	Anaerobic pond	296	264	560
		Aerobic Lagoon	252	214	466
Maturation Pond		342	272	614	
Total		890	750	1,640	

6. Leachate collection and gas removing facility

	Main Pipe	Branch Pipe	Note
Dia.	600mm	200mm	
Stage1	500	5,000	at interval of 30 m
Stage2	390	3,900	
total	890	8,900	

7. Gas removing facility, vertical type

PVC Diameter 300mm
9 unit/each ha

	Area for 1st layer	Gas Vent	Height for 1 unit	Sum Height
	ha	unit	m	m
Stage1	12.0	108	14	1,512
Stage2	7.8	70	14	980
total	19.8	178		2,492

8. Road

unit: m

	Approach Road		Onsite Road	Maintenance Road	note
	Type A	Type B			
Stage1	1,700	900	700	1,200	
Stage2	0	850	560	1,000	
total	1,700	1,750	1,260	2,200	
Height of Road bed	1.0	0.5	0.0	0.0	
width of road (m)	8.0	8.0	7.0	5.0	
Road Shoulder (m)	0.5	0.5	0.5	0.3	
Pavement	Asphalt Con. 10cm layer	Asphalt Con. 5cm layer	Gravel 50 cm	Gravel 30 cm	
Thickness of Road Earth Bed	5.50	2.63	-	-	(m3/m)
Thickness of Road Gravel Bed	30	30	30	30	cm
V= m3/m	2.4	2.4	2.1	1.5	(m3/m)
Thickness of Asphalt pavement	10	5	-	-	t cm
V m3/m	0.80	0.40	-	-	(m3/m)
Drainage of Surface exclusion	Slope 2%				
Side Ditch	Brick and Mortar				

9. Anchorage ditch of liner sheet

unit: m

	1st layer top	2nd layer top	total
Stage1	1,490	1,560	3,050
Stage2	1,220	1,290	2,510

10. Rain Storm drainage system

W x H	Type1	Type2	Type3	Note
	0.5mx0.5m with Riprap or Brick and mortar	0.5mx1.0m with Riprap or Brick and mortar	2.0mx1.0m with Riprap	
Landfill Area				
Stage1				
drainage ditch on emb	6,000			(425m + 325m) x 2 x 4layer installation each of 100m Around Embankment in grand level
Vertical	210			
Ground Level	400	2,700	2,810	
Sub Total	6,610	2,700	2,810	
Stage2				
each embankment lay	5,200			(300m + 350m) x 2 x 4layer installation each of 100m Around Embankment in grand level
Vertical	180			
Ground Level	400	370	600	
Sub Total	5,780	370	600	
TOTAL	11,560	740	1,200	

11. Turfing Work in embankment Slope

	top Area m	H m	L m	A m ² /laer	Layer unit	total m ²
1st Stage	120,000	14.8	1,512	22,378	4	89,510
2nd Stage	72,000	14.8	1,218	18,026	4	72,110
total	192,000		2,730	40,404	8	161,620

Note) 3rd Layer is Average layer

Administration Facility

Items	Qty	specification
1. Measurement office		
Truck scale ,Pavement of concrete t=30 cm	1 Unit	
Measurement office	15 m ²	5m x 3m
2. Security facility		
Light fixture on road	20 Unit	at interval of 50m
Light fixture around building	5 Unit	per 300m ²
Gate	1 unit	W=8m
Boundary fence	4,000 m	
Guards room	10 m ²	3.5m x 3m
3. Work shop		
Resting Room	300 m ²	10m x 30m
Parking of Heavy equipment , Rc, Concrete pavement	5,000 m ²	100m x 50m
Fuel tank	5000 L	

Stage Number	Required Condition(m3)	Volume (A*)	Dimension of Inside Bottom Area (Landfill Area) (ha)	Layer		Embankment Slope (1:S)=(Vertical : Horizontal)					Distance from Tail end Blanket	Bottom Dimension of waste filling layer		Top Surface dimension in Waste Filling Layer			Layer Dimension Landfill Area			Embankment Volume		Soil Volume of Embankm ent		Lbt	Wbt	Lbt	Wbt														
						Inside Slope	Outside Slope	Height	Width top	Width Bottom		Length bottom	Width bottom	L top	W top	Height	Each dimension	Sum Volume (*A)	Balance of volume demand	Section Area	Length		Lbt					Wbt													
																													non.	non.	M	M	M	M	M	M	M	m3	m3	m3	m3
New Site 1 Landfill																																									
Stage 1	Required Volumen(m3)	2,275,000		1st Layer	Excavation	2.0	-	5.0	-	-	-	400	300	420	320	5.0	635,660	635,660	-1,753,090	-	-																				
				2nd Layer	Mounding	2.0	3.0	3.5	5.0	22.5	2.0	424	324	438	338	3.5	499,370	1,135,030	-1,253,720	48.13	1,580	76,100	469	369	448	348															
				3rd Layer	Mounding	2.0	2.0	3.5	3.0	17.0	2.0	408	308	422	322	3.5	457,590	1,592,620	-796,130	35.00	1,500	52,500	442	342	428	328															
				4th Layer	Mounding	2.0	2.0	3.5	3.0	17.0	2.0	392	292	406	306	3.5	417,610	2,010,230	-378,520	35.00	1,440	50,400	426	326	412	312															
				5th Layer	Mounding	2.0	2.0	3.5	3.0	17.0	2.0	376	276	390	290	3.5	379,410	2,389,640	890	35.00	1,380	48,300	410	310	396	296															
		Necessary Volume	2,388,750		Sub Total				19.0							19.0		-									227,300														
Stage 2	Required Volume (m3)	1,400,000		1st Layer	Excavation	2.0	-	5.0	-	-	-	250	300	270	320	5.0	403,160	403,160	-1,066,840	-	-																				
				2nd Layer	Mounding	2.0	3.0	3.5	5.0	22.5	2.0	274	324	288	338	3.5	325,590	728,750	-741,250	48.13	1,280	61,700	319	369	298	348															
				3rd Layer	Mounding	2.0	2.0	3.5	3.0	17.0	2.0	258	308	272	322	3.5	292,210	1,020,960	-449,040	35.00	1,200	42,000	292	342	278	328															
				4th Layer	Mounding	2.0	2.0	3.5	3.0	17.0	2.0	242	292	256	306	3.5	260,630	1,281,590	-188,410	35.00	1,140	39,900	276	326	262	312															
				5th Layer	Mounding	2.0	2.0	3.5	3.0	17.0	2.0	226	276	240	290	3.5	230,840	1,512,430	42,430	35.00	1,080	37,800	260	310	246	296															
		Necessary Volume	1,470,000		Sub Total				19.0							19.0											181,400														
Total	Required Volume (m3)	3,675,000																								408,700															
	Necessary Volume	3,858,750																																							

Table Calculation for Volume Landfill of New site 1 Landfill

Earth Work Volume	Dimension of Inside Bottom Area (ha)	Construction Method	Embankment Volume	Protective layer for Liner Sheet	Final Layer		Compact d condition	Natural ground condition
					Gravel	Rich Native Soil		
					≅ 30 cm	≅ 30 cm		
Stage Number	Layer No.		m3		m3	m3	m3	m3
Stage 1	1st Layer	Excavation		41,170	-	-		
	2nd Layer	Mounding	76,100		-	-		
	3rd Layer	Mounding	52,500		-	-		
	4th Layer	Mounding	50,400		-	-		
	5th Layer	Mounding	48,300		35,165	35,165		
	Sub Total		227,300		35,165	35,165	268,470	298,300
Stage 2	1st Layer	Excavation		26,160	-	-		
	2nd Layer	Mounding	61,700		-	-		
	3rd Layer	Mounding	42,000		-	-		
	4th Layer	Mounding	39,900		-	-		
	5th Layer	Mounding	37,800		21,845	21,845		
	Sub Total		181,400		21,845	21,845	207,560	230,700
Total			408,700	67,330	57,010	57,010	476,030	529,000

Table Calculation of Earth Volume Landfill of New site 1 Landfill In NEW SITE 1 Landfill

Landfill	Cutting Soil		Mounding Soil	
	1st Stage	2nd Stage	1st Stage	2nd Stage
	635,660	403,160	298,300	230,700
			Dairy cover soil	0
			protective soil layer	51,900
			protective soil layer	34,400
	sub-total	1,038,820	sub total	615,300
Pond	1st Stage	31,290	Road bed (L=3000m)	12,000
	2nd Stage	20,580		
	sub-total	51,870		
total		1,090,690	TOTAL	615,300
			balance	475,390

Note: Estimated Volume is condition of Natural ground

Table Calculation of Pond Volume in New Site 1 Landfill

	Required volume (m ³)	Slope 1:s	Bottom (m)		High Water Level (m)			Allowance Level (HWL+0.5m)			Deposit Volume of Water Area V (m ³)	Excavation Volume (m ³)	Compactio n Cray Soil Area m ²	Anchor ditch for liner sheet m
			part of Under H.W.L	Lb	Wb	lho	Who	H ho	La	Wa				
(ALTERNATIVE 6)														
Anaerobic Pond + Aerated Lagoon + Maturation Pond with recirculation														
Anaerobic Pond (Embankment slope 1:3)														
Stage1	6,230	3.0	84	8	105	29	3.5	107	31	4.0	6,240	7,410 x 1 pond	3,530	296
Stage2	4,270	3.0	72	4	93	25	3.5	95	27	4.0	4,310	5,170 x 1 pond	2,440	264
Total	10,500										10,550	12,580	5,970	560
Aerated Lagoon (Embankment slope 1:1.5)														
Stage1	6,230	1.5	77	17	87	27	3.5	88	28	4.0	6,250	7,260 x 1 pond	2,570	252
Stage2	3,990	1.5	63	12	73	22	3.5	74	23	4.0	4,000	4,670 x 1 pond	1,790	214
Total	10,220										10,250	11,930	4,360	466
Maturation Pond (Embankment slope 1:3)														
Stage1	6,250	3.0	107	32	116	41	1.5	118	43	2.0	6,110	8,310 x 2 ponds	9,660	342
Stage2	4,000	3.0	76	28	85	37	1.5	87	39	2.0	3,930	5,370 x 2 ponds	6,400	272
Total	10,250									each pond	10,040	27,360	16,060	614
TOTAL											51,870		26,390	1,640

3.2 New Guanabacoa Landfill

Table 3.2.1 Breakdown of Quantities Estimation for New Guanabacoa Landfill

1. Require capacity of Landfill Area (unit m3)

Propose by M/P		Necessary of Landfill Volume	filled waste Volume	Necessary Covering soil Volume (*1)	Necessary Covering soil Volume at Natural ground, before cutting
Dimension of Landfill Area		After compaction	After compaction	After compaction	(*1) / 0.9
		(m3)	(m3)	(m3)	(m3)
1st Stage	East area 7.8 ha	850,500	599,000	120,100	133,400
2nd Stage	West area 5.5 ha	550,000	458,800	91,600	101,800
Total		1,400,500	1,058,000	211,700	235,200

2. Earth Work (calculated condition is natural ground condition)

(unit m3)

Cutting Volume		1st Stage	2nd Stage	total	Note
Landfill Area					
	1st layer	9,525	97,675	107,200	
	2nd layer	55,325	116,650	171,975	
	3rd layer	70,900	11,850	82,750	
	4th layer	84,250	0	84,250	
	5th layer	19,400	0	19,400	
	Sub-Total	239,400	226,175	465,575	
Compost Yard					
		50,000	0	50,000	
Administration Area					
		67,500	0	67,500	
	Sub-Total	117,500	0	117,500	
	Total	356,900	226,175	583,075	1)
Filling in site					
		Stage 1	Stage 2	Total	
	Filling	99,722	72	99,794	
	Enclosure Embankment	100,123	110,474	210,597	
	Administration area	120,000	0	120,000	
	Protection Soil for Liner sheet	25,920	26,667	52,587	
	Total	345,766	137,213	482,978	2)
Surplus Soil					
		11,134	88,962	100,097	1)-2)
Necessary of Cover Soil					
	m3	133,400	101,800	235,200	
by Onsite soil excavated					
	m3	11,134	88,962	100,097	
Transport from out site					
	m3	122,266	12,838	135,103	

3. Pond Construction Work

		1st Stage	2nd Stage	total
Excavation Volume (m3)	Anaerobic Pond	3,950	2,750	6,700
	Aerobic Pond	3,810	2,590	6,400
	Maturation Pond	9,480	7,100	16,580
	Total	17,240	12,440	29,680
installation area of liner sheet (m2)	Anaerobic Pond	2,102	2,039	4,141
	Aerobic Pond	1,544	1,184	2,728
	Maturation Pond	5,944	4,684	10,628
	Total	9,590	7,907	17,497
Length of Anchorage ditch for liner sheet (m)		610	580	1,190

4. Dimension of Enclosure Embankment

	3.5m height type	5.0m height type
Upper length of embankment	3 m	3 m
height of Embankment	3.5 m	5 m
Bottom length embankment	17 m	28 m
Out side Slope	1: 2	1: 3
Inside slope	1: 2	1: 2
Average Section are	35.0 m2	77.5 m2

5. Volume of inside Area

		Enclosure Dike Embankment			capacity
		L (m)	H (m)	Section Area(m3/m)	V(m3)
Stage1	1st Layer	-	5	-	12,875
	2nd Layer	-	3.5	-	109,775
	3rd Layer	-	3.5	-	238,500
	4th Layer	-	3.5	-	285,725
	5th Layer	-	3.5	-	250,025
	Total	-	-	-	896,900
Stage 2	1st Layer	-	5	-	107,050
	2nd Layer	-	3.5	-	172,275
	3rd Layer	-	3.5	-	159,375
	4th Layer	-	3.5	-	105,700
	5th Layer	-	3.5	-	74,000
	Total	-	-	-	618,400

5-1. Liner Sheet Installation Work

	Bottom Area m2	Slope Area m2	total m2	anchorage Length m	
Stage 1	70,000	26,000	96,000	1,300	
Stage 2	50,000	30,000	80,000	1,500	

6. Leachate Collection Pipe

	Area ha	Main Pipe 600mm	Branch Pipe 300mm
		L (m)	L (m)
Stage1	8	700	2,340
Stage2	6	300	1,650
total	13.3	1000	3,990

7. Leachate Collection Connection Pipe from Landfill to Pond

Connection Pipe			
	From Landfill to pond	Connection for each pond	Total
	m	m	m
Stage1	50	70	120
Stage 2	50	70	120
Total	100	140	240

8. Gas vent pipe , vertical type

Dia=300mm
9 unit per ha, installation of 30m pitch

	Area of 1st layer ha	unit	Height per unit m	Sum Height
Stage1	7.8	70.2	14	983
Stage2	6.0	54.0	10.5	567
total		124	-	1549.8

9. Road facility

	unit	Approach Road Type A	Approach Road Type B	Maintenance Road	Onsite Road	amount	note
Stage1	m	700	900	600	700	2900	
Stage2	m	0	500	900	700	2100	
total	m	700	1400	1500	1400	5000	
Height of road bed	m	1.0	0.5	-	-	-	
Width of road	m	8.0	8.0	5.0	7.0	-	
Width of road shoulder	m	0.5	0.5	0.3	0.3	-	
Condition of pavement		Asphalt Con. 5cm x2 layer	Asphalt Con. 5cm x 2 layer	Gravel 30 cm	Gravel 30 cm		
Volume of Road Bed by soil	m3/m	5.50	2.63	-	-	-	
Thickness of Gravel paving layer	cm	30	30	30	30	-	
Volume of Section per meter leng	m3/m	2.4	2.4	1.5	2.1	-	
Thickness of Asphalt paving layer	t cm	10	5	-	-	-	
Volume of Section per meter leng	m3/m	0.80	0.40	-	-	-	

10. Rain Storm drainage system

W x H	Type1	Type2	Type3	Type4	Note
	0.5mx 0.5m with Riprap or Brick and mortar	0.5m x 1.0m with Riprap or Brick and mortar	2.0m x 1.0m with Riprap	2.0m x 2.0m with Riprap o Concrete	
Landfill and Embankment Area					
Stage1	Included administration area				installation each length 100m of embankment distance Around Embankment in grand level
	each embankment la	2,600	0	0	
	Vertical	260	0	0	
	Around Landfill	650	200	100	
	Sub Total	3,510	200	100	
	Pond area	200	100	100	
	Total	3,710	300	200	
Stage2	each embankment la	2,250			installation each of 100m Around Embankment in grand level
	Vertical	225			
	Around Landfill	750	200	100	
	Sub Total	3,225	200	100	
	Pond area	200	100	100	
	Total	3,425	300	200	

11. Turfing Work for protective erosion in embankment Slope

	Height average m	Wide bench m	Embankment sl m	Slop length m	Length average m	Turfing area m2
Stage 1	14.0	8	2	39	1,300	51,096
Stage 2	10.5	6	2	29	1,500	44,218
total	-	-	-	-	-	95,315

Table3.2.2 Calculation of Pond Volume at New Guanabacoa Landfill

Area (ha)	Dimension (m)			Required volume (m ³)	Slope 1:s	Bottom (m)		H.W.L (m)			Allowance Level (HWL+0.5m)			Deposit Volume of Water Area	Excavation Volume	Liner Sheet Area	Anchor length	
	L	W	H (MWL)			part of Under H.W. L	Lb	Wb	Lh	Wh	Hh	La	Wa					Ha
Alternative 6																		
Anaerobic Pond + Aerated Lagoon + Maturation Pond																		
Anaerobic Pond (Embankment slope 1:3)																		
Stage1	3,080	44	20	3.5	3,080	3	46	5.0	67	26	3.5	69	28	4.0	3,190	3,950 x 1 pond	2,102 x 1 pond	204 x 1 pond
Stage2	2,100	40	15	3.5	2,100	3	46	5.0	67	21	3.5	69	23	4.0	2,200	2,750 x 1 pond	2,039 x 1 pond	194 x 1 pond
Total	5,180	-	-	-	5,180	-	-	-	-	-	-	-	-	-	5,390	6,700 x 1 pond	4,141 x 1 pond	398 x 1 pond
Acrobic Lagoon (Embankment slope 1:1.5)																		
Stage1	3,080	44	20	3.5	3,080	1.5	44.5	12.5	55	23	3.5	56	24	4.0	3,120	3,810 x 1 pond	1,544 x 1 pond	170 x 1 pond
Stage2	2,100	40	15	3.5	2,100	1.5	41.5	7.5	52	18	3.5	53	19	4.0	2,110	2,590 x 1 pond	1,184 x 1 pond	154 x 1 pond
Total	5,180	-	-	-	5,180	-	-	-	-	-	-	-	-	-	5,230	6,400 x 1 pond	2,728 x 1 pond	324 x 1 pond
Maturation Pond (Embankment slope 1:3)																		
Stage1	3,150 x 2 ponds	70	30	1.5	3,150	3	69	24.0	78	33	1.5	80	35	2.0	3,150	4,740 x 2 ponds	2,972 x 2 ponds	240 x 2 ponds
Stage2	2,250 x 2 ponds	60	25	1.5	2,250	3	62	19.0	71	28	1.5	73	30	2.0	2,350	3,550 x 2 ponds	2,342 x 2 ponds	216 x 2 ponds
Total	5,400 x 2 ponds	-	-	-	5,400	-	-	-	-	-	-	-	-	-	5,500	8,290 x 2 ponds	5,314 x 2 ponds	456 x 2 ponds

3.3 Expansion of Calle 100

Table 3.3.1 Breakdown of Quantities Estimation for Calle 100 Landfill


1. Landfill

1.1 Necessary Volume of Waste layer
(Average Volume with daily cove Operation Period)

1st Stage	1,764,000 m ³	2007y-2008y Operation area 10000 m ² x 1.75 m x 10 layer
2nd Stage	1,400,000 m ³	2008y-2010y 8000 m ² x 1.75m x 10 layer
∑	3,164,000 m ³	

1.2 Standard section of Enclosure embankment

	2nd Layer	upper 3rd layer
Upper width of bank	3.0 m	3.0 m
Height of bank	5.0 m	3.5 m
Bottom width	23.0 m	15.3 m
Outside slope	1: 2	1: 2
Inside slope	1: 2	1: 1.5
Average Dimens	65.0 m ²	31.9 m ²



1.3. Mounding volume

	Bank layer	Section Area (m ²)	Length (m)	Volume (m ³)	Percent of Cutting Area	Volume (m ³)
1st Stage	1st layer	65.0	1412	91,780	0	0
	2nd layer	31.9	1488	47,467	70	33,227
	3rd layer	31.9	1406	44,851	100	44,851
	4th layer	31.9	1324	42,236	100	42,236
	5th layer	31.9	1242	39,620	100	39,620
	Total			265,954		159,934
2nd Stage	1st layer	65.0	1272	82,680	0	0
	2nd layer	31.9	1332	42,491	70	29,744
	3rd layer	31.9	1250	39,875	100	39,875
	4th layer	31.9	1168	37,259	100	37,259
	5th layer	31.9	1086	34,643	100	34,643
	Total			236,948		141,521
TOTAL				502,902		301,455

1.4. Cutting volume

	section layer	L (m)		W (m)		H (m)	Layer Volume Val (m ³)	% of Cutting	Cut Volume Vic (m ³)
		Bottom (m)	Top (m)	Bottom (m)	Top (m)				
1st Stage	1st layer	440	456	250	266	3.0	346,752	100	346,752
	2nd layer	460	474	270	284	5.0	646,795	80	517,436
	3rd layer	439.5	454	249.5	264	3.5	400,845	50	200,423
	4th layer	419	433	229	243	3.5	351,876	5	17,594
	5th layer	398.5	413	208.5	223	3.5	305,848	0	0
	Total					18.5	2,052,116		1,082,205
2nd Stage	1st layer	370	386	250	266	3.0	292,572	100	292,572
	2nd layer	386	400	266	280	5.0	536,445	90	482,801
	3rd layer	365.5	380	245.5	260	3.5	329,197	50	164,599
	4th layer	345	359	225	239	3.5	285,824	10	28,582
	5th layer	324.5	339	204.5	219	3.5	245,393	0	0
	Total					18.5	1,689,431		968,554
TOTAL							3,741,547		2,050,759

1.5.Liner Sheet Installation Area

	Waste Layer m ²
1st Stage	127,177
2nd Stage	107,957
total	235,134

1.6.Liner sheet Anchor ditch

	1st Layer m	total m
1st Stage	1,484	1,484
2nd Stage	1,344	1,344
total	2,828	2,828

1.7.Liner Sheet Protection Layer

	sand layer (m ³) t= 30 cm
1st Stage	38,153
2nd Stage	32,387
total	70,540

1.8. Leachate Collection Pipe

	Area ha	Main pipe 600mm	Branch Pipe 200mm
1st Stage	10	400	6,000
2nd Stage	9	450	5,400
total	19	850	11,400

1.9.Gas removing Facility

Diameter 300mm PVC Perforated pipe
9 unit per ha (at interval of 30m)

	Unit	Height (m) 14.5m each
1st Stage	90	1,575
2nd Stage	81	1,418
total	171	2,993

2.Pond Construction Work

21.Anaerobic Pond Construction

	Excavation Volume m ³	Liner Sheet Area m ²	Anchor ditch m
1st Stage	2,490	1,738	234
2nd Stage	2,090	1,842	234
total	4,580	3,580	468

22. Connection Leachate Pipe to Pond (connection Pipe Dia. 600mm)

	Excavated Dimension				Liner Sheet A m ²	filling Volume m ³
	Length m	Width m	Depth m	Volume m ³		
1st Stage	50	1.5	4.5	337.5	675	323
2nd Stage	50	1.5	4.5	337.5	675	323
total	100	-	-	-	1350	646

Table C-3-7 Calculation for dimension of expansion of calle100 landfill

Stage Number	Required Condition	Requirement capacity (m3) (A*)	Dimension of Inside Bottom Area (Landfill Area) (ha)	Method of earth work	Embankment Slope (1:5) (Vertical: Horizontal)					Distance from Tail end Blanket	Landfill Area Layer Dimension (Bottom Surface)		Layer Dimension with embankment (Top Surface)			Layer Dimension Area in Waste layer			Embankment Volume		Soil Volume of Embankment t	
					Layer	Inside Slope	Outside Slope	Height	Width top		Width Bottom	L bottom	W bottom	L top	W top	Height	Each dimension	Sum Total Volume (m3)	Balance of volume demand	Section Area		Length
Expansion of Calle100 Landfill																						
First Stage	Required Volume (m3)	1,764,000								440	250	456	266	4.0	462,420	462,420	-1,477,980	-	-	-		
	Length (M) →		1st Layer	Excavation	2.0	-	4.0	-	-													
	Width (M) →		2nd Layer	Excavation	2.0	2.0	3.5	3.0	17.0	2.0	460	270	474	284	3.5	452,810	915,230	-1,025,170	35.00	1,530	53,600	
	Average Height (M) →		3rd Layer	mounding	2.0	1.5	3.5	3.0	15.3	2.0	439.5	249.5	453.5	263.5	3.5	400,900	1,316,130	-624,270	31.94	1,450	46,400	
	Volume (M3)		4th Layer	mounding	2.0	1.5	3.5	3.0	15.3	2.0	419	229	433	243	3.5	351,930	1,668,060	-272,340	31.94	1,370	43,800	
	x 1.1 for preparative (m3)	1,940,400	5th Layer	mounding	2.0	1.5	3.5	3.0	15.3	2.0	398.5	208.5	412.5	222.5	3.5	305,900	1,973,960	33,560	31.94	1,290	41,300	
			Sub Total				18.0							18.0						185,100		
Second Stage	Required Volume (m3)	1,400,000								370	250	386	266	4.0	390,180	390,180	-1,149,820	-	-	-		
	Length (M) →		1st Layer	Excavation	2.0	-	4.0	-	-													
	Width (M) →		2nd Layer	mounding	2.0	2.0	3.5	3.0	17.0	2.0	386	266	400	280	3.5	375,560	765,740	-774,260	35.00	1,380	48,300	
	Average Height (M) →		3rd Layer	mounding	2.0	1.5	3.5	3.0	15.3	2.0	365.5	245.5	379.5	259.5	3.5	329,250	1,094,990	-445,010	31.94	1,290	41,300	
	Volume (M3)		4th Layer	mounding	2.0	1.5	3.5	3.0	15.3	2.0	345	225	359	239	3.5	285,880	1,380,870	-159,130	31.94	1,210	38,700	
	x 1.1 for preparative (m3)	1,540,000	5th Layer	mounding	2.0	1.5	3.5	3.0	15.3	2.0	324.5	204.5	338.5	218.5	3.5	245,450	1,626,320	86,320	31.94	1,130	36,100	
			Sub Total				18.0							18.0						164,400		
Total	Required Volume (m3)	3,164,000																		349,500		

Earth Work Volume	Dimension of Inside Bottom Area (Landfill Area) (ha)	Blanket Soil Volume		Liner Sheet installation Area	Gravel of final cover layer	Rich Native Soil for final cover layer			
		Layer	Natural Condition				Area	r= 30 cm	r= 50 cm
Stage Number		Number	m3	m2	m3	m3			
Expansion of Calle 100 Landfill									
Stage 1	1st Layer	-	-	127,177	-	-			
	2nd Layer	53,600	-	-	-	-			
	3rd Layer	46,400	-	-	-	-			
	4th Layer	43,800	-	-	-	-			
	5th Layer	41,300	-	27,534	27,534	-			
		Sub Total	185,100	205,700	127,177	27,534	27,534		
Stage 2	1st Layer	-	-	107,957	-	-			
	2nd Layer	48,300	-	-	-	-			
	3rd Layer	41,300	-	-	-	-			
	4th Layer	38,700	-	-	-	-			
	5th Layer	36,100	-	22,189	22,189	-			
		Sub Total	164,400	182,700	107,957	22,189	22,189		
Total		349,500	388,400	235,134	49,723	49,723			

Landfill	Cutting Volume (m3)	Mounding Volume (m3)	
		Embankment	2nd Stage
1st Stage	462,420	205,700	
2nd Stage	390,180	182,700	
sub-total	852,600	673,800	
		sub total	1,062,200
Pond	Pond	Road work (L=3000m)	30,000
		1st Stage	44,300
		2nd Stage	37,700
		sub total	82,000
total	913,500	TOTAL	1,174,200
Balance			-260,700

note) the volume is in condition of natural ground

3. Road Construction Work

3.1. Road

	Access Road Type A	Access Road Type B	Maintenance Road	Onsite Road	amount	note
1st Stage	0	300	400	450	1150	
2nd Stage	0	0	300	300	600	
total	0	300	700	750	1750	
Height of road bed	m	1.0	0.5	0.0	0.0	
Width of road	m	8.0	8.0	5.0	7.0	
width of road	m	0.5	0.5	0.3	0.3	
specification	5cm x2 layer	Asphalt Con. 5cm x 2 layer	Gravel 30 cm	Gravel 30 cm		
Earth volume of road bed	m ³ /m	5.50	2.63	0.00	0.00	Soil layer
Gravel Pavement	thickness (cm)	30	30	30	30	Gravel
	Volume (m ³ /m)	2.4	2.4	1.5	2.1	
Asphalt Pavement	thickness (cm)	10	5	-	-	As
	Volume (m ³ /m)	0.80	0.40	-	-	

4. Rain Storm drainage system

41. Category of Ditch type

	Type1	Type2	Type3
Width m	0.5	1	2
Depth m	0.5	1	1
	with Riprap or Brick and mortar		

42. Landfill and Embankment Area

1st Stage	Landfill Area					installation each length 100m of embankment distance
	embankment 4 la on slope	2800				
	Around Dike	400	1600			
	Road side		300	600		
	total	3,200	1,900	600		Around Embankment in grand level
2nd Stage	Landfill Area					installation each of 100m
	embankment per on Slope	2400				
	Around Dike	100	1400			
	Road side		500	400		
	total	2,500	1,900	400		Around Embankment in grand level

43. Turfing Work in embankment Slope

	Area m ² /laer	total m ²
1st Stage	116,000	116000
2nd Stage	90,000	90000
total	206,000	206,000

5. Final Covering Work in top layer

Final Cover Layer

	L m	W m	A m ²	thickness cm	Volume m ³	thickness cm	Volume m ³
1st Stage	419	229	95,627	30	28,688	30	28,688
2nd Stage	345	225	77,340	30	23,202	30	23,202
total (Turfing area)			172,968		51,890		51,890

Table 3.3.2 Calculation of Pond Volume at Calle100 Landfill

Items	(unit : 1000m ³)											
	First stage				Second stage				Total			
	Total	Sandy Clay	Top soil and sand	soft rock and construction waste	Total	Sandy Clay	Top soil and sand	soft rock and construction waste	Total	Sandy Clay	Top soil and sand	soft rock and construction waste
Ratio of excavated Natural Soil Volume		30%	65%	5%		30%	65%	5%		30%	65%	5%
1. Cut Volume	374	112	243	19	239	72	155	12	612	184	398	31
2.1 Use soils in site												
Mounding and filling	320	100	110	10	111	50	55	6	430	150	165	16
Protection layer for Liner sheet	26	-	26	-	27		27		53		53	
Landfill facility of Landfill Site							50	19			50	19
Sub Total	346	100	136	10	137	50	132	25	483	150	268	35
Surplus Soil	28	12	107	9	101	22	23	-13	130	34	130	-4
1 - 2 Necessary Volume for Dairy Cove	133				92				235		212	
Obtain inside	28				101				130			
From outside	105				-10				106			

Table 3.3.3 Calculation of Soil Volume in the Expansion Area of Calle100 Landfill

	Stage	Dimension (Average size)			Required volume (m ³)	Slope 1:s *1	Bottom (m)		H.W.L. (m)			Allowance Level (HWL=+0.5m)			Deposit Volume of Water Area (m ³)*2	Impermeable Liner Zone (m)		Excavati on Volume (m ³)
		La	Wa	Ha			part of Under HOW. L.	Lb	Web	Lahr	Who	Hz	La	Way		Ha	V	
		(ALTERNATIVE 6)	Anaerobic Pond (Embankment slope 1:3)															
Level 3	1st Stage	59	25	3.5	5,163	3.0	63	10	84	31	3.5	86	33	4.0	5,400	0.75	2.25	6,630
	2nd Stage	60	20	3.5	4,200	3.0	70	5	91	26	3.5	93	28	4.0	4,490	0.75	2.25	5,530
	Total	-	-	-	9,363										9,890			

4. Unit Cost

Table 4.1 Unit Cost of Materials

Items	Specification	Unit Cost	Unit	Specification
HDPE liner Sheet with Geo-composite	1.5 mm double sided textured HDPE	9.80	USS / m2	Geomembran 60mil, t=1.5mm Pavco geodren planar PAVCO Installation kit for installation HDPE liner Sheet
	Double Sided geo-composite	9.16	USS / m2	
	Fitting cost for installation	16.000	USS	
PVC pipe for Under ground water drainage Perforated type	Perforated type, Dia.600mm	35.07	USS per meter	novafort PAVCO 515mm
	Perforated type, Dia.400mm	30.74	USS per meter	novafort PAVCO 400mm
	Perforated type, Dia.300mm	15.04	USS per meter	novafort PAVCO 315mm
	Perforated type, Dia.200mm	7.25	USS per meter	novafort PAVCO 200mm

Table 4.2 Unit Cost by Design and Cost estimation of Pilot Project in Campo Florida

Items	Specification	unit	Amount	Unit Price (CUP)	Note
Boundary Wire Fence	Barbed -wire Fence	m	950	14,051.29	
		m	1	14.79	
littering prevention equipment, Fence type	Installation Fence	m	200	3,505.87	
		Unit Cost per meter	m	1	17.53
Slope Protection Work	Turfing Work, each 10m x 10m	m2	100	2.58	
Net fence Installation Work		m	360	31,237.66	
		Unit Cost per meter	m	1	86.78
Entrance Gate setting work		unit	1	500.00	
Administration office	RC column and block wall	m2	70	27,126.38	
		Unit Cost	m2	1	387.52
Parking Area with Roof	Steel beam with slate a roof , 12m x 18 m	m2	216	31930.18	
		Unit Cost	m2	1	147.83
Fuel Tank	1500Liters of Steel tank with RC column	Liter	1500	3110.13	
		Unit Cost	Liter	1000	2073.5
Parking Area for visitors	Concrete pavement ,2.5m x 9m = 18.5m2	m2	18.5	11837.06	
		Unit Cost	m2	1	639.85
Asphalt pavement	thickness asphalt is 5cm, thickness of road bed is 18cm	m2	1542	11416.91	
		Unit Cost	m2	1	7.41

5. Existing Topographical Landfill Map




Figure 5.1 Topographical Map of Calle 100 Landfill




Figure 5.2 Topographical Map of Existing Guanabacoa Landfill

6. Method of Operation for Second Layer in Campo Florido PLP site

1 ro Esta tapando de piso 1ro

Pagina #01





Figure 6.1 Cover Soil Operation in Campo Florido PLP Site (1)

#2 nd Prepara de Entrada para piso 2ndo


Pagina #02



1. Cuando llena de Cerda 16-D, Construir el entrada para 2nda Piso de tierra de cantera
2. La Entrada de Vehiculo tiene #4.0m de Ancho
3. En Linea 16 y 17(final), se Cambian turno de tapado, como siguiente,
16E => 17E => 16D => 17D => 16C => 17C => 16B => 16A => 17B => 17A
4. La Entrada Talud de Piso 2nda va empesar la construction acabo de llenado de la Cerda de 17E.

Figure 6.2 Cover Soil Operation in Campo Frorido PLP Site (2)

#3 ro **Enpesar Cubierto piso segundo**



1. Tamano de Carda son 6mts de Larga, 10mts de Ancho

Figure 6.3 Cover Soil Operation in Campo Frorido PLP Site (3)

#4 to **Llenado en el Piso 2ndo**




Figure 6.4 Cover Soil Operation in Campo Frorido PLP Site (4)

#5 to Cubierto final de Piso 2nda




Figure 6.5 Cover Soil Operation in Campo Frorido PLP Site (5)

#6 to **Cubierto final de Piso 2nda**

Pagina #06




Figure 6.6 Cover Soil Operation in Campo Frorido PLP Site (6)

7. Improvement plan of Calle100 Landfill existing area at the Almendares riverside




Figure7.1 Actual Situation




Figure 7.2 Proposed Implementation Plan

C. Final Disposal:

C4 Cost of Leachate Treatment Alternatives

C4 COST OF LEACHATE TREATMENT ALTERNATIVES

Leachate Treatment alternatives for the Expansion of Calle 100

Alternative 1: Aerated Lagoon + Maturation Pond with recirculation -calle100 Expansion

(Remarks): Dimensions are at mid-depth. Height allowance should be 50 cm at least.

This system is the same as the one which was adopted in the original pilot project in Campo Florido. However, an aerated lagoon alone cannot remove T-BOD₅ and SS. Therefore, a maturation pond after the aerated lagoon is proposed.

1. Assumptions

1.1 There are no discharge quality criteria for treated leachate. Therefore, the following temporary criteria were proposed.

Table 1 Proposed Waste Quality Criteria

Leachate Quality	Unit-mg/L		
	T-BOD ₅	SS	S-BOD ₅
Inlet	920	540	600
Outlet	60	70	30
Removal rate (%)	93.5	87.0	95

Even though discharge quality criteria will be established in the future, only T-BOD₅ and SS are removed by this system.

There are formulas for estimating leachate generation, including one that considers evaporation; however, in the case of using a pond system as the final treatment, the pond volume is designed ignoring evaporation.

1) Leachate generation

Landfill Area

Stage1	A1	10.1 ha	10,800 m ²
Stage2	A2	8.4 ha	8,400 m ²
Stage3	A3	0.0 ha	0 m ²

Once the surface liner facility is constructed in the landfill site, it is assumed that no water flows into the landfill site

$$q = f \cdot C \cdot A \cdot I / 1000 \text{ (m}^3\text{/day)}$$

Where

q: Daily effluent amount of leachate water (m³/day)

c: Leachate coefficient of on-going landfill section 0.4

l: Annual maximum rainfall (mm/day)

Maximum rainfall during 2000 to 2002 38 mm in September, 2002
11.3 mm/day

A: Landfill area (m²)

f: Safety factor 16

Q: Daily effluent amount of leachate with safety factor (m³/day)

Table 2 Proposed Leachate Volume

Q (m ³ /day)	Stage1	Stage2	Stage3
	730	610	0

2. Leachate treatment

2.1 Aerated Lagoon Process Design

Design Base:

	Symbol	Unit	
Influent flow	Q	m ³ /d	
Influent suspended solids	SS0	mg/L	540
Influent soluble BOD ₅	S0	mg/L	920
Effluent soluble BOD ₅	S-BOD ₅	mg/L	30
Effluent suspended solids after settling	SSe	mg/L	70
Kinetic coefficients:		I/d	0.65
Y		mg-BOD ₅ /L	100
Ks		mg-BOD ₅ /L/d	6.0
Kmax		I/d	0.07
Kd	k (20)	I/d	2.5
First order soluble BoD5 removal rate constants at 20 °C	Ti	°C	21.0
Waste water temperature			
in leachate	α		0.6
in treated water	B		0.9
Oxygen concentration to be maintained in liquid		mg-O ₂ /L	1.5
Lagoon depth	H	m	3.5
Design mean cell - residence time	θc	d	14

2.2 Surface area of the lagoon

$$\theta_c = V/Q \quad \therefore \theta_c * Q \quad V: \text{volume of the lagoon}$$

$$A = V/H$$

Dimensions

Table 3 Dimensions of Aerated Lagoon

	Unit	Stage1	Stage2	Stage3
V	m ³	10,220	8,540	-
A	m ²	2,920	2,440	-
L	m	90	90	-
W	m	35	30	-
H	m	3.5	3.5	-
A'(Connected A)	m ³	3,150	200	-
V'(Connected V)	m ²	11,100	9,500	-

Number of lagoon:1

2.3 Soluble effluent BOD₅ at the lagoon outlet: S-BOD₅-out

$$S\text{-BOD}_5 \text{ out} = \{K_s (1+\theta c * k_d)\} / \{ \theta c (Y * k_{max} - k_d) - 1 \} (\text{mg/L})$$

K _s	θc*k _d	1+θc*k _d	K _s (1+θc*k _d)	θc	Y*k _{max}	Y*k _{max} -k _d	θc (Y*k _{max} -k _d)-1	S-BOD ₅ out
100	0.98	1.98	198	14	3.9	3.83	52.6	3.8

2.4 Effluent BOD₅

1) Correct the removal-rate for temperature effects

$$k(t) = k(20) * \theta^{T-20}$$

T _i	k ₍₂₀₎	T-20	θ	θ ^(T-20)	k ^{(20)θ^(T-20)}
21.0	2.5	1	1.06	1.06	2.7

2) Determine the effluent BOD₅: S_t-out (mg/L)

kt	V/Q	1+kV/Q	1/(1+kV/Q)	S ₀	S _t -out
2.7	14	38.10	0.03	920	24

2.5 Concentration of biological solids produced: X(mg.L)

$$X = Y(S_0 - S - \text{BOD}_{5\text{-out}}) / (1 + k_d \theta c) (\text{mg-VSS/L})$$

Y	S ₀ -S-BOD _{5-out}	k _d	θc	Y(S ₀ -S-BOD _{5-out})/(1+k _d θc)
0.65	916.2	0.07	14	301

2.6 Suspended solids in the lagoon before settling

$$SS_i = \text{Influent suspended solids} + X/0.7 (\text{mg/L})$$

SS ₀	X	SS _i
540	301	970

Ratio of volatile suspended solids 0.7

2.7 Oxygen requirements

$$Q_2 (\text{kg/d}) = Q(S_0 - S - \text{BOD}_{5\text{-out}}) / f - 1.42 P_x$$

f: conversion factor for BOD₅ to BODL 0.68

2.10 Energy requirements for mixing

Table 7 Specifications of Aerator

	Unit	Stage1	Stage2	Stage3
Power for Mixing	kW/m ³	0.005	0.005	-
Lagoon volume	m ³	11,100	9,500	-
Axis power for mixing	kW	55.5	47.5	-
Total efficiency	-	0.75	0.75	-
Required power	kW	74	63	-
Unit Power	kW/No.	15	15	-
No. of Aerators	Nos.	6	5	-

3. Solid separation for aerated lagoon

3.1 Design Base:

1) Process: maturation pond

2) HRT (days): t

3) Depth (m) D

Necessary Area (m²) A

$$A=Qt/d$$

Volume of the maturation pond (m³) V

$$V=A*D_0$$

The effluent SS may be expected to be at about 50-100 mg/L

Dimension Length L

width W

Height H

Table 8 Dimensions of Maturation Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
t	days	14	14	-
V	m ³	10,220	8,540	-
No.of Ponds	-	2	2	-
D ₀	m	1.5	1.5	-
A/pond	m ²	3,450	2,850	-
D/pond	m	100	90	-
W/pond	m	35	35	-
A'(corrected A)/pond	m ²	3,500	3,150	-

4. Leachate recirculation pump

1) Recirculation rate r times/leachate

Recirculation pump flow Q_r m³/day

$$Q_r = r*Q$$

Required Power Ps
 $ps=0.163*Qr(m^3/min)*H(m)/\eta$ Hose power
 Here
 Total head of the pump H m
 Total efficiency η
 Liquid density ps 1.05
 From the entrance of aerated lagoon to landfill

Table 9 Specifications of Leachate Recirculation Pump

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
r	-	3	3	-
Qr	m ³ /day	2,190	1,830	-
	m ³ /min	1.52	1.27	-
Head	m	50	50	-
η	-	0.56	0.56	-
Ps	Horse power	23.2	19.4	-
	kW	17.4	14.6	-
Unit power	kW/No.	19	19	-
Nos.of pumps	Nos.	(1+1)	(1+1)	-

5. Sludge accumulation

5.1 Mass of sludge accumulated in the basin each year without anaerobic decomposition

$$\text{Mass}=(SSi-SSe)(g/m^3)*10^{-3}(kg/g)*q(m^3/day)*365(\text{day/year})$$

SSi : SS from aerated lagoon

SSe : SS after solid separation

VSS: Volatile solids of the mass to be decomposition = 0.7*mass

Fixed solid = Mass-Volatile

Table 10 Accumulated Sludge

	Unit	Stage1	Stage2	Stage3
SSi	mg/L	970	970	-
SSe	mg/L	70	70	-
Q	m ³ /min	730	610	-
Mass	kg/year	239,800	200,400	-
Vss	kg/year	168,000	141,000	-
Fixed solid	kg/year	71,800	59,400	-

5.2 Amount of sludge to be accumulated at the end of ty years

Assumption

- 1) Maximum volatile solids reduction 75 %
- 2) it will occur within 1 year
- 3) deposited volatile suspended solids undergo a liner decomposition

Mass of volatile suspended solids accumulated at the end of 2 year:

$$(VSS)_t = \{0.75 + 0.25(t-1)\} * VSS \quad \text{kg}$$

Total mass of solids accumulated at the end of ty1 year

$$SS_t = V_{sst} + ty * \text{Fixed solid} \quad \text{kg}$$

Table 11 Accumulated Volatile Suspended Solids

	Unit	Stage1	Stage2	Stage3
VSS	kg/year	168,000	141,000	-
ty	year	2	2	-
(Vss) _t	kg	159,600	133,950	-
SS _t	kg	303,200	252,750	-

5.3 Required liquid volume and the dimensions for the sedimentation basin

1) Volume of sedimentation basin: V m³

$$V = t * q (\text{m}^3/\text{d})$$

2) Surface area of the sedimentation basin A m²

3) Effective depth of the solid -liquid separation m

Table 12 Required Liquid Volume

	Unit	Stage1	Stage2	Stage3
V	m ³	10,220	8,540	-
A'	m ²	7,000	6,300	-
D1	m	1.0	1.0	-

5.4 Depth required for the storage of sludge

1) the mass of accumulated sludge per square meter kg/m²

Accumulated mass of sludge: SS_t kg

mass per unit area kg/m²

Table 13 Accumulated Sludge per Square Meter

	Unit	Stage1	Stage2	Stage3
SSt	kg	303,200	252,750	-
A'	m ²	7,000	6,300	-
SSt/A	kg/m ²	43	40	-

2) Required depth

Vds: deposited solids accumulated %
 ρs: density of the sludge: ton/m³

The volume of sludge: Vsst (m³)

$$0.15 * Vsst \text{ (m}^3\text{)} * 1.06 * 103 \text{ (kg/m}^3\text{)} = \text{SSt (kg)}$$

Hs: the height of the sludge zone (m)

$$Vsst = H * A \quad Hs = Vsst / A \quad \text{m}$$

Table 14 Required Depth

	Unit	Stage1	Stage2	Stage3
Vds	%	15	15	-
ρs	ton/m ³	1.06	1.06	-
SSt	kg	303,200	252,750	-
Vsst	m ³	1,907	1,590	-
A	m ²	7,000	6,300	-
Hs	m	0.27	0.25	-

Alternative 2: Aerated Lagoon + Sedimentation Tank + Wetland with recirculation-Calle 100 Expansion

(Remarks): Dimensions are at mid-depth. Height allowance should be 50 cm at least.

This system is the same as the one which was adopted in the original pilot project in Campo Florido. However an aerated lagoon alone cannot remove T-BOD₅ and SS. Therefore a sedimentation pond and wetland were proposed.

1. Premises

1.1 There are no discharge quality criteria for treated leachate. Therefore, a temporary guideline was proposed as follows.

Table 15 Proposed Water Quality Criteria

Leachate Quality	Unit-mg/L		
	T-BOD ₅	SS	S-BOD ₅
Inlet	920	540	600
Outlet	60	70	30
Removal rate (%)	93.5	87.0	95

Even though discharge quality criteria are established in the future, only removal of T-BOD₅ and SS is considered by this system.

There are some estimation formula for leachate generation, including the one with the consideration of evaporation, however, in case of using pond system as the final treatment, pond volume is designed with ignoring evaporation.

1) Leachate generation

Landfill Area

Stage1	A1	10.1ha	10,800 m ²
Stage2	A2	8.4 ha	8,400 m ²
Stage3	A3	0.0 ha	0 m ²

Once surface liner facility is constructed in landfill site, it is assumed that no water flows into the landfill site

$$q = f \cdot C \cdot A \cdot I / 1000 (\text{m}^3/\text{day})$$

Where

q: Daily effluent amount of leachate water(m³/day)

c: Leachate coefficient of on-going landfill section 0.4

I: Annual maximum rainfall (mm/day)

Maximum rainfall during 2000 to 2002 38mm in September in 2002
11.3mm/day

A: Landfill area (m²)

f: Safety factor 16

Q: Daily effluent amount of leachate with safety factor (m³/day)

Table 16 Proposed Leachate Volume

Q (m ³ /day)	Stage1	Stage2	Stage3
	730	610	0

2. Leachate treatment

2.1 Aerated Lagoon Process Design

Design Base:

	Symbol	Unit	
Influent flow	Q	m ³ /d	
Influent suspended solids	SS0	mg/L	540
Influent soluble BOD ₅	S0	mg/L	920
Effluent soluble BOD ₅	S-BOD ₅	mg/L	30
Effluent suspended solid after settling	SSe	mg/L	70
Kinetic coefficients:		I/d	0.65
Y		mg-BOD ₅ /L	100
Ks		mg-BOD ₅ /L/d	6.0
Kmax		I/d	0.07
Kd	k (20)	I/d	2.5
First order soluble BOD ₅ removal rate constants at 20 °C	Ti	°C	21.0
Waste water temperature			
in leachate	α		0.6
in treated water	B		0.9
Oxygen concentration to be maintained in liquid		mg-O ₂ /L	1.5
Lagoon depth	H	m	3.5
Design mean cell - residence time	θc	d	14

2.2 Surface area of the lagoon

$$\theta_c = V/Q \quad \therefore \theta_c * Q = V \quad V: \text{volume of the lagoon}$$

$$A = V/H$$

Dimension

Table 17 Dimensions of Aerated Lagoon

	Unit	Stage1	Stage2	Stage3
V	m ³	10,220	8,540	-
A	m ²	2,920	2,440	-
L	m	90	90	-
W	m	35	30	-
H	m	3.5	3.5	-
A'(Connected A)	m ³	3,150	200	-
V'(Connected V)	m ²	11,100	9,500	-

Number of lagoon:1

2.3 Soluble effluent BOD₅ at the lagoon outlet: S-BOD₅-out

$$S\text{-BOD}_5 \text{ out} = \{K_s (1 + \theta_c * k_d)\} / \{ \theta_c (Y * k_{max} - k_d) - 1 \} (\text{mg/L})$$

Ks	$\theta_c \cdot kd$	$1 + \theta_c \cdot kd$	$K_s (1 + \theta_c \cdot kd)$	θ_c	$Y \cdot k_{max}$	$Y \cdot k_{max} - kd$	$\theta_c (Y \cdot k_{max} - kd) - 1$	S-BOD ₅ out
100	0.98	1.98	198	14	3.9	3.83	52.6	3.8

2.4 Effluent BOD₅

1) Correct the removal-rate for temperature effects

$$k(t) = k(20) \cdot \theta^{T-20}$$

Ti	$k_{(20)}$	T-20	θ	$\theta^{(T-20)}$	$k^{(20)\theta^{(T-20)}}$
21.0	2.5	1	1.06	1.06	2.7

2) Determine the effluent BOD₅: St-out (mg/L)

kt	V/Q	$1 + kV/Q$	$1/(1 + kV/Q)$	S ₀	St-out
2.7	14	38.10	0.03	920	24

2.5 Concentration of biological solids produced: X (mg.L)

$$X = Y (S_0 - S - \text{BOD}_{5-\text{out}}) / (1 + kd\theta_c) \text{ (mg-VSS/L)}$$

Y	$S_0 - S - \text{BOD}_{5-\text{out}}$	kd	θ_c	$Y(S_0 - S - \text{BOD}_{5-\text{out}}) / (1 + kd\theta_c)$
0.65	916.2	0.07	14	301

2.6 Suspended solids in the lagoon before settling

$$\text{SSi} = \text{Influent suspended solids} + X/0.7 \text{ (mg/L)}$$

SSo	X	SSi
540	301	970

Ratio of volatile suspended solid 0.7

2.7 Oxygen requirements

$$Q_2 \text{ (kg/d)} = Q(S_0 - S - \text{BOD}_{5-\text{out}}) / f - 1.42P_x$$

f: conversion factor for BOD₅ to BODL 0.68

$$P_x = Q \cdot (\text{concentration of biological solids produced})$$

Table 18 Required O₂

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
S ₀ -S-BOD _{5-out}	mg/L	916	916	-
f	-	0.68	0.68	-
Px	kg/day	220	183	-
Required O ₂	kg/day	672	561	-

2.8 Ratio of oxygen required to BOD₅ removed

BOD₅ removed (kg/d)

O₂/BOD₅ removed

Table 19 Removed BOD₅

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
S ₀ -S-BOD _{5-out}	mg/L	916	916	-
BOD ₅ removed	kg/day	669	559	-
O ₂ /BOD ₅	-	1.0	1.0	-

2.9 Surface aerator power requirements

assumption: kg-O₂/kw/h kg-O₂/kw/h No 1.6

a) Correction factor for surface aerators for summer conditions f

$f = N_o / N$

1) Oxygen saturation concentration at 21 °C C_s(21) mg/L 8.91

2) C_s(20) mg/L 9.08

3) Do concentration in Lagoon C_L mg/L 1.5

$$f = \{B \cdot C_s T - C_L\} / C_s (20) \cdot 1.024^{T-20} \cdot \alpha$$

Ti-20	1.024 ^{T-20}	α	B	f
1	1.029	0.6	0.9	0.44

b) Field transfer rate : N

N=fN_o kg-O₂/kw/h 0.71

Total amount of transfer O₂ kg-O₂/kw/d kg-O₂/kw/h 17.0

The total axis power required to meet the required oxygen

Table 20 Required O₂ Supply

	Unit	Stage1	Stage2	Stage3
Required O ₂	kg/day	672	561	-
Required power for O ₂ supply	kw	39.5	33.0	-

2.10 Energy requirements for mixing

Table 21 Specifications of Aerator

	Unit	Stage1	Stage2	Stage3
Power for Mixing	kW/m ³	0.005	0.005	-
Lagoon volume	m ³	11,100	9,500	-
Axis power for mixing	kW	55.5	47.5	-
Total efficiency	-	0.75	0.75	-
Required power	kW	74	63	-
Unit Power	kW/No.	15	15	-
No. of Aerator	Nos.	6	5	-

3. Solid separation for aerated lagoon

3.1 Design Base:

1) Process: maturation pond

2) HRT (days): t

3) Depth (m) D

Necessary Area (m²) A

$$A=Qt/d$$

Volume of the maturation pond (m³) V

$$V=A*D0$$

The effluent SS may be expected to be at about 50-100 mg/L

Dimension Length L
width W
Height H

Table 22 Dimension of Maturation Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
t	days	14	14	-
V	m ³	10,220	8,540	-
No.of Ponds	-	2	2	-
D ₀	m	1.5	1.5	-
A/pond	m ²	3,450	2,850	-
D/pond	m	100	90	-
W/pond	m	35	35	-
A'(corrected A)/pond	m ²	3,500	3,150	-

4. Solid-liquid separation: sedimentation tank

Qi: Inflow m³/day

Safety factor 3

R.t: Retention time at Qi*3 hr

OL: Overflow rate at $Q_i \cdot 3$	$m^3/m^2/day$
$Q_i \cdot C_i = Q_o \cdot C_o + Q_u \cdot C_u$	
Ci: Inflow SS	mg/L
Co: Outflow SS	mg/L
Cu: Concentrated SS in the sedimentation tank	mg/L
Qo: Outflow	m^3/day
Qu: Underflow (Sludge flow)	m^3/day
$Q_u = Q_i - Q_o$	m^3/day
$Q_o = Q_i \cdot (C_u - C_i) / (C_u - C_o)$	m^3/day
As: surface area = Q_o / OL	m^2
Dimension	
Ls: Length of sedimentation tank	m
Ws: Width of sedimentation tank	m
Hs: Height of sludge zone = V_s / A_s	m
Vs: Volume of sedimentation tank	m^3
H2: Height allowance = V_s / A_s	m^2

Table 23 Dimension of sedimentation tank

	Unit	Stage1	Stage2	Stage3
Q	m^3/day	730	610	-
Q_i	m^3/day	2,190	1,830	-
RT	hr	2	2	-
OL	$m^3/m^2/day$	22	22	-
Ci	mg/L	970	970	-
Co	mg/L	70	70	-
Cu	mg/L	5,000	5,000	-
Qo	m^3/day	1,800	1,500	-
As	m^2	90	70	-
Ls	m	20	20	-
Ws	m	5	5	-
Hs	m	2.2	2.3	-
Vs	m^3	190	160	-
Qu	m^3/day	390	330	-
H2	m	1.5	1.5	-
H0	m	3.7	3.8	-

Total Height $H_o = H_2 + H_s$

Sludge is returned to land fill

Pump specification

Head

Liquid density

5. To removal nutrients, use wetland.

Only by aerated lagoon, only BOD₅ and SS are removed. For further treatment for nutrients another process is necessary.

Here, wetland was considered as an alternative for this purpose, considering cost efficiency.

Levels of nitrogen and phosphates are estimated as below based on the analysis of leachate during this Study.

Total-N:	240	mg/L
Total-P:	64	mg/L

In biological treatment nitrogen and phosphate are necessary. The ratio of N and P towards BOD₅ is 3:0.3:100

Therefore N and P after biological treatment, their levels are expected as below.

Inlet BOD ₅	920	mg/L
Therefore N to be removed by biological treatment	27.6	mg/L

After aerated lagoon remained N	N	212	mg/L
	P	61	mg/L

Criteria*	
20	mg/L. as KTN
10	mg/L. as P

*:Discharge criteria of industrial waste water into general public water body

Inlet T-P level will be reduced by using cover soil.

Therefore, only removal of nitrogen would be considered.

Here, subsurface-flow (SSF) systems was considered.

In a SSF wetland, the basin is filled with gravel or some other coarse substrate, and the water level is maintained below-ground. Water flows horizontally, or sometimes vertically, through the gravel and the root mat of the wetland vegetation.

Arrow arum (Polyandry spp.) and Pickerel wee (Pontederia spp.) have been used in constructe wetlands.

Also common reed (Phragmitescommunis) is used




Figure 1 Conceptual diagram of subsurface-flow wetlands

Example of determination of basin design for SFS wetlands system

Nitrogen removal will proceed when BOD₅ level is less than 10 mg/L.

1. Premises

Influent BOD ₅	C ₀	60 mg/L
Effluent BOD ₅	Q	m ³ /day
		m ³ /day
Vegetation type		cattails
Minimum water temperature	T	21°C
Basin media		coarse sand with 2 mm of maximum effective size
Basin slope	S	0.01

2. Solution

1. Basin depth for use wit cattail	d	0.3m
2. Porosity	α	0.39
Hydraulic conductivity	K _s	480 m ³ /m ² /day
	K ₂₀	1.35
3. Temperature-dependent first order rate constant		
	K _T at	21°C
		1.49 d ⁻¹
4. Pore-space detention time	t ¹ =-1nCe/C0/Kt	d
5. Cross-sectional area	AC=Q/Ks/S	m ²
6. Basin width	W=Ac/d	m
7. Basin length	L=t'Q/W/d/α	m
8. Required surface area	As=L*W	m ²
		ha
9. Check hydraulic-loading rate or specific area requirements		
	L _w = Q/L/W	150 to 500 m ³ /ha/day
		0.015 to 0.005 m ³ /m ² /day
or	Asp= 1/Lw for advanced treatment	2.1 ha/10 ³ m ³
10. Check BOD ₅ loading rate	Max.BOD _{5L}	60kg/ha/day
LBOD ₅		kg/day
BOD _{5L}		kg/ha/day
11. Vegetation		
Reed can absprb	N	18 to 21g/kg
	P	2.0 to 3.0 g/kg
Inlet N		212.4 mg/L
Vd: vegetation density		10 kg/m ²

Table 24 Specification of Wetland

	Unit	Stage1	Stage2	Stage3
C0	mg/L	60	60	-
Ce	mg/L	8	8	-
Q	m ³ /day	730	610	-
T	°C	21.0	21.0	-
S		0.01	0.01	-
d	m	0.3	0.3	-
α		0.39	0.39	-
Ks	m ³ /m ² /day	480	480	-
K ₂₀		1.35	1.35	-
Kt	d ⁻¹	1.49	1.49	-
t'	day	1.36	1.36	-
Ac	m ²	1.52	1.27	-
W	m	510	430	-
L	m	17	16	-
As	m ²	8,500	7,100	-
Lw	m ³ /m ² /day	0.09	0.09	-
Asp	ha/1000m ³	11.60	11.60	-
L-BOD ₅	kg/day	43.8	36.6	-
BOD _{5L}	kg/ha/day	52	52	-
V	m ³	2,550	2,130	-
RT	day	3.5	3.5	-
Inlet N	mg/L	212	212	-
Total N in WL	g	550,000	460,000	-
N absorption	g/kg	18	18	-
Nos. of reed	kg	30,556	2,556	-
Vd	kg/m ²	10	10	-
Max Reed	kg	85,000	71,000	-

Alternative 3: Natural Pond System (Anaerobic + Facultative + Maturation Pond) -Calle 100 Expansion

(Remarks): Dimensions are at mid-depth. Height allowance should be 50 cm at least.

This system is so called natural pond system to remove BOD₅, SS and nutrients such as N and P.

1. Premises

1.1 There are no discharge quality criteria for treated leachate. Therefore, a temporary guideline was proposed as follows.

Table 25 Proposed Water Quality Criteria

Leachate Quality	Unit-mg/L		
	T-BOD ₅	SS	S-BOD ₅
Inlet	920	540	600
Outlet	60	70	30
Removal rate (%)	93.5	87.0	95

Even though discharge quality criteria are established in the future, only removal of T-BOD₅ and SS is considered by this system.

There are some estimation formula for leachate generation, including the one with the consideration of evaporation, however, in case of using pond system as the final treatment, pond volume is designed with ignoring evaporation.

1.2 Recirculation rate of leachate 3 times/day toward the leachate generated

2. Anaerobic pond

RTa: Retention time of anaerobic pond			7 days
BOD ₅ Removal rate			60%
BOD ₅ out-a			368 mg/L
Da: Depth of the anaerobic pond			3.5 m
Aa: Surface area			m ²
Va: Anaerobic pond volume			m ³
Dimension	Length	La	m
	Width	Wa	m
BOD _{5La} : BOD ₅ load of anaerobic pond			100 to 350 g-BOD ₅ /m ³ -pond/day

Table 26 Dimension of Anaerobic Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
R.T	days	7	7	-
Va	m ³	5,110	4,270	-
Da	m	3.5	3.5	-
Aa	m ²	1,460	1,220	-
La	m	60	60	-
Wa	m	25	22	-
BOD ₅	g/day	671,600	561,200	-
BOD _{5La}	g/m ³ /day	131	131	-

Number of ponds: 1

3. Facultative Pond

Is₁: BOD permissible loading kg/ha/day

$$Is_1 = 350 (1.107 - 0.002T)^{T-25}$$
100 to 400 kg/ha/day

or

$Is_2 = 20T-120$ kg/ha/day

Here, T: Minimum temperature 21 °C

Ls: BOD₅ loading

$Ls = 10 Li Q / Af$ kg/ha/day

Here,

Li: Inflow BOD₅ mg/L

Af: Facultative pond area m²

$Af = Q * (Li - Le) / 18D / (1.05)^{T-20}$

Here,

Le: Outflow BOD₅ mg/L

L_r: BOD₅ removal kg/ha/day

$Lr = 0.725Ls \div 10.75$

Df: Depth of the facultative pond m

Dimensions of facultative pond Length Lf m

Width Wf m

Table 27 Dimension of Sedimentation Tank

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
T	°C	21	21	-
ls ₁	kg/ha/day	272	272	-
ls ₂	kg/ha/day	300	300	-
Ls	kg/ha/day	269	270	-
Li	mg/L	368	368	-
Df	m	1.2	1.2	-
Af	m ²	10,000	8,300	-
Le	mg/L	60	60	-
Lr	kg/ha/day	206	207	-
BOD _{5RF}	%	76.5	76.5	-
BOD _{5out-f}	mg/L	87	87	-
R.T _f	days	16	16	-

Remarks:

- (a) There is a difference between ls₁ and ls₂. Adopt ls₁ for safety.
- (b) There is a difference between Le and BOD_{5out-f}. This is because Equations for Ls and Af are the one to get 60 mg/L-BOD₅ in South America.
- (c) On the contrary, the value of BOD_{5out-f} is calculated by the equation for Lr. Lr shows the average of the data arranged by MacGarry and Pescord.
- (d) The BOD₅ removal in primary facultative ponds is usually in the range 70-80 percent based on unfiltered samples (that is, including the BOD exerted by the algae).
Therefore, effluent BOD_{5out-f} level from facultative pond will be considered 60-117 mg/L with algae.
- (e) It is said BOD₅ quality of the effluent from a facultative ponds as most of the BOD contained (70 to 90%) will be "algal BOD. Therefore, the filtered (soluble) BOD₅ level will be at least 18-35 mg/L.

Table 28 Dimensions of Facultative Pond

	Unit	Stage1	Stage2	Stage3
Af	m ²	10,000	8,300	-
Nos. of ponds	-	2	2	-
Af/pond	m ²	5,000	4,150	-
Lf/pond	m	120	110	-
Wf/pond	m	45	40	-
Df	m	1.2	1.2	-
Vf/pond	m ³	6,480	5,280	-
Total Vf	m ³	12,960	10,560	-

Pond arrangement: Parallel

4. Maturation pond

Maturation ponds (low-cost polishing ponds, which succeed the primary or secondary facultative pond) are primarily designed for tertiary treatment, i.e., the removal of pathogens, nutrients and possibly algae.

With the combination of facultative pond and maturation pond,

- (1) Total nitrogen removal in WSP systems can reach 80 percent or more, and ammonia removal can be as high as 95 percent.
- (2) The best way of increasing phosphorus removal in WSP is to increase the number of

maturation ponds, so that progressively more and more phosphorus becomes immobilized in the sediments. From a well functioning 2 ponds system, 70% mass removal of total.

(3) The removal rate increases by adding maturation ponds.

Design criteria

D_m : Depth of maturation pond 4.5 m
 RT_m : Retention time of maturation pond 14 days
 A_m : Area of maturation pond

Dimensions of maturation pond

Length L_m m
 Width W_m m

Table 29 Dimensions of Maturation Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
RT_m	days	14	14	-
V_m	m ³	10,220	8,540	-
Nos. of Ponds	-	2	2	-
V_m /Pond	m ³	5,110	4,270	-
D_m /Pond	m	1.5	1.5	-
A_m /Pond	m ²	3,500	2,900	-
L_m /Pond	m	100	100	-
W_m /Pond	m	35	35	-

Pond arrangement: Series

5. Leachate Recirculation pump

Recirculation rate r times/leachate

Recirculation pump flow Q_r m³/day

$Q_r = r * Q$

Required Power P_s

$P_s = 0.163 * Q_r(m^3/min) * H(m) / \eta$ Horse power

Here

Total head of the pump H m

Total efficiency η

Liquid density ρ_s 1.05

From the entrance of anaerobic lagoon to landfill

Table 30 Specifications of Leachate Recirculation Pump

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
r	-	3	3	-
Qr	m ³ /day	2,190	1,830	-
	m ³ /min	1.52	1.27	-
Head	m	50	50	-
η	-	0.56	0.56	-
Ps	Horse power	23.2	19.4	-
	kW	17.4	14.6	-
Unit power	kW	19	19	-
Nos. of pumps	Nos.	(1+1)	(1+1)	-

Alternative 4: Natural Pond System (Anaerobic + Facultative + Wetland) -Calle 100 Expansion

(Remarks): Dimensions are at mid-depth. Height allowance should be 50 cm at least.

This system is an alternative to use wetland instead of Maturation Pond in Alternative 3 in order to remove nutrients such as N and P.

1. Premises

1.1 There are no discharge quality criteria for treated leachate. Therefore, a temporary guideline was proposed as follows.

Table 31 Proposed Water Quality Criteria

Leachate Quality	Unit-mg/L		
	T-BOD ₅	SS	S-BOD ₅
Inlet	920	540	600
Outlet	60	70	30
Removal rate (%)	93.5	87.0	95

Even though discharge quality criteria are established in the future, only removal of T-BOD₅ and SS is considered by this system.

There are some estimation formula for leachate generation, including the one with the consideration of evaporation, however, in case of using pond system as the final treatment, pond volume is designed with ignoring evaporation.

1.2 Recirculation rate of leachate 3 times/day toward the leachate generated

2. Anaerobic pond

RTa : Retention time of anaerobic pond			7 days
BOD ₅ Removal rate			60%
BOD ₅ out-a			368 mg/L
Da: Depth of the anaerobic pond			3.5 m
Aa: Surface area			m ²
Va: Anaerobic pond volume			m ³
Dimension	Length	La	m
	Width	Wa	m
BOD _{5La} : BOD ₅ load of anaerobic pond			100 to 350 g-BOD ₅ /m ³ -pond/day

Table 32 Dimension of Anaerobic Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
R.T	days	7	7	-
Va	m ³	5,110	4,270	-
Da	m	3.5	3.5	-
Aa	m ²	1,460	1,220	-
La	m	60	60	-
Wa	m	25	22	-
BOD ₅	g/day	671,600	561,200	-
BOD _{5La}	g/m ³ /day	131	131	-

Number of ponds: 1

3. Facultative Pond

ls₁: BOD permissible loading kg/ha/day
 $ls_1 = 350 (1.107 - 0.002T)^{T-25}$ 100 to 400 kg/ha/day

or

$ls_2 = 20T-120$ kg/ha/day
 Here, T: Minimum temperature 21 °C

Ls: BOD₅ loading

$Ls = 10 Li Q / Af$ kg/ha/day

Here,

Li: Inflow BOD₅ mg/L

Af: Facultative pond area m²

$Af = Q *(Li - Le)/18D/(1.05)^{T-20}$

Here,

Le: Outflow BOD₅ mg/L

L_r: BOD₅ removal kg/ha/day

$Lr = 0.725Ls \div 10.75$

Df: Depth of the facultative pond m

Dimensions of facultative pond Length Lf m

Width Wf m

Table 33 Dimension of Sedimentation Tank

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
T	°C	21	21	-
ls ₁	kg/ha/day	272	272	-
ls ₂	kg/ha/day	300	300	-
Ls	kg/ha/day	269	270	-
Li	mg/L	368	368	-
Df	m	1.2	1.2	-
Af	m ²	10,000	8,300	-
Le	mg/L	60	60	-
Lr	kg/ha/day	206	207	-
BOD _{5RF}	%	76.5	76.5	-
BOD _{5out-f}	mg/L	87	87	-
R.T _f	days	16	16	-

Remarks:

- There is a difference between ls₁ and ls₂. Adopt ls₁ for safety.
- There is a difference between Le and BOD_{5out-f}. This is because Equations for Ls and Af are the one to get 60 mg/L-BOD₅ in South America.
- On the contrary, the value of BOD_{5out-f} is calculated by the equation for Lr. Lr shows the average of the data arranged by MacGarry and Pescord.
- The BOD₅ removal in primary facultative ponds is usually in the range 70-80 percent based on unfiltered samples (that is, including the BOD exerted by the algae).
Therefore, effluent BOD_{5out-f} level from facultative pond will be considered 60-117 mg/L with algae.
- It is said BOD₅ quality of the effluent from a facultative ponds as most of the BOD contained (70 to 90%) will be "algal BOD. Therefore, the filtered (soluble) BOD₅ level will be at least 18-35 mg/L.

Table 34 Dimensions of Facultative Pond

	Unit	Stage1	Stage2	Stage3
Af	m ²	10,000	8,300	-
Nos. of ponds	-	2	2	-
Af/pond	m ²	5,000	4,150	-
Lf/pond	m	120	110	-
Wf/pond	m	45	40	-
Df	m	1.2	1.2	-
Vf/pond	m ³	6,480	5,280	-
Total Vf	m ³	12,960	10,560	-

Pond arrangement: Parallel

4. To removal nutrients, use wetland

Only by aerated lagoon, only BOD₅ and SS are removed. For further treatment for nutrients another process is necessary.

Here, wetland was considered as an alternative for this purpose, considering cost efficiency.

Levels of nitrogen and phosphates are estimated as below based on the analysis of leachate during this Study.

Total-N: 240 mg/L

Total-P: 64 mg/L

In biological treatment nitrogen and phosphate are necessary. The ratio of N and P towards BOD₅ is 3:0.3:100

Therefore N and P after biological treatment, their levels are expected as below.

Inlet BOD₅ 920 mg/L

Therefore N to be removed by biological treatment 27.6 mg/L

Therefore P to be removed by biological treatment 2.76 mg/L

After aerated lagoon remained N N 212 mg/L

P 61 mg/L

Criteria*	
20	mg/L. as KTN
10	mg/L. as P

*:Discharge criteria of industrial waste water into general public water body

Inlet T-P level will be reduced by using cover soil. Therefore, only removal of nitrogen would be considered.

Here, subsurface-flow (SSF) systems was considered.

In a SSF wetland, the basin is filled with gravel or some other coarse substrate, and the water level is maintained below-ground. Water flows horizontally, or sometimes vertically, through the gravel and the root mat of the wetland vegetation.

Arrow arum (Polyandry spp.) and Pickerel weed (Pontederia spp.) have been used in constructed wetlands.

Also common reed (Phragmitescommunis) is used




Figure 2 Conceptual diagram of subsurface-flow wetlands

Example of determination of basin design for SFS wetlands system

Nitrogen removal will proceed when BOD₅ level is less than 10 mg/L.

1. Premises

Influent BOD ₅	C ₀	60 mg/L
Effluent BOD ₅	C _e	8 mg/L
Inflow	Q	m ³ /day
		m ³ /day
Vegetation type		cattails
Minimum water temperature	T	21°C
Basin media		coarse sand with 2 mm of maximum effective size
Basin slope	S	0.01

2. Solution

1. Basin depth for use wit cattail	d	0.3 m
2. Porosity	α	0.39
Hydraulic conductivity	K _s	480 m ³ /m ² /day
	K ₂₀	1.35
3. Temperature-dependent first order rate constant	K _T at	21°C
		1.49 d ⁻¹
4. Pore-space detention time	$t' = -\ln C_e/C_0/K_t$	d
5. Cross-sectional area	$A_c = Q/K_s/S$	m ²
6. Basin width	$W = A_c/d$	m
7. Basin length	$L = t'Q/W/d/\alpha$	m
8. Required surface area	$A_s = L*W$	m ²
		ha
9. Check hydraulic-loading rate or specific area requirements	$L_w = Q/L/W$	150 to 500 m ³ /ha/day
		0.015 to 0.005 m ³ /m ² /day
or	$A_{sp} = 1/L_w$ for advanced treatment	2.1 ha/10 ³ m ³
10. Check BOD ₅ loading rate	Max.BOD _{5L}	60kg/ha/day
	LBOD ₅	kg/day
	BOD _{5L}	kg/ha/day
11. Vegetation		
Reed can absprb	N	18 to 21g/kg
	P	2.0 to 3.0 g/kg
Inlet N		240 mg/L
Vd: vegetation density		10 kg/m ²

Table 35 Specification of Wetland

	Unit	Stage1	Stage2	Stage3
C ₀	mg/L	87	87	-
C _e	mg/L	8	8	-
Q	m ³ /day	730	610	-
T	°C	21.0	21.0	-
S		0.01	0.01	-
d	m	0.3	0.3	-
α		0.39	0.39	-
K _s	m ³ /m ² /day	480	480	-
K ₂₀		1.35	1.35	-
K _t	d ⁻¹	1.49	1.49	-
t'	day	1.61	1.61	-
A _c	m ²	152	127	-
W	m	510	430	-
L	m	20	20	-
A _s	m ²	10,100	8,600	-
L _w	m ³ /m ² /day	0.07	0.07	-
A _{sp}	ha/1000m ³	13.74	14.10	-
L-BOD ₅	kg/day	63.5	53.07	-
BOD _{5L}	kg/ha/day	63	62	-
V	m ³	3,030	2,580	-
RT	day	4.2	4.2	-
Inlet N	mg/L	240	240	-
Total N in WL	g	730,000	620,000	-
N absorption	g/kg	18	18	-
Nos. of reed	kg	40,556	34,444	-
V _d	kg/m ²	10	10	-
Max Reed	kg	101,000	86,000	-

This system seems to be inferior in performance.

5. Leachate Recirculation pump

Recirculation rate r times/leachate

Recirculation pump flow Q_r m³/day

$$Q_r = r * Q$$

Required Power P_s

$$P_s = 0.163 * Q_r (\text{m}^3/\text{min}) * H (\text{m}) / \eta$$
Horse power

Here

Total head of the pump H m

Total efficiency η

Liquid density ρ_s 1.05

From the entrance of anaerobic lagoon to landfill

Table 36 Specifications of Leachate Recirculation Pump

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
r	-	3	3	-
Qr	m ³ /day	2,190	1,830	-
	m ³ /min	1.52	1.27	-
Head	m	50	50	-
η	-	0.56	0.56	-
Ps	Horse power	23.2	19.4	-
	kW	17.4	14.6	-
Unit power	kW	19	19	-
Nos. of pumps	Nos.	(1+1)	(1+1)	-

Alternative 5: Anaerobic Pond + Aerated Lagoon + Sedimentation Pond + Wetland with recirculation -Calle 100 Expansion

(Remarks): Dimensions are at mid-depth. Height allowance should be 50 cm at least.

This system is an alternative adding Anaerobic Pond to Alternative 2 in order to reduce area.

1. Premises

1.1 There are no discharge quality criteria for treated leachate. Therefore, a temporary guideline was proposed as follows.

Table 37 Proposed Water Quality Criteria

Leachate Quality	Unit-mg/L		
	T-BOD ₅	SS	S-BOD ₅
Inlet	920	540	600
Outlet	60	70	30
Removal rate (%)	93.5	87.0	95

Even though discharge quality criteria are established in the future, only removal of T-BOD₅ and SS is considered by this system.

There are some estimation formula for leachate generation, including the one with the consideration of evaporation, however, in case of using pond system as the final treatment, pond volume is designed with ignoring evaporation.

1.2 Recirculation rate of leachate 3 times/day toward the leachate generated

2. Anaerobic pond

RTa : Retention time of anaerobic pond			7 days
BOD ₅ Removal rate			60%
BOD ₅ out-a			368 mg/L
Da: Depth of the anaerobic pond			3.5 m
Aa: Surface area			m ²
Va: Anaerobic pond volume			m ³
Dimension	Length	La	m
	Width	Wa	m
BOD _{5La} : BOD ₅ load of anaerobic pond			100 to 350 g-BOD ₅ /m ³ -pond/day

Table 38 Dimension of Anaerobic Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
R.T	days	7	7	-
Va	m ³	5,110	4,270	-
Da	m	3.5	3.5	-
Aa	m ²	1,460	1,220	-
La	m	60	60	-
Wa	m	25	22	-
BOD ₅	g/day	671,600	561,200	-
BOD _{5La}	g/m ³ /day	131	131	-

Number of ponds: 1

3. Aerated Lagoon

3.1 Aerated Lagoon Process

Design Base:

	Symbol	Unit	
Influent flow	Q	m ³ /d	
Influent suspended solids	SS ₀	mg/L	378
Influent soluble BOD ₅	S ₀	mg/L	368
Effluent soluble BOD ₅	S-BOD _{5-out}	mg/L	30
Effluent suspended solid after setting	SSe	mg/L	70

Kinetic coefficients:

Y		l/d	0.65
K _s		mg-BOD ₅ /L	100
K _{max}		mg-BOD ₅ /L/d	6.0
K _d		l/d	0.07

First order soluble BOD₅ removal rate constants at 20 °C

	k ₍₂₀₎	l/d	2.5
Waste water temperature	T _i	°C	21.0

Aeration constants in leachate

in leachate	α		0.6
in treated water	β		0.9
Oxygen concentration to be maintained in liquid		mg - O ₂ /L	1.5
Lagoon depth	H	m	3.5
Design mean cell - residence time	θ _c	d	7

3.2 Surface area of the lagoon A m²

$$\theta c = V/Q \quad \therefore V = \theta c * Q \quad V: \text{volume of the lagoon}$$

$$A = V/H$$

Dimension

Table 39 Dimension of Aerated Lagoon

	Unit	Stage1	Stage2	Stage3
V	m ³	5,110	4,270	-
A	m ²	1,460	1,220	-
L	m	60	60	-
W	m	25	22	-
H	m	3.5	3.5	-
A' (corrected A)	m ²	1,500	1,320	-
V' (Corrected V)	m ³	5,300	4,700	-

3.3 Soluble effluent BOD₅ at the lagoon outlet: S-BOD₅-out

$$S\text{-BOD}_{5\text{out}} = \{ K_s (1 + \theta c * k_d) \} / \{ \theta c (Y * k_{\text{max}} - k_d) - I \} \quad (\text{mg/L})$$

Ks	$\theta c * k_d$	1+ $\theta c * k_d$	Ks (1+ $\theta c * k_d$)	θc	Y*kmax	Y*kmax-kd	$\theta c (Y * k_{\text{max}} - k_d) - I$	S-BOD ₅ out
100	0.49	1.49	149	7	3.9	3.83	25.8	5.8

3.4 Effluent BOD₅

(1) Correct the removal-rate for temperature effects

$$k(t) = k(20) * \theta^{T-20} \quad (\text{l/d})$$

Ti	k ₍₂₀₎	T-20	θ	$\theta^{(T-20)}$	k ₍₂₀₎ $\theta^{(T-20)}$
21.0	2.5	1	1.06	1.06	2.7

(2) Determine the effluent BOD₅: St_{-out} (mg/L)

$$St\text{-out}/S_0 = 1/(1+k\theta_H) = S/S_0 = 1/(1+kV/Q)$$

kt	V/Q	1+kV/Q	1/(1+kV/Q)	S ₀	St-out
2.7	14	19.55	0.05	368	19

3.5 Concentration of biological solids produced: X (mg/L)

$$X = Y (S_0 - S - \text{BOD}_{5\text{-out}}) / (1 + k_d \theta c) \quad (\text{mg-VSS/L})$$

Y	S ₀ -S-BOD _{5-out}	k _d	θc	Y(S ₀ -S-BOD _{5-out})/(1+k _d θc)
0.65	362.2	0.07	7	158

3.6 Suspended solids in the lagoon before settling

$$SS_i = \text{Influent suspended solids} + X/0.7(\text{mg/L})$$

Ratio of volatile suspended solid 0.7

SSo	X	SSi
378	158	604

3.7 Oxygen requirements

$$Q_2 (\text{kg/d}) = Q (S_0 - S - \text{BOD}_{5-\text{out}}) / f - 1.42P_x$$

f: conversion factor for BOD₅ to BOD_L 0.68

P_x = Q*(concentration of biological solids produced)

Table 40 Required O₂

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
S ₀ -S-BOD _{5-out}	mg/L	362	362	-
f	-	0.68	0.68	-
P _x	kg/day	115	96	-
Required O ₂	kg/day	225	188	-

3.8 Ratio of oxygen required to BOD₅ removed

BOD₅ removed (kg/d)

O₂/BOD₅ removed

Table 41 Removed BOD₅

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
S ₀ -S-BOD _{5-out}	mg/L	362.2	362.2	-
BOD ₅ removed	kg/day	264	221	-
O ₂ /BOD ₅	-	0.9	0.9	-

3.9 Surface aerator power requirements

assumption: kg-O₂/kw/h kg-O₂/kw/h No 1.6

a) Correction factor for surface aerators for summer conditions f

$$f = N_o/N$$

1) Oxygen saturation concentration at 21 °C Cs(21) mg/L 8.91

2) Cs(20) mg/L 9.08

3) DO concentration in Lagoon CL mg/L 1.5

$$f = \{B * C_s T - CL\} / C_s (20) * 1.024^{T-20} * \alpha$$

Ti-20	1.024^{T-20}	α	B	f
1	1.029	0.6	0.9	0.44

b) Field transfer rate : N

$$N = fN_0 \quad \text{kg-O}_2/\text{kw/h} \quad 0.71$$

$$\text{Total amount of transfer O}_2 \quad \text{kg-O}_2/\text{kw/d} \quad \text{kg-O}_2/\text{kw/h} \quad 17.0$$

The total axis power required to meet the required oxygen

Table 42 Required O₂ Supply

	Unit	Stage1	Stage2	Stage3
Required O ₂	kg/day	225	188	-
Required power for O ₂ supply	kW	13.2	11.1	-

3.10 Energy requirements for mixing

Table 43 Specifications of Aerator

	Unit	Stage1	Stage2	Stage3
Power for Mixing	kW/m ³	0.005	0.005	-
Lagoon volume	m ³	5,300	4,700	-
Axis power for mixing	kW	26.5	23.5	-
Total efficiency	-	0.75	0.75	-
Required power	kW	35	31	-
Required power per unit	kW/No.	11	7.5	-
Power for Mixing	Nos.	4	5	-

4. Leachate recirculation pump

Recirculation rate r times/leachate

Recirculation pump flow Q_r m³/day

$$Q_r = r \cdot Q$$

Required Power P_s

$$P_s = 0.163 \cdot Q_r (\text{m}^3/\text{min}) \cdot H (\text{m}) / \eta \quad \text{Horse power}$$

Here

Total head of the pump H m

Total efficiency η

Liquid density ρ_s 1.05

From the entrance of anaerobic lagoon to landfill

Table 44 Specifications of Leachate Recirculation Pump

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
r	-	3	3	-
Qr	m ³ /day	2,190	1,830	-
	m ³ /min	1.52	1.27	-
Head	m	50	50	-
η	-	0.56	0.56	-
Ps	Horse power	23.2	19.4	-
	kW	17.4	14.6	-
Unit power	kW/Nos.	19	19	-
Nos. of pumps	Nos.	(1+1)	(1+1)	-

5. Solid-liquid separation: sedimentation tank

Qi: Inflow	m ³ /day
Safety factor	3
R.t: Retention time at Qi*3	hr
OL: Overflow rate at Qi*3	m ³ /m ² /day
Qi*Ci = Qo*Co+Qu*Cu	
Ci: Inflow SS	mg/L
Co: Outflow SS	mg/L
Cu: Concentrated SS in the sedimentation tank	mg/L
Qo: Outflow	m ³ /day
Qu: Underflow (Sludge flow)	m ³ /day
Qu = Qi-Qo	m ³ /day
Qo = Qi*(Cu-Ci) / (Cu-Co)	m ³ /day
As: surface area=Qo/OL	m ³
Dimension	
Ls: Length of sedimentation tank	m
Ws: Width of sedimentation tank	m
Hs: Height of sludge zone =Vs/As	m
Vs: Volume of sedimentation tank	m ³
H ₂ : Height allowance = Vs/As	m ²

Table 45 Dimension of Sedimentation Tank

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
Qi	m ³ /day	2,190	1,830	-
R.T	hr	2	2	-
O _L	m ³ /m ² /day	22	22	-
C _i	mg/L	604	604	-
C _o	mg/L	70	70	-
C _u	mg/L	5,000	5,000	-
Q _o	m ³ /day	2,000	1,600	-
A _s	m ²	100	80	-
L _s	m	20	20	-
W _s	m	5	5	-
H _s	m	1.9	2.0	-
V _s	m ³	190	160	-
Q _u	m ³ /day	190	230	-
H ₂	m	1.5	1.5	-
H ₀	m	3.4	3.5	-

6. To removal nutrients, use wetland.

Only by aerated lagoon, only BOD₅ and SS are removed. For further treatment for nutrients another process is necessary.

Here, wetland was considered as an alternative for this purpose, considering cost efficiency.

Levels of nitrogen and phosphates are estimated as below based on the analysis of leachate during this Study.

Total-N:	240	mg/L
Total-P:	64	mg/L

In biological treatment nitrogen and phosphate are necessary. The ratio of N and P towards BOD₅ is 3:0.3:100

Therefore N and P after biological treatment, their levels are expected as below.

Inlet BOD ₅	920	mg/L	
Therefore N to be removed by biological treatment	27.6	mg/L	
Therefore P to be removed by biological treatment	2.76	mg/L	
After aerated lagoon remained N	N	212	mg/L
	P	61	mg/L

Criteria*	
20	mg/L. as KTN
10	mg/L. as P

*:Discharge criteria of industrial waste water into general public water body

Inlet T-P level will be reduced by using cover soil.


Therefore, only removal of nitrogen would be considered.

Here, subsurface-flow (SSF) systems was considered.

In a SSF wetland, the basin is filled with gravel or some other coarse substrate, and the water level is maintained below-ground. Water flows horizontally, or sometimes vertically, through the gravel and the root mat of the wetland vegetation.

Arrow arum (*Polyandry* spp.) and Pickerel weed (*Pontederia* spp.) have been used in constructed wetlands.

Also common reed (*Phragmites communis*) is used



**Figure 3 Conceptual diagram of
subsurface-flow wetlands**

Example of determination of basin design for SFS wetlands system

Nitrogen removal will proceed when BOD₅ level is less than 10 mg/L.

1. Premises

Influent BOD ₅	C ₀	60 mg/L
Effluent BOD ₅	C _e	8 mg/L
Inflow	Q	m ³ /day
		m ³ /day
Vegetation type		cattails
Minimum water temperature	T	21°C
Basin media		coarse sand with 2 mm of maximum effective size
Basin slope	S	0.01

2. Solution

1. Basin depth for use wit cattail	d	0.3 m
2. Porosity	α	0.39
Hydraulic conductivity	K _s	480 m ³ /m ² /day
	K ₂₀	1.35
3. Temperature-dependent first order rate constant	K _T at	21°C
		1.49 d ⁻¹
4. Pore-space detention time	$t' = -\ln C_e/C_0/K_t$	d
5. Cross-sectional area	$A_c = Q/K_s/S$	m ²
6. Basin width	$W = A_c/d$	m
7. Basin length	$L = t'Q/W/d/\alpha$	m
8. Required surface area	$A_s = L*W$	m ²
		ha
9. Check hydraulic-loading rate or specific area requirements	$L_w = Q/L/W$	150 to 500 m ³ /ha/day
		0.015 to 0.005 m ³ /m ² /day
or	$A_{sp} = 1/L_w$ for advanced treatment	2.1 ha/10 ³ m ³
10. Check BOD ₅ loading rate	Max.BOD _{5L}	60 kg/ha/day
LBOD ₅		kg/day
BOD _{5L}		kg/ha/day
11. Vegetation		
Reed can absorb	N	18 to 21 g/kg
	P	2.0 to 3.0 g/kg
Inlet N		212.4 mg/L
Vd: vegetation density		10 kg/m ²

Table 46 Specification of Wetland

	Unit	Stage1	Stage2	Stage3
C ₀	mg/L	60	60	-
C _e	mg/L	8	8	-
Q	m ³ /day	730	610	-
T	°C	21.0	21.0	-
S		0.01	0.01	-
d	m	0.3	0.3	-
α		0.39	0.39	-
K _s	m ³ /m ² /day	480	480	-
K ₂₀		1.35	1.35	-
K _t	d ⁻¹	1.49	1.49	-
t'	day	1.36	1.36	-
A _c	m ²	152	127	-
W	m	510	430	-
L	m	17	16	-
A _s	m ²	8,500	7,100	-
L _w	m ³ /m ² /day	0.09	0.09	-
A _{sp}	ha/1000m ³	11.60	11.60	-
L-BOD ₅	kg/day	43.8	36.6	-
BOD _{5L}	kg/ha/day	52	52	-
V	m ³	2,550	2,130	-
R.T	day	3.5	3.5	-
Inlet N	mg/L	212	212	-
Total N in WL	g	550,000	460,000	-
N absorption	g/kg	18	18	-
Nos. of reed	kg	30,556	25,556	-
V _d	kg/m ²	10	10	-
Max Reed	kg	85,000	71,000	-

**Alternative 6: Anaerobic Pond + Aerated Lagoon + Maturation Pond with recirculation
-Calle 100 Expansion**

(Remarks): Dimensions are at mid-depth. Height allowance should be 50 cm at least.

This system is an alternative adding Anaerobic Pond to Alternative 1 to reduce area.

1. Premises

1.1 There are no discharge quality criteria for treated leachate. Therefore, a temporary guideline was proposed as follows.

Table 47 Proposed Water Quality Criteria

Leachate Quality	Unit-mg/L		
	T-BOD ₅	SS	S-BOD ₅
Inlet	920	540	600
Outlet	60	70	30
Removal rate (%)	93.5	87.0	95

Even though discharge quality criteria are established in the future, only removal of T-BOD₅ and SS is considered by this system.

There are some estimation formula for leachate generation, including the one with the consideration of evaporation, however, in case of using pond system as the final treatment, pond volume is designed with ignoring evaporation.

1.2 Recirculation rate of leachate 3 times/day toward the leachate generated

2. Anaerobic pond

RTa: Retention time of anaerobic pond			7 days
BOD ₅ Removal rate			60%
BOD ₅ out-a			368 mg/L
Da: Depth of the anaerobic pond			3.5 m
Aa: Surface area			m ²
Va: Anaerobic pond volume			m ³
Dimension	Length	La	m
	Width	Wa	m
BOD _{5La} : BOD ₅ load of anaerobic pond			100 to 350 g-BOD ₅ /m ³ -pond/day

Table 48 Dimension of Anaerobic Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
R.T	days	7	7	-
Va	m ³	5,110	4,270	-
Da	m	3.5	3.5	-
Aa	m ²	1,460	1,220	-
La	m	60	60	-
Wa	m	25	22	-
BOD ₅	g/day	671,600	561,200	-
BOD _{5La}	g/m ³ /day	131	131	-

Number of ponds: 1

3. Aerated Lagoon

3.1 Aerated Lagoon Process

Design Base:

	Symbol	Unit	
Influent flow	Q	m ³ /d	
Influent suspended solids	SS ₀	mg/L	378
Influent soluble BOD ₅	S ₀	mg/L	368
Effluent soluble BOD ₅	S-BOD _{5-out}	mg/L	30
Effluent suspended solid after setting	S _{Se}	mg/L	70

Kinetic coefficients:

Y		l/d	0.65
K _s		mg-BOD ₅ /L	100
K _{max}		mg-BOD ₅ /L/d	6.0
K _d		l/d	0.07

First order soluble BOD₅ removal rate constants at 20 °C

	k ₍₂₀₎	l/d	2.5
Waste water temperature	T _i	°C	21.0

Aeration constants in leachate

in leachate	α		0.6
in treated water	β		0.9
Oxygen concentration to be maintained in liquid		mg - O ₂ /L	1.5
Lagoon depth	H	m	3.5
Design mean cell - residence time	θ _c	d	7

3.2 Surface area of the lagoon A m²

$$\theta c = V/Q \quad \therefore V = \theta c * Q \quad V: \text{volume of the lagoon}$$

$$A = V/H$$

Dimension

Table 49 Dimension of Aerated Lagoon

	Unit	Stage1	Stage2	Stage3
V	m ³	5,110	4,270	-
A	m ²	1,460	1,220	-
L	m	60	60	-
W	m	25	22	-
H	m	3.5	3.5	-
A' (corrected A)	m ²	1,500	1,320	-
V' (Corrected V)	m ³	5,300	4,700	-

3.3 Soluble effluent BOD₅ at the lagoon outlet: S-BOD₅-out

$$S\text{-BOD}_{5\text{out}} = \{ K_s (1 + \theta c * k_d) \} / \{ \theta c (Y * k_{\text{max}} - k_d) - I \} \quad (\text{mg/L})$$

Ks	$\theta c * k_d$	$1 + \theta c * k_d$	$K_s (1 + \theta c * k_d)$	θc	$Y * k_{\text{max}}$	$Y * k_{\text{max}} - k_d$	$\theta c (Y * k_{\text{max}} - k_d) - I$	S-BOD ₅ out
100	0.49	1.49	149	7	3.9	3.83	25.8	5.8

3.4 Effluent BOD₅

(1) Correct the removal-rate for temperature effects

$$k(t) = k(20) * \theta^{T-20} \quad (\text{l/d})$$

Ti	$k_{(20)}$	T-20	θ	$\theta^{(T-20)}$	$k_{(20)} \theta^{(T-20)}$
21.0	2.5	1	1.06	1.06	2.7

(2) Determine the effluent BOD₅: St_{-out} (mg/L)

$$St\text{-out}/S_0 = 1/(1+k\theta_H) = S/S_0 = 1/(1+kV/Q)$$

kt	V/Q	$1+kV/Q$	$1/(1+kV/Q)$	S ₀	St-out
2.7	14	19.55	0.05	368	19

3.5 Concentration of biological solids produced: X (mg/L)

$$X = Y (S_0 - S\text{-BOD}_{5\text{-out}}) / (1 + k_d \theta c) \quad (\text{mg-VSS/L})$$

Y	$S_0 - S\text{-BOD}_{5\text{-out}}$	k_d	θc	$Y(S_0 - S\text{-BOD}_{5\text{-out}}) / (1 + k_d \theta c)$
0.65	362.2	0.07	7	158

3.6 Suspended solids in the lagoon before settling

$$SS_i = \text{Influent suspended solids} + X/0.7(\text{mg/L})$$

Ratio of volatile suspended solid 0.7

SSo	X	SSi
378	158	604

3.7 Oxygen requirements

$$Q_2 (\text{kg/d}) = Q (S_0 - S - \text{BOD}_{5-\text{out}}) / f - 1.42P_x$$

f: conversion factor for BOD₅ to BOD_L 0.68

P_x = Q*(concentration of biological solids produced)

Table 50 Required O₂

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
S ₀ -S-BOD _{5-out}	mg/L	362	362	-
f	-	0.68	0.68	-
P _x	kg/day	115	96	-
Required O ₂	kg/day	225	188	-

3.8 Ratio of oxygen required to BOD₅ removed

BOD₅ removed (kg/d)

O₂/BOD₅ removed

Table 51 Removed BOD₅

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
S ₀ -S-BOD _{5-out}	mg/L	362.2	362.2	-
BOD ₅ removed	kg/day	264	221	-
O ₂ /BOD ₅	-	0.9	0.9	-

3.9 Surface aerator power requirements

assumption: kg-O₂/kw/h kg-O₂/kw/h No 1.6

a) Correction factor for surface aerators for summer conditions f

$$f = N_o/N$$

1) Oxygen saturation concentration at 21 °C Cs(21) mg/L 8.91

2) Cs(20) mg/L 9.08

3) DO concentration in Lagoon CL mg/L 1.5

$$f = \{B * C_s T - CL\} / C_s (20) * 1.024^{T-20} * \alpha$$

Ti-20	1.024^{T-20}	α	B	f
1	1.029	0.6	0.9	0.44

b) Field transfer rate: N

$$N = fN_0 \quad \text{kg-O}_2/\text{kw/h} \quad 0.71$$

$$\text{Total amount of transfer O}_2 \quad \text{kg-O}_2/\text{kw/d} \quad \text{kg-O}_2/\text{kw/h} \quad 17.0$$

The total axis power required to meet the required oxygen

Table 52 Required O₂ Supply

	Unit	Stage1	Stage2	Stage3
Required O ₂	kg/day	225	188	-
Required power for O ₂ supply	kW	13.2	11.1	-

3.10 Energy requirements for mixing

Table 53 Specifications of Aerator

	Unit	Stage1	Stage2	Stage3
Power for Mixing	kW/m ³	0.005	0.005	-
Lagoon volume	m ³	5,300	4,700	-
Axis power for mixing	kW	26.5	23.5	-
Total efficiency	-	0.75	0.75	-
Required power	kW	35	31	-
Unit power	kW/No.	11	7.5	-
No. of Aerator	Nos.	(4+1)	(5+1)	-

4. Leachate recirculation pump

Recirculation rate r times/leachate

Recirculation pump flow Q_r m³/day

$$Q_r = r \cdot Q$$

Required Power P_s

$$P_s = 0.163 \cdot Q_r (\text{m}^3/\text{min}) \cdot H (\text{m}) / \eta \quad \text{Horse power}$$

Here

Total head of the pump H m

Total efficiency η

Liquid density ρ_s 1.05

From the entrance of anaerobic lagoon to landfill

Table 54 Specifications of Leachate Recirculation Pump

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
r	-	3	3	-
Qr	m ³ /day	2,190	1,830	-
	m ³ /min	1.52	1.27	-
Head	m	50	50	-
η	-	0.56	0.56	-
Ps	Horse power	23.2	19.4	-
	kW	17.4	14.6	-
Unit power	kW	19	19	-
Nos. of pumps	Nos.	(1+1)	(1+1)	-

5. Maturation Pond

Design criteria

D_m : Depth of maturation pond 1.5 m

RT_m : Retention time of maturation pond 14 days

A_m : Area of maturation pond

Dimensions of maturation pond

Length Lm m

Width Wm m

Table 55 Dimensions of Maturation Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	730	610	-
RT_m	days	14	14	-
V_m	m ³	10,220	8,540	-
Nos. of Ponds	-	2	2	-
V_m /Pond	m ³	5,110	4,270	-
D_m /Pond	m	1.5	1.5	-
A_m /Pond	m ²	3,500	2,900	-
L_m /Pond	m	100	100	-
W_m /Pond	m	35	35	-

Pond arrangement: Series

Leachate Treatment Alternatives of New Site-1

Alternative 1: Aerated Lagoon + Maturation Pond with recirculation -New Site 1

(Remarks): Dimensions are at mid-depth. Height allowance should be 50 cm at least.

This system is the same as the one which was adopted in the original pilot project in Campo Florido. However only aerated lagoon can not remove T-BOD₅ and SS. Therefore maturation pond after aerated lagoon was proposed.

1. Premises

1.1 There are no discharge quality criteria for treated leachate. Therefore, a temporary guideline was proposed as follows.

Table 56 Proposed Water Quality Criteria

Leachate Quality	Unit-mg/L		
	T-BOD ₅	SS	S-BOD ₅
Inlet	920	540	600
Outlet	60	70	30
Removal rate (%)	93.5	87.0	95

Even though discharge quality criteria are established in the future, only removal of T-BOD₅ and SS is considered by this system.

There are some estimation formula for leachate generation, including the one with the consideration of evaporation, however, in case of using pond system as the final treatment, pond volume is designed with ignoring evaporation.

1) Leachate generation

Stage1	A ₁	13.41 ha	134,000 m ²
Stage2	A ₂	8.4 ha	84,000 m ²
Stage3	A ₃	0.0 ha	0 m ²

Once surface liner facility is constructed in landfill site, it is assumed that no water flows into the landfill site

$$q = f \cdot C \cdot A \cdot I / 1000 \text{ (m}^3\text{/day)}$$

Where

q: Daily effluent amount of leachate water(m³/day)

C: Leachate coefficient of on-going landfill section 0.4

I: Annual maximum rainfall (mm/day)

Maximum rainfall during 2000 to 2002 338 mm in September in 2002
11.3 mm/day

A: Landfill area (m²)

f: Safety factor 1.6

Q: Daily effluent amount of leachate with safety factor (m³/day)

Table 57 Proposed Leachate Volume

Q (m ³ /day)	Stage1	Stage2	Stage3
	730	610	0

2. Leachate treatment

2.1 Aerated Lagoon Process Design

Design Base:

	Symbol	Unit	
Influent flow	Q	m ³ /d	
Influent suspended solids	SS ₀	mg/L	540
Influent soluble BOD ₅	S ₀	mg/L	920
Effluent soluble BOD ₅	S-BOD _{5-out}	mg/L	30
Effluent suspended solid after settling	SSe	mg/L	70
Kinetic coefficients:		l/d	0.65
Y		mg-BOD ₅ /L	100
Ks		mg-BOD ₅ /L/d	6.0
Kmax		l/d	0.07
Kd	k ₍₂₀₎	l/d	2.5
First order soluble BOD ₅ removal rate constants at 20 °C	Ti	°C	21.0
Waste water temperature			
in leachate	α		0.6
in treated water	β		0.9
Oxygen concentration to be maintained in liquid		mg-O ₂ /L	1.5
Lagoon depth	H	m	3.5
Design mean cell - residence time	θc	d	14

2.2 Surface area of the lagoon

$$\theta c = V/Q \quad \therefore V = \theta c * Q \quad V: \text{volume of the lagoon}$$

$$A = V/H$$

Dimension

Table 58 Dimensions of Aerated Lagoon

	Unit	Stage1	Stage2	Stage3
V	m ³	13,580	8,540	-
A	m ²	3,880	2,440	-
L	m	100	90	-
W	m	40	30	-
H	m	-	-	-
A' (Connected A)	m ²	4,000	2,700	-
V' (Connected V)	m ³	14,000	9,500	-

Number of lagoon: 1

2.3 Soluble effluent BOD₅ at the lagoon outlet: S-BOD_{5-out}

$$S\text{-BOD}_5 \text{ out} = \{Ks (1+\theta c * kd)\} / \{ \theta c (Y * kmax - kd) - 1 \} (mg/L)$$

Ks	$\theta_c \cdot kd$	$1 + \theta_c \cdot kd$	$Ks (1 + \theta_c \cdot kd)$	θ_c	$Y \cdot k_{max}$	$Y \cdot k_{max} - kd$	$\theta_c (Y \cdot k_{max} - kd) - 1$	S-BOD ₅ out
100	0.98	1.98	198	14	3.9	3.83	52.6	3.8

2.4 Effluent BOD₅

1) Correct the removal-rate for temperature effects

$$k(t) = k(20) \cdot \theta^{T-20}$$

Ti	$k_{(20)}$	T-20	θ	$\theta^{(T-20)}$	$k_{(20)} \theta^{(T-20)}$
21.0	2.5	1	1.06	1.06	2.7

2) Determine the effluent BOD₅: St-out (mg/L)

kt	V/Q	$1 + kV/Q$	$1/(1 + kV/Q)$	S ₀	St-out
2.7	14	38.10	0.30	920	24

2.5 Concentration of biological solids produced : X(mg.L)

$$X = Y(S_0 - S - BOD_{5-out}) / (1 + kd\theta_c) \text{ (mg-VSS/L)}$$

Y	$S_0 - S - BOD_{5-out}$	kd	θ_c	$Y(S_0 - S - BOD_{5-out}) / (1 + kd\theta_c)$
0.65	916.2	0.07	14	301

2.6 Suspended solids in the lagoon before settling

$$SS_i = \text{Influent suspended solids} + X/0.7 \text{ (mg/L)}$$

SS ₀	X	SS _i
540	301	970

Ratio of volatile suspended solid 0.7

2.7 Oxygen requirements

$$Q_2 \text{ (kg/d)} = Q(S_0 - S - BOD_{5-out}) / f - 1.42Px$$

f: conversion factor for BOD₅ to BODL 0.68

$$Px = Q \cdot (\text{concentration of biological solids produced})$$

2.10 Energy requirements for mixing

Table 62 Specifications of Aerator

	Unit	Stage1	Stage2	Stage3
Power for Mixing	kW/m ³	0.005	0.005	-
Lagoon volume	m ³	14,000	9,500	-
Axis power for mixing	kW	70	47.5	-
Total efficiency	-	0.75	0.75	-
Required power	kW	93	63	-
Unit Power	kW/No.	15	15	-
No. of Aerator	Nos.	7	5	-

3. Solid separation for aerated lagoon

3.1 Design Base:

1) Process: maturation pond

2) HRT (days): t

3) Depth (m) D

Necessary Area (m²) A

$$A = Qt/d$$

Volume of the maturation pond (m³) V

$$V = A * D0$$

The effluent SS may be expected to be at about 50-100 mg/L

Dimension Length L

Width W

Height H

Table 63 Dimension of Maturation Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
t	days	14	14	-
V	m ³	13,580	8,540	-
No. of Ponds	-	2	2	-
D ₀	m	1.5	1.5	-
A/pond	m ²	4,550	2,850	-
D/pond	m	120	90	-
W/pond	m	40	35	-
A' (corrected A)/pond	m ²	4,800	3,150	-

4. Leachate recirculation pump

1) Recirculation rate r times/leachate

Recirculation pump flow Q_r m³/day

$$Q_r = r * Q$$

Required Power Ps
 $Ps = 0.163 * Q_r(m^3/min) * H(m) / \eta$ Hose power

Here

Total head of the pump H m
 Total efficiency η
 Liquid density ρ_s 1.05

From the entrance of aerated lagoon to landfill

Table 64 Specifications of Leachate Recirculation Pump

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
r	-	3	3	-
Q _r	m ³ /day	2,910	1,830	-
	m ³ /min	2.02	1.27	-
Head	m	50	50	-
η	-	0.56	0.56	-
Ps	Horse power	15.4	19.4	-
	kW	19.6	14.6	-
Unit power	kW/No.	15	19	-
Nos. of pumps	Nos.	(2+1)	(1+1)	-

5. Sludge accumulation

5.1 Mass of sludge accumulated in the basin each year without anaerobic decomposition

$$\text{Mass} = (SS_i - SS_e) (g/m^3) * 10^{-3} (kg/g) * q (m^3/day) * 365 (\text{day/year})$$

SS_i: SS from aerated lagoon

SS_e: SS after solid separation

VSS: Volatile solids of the mass to be decomposition = 0.7 * mass

Fixed solid = Mass - Volatile

Table 65 Accumulated Sludge

	Unit	Stage1	Stage2	Stage3
SS _i	mg/L	970	970	-
SS _e	mg/L	70	70	-
Q	m ³ /min	970	610	-
Mass	kg/year	318,600	200,400	-
V _{ss}	kg/year	224,000	141,000	-
Fixed solid	kg/year	94,600	59,400	-

5.2 Amount of sludge to be accumulated at the end of ty years

Assumption

- 1) Maximum volatile solids reduction 75 %
- 2) it will occur within 1 year
- 3) deposited volatile suspended solids undergo a liner decomposition

Mass of volatile suspended solids accumulated at the end of 2 year:

$$(VSS)_t = \{0.75 + 0.25(t-1)\} * VSS \quad \text{kg}$$

Total mass of solids accumulated at the end of ty-1 year

$$SS_t = V_{sst} + ty * \text{Fixed solid} \quad \text{kg}$$

Table 66 Accumulated Volatile Suspended Solids

	Unit	Stage1	Stage2	Stage3
VSS	kg/year	224,000	141,000	-
ty	year	2	2	-
(Vss)t	kg	212,800	133,950	-
SSt	kg	402,000	252,750	-

5.3 Required liquid volume and the dimensions for the sedimentation basin

- 1) Volume of sedimentation basin: V m³

$$V = t * q (\text{m}^3/\text{d})$$

- 2) Surface area of the sedimentation basin A m²

- 3) Effective depth of the solid -liquid separation m

Table 67 Required Liquid Volume

	Unit	Stage1	Stage2	Stage3
V	m ³	13,580	8,540	-
A'	m ²	9,600	6,300	-
Dl	m	1.0	1.0	-

5.4 Depth required for the storage of sludge

- 1) the mass of accumulated sludge per square meter kg/m²

Accumulated mass of sludge: SSt kg

mass per unit area kg/m²

Table 68 Accumulated Sludge per Square Meter

	Unit	Stage1	Stage2	Stage3
SSt	kg	402,000	252,750	-
A'	m ²	9,600	6,300	-
SSt/A	kg/m ²	42	40	-

2) Required depth

V_{ds}: deposited solids accumulated to the extend of %
 ρ_s: density of the sludge: ton/m³
 The volume of sludge: V_{sst} (m³)
 $0.15 * V_{sst} (m^3) * 1.06 * 10^3 (kg/m^3) = SSt (kg)$
 H_s: the height of the sludge zone (m)
 $V_{sst} = H * A \quad H_s = V_{sst} / A$ m

Table 69 Required Depth

	Unit	Stage1	Stage2	Stage3
V _{ds}	%	15	15	-
ρ _s	ton/m ³	1.06	1.06	-
SSt	kg	402,000	252,750	-
V _{sst}	m ³	2,528	1,590	-
A	m ²	9,600	6,300	-
H _s	m	0.26	0.25	-

**Alternative 2: Aerated Lagoon + Sedimentation Pond + Wetland with recirculation
-New Site 1**

(Remarks): Dimensions are at mid-depth. Height allowance should be 50 cm at least.

This system is the same as the one which was adopted in the original pilot project in Campo Florido. However only aerated lagoon can not remove T-BOD₅ and SS. Therefore sedimentation pond and wetland were proposed.

1. Premises

1.1 There are no discharge quality criteria for treated leachate. Therefore, a temporary guideline was proposed as follows.

Table 70 Proposed Water Quality Criteria

Leachate Quality	Unit-mg/L		
	T-BOD ₅	SS	S-BOD ₅
Inlet	920	540	600
Outlet	60	70	30
Removal rate (%)	93.5	87.0	95

Even though discharge quality criteria are established in the future, only removal of T-BOD₅ and SS is considered by this system.

There are some estimation formula for leachate generation, including the one with the consideration of evaporation, however, in case of using pond system as the final treatment, pond volume is designed with ignoring evaporation.

1) Leachate generation

Landfill Area

Stage1	A ₁	13.41 ha	134,000 m ²
Stage2	A ₂	8.4 ha	84,000 m ²
Stage3	A ₃	0.0 ha	0 m ²

Once surface liner facility is constructed in landfill site, it is assumed that no water flows into the landfill site

$$q = f \cdot C \cdot A \cdot I / 1000 \text{ (m}^3\text{/day)}$$

Where

q: Daily effluent amount of leachate water(m³/day)

C: Leachate coefficient of on-going landfill section 0.4

I: Annual maximum rainfall (mm/day)

Maximum rainfall during 2000 to 2002 38 mm in September in 2002
11.3 mm/day

A: Landfill area (m²)

f: Safety factor 16

Q: Daily effluent amount of leachate with safety factor (m³/day)

Table 71 Proposed Leachate Volume

Q (m ³ /day)	Stage1	Stage2	Stage3
	730	610	0

2. Leachate treatment

2.1 Aerated Lagoon Process Design

Design Base:

	Symbol	Unit	
Influent flow	Q	m ³ /d	
Influent suspended solids	SS ₀	mg/L	540
Influent soluble BOD ₅	S ₀	mg/L	920
Effluent soluble BOD ₅	S-BOD _{5-out}	mg/L	30
Effluent suspended solid after settling	S _{Se}	mg/L	70
Kinetic coefficients:		l/d	0.65
Y		mg-BOD ₅ /L	100
K _s		mg-BOD ₅ /L/d	6.0
K _{max}		l/d	0.07
K _d	k ₍₂₀₎	l/d	2.5
First order soluble BoD5 removal rate constants at 20 °C	T _i	°C	21.0
Waste water temperature			
in leachate	α		0.6
in treated water	β		0.9
Oxygen concentration to be maintained in liquid		mg-O ₂ /L	1.5
Lagoon depth	H	m	3.5
Design mean cell - residence time	θ _c	d	14

2.2 Surface area of the lagoon

$$\theta_c = V/Q \quad \therefore V = \theta_c * Q \quad V: \text{volume of the lagoon}$$

$$A = V/H$$

Dimension

Table 72 Dimensions of Aerated Lagoon

	Unit	Stage1	Stage2	Stage3
V	m ³	13,580	8,540	-
A	m ²	3,880	2,440	-
L	m	100	90	-
W	m	40	30	-
H	m	3.5	3.5	-
A' (Connected A)	m ²	4,000	2,700	-
V' (Connected V)	m ³	14,000	9,500	-

Number of lagoon: 1

2.3 Soluble effluent BOD₅ at the lagoon outlet: S-BOD₅-out

$$S\text{-BOD}_{5\text{-out}} = \{K_s (1+\theta_c \cdot k_d)\} / \{ \theta_c (Y \cdot k_{\max} - k_d) - 1 \} (\text{mg/L})$$

K _s	θ _c ·k _d	1+θ _c ·k _d	K _s (1+θ _c ·k _d)	θ _c	Y·k _{max}	Y·k _{max} -k _d	θ _c (Y·k _{max} -k _d)-1	S-BOD ₅ -out
100	0.98	1.98	198	14	3.9	3.83	52.6	3.8

2.4 Effluent BOD₅

1) Correct the removal-rate for temperature effects

$$k(t) = k(20) \cdot \theta^{T-20}$$

T _i	k ₍₂₀₎	T-20	θ	θ ^(T-20)	k ₍₂₀₎ θ ^(T-20)
21.0	2.5	1	1.06	1.06	2.7

2) Determine the effluent BOD₅: S_t-out (mg/L)

kt	V/Q	1+kV/Q	1/(1+kV/Q)	S ₀	S _t -out
2.7	14	38.10	0.03	920	24

2.5 Concentration of biological solids produced: X (mg/L)

$$X = Y (S_0 - S\text{-BOD}_{5\text{-out}}) / (1 + k_d \theta_c) (\text{mg-VSS/L})$$

Y	S ₀ -S-BOD ₅ -out	k _d	θ _c	Y(S ₀ -S-BOD ₅ -out)/(1+k _d θ _c)
0.65	916.2	0.07	14	301

2.6 Suspended solids in the lagoon before settling

$$SS_i = \text{Influent suspended solids} + X/0.7 (\text{mg/L})$$

SS ₀	X	SS _i
540	301	970

Ratio of volatile suspended solid 0.7

2.7 Oxygen requirements

$$Q_2 (\text{kg/d}) = Q(S_0 - S\text{-BOD}_{5\text{-out}}) / f - 1.42 P_x$$

f: conversion factor for BOD₅ to BODL 0.68

$$P_x = Q \cdot (\text{concentration of biological solids produced})$$

2.10 Energy requirements for mixing

Table 76 Specifications of Aerator

	Unit	Stage1	Stage2	Stage3
Power for Mixing	kW/m ³	0.005	0.005	-
Lagoon volume	m ³	14,000	9,500	-
Axis power for mixing	kW	70	47.5	-
Total efficiency	-	0.75	0.75	-
Required power	kW	93	63	-
Unit Power	kW/No.	15	15	-
No. of Aerator	Nos.	7	5	-

3. Leachate recirculation pump

1) Recirculation rate r times/leachate

Recirculation pump flow Q_r m³/day

$$Q_r = r \cdot Q$$

Required Power P_s

$$P_s = 0.163 \cdot Q_r (\text{m}^3/\text{min}) \cdot H (\text{m}) / \eta$$

Horse power

Here

Total head of the pump H m

Total efficiency η

Liquid density ρ_s 1.05

From the entrance of aerated lagoon to landfill

Table 77 Specifications of Leachate Recirculation Pump

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
r	-	3	3	-
Q_r	m ³ /day	2,910	1,830	-
	m ³ /min	2.02	1.27	-
Head	m	50	50	-
η	-	0.56	0.56	-
P_s	Horse power	15.4	19.4	-
	kW	19.6	14.6	-
Unit power	kW/No.	15	19	-
Nos. of pumps	Nos.	(2+1)	(1+1)	-

4. Solid-liquid separation: sedimentation tank

Q_i : Inflow m³/day

Safety factor 3

R.T: Retention time at $Q_i \cdot 3$ hr

OL: Overflow rate at $Q_i \cdot 3$ m³/m²/day

$$Q_i \cdot C_i = Q_o \cdot C_o + Q_u \cdot C_u$$

Ci: Inflow SS mg/L

Co: Outflow SS mg/L

Cu: Concentrated SS in the sedimentation tank mg/L

Qo: Outflow m³/day

Qu: Underflow (Sludge flow) m³/day

$$Q_u = Q_i - Q_o \quad m^3/day$$

$$Q_o = Q_i \cdot (C_u - C_i) / (C_u - C_o) \quad m^3/day$$

$$A_s: \text{Surface area} = Q_o / OL \quad m^2$$

Dimension Ls: Length of sedimentation tank m

Ws: Width of sedimentation tank m

$$H_s: \text{Height of sludge zone} = V_s / A_s \quad m$$

$$V_s: \text{Volume of sedimentation tank} \quad m^3$$

$$H_2: \text{Height allowance} = V_s / A_s \quad m^2$$

Table 78 Dimension of sedimentation tank

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
Qi	m ³ /day	2,910	1,830	-
RT	hr	2	2	-
OL	m ³ /m ² /day	22	22	-
Ci	mg/L	970	970	-
Co	mg/L	70	70	-
Cu	mg/L	5,000	5,000	-
Qo	m ³ /day	2,400	1,500	-
As	m ²	110	70	-
Ls	m	30	20	-
Ws	m	5	5	-
Hs	m	2.3	2.3	-
Vs	m ³	250	160	-
Qu	m ³ /day	510	330	-
H2	m	1.5	1.5	-
H0	m	3.8	3.8	-

$$\text{Total Height } H_o = H_2 + H_s$$

5. To removal nutrients, use wetland.

Only by aerated lagoon, only BOD₅ and SS are removed. For further treatment for nutrients another process is necessary.

Here, wetland was considered as an alternative for this purpose, considering cost efficiency.

Levels of nitrogen and phosphates are estimated as below based on the analysis of leachate during this Study.

Total-N: 240 mg/L

Total-P: 64 mg/L

In biological treatment nitrogen and phosphate are necessary. The ratio of N and P towards BOD₅ is 3:0.3:100

Therefore N and P after biological treatment, their levels are expected as below.

Inlet BOD₅ 920 mg/L

Therefore N to be removed by biological treatment 27.6 mg/L

Therefore P to be removed by biological treatment 2.76 mg/L

After aerated lagoon remained N 212 mg/L

P 61 mg/L

Criteria*	
20	mg/L. as KTN
10	mg/L. as P

*:Discharge criteria of industrial waste water into general public water body

Inlet T-P level will be reduced by using cover soil.

Therefore, only removal of nitrogen would be considered.

Here, subsurface-flow (SSF) systems was considered.

In a SSF wetland, the basin is filled with gravel or some other coarse substrate, and the water level is maintained below-ground. Water flows horizontally, or sometimes vertically, through the gravel and the root mat of the wetland vegetation.

Arrow arum (Polyandry spp.) and Pickerel weed (Pontederia spp.) have been used in constructed wetlands.

Also common reed (Phragmitescommunis) is used




Figure 4 Conceptual diagram of subsurface-flow wetlands

Example of determination of basin design for SFS wetlands system

Nitrogen removal will proceed when BOD₅ level is less than 10 mg/L.

1. Premises

Influent BOD ₅	C ₀	60 mg/L
Effluent BOD ₅	C _e	8 mg/L
Inflow	Q	m ³ /day
		m ³ /day
Vegetation type		cattails
Minimum water temperature	T	21°C
Basin media		coarse sand with 2 mm of maximum effective size
Basin slope	S	0.01

2. Solution

1. Basin depth for use wit cattail	d	0.3 m
2. Porosity	α	0.39
Hydraulic conductivity	K _s	480 m ³ /m ² /day
	K ₂₀	1.35
3. Temperature-dependent first order rate constant		
	K _T at	21°C
		1.49 d ⁻¹
4. Pore-space detention time	t' = -lnC _e /C ₀ /K _t	d
5. Cross-sectional area	A _c = Q/K _s /S	m ²
6. Basin width	W = A _c /d	m
7. Basin length	L = t'Q/W/d/α	m
8. Required surface area	A _s = L*W	m ²
		ha
9. Check hydraulic-loading rate or specific area requirements		
	L _w = Q/L/W	150 to 500 m ³ /ha/day
		0.015 to 0.005 m ³ /m ² /day
or	A _{sp} = 1/L _w for advanced treatment	2.1 ha/10 ³ m ³
10. Check BOD ₅ loading rate	Max.BOD _{5L}	60 kg/ha/day
LBOD ₅		kg/day
BOD _{5L}		kg/ha/day
11. Vegetation		
Reed can absprb	N	18 to 21g/kg
	P	2.0 to 3.0 g/kg
Inlet N		212.4 mg/L
Vd: vegetation density		10kg/m ²

Table 79 Specification of Wetland

	Unit	Stage1	Stage2	Stage3
C ₀	mg/L	60	60	-
C _e	mg/L	8	8	-
Q	m ³ /day	970	610	-
T	°C	21	21	-
S		0.01	0.01	-
d	m	0.3	0.3	-
α		0.39	0.39	-
K _s	m ³ /m ² /day	480	480	-
K ₂₀		1.35	1.35	-
K _t	d ⁻¹	1.49	1.49	-
t'	day	1.36	1.36	-
A _c	m ²	202	127	-
W	m	680	430	-
L	m	17	16	-
A _s	m ²	11,300	7,100	-
L _w	m ³ /m ² /day	0.09	0.09	-
A _{sp}	ha/1000m ³	11.60	11.60	-
L-BOD ₅	kg/day	58.2	36.6	-
BOD _{5L}	kg/ha/day	52	52	-
V	m ³	3,390	2,130	-
R.T	day	3.5	3.5	-
Inlet N	mg/L	212	212	-
Total N in WL	g	739,000	460,000	-
N absorption	g/kg	18	18	-
Nos. of reed	kg	40,556	25,556	-
V _d	kg/m ²	10	10	-
Max Reed	kg	113,000	71,000	-

Alternative 3: Natural Pond System (Anaerobic + Facultative + Maturation Pond) -New Site 1

(Remarks): Dimensions are at mid-depth. Height allowance should be 50 cm at least.

This system is so called natural pond system to remove BOD₅, SS and nutrients such as N and P.

1. Premises

1.1 There are no discharge quality criteria for treated leachate. Therefore, a temporary guideline was proposed as follows.

Table 80 Proposed Water Quality Criteria

Leachate Quality	Unit-mg/L		
	T-BOD ₅	SS	S-BOD ₅
Inlet	920	540	600
Outlet	60	70	30
Removal rate (%)	93.5	87.0	95

Even though discharge quality criteria are established in the future, only removal of T-BOD₅ and SS is considered by this system.

There are some estimation formula for leachate generation, including the one with the consideration of evaporation, however, in case of using pond system as the final treatment, pond volume is designed with ignoring evaporation.

1.2 Recirculation rate of leachate 3 times/day toward the leachate generated

2. Anaerobic pond

RTa: Retention time of anaerobic pond			7 days
BOD ₅ Removal rate			60%
BOD ₅ out-a			368 mg/L
Da: Depth of the anaerobic pond			3.5 m
Aa: Surface area			m ²
Va: Anaerobic pond volume			m ³
Dimension	Length	La	m
	Width	Wa	m
BOD _{5La} : BOD ₅ load of anaerobic pond			100 to 350 g-BOD ₅ /m ³ -pond/day

Table 81 Dimension of Anaerobic Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
R.T	days	7	7	-
Va	m ³	6,790	4,270	-
Da	m	3.5	3.5	-
Aa	m ²	1,940	1,220	-
La	m	70	60	-
Wa	m	30	22	-
BOD ₅	g/day	892,410	561,200	-
BOD _{5La}	g/m ³ /day	131	131	-

Number of ponds: 1

3. Facultative Pond

ls₁: BOD permissible loading

kg/ha/day

$$ls_1 = 350 (1.107 - 0.002T)^{T-25}$$

100 to 400 kg/ha/day

or

$$ls_2 = 20T-120$$

kg/ha/day

Here, T: Minimum temperature

21 °C

Ls: BOD₅ loading

$$Ls = 10 Li Q / Af$$

kg/ha/day

Here,

Li: Inflow BOD₅

mg/L

Af: Facultative pond area

m²

$$Af = Q *(Li - Le)/18D/(1.05)^{T-20}$$

Here,

Le: Outflow BOD₅

mg/L

L_r: BOD₅ removal

kg/ha/day

$$Lr = 0.725Ls \div 10.75$$

Df: Depth of the facultative pond

m

Dimensions of facultative pond

Length

Lf

m

Width

Wf

m

Table 82 Dimension of Sedimentation Tank

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
T	°C	21	21	-
ls ₁	kg/ha/day	272	272	-
ls ₂	kg/ha/day	300	300	-
Ls	kg/ha/day	270	270	-
Li	mg/L	368	368	-
Df	m	1.2	1.2	-
Af	m ²	13,200	8,300	-
Le	mg/L	60	60	-
Lr	kg/ha/day	207	207	-
BOD _{5RF}	%	76.5	76.5	-
BOD _{5out-f}	mg/L	87	87	-
R.T _f	days	16	16	-

Remarks:

- (a) There is a difference between ls₁ and ls₂. Adopt ls₁ for safety.
- (b) There is a difference between Le and BOD_{5out-f}. This is because Equations for Ls and Af are the one to get 60 mg/L-BOD₅ in South America.
- (c) On the contrary, the value of BOD_{5out-f} is calculated by the equation for Lr. Lr shows the average of the data arranged by MacGarry and Pescord.
- (d) The BOD₅ removal in primary facultative ponds is usually in the range 70-80 percent based on unfiltered samples (that is, including the BOD exerted by the algae).
Therefore, effluent BOD_{5out-f} level from facultative pond will be considered 60-117 mg/L with algae.
- (e) It is said BOD₅ quality of the effluent from a facultative ponds as most of the BOD contained (70 to 90%) will be "algal BOD. Therefore, the filtered (soluble) BOD₅ level will be at least 18-35 mg/L.

Table 83 Dimensions of Facultative Pond

	Unit	Stage1	Stage2	Stage3
Af	m ²	13,200	8,300	-
Nos. of ponds	-	2	2	-
Af/pond	m ²	6,600	4,150	-
Lf/pond	m	140	110	-
Wf/pond	m	50	40	-
Df	m	1.2	1.2	-
Vf/pond	m ³	8,400	5,280	-
Total Vf	m ³	16,800	10,560	-

Pond arrangement: Parallel

4. Maturation pond

Maturation ponds (low-cost polishing ponds, which succeed the primary or secondary facultative pond) are primarily designed for tertiary treatment, i.e., the removal of pathogens, nutrients and possibly algae.

With the combination of facultative pond and maturation pond,

- (1) Total nitrogen removal in WSP systems can reach 80 percent or more, and ammonia removal can be as high as 95 percent.
- (2) The best way of increasing phosphorus removal in WSP is to increase the number of

maturation ponds, so that progressively more and more phosphorus becomes immobilized in the sediments. From a well functioning 2 ponds system, 70% mass removal of total.

- (3) The removal rate increases by adding maturation ponds.

Design criteria

D_m : Depth of maturation pond 1.5 m
 RT_m : Retention time of maturation pond 14 days
 A_m : Area of maturation pond

Dimensions of maturation pond

Length L_m m
 Width W_m m

Table 84 Dimensions of Maturation Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
RT_m	days	14	14	-
V_m	m ³	13,580	8,540	-
Nos. of Ponds	-	2	2	-
V_m /Pond	m ³	6,790	4,270	-
D_m /Pond	m	1.5	1.5	-
A_m /Pond	m ²	4,600	2,900	-
L_m /Pond	m	120	90	-
W_m /Pond	m	40	35	-

Pond arrangement: Series

5. Leachate Recirculation pump

Recirculation rate r times/leachate

Recirculation pump flow Q_r m³/day

$Q_r = r * Q$

Required Power P_s

$P_s = 0.163 * Q_r(m^3/min) * H(m) / \eta$ Horse power

Here

Total head of the pump H m

Total efficiency η

Liquid density ρ_s 1.05

From the entrance of anaerobic lagoon to landfill

Table 85 Specifications of Leachate Recirculation Pump

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
r	-	3	3	-
Qr	m ³ /day	2,910	1,830	-
	m ³ /min	2.02	1.27	-
Head	m	50	50	-
η	-	0.56	0.56	-
Ps	Horse power	15.4	19.4	-
	kW	19.6	14.6	-
Unit power	kW/No.	15	19	-
Nos. of pumps	Nos.	(2+1)	(1+1)	-

Alternative 4: Natural Pond System (Anaerobic + Facultative + Wetland) -New Site 1

(Remarks): Dimensions are at mid-depth. Height allowance should be 50 cm at least.

This system is an alternative to use wetland instead of Maturation Pond in Alternative 3 in order to remove nutrients such as N and P.

1. Premises

1.1 There are no discharge quality criteria for treated leachate. Therefore, a temporary guideline was proposed as follows.

Table 86 Proposed Water Quality Criteria

Leachate Quality	Unit-mg/L		
	T-BOD ₅	SS	S-BOD ₅
Inlet	920	540	600
Outlet	60	70	30
Removal rate (%)	93.5	87.0	95

Even though discharge quality criteria are established in the future, only removal of T-BOD₅ and SS is considered by this system.

There are some estimation formula for leachate generation, including the one with the consideration of evaporation, however, in case of using pond system as the final treatment, pond volume is designed with ignoring evaporation.

1.2 Recirculation rate of leachate 3 times/day toward the leachate generated

2. Anaerobic pond

RTa : Retention time of anaerobic pond			7 days
BOD ₅ Removal rate			60%
BOD ₅ out-a			368 mg/L
Da: Depth of the anaerobic pond			3.5 m
Aa: Surface area			m ²
Va: Anaerobic pond volume			m ³
Dimension	Length	La	m
	Width	Wa	m
BOD _{5La} : BOD ₅ load of anaerobic pond			100 to 350 g-BOD ₅ /m ³ -pond/day

Table 87 Dimension of Anaerobic Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
R.T	days	7	7	-
Va	m ³	6,790	4,270	-
Da	m	3.5	3.5	-
Aa	m ²	1,940	1,220	-
La	m	70	60	-
Wa	m	30	70	-
BOD ₅	g/day	892,400	20	-
BOD _{5La}	g/m ³ /day	131	131	-

Number of ponds: 1

3. Facultative Pond

ls₁: BOD permissible loading kg/ha/day
 $ls_1 = 350 (1.107 - 0.002T)^{T-25}$ 100 to 400 kg/ha/day

or

$ls_2 = 20T-120$ kg/ha/day
 Here, T: Minimum temperature 21 °C

Ls: BOD₅ loading

$Ls = 10 Li Q / Af$ kg/ha/day

Here,

Li: Inflow BOD₅ mg/L

Af: Facultative pond area m²

$Af = Q *(Li - Le)/18D/(1.05)^{T-20}$

Here,

Le: Outflow BOD₅ mg/L

L_r: BOD₅ removal kg/ha/day

$Lr = 0.725Ls \div 10.75$

Df: Depth of the facultative pond m

Dimensions of facultative pond Length Lf m

Width Wf m

Table 88 Dimension of Sedimentation Tank

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
T	°C	21	21	-
ls ₁	kg/ha/day	272	272	-
ls ₂	kg/ha/day	300	300	-
Ls	kg/ha/day	270	270	-
Li	mg/L	368	368	-
Df	m	1.2	1.2	-
Af	m ²	13,200	8,900	-
Le	mg/L	60	60	-
Lr	kg/ha/day	207	207	-
BOD _{5Rf}	%	76.5	76.5	-
BOD _{5out-f}	mg/L	87	87	-
R.T _f	days	16	16	-

Remarks:

- There is a difference between ls₁ and ls₂. Adopt ls₁ for safety.
- There is a difference between Le and BOD_{5out-f}. This is because Equations for Ls and Af are the one to get 60 mg/L-BOD₅ in South America.
- On the contrary, the value of BOD_{5out-f} is calculated by the equation for Lr. Lr shows the average of the data arranged by MacGarry and Pescord.
- The BOD₅ removal in primary facultative ponds is usually in the range 70-80 percent based on unfiltered samples (that is, including the BOD exerted by the algae).
Therefore, effluent BOD_{5out-f} level from facultative pond will be considered 60-117 mg/L with algae.
- It is said BOD₅ quality of the effluent from a facultative ponds as most of the BOD contained (70 to 90%) will be "algal BOD. Therefore, the filtered (soluble) BOD₅ level will be at least 18-35 mg/L.

Table 89 Dimensions of Facultative Pond

	Unit	Stage1	Stage2	Stage3
Af	m ²	13,200	8,300	-
Nos. of ponds	-	2	2	-
Af/pond	m ²	6,600	6,600	-
Lf/pond	m	140	140	-
Wf/pond	m	50	50	-
Df	m	1.2	1.2	-
Vf/pond	m ³	8,400	8,400	-
Total Vf	m ³	16,800	16,800	-

Pond arrangement: Parallel

4. To removal nutrients, use wetland

Only by aerated lagoon, only BOD₅ and SS are removed. For further treatment for nutrients another process is necessary.

Here, wetland was considered as an alternative for this purpose, considering cost efficiency.

Levels of nitrogen and phosphates are estimated as below based on the analysis of leachate during this Study.

Total-N: 240 mg/L

Total-P: 64 mg/L

In biological treatment nitrogen and phosphate are necessary. The ratio of N and P towards BOD₅ is 3:0.3:100

Therefore N and P after biological treatment, their levels are expected as below.

Inlet BOD₅ 920 mg/L

Therefore N to be removed by biological treatment 27.6 mg/L

Therefore P to be removed by biological treatment 2.76 mg/L

After aerated lagoon remained N N 212 mg/L

P 61 mg/L

Criteria*	
20	mg/L. as KTN
10	mg/L. as P

*:Discharge criteria of industrial waste water into general public water body

Inlet T-P level will be reduced by using cover soil. Therefore, only removal of nitrogen would be considered.

Here, subsurface-flow (SSF) systems was considered.

In a SSF wetland, the basin is filled with gravel or some other coarse substrate, and the water level is maintained below-ground. Water flows horizontally, or sometimes vertically, through the gravel and the root mat of the wetland vegetation.

Arrow arum (Polyandry spp.) and Pickerel weed (Pontederia spp.) have been used in constructed wetlands.

Also common reed (Phragmitescommunis) is used




Figure 5 Conceptual diagram of subsurface-flow wetlands

Example of determination of basin design for SFS wetlands system

Nitrogen removal will proceed when BOD₅ level is less than 10 mg/L.

1. Premises

Influent BOD ₅	C ₀	87 mg/L
Effluent BOD ₅	C _e	8 mg/L
Inflow	Q	m ³ /day
		m ³ /day
Vegetation type		cattails
Minimum water temperature	T	21°C
Basin media		coarse sand with 2 mm of maximum effective size
Basin slope	S	0.01

2. Solution

1. Basin depth for use wit cattail	d	0.3 m
2. Porosity	α	0.39
Hydraulic conductivity	K _s	480 m ³ /m ² /day
	K ₂₀	1.35
3. Temperature-dependent first order rate constant	K _T at	21 °C
		1.49 d ⁻¹
4. Pore-space detention time	$t' = -\ln C_e/C_0/K_t$	d
5. Cross-sectional area	$A_c = Q/K_s/S$	m ²
6. Basin width	$W = A_c/d$	m
7. Basin length	$L = t'Q/W/d/\alpha$	m
8. Required surface area	$A_s = L*W$	m ²
		ha
9. Check hydraulic-loading rate or specific area requirements	$L_w = Q/L/W$	150 to 500 m ³ /ha/day
		0.015 to 0.005 m ³ /m ² /day
or	$A_{sp} = 1/L_w$ for advanced treatment	2.1 ha/10 ³ m ³
10. Check BOD ₅ loading rate	Max.BOD _{5L}	60kg/ha/day
	LBOD ₅	kg/day
	BOD _{5L}	kg/ha/day
11. Vegetation		
Reed can absprb	N	18 to 21g/kg
	P	2.0 to 3.0 g/kg
Inlet N		240 mg/L
Vd: vegetation density		10 kg/m ²

Table 90 Specification of Wetland

	Unit	Stage1	Stage2	Stage3
C ₀	mg/L	87	87	-
C _e	mg/L	8	8	-
Q	m ³ /day	970	610	-
T	°C	21.0	21.0	-
S		0.01	0.01	-
d	m	0.3	0.3	-
α		0.39	0.39	-
K _s	m ³ /m ² /day	480	480	-
K ₂₀		1.35	1.35	-
K _t	d ⁻¹	1.49	1.49	-
t'	day	1.61	1.61	-
A _c	m ²	202	127	-
W	m	680	430	-
L	m	20	19	-
A _s	m ²	13,400	8,400	-
L _w	m ³ /m ² /day	0.07	0.07	-
A _{sp}	ha/1000m ³	13.74	13.74	-
L-BOD ₅	kg/day	84.4	53.07	-
BOD _{5L}	kg/ha/day	63	63	-
V	m ³	4,020	2,520	-
RT	day	4.1	4.1	-
Inlet N	mg/L	240	240	-
Total N in WL	g	970,000	610,000	-
N absorption	g/kg	18	18	-
Nos. of reed	kg	53,889	33,889	-
V _d	kg/m ²	10	10	-
Max Reed	kg	134,000	84,000	-

This system seems to be inferior in performance.

5. Leachate Recirculation pump

Recirculation rate r times/leachate

Recirculation pump flow Q_r m³/day

$$Q_r = r * Q$$

Required Power P_s

$$P_s = 0.163 * Q_r (\text{m}^3/\text{min}) * H (\text{m}) / \eta$$
Horse power

Here

Total head of the pump H m

Total efficiency η

Liquid density ρ_s 1.05

From the entrance of anaerobic lagoon to landfill

Table 91 Specifications of Leachate Recirculation Pump

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
r	-	3	3	-
Qr	m ³ /day	2,910	1,830	-
	m ³ /min	2.02	1.27	-
Head	m	50	50	-
η	-	0.56	0.56	-
Ps	Horse power	15.4	19.4	-
	kW	19.6	14.6	-
Unit power	kW/No.	15	19	-
Nos. of pumps	Nos.	(2+1)	(1+1)	-

Alternative 5: Anaerobic Pond + Aerated Lagoon + Sedimentation Pond + Wetland with recirculation -New Site 1

(Remarks): Dimensions are at mid-depth. Height allowance should be 50 cm at least.

This system is an alternative adding Anaerobic Pond to Alternative 2 in order to reduce area.

1. Premises

1.1 There are no discharge quality criteria for treated leachate. Therefore, a temporary guideline was proposed as follows.

Table 92 Proposed Water Quality Criteria

Leachate Quality	Unit-mg/L		
	T-BOD ₅	SS	S-BOD ₅
Inlet	920	540	600
Outlet	60	70	30
Removal rate (%)	93.5	87.0	95

Even though discharge quality criteria are established in the future, only removal of T-BOD₅ and SS is considered by this system.

There are some estimation formula for leachate generation, including the one with the consideration of evaporation, however, in case of using pond system as the final treatment, pond volume is designed with ignoring evaporation.

1.2 Recirculation rate of leachate 3 times/day toward the leachate generated

2. Anaerobic pond

RTa : Retention time of anaerobic pond			7 days
BOD ₅ Removal rate			60%
BOD ₅ out-a			368 mg/L
Da: Depth of the anaerobic pond			3.5 m
Aa: Surface area			m ²
Va: Anaerobic pond volume			m ³
Dimension	Length	La	m
	Width	Wa	m
BOD _{5La} : BOD ₅ load of anaerobic pond			100 to 350 g-BOD ₅ /m ³ -pond/day

Table 93 Dimension of Anaerobic Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
R.T	days	7	7	-
Va	m ³	6,790	4,270	-
Da	m	3.5	3.5	-
Aa	m ²	1,940	1,220	-
La	m	70	66	-
Wa	m	30	22	-
BOD ₅	g/day	892,400	561,200	-
BOD _{5La}	g/m ³ /day	131	131	-

Number of ponds: 1

3. Aerated Lagoon

3.1 Aerated Lagoon Process

Design Base:

	Symbol	Unit	
Influent flow	Q	m ³ /d	
Influent suspended solids	SS ₀	mg/L	378
Influent soluble BOD ₅	S ₀	mg/L	368
Effluent soluble BOD ₅	S-BOD _{5-out}	mg/L	30
Effluent suspended solid after setting	S _{Se}	mg/L	70

Kinetic coefficients:

Y	l/d	0.65
K _s	mg-BOD ₅ /L	100
K _{max}	mg-BOD ₅ /L/d	6.0
K _d	l/d	0.07

First order soluble BOD₅ removal rate constants at 20 °C

	k ₍₂₀₎	l/d	2.5
Waste water temperature	T _i	°C	21.0

Aeration constants in leachate

in leachate	α	0.6	
in treated water	β	0.9	
Oxygen concentration to be maintained in liquid	mg - O ₂ /L	1.5	
Lagoon depth	H	m	3.5
Design mean cell - residence time	θ _c	d	7

3.2 Surface area of the lagoon A m²

$$\theta_c = V/Q \quad \therefore V = \theta_c * Q \quad V: \text{volume of the lagoon}$$

$$A = V/H$$

Dimension

Table 94 Dimension of Aerated Lagoon

	Unit	Stage1	Stage2	Stage3
V	m ³	6,790	4,270	-
A	m ²	1,940	1,220	-
L	m	70	60	-
W	m	30	22	-
H	m	3.5	3.5	-
A' (corrected A)	m ²	2,100	1,320	-
V' (Corrected V)	m ³	7,400	4,700	-

3.3 Soluble effluent BOD₅ at the lagoon outlet: S-BOD₅-out

$$S\text{-BOD}_{5\text{out}} = \{ K_s (1 + \theta_c * k_d) \} / \{ \theta_c (Y * k_{\text{max}} - k_d) - I \} \quad (\text{mg/L})$$

Ks	$\theta_c * k_d$	1+ $\theta_c * k_d$	Ks (1+ $\theta_c * k_d$)	θ_c	Y*kmax	Y*kmax-kd	$\theta_c (Y * k_{\text{max}} - k_d) - I$	S-BOD ₅ out
100	0.49	1.49	149	7	3.9	3.83	25.8	5.8

3.4 Effluent BOD₅

(1) Correct the removal-rate for temperature effects

$$k(t) = k(20) * \theta^{T-20} \quad (\text{l/d})$$

Ti	k ₍₂₀₎	T-20	θ	$\theta^{(T-20)}$	k ₍₂₀₎ $\theta^{(T-20)}$
21.0	2.5	1	1.06	1.06	2.7

(2) Determine the effluent BOD₅: St_{-out} (mg/L)

$$St\text{-out}/S_0 = 1/(1+k\theta_H) = S/S_0 = 1/(1+kV/Q)$$

kt	V/Q	1+kV/Q	1/(1+kV/Q)	S ₀	St-out
2.7	14	19.55	0.05	368	19

3.5 Concentration of biological solids produced: X (mg/L)

$$X = Y (S_0 - S - \text{BOD}_{5\text{-out}}) / (1 + k_d \theta_c) \quad (\text{mg-VSS/L})$$

Y	S ₀ -S-BOD _{5-out}	k _d	θ_c	Y(S ₀ -S-BOD _{5-out})/(1+k _d θ_c)
0.65	362.2	0.07	7	158

3.6 Suspended solids in the lagoon before settling

$$SSi = \text{Influent suspended solids} + X/0.7(\text{mg/L})$$

Ratio of volatile suspended solid 0.7

SSo	X	SSi
378	158	604

3.7 Oxygen requirements

$$Q_2 (\text{kg/d}) = Q (S_0 - S - \text{BOD}_{5-\text{out}}) / f - 1.42P_x$$

f: conversion factor for BOD₅ to BOD_L 0.68

P_x = Q*(concentration of biological solids produced)

Table 95 Required O₂

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
S ₀ -S-BOD _{5-out}	mg/L	362	362	-
f	-	0.68	0.68	-
P _x	kg/day	153	96	-
Required O ₂	kg/day	299	188	-

3.8 Ratio of oxygen required to BOD₅ removed

BOD₅ removed (kg/d)

O₂/BOD₅ removed

Table 96 Removed BOD₅

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
S ₀ -S-BOD _{5-out}	mg/L	362	362.2	-
BOD ₅ removed	kg/day	351	221	-
O ₂ /BOD ₅	-	0.9	0.9	-

3.9 Surface aerator power requirements

assumption: kg-O₂/kw/h kg-O₂/kw/h No 1.6

a) Correction factor for surface aerators for summer conditions f

$$f = N_0 / N$$

1) Oxygen saturation concentration at 21 °C Cs(21) mg/L 8.91

2) Cs(20) mg/L 9.08

3) DO concentration in Lagoon CL mg/L 1.5

$$f = \{B * C_s T - CL\} / C_s (20) * 1.024^{T-20} * \alpha$$

Ti-20	1.024^{T-20}	α	B	f
1	1.029	0.6	0.9	0.44

b) Field transfer rate : N

$$N = fN_0 \quad \text{kg-O}_2/\text{kw/h} \quad 0.71$$

$$\text{Total amount of transfer O}_2 \quad \text{kg-O}_2/\text{kw/d} \quad \text{kg-O}_2/\text{kw/h} \quad 17.0$$

The total axis power required to meet the required oxygen

Table 97 Required O₂ Supply

	Unit	Stage1	Stage2	Stage3
Required O ₂	kg/day	299	188	-
Required power for O ₂ supply	kW	17.6	11.1	-

3.10 Energy requirements for mixing

Table 98 Specifications of Aerator

	Unit	Stage1	Stage2	Stage3
Power for Mixing	kW/m ³	0.005	0.005	-
Lagoon volume	m ³	7,400	7,400	-
Axis power for mixing	kW	37	23.5	-
Total efficiency	-	0.75	0.75	-
Required power	kW	49.3	31	-
Required power per unit	kW/No.	11	7.5	-
Power for Mixing	Nos.	5	5	-

4. Leachate recirculation pump

Recirculation rate r times/leachate

Recirculation pump flow Q_r m³/day

$$Q_r = r \cdot Q$$

Required Power P_s

$$P_s = 0.163 \cdot Q_r (\text{m}^3/\text{min}) \cdot H (\text{m}) / \eta \quad \text{Horse power}$$

Here

Total head of the pump H m

Total efficiency η

Liquid density ρ_s 1.05

From the entrance of anaerobic lagoon to landfill

Table 99 Specifications of Leachate Recirculation Pump

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
r	-	3	3	-
Qr	m ³ /day	2,910	1,830	-
	m ³ /min	2.02	1.27	-
Head	m	50	50	-
η	-	0.56	0.56	-
Ps	Horse power	15.4	19.4	-
	kW	19.6	14.6	-
Unit power	kW	15	19	-
Nos. of pumps	Nos.	(2+1)	(1+1)	-

5. Solid-liquid separation: sedimentation tank

Qi: Inflow	m ³ /day
Safety factor	3
R.t: Retention time at Qi*3	hr
OL: Overflow rate at Qi*3	m ³ /m ² /day
Qi*Ci = Qo*Co+Qu*Cu	
Ci: Inflow SS	mg/L
Co: Outflow SS	mg/L
Cu: Concentrated SS in the sedimentation tank	mg/L
Qo: Outflow	m ³ /day
Qu: Underflow (Sludge flow)	m ³ /day
Qu = Qi-Qo	m ³ /day
Qo = Qi*(Cu-Ci) / (Cu-Co)	m ³ /day
As: surface area=Qo/OL	m ³
Dimension	
Ls: Length of sedimentation tank	m
Ws: Width of sedimentation tank	m
Hs: Height of sludge zone =Vs/As	m
Vs: Volume of sedimentation tank	m ³
H ₂ : Height allowance = Vs/As	m ²

Table 100 Dimension of Sedimentation Tank

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
Qi	m ³ /day	2,910	1,830	-
R.T	hr	2	2	-
O _L	m ³ /m ² /day	22	22	-
Ci	mg/L	604	604	-
Co	mg/L	70	70	-
Cu	mg/L	5,000	5,000	-
Qo	m ³ /day	2,600	1,600	-
As	m ²	120	80	-
Ls	m	30	20	-
Ws	m	5	5	-
Hs	m	2.1	2.0	-
Vs	m ³	250	160	-
Qu	m ³ /day	310	230	-
H ₂	m	1.5	1.5	-
H ₀	m	3.6	3.5	-

6. To removal nutrients, use wetland.

Only by aerated lagoon, only BOD₅ and SS are removed. For further treatment for nutrients another process is necessary.

Here, wetland was considered as an alternative for this purpose, considering cost efficiency.

Levels of nitrogen and phosphates are estimated as below based on the analysis of leachate during this Study.

Total-N:	240	mg/L
Total-P:	64	mg/L

In biological treatment nitrogen and phosphate are necessary. The ratio of N and P towards BOD₅ is 3:0.3:100

Therefore N and P after biological treatment, their levels are expected as below.

Inlet BOD ₅	920	mg/L	
Therefore N to be removed by biological treatment	27.6	mg/L	
Therefore P to be removed by biological treatment	2.76	mg/L	
After aerated lagoon remained N	N	212	mg/L
	P	61	mg/L

Criteria*	
20	mg/L. as KTN
10	mg/L. as P

*:Discharge criteria of industrial waste water into general public water body

Inlet T-P level will be reduced by using cover soil.

Therefore, only removal of nitrogen would be considered.

Here, subsurface-flow (SSF) systems was considered.

In a SSF wetland, the basin is filled with gravel or some other coarse substrate, and the water level is maintained below-ground. Water flows horizontally, or sometimes vertically, through the gravel and the root mat of the wetland vegetation.

Arrow arum (*Polyandry* spp.) and Pickerel weed (*Pontederia* spp.) have been used in constructed wetlands.

Also common reed (*Phragmites communis*) is used




Figure 6 Conceptual diagram of
subsurface-flow wetlands

Example of determination of basin design for SFS wetlands system

Nitrogen removal will proceed when BOD₅ level is less than 10 mg/L.

1. Premises

Influent BOD ₅	C ₀	60 mg/L
Effluent BOD ₅	C _e	8 mg/L
Inflow	Q	m ³ /day
		m ³ /day
Vegetation type		cattails
Minimum water temperature	T	21°C
Basin media		coarse sand with 2 mm of maximum effective size
Basin slope	S	0.01

2. Solution

1. Basin depth for use wit cattail	d	0.3 m
2. Porosity	α	0.39
Hydraulic conductivity	K _s	480 m ³ /m ² /day
	K ₂₀	1.35
3. Temperature-dependent first order rate constant	K _T at	21°C
		1.49 d ⁻¹
4. Pore-space detention time	$t' = -\ln C_e/C_0/K_t$	d
5. Cross-sectional area	$A_c = Q/K_s/S$	m ²
6. Basin width	$W = A_c/d$	m
7. Basin length	$L = t'Q/W/d/\alpha$	m
8. Required surface area	$A_s = L*W$	m ²
		ha
9. Check hydraulic-loading rate or specific area requirements	$L_w = Q/L/W$	150 to 500 m ³ /ha/day
		0.015 to 0.005 m ³ /m ² /day
or	$A_{sp} = 1/L_w$ for advanced treatment	2.1 ha/10 ³ m ³
10. Check BOD ₅ loading rate	Max.BOD _{5L}	60 kg/ha/day
LBOD ₅		kg/day
BOD _{5L}		kg/ha/day
11. Vegetation		
Reed can absorb	N	18 to 21 g/kg
	P	2.0 to 3.0 g/kg
Inlet N		212.4 mg/L
Vd: vegetation density		10 kg/m ²

Table 101 Specification of Wetland

	Unit	Stage1	Stage2	Stage3
C ₀	mg/L	60	60	-
C _e	mg/L	8	8	-
Q	m ³ /day	970	610	-
T	°C	21.0	21.0	-
S		0.01	0.01	-
d	m	0.3	0.3	-
α		0.39	0.39	-
K _s	m ³ /m ² /day	480	480	-
K ₂₀		1.35	1.35	-
K _t	d ⁻¹	1.49	1.49	-
t'	day	1.36	1.36	-
A _c	m ²	202	127	-
W	m	680	430	-
L	m	17	16	-
A _s	m ²	11,300	7,100	-
L _w	m ³ /m ² /day	0.09	0.09	-
A _{sp}	ha/1000m ³	11.60	11.60	-
L-BOD ₅	kg/day	58.2	36.6	-
BOD _{5L}	kg/ha/day	52	52	-
V	m ³	3,390	2,130	-
R.T	day	3.5	3.5	-
Inlet N	mg/L	212	212	-
Total N in WL	g	730,000	460,000	-
N absorption	g/kg	18	18	-
Nos. of reed	kg	40,556	25,556	-
V _d	kg/m ²	10	10	-
Max Reed	kg	113,000	71,000	-

**Alternative 6: Anaerobic Pond + Aerated Lagoon + Maturation Pond with recirculation
-New Site 1**

(Remarks): Dimensions are at mid-depth. Height allowance should be 50 cm at least.

This system is an alternative adding Anaerobic Pond to Alternative 1 to reduce area.

1. Premises

1.1 There are no discharge quality criteria for treated leachate. Therefore, a temporary guideline was proposed as follows.

Table 102 Proposed Water Quality Criteria

Leachate Quality	Unit-mg/L		
	T-BOD ₅	SS	S-BOD ₅
Inlet	920	540	600
Outlet	60	70	30
Removal rate (%)	93.5	87.0	95

Even though discharge quality criteria are established in the future, only removal of T-BOD₅ and SS is considered by this system.

There are some estimation formula for leachate generation, including the one with the consideration of evaporation, however, in case of using pond system as the final treatment, pond volume is designed with ignoring evaporation.

1.2 Recirculation rate of leachate 3 times/day toward the leachate generated

2. Anaerobic pond

RTa: Retention time of anaerobic pond			7 days
BOD ₅ Removal rate			60%
BOD ₅ out-a			368 mg/L
Da: Depth of the anaerobic pond			3.5 m
Aa: Surface area			m ²
Va: Anaerobic pond volume			m ³
Dimension	Length	La	m
	Width	Wa	m
BOD _{5La} : BOD ₅ load of anaerobic pond			100 to 350 g-BOD ₅ /m ³ -pond/day

Table 103 Dimension of Anaerobic Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
R.T	days	7	7	-
Va	m ³	6,790	4,270	-
Da	m	3.5	3.5	-
Aa	m ²	1,940	1,220	-
La	m	70	60	-
Wa	m	30	22	-
BOD ₅	g/day	892,400	561,200	-
BOD _{5La}	g/m ³ /day	131	131	-

Number of ponds: 1

3. Aerated Lagoon

3.1 Aerated Lagoon Process

Design Base:

	Symbol	Unit	
Influent flow	Q	m ³ /d	
Influent suspended solids	SS ₀	mg/L	378
Influent soluble BOD ₅	S ₀	mg/L	368
Effluent soluble BOD ₅	S-BOD _{5-out}	mg/L	30
Effluent suspended solid after setting	S _{Se}	mg/L	70

Kinetic coefficients:

Y		l/d	0.65
K _s		mg-BOD ₅ /L	100
K _{max}		mg-BOD ₅ /L/d	6.0
K _d		l/d	0.07

First order soluble BOD₅ removal rate constants at 20 °C

	k ₍₂₀₎	l/d	2.5
Waste water temperature	T _i	°C	21.0

Aeration constants in leachate

in leachate	α		0.6
in treated water	β		0.9
Oxygen concentration to be maintained in liquid		mg - O ₂ /L	1.5
Lagoon depth	H	m	3.5
Design mean cell - residence time	θ _c	d	7

3.2 Surface area of the lagoon A m^2

$$\theta c = V/Q \quad \therefore V = \theta c * Q \quad V: \text{volume of the lagoon}$$

$$A = V/H$$

Dimension

Table 104 Dimension of Aerated Lagoon

	Unit	Stage1	Stage2	Stage3
V	m ³	6,790	4,270	-
A	m ²	1,940	1,220	-
L	m	70	60	-
W	m	30	22	-
H	m	3.5	3.5	-
A' (corrected A)	m ²	2,100	1,320	-
V' (Corrected V)	m ³	7,400	4,700	-

3.3 Soluble effluent BOD₅ at the lagoon outlet: S-BOD₅-out

$$S\text{-BOD}_{5\text{out}} = \{ K_s (1 + \theta c * k_d) \} / \{ \theta c (Y * k_{\text{max}} - k_d) - I \} \quad (\text{mg/L})$$

Ks	$\theta c * k_d$	$1 + \theta c * k_d$	$K_s (1 + \theta c * k_d)$	θc	$Y * k_{\text{max}}$	$Y * k_{\text{max}} - k_d$	$\theta c (Y * k_{\text{max}} - k_d) - I$	S-BOD ₅ out
100	0.49	1.49	149	7	3.9	3.83	25.8	5.8

3.4 Effluent BOD₅

(1) Correct the removal-rate for temperature effects

$$k(t) = k(20) * \theta^{T-20} \quad (\text{l/d})$$

Ti	$k_{(20)}$	T-20	θ	$\theta^{(T-20)}$	$k_{(20)}\theta^{(T-20)}$
21.0	2.5	1	1.06	1.06	2.7

(2) Determine the effluent BOD₅: St_{-out} (mg/L)

$$St\text{-out}/S_0 = 1/(1+k\theta_H) = S/S_0 = 1/(1+kV/Q)$$

kt	V/Q	$1+kV/Q$	$1/(1+kV/Q)$	S_0	St-out
2.7	14	19.55	0.05	368	19

3.5 Concentration of biological solids produced: X (mg/L)

$$X = Y (S_0 - S - \text{BOD}_{5\text{-out}}) / (1 + k_d \theta c) \quad (\text{mg-VSS/L})$$

Y	S ₀ -S-BOD _{5-out}	k _d	θ _c	Y(S ₀ -S-BOD _{5-out})/(1+k _d θ _c)
0.65	362.2	0.07	7	158

3.6 Suspended solids in the lagoon before settling

$$SS_i = \text{Influent suspended solids} + X/0.7(\text{mg/L})$$

Ratio of volatile suspended solid 0.7

SS ₀	X	SS _i
378	158	604

3.7 Oxygen requirements

$$Q_2 (\text{kg/d}) = Q (S_0\text{-S-BOD}_{5\text{-out}})/f - 1.42P_x$$

f: conversion factor for BOD₅ to BOD_L 0.68

P_x = Q*(concentration of biological solids produced)

Table 105 Required O₂

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
S ₀ -s-BOD _{5-out}	mg/L	362	362	-
f	-	0.68	0.68	-
P _x	kg/day	153	96	-
Required O ₂	kg/day	299	188	-

3.8 Ratio of oxygen required to BOD₅ removed

BOD₅ removed (kg/d)

O₂/BOD₅ removed

Table 106 Removed BOD₅

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
S ₀ -S-BOD _{5-out}	mg/L	362	362.2	-
BOD ₅ removed	kg/day	351	22.1	-
O ₂ /BOD ₅	-	0.9	0.9	-

3.9 Surface aerator power requirements

assumption: kg-O₂/kw/h kg-O₂/kw/h No 1.6

a) Correction factor for surface aerators for summer conditions f

$$f = N_0/N$$

1) Oxygen saturation concentration at 21 °C C_s(21) mg/L 8.91

2) C_s(20) mg/L 9.08

3) DO concentration in Lagoon CL mg/L 1.5

$$f = \{B * C_s T - CL\} / C_s (20) * 1.024^{T-20} * \alpha$$

Ti-20	1.024 ^{T-20}	α	B	f
1	1.029	0.6	0.9	0.44

b) Field transfer rate: N

$$N = fN_0 \quad \text{kg-O}_2/\text{kw/h} \quad 0.71$$

$$\text{Total amount of transfer O}_2 \quad \text{kg-O}_2/\text{kw/d} \quad \text{kg-O}_2/\text{kw/h} \quad 17.0$$

The total axis power required to meet the required oxygen

Table 107 Required O₂ Supply

	Unit	Stage1	Stage2	Stage3
Required O ₂	kg/day	299	188	-
Required power for O ₂ supply	kW	17.6	11.1	-

3.10 Energy requirements for mixing

Table 108 Specifications of Aerator

	Unit	Stage1	Stage2	Stage3
Power for Mixing	kW/m ³	0.005	0.005	-
Lagoon volume	m ³	7,400	4,700	-
Axis power for mixing	kW	37	23.5	-
Total efficiency	-	0.75	0.75	-
Required power	kW	49	31	-
Unit power	kW/No.	11	11	-
No. of Aerator	Nos.	5	3	-

4. Leachate recirculation pump

Recirculation rate r times/leachate

Recirculation pump flow Q_r m³/day

$$Q_r = r * Q$$

Required Power P_s

$$P_s = 0.163 * Q_r (\text{m}^3/\text{min}) * H (\text{m}) / \eta \quad \text{Horse power}$$

Here

Total head of the pump H m

Total efficiency η

Liquid density ρ_s 1.05

From the entrance of anaerobic lagoon to landfill

Table 109 Specifications of Leachate Recirculation Pump

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
r	-	3	3	-
Qr	m ³ /day	2,910	1,830	-
	m ³ /min	2.02	1.27	-
Head	m	50	50	-
η	-	0.56	0.56	-
Ps	Horse power	15.4	19.4	-
	kW	11.6	14.6	-
Unit power	kW/No.	15	19	-
Nos. of pumps	Nos.	(2+1)	(1+1)	-

5. Maturation Pond

Design criteria

D_m : Depth of maturation pond 1.5 m

RT_m : Retention time of maturation pond 14 days

A_m : Area of maturation pond

Dimensions of maturation pond

Length L_m m

Width W_m m

Table 110 Dimensions of Maturation Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
RT_m	days	14	14	-
V_m	m ³	13,580	8,540	-
Nos. of Ponds	-	2	2	-
V_m /Pond	m ³	6,790	4,270	-
D_m /Pond	m	1.5	1.5	-
A_m /Pond	m ²	4,600	2,900	-
L_m /Pond	m	120	90	-
W_m /Pond	m	40	35	-

Pond arrangement: Series

Leachate Treatment Alternatives of New Guanabacoa

Alternative 1: Aerated Lagoon + Maturation Pond with recirculation -New Guanabacoa

(Remarks): Dimensions are at mid-depth. Height allowance should be 50 cm at least.

This system is the same as the one which was adopted in the original pilot project in Campo Florido. However only aerated lagoon can not remove T-BOD₅ and SS. Therefore maturation pond after aerated lagoon was proposed.

1. Premises

1.1 There are no discharge quality criteria for treated leachate. Therefore, a temporary guideline was proposed as follows.

Table 111 Proposed Water Quality Criteria

Leachate Quality	Unit-mg/L		
	T-BOD ₅	SS	S-BOD ₅
Inlet	920	540	600
Outlet	60	70	30
Removal rate (%)	93.5	87.0	95

Even though discharge quality criteria are established in the future, only removal of T-BOD₅ and SS is considered by this system.

There are some estimation formula for leachate generation, including the one with the consideration of evaporation, however, in case of using pond system as the final treatment, pond volume is designed with ignoring evaporation.

1) Leachate generation

Stage1	A ₁	6.0 ha	60,000 m ²
Stage2	A ₂	4.0 ha	40,000 m ²
Stage3	A ₃	0.0 ha	0 m ²

Once surface liner facility is constructed in landfill site, it is assumed that no water flows into the landfill site

$$q = f \cdot C \cdot A \cdot I / 1000 \text{ (m}^3\text{/day)}$$

Where

q: Daily effluent amount of leachate water(m³/day)

C: Leachate coefficient of on-going landfill section 0.4

I: Annual maximum rainfall (mm/day)

Maximum rainfall during 2000 to 2002 338 mm in September in 2002
11.3 mm/day

A: Landfill area (m²)

f: Safety factor 1.6

Q: Daily effluent amount of leachate with safety factor (m³/day)

Table 112 Proposed Leachate Volume

Q (m ³ /day)	Stage1	Stage2	Stage3
	730	610	0

2. Leachate treatment

2.1 Aerated Lagoon Process Design

Design Base:

	Symbol	Unit	
Influent flow	Q	m ³ /d	
Influent suspended solids	SS ₀	mg/L	540
Influent soluble BOD ₅	S ₀	mg/L	920
Effluent soluble BOD ₅	S-BOD _{5-out}	mg/L	30
Effluent suspended solid after settling	SSe	mg/L	70
Kinetic coefficients:		l/d	0.65
Y		mg-BOD ₅ /L	100
Ks		mg-BOD ₅ /L/d	6.0
Kmax		l/d	0.07
Kd	k ₍₂₀₎	l/d	2.5
First order soluble BOD ₅ removal rate constants at 20 °C	Ti	°C	21.0
Waste water temperature			
in leachate	α		0.6
in treated water	β		0.9
Oxygen concentration to be maintained in liquid		mg-O ₂ /L	1.5
Lagoon depth	H	m	3.5
Design mean cell - residence time	θc	d	14

2.2 Surface area of the lagoon

$$\theta c = V/Q \quad \therefore V = \theta c * Q \quad V: \text{volume of the lagoon}$$

$$A = V/H$$

Dimension

Table 113 Dimensions of Aerated Lagoon

	Unit	Stage1	Stage2	Stage3
V	m ³	6,160	4,060	-
A	m ²	1,760	1,160	-
L	m	60	60	-
W	m	30	20	-
H	m	3.5	3.5	-
A' (Connected A)	m ²	1,800	1,200	-
V' (Connected V)	m ³	6,300	4,200	-

Number of lagoon: 1

2.3 Soluble effluent BOD₅ at the lagoon outlet: S-BOD_{5-out}

$$S\text{-BOD}_5 \text{ out} = \{Ks (1+\theta c * kd)\} / \{ \theta c (Y * kmax - kd) - 1 \} (\text{mg/L})$$

Ks	$\theta_c \cdot kd$	$1 + \theta_c \cdot kd$	$Ks (1 + \theta_c \cdot kd)$	θ_c	$Y \cdot k_{max}$	$Y \cdot k_{max} - kd$	$\theta_c (Y \cdot k_{max} - kd) - 1$	S-BOD ₅ out
100	0.98	1.98	198	14	3.9	3.83	52.6	3.8

2.4 Effluent BOD₅

1) Correct the removal-rate for temperature effects

$$k(t) = k(20) \cdot \theta^{T-20}$$

Ti	$k_{(20)}$	T-20	θ	$\theta^{(T-20)}$	$k_{(20)} \theta^{(T-20)}$
21.0	2.5	1	1.06	1.06	2.7

2) Determine the effluent BOD₅: St-out (mg/L)

kt	V/Q	$1 + kV/Q$	$1/(1 + kV/Q)$	S ₀	St-out
2.7	14	38.10	0.03	920	24

2.5 Concentration of biological solids produced : X(mg/L)

$$X = Y(S_0 - S - BOD_{5-out}) / (1 + kd\theta_c) \text{ (mg-VSS/L)}$$

Y	$S_0 - S - BOD_{5-out}$	kd	θ_c	$Y(S_0 - S - BOD_{5-out}) / (1 + kd\theta_c)$
0.65	916.2	0.07	14	301

2.6 Suspended solids in the lagoon before settling

$$SS_i = \text{Influent suspended solids} + X/0.7 \text{ (mg/L)}$$

SS ₀	X	SS _i
540	301	970

Ratio of volatile suspended solid 0.7

2.7 Oxygen requirements

$$Q_2 \text{ (kg/d)} = Q(S_0 - S - BOD_{5-out}) / f - 1.42Px$$

f: conversion factor for BOD₅ to BODL 0.68

$$Px = Q \cdot (\text{concentration of biological solids produced})$$

Table 114 Required O₂

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
S _{0-s} -BOD _{5-out}	mg/L	916	916	-
f	-	0.68	0.68	-
Px	kg/day	132	87	-
Required O ₂	kg/day	405	267	-

2.8 Ratio of oxygen required to BOD₅ removed

BOD₅ removed (kg/d)

O₂/BOD₅ removed

Table 115 Removed BOD₅

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
S _{0-S} -BOD _{5-out}	mg/L	916	916	-
BOD ₅ removed	kg/day	403	266	-
O ₂ /BOD ₅	-	1.0	1.0	-

2.9 Surface aerator power requirements

assumption: kg-O₂/kw/h kg-O₂/kw/h No 1.6

a) Correction factor for surface aerators for summer conditions f

$f = N_o / N$

1) Oxygen saturation concentration at 21 °C C_s(21) mg/L 8.91

2) C_s(20) mg/L 9.08

3) Do concentration in Lagoon C_L mg/L 1.5

$$f = \{B \cdot C_s(T - C_L)\} / \{C_s(20) \cdot 1.024^{T-20} \cdot \alpha\}$$

Ti-20	1.024 ^{T-20}	α	B	f
1	1.029	0.6	0.9	0.44

b) Field transfer rate : N

N=fN_o kg-O₂/kw/h 0.71

Total amount of transfer O₂ kg-O₂/kw/d kg-O₂/kw/h 17.0

The total axis power required to meet the required oxygen

Table 116 Required O₂ Supply

	Unit	Stage1	Stage2	Stage3
Required O ₂	kg/day	405	267	-
Required power for O ₂ supply	kw	23.8	15.7	-

2.10 Energy requirements for mixing

Table 117 Specifications of Aerator

	Unit	Stage1	Stage2	Stage3
Power for Mixing	kW/m ³	0.005	0.005	-
Lagoon volume	m ³	6,300	4,200	-
Axis power for mixing	kW	31.5	21	-
Total efficiency	-	0.75	0.75	-
Required power	kW	42	28	-
Unit Power	kW/No.	11	11	-
No. of Aerator	Nos.	5	4	-

3. Solid separation for aerated lagoon

3.1 Design Base:

1) Process: maturation pond

2) HRT (days): t

3) Depth (m) D

Necessary Area (m²) A

$$A = Qt/d$$

Volume of the maturation pond (m³) V

$$V = A * D_0$$

The effluent SS may be expected to be at about 50-100 mg/L

Dimension Length L

Width W

Height H

Table 118 Dimension of Maturation Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
t	days	14	14	-
V	m ³	6,160	4,060	-
No. of Ponds	-	2	2	-
D ₀	m	1.5	1.5	-
A/pond	m ²	2,100	1,400	-
D/pond	m	70	60	-
W/pond	m	30	25	-
A' (corrected A)/pond	m ²	2,100	1,500	-

4. Leachate recirculation pump

1) Recirculation rate r times/leachate

Recirculation pump flow Q_r m³/day

$$Q_r = r * Q$$

Required Power Ps
 $Ps = 0.163 * Q_r(m^3/min) * H(m) / \eta$ Hose power

Here

Total head of the pump H m
 Total efficiency η
 Liquid density ρ_s 1.05

From the entrance of aerated lagoon to landfill

Table 119 Specifications of Leachate Recirculation Pump

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
r	-	3	3	-
Q _r	m ³ /day	2,9910	1,830	-
	m ³ /min	2.02	1.27	-
Head	m	50	50	-
η	-	0.56	0.56	-
Ps	Horse power	15.4	19.4	-
	kW	11.6	14.6	-
Unit power	kW/No.	15	19	-
Nos. of pumps	Nos.	(2+1)	(1+1)	-

**Alternative 2: Aerated Lagoon + Sedimentation Pond + Wetland with recirculation
-New Guanabacoa**

(Remarks): Dimensions are at mid-depth. Height allowance should be 50 cm at least.

This system is the same as the one which was adopted in the original pilot project in Campo Florido. However only aerated lagoon can not remove T-BOD₅ and SS. Therefore sedimentation pond and wetland were proposed.

1. Premises

1.1 There are no discharge quality criteria for treated leachate. Therefore, a temporary guideline was proposed as follows.

Table 120 Proposed Water Quality Criteria

Leachate Quality	Unit-mg/L		
	T-BOD ₅	SS	S-BOD ₅
Inlet	920	540	600
Outlet	60	70	30
Removal rate (%)	93.5	87.0	95

Even though discharge quality criteria are established in the future, only removal of T-BOD₅ and SS is considered by this system.

There are some estimation formula for leachate generation, including the one with the consideration of evaporation, however, in case of using pond system as the final treatment, pond volume is designed with ignoring evaporation.

1) Leachate generation

Landfill Area

Stage1	A ₁	6.0 ha	60,000 m ²
Stage2	A ₂	4.0 ha	40,000 m ²
Stage3	A ₃	0.0 ha	0 m ²

Once surface liner facility is constructed in landfill site, it is assumed that no water flows into the landfill site

$$q = f \cdot C \cdot A \cdot I / 1000 \text{ (m}^3\text{/day)}$$

Where

q: Daily effluent amount of leachate water(m³/day)

C: Leachate coefficient of on-going landfill section 0.4

I: Annual maximum rainfall (mm/day)

Maximum rainfall during 2000 to 2002 338 mm in September in 2002
11.3 mm/day

A: Landfill area (m²)

f: Safety factor 16

Q: Daily effluent amount of leachate with safety factor (m³/day)

Table 121 Proposed Leachate Volume

Q (m ³ /day)	Stage1	Stage2	Stage3
	440	290	0

2. Leachate treatment

2.1 Aerated Lagoon Process Design

Design Base:

	Symbol	Unit	
Influent flow	Q	m ³ /d	
Influent suspended solids	SS ₀	mg/L	540
Influent soluble BOD ₅	S ₀	mg/L	920
Effluent soluble BOD ₅	S-BOD _{5-out}	mg/L	30
Effluent suspended solid after settling	S _{Se}	mg/L	70
Kinetic coefficients:		l/d	0.65
Y		mg-BOD ₅ /L	100
K _s		mg-BOD ₅ /L/d	6.0
K _{max}		l/d	0.07
K _d	k ₍₂₀₎	l/d	2.5
First order soluble BoD5 removal rate constants at 20 °C	T _i	°C	21.0
Waste water temperature			
in leachate	α		0.6
in treated water	β		0.9
Oxygen concentration to be maintained in liquid		mg-O ₂ /L	1.5
Lagoon depth	H	m	3.5
Design mean cell - residence time	θ _c	d	14

2.2 Surface area of the lagoon

$$\theta_c = V/Q \quad \therefore V = \theta_c * Q \quad V: \text{volume of the lagoon}$$

$$A = V/H$$

Dimension

Table 122 Dimensions of Aerated Lagoon

	Unit	Stage1	Stage2	Stage3
V	m ³	6,160	4,060	-
A	m ²	1,760	1,160	-
L	m	60	60	-
W	m	30	20	-
H	m	3.5	3.5	-
A' (Connected A)	m ²	1,800	1,200	-
V' (Connected V)	m ³	6,300	4,200	-

Number of lagoon: 1

2.3 Soluble effluent BOD₅ at the lagoon outlet: S-BOD₅-out

$$S\text{-BOD}_{5\text{-out}} = \{K_s (1+\theta_c \cdot k_d)\} / \{ \theta_c (Y \cdot k_{\max} - k_d) - 1 \} (\text{mg/L})$$

K _s	θ _c ·k _d	1+θ _c ·k _d	K _s (1+θ _c ·k _d)	θ _c	Y·k _{max}	Y·k _{max} -k _d	θ _c (Y·k _{max} -k _d)-1	S-BOD ₅ -out
100	0.98	1.98	198	14	3.9	3.83	52.6	3.8

2.4 Effluent BOD₅

1) Correct the removal-rate for temperature effects

$$k(t) = k(20) \cdot \theta^{T-20}$$

T _i	k ₍₂₀₎	T-20	θ	θ ^(T-20)	k ₍₂₀₎ θ ^(T-20)
21.0	2.5	1	1.06	1.06	2.7

2) Determine the effluent BOD₅: S_t-out (mg/L)

kt	V/Q	1+kV/Q	1/(1+kV/Q)	S ₀	S _t -out
2.7	14	38.10	0.03	920	24

2.5 Concentration of biological solids produced: X (mg/L)

$$X = Y (S_0 - S\text{-BOD}_{5\text{-out}}) / (1 + k_d \theta_c) (\text{mg-VSS/L})$$

Y	S ₀ -S-BOD ₅ -out	k _d	θ _c	Y(S ₀ -S-BOD ₅ -out)/(1+k _d θ _c)
0.65	916.2	0.07	14	301

2.6 Suspended solids in the lagoon before settling

$$SS_i = \text{Influent suspended solids} + X/0.7 (\text{mg/L})$$

SS ₀	X	SS _i
540	301	970

Ratio of volatile suspended solid 0.7

2.7 Oxygen requirements

$$Q_2 (\text{kg/d}) = Q(S_0 - S\text{-BOD}_{5\text{-out}}) / f - 1.42 P_x$$

f: conversion factor for BOD₅ to BOD_L 0.68

$$P_x = Q \cdot (\text{concentration of biological solids produced})$$

Table 123 Required O₂

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
S ₀ -S-BOD _{5-out}	mg/L	916	916	-
f	-	0.68	0.68	-
Px	kg/day	132	87	-
Required O ₂	kg/day	405	267	-

2.8 Ratio of oxygen required to BOD₅ removed

BOD₅ removed (kg/d)

O₂/BOD₅ removed

Table 124 Removed BOD₅

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
S ₀ -S-BOD _{5-out}	mg/L	916	916	-
BOD ₅ removed	kg/day	403	266	-
O ₂ /BOD ₅	-	1.0	1.0	-

2.9 Surface aerator power requirements

assumption: kg-O₂/kw/h

a) Correction factor for surface aerators for summer conditions f

$$f = N_o / N$$

1) Oxygen saturation concentration at 21 °C Cs(21) mg/L 8.91

2) Cs(20) mg/L 9.08

3) Do concentration in Lagoon C_L mg/L 1.5

$$f = \{B \cdot C_s T - C_L\} / C_s (20) \cdot 1.024^{T-20} \cdot \alpha$$

Ti-20	1.024 ^{T-20}	α	B	f
1	1.029	0.6	0.9	0.44

b) Field transfer rate: N

N = fN_o kg-O₂/kw/h 0.71

Total amount of transfer O₂ kg-O₂/kw/d kg-O₂/kw/h 17.0

The total axis power required to meet the required oxygen

Table 125 Required O₂ Supply

	Unit	Stage1	Stage2	Stage3
Required O ₂	kg/day	405	267	-
Required power for O ₂ supply	kw	23.8	15.7	-

2.10 Energy requirements for mixing

Table 126 Specifications of Aerator

	Unit	Stage1	Stage2	Stage3
Power for Mixing	kW/m ³	0.005	0.005	-
Lagoon volume	m ³	6,300	4,200	-
Axis power for mixing	kW	31.5	21	-
Total efficiency	-	0.75	0.75	-
Required power	kW	42	28	-
Unit Power	kW/No.	11	11	-
No. of Aerator	Nos.	5	4	-

3. Leachate recirculation pump

1) Recirculation rate r times/leachate

Recirculation pump flow Q_r m³/day

$$Q_r = r \cdot Q$$

Required Power P_s

$$P_s = 0.163 \cdot Q_r (\text{m}^3/\text{min}) \cdot H (\text{m}) / \eta$$

Horse power

Here

Total head of the pump H m

Total efficiency η

Liquid density ρ_s 1.05

From the entrance of aerated lagoon to landfill

Table 127 Specifications of Leachate Recirculation Pump

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	970	610	-
r	-	3	3	-
Q_r	m ³ /day	2,910	1,830	-
	m ³ /min	2.02	1.27	-
Head	m	50	50	-
η	-	0.56	0.56	-
P_s	Horse power	15.4	19.4	-
	kW	11.6	14.6	-
Unit power	kW/No.	15	19	-
Nos. of pumps	Nos.	(2+1)	(1+1)	-

4. Solid-liquid separation: sedimentation tank

Q_i : Inflow m³/day

Safety factor 3

R.T: Retention time at $Q_i \cdot 3$ hr

OL: Overflow rate at $Q_i \cdot 3$ m³/m²/day

$$Q_i \cdot C_i = Q_o \cdot C_o + Q_u \cdot C_u$$

Ci: Inflow SS	mg/L
Co: Outflow SS	mg/L
Cu: Concentrated SS in the sedimentation tank	mg/L
Qo: Outflow	m ³ /day
Qu: Underflow (Sludge flow)	m ³ /day
Qu = Qi-Qo	m ³ /day
Qo=Qi*(Cu-Ci) / (Cu-Co)	m ³ /day
As: Surface area = Qo/OL	m ²
Dimension	
Ls: Length of sedimentation tank	m
Ws: Width of sedimentation tank	m
Hs: Height of sludge zone = Vs/As	m
Vs: Volume of sedimentation tank	m ³
H2: Height allowance = Vs/As	m ²

Table 128 Dimension of sedimentation tank

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
Qi	m ³ /day	1,320	870	-
RT	hr	2	2	-
OL	m ³ /m ² /day	22	22	-
Ci	mg/L	970	970	-
Co	mg/L	70	70	-
Cu	mg/L	5,000	5,000	-
Qo	m ³ /day	1,100	700	-
As	m ²	50	40	-
Ls	m	20	10	-
Ws	m	4	4	-
Hs	m	2.2	2.0	-
Vs	m ³	110	80	-
Qu	m ³ /day	220	170	-
H2	m	1.5	1.5	-
H0	m	3.7	3.8	-

Total Height Ho=H2+Hs

5. To removal nutrients, use wetland.

Only by aerated lagoon, only BOD₅ and SS are removed. For further treatment for nutrients another process is necessary.

Here, wetland was considered as an alternative for this purpose, considering cost efficiency.

Levels of nitrogen and phosphates are estimated as below based on the analysis of leachate during this Study.

Total-N: 240 mg/L

Total-P: 64 mg/L

In biological treatment nitrogen and phosphate are necessary. The ratio of N and P towards BOD₅ is 3:0.3:100

Therefore N and P after biological treatment, their levels are expected as below.

Inlet BOD₅ 920 mg/L

Therefore N to be removed by biological treatment 27.6 mg/L

Therefore P to be removed by biological treatment 2.76 mg/L

After aerated lagoon remained N 212 mg/L

P 61 mg/L

Criteria*	
20	mg/L. as KTN
10	mg/L. as P

*:Discharge criteria of industrial waste water into general public water body

Inlet T-P level will be reduced by using cover soil.

Therefore, only removal of nitrogen would be considered.

Here, subsurface-flow (SSF) systems was considered.

In a SSF wetland, the basin is filled with gravel or some other coarse substrate, and the water level is maintained below-ground. Water flows horizontally, or sometimes vertically, through the gravel and the root mat of the wetland vegetation.

Arrow arum (Polyandry spp.) and Pickerel weed (Pontederia spp.) have been used in constructed wetlands.

Also common reed (Phragmitescommunis) is used




Figure 7 Conceptual diagram of subsurface-flow wetlands

Example of determination of basin design for SFS wetlands system

Nitrogen removal will proceed when BOD₅ level is less than 10 mg/L.

1. Premises

Influent BOD ₅	C ₀	60 mg/L
Effluent BOD ₅	C _e	8 mg/L
Inflow	Q	m ³ /day
		m ³ /day
Vegetation type		cattails
Minimum water temperature	T	21°C
Basin media		coarse sand with 2 mm of maximum effective size
Basin slope	S	0.01

2. Solution

1. Basin depth for use wit cattail	d	0.3 m
2. Porosity	α	0.39
Hydraulic conductivity	K _s	480 m ³ /m ² /day
	K ₂₀	1.35
3. Temperature-dependent first order rate constant		
	K _T at	21 °C
		1.49 d ⁻¹
4. Pore-space detention time	t' = -lnC _e /C ₀ /K _t	d
5. Cross-sectional area	A _c = Q/K _s /S	m ²
6. Basin width	W = A _c /d	m
7. Basin length	L = t'Q/W/d/α	m
8. Required surface area	A _s = L*W	m ²
		ha
9. Check hydraulic-loading rate or specific area requirements		
	L _w = Q/L/W	150 to 500 m ³ /ha/day
		0.015 to 0.005 m ³ /m ² /day
or	A _{sp} = 1/L _w for advanced treatment	2.1 ha/10 ³ m ³
10. Check BOD ₅ loading rate	Max.BOD _{5L}	60 kg/ha/day
LBOD ₅		kg/day
BOD _{5L}		kg/ha/day
11. Vegetation		
Reed can absprb	N	18 to 21g/kg
	P	2.0 to 3.0 g/kg
Inlet N		212.4 mg/L
Vd: vegetation density		10 kg/m ²

Table 129 Specification of Wetland

	Unit	Stage1	Stage2	Stage3
C ₀	mg/L	60	60	-
C _e	mg/L	8	8	-
Q	m ³ /day	440	290	-
T	°C	21	21	-
S		0.01	0.01	-
d	m	0.3	0.3	-
α		0.39	0.39	-
K _s	m ³ /m ² /day	480	480	-
K ₂₀		1.35	1.35	-
K _t	d ⁻¹	1.49	1.49	-
t'	day	1.36	1.36	-
A _c	m ²	92	60	-
W	m	310	210	-
L	m	16	16	-
A _s	m ²	5,200	3,400	-
L _w	m ³ /m ² /day	0.09	0.09	-
A _{sp}	ha/1000m ³	11.60	11.60	-
L-BOD ₅	kg/day	26.4	17.4	-
BOD _{5L}	kg/ha/day	51	51	-
V	m ³	1,560	1,020	-
R.T	day	3.5	3.5	-
Inlet N	mg/L	212	212	-
Total N in WL	g	340,000	220,000	-
N absorption	g/kg	18	18	-
Nos. of reed	kg	18,889	12,222	-
V _d	kg/m ²	10	10	-
Max Reed	kg	52,000	34,000	-

**Alternative 3: Natural Pond System (Anaerobic + Facultative + Maturation Pond)
-New Guanabacoa**

(Remarks): Dimensions are at mid-depth. Height allowance should be 50 cm at least.

This system is so called natural pond system to remove BOD₅, SS and nutrients such as N and P.

1. Premises

1.1 There are no discharge quality criteria for treated leachate. Therefore, a temporary guideline was proposed as follows.

Table 130 Proposed Water Quality Criteria

Leachate Quality	Unit-mg/L		
	T-BOD ₅	SS	S-BOD ₅
Inlet	920	540	600
Outlet	60	70	30
Removal rate (%)	93.5	87.0	95

Even though discharge quality criteria are established in the future, only removal of T-BOD₅ and SS is considered by this system.

There are some estimation formula for leachate generation, including the one with the consideration of evaporation, however, in case of using pond system as the final treatment, pond volume is designed with ignoring evaporation.

1.2 Recirculation rate of leachate 3 times/day toward the leachate generated

2. Anaerobic pond

RTa: Retention time of anaerobic pond			7 days
BOD ₅ Removal rate			60%
BOD ₅ out-a			368 mg/L
Da: Depth of the anaerobic pond			3.5 m
Aa: Surface area			m ²
Va: Anaerobic pond volume			m ³
Dimension	Length	La	m
	Width	Wa	m
BOD _{5La} : BOD ₅ load of anaerobic pond			100 to 350 g-BOD ₅ /m ³ -pond/day

Table 131 Dimension of Anaerobic Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	940	290	-
R.T	days	7	7	-
Va	m ³	3,080	2,080	-
Da	m	3.5	3.5	-
Aa	m ²	880	580	-
La	m	50	40	-
Wa	m	20	15	-
BOD ₅	g/day	404,800	266,800	-
BOD _{5La}	g/m ³ /day	131	131	-

Number of ponds: 1

3. Facultative Pond

ls₁: BOD permissible loading kg/ha/day
 $ls_1 = 350 (1.107 - 0.002T)^{T-25}$ 100 to 400 kg/ha/day

or

$ls_2 = 20T-120$ kg/ha/day
 Here, T: Minimum temperature 21 °C

Ls: BOD₅ loading

$Ls = 10 Li Q / Af$ kg/ha/day

Here,

Li: Inflow BOD₅ mg/L

Af: Facultative pond area m²

$Af = Q *(Li - Le)/18D/(1.05)^{T-20}$

Here,

Le: Outflow BOD₅ mg/L

L_r: BOD₅ removal kg/ha/day

$Lr = 0.725Ls \div 10.75$

Df: Depth of the facultative pond m

Dimensions of facultative pond Length Lf m

Width Wf m

Table 132 Dimension of Sedimentation Tank

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
T	°C	21	21	-
ls ₁	kg/ha/day	272	272	-
ls ₂	kg/ha/day	300	300	-
Ls	kg/ha/day	270	267	-
Li	mg/L	368	368	-
Df	m	1.2	1.2	-
Af	m ²	6,000	4,000	-
Le	mg/L	60	60	-
Lr	kg/ha/day	206	204	-
BOD _{5RF}	%	76.5	76.5	-
BOD _{5out-f}	mg/L	87	87	-
R.T _f	days	16	17	-

Remarks:

- (a) There is a difference between ls₁ and ls₂. Adopt ls₁ for safety.
- (b) There is a difference between Le and BOD_{5out-f}. This is because Equations for Ls and Af are the one to get 60 mg/L-BOD₅ in South America.
- (c) On the contrary, the value of BOD_{5out-f} is calculated by the equation for Lr. Lr shows the average of the data arranged by MacGarry and Pescord.
- (d) The BOD₅ removal in primary facultative ponds is usually in the range 70-80 percent based on unfiltered samples (that is, including the BOD exerted by the algae).
Therefore, effluent BOD_{5out-f} level from facultative pond will be considered 60-117 mg/L with algae.
- (e) It is said BOD₅ quality of the effluent from a facultative ponds as most of the BOD contained (70 to 90%) will be "algal BOD. Therefore, the filtered (soluble) BOD₅ level will be at least 18-35 mg/L.

Table 133 Dimensions of Facultative Pond

	Unit	Stage1	Stage2	Stage3
Af	m ²	6,000	4,000	-
Nos. of ponds	-	2	2	-
Af/pond	m ²	3,000	2,000	-
Lf/pond	m	90	70	-
Wf/pond	m	35	30	-
Df	m	1.2	1.2	-
Vf/pond	m ³	3,780	2,520	-
Total Vf	m ³	7,560	5,040	-

Pond arrangement: Parallel

4. Maturation pond

Maturation ponds (low-cost polishing ponds, which succeed the primary or secondary facultative pond) are primarily designed for tertiary treatment, i.e., the removal of pathogens, nutrients and possibly algae.

With the combination of facultative pond and maturation pond,

- (1) Total nitrogen removal in WSP systems can reach 80 percent or more, and ammonia removal can be as high as 95 percent.
- (2) The best way of increasing phosphorus removal in WSP is to increase the number of

maturation ponds, so that progressively more and more phosphorus becomes immobilized in the sediments. From a well functioning 2 ponds system, 70% mass removal of total.

- (3) The removal rate increases by adding maturation ponds.

Design criteria

D_m : Depth of maturation pond 1.5 m
 RT_m : Retention time of maturation pond 14 days
 A_m : Area of maturation pond

Dimensions of maturation pond

Length L_m m
 Width W_m m

Table 134 Dimensions of Maturation Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
RT_m	days	14	14	-
V_m	m ³	6,160	4,060	-
Nos. of Ponds	-	2	2	-
V_m /Pond	m ³	3,080	2,030	-
D_m /Pond	m	1.5	1.5	-
A_m /Pond	m ²	2,100	1,400	-
L_m /Pond	m	70	60	-
W_m /Pond	m	30	25	-

Pond arrangement: Series

5. Leachate Recirculation pump

Recirculation rate r times/leachate

Recirculation pump flow Q_r m³/day

$Q_r = r * Q$

Required Power P_s

$P_s = 0.163 * Q_r(m^3/min) * H(m) / \eta$ Horse power

Here

Total head of the pump H m

Total efficiency η

Liquid density ρ_s 1.05

From the entrance of anaerobic lagoon to landfill

Table 135 Specifications of Leachate Recirculation Pump

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
r	-	3	3	-
Qr	m ³ /day	1,320	870	-
	m ³ /min	0.92	0.60	-
Head	m	40	40	-
η	-	0.56	0.56	-
Ps	Horse power	11.2	7.4	-
	kW	8.4	5.5	-
Unit power	kW/No.	11	7.5	-
Nos. of pumps	Nos.	(1+1)	(1+1)	-

Alternative 4: Natural Pond System (Anaerobic + Facultative + Wetland) -New Guanabacoa

(Remarks): Dimensions are at mid-depth. Height allowance should be 50 cm at least.

This system is an alternative to use wetland instead of Maturation Pond in Alternative 3 in order to remove nutrients such as N and P.

1. Premises

1.1 There are no discharge quality criteria for treated leachate. Therefore, a temporary guideline was proposed as follows.

Table 136 Proposed Water Quality Criteria

Leachate Quality	Unit-mg/L		
	T-BOD ₅	SS	S-BOD ₅
Inlet	920	540	600
Outlet	60	70	30
Removal rate (%)	93.5	87.0	95

Even though discharge quality criteria are established in the future, only removal of T-BOD₅ and SS is considered by this system.

There are some estimation formula for leachate generation, including the one with the consideration of evaporation, however, in case of using pond system as the final treatment, pond volume is designed with ignoring evaporation.

1.2 Recirculation rate of leachate 3 times/day toward the leachate generated

2. Anaerobic pond

RTa : Retention time of anaerobic pond			7 days
BOD ₅ Removal rate			60%
BOD ₅ out-a			368 mg/L
Da: Depth of the anaerobic pond			3.5 m
Aa: Surface area			m ²
Va: Anaerobic pond volume			m ³
Dimension	Length	La	m
	Width	Wa	m
BOD _{5La} : BOD ₅ load of anaerobic pond			100 to 350 g-BOD ₅ /m ³ -pond/day

Table 137 Dimension of Anaerobic Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
R.T	days	7	7	-
Va	m ³	3,080	2,030	-
Da	m	3.5	3.5	-
Aa	m ²	880	580	-
La	m	50	40	-
Wa	m	20	15	-
BOD ₅	g/day	404,800	266,800	-
BOD _{5La}	g/m ³ /day	131	131	-

Number of ponds: 1

3. Facultative Pond

ls₁: BOD permissible loading kg/ha/day
 $ls_1 = 350 (1.107 - 0.002T)^{T-25}$ 100 to 400 kg/ha/day

or

$ls_2 = 20T-120$ kg/ha/day
 Here, T: Minimum temperature 21 °C

Ls: BOD₅ loading

$Ls = 10 Li Q / Af$ kg/ha/day

Here,

Li: Inflow BOD₅ mg/L

Af: Facultative pond area m²

$Af = Q *(Li - Le)/18D/(1.05)^{T-20}$

Here,

Le: Outflow BOD₅ mg/L

L_r: BOD₅ removal kg/ha/day

$Lr = 0.725Ls \div 10.75$

Df: Depth of the facultative pond m

Dimensions of facultative pond Length Lf m

Width Wf m

Table 138 Dimension of Sedimentation Tank

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
T	°C	21	21	-
ls ₁	kg/ha/day	272	272	-
ls ₂	kg/ha/day	300	300	-
Ls	kg/ha/day	270	267	-
Li	mg/L	368	368	-
Df	m	1.2	1.2	-
Af	m ²	6,000	4,000	-
Le	mg/L	60	60	-
Lr	kg/ha/day	206	204	-
BOD _{5RF}	%	76.5	76.5	-
BOD _{5out-f}	mg/L	87	87	-
R.T _f	days	16	17	-

Remarks:

- There is a difference between ls₁ and ls₂. Adopt ls₁ for safety.
- There is a difference between Le and BOD_{5out-f}. This is because Equations for Ls and Af are the one to get 60 mg/L-BOD₅ in South America.
- On the contrary, the value of BOD_{5out-f} is calculated by the equation for Lr. Lr shows the average of the data arranged by MacGarry and Pescord.
- The BOD₅ removal in primary facultative ponds is usually in the range 70-80 percent based on unfiltered samples (that is, including the BOD exerted by the algae).
Therefore, effluent BOD_{5out-f} level from facultative pond will be considered 60-117 mg/L with algae.
- It is said BOD₅ quality of the effluent from a facultative ponds as most of the BOD contained (70 to 90%) will be "algal BOD. Therefore, the filtered (soluble) BOD₅ level will be at least 18-35 mg/L.

Table 139 Dimensions of Facultative Pond

	Unit	Stage1	Stage2	Stage3
Af	m ²	6,000	4,000	-
Nos. of ponds	-	2	2	-
Af/pond	m ²	3,000	2,000	-
Lf/pond	m	90	70	-
Wf/pond	m	35	30	-
Df	m	1.2	1.2	-
Vf/pond	m ³	3,780	2,520	-
Total Vf	m ³	7,560	5,040	-

Pond arrangement: Parallel

4. To removal nutrients, use wetland

Only by aerated lagoon, only BOD₅ and SS are removed. For further treatment for nutrients another process is necessary.

Here, wetland was considered as an alternative for this purpose, considering cost efficiency.

Levels of nitrogen and phosphates are estimated as below based on the analysis of leachate during this Study.

Total-N: 240 mg/L

Total-P: 64 mg/L

In biological treatment nitrogen and phosphate are necessary. The ratio of N and P towards BOD₅ is 3:0.3:100

Therefore N and P after biological treatment, their levels are expected as below.

Inlet BOD₅ 920 mg/L

Therefore N to be removed by biological treatment 27.6 mg/L

Therefore P to be removed by biological treatment 2.76 mg/L

After aerated lagoon remained N N 212 mg/L

P 61 mg/L

Criteria*	
20	mg/L. as KTN
10	mg/L. as P

*:Discharge criteria of industrial waste water into general public water body

Inlet T-P level will be reduced by using cover soil. Therefore, only removal of nitrogen would be considered.

Here, subsurface-flow (SSF) systems was considered.

In a SSF wetland, the basin is filled with gravel or some other coarse substrate, and the water level is maintained below-ground. Water flows horizontally, or sometimes vertically, through the gravel and the root mat of the wetland vegetation.

Arrow arum (Polyandry spp.) and Pickerel weed (Pontederia spp.) have been used in constructed wetlands.

Also common reed (Phragmitescommunis) is used




Figure 8 Conceptual diagram of subsurface-flow wetlands

Example of determination of basin design for SFS wetlands system

Nitrogen removal will proceed when BOD₅ level is less than 10 mg/L.

1. Premises

Influent BOD ₅	C ₀	87 mg/L
Effluent BOD ₅	C _e	8 mg/L
Inflow	Q	m ³ /day
		m ³ /day
Vegetation type		cattails
Minimum water temperature	T	21°C
Basin media		coarse sand with 2 mm of maximum effective size
Basin slope	S	0.01

2. Solution

1. Basin depth for use wit cattail	d	0.3 m
2. Porosity	α	0.39
Hydraulic conductivity	K _s	480 m ³ /m ² /day
	K ₂₀	1.35
3. Temperature-dependent first order rate constant	K _T at	21 °C
		1.49 d ⁻¹
4. Pore-space detention time	$t' = -\ln C_e/C_0/K_t$	d
5. Cross-sectional area	$A_c = Q/K_s/S$	m ²
6. Basin width	$W = A_c/d$	m
7. Basin length	$L = t'Q/W/d/\alpha$	m
8. Required surface area	$A_s = L*W$	m ²
		ha
9. Check hydraulic-loading rate or specific area requirements	$L_w = Q/L/W$	150 to 500 m ³ /ha/day
		0.015 to 0.005 m ³ /m ² /day
or	$A_{sp} = 1/L_w$ for advanced treatment	2.1 ha/10 ³ m ³
10. Check BOD ₅ loading rate	Max.BOD _{5L}	60kg/ha/day
	LBOD ₅	kg/day
	BOD _{5L}	kg/ha/day
11. Vegetation		
Reed can absprb	N	18 to 21g/kg
	P	2.0 to 3.0 g/kg
Inlet N		240 mg/L
Vd: vegetation density		10 kg/m ²

Table 140 Specification of Wetland

	Unit	Stage1	Stage2	Stage3
C ₀	mg/L	87	87	-
C _e	mg/L	8	8	-
Q	m ³ /day	440	290	-
T	°C	21	21	-
S		0.01	0.01	-
d	m	0.3	0.3	-
α		0.39	0.39	-
K _s	m ³ /m ² /day	480	480	-
K ₂₀		1.35	1.35	-
K _t	d ⁻¹	1.49	1.49	-
t'	day	1.61	1.61	-
A _c	m ²	92	60	-
W	m	310	210	-
L	m	19	19	-
A _s	m ²	6,100	4,000	-
L _w	m ³ /m ² /day	0.07	0.07	-
A _{sp}	ha/1000m ³	13.74	13.74	-
L-BOD ₅	kg/day	38.3	25.23	-
BOD _{5L}	kg/ha/day	63	63	-
V	m ³	1,830	1,200	-
RT	day	4.2	4.1	-
Inlet N	mg/L	240	240	-
Total N in WL	g	440,000	290,000	-
N absorption	g/kg	18	18	-
Nos. of reed	kg	24,444	290,000	-
V _d	kg/m ²	10	10	-
Max Reed	kg	61,000	40,000	-

This system seems to be inferior in performance.

5. Leachate Recirculation pump

Recirculation rate r times/leachate

Recirculation pump flow Q_r m³/day

$$Q_r = r * Q$$

Required Power P_s

$$P_s = 0.163 * Q_r (\text{m}^3/\text{min}) * H (\text{m}) / \eta$$
Horse power

Here

Total head of the pump H m

Total efficiency η

Liquid density ρ_s 1.05

From the entrance of anaerobic lagoon to landfill

Table 141 Specifications of Leachate Recirculation Pump

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
r	-	3	3	-
Qr	m ³ /day	1,320	870	-
	m ³ /min	0.92	0.60	-
Head	m	40	40	-
η	-	0.56	0.56	-
Ps	Horse power	11.2	7.4	-
	kW	8.4	5.5	-
Unit power	kW/No.	11	7.5	-
Nos. of pumps	Nos.	(1+1)	(1+1)	-

Alternative 5: Anaerobic Pond + Aerated Lagoon + Sedimentation Pond + Wetland with recirculation -New Guanabacoa

(Remarks): Dimensions are at mid-depth. Height allowance should be 50 cm at least.

This system is an alternative adding Anaerobic Pond to Alternative 2 in order to reduce area.

1. Premises

1.1 There are no discharge quality criteria for treated leachate. Therefore, a temporary guideline was proposed as follows.

Table 142 Proposed Water Quality Criteria

Leachate Quality	Unit-mg/L		
	T-BOD ₅	SS	S-BOD ₅
Inlet	920	540	600
Outlet	60	70	30
Removal rate (%)	93.5	87.0	95

Even though discharge quality criteria are established in the future, only removal of T-BOD₅ and SS is considered by this system.

There are some estimation formula for leachate generation, including the one with the consideration of evaporation, however, in case of using pond system as the final treatment, pond volume is designed with ignoring evaporation.

1.2 Recirculation rate of leachate 3 times/day toward the leachate generated

2. Anaerobic pond

RTa : Retention time of anaerobic pond			7 days
BOD ₅ Removal rate			60%
BOD ₅ out-a			368 mg/L
Da: Depth of the anaerobic pond			3.5 m
Aa: Surface area			m ²
Va: Anaerobic pond volume			m ³
Dimension	Length	La	m
	Width	Wa	m
BOD _{5La} : BOD ₅ load of anaerobic pond			100 to 350 g-BOD ₅ /m ³ -pond/day

Table 143 Dimension of Anaerobic Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
R.T	days	7	7	-
Va	m ³	3,080	2,030	-
Da	m	3.5	3.5	-
Aa	m ²	880	580	-
La	m	50	40	-
Wa	m	20	15	-
BOD ₅	g/day	404,800	266,800	-
BOD _{5La}	g/m ³ /day	131	131	-

Number of ponds: 1

3. Aerated Lagoon

3.1 Aerated Lagoon Process

Design Base:

	Symbol	Unit	
Influent flow	Q	m ³ /d	
Influent suspended solids	SS ₀	mg/L	378
Influent soluble BOD ₅	S ₀	mg/L	368
Effluent soluble BOD ₅	S-BOD _{5-out}	mg/L	30
Effluent suspended solid after setting	SSe	mg/L	70

Kinetic coefficients:

Y		l/d	0.65
Ks		mg-BOD ₅ /L	100
Kmax		mg-BOD ₅ /L/d	6.0
Kd		l/d	0.07

First order soluble BOD₅ removal rate constants at 20 °C

	k ₍₂₀₎	l/d	2.5
Waste water temperature	Ti	°C	21.0

Aeration constants in leachate

in leachate	α		0.6
in treated water	β		0.9
Oxygen concentration to be maintained in liquid		mg - O ₂ /L	1.5
Lagoon depth	H	m	3.5
Design mean cell - residence time	θ _c	d	7

3.2 Surface area of the lagoon A m²

$$\theta c = V/Q \quad \therefore V = \theta c * Q \quad V: \text{volume of the lagoon}$$

$$A = V/H$$

Dimension

Table 144 Dimension of Aerated Lagoon

	Unit	Stage1	Stage2	Stage3
V	m ³	3,080	2,030	-
A	m ²	880	580	-
L	m	50	40	-
W	m	20	15	-
H	m	3.5	3.5	-
A' (corrected A)	m ²	1,000	600	-
V' (Corrected V)	m ³	3,500	2,100	-

3.3 Soluble effluent BOD₅ at the lagoon outlet: S-BOD₅-out

$$S\text{-BOD}_{5\text{out}} = \{ K_s (1 + \theta c * k_d) \} / \{ \theta c (Y * k_{\text{max}} - k_d) - I \} \quad (\text{mg/L})$$

Ks	$\theta c * k_d$	$1 + \theta c * k_d$	$K_s (1 + \theta c * k_d)$	θc	$Y * k_{\text{max}}$	$Y * k_{\text{max}} - k_d$	$\theta c (Y * k_{\text{max}} - k_d) - I$	S-BOD ₅ out
100	0.49	1.49	149	7	3.9	3.83	25.8	5.8

3.4 Effluent BOD₅

(1) Correct the removal-rate for temperature effects

$$k(t) = k(20) * \theta^{T-20} \quad (\text{l/d})$$

Ti	$k_{(20)}$	T-20	θ	$\theta^{(T-20)}$	$k_{(20)}\theta^{(T-20)}$
21.0	2.5	1	1.06	1.06	2.7

(2) Determine the effluent BOD₅: St_{-out} (mg/L)

$$St\text{-out}/S_0 = 1/(1+k\theta_H) = S/S_0 = 1/(1+kV/Q)$$

kt	V/Q	$1+kV/Q$	$1/(1+kV/Q)$	S ₀	St-out
2.7	7	19.55	0.05	368	19

3.5 Concentration of biological solids produced: X (mg/L)

$$X = Y (S_0 - S - \text{BOD}_{5\text{-out}}) / (1 + k_d \theta c) \quad (\text{mg-VSS/L})$$

Y	$S_0 - S - \text{BOD}_{5\text{-out}}$	k_d	θc	$Y(S_0 - S - \text{BOD}_{5\text{-out}}) / (1 + k_d \theta c)$
0.65	362.2	0.07	7	158

3.6 Suspended solids in the lagoon before settling

$$SSi = \text{Influent suspended solids} + X/0.7(\text{mg/L})$$

Ratio of volatile suspended solid 0.7

SSo	X	SSi
378	158	604

3.7 Oxygen requirements

$$Q_2 (\text{kg/d}) = Q (S_0 - S - \text{BOD}_{5-\text{out}}) / f - 1.42P_x$$

f: conversion factor for BOD₅ to BOD_L 0.68

P_x = Q*(concentration of biological solids produced)

Table 145 Required O₂

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
S ₀ -S-BOD _{5-out}	mg/L	362	362	-
f	-	0.68	0.68	-
P _x	kg/day	70	46	-
Required O ₂	kg/day	136	89	-

3.8 Ratio of oxygen required to BOD₅ removed

BOD₅ removed (kg/d)

O₂/BOD₅ removed

Table 146 Removed BOD₅

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
S ₀ -S-BOD _{5-out}	mg/L	362	362	-
BOD ₅ removed	kg/day	159	105	-
O ₂ /BOD ₅	-	0.9	0.9	-

3.9 Surface aerator power requirements

assumption: kg-O₂/kw/h kg-O₂/kw/h No 1.6

a) Correction factor for surface aerators for summer conditions f

$$f = N_0 / N$$

1) Oxygen saturation concentration at 21 °C Cs(21) mg/L 8.91

2) Cs(20) mg/L 9.08

3) DO concentration in Lagoon CL mg/L 1.5

$$f = \{B * C_s T - CL\} / C_s (20) * 1.024^{T-20} * \alpha$$

Ti-20	1.024^{T-20}	α	B	f
1	1.029	0.6	0.9	0.44

b) Field transfer rate : N

$$N = fN_0 \quad \text{kg-O}_2/\text{kw/h} \quad 0.71$$

$$\text{Total amount of transfer O}_2 \quad \text{kg-O}_2/\text{kw/d} \quad \text{kg-O}_2/\text{kw/h} \quad 17.0$$

The total axis power required to meet the required oxygen

Table 147 Required O₂ Supply

	Unit	Stage1	Stage2	Stage3
Required O ₂	kg/day	136	89	-
Required power for O ₂ supply	kW	8.0	5.3	-

3.10 Energy requirements for mixing

Table 148 Specifications of Aerator

	Unit	Stage1	Stage2	Stage3
Power for Mixing	kW/m ³	0.005	0.005	-
Lagoon volume	m ³	3,500	2,100	-
Axis power for mixing	kW	17.5	10.5	-
Total efficiency	-	0.75	0.75	-
Required power	kW	23	14	-
Required power per unit	kW/No.	11	11	-
Power for Mixing	Nos.	3	2	-

4. Leachate recirculation pump

Recirculation rate r times/leachate

Recirculation pump flow Q_r m³/day

$$Q_r = r \cdot Q$$

Required Power P_s

$$P_s = 0.163 \cdot Q_r (\text{m}^3/\text{min}) \cdot H (\text{m}) / \eta \quad \text{Horse power}$$

Here

Total head of the pump H m

Total efficiency η

Liquid density ρ_s 1.05

From the entrance of anaerobic lagoon to landfill

Table 149 Specifications of Leachate Recirculation Pump

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
r	-	3	3	-
Qr	m ³ /day	1,320	870	-
	m ³ /min	0.92	0.60	-
Head	m	40	40	-
η	-	0.56	0.56	-
Ps	Horse power	11.2	7.4	-
	kW	8.4	5.5	-
Unit power	kW/No.	11	7.5	-
Nos. of pumps	Nos.	(1+1)	(1+1)	-

5. Solid-liquid separation: sedimentation tank

Qi: Inflow	m ³ /day
Safety factor	3
R.t: Retention time at Qi*3	hr
OL: Overflow rate at Qi*3	m ³ /m ² /day
Qi*Ci = Qo*Co+Qu*Cu	
Ci: Inflow SS	mg/L
Co: Outflow SS	mg/L
Cu: Concentrated SS in the sedimentation tank	mg/L
Qo: Outflow	m ³ /day
Qu: Underflow (Sludge flow)	m ³ /day
Qu = Qi-Qo	m ³ /day
Qo = Qi*(Cu-Ci) / (Cu-Co)	m ³ /day
As: surface area=Qo/OL	m ³
Dimension	Ls: Length of sedimentation tank m
	Ws: Width of sedimentation tank m
Hs: Height of sludge zone =Vs/As	m
Vs: Volume of sedimentation tank	m ³
H ₂ : Height allowance = Vs/As	m ²

Table 150 Dimension of Sedimentation Tank

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
Qi	m ³ /day	1,320	870	-
R.T	hr	2	2	-
O _L	m ³ /m ² /day	22	22	-
C _i	mg/L	604	604	-
C _o	mg/L	70	70	-
C _u	mg/L	5,000	5,000	-
Q _o	m ³ /day	1,200	800	-
A _s	m ²	60	40	-
L _s	m	20	10	-
W _s	m	5	4	-
H _s	m	1.9	2.0	-
V _s	m ³	110	80	-
Q _u	m ³ /day	120	70	-
H ₂	m	1.5	1.5	-
H ₀	m	3.4	3.5	-

6. To removal nutrients, use wetland.

Only by aerated lagoon, only BOD₅ and SS are removed. For further treatment for nutrients another process is necessary.

Here, wetland was considered as an alternative for this purpose, considering cost efficiency.

Levels of nitrogen and phosphates are estimated as below based on the analysis of leachate during this Study.

Total-N:	240	mg/L
Total-P:	64	mg/L

In biological treatment nitrogen and phosphate are necessary. The ratio of N and P towards BOD₅ is 3:0.3:100

Therefore N and P after biological treatment, their levels are expected as below.

Inlet BOD ₅	920	mg/L	
Therefore N to be removed by biological treatment	27.6	mg/L	
Therefore P to be removed by biological treatment	2.76	mg/L	
After aerated lagoon remained N	N	212	mg/L
	P	61	mg/L

Criteria*	
20	mg/L. as KTN
10	mg/L. as P

*:Discharge criteria of industrial waste water into general public water body

Inlet T-P level will be reduced by using cover soil.


Therefore, only removal of nitrogen would be considered.

Here, subsurface-flow (SSF) systems was considered.

In a SSF wetland, the basin is filled with gravel or some other coarse substrate, and the water level is maintained below-ground. Water flows horizontally, or sometimes vertically, through the gravel and the root mat of the wetland vegetation.

Arrow arum (*Polyandry* spp.) and Pickerel weed (*Pontederia* spp.) have been used in constructed wetlands.

Also common reed (*Phragmites communis*) is used



**Figure 9 Conceptual diagram of
subsurface-flow wetlands**

Example of determination of basin design for SFS wetlands system

Nitrogen removal will proceed when BOD₅ level is less than 10 mg/L.

1. Premises

Influent BOD ₅	C ₀	60 mg/L
Effluent BOD ₅	C _e	8 mg/L
Inflow	Q	m ³ /day
		m ³ /day
Vegetation type		cattails
Minimum water temperature	T	21°C
Basin media		coarse sand with 2 mm of maximum effective size
Basin slope	S	0.01

2. Solution

1. Basin depth for use wit cattail	d	0.3 m
2. Porosity	α	0.39
Hydraulic conductivity	K _s	480 m ³ /m ² /day
	K ₂₀	1.35
3. Temperature-dependent first order rate constant	K _T at	21°C
		1.49 d ⁻¹
4. Pore-space detention time	$t' = -\ln C_e/C_0/K_t$	d
5. Cross-sectional area	$A_c = Q/K_s/S$	m ²
6. Basin width	$W = A_c/d$	m
7. Basin length	$L = t'Q/W/d/\alpha$	m
8. Required surface area	$A_s = L*W$	m ²
		ha
9. Check hydraulic-loading rate or specific area requirements	$L_w = Q/L/W$	150 to 500 m ³ /ha/day
		0.015 to 0.005 m ³ /m ² /day
or	$A_{sp} = 1/L_w$ for advanced treatment	2.1 ha/10 ³ m ³
10. Check BOD ₅ loading rate	Max.BOD _{5L}	60 kg/ha/day
LBOD ₅		kg/day
BOD _{5L}		kg/ha/day
11. Vegetation		
Reed can absorb	N	18 to 21 g/kg
	P	2.0 to 3.0 g/kg
Inlet N		212.4 mg/L
Vd: vegetation density		10 kg/m ²

Table 151 Specification of Wetland

	Unit	Stage1	Stage2	Stage3
C ₀	mg/L	60	60	-
C _e	mg/L	8	8	-
Q	m ³ /day	440	290	-
T	°C	21	21	-
S		0.01	0.01	-
d	m	0.3	0.3	-
α		0.39	0.39	-
K _s	m ³ /m ² /day	480	480	-
K ₂₀		1.35	1.35	-
K _t	d ⁻¹	1.49	1.49	-
t'	day	1.36	1.36	-
A _c	m ²	92	60	-
W	m	310	210	-
L	m	16	16	-
A _s	m ²	5,200	3,400	-
L _w	m ³ /m ² /day	0.09	0.09	-
A _{sp}	ha/1000m ³	11.60	11.60	-
L-BOD ₅	kg/day	26.4	17.4	-
BOD _{5L}	kg/ha/day	51	51	-
V	m ³	1,560	1,020	-
R.T	day	3.5	3.5	-
Inlet N	mg/L	212	212	-
Total N in WL	g	340,000	220,000	-
N absorption	g/kg	18	18	-
Nos. of reed	kg	18,889	12,222	-
V _d	kg/m ²	10	10	-
Max Reed	kg	52,000	34,000	-

**Alternative 6: Anaerobic Pond + Aerated Lagoon + Maturation Pond with recirculation
-New Guanabacoa**

(Remarks): Dimensions are at mid-depth. Height allowance should be 50 cm at least.

This system is an alternative adding Anaerobic Pond to Alternative 1 to reduce area.

1. Premises

1.1 There are no discharge quality criteria for treated leachate. Therefore, a temporary guideline was proposed as follows.

Table 152 Proposed Water Quality Criteria

Leachate Quality	Unit-mg/L		
	T-BOD ₅	SS	S-BOD ₅
Inlet	920	540	600
Outlet	60	70	30
Removal rate (%)	93.5	87.0	95

Even though discharge quality criteria are established in the future, only removal of T-BOD₅ and SS is considered by this system.

There are some estimation formula for leachate generation, including the one with the consideration of evaporation, however, in case of using pond system as the final treatment, pond volume is designed with ignoring evaporation.

1.2 Recirculation rate of leachate 3 times/day toward the leachate generated

2. Anaerobic pond

RTa: Retention time of anaerobic pond			7 days
BOD ₅ Removal rate			60%
BOD ₅ out-a			368 mg/L
Da: Depth of the anaerobic pond			3.5 m
Aa: Surface area			m ²
Va: Anaerobic pond volume			m ³
Dimension	Length	La	m
	Width	Wa	m
BOD _{5La} : BOD ₅ load of anaerobic pond			100 to 350 g-BOD ₅ /m ³ -pond/day

Table 153 Dimension of Anaerobic Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
R.T	days	7	7	-
Va	m ³	3,080	2,030	-
Da	m	3.5	3.5	-
Aa	m ²	880	580	-
La	m	50	40	-
Wa	m	20	15	-
BOD ₅	g/day	404,800	266,800	-
BOD _{5La}	g/m ³ /day	131	131	-

Number of ponds: 1

3. Aerated Lagoon

3.1 Aerated Lagoon Process

Design Base:

	Symbol	Unit	
Influent flow	Q	m ³ /d	
Influent suspended solids	SS ₀	mg/L	378
Influent soluble BOD ₅	S ₀	mg/L	368
Effluent soluble BOD ₅	S-BOD _{5-out}	mg/L	30
Effluent suspended solid after setting	S _{Se}	mg/L	70

Kinetic coefficients:

Y		l/d	0.65
K _s		mg-BOD ₅ /L	100
K _{max}		mg-BOD ₅ /L/d	6.0
K _d		l/d	0.07

First order soluble BOD₅ removal rate constants at 20 °C

	k ₍₂₀₎	l/d	2.5
Waste water temperature	T _i	°C	21.0

Aeration constants in leachate

in leachate	α		0.6
in treated water	β		0.9
Oxygen concentration to be maintained in liquid		mg - O ₂ /L	1.5
Lagoon depth	H	m	3.5
Design mean cell - residence time	θ _c	d	7

3.2 Surface area of the lagoon A m²

$$\theta c = V/Q \quad \therefore V = \theta c * Q \quad V: \text{volume of the lagoon}$$

$$A = V/H$$

Dimension

Table 154 Dimension of Aerated Lagoon

	Unit	Stage1	Stage2	Stage3
V	m ³	3,080	2,030	-
A	m ²	880	580	-
L	m	50	40	-
W	m	20	15	-
H	m	3.5	3.5	-
A' (corrected A)	m ²	1,000	600	-
V' (Corrected V)	m ³	3,500	2,100	-

3.3 Soluble effluent BOD₅ at the lagoon outlet: S-BOD₅-out

$$S\text{-BOD}_{5\text{out}} = \{ K_s (1 + \theta c * k_d) \} / \{ \theta c (Y * k_{\text{max}} - k_d) - I \} \quad (\text{mg/L})$$

Ks	$\theta c * k_d$	$1 + \theta c * k_d$	$K_s (1 + \theta c * k_d)$	θc	$Y * k_{\text{max}}$	$Y * k_{\text{max}} - k_d$	$\theta c (Y * k_{\text{max}} - k_d) - I$	S-BOD ₅ out
100	0.49	1.49	149	7	3.9	3.83	25.8	5.8

3.4 Effluent BOD₅

(1) Correct the removal-rate for temperature effects

$$k(t) = k(20) * \theta^{T-20} \quad (\text{l/d})$$

Ti	$k_{(20)}$	T-20	θ	$\theta^{(T-20)}$	$k_{(20)}\theta^{(T-20)}$
21.0	2.5	1	1.06	1.06	2.7

(2) Determine the effluent BOD₅: St_{-out} (mg/L)

$$St\text{-out}/S_0 = 1/(1+k\theta_H) = S/S_0 = 1/(1+kV/Q)$$

kt	V/Q	$1+kV/Q$	$1/(1+kV/Q)$	S ₀	St-out
2.7	7	20	0.05	368	19

3.5 Concentration of biological solids produced: X (mg/L)

$$X = Y (S_0 - S - \text{BOD}_{5\text{-out}}) / (1 + k_d \theta c) \quad (\text{mg-VSS/L})$$

Y	S ₀ -S-BOD _{5-out}	k _d	θ _c	Y(S ₀ -S-BOD _{5-out})/(1+k _d θ _c)
0.65	362.2	0.07	7	158

3.6 Suspended solids in the lagoon before settling

$$SS_i = \text{Influent suspended solids} + X/0.7(\text{mg/L})$$

Ratio of volatile suspended solid 0.7

SS ₀	X	SS _i
378	158	604

3.7 Oxygen requirements

$$Q_2 (\text{kg/d}) = Q (S_0\text{-S-BOD}_{5\text{-out}})/f - 1.42P_x$$

f: conversion factor for BOD₅ to BOD_L 0.68

$$P_x = Q * (\text{concentration of biological solids produced})$$

Table 155 Required O₂

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
S ₀ -s-BOD _{5-out}	mg/L	362	362	-
f	-	0.638	0.68	-
P _x	kg/day	70	46	-
Required O ₂	kg/day	136	89	-

3.8 Ratio of oxygen required to BOD₅ removed

BOD₅ removed (kg/d)

O₂/BOD₅ removed

Table 156 Removed BOD₅

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
S ₀ -S-BOD _{5-out}	mg/L	362.2	362.2	-
BOD ₅ removed	kg/day	159	105	-
O ₂ /BOD ₅	-	0.9	0.9	-

3.9 Surface aerator power requirements

assumption: kg-O₂/kw/h kg-O₂/kw/h No 1.6

a) Correction factor for surface aerators for summer conditions f

$$f = N_0/N$$

1) Oxygen saturation concentration at 21 °C C_s(21) mg/L 8.91

2) C_s(20) mg/L 9.08

3) DO concentration in Lagoon CL mg/L 1.5

$$f = \{B * C_s T - CL\} / C_s (20) * 1.024^{T-20} * \alpha$$

Ti-20	1.024 ^{T-20}	α	B	f
1	1.029	0.6	0.9	0.44

b) Field transfer rate: N

$$N = fN_0 \quad \text{kg-O}_2/\text{kw/h} \quad 0.71$$

$$\text{Total amount of transfer O}_2 \quad \text{kg-O}_2/\text{kw/d} \quad \text{kg-O}_2/\text{kw/h} \quad 17.0$$

The total axis power required to meet the required oxygen

Table 157 Required O₂ Supply

	Unit	Stage1	Stage2	Stage3
Required O ₂	kg/day	136	89	-
Required power for O ₂ supply	kW	8.0	5.3	-

3.10 Energy requirements for mixing

Table 158 Specifications of Aerator

	Unit	Stage1	Stage2	Stage3
Power for Mixing	kW/m ³	0.005	0.005	-
Lagoon volume	m ³	3,500	2,100	-
Axis power for mixing	kW	17.5	10.5	-
Total efficiency	-	0.75	0.75	-
Required power	kW	23	14	-
Unit power	kW/No.	11	11	-
No. of Aerator	Nos.	(3+1)	(2+1)	-

4. Leachate recirculation pump

Recirculation rate r times/leachate

Recirculation pump flow Q_r m³/day

$$Q_r = r * Q$$

Required Power P_s

$$P_s = 0.163 * Q_r (\text{m}^3/\text{min}) * H (\text{m}) / \eta \quad \text{Horse power}$$

Here

Total head of the pump H m

Total efficiency η

Liquid density ρ_s 1.05

From the entrance of anaerobic lagoon to landfill

Table 159 Specifications of Leachate Recirculation Pump

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
r	-	3	3	-
Qr	m ³ /day	1,320	870	-
	m ³ /min	0.92	0.60	-
Head	m	40	40	-
η	-	0.56	0.56	-
Ps	Horse power	11.2	7.4	-
	kW	8.4	5.5	-
Unit power	kW	11	7.5	-
Nos. of pumps	Nos.	(1+1)	(1+1)	-

5. Maturation Pond

Design criteria

D_m : Depth of maturation pond 1.5 m

RT_m : Retention time of maturation pond 14 days

A_m : Area of maturation pond

Dimensions of maturation pond

Length Lm m

Width Wm m

Table 160 Dimensions of Maturation Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
RT_m	days	14	14	-
V_m	m ³	6,160	4,060	-
Nos. of Ponds	-	2	2	-
V_m /Pond	m ³	3,080	2,030	-
D_m /Pond	m	1.5	1.5	-
A_m /Pond	m ²	2,100	1,400	-
L_m /Pond	m	70	60	-
W_m /Pond	m	30	25	-

Pond arrangement: Series

C. Final Disposal:

C5 Supplemental Explanation on Leachate

Treatment System


C5 SUPPLEMENTAL EXPLANATION ON LEACHATE TREATMENT SYSTEM

Table of Contents


1. Adopted leachate treatment system in this project with flow diagram, quality and major facility	C5.2
2. Outline of adopted leachate treatment system	C5.5
3. Example of the capacity calculation on the adopted treatment system	C5.6
4. Out line of alternative study on selecting leachate treatment system	C5.10
5. References regarding wastewater treatment system and adopted treatment system with the design parameters	C5.11
6. Examples of leachate treatment systems in other parts of the world	C5.12

1. Adopted leachate treatment system in this project with flow diagram, quality and major facility

1.1 Location: NEW GUANABACOA



1.2 NEW SITE 1



1.3 Calle 100

<p>Recirculation to landfill</p> <p>From landfill BOD=920mg/L</p> <p>920 mg/L</p> <p>Anaerobic pond</p> <p>Legend: (P) Leachate recirculation pump</p>			
Retention time	7 days		
1st stage	Design flow = 730m ³ /day		
2nd stage	Design flow = 610m ³ /day		
In T-BOD ₅ (mg/L)	920		
Out T-BOD ₅ (mg/L)	368		
BOD removal rate (%)	60		
In SS (mg/L)	540		
Out SS (mg/L)	378		
Size of pond			
1st stage			
Width (m)	25		
Length (m)	60		
Effective depth (m)	3.5		
No. of pond	1		
Surface area (m ²)	1,500		
Volume of pond (m ³)	5,250		
2nd stage			
Width (m)	22		
Length (m)	60		
Effective depth (m)	3.5		
No. of pond	1		
Surface area (m ²)	1,320		
Volume of pond (m ³)	4,620		
Specification of leachate recirculation pump			
1st stage	1.52m ³ /min x50mH x19kw x (1+1)		including 1 spare
2nd stage	1.27m ³ /min x50mH x19kw x (1+1)		including 1 spare

2. Outline of adopted leachate treatment system

Leachate is discharged from the landfill to the treatment system. The proposed leachate treatment system consists of an anaerobic pond, aerated lagoon, and maturation pond.

In the anaerobic pond, high organic load is removed as it is best to pretreat strong wastes having a high solid content. The solids settle to the bottom where they are digested anaerobically. The retention time is set at 7 days and BOD removal ratio at 60%. The treated leachate in the anaerobic pond is sent to the aerated lagoon and is also recirculated to the landfill. The recirculated landfill undergoes contact filtration system, although the treatment efficiency is not considered in calculation.

In the aerated lagoon, BOD removal is estimated at about 85% for a 7-day retention time. The aerated lagoon is developed as a modified waste stabilization pond (facultative pond) for hot climates where mechanical aeration is used to supplement the algal oxygen supply. Aerators are installed to add oxygen into the pond and to mix water in the lagoon. The capacity of the aerators is designed based on the power required for mixing water in the lagoon. Treated wastewater at the aerated lagoon flows into the maturation pond.

The aerated lagoon effluent includes high BOD due to the presence of bacteria. The maturation pond predominantly reduces the bacterial cells, still the BOD is also considerably reduced. Moreover the maturation pond destroys pathogens. Two maturation ponds in series, each with a retention time of 7 days, are provided to achieve the treatment.

A sludge pump is provided to remove sludge from the maturation pond and anaerobic pond, and hence to facilitate maintenance of the ponds.

It is desirable to construct a storage pond to reduce the peak inflow and to stabilize the leachate quality to the leachate treatment system, but it is not included due to financial constraints. To mitigate the negative impact, when influent flow exceeds the design flow due to high rainfall, the following actions are taken, i) inflow is stopped by closing the inflow gate, ii) the inflow is stored in the ponds, iii) the recirculation of flow to the landfill site by the leachate recirculation pump is increased.

3. Example of the capacity calculation on the adopted treatment system

Capacity calculation of Alternative 6 for New Guanabacoa landfill is described below as an example of the adopted leachate treatment system. Parameters used in the calculation are obtained from “Wastewater Engineering, Metcalf & Eddy, Third Edition, 1991”, although they shall be established based on experimental results. So, the retention time of ponds is set with a high safety factor.

1. Premises)

1.1 Planned Leachate Quality

There is no discharge quality criteria for treated leachate. Therefore, a temporally guideline was proposed as the following.

Leachate quality	Unit: mg/L		
	T-BOD ₅	SS	S-BOD ₅
Inlet	920	540	600
Outlet	60	70	30
Removal rate (%)	93.5	87.0	95

Even though discharge quality criteria are established in the future, only removal of T-BOD₅ and SS is considered by this system.

There are some estimation formula for leachate generation, including the one with the consideration of evaporation, however, in case of using pond system as the final treatment, pond volume is designed with ignoring evaporation.

1.2 Estimated Leachate Generation

Landfill Area

Stage 1	A ₁	6.0 ha	60,000 m ²
Stage 2	A ₂	4.0 ha	40,000 m ²
Stage 3	A ₃	0.0 ha	0 m ²

Once surface liner facility is constructed in landfill site, it is assumed that no water flows into the landfill site.

$$q = f \cdot C \cdot A \cdot I / 1000 \text{ (m}^3/\text{day)}$$

Where

q : Daily effluent amount of leachate water (m³/day)

C: Leachate coefficient of on-going landfill section

0.4

I: Annual maximum rainfall (mm/day)

Maximum rainfall during 2000 to 2002

338 mm in September in 2002

11.3 mm/day

A: Landfill area (m²)

f: Safety factor

1.6

Q : Daily effluent amount of leachate with safety factor (m³/day)

Q (m ³ /day)	Stage1	Stage2	Stage3
	440	290	-

2. Anaerobic Pond

RTa : Retention time of anaerobic pond 7 days

BOD₅ Removal rate 60 %

BOD₅ out-a 368 mg/L

SS Removal rate 30 %

SSout 378 mg/L

Da: Depth of the anaerobic pond 3.5 m

Aa: Surface area required m²

Va: Anaerobic pond volume required m³

Dimension Length La m

Width Wa m

BOD_{5La} : BOD₅ load of anaerobic pond

100 to 350 g-BOD₅/ m³-pond/day

Dimensions of Anaerobic Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
R.T	days	7	7	-
Va	m ³	3,080	2,030	-
Da	m	3.5	3.5	-
Aa	m ²	880	580	-
La	m	50	40	-
Wa	m	20	15	-
BOD ₅	g/day	404,800	266,800	-
BOD _{5La}	g/m ³ /day	131	131	-

Number of ponds: 1

3. Aerated Lagoon

3.1 Aerated Lagoon Process

Design Base :

Influent flow volume estimated	Q (stage 1)	m ³ /d	440
	Q (stage 2)	m ³ /d	290
Influent suspended solids	SS ₀	mg/L	378
Influent soluble BOD ₅	S ₀	mg/L	368
Effluent soluble BOD ₅	S-BOD _{5-out}	mg/L	30
Effluent suspended solid after settling	SSe	mg/L	70
Kinetic coefficients :			
Sludge conversion ratio from BOD ₅ removed	Y	1/d	0.65
Saturation constant	K _s	mg-BOD ₅ /L	100
Maximum substrate usage velocity	K _{max}	mg-BOD ₅ /L/d	6.0
Endogenous decay coefficient	K _d	1/d	0.07
First order soluble BOD ₅ removal rate constants at 20 °C	k ₍₂₀₎	1/d	2.5
Waste water temperature	T _i	°C	21.0
Aeration constants in leachate			
in leachate	α		0.6
in treated water	β		0.9
Oxygen concentration to be maintained in liquid		mg - O ₂ /L	1.5
Lagoon depth	H	m	3.5
Design mean cell - residence time	θ _c	d	7

3.2 Surface area of the lagoon

$$V \text{ required} = \theta_c * Q$$

V: volume of lagoon

$$A \text{ required} = V \text{ required} / H$$

Dimensions of Aerated Lagoon

	Unit	Stage1	Stage2	Stage3
V required	m ³	3,080	2,030	-
A required	m ²	880	580	-
L	m	50	40	-
W	m	20	15	-
H	m	3.5	3.5	-
A designed	m ²	1,000	600	-
V designed	m ³	3,500	2,100	-

3.3 Soluble effluent BOD₅ at lagoon outlet: S-BOD_{5-out}

$$S\text{-BOD}_{5\text{out}} = \left\{ \frac{K_s (1 + \theta_c * k_d)}{\theta_c (Y * k_{\max} - k_d) - 1} \right\} \quad (\text{mg/L})$$

K _s	θ _c *k _d	1 + θ _c *k _d	K _s (1 + θ _c *k _d)	θ _c	Y * k _{max}	Y * k _{max} - k _d	θ _c (Y * k _{max} - k _d) - 1	S-BOD _{5-out}
100	0.49	1.49	149	7	3.9	3.83	25.8	5.8

3.4 Effluent BOD₅:

3.4.1 Modify the removal-rate for temperature effects

$$k(t) = k(20) * \theta^{T-20} \quad (1/d)$$

T _i	k ₍₂₀₎	T-20	θ	θ ^(T-20)	k ₍₂₀₎ θ ^(T-20)
21.0	2.5	1	1.06	1.060	2.7

3.4.2 Determine the effluent BOD₅ : St_{-out} (mg/L)

$$St\text{-out}/S_0 = 1/(1 + k\theta_H) = S/S_0 = 1/(1 + kV/Q)$$

kt	V/Q	1 + kV/Q	1/(1 + kV/Q)	S ₀	St-out
2.7	7	19.55	0.05	368	19

<60 OK

3.5 Concentration of biological solids produced : X (mg/L)

$$X = Y(S_0 - S\text{-BOD}_{5\text{-out}}) / (1 + k_d \theta_c) \quad (\text{mg} - \text{VSS} / \text{L})$$

BOD removal rate at AL=1-60/368=84%

Y	S ₀ - S-BOD _{5-out}	k _d	θ _c	Y(S ₀ - S-BOD _{5-out}) / (1 + k _d θ _c)
0.65	362.2	0.07	7	158

3.6 Suspended solids in the lagoon before settling

$$SS_i = SS_0 + X/0.7 \text{ (mg/L)}$$

0.7 = Ratio of volatile suspended solid

SS ₀	X	SS _i
378	158	604

It is reduced to be less than 70 in MP . OK

3.7 Oxygen requirements

$$O_2 \text{ (kg/d)} = Q (S_0 - S - BOD_{5-out})/f - 1.42P_x$$

f : conversion factor for BOD₅ to BOD_L = 0.68

$$P_x = Q*(\text{concentration of biological solids produced})$$

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
So-S-BOD _{5-out}	mg/L	362	362	-
f	-	0.68	0.68	-
P _x	kg/day	70	46	-
Required O ₂	kg/day	136	89	-

3.8 Ratio of oxygen required to BOD₅ removed

BOD₅ removed (kg/d)

O₂/BOD₅ removed

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
So-S-BOD _{5-out}	mg/L	362	362	-
BOD ₅ removal	kg/day	159	105	-
O ₂ /BOD ₅	-	0.9	0.9	-

3.9 Surface aerator power requirements

assumed Unit Oxygen supply per power: No

kg-O₂/kw/h 1.6

a) Modification factor for surface aerators for summer conditions f f = No/N

1) Oxygen saturation concentration at 21 °C

C_{s(21)} mg/L 8.91

2) C_{s(20)}

mg/L 9.08

3) DO concentration in Lagoon

C_L mg/L 1.5

$$f = \{(\beta * C_{sT} - C_L) / C_{s(20)} * 1.024^{T-20} * \alpha\}$$

Ti-20	1.024 ^{T-20}	α	β	f
1	1.024	0.6	0.9	0.44

b) Field transfer rate : N

$$N = f N_0$$

kg-O₂/kw/h 0.71

Total amount of transfer O₂ kg-O₂/kw/d

kg-O₂/kw/d 16.9

The total axis power required to meet the required oxygen

	Unit	Stage1	Stage2	Stage3
Required O ₂	kg/day	136	89	-
Required power for O ₂ supply	kW	8.0	5.3	-

3.10 Energy requirements for mixing

Specifications of Aerator

	Unit	Stage1	Stage2
Power for Mixing	kW/m ³	0.005	0.005
Lagoon volume	m ³	3,500	2,100
Axis power for mixing	kW	17.5	10.5
Total efficiency	-	0.75	0.75
Required power	kW	23	14
Unit power	kW/No.	11	11
Number of Aerator	Nos.	(3 + 1)	(2 + 1)

4. Leachate recirculation pump

1) Recirculation rate	r	times/leachate
Recirculation pump fl	Qr	m ³ /day
Qr = r*Q		
Required Power	Ps	horse power
Ps = 0.163*Qr(m ³ /min)*H(m)/η		
Here		
Total head of the pump	H	m
Total efficiency	η	
Liquid density	ρ	s 1.05
From the entrance of aerated lagoon to landfill		

Specifications of Leachate Recirculation Pump

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
r	-	3	3	-
Qr	m ³ /day	1,320	870	-
	m ³ /min	0.92	0.60	-
Head	m	40	40	-
η	-	0.56	0.56	-
Ps	Horse power	11.2	7.4	-
	kW	8.4	5.5	-
Unit power	kW/No.	11	7.5	-
No. of pumps	Nos.	(1+1)	(1+1)	-

5. Maturation Pond

<u>Design criteria</u>		
D _m : Depth of maturation pond		1.5 m
RT _m : Retention time of maturation		14 days
A _m : Area od maturation pond		
V _m = Am x Dm		
Dimensions of maturation pond.		
Length	Lm	m
Width	Wm	m

Dimensions of Maturation Pond

	Unit	Stage1	Stage2	Stage3
Q	m ³ /day	440	290	-
RT _m	days	14	14	-
V _m	m ³	6,160	4,060	-
Nos. of Ponds	-	2	2	-
V _m /Pond	m ³	3,080	2,030	-
Dm/Pond	m	1.5	1.5	-
Am/Pond	m ²	2,100	1,400	-
Lm/Pond	m	70	60	-
Wm/Pond	m	30	25	-

Pond arrangement: Series

As described above, the retention time is set at 7 days in the anaerobic ponds, 7 days in the aerated lagoon and 14 days in the maturation ponds, and the total retention time is 28 days. And each pond characteristics are set followings,

Anaerobic pond with 7 days retention time reduces BOD by 60%.

Finally, aerated lagoon with 7 days retention time and two (2) maturation ponds with each 7 days retention time reduce BOD to less than 60 mg/L.

4. Out line of alternative study on selecting leachate treatment system

Alternative 6 is adopted, after studying characteristics of six (6) alternatives shown below.

Alternative 1	Aerated Lagoon	==>	Maturation Pond	
Alternative 2	Aerated Lagoon	==>	Sedimentation Pond	==> Wet Land
Alternative 3	Anaerobic Pond	==>	Facultative Pond	==> Maturation Pond
Alternative 4	Anaerobic Pond	==>	Facultative Pond	==> Wetland
Alternative 5	Anaerobic Pond	==>	Aerated Lagoon	==> Sedimentation Pond ==> Wetland
Alternative 6	Anaerobic Pond	==>	Aerated Lagoon	==> Maturation Pond

Characteristics of the ponds applied in the Alternative 6 are described below,

- ① Anaerobic Pond: Organic matter is reduced under anaerobic conditions, and it is effective for high load wastewater. If an aerobic treatment system is applied for high load wastewater, the cost of the aerobic equipment and O/M cost are higher.
- ② Aerated Lagoon : Required area and required sheet area are reduced by introducing the aerated lagoon system.
- ③ Maturation Pond : Suspended solids contained in the effluent from the aerated lagoon are settled in the maturation pond using a long retention time. Moreover, pathogens, faecal bacteria and viruses are removed in the inhospitable environment with sun light, high dissolved oxygen and high pH.

Reasons for not selecting the other alternatives are described below,

- Alternative 1 consists of aerated lagoon + maturation pond and it does not have an anaerobic pond. The system required a large scale aerated lagoon and the OM cost is very high. So, Alternative 1 is eliminated.
- Although wetland is utilized for 2nd treatment or 3rd treatment that would remove nutrients, it is difficult to select appropriate type of plants. Moreover it is labor intensive to cut and remove them. So, Alternatives 2, 4, and 5 are not selected.
- Required retention time of the facultative pond is around one (1) month or more to remove organic matter utilizing oxygen from algal photosynthesis and surface re-aeration. It does not require any mechanical equipment and electric power and the OM is easy. However, it requires large land area. So Alternative 3 is not selected.

5. References regarding wastewater treatment system and adopted treatment system with the design parameters

1. Reference

References used in the study and design of the leachate treatment system and the relevant design parameters are given below.

(1) Ref. 1: Design Manual for Waste Stabilization Ponds in Mediterranean Countries, European Investment Bank, 1998

Kind of pond	Anaerobic Pond	Aerated Pond	Facultative Pond	Maturation Pond
Depth (m)	2 - 5	—	1 - 2	1 - 1.5
Retention time (day)	1 - 7	—	4 - 5	1 - 7
BOD removal rate (%)	40 - 70 Temperature less 10°C: 40 Temperature over 25°C: 70	—	70 - 80 Temperature: over 20°C	—

(2) Ref. 2: Wastewater Engineering, Metcalf & Eddy, Third Edition, 1991

Kind of pond	Anaerobic Pond	Aerated Pond	Facultative Pond	Maturation Pond
Retention time (day)	—	—	—	18 - 20
BOD removal rate (%)	70 - 85	Over 95	—	—

(3) Ref. 3: Sewage Treatment in Hot Climates, Duncan Mara, 1976

Kind of pond	Anaerobic Pond	Aerated Pond	Facultative Pond	Maturation Pond
Depth (m)	2-4m	3 - 5	1-1.5m	1-1.5m
Retention time (day)	5	2-6	—	7 x 2ponds
BOD removal rate (%)	70	90 以上	—	65
Remark	Over 20°C			bacteria coliform removal rate95%

2. Adopted pond system and its specification for this project

Following specification is adopted based on engineering judgment referring to the above mentioned reference and field condition.

Kind of pond	Anaerobic Pond	Aerated Pond	Maturation Pond
Depth (m)	3.5m	3.5	1.5m
Retention time (day)	7	7	7x2ponds=14
BOD removal rate (%)	60	Over 85%	

6. Examples of leachate treatment systems in other parts of the world

Examples of leachate treatment systems in Latin America, Asia and Africa are described below. (Reference: Observations of Solid Waste Landfills in Developing Countries: Africa, Asia, and Latin America, Urban Development Division, The World Bank)

1. Instances in Latin America

Leachate treatment systems at landfill sites in Latin America

Country	Brazil	Brazil	Brazil	Brazil	Brazil	Brazil	Brazil	Mexico
City	Curitiba	Caxias do Sul	Salvador	Belo Horizonte	Macaé	Rio de Janeiro	Americana	Bordo Xochiaca
Waste type	-Domestic -Demolition	-Domestic	-Domestic -Demolition	-Domestic -Demolition	-Domestic	-Domestic	-Domestic	-Domestic
Amount(t/d)	1,800	150	3,000	4,500	150	6,500	150	1,700
Leachate treatment	Lagoon	Biological + physical chemical	None	None	None	Recirculation	None	None

Country	Mexico	Mexico	Mexico	Argentina	Argentina	Chile	Chile	Colombia
City	Queretaro	Nuevo Laredo	Monterrey	Villa Dominico	Relleno Norte 3	Santiago	Colihues La-Yesca	Bogotá
Waste type	-Domestic	-Domestic -Non-hazardous industrial	-Domestic -Non-hazardous industrial	-Domestic -industrial	-Domestic -Non-hazardous industrial	-Domestic	-Domestic	-Domestic
Amount(t/d)	450	350	3,000	8,000	4,500	4,200	400	4,500
Leachate treatment	Evaporation and recirculation	Evaporation and recirculation	Recirculation	None	Physico/chemical followed by biological anaerobic / aerobic BOD in 3000ppm BOD out 80ppm,	Recirculation	Recirculation / physico-chemical	Recirculation

Country	Colombia	Colombia	Colombia	Colombia	Colombia
City	Marinilla	Viboral	Medellin	Lima South	Zapalla
Waste type	-Domestic	-Domestic	-Domestic -Demolition -Industrial -Health care	-Domestic	-Domestic
Amount(t/d)	15	5	2,000	1,200-1,400	600-700
Leachate treatment	Release of Leachate through fascine	Release of Leachate through fascine	None	None	None

As shown above, the abundance of leachate management systems applied at Latin America landfill sites are in the following order:

- 1) No treatment system applied.
- 2) Circulation and evaporation system is applied, and both are adopted in this project.
- 3) Lagoon and pond system, including anaerobic and aerobic system, is applied.

In the references it is also reported that anaerobic + aerobic + physical/chemical treatment system, which is similar to the system adopted in this project, is utilized in Relleno Norte 3 in Argentina where influent BOD is 3000 mg/L and effluent BOD is 80 mg/L, although the details are not clear.

2. Instance in Asia

A series of aeration channels followed by settlement tanks is used in Asuwei landfill in China, and it is reported that influent BOD is 1000 mg/L and effluent BOD is 60 mg/L.

The Carmona and San Mateo land fills in the Philippines and the Bantar Geban landfill in Indonesia treat leachate in aerated and facultative ponds. Leachate is circulated in the Philippines and during the rainy season excess leachate is drained into an adjacent creek.

The Kuda landfill in Indonesia has a leachate treatment facility that consists of a facultative pond followed by an aerobic pond, after which the leachate flows through a reed bed (artificial wetland system) for polishing.

3. Instance in Africa

In Africa, leachate is generally not treated, but in Durban in South Africa and Ghana, located in a wet climate zone, pond systems for leachate treatment are applied. Wetlands are applied at some landfills and one (1) case was reported of the wetland being practically non-functional due to insufficient resources for maintenance.

4. Conclusion

As described above there are similar working examples of the adopted treatment system for this project (anaerobic pond + aerated lagoon + maturation pond).

D. Financial Data

D. FINANCIAL DATA

List of Tables

Table 1	SWM Expenditure of Havana City.....	D.2
Table 2	SWM Staff Distribution in Havana City	D.3
Table 3	SWM Expenditure of UPPH.....	D.4
Table 4	SWM Expenditure of Aurora Plaza	D.5
Table 5	Balance Sheet of Aurora Plaza	D.6
Table 6	Income Statement of Aurora Plaza	D.6
Table 7	SWM Expenditure of Aurora Habana Vieja	D.7
Table 8	Balance Sheet of Aurora Habana Vieja.....	D.8
Table 9	Income Statement of Aurora Habana Vieja	D.8
Table 10	SWM Expenditure of DMSC and Small Scaled Auroras	D.9
Table 11	Tariff Scenario 1: Current Tariff Applicable to All Havana City	D.10
Table 12	Tariff Scenario 2: Full O/M Cost Recovery with Least Cross Subsidy	D.11
Table 13	Tariff Scenario 3: 50% O/M Cost Recovery with Cross Subsidy.....	D.12
Table 14	Tariff Setting Example 1: Year 2015; Full Cost Recovery for CUC; 50% Cost Recovery for CUP; and Cross Subsidy 1:2:3 (partial presentation 1/3)	D.13
Table 15	Tariff Setting Example 1: Year 2015; Full Cost Recovery for CUC; 50% Cost Recovery for CUP; and Cross Subsidy 1:2:3 (partial presentation 2/3)	D.14
Table 16	Tariff Setting Example 1: Year 2015; Full Cost Recovery for CUC; 50% Cost Recovery for CUP; and Cross Subsidy 1:2:3 (partial presentation 3/3)	D.15
Table 17	Tariff Setting Example 2: Year 2015; 70% Cost Recovery for CUC and CUP CUP; and Cross Subsidy 2:3:4 (partial presentation 1/3)	D.16
Table 18	Tariff Setting Example 2: Year 2015; 70% Cost Recovery for CUC and CUP CUP; and Cross Subsidy 2:3:4 (partial presentation 2/3)	D.17
Table 19	Tariff Setting Example 2: Year 2015; 70% Cost Recovery for CUC and CUP CUP; and Cross Subsidy 2:3:4 (partial presentation 3/3)	D.18
Table 20	Population Benefited from Sanitary Landfill (inhabitants within a 1km radius of landfills).....	D.19
Table 21	BOD Reduction by Leachate Treatment.....	D.20
Table 22	Summary of Master Plan Cost.....	D.21
Table 23	Disbursement Schedule of Master Plan Costs	D.22
Table 24-1	Cost Disbursement of Master Plan Components (2005 constant price: 1/4)	D.23
Table 24-2	Cost Disbursement of Master Plan Components (2005 constant price: 2/4)	D.24
Table 24-3	Cost Disbursement of Master Plan Components (2005 constant price: 3/4)	D.25
Table 24-4	Cost Disbursement of Master Plan Components (2005 constant price: 4/4)	D.26
Table 25-1	Fund Requirement of Master Plan Components (2005 constant price: 1/4).....	D.27
Table 25-2	Fund Requirement of Master Plan Components (2005 constant price: 2/4).....	D.28
Table 25-3	Fund Requirement of Master Plan Components (2005 constant price: 3/4).....	D.29
Table 25-4	Fund Requirement of Master Plan Components (2005 constant price: 4/4).....	D.30
Table 26	Financial Cash Flow of the Master Plan (2005 constant price).....	D.31

Table 1 SWM Expenditure of Havana City

(Data of year 2003; Unit: CUP 000, CUC 000)

	Sweeping *1		Collection *2		Landfill *2		Others *3		Administration		Total		
	CUP	CUC	CUP	CUC	CUP	CUC	CUP	CUC	CUP	CUC	CUP	CUC	Total*4
Revenue	12,531	107	13,241	1,542	0	0	1,491	0	1,000	100	28,263	1,749	30,012
Expenditure													
Personnel cost	14,929	0	36,611	0	2,428	0	4,461	0	7,380	0	65,809	0	65,809
Materials	3,455	127	24,945	393	2,472	59	739	16	13,187	108	44,798	702	45,500
Clothing and provisions *5	0	85	0	166	0	9	0	24	0	156	0	440	440
Fuel and energy cost	575	6	3,236	23	320	3	123	0	1,966	1	6,220	33	6,253
Administrative cost	3,955	4	16,836	0	1,697	1	1,259	0	3,243	494	26,989	499	27,488
Depreciation and investment	1,604	0	9,361	315	639	0	404	0	1,058	0	13,065	315	13,380
Total expenditure	24,518	222	90,989	897	7,556	72	6,985	40	26,833	759	156,881	1,989	158,870
Unit cost (direct cost only)	4.96 (Peso/m2)	0.04 (Peso/m2)	98.80 (Peso/ton)	0.97 (Peso/ton)	8.21 (Peso/ton)	0.08 (Peso/ton)					133.63 (Peso/ton)	1.29 (Peso/ton)	134.93 (Peso/ton)
Unit cost (including indirect cost)	5.98 (Peso/m2)	1.03 (Peso/m2)	119.19 (Peso/ton)	1.57 (Peso/ton)	9.90 (Peso/ton)	0.13 (Peso/ton)					161.21 (Peso/ton)	2.09 (Peso/ton)	163.30 (Peso/ton)

*1: Street sweeping work was performed for 4,941,813 thousand m² (3,676,813 by DMSC & Auroritas + 622,837 by Aurora Habana Vieja + 642,163 by Aurora Plaza). The wastes was collected in bins or trucks and sent to landfills. The volume of wastes collected by street sweeping was estimated at 36,720 tons a year, given that Havana City had 1,700 street cleaning cars of 200 liter capacity; the capacity utilization of a cleaning car is 40%; anual working days was 360; and the specific gravity fo the street waste is 1000 kg/m³.

*2: The volume of solid wastes collected and landfilled was 7739.206 thousand m³ (5378.7 by DMSC & Auroritas + 1471.5 by UPPH + 567.7 by Aurora Plaza + 321.306 by Aurora Habana Vieja), which was considered as 920,895 tons, given that the average weight of wastes collected in Havana City was 2523 ton/dat. As a result, the average specific gravity of the wastes was 119kg/m³.

*3: Other activities include cleaning of monuments and public places, and gardener.

*4: CUP and CUC are added up at par.

*5: Item includes foodstuffs, soaps, clothes, and shoes.

Source: DPSC

Table 2 SWM Staff distribution in Havana City

	Composition of workers					Number of workers												Total					
						Sweeping			Collection					Landfill	Others *1				Administration				
	Sweep	Collect.	Landfill	Others	Admin.	Sweep	Park	Public places	Ditch	Collect.	Sanitation	Green area	Street		Garage	Public place	Funeral, cemetrv		Others	Admin. technical	Inspector		
DPSC *2																				80		80	
UPPH *3	0%	76%	11%	0%	13%					198	224			171	84					93	12	782	
Aurora Plaza	46%	39%	0%	9%	5%	313		76		25	98	123	73	9						46		839	
Aurora Habana Vieja	66%	18%	0%	5%	10%	201	237	39		64	35	21		13					39	71		720	
Playa	32%	65%	0%	0%	4%	58	81		19	34	56	135	19	22								17	441
Aurora Miramar *4	81%	19%	0%	0%	0%	77				7	11												95
Centro Habana	60%	36%	0%	0%	4%	108	43			1	35	21	19	14								11	252
Aurora Cayo Hueso *4	75%	25%	0%	0%	0%	27				3	6												36
Habana del Este	16%	74%	3%	4%	1%	86	31			28	123	329	41	10	25			32				10	715
Aurora Guanabo *4	68%	32%	0%	0%	0%	60				5	23												88
Regla	23%	45%	0%	15%	17%	44	35		6	33	32	54	23	11				22	31	51	8	350	
Guanabacoa	26%	43%	0%	17%	14%	129	26				148	72	17	15				98		72	8	585	
San Miguel de Padron	21%	42%	0%	24%	13%	84	43		54	121		51	16	13				10	139	71	11	613	
10 de octubre	46%	33%	0%	5%	16%	219	60		8	117	1	33	23	15					31	78	17	602	
Cerro	35%	45%	0%	4%	17%	115	48		17	107		54	10	20					17	61	16	465	
Marianao	30%	43%	0%	15%	11%	104	26		21	72		76	15					20	46	41	6	427	
Lisa	26%	34%	0%	27%	13%	147	25		39	97		66	12	9	2			36	139	77	7	656	
Boyeros	24%	52%	1%	10%	12%	116	57		13	237	49	36	24	14	10			69	2	77	12	716	
Arroyo Naranjo	23%	56%	1%	10%	11%	186	51		55	422		80	19	7	15			36	67	92	20	1,050	
Cotorro	18%	62%	1%	8%	11%	94	38		7	126		278	21	14	6			33	27	75	6	725	
Total	30%	48%	1%	9%	11%	2,168	801	115	239	1,845	693	1,429	332	357	142	115	356	499	985	161	10,237		

*1: Auroras and DMSCs have workers not involved in SWM such as maintenance and custody of monuments and public places, and funeral services.

*2: Total number of workers at DPSC is 120, of which 80 is considered as workers for SWM.

*3: Total of 225 workers (184 direct and 41 indirect) are working for recycling activities. Due to difficulty of cost separation, those workers are included in collection.

*4: Aurora Miramar, Cayo Hueso, and Guanabao are experimental units belonging to municipalities of Playa, Centro Habana and Habana del Este respectively.

Source: "Comportamiento de los componentes esenciales de la política laboral y salarial en el sistema de comunales LL trimestre Año2003" DPSC, and UPPH

Table 3 SWM expenditure of UPPH

(Data of year 2003; Unit: CUP 000, CUC 000)

	Collection *1		Landfill		Administration		Total		
	CUP	CUC	CUP	CUC	CUP	CUC	CUP	CUC	Total*2
Revenue *3	594	340					594	340	934
Expenditure									
Personnel cost *4	15,847	0	2,294	0	2,711	0	20,851	0	20,851
Materials *5	15,695	244	1,744	27	2,561	40	20,000	311	20,311
Foodstuff		56		8		10		74	74
Fuel and energy cost *5	1,600	10	200	1	200	1	2,000	13	2,013
Administrative cost *5	10,931	0	1,582	0	1,870	33	14,383	33	14,416
Depreciation and investment*6*7	4,500	37	250	0	250	0	5,000	37	5,037
Total expenditure	48,573	347	6,070	36	7,591	83	62,234	467	62,701
Unit cost (direct cost only)	277.39 (Peso/ton)	1.98 (Peso/ton)	34.66 (Peso/ton)	0.21 (Peso/ton)			312.05 (Peso/ton)	2.19 (Peso/ton)	314.24 (Peso/ton)
Unit cost (including indirect cost)	315.93 (Peso/ton)	2.41 (Peso/ton)	39.48 (Peso/ton)	0.25 (Peso/ton)			355.40 (Peso/ton)	2.67 (Peso/ton)	358.07 (Peso/ton)

*1: The volume of solid waste collected was 1471.5 thousand m³ (equivalent to 175,109 tons, applying the specific gravity of 119kg/m³)

*2: CUP and CUC are added up at par.

*3: UPPH is the budgeted whose primary financing source depends on the government budget. However UPPH can also charge tariffs to some users and record them as revenues.

*4: Cost distribution among departments is considered same as staff distribution, which is sweeping (76%), collection (11%), and administration (13%). 225 workers working at recycling section are included in collection department.

*5: Total costs in CUP is estimated. Cost distribution among departments is supposedly same as that of CUC.

*6: Total costs in peso is estimated. Distribution of equipment invested is considered 90% for collection, 5% for landfill, and 5% for administration.

*7: UPPH only expenses its cost in cash basis. The amount of investment and payment of loan for equipment purchase is considered as capital cost instead of depreciation.

Table 4 SWM Expenditure of Aurora Plaza

(Data of year 2003; Unit: CUP 000, CUC 000)

	Sweeping *1		Collection *2		Others *3		Administration		Total		
	CUP	CUC	CUP	CUC	CUP	CUC	CUP	CUC	CUP	CUC	Total*4
Revenue	4,531	7	4,317	220	491	0			9,339	227	9,566
Expenditure											
Personnel cost *5	2,799		2,373		548		365		6,085		6,085
Materials *6	5	1	133	22	0	0	31	5	169	28	197
Clothing and provisions		28		24				4		60	60
Fuel and energy cost *6	0	0	116	2	0	0	0	0	116	2	118
Administrative cost *5	136	4	115	0	27	0	18	97	295	101	396
Depreciation and investment*7	4	0	61	7	4	0	8	0	76	7	83
Total expenditure	2,944	33	2,798	55	578	5	421	106	6,741	198	6,939
Unit cost (direct cost only)	4.58 (Peso/m2)	0.05 (Peso/m2)	41.42 (Peso/ton)	0.81 (Peso/ton)					84.99 (Peso/ton)	1.29 (Peso/ton)	86.29 (Peso/ton)
Unit cost (including indirect cost)	4.89 (Peso/m2)	0.11 (Peso/m2)	44.18 (Peso/ton)	1.73 (Peso/ton)					90.66 (Peso/ton)	2.76 (Peso/ton)	93.42 (Peso/ton)

*1: Street sweeping work was performed for 642,163 thousand m2.

*2: The volume of solid waste collected was 567.7 thousand m3 (equivalent to 67,556 tons, applying the specific gravity of 119kg/m3)

*3: Other activities include cleaning and maintenance of monuments and public places.

*4: CUP and CUC are added up at par.

*5: Cost distribution among departments is considered same as staff distribution, which is sweeping (46%), collection (39%), others (9%), and administration (6%).

*6: Total costs in CUP is estimated. Cost distribution among departments is supposedly same as that of CUC.

*7: Distribution of depreciable equipment is considered 5% for sweeping, 80% for collection, 5% for others, and 10% for administration.

Table 5 Balance Sheet of Aurora Plaza

(At the end of 2003; Unit: Peso *)

Assets	
Current assets	
Cash on hand	2,800
Cash to be deposited at bank (CUP)	9,422
Cash to be deposited at bank (CUC)	1,420
Cash at bank	807,831
Account receivable in short term (CUP)	970,872
Account receivable in short term (CUC)	23,224
Anticipated payment to suppliers	48,095
Debt from state budget	51
Materials and spare parts	19,872
Foodstuff	2,263
Utensils and tools in use	73,923
Utensils and tools in stock	1,935
Wardrobe and linen	9,661
Ornamental plants	15,219
Total current assets	1,986,588
Fixed assets	
Fixed tangible assets in use	601,539
Fixed tangible assets in stock	23,822
Fixed intangible assets	18,404
Depreciation of fixed tangible assets	(496,948)
Amortization of intangible fixed assets	(17,704)
Total fixed assets	129,113
Other assets	
Differed expenses in short term	(4,166)
Account receivable	640
Account receivable for countervalues	36,691
Account receivable from workers	2,106
Deposits and finance in CUC	3,124
Total other assets	38,395
Total assets	2,154,096
Liability	
Current liabilities	
Account payable in short term	21,871
Anticipated collection	2,974
Anticipated collection in CUC	143
Liabilities for social security in the state budg	100,459
Liabilities for profit account in the state budg	785,031
Social security payable to budget	48,030
Retention payable to L.G.V.	397
Retention payable to personal credits	5,989
Retention payable to judicial embargo	70
Retention payable for saving accounts	190
Provision for investments	53,289
Provision for vacations	159,447
Total current liabilities	1,177,890
Other liabilities	
Various accounts payable	27,018
Accounts payable for unclaimed salaries	2,058
Total other liabilities	29,076
Net worth	
State investment	662,883
Reserve for contingencies	99,088
Reserves for development	185,159
Total net worth	947,130
Total liabilities and net worth	2,154,096

* CUP and CUC are added up at par.

Source: DPSC

Table 6 Income Statements of Aurora Plaza

(Year ending Dec. 2003; Unit: Peso 000 *)

Revenue	
Sales	9,561
Other revenue	118
of which employee's restaurants	67
Total revenues	9,679
Expenditure	
Salaries	4,422
Laborforce utilization tax	1,105
Social security	557
Materials	293
Depreciation and amortization	76
Other monetary expenses	240
of which, energy costs	152
Restaurant and foodstuff	45
Financial expense	30
Other expenses (adjustment)	-39
Total expenditure	6,729
Profit	2,950
Reserve for contingency	29
Income tax	1,022
Profit after tax	1,898
Reserve for development	135
Contiribution for state investment	1,763

* CUP and CUC are added up at par.

Source: DPSC

Table 7 SWM Expenditure of Aurora Habana Vieja

(Data of year 2003; Unit: CUP 000, CUC 000)

	Sweeping *1		Collection *2		Others *3		Administration		Total		
	CUP	CUC	CUP	CUC	CUP	CUC	CUP	CUC	CUP	CUC	Total*4
Revenue	5,201		2,988	61				84	8,189	145	8,334
Expenditure *5											
Personnel cost *6	3,397	0	978	0	257	0	515	0	5,147	0	5,147
Materials *7	58	8	102	14	11	1	192	26	363	49	412
Clothing and provisions *6	0	34	0	10	0	3	0	5	0	51	51
Fuel and energy cost *7	16	0	28	0	3	0	52	1	98	2	100
Administrative cost *6	114	52	33	15	9	4	17	8	173	79	252
Depreciation and investment*8	11	1	171	16	11	1	21	2	214	20	234
Total expenditure	3,596	95	1,311	55	291	9	798	42	5,995	201	6,196
Unit cost (direct cost only)	5.77	0.15	34.29	1.43					128.33	3.92	132.25
	(Peso/m2)	(Peso/m2)	(Peso/ton)	(Peso/ton)					(Peso/ton)	(Peso/ton)	(Peso/ton)
Unit cost (including indirect cost)	6.66	0.19	39.56	1.81					148.03	4.96	152.98
	(Peso/m2)	(Peso/m2)	(Peso/ton)	(Peso/ton)					(Peso/ton)	(Peso/ton)	(Peso/ton)

*1: Street sweeping work was performed for 622,837 thousand m2.

*2: The volume of solid waste collected was 321,306 m3 (equivalent to 38,236 tons, applying the specific gravity of 119kg/m3)

*3: Other activities include cleaning and maintenance of monuments and public places.

*4: CUP and CUC are added up at par.

*5: Cost distribution among departments is considered same as Aurora Plaza, which is as follows:

Between CUP and CUC		
	CUP	CUC
Personnel cost	100%	0%
Materials	88%	12%
Clothing and provisions	0%	100%
Fuel and energy cost	98%	2%
Administrative cost	69%	31%
Depreciation and investment	92%	8%

*6: Cost distribution among departments is considered same as staff distribution, which is sweeping (66%), collection (19%), others (5%), and administration (10%).

*7: Cost distribution among departments is considered same as distribution of CUC expenses, which is sweeping (16%), collection (28%), others (3%), and administration (53%).

*8: Distribution of depreciable equipment is considered 5% for sweeping, 80% for collection, 5% for others, and 10% for administration.

Table 8 Balance Sheet of Aurora Habana Vieja

(At the end of 2003; Unit: Peso *)

Assets	
Current assets	
Cash on hand	500
Cash at bank	536,301
Account receivable in short term	970,232
Anticipated payment to suppliers	42,721
Income tax payment	1,571,214
Profit contribution for state investment	889,788
Debt from state budget	573
Inventory	<u>226,796</u>
Total current assets	4,238,125
Fixed assets	
Fixed tangible assets	326,222
Depreciation	<u>(202,090)</u>
Total fixed assets	<u>124,132</u>
Total assets	<u>4,362,257</u>
Liability	
Current liabilities	
Account payable in short term	103,193
Liabilities for social security in the state budge	38,260
Income tax payable	129,855
Labor force tax payable	79,708
Contribution for state investment	536,432
Other contribution payable	31,529
Retention payable	6,529
Provision for vacations	<u>150,684</u>
Total current liabilities	1,076,190
Other liabilities	
Various accounts payable	<u>4</u>
Total other liabilities	4
Net worth	
State investment	1,012,104
Donation received	23,168
Reserve for contingencies	109,252
Accumulated profit	<u>2,141,539</u>
Total net worth	<u>3,286,063</u>
Total liabilities and net worth	<u>4,362,257</u>

* CUP and CUC are added up at par.

Source: DPSC

Table 9 Income Statements of Aurora Habana Vieja

(Unit: Peso 000 *a)

Revenue	
Sales	8,254 *b
Other revenue	84
of which employee's restaurants	<u>54</u>
Total revenues	8,338
Expenditure	
Salaries	3,734
Laborforce utilization tax	933
Social security	480
Materials	412
Depreciation and amortization	234
Other monetary expenses	334
of which, energy costs	62
Restaurant and foodstuff	51
Financial expense	1
Other expenses (adjustment)	<u>18</u>
Total expenditure	<u>6,196</u>
Profit	2,142
Reserve for contingency	107
Income tax	<u>712</u>
Profit after tax	1,322
Reserve for development	
Contribution for state investment	1,243
Distributable profit	79

*a: CUP and CUC are added up at par.

*b: Comprised of CUP8,158,764 and CUC94,594

Source: DPSC

Table 10 SWM Expenditure of DMSC and Small Scaled Auroras

(Data of year 2003 *a; Unit: CUP 000, CUC 000)

	Sweeping *b		Collection *c		Landfill		Others		Administration		Total		Total*d
	CUP	CUC	CUP	CUC	CUP	CUC	CUP	CUC	CUP	CUC	CUP	CUC	
Revenue	2,799	100	5,342	922	0	0	1,000	0	1,000	16	10,141	1,038	11,179
Expenditure													
Personnel cost	8,733	0	17,413	0	134		3,656	0	3,790	0	33,726	0	33,726
Materials	3,392	119	9,015	113	728	32	728	14	10,403	36	24,266	314	24,580
Foodstuff	0	24	0	77	0	1	0	16	0	137	0	255	255
Fuel and energy cost	559	5	1,492	11	120	2	120	-0	1,714	-1	4,005	17	4,023
Administrative cost	3,705	-52	5,757	-15	115	1	1,223	-4	1,338	357	12,138	286	12,425
Depreciation and investment	1,589	-1	4,629	255	389		389	-1	779	-2	7,775	251	8,026
Total expenditure	17,978	94	38,306	440	1,486	35	6,117	25	18,023	528	81,910	1,123	83,034
Unit cost	4.89	0.03	59.85	0.69	2.32	0.06					90.26	0.89	91.15
(direct cost only)	(Peso/m2)	(Peso/m2)	(Peso/ton)	(Peso/ton)	(Peso/ton)	(Peso/ton)					(Peso/ton)	(Peso/ton)	(Peso/ton)
Unit cost	5.41	0.03	66.18	0.72	2.32	0.06					115.72	1.68	117.40
(including indirect cost)	(Peso/m2)	(Peso/m2)	(Peso/ton)	(Peso/ton)	(Peso/ton)	(Peso/ton)					(Peso/ton)	(Peso/ton)	(Peso/ton)

*a: Data of sum of DMSC and 3 small Auroras is computed by subtracting quantity of Aurora Habana Vieja from the total of DMSC, Aurora Habana Vieja, and 3 small Auroras.

Some values are negative as a result of artificial allocation of costs.

*b: Street sweeping work was performed for 3,676,813 m2.

*c: The volume of solid waste collected was 5378.7 thousand m3 (equivalent to 640,065 tons, applying the specific gravity of 119kg/m3)

*d: CUP and CUC are added up at par.

Table 11: Tariff Scenario 1- Current Tariff Applicable to All Havana City

Table 11-1: Assumption of MSW generation (2005-2015) in Tariff Analysis

Category	No. of users	MSW generation assumption			
		(liter/user /day)	Specific gravity	(kg/user)	(ton/category/day)
Inhabitant	2,100,000	3.1	0.22	0.68	1,432
Office (non-CUC earner) by communal bin	7,700	30.0	0.30	9.00	69
Office (non-CUC earner) by exclusive bin	300	300.0	0.30	90.00	27
Office (CUC earner) by communal bin	1,700	30.0	0.30	9.00	15
Office (CUC earner) by exclusive bin	300	300.0	0.30	90.00	27
Foreigner by communal bin	700	30.0	0.30	9.00	6
Foreigner with exclusive bin	300	300.0	0.30	90.00	27
Total	2,111,000				1,604

Table 11-2: Assumption of Waste Collection in Tariff Analysis

	(ton/day)
	2005
MSW to be collected by Havana City	940
MSW to be collected by other systems	664
Construction and bulk waste	520
Industrial waste	350
Total	2,474

Table 11-3 Landfill O/M cost to be recovered from MSW collected by Havana City

	(Peso '000, current prices)	
	2003	2005
CUC	116	44
CUP	9,115	3,463

Table 11-4 Collection O/M cost to be recovered from MSW collected by Havana City

	(Peso '000, current prices)	
	2003	2005
CUC	1,450	753
CUP	109,763	57,004

Table 11-5: Collection cost to be recovered

Cost item	(Peso '000)	
	CUC	CUP
Collection cost (annual)	797	60,467
Collection cost (monthly)	66	5,039
Recovery target (monthly)	66	1,364
Recovery rate	100%	27%

Table 11-6: Tariff for cost recovery

User Category	(Peso/user/month)	
	CUC	CUP
Inhabitant	0.0	0.4
Office (non-CUC earner) by communal bin	0.0	63.0
Office (non-CUC earner) by exclusive bin	0.0	114.0
Office (CUC earner) by communal bin	30.0	33.0
Office (CUC earner) by exclusive bin	45.0	69.0
Foreigner by communal bin	30.0	0.0
Foreigner with exclusive bin	120.0	0.0
Efficiency of bill collection	95%	95%
Surplus/deficit (Peso/month)	48,984	295

Table 11-7: Cross Subsidy Coefficient

User Category	CUC	CUP
Inhabitant	0.0	1.0
Office (non-CUC earner) by communal bin	0.0	16.3
Office (non-CUC earner) by exclusive bin	0.0	2.9
Office (CUC earner) by communal bin	6.7	8.5
Office (CUC earner) by exclusive bin	1.0	1.8
Foreigner by communal bin	6.7	0.0
Foreigner with exclusive bin	2.7	0.0

Table 11-8: Per liter tariff

User Category	(Peso/liter)	
	CUC	CUP
Inhabitant	0.000	0.004
Office (non-CUC earner) by communal bin	0.000	0.070
Office (non-CUC earner) by exclusive bin	0.000	0.013
Office (CUC earner) by communal bin	0.033	0.037
Office (CUC earner) by exclusive bin	0.005	0.008
Foreigner by communal bin	0.033	0.000
Foreigner with exclusive bin	0.013	0.000

Table 11-9: Monthly revenue

User Category	(Peso '000)	
	CUC	CUP
Inhabitant	0	798
Office (non-CUC earner) by communal bin	0	461
Office (non-CUC earner) by exclusive bin	0	32
Office (CUC earner) by communal bin	48	53
Office (CUC earner) by exclusive bin	13	20
Foreigner by communal bin	20	0
Foreigner with exclusive bin	34	0
Total	115	1,364

Table 12: Tariff Scenario 2 - Full O/M Cost Recovery with Least Cross Subsidy

Table 12-1: Assumption of MSW generation (2005-2015) in Tariff Analysis

Category	No. of users	MSW generation assumption			
		(liter/user /day)	Specific gravity	(kg/user)	(ton/category/day)
Inhabitant	2,100,000	3.1	0.22	0.68	1,432
Office (non-CUC earner) by communal bin	7,700	30.0	0.30	9.00	69
Office (non-CUC earner) by exclusive bin	300	300.0	0.30	90.00	27
Office (CUC earner) by communal bin	1,700	30.0	0.30	9.00	15
Office (CUC earner) by exclusive bin	300	300.0	0.30	90.00	27
Foreigner by communal bin	700	30.0	0.30	9.00	6
Foreigner with exclusive bin	300	300.0	0.30	90.00	27
Total	2,111,000				1,604

Table 12-2: Assumption of Waste Collection in Tariff Analysis

	(ton/day)
	2005
MSW to be collected by Havana City	940
MSW to be collected by other systems	664
Construction and bulk waste	520
Industrial waste	350
Total	2,474

Table 12-3 Landfill O/M cost to be recovered from MSW collected by Havana City

	(Peso '000, current prices)	
	2003	2005
CUC	116	44
CUP	9,115	3,463

Table 12-4 Collection O/M cost to be recovered from MSW collected by Havana City

	(Peso '000, current prices)	
	2003	2005
CUC	1,450	753
CUP	109,763	57,004

Table 12-5: Collection cost to be recovered

Cost item	(Peso '000)	
	CUC	CUP
Collection cost (annual)	797	60,467
Collection cost (monthly)	66	5,039
Recovery target (monthly)	66	5,039
Recovery rate	100%	100%

Table 12-6: Tariff for cost recovery

User Category	(Peso/user/month)	
	CUC	CUP
Inhabitant	0.0	1.9
Office (non-CUC earner) by communal bin	3.7	69
Office (non-CUC earner) by exclusive bin	37.0	690
Office (CUC earner) by communal bin	3.7	69
Office (CUC earner) by exclusive bin	37.0	690
Foreigner by communal bin	3.7	69
Foreigner with exclusive bin	37.0	690
Efficiency of bill collection	95%	95%
Surplus/deficit (Peso/month)	695	3,571

Table 12-7: Cross Subsidy Coefficient

User Category	CUC	CUP
Inhabitant	0.0	1.0
Office (non-CUC earner) by communal bin	1.0	3.8
Office (non-CUC earner) by exclusive bin	1.0	3.8
Office (CUC earner) by communal bin	1.0	3.8
Office (CUC earner) by exclusive bin	1.0	3.8
Foreigner by communal bin	1.0	3.8
Foreigner with exclusive bin	1.0	3.8

Table 12-8: Per liter tariff

User Category	(Peso/liter)	
	CUC	CUP
Inhabitant	0.000	0.020
Office (non-CUC earner) by communal bin	0.004	0.077
Office (non-CUC earner) by exclusive bin	0.004	0.077
Office (CUC earner) by communal bin	0.004	0.077
Office (CUC earner) by exclusive bin	0.004	0.077
Foreigner by communal bin	0.004	0.077
Foreigner with exclusive bin	0.004	0.077

Table 12-9: Monthly revenue

User Category	(Peso '000)	
	CUC	CUP
Inhabitant	0	3,791
Office (non-CUC earner) by communal bin	27	505
Office (non-CUC earner) by exclusive bin	11	197
Office (CUC earner) by communal bin	6	111
Office (CUC earner) by exclusive bin	11	197
Foreigner by communal bin	2	46
Foreigner with exclusive bin	11	197
Total	67	5,043

Table 13: Tariff Scenario 3 - 50% O/M Cost Recovery with Cross Subsidy

Table 13-1: Assumption of MSW generation (2005-2015) in Tariff Analysis

Category	No. of users	MSW generation assumption			
		(liter/user/day)	Specific gravity	(kg/user)	(ton/category/day)
Inhabitant	2,100,000	3.1	0.22	0.68	1,432
Office (non-CUC earner) by communal bin	7,700	30.0	0.30	9.00	69
Office (non-CUC earner) by exclusive bin	300	300.0	0.30	90.00	27
Office (CUC earner) by communal bin	1,700	30.0	0.30	9.00	15
Office (CUC earner) by exclusive bin	300	300.0	0.30	90.00	27
Foreigner by communal bin	700	30.0	0.30	9.00	6
Foreigner with exclusive bin	300	300.0	0.30	90.00	27
Total	2,111,000				1,604

Table 13-2: Assumption of Waste Collection in Tariff Analysis

	(ton/day)
	2005
MSW to be collected by Havana City	940
MSW to be collected by other systems	664
Construction and bulk waste	520
Industrial waste	350
Total	2,474

Table 13-3 Landfill O/M cost to be recovered from MSW collected by Havana City

	(Peso '000, current prices)	
	2003	2005
CUC	116	44
CUP	9,115	3,463

Table 13-4 Collection O/M cost to be recovered from MSW collected by Havana City

	(Peso '000, current prices)	
	2003	2005
CUC	1,450	753
CUP	109,763	57,004

Table 13-5: Collection cost to be recovered

Cost item	(Peso '000)	
	CUC	CUP
Collection cost (annual)	797	60,467
Collection cost (monthly)	66	5,039
Recovery target (monthly)	33	2,519
Recovery rate	50%	50%

Table 13-6: Tariff for cost recovery

User Category	(Peso/user/month)	
	CUC	CUP
Inhabitant	0.0	1.1
Office (non-CUC earner) by communal bin	1.2	11
Office (non-CUC earner) by exclusive bin	12.0	110
Office (CUC earner) by communal bin	2.4	22
Office (CUC earner) by exclusive bin	24.0	220
Foreigner by communal bin	3.6	33
Foreigner with exclusive bin	36.0	330
Efficiency of bill collection	95%	95%
Surplus/deficit (Peso/month)	2,347	1,073

Table 13-7: Cross Subsidy Coefficient

User Category	CUC	CUP
Inhabitant	0.0	1.0
Office (non-CUC earner) by communal bin	0.5	1.0
Office (non-CUC earner) by exclusive bin	0.5	1.0
Office (CUC earner) by communal bin	1.0	2.1
Office (CUC earner) by exclusive bin	1.0	2.1
Foreigner by communal bin	1.5	3.1
Foreigner with exclusive bin	1.5	3.1

Table 13-8: Per liter tariff

User Category	(Peso/liter)	
	CUC	CUP
Inhabitant	0.000	0.012
Office (non-CUC earner) by communal bin	0.001	0.012
Office (non-CUC earner) by exclusive bin	0.001	0.012
Office (CUC earner) by communal bin	0.003	0.024
Office (CUC earner) by exclusive bin	0.003	0.024
Foreigner by communal bin	0.004	0.037
Foreigner with exclusive bin	0.004	0.037

Table 13-9: Monthly revenue

User Category	(Peso '000)	
	CUC	CUP
Inhabitant	0	2,195
Office (non-CUC earner) by communal bin	9	80
Office (non-CUC earner) by exclusive bin	3	31
Office (CUC earner) by communal bin	4	36
Office (CUC earner) by exclusive bin	7	63
Foreigner by communal bin	2	22
Foreigner with exclusive bin	10	94
Total	36	2,521

Table 14 Tariff Setting Example 1: Year 2015; Full Cost Recovery for CUC; 50% Cost Recovery for CUP; and Cross Subsidy 1:2:3 (partial presentation 1/3)

Table 1: Assumption of MSW generation (2005-2015) in Tariff Analysis

Category	No. of users	MSW generation assumption			
		(liter/user/day)	Specific gravity	(kg/user)	(ton/category/day)
Inhabitant	2,100,000	3.1	0.22	0.68	1,432
Office (non-CUC earner) by communal bin	7,700	30.0	0.30	9.00	69
Office (non-CUC earner) by exclusive bin	300	300.0	0.30	90.00	27
Office (CUC earner) by communal bin	1,700	30.0	0.30	9.00	15
Office (CUC earner) by exclusive bin	300	300.0	0.30	90.00	27
Foreigner by communal bin	700	30.0	0.30	9.00	6
Foreigner with exclusive bin	300	300.0	0.30	90.00	27
Total	2,111,000				1,604

Table 2: Assumption of Waste Collection in Tariff Analysis

	(ton/day)										
	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015
MSW to be collected by Havana City	940	940	940	940	940	940	940	940	940	940	940
MSW to be collected by other systems	664	664	664	664	664	664	664	664	664	664	664
Construction and bulk waste	520	520	520	520	520	520	520	520	520	520	520
Industrial waste	350	350	350	350	350	350	350	350	350	350	350
Total	2,474	2,474	2,474	2,474	2,474	2,474	2,474	2,474	2,474	2,474	2,474

Table 3: Collection O/M cost (with M/P) to be recovered from all SW

	(Peso '000, current prices)										
	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total
CUC	2,164	2,317	2,348	2,379	2,746	3,043	3,082	3,121	3,161	3,201	27,560
CUP	119,665	122,499	125,316	128,199	131,402	135,207	138,317	141,498	144,752	148,082	1,334,936

Table 4: Collection O/M cost (with M/P) to be recovered from MSW collected by Havana City

	(Peso '000, current prices)										
	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total
CUC	1,124	1,203	1,219	1,235	1,426	1,581	1,601	1,621	1,641	1,662	14,313
CUP	62,146	63,618	65,081	66,578	68,242	70,218	71,833	73,485	75,175	76,904	693,282

Table 5 Landfill O/M cost (without M/P)

	(Peso '000, current prices)											
	2003	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015
CUC	116	119	120	121	122	124	125	126	127	129	130	131
CUP	9,115	9,298	9,512	9,731	9,955	10,184	10,418	10,657	10,903	11,153	11,410	11,672

Table 6 Collection O/M cost (without M/P)

	(Peso '000, current prices)											
	2003	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015
CUC	1,450	1,479	1,494	1,509	1,524	1,539	1,555	1,570	1,586	1,602	1,618	1,634
CUP	109,763	114,870	117,512	120,215	122,980	125,808	128,702	131,662	134,690	137,788	140,957	144,199

Table 7: Landfill O/M cost (with M/P) to be recovered from all SW

	(Peso '000, current prices)										
	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total
CUC	124	797	804	813	765	773	780	788	796	804	7,243
CUP	9,512	11,314	11,574	11,848	12,121	12,481	12,761	13,055	13,343	13,649	121,658

Table 8: Landfill O/M cost (with M/P) to be recovered from MSW collected by Havana City

	(Peso '000, current prices)										
	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total
CUC	41	244	247	250	237	237	240	244	244	247	2,230
CUP	2,906	3,455	3,534	3,620	3,702	3,812	3,898	3,987	4,076	4,169	37,158

Table 9: Collection and landfill O/M cost (with M/P) to be recovered from MSW collected by Havana City

	(Peso '000, current prices)										
	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total
CUC	1,165	1,447	1,466	1,486	1,663	1,817	1,841	1,864	1,885	1,909	16,543
CUP	65,053	67,073	68,615	70,198	71,944	74,030	75,731	77,472	79,251	81,073	730,439

Table 10: Household income check (CUP/month)

	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015
Household income	777	795	814	832	852	871	891	912	933	954	976
1% of income	7.8	8.0	8.1	8.3	8.5	8.7	8.9	9.1	9.3	9.5	9.8
1% of income divided by 4 members	1.9	2.0	2.0	2.1	2.1	2.2	2.2	2.3	2.3	2.4	2.4

Table 15 Tariff Setting Example 1: Year 2015; Full Cost Recovery for CUC; 50% Cost Recovery for CUP; and Cross Subsidy 1:2:3 (partial presentation 2/3)

Table 11: CUC cost recovery 100%, CUP cost recovery 50%, and cross subsidy 1:2:3

		(Peso/user/month)									
User Category		2006	2007	2008	2009	2010	2011	2012	2013	2014	2015
Inhabitant	CUC	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	CUP	1.0	1.0	1.0	1.0	1.0	1.2	1.2	1.2	1.2	1.2
Office (non-CUC earner) by communal bin	CUC	3.3	4.1	4.1	4.2	4.7	5.1	5.2	5.3	5.3	5.4
	CUP	24.0	27.0	29.0	32.0	34.0	24.0	26.0	28.0	31.0	33.0
Office (non-CUC earner) by exclusive bin	CUC	33.0	41.0	41.0	42.0	47.0	51.0	52.0	53.0	53.0	54.0
	CUP	240.0	270.0	290.0	320.0	340.0	240.0	260.0	280.0	310.0	330.0
Office (CUC earner) by communal bin	CUC	6.6	8.2	8.2	8.4	9.4	10.2	10.4	10.6	10.6	10.8
	CUP	48.0	54.0	58.0	64.0	68.0	48.0	52.0	56.0	62.0	66.0
Office (CUC earner) by exclusive bin	CUC	66.0	82.0	82.0	84.0	94.0	102.0	104.0	106.0	106.0	108.0
	CUP	480.0	540.0	580.0	640.0	680.0	480.0	520.0	560.0	620.0	660.0
Foreigner by communal bin	CUC	9.9	12.3	12.3	12.6	14.1	15.3	15.6	15.9	15.9	16.2
	CUP	72.0	81.0	87.0	96.0	102.0	72.0	78.0	84.0	93.0	99.0
Foreigner by exclusive bin	CUC	99.0	123.0	123.0	126.0	141.0	153.0	156.0	159.0	159.0	162.0
	CUP	720.0	810.0	870.0	960.0	1,020.0	720.0	780.0	840.0	930.0	990.0
Tipping fee (MSW hauled by Havana City) (unit: peso/ton)	CUC	0.1	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
	CUP	8.5	10.1	10.3	10.6	10.8	11.1	11.4	11.6	11.9	12.2
Tipping fee (other SW) (unit: peso/ton)	CUC	0.2	1.1	1.1	1.1	1.0	1.0	1.1	1.1	1.1	1.1
	CUP	12.7	15.1	15.5	15.8	16.2	16.7	17.0	17.4	17.8	18.2

Table 12 (Table 6.15.9 of Main Report): Simulated Tariffs

		(unit: peso/user/month)										
User Category		2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015
		Actual	Plan	Plan	Plan	Plan	Plan	Plan	Plan	Plan	Plan	Plan
Inhabitant	CUC	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	CUP	0.4	0.4	1.0	1.0	1.0	1.0	1.2	1.2	1.2	1.2	1.2
Office (non-CUC earner) by communal bin	CUC	0.0	3.3	4.1	4.1	4.2	4.7	5.1	5.2	5.3	5.3	5.4
	CUP	63.0	24.0	27.0	29.0	32.0	32.0	32.0	32.0	32.0	32.0	32.0
Office (non-CUC earner) by exclusive bin	CUC	0.0	33.0	41.0	41.0	42.0	47.0	51.0	52.0	53.0	53.0	54.0
	CUP	114.0	240.0	270.0	290.0	320.0	320.0	320.0	320.0	320.0	320.0	320.0
Office (CUC earner) by communal bin	CUC	30.0	6.6	8.2	8.2	8.4	9.4	10.2	10.4	10.6	10.6	10.8
	CUP	33.0	48.0	54.0	58.0	64.0	64.0	64.0	64.0	64.0	64.0	64.0
Office (CUC earner) by exclusive bin	CUC	45.0	66.0	82.0	82.0	84.0	94.0	102.0	104.0	106.0	106.0	108.0
	CUP	69.0	480.0	540.0	580.0	640.0	640.0	640.0	640.0	640.0	640.0	640.0
Foreigner by communal bin	CUC	30.0	9.9	12.3	12.3	12.6	14.1	15.3	15.6	15.9	15.9	16.2
	CUP	0.0	72.0	81.0	87.0	96.0	96.0	96.0	96.0	96.0	96.0	96.0
Foreigner by exclusive bin	CUC	120.0	99.0	123.0	123.0	126.0	141.0	153.0	156.0	159.0	159.0	162.0
	CUP	0.0	720.0	810.0	870.0	960.0	960.0	960.0	960.0	960.0	960.0	960.0
Tipping fee (MSW hauled by Havana City) (unit: peso/ton)	CUC	0.0	0.1	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
	CUP	0.5	8.5	10.1	10.3	10.6	10.8	11.1	11.4	11.6	11.9	12.2
Tipping fee (other SW) (unit: peso/ton)	CUC	0.0	0.2	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1
	CUP	0.5	12.7	15.1	15.5	15.8	16.2	16.7	17.0	17.4	17.8	18.2

Table 13: Expected Revenue under Proposed Tariff (With M/P)

		(Peso '000, current prices)										
User Category		2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total
Inhabitant	CUC	0	0	0	0	0	0	0	0	0	0	0
	CUP	9,576	23,940	23,940	23,940	23,940	28,728	28,728	28,728	28,728	28,728	248,976
Office (non-CUC earner) by communal bin	CUC	290	360	360	369	413	448	456	465	465	474	4,099
	CUP	2,107	2,370	2,546	2,809	2,809	2,809	2,809	2,809	2,809	2,809	26,685
Office (non-CUC earner) by exclusive bin	CUC	113	140	140	144	161	174	178	181	181	185	1,597
	CUP	821	923	992	1,094	1,094	1,094	1,094	1,094	1,094	1,094	10,397
Office (CUC earner) by communal bin	CUC	128	159	159	163	182	198	202	205	205	209	1,810
	CUP	930	1,047	1,124	1,240	1,240	1,240	1,240	1,240	1,240	1,240	11,783
Office (CUC earner) by exclusive bin	CUC	226	280	280	287	321	349	356	363	363	369	3,194
	CUP	1,642	1,847	1,984	2,189	2,189	2,189	2,189	2,189	2,189	2,189	20,794
Foreigner by communal bin	CUC	79	98	98	101	113	122	124	127	127	129	1,118
	CUP	575	646	694	766	766	766	766	766	766	766	7,278
Foreigner by exclusive bin	CUC	339	421	421	431	482	523	534	544	544	554	4,791
	CUP	2,462	2,770	2,975	3,283	3,283	3,283	3,283	3,283	3,283	3,283	31,190
Tipping fee (other SW) *	CUC	96	569	574	585	585	585	559	569	569	574	5,266
	CUP	6,761	8,037	8,218	8,420	8,612	8,867	9,064	9,271	9,479	9,679	86,425
Total	CUC	1,269	2,027	2,033	2,079	2,257	2,399	2,408	2,454	2,454	2,495	21,876
	CUP	24,873	41,581	42,473	43,742	43,933	48,977	49,174	49,381	49,588	49,807	443,528

Note: Efficiency of bill collection is assumed to be 95%

* Tipping fee revenue from MSW hauled by Havana City system is offset by the same amount of tipping cost when the entire Havana City SWM accounting is consolidated.

Table 14: Expected Revenue under Current Tariff (Without M/P)

		(Peso '000, current prices)											
		2005*	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total
CUC		1,108	1,119	1,130	1,142	1,153	1,165	1,176	1,188	1,200	1,212	1,224	11,710
CUP		6,877	6,945	7,015	7,085	7,156	7,227	7,300	7,373	7,446	7,521	7,596	72,663

*2005 revenues were estimated from 2003 revenues, taking account of the ratio of MSW collection and non-MSW collection.

CUC escalation 1%

CUP escalation 2.3%

Table 16 Tariff Setting Example 1: Year 2015; Full Cost Recovery for CUC; 50% Cost Recovery for CUP; and Cross Subsidy 1:2:3 (partial presentation 3/3)

Year 2006 Tipping Fee

Table 16: Hauled SW

	SW volume	
	(ton/category /day)	(ton/category /year)
MSW collected by Havana City	940	343,100
MSW collected by other systems	664	242,360
Construction and bulk waste	520	189,800
Industrial waste	350	127,750
Total waste collection	2,474	903,010

Table 17: Landfill Cost to Be Recovered

	(Peso '000/year)	
	CUC	CUP
Landfill cost	124	9,512
Recovery target	124	9,512
Recovery rate	100%	100%
Efficiency of tariff collection	95%	95%
Billing target	131	10,013

Table 18: Cross Subsidy Coefficient in Tipping Fee

User Category	CUC	CUP
MSW collected by Havana City	1.0	1.0
MSW collected by other systems	1.5	1.5
Construction and bulk waste	1.5	1.5
Industrial waste	1.5	1.5

Table 19: Tipping Fee for Cost Recovery

	(Peso/ton)	
	CUC	CUP
MSW collected by Havana City	0.12	8.47
MSW collected by other systems	0.18	12.71
Construction and bulk waste	0.18	12.71
Industrial waste	0.18	12.71

Year 2006 Collection Fee:

(100% CUC recovery; 50% CUP recovery; Cross Subsidy 1:2:3)

Table 20: Collection cost to be recovered

Cost item	(Peso '000)	
	CUC	CUP
Collection cost (annual)	1,165	65,053
Collection cost (monthly)	97	5,421
Recovery target (monthly)	97	2,711
Recovery rate	100%	50%

Table 21: Tariff for cost recovery

User Category	(Peso/user/month)	
	CUC	CUP
Inhabitant	0.0	1.0
Office (non-CUC earner) by communal bin	3.3	24
Office (non-CUC earner) by exclusive bin	33.0	240
Office (CUC earner) by communal bin	6.6	48
Office (CUC earner) by exclusive bin	66.0	480
Foreigner by communal bin	9.9	72
Foreigner with exclusive bin	99.0	720
Efficiency of bill collection	95%	95%
Surplus/deficit (Peso/month)	746	-4,162

Table 22: Cross Subsidy Coefficient

User Category	CUC	CUP
Inhabitant	0.0	1.0
Office (non-CUC earner) by communal bin	1.0	2.5
Office (non-CUC earner) by exclusive bin	1.0	2.5
Office (CUC earner) by communal bin	2.0	5.0
Office (CUC earner) by exclusive bin	2.0	5.0
Foreigner by communal bin	3.0	7.4
Foreigner with exclusive bin	3.0	7.4

Table 23: Per liter tariff

User Category	(Peso/liter)	
	CUC	CUP
Inhabitant	0.000	0.011
Office (non-CUC earner) by communal bin	0.004	0.027
Office (non-CUC earner) by exclusive bin	0.004	0.027
Office (CUC earner) by communal bin	0.007	0.053
Office (CUC earner) by exclusive bin	0.007	0.053
Foreigner by communal bin	0.011	0.080
Foreigner with exclusive bin	0.011	0.080

Table 24: Monthly revenue

User Category	(Peso '000)	
	CUC	CUP
Inhabitant	0	1,995
Office (non-CUC earner) by communal bin	24	176
Office (non-CUC earner) by exclusive bin	9	68
Office (CUC earner) by communal bin	11	78
Office (CUC earner) by exclusive bin	19	137
Foreigner by communal bin	7	48
Foreigner with exclusive bin	28	205
Total	98	2,706

Year 2015 Tipping Fee

Table 16: Hauled SW

	SW volume	
	(ton/category /day)	(ton/category /year)
MSW collected by Havana City	940	343,100
MSW collected by other systems	664	242,360
Construction and bulk waste	520	189,800
Industrial waste	350	127,750
Total waste collection	2,474	903,010

Table 17: Landfill Cost to Be Recovered

	(Peso '000/year)	
	CUC	CUP
Landfill cost	804	13,649
Recovery target	804	13,649
Recovery rate	100%	100%
Efficiency of tariff collection	95%	95%
Billing target	846	14,368

Table 18: Cross Subsidy Coefficient in Tipping Fee

User Category	CUC	CUP
MSW collected by Havana City	1.0	1.0
MSW collected by other systems	1.5	1.5
Construction and bulk waste	1.5	1.5
Industrial waste	1.5	1.5

Table 19: Tipping Fee for Cost Recovery

	(Peso/ton)	
	CUC	CUP
MSW collected by Havana City	0.72	12.15
MSW collected by other systems	1.08	18.23
Construction and bulk waste	1.08	18.23
Industrial waste	1.08	18.23

Year 2015 Collection Fee:

(100% CUC recovery; 50% CUP recovery; Cross Subsidy 1:2:3)

Table 20: Collection cost to be recovered

Cost item	(Peso '000)	
	CUC	CUP
Collection cost (annual)	1,909	81,073
Collection cost (monthly)	159	6,756
Recovery target (monthly)	159	3,378
Recovery rate	100%	50%

Table 21: Tariff for cost recovery

User Category	(Peso/user/month)	
	CUC	CUP
Inhabitant	0.0	1.2
Office (non-CUC earner) by communal bin	5.4	33
Office (non-CUC earner) by exclusive bin	54.0	330
Office (CUC earner) by communal bin	10.8	66
Office (CUC earner) by exclusive bin	108.0	660
Foreigner by communal bin	16.2	99
Foreigner with exclusive bin	162.0	990
Efficiency of bill collection	95%	95%
Surplus/deficit (Peso/month)	956	-5,919

Table 22: Cross Subsidy Coefficient

User Category	CUC	CUP
Inhabitant	0.0	1.0
Office (non-CUC earner) by communal bin	1.0	2.8
Office (non-CUC earner) by exclusive bin	1.0	2.8
Office (CUC earner) by communal bin	2.0	5.7
Office (CUC earner) by exclusive bin	2.0	5.7
Foreigner by communal bin	3.0	8.5
Foreigner with exclusive bin	3.0	8.5

Table 23: Per liter tariff

User Category	(Peso/liter)	
	CUC	CUP
Inhabitant	0.000	0.013
Office (non-CUC earner) by communal bin	0.006	0.037
Office (non-CUC earner) by exclusive bin	0.006	0.037
Office (CUC earner) by communal bin	0.012	0.073
Office (CUC earner) by exclusive bin	0.012	0.073
Foreigner by communal bin	0.018	0.110
Foreigner with exclusive bin	0.018	0.110

Table 24: Monthly revenue

User Category	(Peso '000)	
	CUC	CUP
Inhabitant	0	2,394
Office (non-CUC earner) by communal bin	40	241
Office (non-CUC earner) by exclusive bin	15	94
Office (CUC earner) by communal bin	17	107
Office (CUC earner) by exclusive bin	31	188
Foreigner by communal bin	11	66
Foreigner with exclusive bin	46	282
Total	160	3,372

Table 17 Tariff Setting Example 2: Year 2015; 70% Cost Recovery for CUC and CUP CUP; and Cross Subsidy 2:3:4 (partial presentation 1/3)

Table 1: Assumption of MSW generation (2005-2015) in Tariff Analysis

Category	No. of users	MSW generation assumption			
		(liter/user/day)	Specific gravity	(kg/user)	(ton/category/day)
Inhabitant	2,100,000	3.1	0.22	0.68	1,432
Office (non-CUC earner) by communal bin	7,700	30.0	0.30	9.00	69
Office (non-CUC earner) by exclusive bin	300	300.0	0.30	90.00	27
Office (CUC earner) by communal bin	1,700	30.0	0.30	9.00	15
Office (CUC earner) by exclusive bin	300	300.0	0.30	90.00	27
Foreigner by communal bin	700	30.0	0.30	9.00	6
Foreigner with exclusive bin	300	300.0	0.30	90.00	27
Total	2,111,000				1,604

Table 2: Assumption of Waste Collection in Tariff Analysis

	(ton/day)										
	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015
MSW to be collected by Havana City	940	940	940	940	940	940	940	940	940	940	940
MSW to be collected by other systems	664	664	664	664	664	664	664	664	664	664	664
Construction and bulk waste	520	520	520	520	520	520	520	520	520	520	520
Industrial waste	350	350	350	350	350	350	350	350	350	350	350
Total	2,474	2,474	2,474	2,474	2,474	2,474	2,474	2,474	2,474	2,474	2,474

Table 3: Collection O/M cost (with M/P) to be recovered from all SW

	(Peso '000, current prices)										
	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total
CUC	2,164	2,317	2,348	2,379	2,746	3,043	3,082	3,121	3,161	3,201	27,560
CUP	119,665	122,499	125,316	128,199	131,402	135,207	138,317	141,498	144,752	148,082	1,334,936

Table 4: Collection O/M cost (with M/P) to be recovered from MSW collected by Havana City

	(Peso '000, current prices)										
	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total
CUC	1,124	1,203	1,219	1,235	1,426	1,581	1,601	1,621	1,641	1,662	14,313
CUP	62,146	63,618	65,081	66,578	68,242	70,218	71,833	73,485	75,175	76,904	693,282

Table 5 Landfill O/M cost (without M/P)

	(Peso '000, current prices)											
	2003	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015
CUC	116	119	120	121	122	124	125	126	127	129	130	131
CUP	9,115	9,298	9,512	9,731	9,955	10,184	10,418	10,657	10,903	11,153	11,410	11,672

Table 6 Collection O/M cost (without M/P)

	(Peso '000, current prices)											
	2003	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015
CUC	1,450	1,479	1,494	1,509	1,524	1,539	1,555	1,570	1,586	1,602	1,618	1,634
CUP	109,763	114,870	117,512	120,215	122,980	125,808	128,702	131,662	134,690	137,788	140,957	144,199

Table 7: Landfill O/M cost (with M/P) to be recovered from all SW

	(Peso '000, current prices)										
	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total
CUC	124	797	804	813	765	773	780	788	796	804	7,243
CUP	9,512	11,314	11,574	11,848	12,121	12,481	12,761	13,055	13,343	13,649	121,658

Table 8: Landfill O/M cost (with M/P) to be recovered from MSW collected by Havana City

	(Peso '000, current prices)										
	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total
CUC	41	244	247	250	237	237	240	244	244	247	2,230
CUP	2,906	3,455	3,534	3,620	3,702	3,812	3,898	3,987	4,076	4,169	37,158

Table 9: Collection and landfill O/M cost (with M/P) to be recovered from MSW collected by Havana City

	(Peso '000, current prices)										
	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total
CUC	1,165	1,447	1,466	1,486	1,663	1,817	1,841	1,864	1,885	1,909	16,543
CUP	65,053	67,073	68,615	70,198	71,944	74,030	75,731	77,472	79,251	81,073	730,439

Table 10: Household income check (CUP/month)

	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015
Household income	777	795	814	832	852	871	891	912	933	954	976
1% of income	7.8	8.0	8.1	8.3	8.5	8.7	8.9	9.1	9.3	9.5	9.8
1% of income divided by 4 members	1.9	2.0	2.0	2.1	2.1	2.2	2.2	2.3	2.3	2.4	2.4

Table 18 Tariff Setting Example 2: Year 2015; 70% Cost Recovery for CUC and CUP CUP; and Cross Subsidy 2:3:4 (partial presentation 2/3)

Table 11: CUC cost recovery 100%, CUP cost recovery 50%, and cross subsidy 1:2:3

User Category		2006	2007	2008	2009	2010	2011	2012	2013	2014	2015
Inhabitant		CUC	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
		CUP	1.0	1.0	1.0	1.0	1.2	1.2	1.2	1.2	1.2
Office (non-CUC earner) by communal bin		CUC	2.3	2.9	2.9	2.9	3.3	3.6	3.7	3.7	3.8
		CUP	61.0	65.0	68.0	71.0	74.0	65.0	68.0	72.0	79.0
Office (non-CUC earner) by exclusive bin		CUC	23.0	29.0	29.0	29.0	33.0	36.0	36.0	37.0	38.0
		CUP	610.0	650.0	680.0	710.0	740.0	650.0	680.0	720.0	790.0
Office (CUC earner) by communal bin		CUC	4.6	5.8	5.8	5.8	6.6	7.2	7.2	7.4	7.6
		CUP	122.0	130.0	136.0	142.0	148.0	130.0	136.0	144.0	158.0
Office (CUC earner) by exclusive bin		CUC	46.0	58.0	58.0	58.0	66.0	72.0	72.0	74.0	76.0
		CUP	1,220.0	1,300.0	1,360.0	1,420.0	1,480.0	1,300.0	1,360.0	1,440.0	1,580.0
Foreigner by communal bin		CUC	6.9	8.7	8.7	8.7	9.9	10.8	10.8	11.1	11.4
		CUP	183.0	195.0	204.0	213.0	222.0	195.0	204.0	216.0	237.0
Foreigner by exclusive bin		CUC	69.0	87.0	87.0	87.0	99.0	108.0	108.0	111.0	114.0
		CUP	1,830.0	1,950.0	2,040.0	2,130.0	2,220.0	1,950.0	2,040.0	2,160.0	2,370.0
Tipping fee (MSW hauled by Havana City) (unit: peso/ton)		CUC	0.1	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
		CUP	8.5	10.1	10.3	10.6	10.8	11.1	11.4	11.6	11.9
Tipping fee (other SW) (unit: peso/ton)		CUC	0.2	1.1	1.1	1.1	1.0	1.0	1.1	1.1	1.1
		CUP	12.7	15.1	15.5	15.8	16.2	16.7	17.0	17.4	18.2

Table 12: Proposed Tariff

User Category		2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015
		Actual	Plan	Plan	Plan	Plan	Plan	Plan	Plan	Plan	Plan	Plan
Inhabitant		CUC	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
		CUP	0.4	0.4	1.0	1.0	1.0	1.2	1.2	1.2	1.2	1.2
Office (non-CUC earner) by communal bin		CUC	0.0	2.3	2.9	2.9	2.9	3.3	3.6	3.7	3.7	3.8
		CUP	63.0	63.0	65.0	68.0	71.0	74.0	74.0	74.0	74.0	74.0
Office (non-CUC earner) by exclusive bin		CUC	0.0	23.0	29.0	29.0	29.0	33.0	36.0	36.0	37.0	38.0
		CUP	114.0	610.0	650.0	680.0	710.0	740.0	740.0	740.0	740.0	740.0
Office (CUC earner) by communal bin		CUC	30.0	4.6	5.8	5.8	5.8	6.6	7.2	7.2	7.4	7.6
		CUP	33.0	122.0	130.0	136.0	142.0	148.0	148.0	148.0	148.0	158.0
Office (CUC earner) by exclusive bin		CUC	45.0	46.0	58.0	58.0	58.0	66.0	72.0	72.0	74.0	76.0
		CUP	69.0	1,220.0	1,300.0	1,360.0	1,420.0	1,480.0	1,480.0	1,480.0	1,480.0	1,580.0
Foreigner by communal bin		CUC	30.0	6.9	8.7	8.7	8.7	9.9	10.8	10.8	11.1	11.4
		CUP	0.0	183.0	195.0	204.0	213.0	222.0	222.0	222.0	222.0	237.0
Foreigner by exclusive bin		CUC	120.0	69.0	87.0	87.0	87.0	99.0	108.0	108.0	111.0	114.0
		CUP	0.0	1,830.0	1,950.0	2,040.0	2,130.0	2,220.0	2,220.0	2,220.0	2,220.0	2,370.0
Tipping fee (MSW hauled by Havana City) (unit: peso/ton)		CUC	0.0	0.1	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
		CUP	0.5	8.5	10.1	10.3	10.6	10.8	11.1	11.4	11.6	11.9
Tipping fee (other SW) (unit: peso/ton)		CUC	0.0	0.2	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1
		CUP	0.5	12.7	15.1	15.5	15.8	16.2	16.7	17.0	17.4	18.2

Table 13: Expected Revenue under Proposed Tariff (With M/P)

User Category		2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total
Inhabitant		CUC	0	0	0	0	0	0	0	0	0	0
		CUP	9,576	23,940	23,940	23,940	23,940	28,728	28,728	28,728	28,728	248,976
Office (non-CUC earner) by communal bin		CUC	202	255	255	255	290	316	316	325	325	334
		CUP	5,530	5,706	5,969	6,232	6,496	6,496	6,496	6,496	6,496	62,412
Office (non-CUC earner) by exclusive bin		CUC	79	99	99	99	113	123	123	127	127	130
		CUP	2,086	2,223	2,326	2,428	2,531	2,531	2,531	2,531	2,531	24,248
Office (CUC earner) by communal bin		CUC	89	112	112	112	128	140	140	143	143	147
		CUP	2,364	2,519	2,636	2,752	2,868	2,868	2,868	2,868	2,868	27,675
Office (CUC earner) by exclusive bin		CUC	157	198	198	198	226	246	246	253	253	260
		CUP	4,172	4,446	4,651	4,856	5,062	5,062	5,062	5,062	5,062	48,838
Foreigner by communal bin		CUC	55	69	69	69	79	86	86	89	89	91
		CUP	1,460	1,556	1,628	1,700	1,772	1,772	1,772	1,772	1,772	17,093
Foreigner by exclusive bin		CUC	236	298	298	298	339	369	369	380	380	390
		CUP	6,259	6,669	6,977	7,285	7,592	7,592	7,592	7,592	7,592	73,256
Tipping fee (other SW) *		CUC	96	569	574	585	585	559	569	569	569	574
		CUP	6,761	8,037	8,218	8,420	8,612	8,867	9,064	9,271	9,479	86,425
Total		CUC	914	1,601	1,606	1,617	1,759	1,866	1,839	1,885	1,885	1,926
		CUP	38,209	55,096	56,344	57,613	58,872	63,915	64,112	64,320	64,527	588,923

Note: Efficiency of bill collection is assumed to be 95%

* Tipping fee revenue from MSW hauled by Havana City system is offset by the same amount of tipping cost when the entire Havana City SWM accounting is consolidated.

Table 14: Expected Revenue under Current Tariff (Without M/P)

User Category		2005*	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total
CUC		1,108	1,119	1,130	1,142	1,153	1,165	1,176	1,188	1,200	1,212	1,224	11,710
CUP		6,877	6,945	7,015	7,085	7,156	7,227	7,300	7,373	7,446	7,521	7,596	72,663

*2005 revenues were estimated from 2003 revenues, taking account of the ratio of MSW collection and non-MSW collection.

CUC escalation 1% CUP escalation 2.3%

Table 19 Tariff Setting Example 2: Year 2015; 70% Cost Recovery for CUC and CUP CUP; and Cross Subsidy 2:3:4 (partial presentation 3/3)

Year 2006 Tipping Fee
Table 16: Hauled SW

	SW volume	
	(ton/category /day)	(ton/category /year)
MSW collected by Havana City	940	343,100
MSW collected by other systems	664	242,360
Construction and bulk waste	520	189,800
Industrial waste	350	127,750
Total waste collection	2,474	903,010

Table 17: Landfill Cost to Be Recovered

	(Peso '000/year)	
	CUC	CUP
Landfill cost	124	9,512
Recovery target	124	9,512
Recovery rate	100%	100%
Efficiency of tariff collection	95%	95%
Billing target	131	10,013

Table 18: Cross Subsidy Coefficient in Tipping Fee

User Category	CUC	CUP
MSW collected by Havana City	1.0	1.0
MSW collected by other systems	1.5	1.5
Construction and bulk waste	1.5	1.5
Industrial waste	1.5	1.5

Table 19: Tipping Fee for Cost Recovery

	(Peso/ton)	
	CUC	CUP
MSW collected by Havana City	0.12	8.47
MSW collected by other systems	0.18	12.71
Construction and bulk waste	0.18	12.71
Industrial waste	0.18	12.71

Year 2006 Collection Fee:
(70% CUC recovery; 70% CUP recovery; Cross Subsidy 1:2:3)
Table 20: Collection cost to be recovered

Cost item	(Peso '000)	
	CUC	CUP
Collection cost (annual)	1,165	65,053
Collection cost (monthly)	97	5,421
Recovery target (monthly)	68	3,795
Recovery rate	70%	70%

Table 21: Tariff for cost recovery

User Category	(Peso/user/month)	
	CUC	CUP
Inhabitant	0.0	1.0
Office (non-CUC earner) by communal bin	2.3	61
Office (non-CUC earner) by exclusive bin	23.0	610
Office (CUC earner) by communal bin	4.6	122
Office (CUC earner) by exclusive bin	46.0	1220
Foreigner by communal bin	6.9	183
Foreigner with exclusive bin	69.0	1830
Efficiency of bill collection	95%	95%
Surplus/deficit (Peso/month)	226	8,309

Table 22: Cross Subsidy Coefficient

User Category	CUC	CUP
Inhabitant	0.0	1.0
Office (non-CUC earner) by communal bin	1.0	6.3
Office (non-CUC earner) by exclusive bin	1.0	6.3
Office (CUC earner) by communal bin	2.0	12.6
Office (CUC earner) by exclusive bin	2.0	12.6
Foreigner by communal bin	3.0	18.9
Foreigner with exclusive bin	3.0	18.9

Table 23: Per liter tariff

User Category	(Peso/liter)	
	CUC	CUP
Inhabitant	0.000	0.011
Office (non-CUC earner) by communal bin	0.003	0.068
Office (non-CUC earner) by exclusive bin	0.003	0.068
Office (CUC earner) by communal bin	0.005	0.136
Office (CUC earner) by exclusive bin	0.005	0.136
Foreigner by communal bin	0.008	0.203
Foreigner with exclusive bin	0.008	0.203

Table 24: Monthly revenue

User Category	(Peso '000)	
	CUC	CUP
Inhabitant	0	1,995
Office (non-CUC earner) by communal bin	17	446
Office (non-CUC earner) by exclusive bin	7	174
Office (CUC earner) by communal bin	7	197
Office (CUC earner) by exclusive bin	13	348
Foreigner by communal bin	5	122
Foreigner with exclusive bin	20	522
Total	68	3,803

Year 2015 Tipping Fee
Table 16: Hauled SW

	SW volume	
	(ton/category /day)	(ton/category /year)
MSW collected by Havana City	940	343,100
MSW collected by other systems	664	242,360
Construction and bulk waste	520	189,800
Industrial waste	350	127,750
Total waste collection	2,474	903,010

Table 17: Landfill Cost to Be Recovered

	(Peso '000/year)	
	CUC	CUP
Landfill cost	804	13,649
Recovery target	804	13,649
Recovery rate	100%	100%
Efficiency of tariff collection	95%	95%
Billing target	846	14,368

Table 18: Cross Subsidy Coefficient in Tipping Fee

User Category	CUC	CUP
MSW collected by Havana City	1.0	1.0
MSW collected by other systems	1.5	1.5
Construction and bulk waste	1.5	1.5
Industrial waste	1.5	1.5

Table 19: Tipping Fee for Cost Recovery

	(Peso/ton)	
	CUC	CUP
MSW collected by Havana City	0.72	12.15
MSW collected by other systems	1.08	18.23
Construction and bulk waste	1.08	18.23
Industrial waste	1.08	18.23

Year 2015 Collection Fee:
(70% CUC recovery; 70% CUP recovery; Cross Subsidy 1:2:3)
Table 20: Collection cost to be recovered

Cost item	(Peso '000)	
	CUC	CUP
Collection cost (annual)	1,909	81,073
Collection cost (monthly)	159	6,756
Recovery target (monthly)	111	4,729
Recovery rate	70%	70%

Table 21: Tariff for cost recovery

User Category	(Peso/user/month)	
	CUC	CUP
Inhabitant	0.0	1.2
Office (non-CUC earner) by communal bin	3.8	79
Office (non-CUC earner) by exclusive bin	38.0	790
Office (CUC earner) by communal bin	7.6	158
Office (CUC earner) by exclusive bin	76.0	1580
Foreigner by communal bin	11.4	237
Foreigner with exclusive bin	114.0	2370
Efficiency of bill collection	95%	95%
Surplus/deficit (Peso/month)	1,262	6,305

Table 22: Cross Subsidy Coefficient

User Category	CUC	CUP
Inhabitant	0.0	1.0
Office (non-CUC earner) by communal bin	1.0	6.8
Office (non-CUC earner) by exclusive bin	1.0	6.8
Office (CUC earner) by communal bin	2.0	13.6
Office (CUC earner) by exclusive bin	2.0	13.6
Foreigner by communal bin	3.0	20.4
Foreigner with exclusive bin	3.0	20.4

Table 23: Per liter tariff

User Category	(Peso/liter)	
	CUC	CUP
Inhabitant	0.000	0.013
Office (non-CUC earner) by communal bin	0.004	0.088
Office (non-CUC earner) by exclusive bin	0.004	0.088
Office (CUC earner) by communal bin	0.008	0.176
Office (CUC earner) by exclusive bin	0.008	0.176
Foreigner by communal bin	0.013	0.263
Foreigner with exclusive bin	0.013	0.263

Table 24: Monthly revenue

User Category	(Peso '000)	
	CUC	CUP
Inhabitant	0	2,394
Office (non-CUC earner) by communal bin	28	578
Office (non-CUC earner) by exclusive bin	11	225
Office (CUC earner) by communal bin	12	255
Office (CUC earner) by exclusive bin	22	450
Foreigner by communal bin	8	158
Foreigner with exclusive bin	32	675
Total	113	4,736

Table 20 Population Benefited from Sanitary Landfill (inhabitants within a 1km radius of landfills)

No.	Landfill	Closing/operation status	Municipality	Landfill area (ha)	Outer 1km area (ha)	Net outer area (km2)	Population density (person/km2)	Population benefited
1	Ocho Vias	Operational until 2015	Cotorro	30.0	538.1	5.1	1,134	5,762
2	Barreras	Operational until 2015	Habana este	10.0	436.1	4.3	1,280	5,454
3	Lugardita	Closed by the end of 2008	Boyeros	1.5	358.9	3.6	1,407	5,029
4	Prensa Latina	Closed by the end of 2008	Boyeros	2.0	366.1	3.6	1,407	5,123
5	Rincon	Closed by the end of 2008	Boyeros	0.5	339.6	3.4	1,407	4,771
6	Las Canas	Closed by the end of 2008	Boyeros	1.0	350.4	3.5	1,407	4,917
7	El Vidrio	Closed by the end of 2008	La Lisa	2.5	372.5	3.7	3,408	12,611
8	Los Perros	Closed by the end of 2008	Cotorro	2.0	366.1	3.6	1,134	4,129
9	Campo Florido	Operational until 2015	Habana este	1.8	363.3	3.6	1,280	4,628
10	New Guanabacoa	Operational until 2015	Guanabacoa	18.0	482.4	4.6	834	3,873
11	New site	Operational from 2011 to 2015	Boyeros	60.0	648.5	5.9	1,407	8,280
12	Calle 100 (existing)	Closed by the end of 2008	Marianao	80.0	711.0	6.3	6,464	40,787
13	Calle 100 (extension)	Operational until 2010	Marianao	24.0	68.4	0.4	6,464	2,872
	Closed landfill total (3+4+5+6+7+8+12)			89.5	2,222.1	21.9		39,451
	Operational landfill total (1+2+9+10+11+13)			143.8	2,468.4	23.5		27,997
	Total (1+2+3+4+5+6+7+8+9+10+11+12+13)			233.3	4,690.5	45.4		67,448

Table 21 BOD Reduction by Leachate Treatment

(BOD ton/year)

	New Site 1 Stage 1	New Site 1 Stage 2	New Site 1 Stage 3	New Guan. Stage 1	New Guan. Stage 2	Total BOD reduction
2007	76			41		117
2008	76			41		117
2009	76			41		117
2010	76			41		117
2011	76			44	35	155
2012	81	47		44	35	207
2013	81	47		44	35	207
2014	81	50	47	44	35	256
2015	81	50	47	44	35	256
Total	704	193	94	382	176	1,549
	Annual average					172

Where:

BOD reduction is 940mg/L (=1000mg/L - 60mg/L)

Leachate generation coefficient = 0.4

Annual rainfall (year 2002) = 1,557 mm

Environmental load of Havana City (year 2003)= 28,501 BOD ton

Landfill area:

New site 1(stage1) = 13 ha = 130,000 m²

New site 1(stage2) = 8 ha = 80,000 m²

New site 1(stage3) = 8 ha = 80,000 m²

New Guanabacoa (stage1) : 7 ha = 70,000 m²

New Guanabacoa (stage2) : 6 ha = 60,000 m²

Precipitation at landfill:

New site 1(stage1) = 202,410 m³/year

New site 1(stage2) = 124,560 m³/year

New site 1(stage3) = 124,560 m³/year

New Guanabacoa (stage1) : 108,990 m³/year

New Guanabacoa (stage2) : 93,420 m³/year

Leachate generation at landfill:

New site 1(stage1) = 80,964 m³/year

New site 1(stage2) = 49,824 m³/year

New site 1(stage3) = 49,824 m³/year

New Guanabacoa (stage1) : 43,596 m³/year

New Guanabacoa (stage2) : 37,368 m³/year

BOD reduction before closure:

New site 1(stage1) = 76 ton/year

New site 1(stage2) = 47 ton/year

New site 1(stage3) = 47 ton/year

New Guanabacoa (stage1) : 41 ton/year

New Guanabacoa (stage2) : 35 ton/year

BOD reduction after closure:

New site 1(stage1) = 81 ton/year

New site 1(stage2) = 50 ton/year

New site 1(stage3) = 50 ton/year

New Guanabacoa (stage1) : 44 ton/year

New Guanabacoa (stage2) : 37 ton/year

Table 22 Summary of Master Plan Cost

(FC: US\$ million, LC: CUP million, 2005 prices)

Component	Capital cost						O/M Cost		Capital Cost + O/M Cost	
	Direct Cost		Indirect Cost		Direct+Indirect		FC	LC	FC	LC
	FC	LC	FC	LC	FC	LC				
Composting (total)	4.7	4.0	0.4	0.6	5.1	4.6	0.3	6.4	5.4	11.0
Composting at Calle 100	2.1	2.2	0.1	0.3	2.3	2.5	0.1	2.2	2.4	4.7
Composting at New Guanabacoa	1.6	1.8	0.2	0.3	1.8	2.2	0.2	4.2	2.0	6.3
Home composting	1.0	0.0	0.0	0.0	1.0	0.0	0.0	0.0	1.0	0.0
Recycling (total)	4.0	3.9	0.3	0.5	4.3	4.4	0.3	14.2	4.5	18.6
Recycling at Calle 100	2.3	2.2	0.2	0.3	2.5	2.5	0.2	9.8	2.6	12.3
Recycling at New Guanabacoa	1.7	1.7	0.1	0.2	1.8	1.9	0.1	4.4	1.9	6.3
Collection and transportation (total)	22.7	0.0	1.6	0.0	24.2	0.0	7.5	65.5	31.8	65.5
Collection vehicle replacement	13.9	0.0	1.0	0.0	14.9	0.0	6.3	57.0	21.2	57.0
Improvement of waste bin	5.4	0.0	0.4	0.0	5.8	0.0	0.3	0.0	6.1	0.0
Maintenance workshop improvement	3.3	0.0	0.2	0.0	3.6	0.0	1.0	8.5	4.5	8.5
Landfill (total)	42.0	26.8	6.0	4.0	48.0	30.9	4.3	11.0	52.3	41.8
Construction of new site	7.5	6.5	1.3	1.1	8.7	7.6	2.2	4.6	11.0	12.2
Construction of New Guanabacoa	10.7	4.9	1.5	0.8	12.2	5.6	1.0	2.9	13.2	8.5
Extension of Calle 100	18.0	7.2	2.2	1.0	20.2	8.2	0.9	1.7	21.2	9.9
Closure of special period dumping sites	2.2	3.3	0.3	0.4	2.5	3.7	0.0	0.0	2.5	3.7
Closure of Calle 100	1.9	2.9	0.4	0.5	2.4	3.3	0.0	0.0	2.4	3.3
Closure of Extended Area of Calle 100	0.2	0.3	0.1	0.1	0.3	0.4	0.0	0.0	0.3	0.4
Closure of Guanabacoa landfill	1.2	1.7	0.2	0.2	1.4	2.0	0.0	0.0	1.4	2.0
Central workshop improvement	0.3	0.0	0.0	0.0	0.3	0.0	0.1	1.8	0.4	1.8
Awareness raising	0.0	0.0	0.0	0.0	0.0	0.0	2.1	1.4	2.1	1.4
Environmental monitoring	0.3	0.1	0.0	0.0	0.3	0.1	0.3	0.0	0.6	0.1
Total	73.6	34.8	8.3	5.2	81.9	40.0	14.8	98.4	96.7	138.4

Table 23 Disbursement Schedule of Master Plan Costs

(FC: US\$'000, LC: CUP'000, Total: US\$'000, constant prices)

		2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total
Composting (Total)	FC	0	0	231	1,919	151	151	2,440	186	186	186	5,448
	LC	0	0	0	2,164	693	693	3,168	1,425	1,425	1,425	10,993
Composting at Calle 100	FC							2,290	35	35	35	2,395
	LC							2,475	732	732	732	4,671
Composting at New Guanabacoa	FC				1,803	35	35	35	35	35	35	2,013
	LC				2,164	693	693	693	693	693	693	6,322
Home composting	FC			231	116	116	116	116	116	116	116	1,040
	LC											0
Recycling (Total)	FC				2,475	28	28	1,836	56	56	56	4,535
	LC				2,535	1,630	1,630	3,516	3,104	3,104	3,104	18,623
Recycling at Calle 100	FC				2,475	28	28	28	28	28	28	2,643
	LC				2,535	1,630	1,630	1,630	1,630	1,630	1,630	12,315
Recycling at New Guanabacoa	FC							1,808	28	28	28	1,892
	LC							1,886	1,474	1,474	1,474	6,308
Collection & transportation (Total)	FC	0	0	8,319	928	5,384	5,721	948	8,279	1,097	1,097	31,772
	LC	0	0	6,481	6,481	7,115	8,564	8,564	9,421	9,421	9,421	65,470
Collection vehicle replacement	FC			7,419	891	3,331	2,832	780	4,069	930	930	21,181
	LC			5,461	5,461	6,094	7,480	7,480	8,337	8,337	8,337	56,986
Improvement of waste bin	FC					2,015			4,042			6,058
	LC											0
Maintenance workshop improvement	FC			899	38	38	2,889	167	167	167	167	4,534
	LC			1,021	1,021	1,021	1,084	1,084	1,084	1,084	1,084	8,485
Final Disposal (Total)	FC		336	27,917	5,802	5,125	6,996	625	4,097	625	767	52,291
	LC		229	12,233	8,480	6,483	5,267	1,596	4,398	1,575	1,575	41,837
Construction of new site	FC		40	160	66	4,339	1,355	454	3,491	455	605	10,965
	LC		33	125	48	4,867	994	928	3,403	913	913	12,224
Construction of New Guanabacoa	FC			7,812	144	299	4,289	144	218	148	144	13,196
	LC			3,868	415	494	2,076	411	411	411	411	8,498
Extension of Calle 100	FC		139	19,736	847	447	10		10			21,188
	LC		50	8,185	853	853						9,942
Closure of special period dumping sites	FC		25	7	2,455	11						2,498
	LC		25	5	3,654	10						3,694
Closure of Calle 100	FC		95	23	2,240							2,358
	LC		88	20	3,230							3,338
Closure of Extended Area of Calle 100	FC		37	34				9	222			302
	LC		33	30				6	333			402
Closure of Guanabacoa landfill	FC				32	7	1,325					1,364
	LC				28	8	1,946					1,982
Central workshop improvement	FC			146	19	22	18	18	157	22	18	420
	LC				251	251	251	251	251	251	251	1,757
Awareness raising	FC		364	363	361	242	284	284	92	50	50	2,090
	LC		257	256	254	162	194	194	46	14	14	1,391
Environmental monitoring	FC		115	110	95	91	29	29	29	29	29	555
	LC			13	31	17	11	5	5	5	5	97
Total	FC	0	815	36,940	11,581	11,019	13,208	6,162	12,738	2,042	2,185	96,691
	LC	0	499	19,002	19,930	16,094	16,354	17,043	18,400	15,545	15,545	138,412
Grand Total (US\$'000)		0	835	37,671	12,347	11,638	13,837	6,818	13,446	2,640	2,783	102,014

Grand Total at US\$1 : CUP26

Table 24-1 Cost Disbursement of Master Plan Components (2005 constant price: 1/4)

			(FC: US\$'000, LC: CUP'000, Total: US\$'000, constant prices)											
			2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total	
Composting at Calle 100	Capital cost (direct)	FC							2,140				2,140	
	Capital cost (direct)	LC							2,190				2,190	
	Total capital cost (direct) *a								4,330				4,330	
	Engineering cost *b	FC							43				43	
	Engineering cost *c	LC							110				110	
	Administration	FC											0	
	Administration *d	LC								66				66
	Physical conting. *e	FC								107				107
	Physical conting. *e	LC								110				110
	O/M cost	FC									35	35	35	105
	O/M cost	LC									732	732	732	2,196
	Total FC portion	FC								2,290	35	35	35	2,395
	Total LC portion	LC								2,475	732	732	732	4,671
Total FC + LC *f									2,385	63	63	63	2,574	
Total FC + LC *a									4,765	767	767	767	7,066	
Composting at New Guanabacoa	Capital cost (direct)	FC				1,610							1,610	
	Capital cost (direct)	LC				1,834							1,834	
	Total capital cost (direct) *a					3,444							3,444	
	Engineering cost *b	FC				32							32	
	Engineering cost *c	LC				92							92	
	Administration	FC											0	
	Administration *d	LC											55	
	Physical conting. *e	FC											161	
	Physical conting. *e	LC											183	
	O/M cost	FC						35	35	35	35	35	35	210
	O/M cost	LC						693	693	693	693	693	693	4,158
	Total FC portion	FC					1,803	35	35	35	35	35	35	2,013
	Total LC portion	LC					2,164	693	693	693	693	693	693	6,322
Total FC + LC *f						1,886	62	62	62	62	62	62	2,256	
Total FC + LC *a						3,967	728	728	728	728	728	728	8,335	
Home composting	Capital cost (direct)	FC			220	110	110	110	110	110	110	110	990	
	Capital cost (direct)	LC											0	
	Total capital cost (direct) *a				220	110	110	110	110	110	110	110	990	
	Engineering cost *b	FC											0	
	Engineering cost *c	LC											0	
	Administration	FC											0	
	Administration *d	LC											0	
	Physical conting. *e	FC				11	6	6	6	6	6	6	6	50
	Physical conting. *e	LC												0
	O/M cost	FC												0
	O/M cost	LC												0
	Total FC portion	FC				231	116	116	116	116	116	116	116	1,040
	Total LC portion	LC												0
Total FC + LC *f					231	116	116	116	116	116	116	116	1,040	
Total FC + LC *a					231	116	116	116	116	116	116	116	1,040	
Recycling at Calle 100	Capital cost (direct)	FC				2,313							2,313	
	Capital cost (direct)	LC				2,243							2,243	
	Total capital cost (direct) *a					4,556							4,556	
	Engineering cost *b	FC				46							46	
	Engineering cost *c	LC				112							112	
	Administration	FC											0	
	Administration *d	LC											67	
	Physical conting. *e	FC											116	
	Physical conting. *e	LC											112	
	O/M cost	FC						28	28	28	28	28	28	168
	O/M cost	LC						1,630	1,630	1,630	1,630	1,630	1,630	9,780
	Total FC portion	FC					2,475	28	28	28	28	28	28	2,643
	Total LC portion	LC					2,535	1,630	1,630	1,630	1,630	1,630	1,630	12,315
Total FC + LC *f						2,572	91	91	91	91	91	91	3,117	
Total FC + LC *a						5,010	1,658	1,658	1,658	1,658	1,658	1,658	14,958	
Recycling at New Guanabacoa	Capital cost (direct)	FC							1,690				1,690	
	Capital cost (direct)	LC							1,669				1,669	
	Total capital cost (direct) *a								3,359				3,359	
	Engineering cost *b	FC							34				34	
	Engineering cost *c	LC							83				83	
	Administration	FC											0	
	Administration *d	LC								50			50	
	Physical conting. *e	FC								85			85	
	Physical conting. *e	LC								85			85	
	O/M cost	FC									28	28	28	84
	O/M cost	LC									1,474	1,474	1,474	4,422
	Total FC portion	FC								1,808	28	28	28	1,892
	Total LC portion	LC								1,886	1,474	1,474	1,474	6,308
Total FC + LC *f									1,881	85	85	85	2,135	
Total FC + LC *a									3,694	1,502	1,502	1,502	8,200	

Table 24-2 Cost Disbursement of Master Plan Components (2005 constant price: 2/4)

			(FC: US\$'000, LC: CUP'000, Total: US\$'000, constant prices)											
			2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total	
Collection vehicle replacement	Capital cost (direct)	FC			6,352	260	2,340	1,954		2,990			13,895	
	Capital cost (direct)	LC											0	
	Total capital cost (direct) *a				6,352	260	2,340	1,954		2,990			13,895	
	Engineering cost *b	FC			132		146						278	
	Engineering cost *c	LC											0	
	Administration	FC											0	
	Administration *d	LC											0	
	Physical conting. *e	FC			318	13	117	98		150				695
	Physical conting. *e	LC												0
	O/M cost	FC			618	618	728	780	780	930	930	930		6,312
	O/M cost *g	LC			5,461	5,461	6,094	7,480	7,480	8,337	8,337	8,337		56,986
	Total FC portion	FC			7,419	891	3,331	2,832	780	4,069	930	930		21,181
	Total LC portion	LC			5,461	5,461	6,094	7,480	7,480	8,337	8,337	8,337		56,986
	Total FC + LC *f				7,629	1,101	3,565	3,119	1,068	4,390	1,250	1,250		23,372
Total FC + LC *a				12,880	6,351	9,425	10,311	8,260	12,406	9,267	9,267		78,166	
Improvement of waste bin	Capital cost (direct)	FC					1,734			3,675			5,409	
	Capital cost (direct)	LC											0	
	Total capital cost (direct) *a						1,734			3,675			5,409	
	Engineering cost *b	FC					108						108	
	Engineering cost *c	LC											0	
	Administration	FC											0	
	Administration *d	LC											0	
	Physical conting. *e	FC					87			184				270
	Physical conting. *e	LC												0
	O/M cost	FC					87			184				270
	O/M cost	LC												0
	Total FC portion	FC					2,015			4,042				6,058
	Total LC portion	LC												0
	Total FC + LC *f						2,015			4,042				6,058
Total FC + LC *a						2,015			4,042				6,058	
Maintenance workshop improvement	Capital cost (direct)	FC			757			2,592					3,349	
	Capital cost (direct)	LC											0	
	Total capital cost (direct) *a				757			2,592					3,349	
	Engineering cost *b	FC			67								67	
	Engineering cost *c	LC											0	
	Administration	FC											0	
	Administration *d	LC											0	
	Physical conting. *e	FC			38			130						167
	Physical conting. *e	LC												0
	O/M cost	FC			38	38	38	167	167	167	167	167		951
	O/M cost	LC			1,021	1,021	1,021	1,084	1,084	1,084	1,084	1,084		8,485
	Total FC portion	FC			899	38	38	2,889	167	167	167	167		4,534
	Total LC portion	LC			1,021	1,021	1,021	1,084	1,084	1,084	1,084	1,084		8,485
	Total FC + LC *f				939	77	77	2,931	209	209	209	209		4,860
Total FC + LC *a				1,920	1,059	1,059	3,973	1,252	1,252	1,252	1,252		13,019	
Construction of new site 1	Capital cost (direct)	FC					3,794	770		2,734	8	151	7,456	
	Capital cost (direct)	LC					4,356			2,186			6,542	
	Total capital cost (direct) *a						8,150	770		4,920	8	151	13,998	
	Engineering cost *b	FC		26	100	41	110	62	4	30			373	
	Engineering cost *c	LC		13	50	19	30	28	2	30			172	
	Administration	FC		14	60	25	66	38	3	19			225	
	Administration *d	LC		20	75	29	45	42	3	45			259	
	Physical conting. *e	FC					369	39		261	0	8	677	
	Physical conting. *e	LC					436			219			654	
	O/M cost	FC						447	447	447	447	447		2,234
	O/M cost	LC						924	923	923	913	913		4,597
	Total FC portion	FC		40	160	66	4,339	1,355	454	3,491	455	605		10,965
	Total LC portion	LC		33	125	48	4,867	994	928	3,403	913	913		12,224
	Total FC + LC *f			41	165	68	4,526	1,393	489	3,622	490	640		11,435
Total FC + LC *a			73	285	114	9,206	2,349	1,382	6,894	1,369	1,518		23,189	
Construction of New Guanabacoa	Capital cost (direct)	FC			6,952		3	3,631		70	3		10,659	
	Capital cost (direct)	LC			3,422			1,434					4,856	
	Total capital cost (direct) *a				10,374		3	5,065		70	3		15,515	
	Engineering cost *b	FC			156		94	99					349	
	Engineering cost *c	LC			42		31	33					106	
	Administration	FC			93		57	60					210	
	Administration *d	LC			62		47	50					159	
	Physical conting. *e	FC			611		0	355		4	0		969	
	Physical conting. *e	LC			342			143					486	
	O/M cost	FC				144	144	144	144	144	144	144		1,009
	O/M cost	LC				415	416	416	411	411	411	411		2,891
	Total FC portion	FC			7,812	144	299	4,289	144	218	148	144		13,196
	Total LC portion	LC			3,868	415	494	2,076	411	411	411	411		8,498
	Total FC + LC *f				7,960	160	317	4,369	160	233	163	160		13,523
Total FC + LC *a				11,680	560	792	6,365	555	629	559	555		21,694	

Table 24-3 Cost Disbursement of Master Plan Components (2005 constant price: 3/4)

			(FC: US\$'000, LC: CUP'000, Total: US\$'000, constant prices)											
			2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total	
Extension of Calle 100	Capital cost (direct)	FC			17,674	331			9				18,024	
	Capital cost (direct)	LC			7,234								7,234	
	Total capital cost (direct) *a				24,908	331			9				25,258	
	Engineering cost *b	FC		100	359								459	
	Engineering cost *c	LC		20	91								111	
	Administration	FC		39	139								178	
	Administration *d	LC		30	137								167	
	Physical conting. *e	FC			1,564	17			0		0			1,582
	Physical conting. *e	LC			723									723
	O/M cost	FC				499	447							946
	O/M cost	LC				853	853							1,706
	Total FC portion	FC		139	19,736	847	447		10			10		21,188
	Total LC portion	LC		50	8,185	853	853							9,942
Total FC + LC *f			141	20,051	880	480		10			10		21,571	
Total FC + LC *a			189	27,921	1,700	1,300		10		10			31,130	
Closure of special period dumping sites	Capital cost (direct)	FC				2,217							2,217	
	Capital cost (direct)	LC				3,308							3,308	
	Total capital cost (direct) *a					5,525							5,525	
	Engineering cost *b	FC		16	4	10	7						37	
	Engineering cost *c	LC		10	2	6	4						22	
	Administration	FC		9	3	6	4						22	
	Administration *d	LC		15	3	9	6						33	
	Physical conting. *e	FC				222							222	
	Physical conting. *e	LC				331							331	
	O/M cost	FC											0	
	O/M cost	LC											0	
	Total FC portion	FC		25	7	2,455	11						2,498	
	Total LC portion	LC		25	5	3,654	10						3,694	
Total FC + LC *f			26	7	2,595	11						2,640		
Total FC + LC *a			50	12	6,109	21						6,192		
Closure of Calle 100	Capital cost (direct)	FC				1,945							1,945	
	Capital cost (direct)	LC				2,852							2,852	
	Total capital cost (direct) *a					4,797							4,797	
	Engineering cost *b	FC		59	14	62							135	
	Engineering cost *c	LC		35	8	37							80	
	Administration	FC		36	9	38							83	
	Administration *d	LC		53	12	56							121	
	Physical conting. *e	FC				195							195	
	Physical conting. *e	LC				285							285	
	O/M cost	FC											0	
	O/M cost	LC											0	
	Total FC portion	FC		95	23	2,240							2,358	
	Total LC portion	LC		88	20	3,230							3,338	
Total FC + LC *f			98	24	2,364							2,486		
Total FC + LC *a			183	43	5,470							5,696		
Closure of Extended Area of Calle 100	Capital cost (direct)	FC								202			202	
	Capital cost (direct)	LC								303			303	
	Total capital cost (direct) *a									505			505	
	Engineering cost *b	FC		22	20								51	
	Engineering cost *c	LC		13	12				9				31	
	Administration	FC		15	14				6				29	
	Administration *d	LC		20	18								38	
	Physical conting. *e	FC									20		20	
	Physical conting. *e	LC									30		30	
	O/M cost	FC											0	
	O/M cost	LC											0	
	Total FC portion	FC		37	34					9	222		302	
	Total LC portion	LC		33	30					6	333		402	
Total FC + LC *f			38	35					9	235		318		
Total FC + LC *a			70	64					15	556		705		
Closure of Guanabacoa landfill	Capital cost (direct)	FC						1,175					1,175	
	Capital cost (direct)	LC						1,742					1,742	
	Total capital cost (direct) *a							2,917					2,917	
	Engineering cost *b	FC				20	4	20					44	
	Engineering cost *c	LC				11	3	12					26	
	Administration	FC				12	3	12					27	
	Administration *d	LC				17	5	18					40	
	Physical conting. *e	FC						118					118	
	Physical conting. *e	LC						174					174	
	O/M cost	FC											0	
	O/M cost	LC											0	
	Total FC portion	FC				32	7	1,325					1,364	
	Total LC portion	LC				28	8	1,946					1,982	
Total FC + LC *f					33	9	1,399					1,440		
Total FC + LC *a					60	15	3,271					3,346		

Table 24-4 Cost Disbursement of Master Plan Components (2005 constant price: 4/4)

(FC: US\$'000, LC: CUP'000, Total: US\$'000, constant prices)

			2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total	
Central workshop improvement	Capital cost (direct)	FC			135		4			132	4		275	
	Capital cost (direct)	LC											0	
	Total capital cost (direct) *a				135		4			132	4		275	
	Engineering cost *b	FC											0	
	Engineering cost *c	LC											0	
	Administration	FC											0	
	Administration *d	LC											0	
	Physical conting. *e	FC			7		0				7	0		14
	Physical conting. *e	LC												0
	O/M cost	FC			4	19	18	18	18	18	18	18	18	132
	O/M cost	LC				251	251	251	251	251	251	251	251	1,757
	Total FC portion	FC			146	19	22	18	18	157	22	18		420
	Total LC portion	LC				251	251	251	251	251	251	251		1,757
Total FC + LC *f				146	29	32	28	28	166	32	28		488	
Total FC + LC *a				146	270	273	269	269	408	273	269		2,177	
Awareness raising	Capital cost (direct)	FC											0	
	Capital cost (direct)	LC											0	
	Total capital cost (direct) *a												0	
	Engineering cost *b	FC											0	
	Engineering cost *c	LC											0	
	Administration	FC											0	
	Administration *d	LC											0	
	Physical conting. *e	FC											0	
	Physical conting. *e	LC											0	
	O/M cost	FC		364	363	361	242	284	284	92	50	50		2,090
	O/M cost	LC		257	256	254	162	194	194	46	14	14		1,391
	Total FC portion	FC		364	363	361	242	284	284	92	50	50		2,090
	Total LC portion	LC		257	256	254	162	194	194	46	14	14		1,391
Total FC + LC *f			374	373	371	248	291	291	94	51	51		2,144	
Total FC + LC *a			621	619	615	404	478	478	138	64	64		3,481	
Environmental monitoring	Capital cost (direct)	FC		85	72	72	36						265	
	Capital cost (direct)	LC		10	27	12	6						55	
	Total capital cost (direct) *a			95	99	84	42						321	
	Engineering cost *b	FC											0	
	Engineering cost *c	LC											0	
	Administration	FC											0	
	Administration *d	LC											0	
	Physical conting. *e	FC		4	4	4	2						13	
	Physical conting. *e	LC		1	1	1	0						3	
	O/M cost	FC		26	34	20	53	29	29	29	29	29		276
	O/M cost	LC		3	3	4	5	5	5	5	5	5		40
	Total FC portion	FC		115	110	95	91	29	29	29	29	29		555
	Total LC portion	LC		13	31	17	11	5	5	5	5	5		97
Total FC + LC *f			116	111	96	91	29	29	29	29	29		559	
Total FC + LC *a			128	141	112	102	34	34	34	34	34		652	
Total	Capital cost (direct)	FC		85	32,161	8,858	8,020	10,241	3,940	9,922	125	261	73,614	
	Capital cost (direct)	LC		10	10,683	10,249	4,362	3,176	3,859	2,489			34,828	
	Total capital cost (direct) *a			95	42,844	19,107	12,382	13,417	7,799	12,411	125	261	108,442	
	Engineering cost *b	FC		223	852	211	469	181	90	30			2,056	
	Engineering cost *c	LC		91	205	277	68	73	201	30			945	
	Administration	FC		113	318	81	130	110	3	19			774	
	Administration *d	LC		138	307	233	103	110	119	45			1,055	
	Physical conting. *e	FC		4	2,552	732	581	744	197	631	6	13	5,459	
	Physical conting. *e	LC		1	1,067	912	436	318	193	249			3,175	
	O/M cost	FC		390	1,057	1,699	1,819	1,932	1,932	2,137	1,911	1,911	14,787	
	O/M cost	LC		260	6,740	8,259	11,125	12,677	12,672	15,587	15,545	15,545	98,408	
	Total FC portion	FC		815	36,940	11,581	11,019	13,208	6,162	12,738	2,042	2,185	96,691	
	Total LC portion	LC		499	19,002	19,930	16,094	16,354	17,043	18,400	15,545	15,545	138,412	
Total FC + LC *f			835	37,671	12,347	11,638	13,837	6,818	13,446	2,640	2,783	102,014		
Total FC + LC *a			1,314	55,942	31,511	27,113	29,562	23,205	31,138	17,587	17,730	235,102		

*a. FC portion (US\$) and LC portion (CUP) are added up at exchange rate of US\$1=CUP 1

*b. Engineering cost in FC portion will be incurred at the designing stage, which is 2% of the direct capital cost.

*c. Engineering cost in LC portion will be incurred at the designing stage, which is 5% of the direct capital cost.

*d. Administration cost will be incurred during construction/acquisition period, which is 3% of direct capital cost of LC portion.

*e. Physical contingency is 10% of direct construction cost and 5% of direct equipment cost, both for FC and LC portions.

*f. FC portion (US\$) and LC portion (CUP) are added up at exchange rate of US\$1= CUP26

Table 25-1 Fund Requirement of Master Plan Components (2005 constant price: 1/4)

			(FC: US\$'000, LC: CUP'000, Total: US\$'000, current prices)										
			2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total
Composting at Calle 100	Capital cost (direct)	FC							2,294				2,294
	Capital cost (direct)	LC							2,568				2,568
	Total capital cost (direct) *a								4,862				4,862
	Engineering cost *b	FC							46				46
	Engineering cost *c	LC							128				128
	Administration	FC											0
	Administration *d	LC							77				77
	Physical conting. *e	FC							115				115
	Physical conting. *e	LC							128				128
	O/M cost	FC								38	38	39	115
	O/M cost	LC								878	898	919	2,695
	Total FC portion	FC							2,455	38	38	39	2,570
	Total LC portion	LC							2,902	878	898	919	5,597
Total FC + LC *f								2,567	72	73	74	2,785	
Total FC + LC *a								5,357	916	937	958	8,167	
Composting at New Guanabacoa	Capital cost (direct)	FC				1,675							1,675
	Capital cost (direct)	LC				2,009							2,009
	Total capital cost (direct) *a					3,684							3,684
	Engineering cost *b	FC				34							34
	Engineering cost *c	LC				100							100
	Administration	FC											0
	Administration *d	LC				60							60
	Physical conting. *e	FC				168							168
	Physical conting. *e	LC				201							201
	O/M cost	FC					37	37	38	38	38	39	226
	O/M cost	LC					776	794	813	831	850	870	4,935
	Total FC portion	FC				1,876	37	37	38	38	38	39	2,103
	Total LC portion	LC				2,370	776	794	813	831	850	870	7,305
Total FC + LC *f					1,968	67	68	69	70	71	72	2,384	
Total FC + LC *a					4,247	813	831	850	869	889	909	9,408	
Home composting	Capital cost (direct)	FC			227	114	116	117	118	119	120	122	1,052
	Capital cost (direct)	LC											0
	Total capital cost (direct) *a				227	114	116	117	118	119	120	122	1,052
	Engineering cost *b	FC											0
	Engineering cost *c	LC											0
	Administration	FC											0
	Administration *d	LC											0
	Physical conting. *e	FC			11	6	6	6	6	6	6	6	53
	Physical conting. *e	LC											0
	O/M cost	FC											0
	O/M cost	LC											0
	Total FC portion	FC			238	120	121	123	124	125	126	128	1,105
	Total LC portion	LC											0
Total FC + LC *f				238	120	121	123	124	125	126	128	1,105	
Total FC + LC *a				238	120	121	123	124	125	126	128	1,105	
Recycling at Calle 100	Capital cost (direct)	FC				2,407							2,407
	Capital cost (direct)	LC				2,457							2,457
	Total capital cost (direct) *a					4,864							4,864
	Engineering cost *b	FC				48							48
	Engineering cost *c	LC				123							123
	Administration	FC											0
	Administration *d	LC				74							74
	Physical conting. *e	FC				120							120
	Physical conting. *e	LC				123							123
	O/M cost	FC					29	30	30	30	31	31	181
	O/M cost	LC					1,826	1,868	1,911	1,955	2,000	2,046	11,607
	Total FC portion	FC				2,575	29	30	30	30	31	31	2,756
	Total LC portion	LC				2,776	1,826	1,868	1,911	1,955	2,000	2,046	14,383
Total FC + LC *f					2,682	100	102	104	106	108	110	3,310	
Total FC + LC *a					5,351	1,856	1,898	1,941	1,986	2,031	2,077	17,140	
Recycling at New Guanabacoa	Capital cost (direct)	FC							1,812				1,812
	Capital cost (direct)	LC							1,957				1,957
	Total capital cost (direct) *a								3,769				3,769
	Engineering cost *b	FC							36				36
	Engineering cost *c	LC							98				98
	Administration	FC											0
	Administration *d	LC							59				59
	Physical conting. *e	FC							91				91
	Physical conting. *e	LC							98				98
	O/M cost	FC								30	31	31	92
	O/M cost	LC								1,768	1,809	1,850	5,427
	Total FC portion	FC							1,939	30	31	31	2,031
	Total LC portion	LC							2,211	1,768	1,809	1,850	7,639
Total FC + LC *f								2,024	98	100	102	2,324	
Total FC + LC *a								4,150	1,798	1,839	1,881	9,669	

Table 25-2 Fund Requirement of Master Plan Components (2005 constant price: 2/4)

			(FC: US\$'000, LC: CUP'000, Total: US\$'000, current prices)										
			2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total
Collection vehicle replacement	Capital cost (direct)	FC			6,544	271	2,459	2,074		3,238			14,586
	Capital cost (direct)	LC											0
	Total capital cost (direct) *a				6,544	271	2,459	2,074		3,238			14,586
	Engineering cost *b	FC			136		153						289
	Engineering cost *c	LC											0
	Administration	FC											0
	Administration *d	LC											0
	Physical conting. *e	FC			327	14	123	104		162			729
	Physical conting. *e	LC											0
	O/M cost	FC			636	643	765	828	836	1,007	1,017	1,027	6,759
	O/M cost *g	LC			5,846	5,980	6,828	8,573	8,771	10,000	10,230	10,466	66,694
	Total FC portion	FC			7,644	927	3,501	3,006	836	4,406	1,017	1,027	22,363
	Total LC portion	LC			5,846	5,980	6,828	8,573	8,771	10,000	10,230	10,466	66,694
	Total FC + LC *f				7,869	1,157	3,763	3,335	1,174	4,791	1,410	1,429	24,929
Total FC + LC *a				13,490	6,907	10,328	11,579	9,607	14,407	11,247	11,493	89,058	
Improvement of waste bin	Capital cost (direct)	FC					1,822			3,979			5,801
	Capital cost (direct)	LC											0
	Total capital cost (direct) *a						1,822			3,979			5,801
	Engineering cost *b	FC					114						114
	Engineering cost *c	LC											0
	Administration	FC											0
	Administration *d	LC											0
	Physical conting. *e	FC					91			199			290
	Physical conting. *e	LC											0
	O/M cost	FC					91			199			290
	O/M cost	LC											0
	Total FC portion	FC					2,118			4,377			6,495
	Total LC portion	LC											0
	Total FC + LC *f						2,118			4,377			6,495
Total FC + LC *a						2,118			4,377			6,495	
Maintenance workshop improvement	Capital cost (direct)	FC			780			2,751					3,531
	Capital cost (direct)	LC											0
	Total capital cost (direct) *a				780			2,751					3,531
	Engineering cost *b	FC			69								69
	Engineering cost *c	LC											0
	Administration	FC											0
	Administration *d	LC											0
	Physical conting. *e	FC			39			138					177
	Physical conting. *e	LC											0
	O/M cost	FC			39	39	40	178	180	181	183	185	1,025
	O/M cost	LC			1,093	1,118	1,144	1,243	1,271	1,301	1,331	1,361	9,862
	Total FC portion	FC			927	39	40	3,067	180	181	183	185	4,802
	Total LC portion	LC			1,093	1,118	1,144	1,243	1,271	1,301	1,331	1,361	9,862
	Total FC + LC *f				969	82	84	3,115	226	231	234	237	5,181
Total FC + LC *a				2,020	1,158	1,184	4,310	1,451	1,482	1,514	1,546	14,664	
Construction of new site	Capital cost (direct)	FC					3,987	817		2,960	9	167	7,940
	Capital cost (direct)	LC					4,881			2,622			7,503
	Total capital cost (direct) *a						8,868	817		5,582	9	167	15,443
	Engineering cost *b	FC		27	103	43	116	66	4	33			390
	Engineering cost *c	LC		14	54	21	34	32	2	36			192
	Administration	FC		14	62	26	69	40	3	21			236
	Administration *d	LC		21	80	32	50	48	4	54			289
	Physical conting. *e	FC					388	41		283	0	8	721
	Physical conting. *e	LC					488			262			750
	O/M cost	FC						474	479	484	489	494	2,419
	O/M cost	LC						1,059	1,083	1,107	1,121	1,146	5,516
	Total FC portion	FC		41	165	69	4,560	1,439	487	3,780	498	669	11,706
	Total LC portion	LC		35	134	53	5,453	1,139	1,089	4,082	1,121	1,146	14,250
	Total FC + LC *f			42	170	71	4,770	1,482	528	3,937	541	713	12,234
Total FC + LC *a			75	299	121	10,013	2,577	1,575	7,862	1,619	1,815	25,956	
Construction of New Guanabacoa	Capital cost (direct)	FC			7,163		3	3,854		76	3		11,100
	Capital cost (direct)	LC			3,663			1,644					5,307
	Total capital cost (direct) *a				10,826		3	5,498		76	3		16,407
	Engineering cost *b	FC			161		99	105					365
	Engineering cost *c	LC			45		35	38					118
	Administration	FC			96		60	64					219
	Administration *d	LC			66		53	57					176
	Physical conting. *e	FC			629		0	376		4	0		1,010
	Physical conting. *e	LC			366			164					531
	O/M cost	FC				150	151	153	155	156	158	159	1,082
	O/M cost	LC				455	466	477	482	493	504	516	3,393
	Total FC portion	FC			8,048	150	314	4,553	155	236	161	159	13,775
	Total LC portion	LC			4,141	455	553	2,380	482	493	504	516	9,525
	Total FC + LC *f				8,207	167	335	4,644	173	255	181	179	14,142
Total FC + LC *a				12,189	605	867	6,933	636	729	666	675	23,300	

Table 25-3 Fund Requirement of Master Plan Components (2005 constant price: 3/4)

			(FC: US\$'000, LC: CUP'000, Total: US\$'000, current prices)											
			2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total	
Extension of Calle 100	Capital cost (direct)	FC			18,209	344			10			10	18,574	
	Capital cost (direct)	LC			7,745								7,745	
	Total capital cost (direct) *a				25,954	344			10			10	26,319	
	Engineering cost *b	FC		102	370								472	
	Engineering cost *c	LC		21	97								118	
	Administration	FC		40	143								183	
	Administration *d	LC		31	147								178	
	Physical conting. *e	FC			1,612	17			1				1	1,630
	Physical conting. *e	LC			774									774
	O/M cost	FC				519	470							989
	O/M cost	LC				934	956							1,890
	Total FC portion	FC		142	20,334	881	470		11				11	21,848
	Total LC portion	LC		52	8,763	934	956							10,706
Total FC + LC *f			144	20,671	917	506		11				11	22,259	
Total FC + LC *a			194	29,097	1,815	1,425		11				11	32,553	
Closure of special period dumping sites	Capital cost (direct)	FC				2,307							2,307	
	Capital cost (direct)	LC				3,623							3,623	
	Total capital cost (direct) *a					5,930							5,930	
	Engineering cost *b	FC		16	4	10	7						38	
	Engineering cost *c	LC		10	2	7	4						24	
	Administration	FC		9	3	6	4						23	
	Administration *d	LC		16	3	10	7						35	
	Physical conting. *e	FC					231						231	
	Physical conting. *e	LC					362						362	
	O/M cost	FC											0	
	O/M cost	LC											0	
	Total FC portion	FC		26	7	2,554	12							2,599
	Total LC portion	LC		26	5	4,002	11							4,044
Total FC + LC *f			27	7	2,708	12							2,754	
Total FC + LC *a			52	13	6,556	23							6,643	
Closure of Calle 100	Capital cost (direct)	FC				2,024							2,024	
	Capital cost (direct)	LC				3,124							3,124	
	Total capital cost (direct) *a					5,148							5,148	
	Engineering cost *b	FC		60	14	65							139	
	Engineering cost *c	LC		37	9	41							86	
	Administration	FC		37	9	40							86	
	Administration *d	LC		55	13	61							130	
	Physical conting. *e	FC					202						202	
	Physical conting. *e	LC					312						312	
	O/M cost	FC											0	
	O/M cost	LC											0	
	Total FC portion	FC		97	24	2,330								2,451
	Total LC portion	LC		92	21	3,538								3,651
Total FC + LC *f			100	25	2,467								2,591	
Total FC + LC *a			189	45	5,868								6,102	
Closure of Extended Area of Calle 100	Capital cost (direct)	FC								219			219	
	Capital cost (direct)	LC								363			363	
	Total capital cost (direct) *a									582			582	
	Engineering cost *b	FC		22	21				10				53	
	Engineering cost *c	LC		14	13				7				34	
	Administration	FC		15	14								30	
	Administration *d	LC		21	19								40	
	Physical conting. *e	FC									22		22	
	Physical conting. *e	LC									36		36	
	O/M cost	FC											0	
	O/M cost	LC											0	
	Total FC portion	FC		38	35				10		241		323	
	Total LC portion	LC		35	32				7		400		474	
Total FC + LC *f			39	36				10		256		341		
Total FC + LC *a			72	67				17		640		797		
Closure of Guanabacoa landfill	Capital cost (direct)	FC						1,247					1,247	
	Capital cost (direct)	LC						1,997					1,997	
	Total capital cost (direct) *a							3,244					3,244	
	Engineering cost *b	FC				21	4	21					46	
	Engineering cost *c	LC				12	3	14					29	
	Administration	FC				12	3	13					28	
	Administration *d	LC				19	6	21					45	
	Physical conting. *e	FC						125					125	
	Physical conting. *e	LC						200					200	
	O/M cost	FC											0	
	O/M cost	LC											0	
	Total FC portion	FC				33	7	1,406					1,447	
	Total LC portion	LC				31	9	2,231					2,270	
Total FC + LC *f					34	8	1,492					1,534		
Total FC + LC *a					64	16	3,637					3,717		

Table 25-4 Fund Requirement of Master Plan Components (2005 constant price: 4/4)

(FC: US\$'000, LC: CUP'000, Total: US\$'000, current prices)

			2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	Total	
Central workshop improvement	Capital cost (direct)	FC			139		4			143	4		291	
	Capital cost (direct)	LC											0	
	Total capital cost (direct) *a				139		4			143	4		291	
	Engineering cost *b	FC											0	
	Engineering cost *c	LC											0	
	Administration	FC											0	
	Administration *d	LC											0	
	Physical conting. *e	FC			7		0			7		0		15
	Physical conting. *e	LC												0
	O/M cost	FC			4		20	19	19	19	20	20	20	141
	O/M cost	LC					275	281	288	294	301	308	315	2,062
	Total FC portion	FC			151		20	23	19	19	170	24	20	446
	Total LC portion	LC					275	281	288	294	301	308	315	2,062
Total FC + LC *f				151		30	34	30	31	181	36	32	525	
Total FC + LC *a				151		295	305	307	314	471	332	335	2,508	
Awareness raising	Capital cost (direct)	FC											0	
	Capital cost (direct)	LC											0	
	Total capital cost (direct) *a												0	
	Engineering cost *b	FC											0	
	Engineering cost *c	LC											0	
	Administration	FC											0	
	Administration *d	LC											0	
	Physical conting. *e	FC											0	
	Physical conting. *e	LC											0	
	O/M cost	FC		371	374	376	254	301	304	100	55	55	55	2,191
	O/M cost	LC		269	274	278	182	222	227	55	17	18	18	1,542
	Total FC portion	FC		371	374	376	254	301	304	100	55	55	55	2,191
	Total LC portion	LC		269	274	278	182	222	227	55	17	18	18	1,542
Total FC + LC *f			382	385	386	261	310	313	102	55	56	56	2,250	
Total FC + LC *a			640	648	654	436	524	532	155	72	73	73	3,733	
Environment monitoring	Capital cost (direct)	FC		87	74	75	38						274	
	Capital cost (direct)	LC		11	29	13	7						59	
	Total capital cost (direct) *a			98	103	88	45						333	
	Engineering cost *b	FC											0	
	Engineering cost *c	LC											0	
	Administration	FC											0	
	Administration *d	LC											0	
	Physical conting. *e	FC		4	4	4	2						14	
	Physical conting. *e	LC		1	1	1	0						3	
	O/M cost	FC		26	35	21	55	31	31	31	31	32	293	
	O/M cost	LC		3	3	4	6	6	6	6	6	6	46	
	Total FC portion	FC		118	113	99	95	31	31	31	31	32	581	
	Total LC portion	LC		14	34	18	13	6	6	6	6	6	108	
Total FC + LC *f			118	114	100	96	31	31	31	32	32	585		
Total FC + LC *a			131	147	118	108	36	37	37	38	38	689		
Total	Capital cost (direct)	FC		87	33,136	9,218	8,430	10,871	4,224	10,744	137	288	77,135	
	Capital cost (direct)	LC		11	11,437	11,225	4,887	3,640	4,525	2,986			38,711	
	Total capital cost (direct) *a			98	44,573	20,443	13,317	14,512	8,749	13,730	137	288	115,845	
	Engineering cost *b	FC		227	878	220	493	192	96	33			2,139	
	Engineering cost *c	LC		95	219	303	76	84	236	36			1,050	
	Administration	FC		115	328	84	137	117	3	21			804	
	Administration *d	LC		144	329	256	115	126	139	54			1,163	
	Physical conting. *e	FC		4	2,629	761	610	790	21	683	7	14	5,710	
	Physical conting. *e	LC		1	1,142	999	488	364	226	299			3,519	
	O/M cost	FC		398	1,089	1,768	1,912	2,051	2,072	2,314	2,090	2,111	15,803	
	O/M cost	LC		272	7,216	9,045	12,464	14,530	14,858	18,696	19,075	19,514	115,671	
	Total FC portion	FC		832	38,059	12,051	11,581	14,021	6,607	13,794	2,234	2,413	101,591	
	Total LC portion	LC		522	20,344	21,828	18,032	18,744	19,984	22,071	19,075	19,514	160,114	
Total FC + LC *f			852	38,841	12,890	12,275	14,742	7,375	14,643	2,967	3,164	107,750		
Total FC + LC *a			1,354	58,403	33,879	29,613	32,765	26,591	35,864	21,309	21,927	261,705		

Price Escalation Index		2006	2007	2008	2009	2010	2011	2012	2013	2014	2015
Escalation rate of US\$	1.0%	1.01	1.02	1.03	1.04	1.05	1.06	1.07	1.08	1.09	1.10
Escalation rate of CUP	2.3%	1.02	1.05	1.07	1.10	1.12	1.15	1.17	1.20	1.23	1.26

*a. FC portion (US\$) and LC portion (CUP) are added up at exchange rate of US\$1=CUP 1

*b. Engineering cost in FC portion will be incurred at the designing stage, which is 2% of the direct capital cost.

*c. Engineering cost in LC portion will be incurred at the designing stage, which is 5% of the direct capital cost.

*d. Administration cost will be incurred during construction/acquisition period, which is 3% of direct capital cost of LC portion.

*e. Physical contingency is 10% of direct construction cost and 5% of direct equipment cost, both for FC and LC portions.

*f. FC portion (US\$) and LC portion (CUP) are added up at exchange rate of US\$1= CUP26

Table 26 Financial Cash Flow of the Master Plan (2005 constant price)

		(FC:US\$ million, LC:CUP million)									
Year		2006	2007	2008	2009	2010	2011	2012	2013	2014	2015
Cost											
Composting	FC	0.0	0.0	0.2	1.9	0.2	0.2	2.4	0.2	0.2	0.2
	LC	0.0	0.0	0.0	2.2	0.7	0.7	3.2	1.4	1.4	1.4
Recycling	FC	0.0	0.0	0.0	2.5	0.0	0.0	1.8	0.1	0.1	0.1
	LC	0.0	0.0	0.0	2.5	1.6	1.6	3.5	3.1	3.1	3.1
Collection & Transportation	FC	0.0	0.0	8.3	0.9	5.4	5.7	0.9	8.3	1.1	1.1
	LC	0.0	0.0	6.5	6.5	7.1	8.6	8.6	9.4	9.4	9.4
Final Disposal	FC	0.0	0.3	27.9	5.8	5.1	7.0	0.6	4.1	0.6	0.8
	LC	0.0	0.2	12.2	8.5	6.5	5.3	1.6	4.4	1.6	1.6
Awareness raising	FC	0.0	0.4	0.4	0.4	0.2	0.3	0.3	0.1	0.1	0.1
	LC	0.0	0.3	0.3	0.3	0.2	0.2	0.2	0.0	0.0	0.0
Environmental monitoring	FC	0.0	0.1	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0
	LC	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
MP Cost Total	FC	0.0	0.8	36.9	11.6	11.0	13.2	6.2	12.7	2.0	2.2
	LC	0.0	0.5	19.0	19.9	16.1	16.4	17.0	18.4	15.5	15.5
Salvage Value	FC	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-21.9
	LC	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-9.7
TOTAL	FC	0.0	0.8	36.9	11.6	11.0	13.2	6.2	12.7	2.0	-19.7
	LC	0.0	0.5	19.0	19.9	16.1	16.4	17.0	18.4	15.5	5.9
Total Cost*		0.0	0.8	37.7	12.3	11.6	13.8	6.8	13.4	2.6	-19.5
Benefit											
Compost Products	LC	0.0	0.0	0.0	0.0	2.5	3.3	3.7	9.8	10.8	11.8
Recycle Products	FC	0.0	0.0	0.0	0.0	0.2	0.2	0.2	0.6	0.7	0.7
	LC	0.0	0.0	0.0	0.0	0.6	0.7	0.9	2.1	2.4	2.8
Tariff Revenue from Inhabitants	FC	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	LC	0.0	5.2	5.6	5.9	6.3	6.7	7.1	7.5	7.8	8.2
Tariff Revenue from Institute	FC	0.0	0.7	0.8	0.8	0.9	0.9	1.0	1.1	1.1	1.2
	LC	0.0	3.6	3.8	4.1	4.4	4.6	4.9	5.2	5.5	5.7
Tipping Fee Revenue	FC	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	LC	0.0	0.0	0.0	0.0	0.2	0.2	0.2	0.2	0.2	0.3
Total	FC	0.0	0.7	0.8	0.8	1.1	1.2	1.2	1.7	1.8	1.9
	LC	0.0	8.8	9.4	10.1	13.9	15.6	16.8	24.7	26.8	28.8
Total Benefit*		0.0	1.1	1.1	1.2	1.6	1.8	1.9	2.6	2.8	3.0
Balance		0.0	0.2	-36.5	-11.1	-10.0	-12.1	-4.9	-10.8	0.2	22.5
Base Case											
O&M Cost	FC	0.0	0.4	1.1	1.7	1.8	1.9	1.9	2.1	1.9	1.9
	LC	0.0	0.3	6.7	8.3	11.1	12.7	12.7	15.6	15.5	15.5
Balance	FC	0.0	0.3	-0.3	-0.9	-0.8	-0.8	-0.7	-0.5	-0.1	-0.0
	LC	0.0	8.5	2.7	1.8	2.8	2.9	4.1	9.1	11.3	13.2
		0.0	0.7	-0.2	-0.8	-0.6	-0.7	-0.5	-0.1	0.3	0.5
Alternative Case											
Balance	FC	0.0	-0.1	-36.2	-10.7	-10.0	-12.1	-4.9	-11.1	-0.3	21.6
	LC	0.0	8.3	-9.6	-9.9	-2.2	-0.8	-0.2	6.3	11.3	22.9
		0.0	0.2	-36.5	-11.1	-10.0	-12.1	-4.9	-10.8	0.2	22.5

E. Industrial and Medical Waste:

E1 Questionnaire Survey for Industries

E1 QUESTIONNAIRE SURVEY TO INDUSTRIES

1. Objective of Survey

To collect information about the existing operational conditions and opinions on the industrial solid waste management system generated in the factory in Havana City and problem issues, and future plan for treatment of hazardous waste.

2. Area Subject to Survey and Number of Sampling

15 factories located inside of Havana City

3. Method of Survey

Data collection with questionnaire, by means of direct interview by visit or indirect inquiry by mailing to sample industries

4. Main Items Included in Questionnaire

Subject	Questions
General conditions	Name of factory, Products of factory, Number of workers, Constructed/Established year, etc.
Conditions of waste	Waste generation, Quantity, Type of waste, Type of bins/containers, Hazardous waste, etc.
Collection of waste	Times of waste collection per week, Segregation and separate collection, Requirement of collection and disposal, etc.
Recycling	Items of recycling,
Disposal and dumping of waste	Name of dumping site, Operation of disposal, In charge of transportation and dumping, Methodology of treatment, Monitoring, Waste treatment system, etc.
Future Plan	Future plan, etc.

5. Analysis and Data Processing

Being based on the results of the answered questionnaires:

- To analyze the existing conditions of industrial waste disposal and treatment
- To clarify issues related to industrial waste and environmental conditions
- To statistically edit the survey data, especially for generated hazardous waste

6. Survey Duration: 10 days

This survey was conducted in the last ten days of March, 2004

7. Output

- Survey Reports
- Filled questionnaires

Date: _____

QUESTIONNAIRE TO FACTORIES

1. Name of factory: _____

2. Number of workers: _____

3. Address of Factory: _____

4. Constructed/Established year: _____

5. Name of products: _____

6. Production:

	Name	
(1)	_____	unit: _____ (___/month_)
(2)	_____	unit: _____ (___/month_)
(3)	_____	unit: _____ (___/month_)

7. Volume of generated waste in factory:

7.1 Municipal solid waste _____ m³/day

7.2 Industrial waste (A+B) _____ m³/day

-Hazardous waste (A): _____ m³/day

-Non-hazardous waste (B): _____ m³/day

8. Type of hazardous waste: _____

9. Is there hazardous waste treatment facilities in your factory ?

9.1 Yes 9.2 No

10. For those who answered “Yes”, please answer following

10.1 Type and name of facilities: _____

10.2 Capacity: _____ kg/day

10.3 Year of Construction/Installation: _____

11. Number of bins and containers installed in factory

11.1 Bins: _____ Nos. Size: _____

11.2 Containers: _____ Nos. Size: _____

12. Times of waste collection per week: _____ Times

13. Do you carry out segregation and separate collection for waste ?

13.1 Yes 13.2 No

14. For those who answered “Yes”, please describe categories:

Example; Steel, woods, Glass, Aluminum, Copper,

15. Do you have a contract of waste transportation to dumping site and/or treatment of waste?

15.1 Yes 15.2 No

16. For those who answered “Yes”, please describe following:

16.1 Name of operation companies: _____

16.2 Scope of contract: _____

16.3 Amount (\$) _____ /month

17. Dumping site of industrial waste and municipal solid waste: please select the location:

- 1) Calle 100
- 2) Guanabacoa
- 3) Ocho Vias
- 4) Municipal landfill site
- 5) Provincial landfill site
- 6) Others

18. Volume of solid waste dumping to landfill site: _____ m³/week

19. Times of dumping to landfill site per week: _____ Times

20. Do you want equipment or facilities for the treatment of industrial waste?

20.1 Yes 20.2 No

21. For those who answered “Yes”, please describe required items below:

22. Do you have plans of construction/ installation of waste treatment facilities?

22.1 Yes 22.2 No

23. For those who answered “Yes”, please describe following:

23.1 Proposed year: _____

23.2 Name of facilities: _____

24. Do you have willing to carry out monitoring of hazardous waste?

24.1 Yes 24.2 No

25. How do you think treatment of hazardous waste in future?

25.1 Recommend self treatment system by each factory

25.2 Would like to request other company

25.3 Recommend construction of centralized plant for treatment

25.4 No idea

26. Do you want to preserve environment in Havana City area as it is?

26.1 Yes, never change by any development

26.2 Yes, but some developments to improve residents’ life are acceptable.

26.3 No, I do not mind any development is done.

26.4 No, but if living and natural environment can be kept as it is or better.

27. If you have comments, opinions and troubles concerning the industrial waste management, please describe below:

Thank you very much for your kind cooperation.

Survey Data of Questionnaire for Industries

Survey Data of Industries (1/4)

No.	Enterprises	Solid Waste	Quantity	Unit	Reuse	Quantity	Unit
1	<i>"El Lucero" Pasteurizing Factory</i>	Polyethylene Broken Boxes	30 300	t u	NR (contaminated with milk) Recycling	300	u
2	<i>"Beatriz" Pasteurizing Factory</i>	Paper Pots 125 cc Plastic buckets Broken baskets White glass	5,800 3 850 400 30	B Kg/y t	For cereal boxes NR (the raw material enterprise does not collect it, because of the lithography. For yogurt and ice cream pots. Reprocessing Reprocessing	4,385 800 400 30	B t
3	<i>"Havana" Refractory Factory (for firebricks)</i>	Small pieces and sweepings	11,800	t/y	As raw materials for maintenance	11,800	t/y
4	<i>Coppelia Ice cream Factory</i>	Ordinary Paper Cans of 5 gallons Polyethylene Polypropylene bags Jute bags Plastic buckets Large buckets Tops of buckets Egg shells	1,833 437 4,118 2,502 250 32,000 1,100 2,000 0.633	t u t u u u u u t	Raw material Enterprise Raw material Enterprise Raw material Enterprise Raw material Enterprise Raw material Enterprise Raw material Enterprise NR	1,833 437 4,118 2,502 250 32,000 1,100 2,000	t u t u u u u u
5	<i>COLFA</i>	Iron inner part Copper Scrap iron	90 23 290	u/y t/y t/y	For the production of dry and low voltage transformers. As raw materials As raw materials	90 23 290	u/y t/y t/y
6	<i>Suchel Camacho SA</i>	Plastic Flasks Glass Flasks Cardboard Boxes	56 43 25	t/y t/y t/y	As raw materials As raw materials As raw materials	56 43 25	t/y t/y t/y
7	<i>HILATEX Textile Factory</i>	Burlap Scrapings	7.3 10	t/y t/y	It is used in the same enterprise in the maintenance workshops. To manufacture dishcloth, remnant, layettes, etc	7.3 10	t/y t/y
8	<i>Jose Marti Airport</i>	Iron Scraps Paper and Cardboard	21 3	t/y t/y	As raw materials As raw materials	21 3	t/y t/y

Survey Data of Industries (2/4)

No.	Enterprises	Solid Waste	Quantity	Unit	Reuse	Quantity	Unit
9	<i>Electronically Factory</i>	Steel, tin. Plastic waste Cardboard and paper	38 7	t/y t/y	As raw materials It is reinserted in the production process As raw materials	38 7	t/y t/y
10	<i>LABIOFAM (PU 1-2 and 5)</i>	Plastic divisions Cardboard divisions Defective pots and burrs Food waste	8,640 8,640 172.8 5,184	cb/y cb/y t/y t/y	Division of pots For file manufacturing It is reinserted in the production process Food supplement	8,640 8,640 172.8 5,184	cb/y cb/y t/y t/y
11	<i>Santiago de las Vegas Slaughterhouse of poultry</i>	Feather, entrails, heads	50	t/y	Production of flour for animal consumption	50	t/y
12	<i>"Villena Revolucion" Pigs Raising Farm</i>	Offal of agriculture (straw, pods, etc) Animal manure	60 1,200	t/y t/y	Ground, it is part of the fodder for animal consumption For the production of Compost and vermin production	60 1,200	t/y t/y
13	<i>"La Estrella" Candies Factory</i>	Cardboard Boxes Sweepings	1,200 2,000	u t/y	As raw materials For animal consumption	1,120 2,000	u t/y
14	<i>Managua Cheese Factory</i>	Soy bean shell (20.1 t)			For animal Consumption (20.1 t)		
15	<i>"8 de octubre" Rural Junior High School</i>	Crops waste, leaves, cattle manure, waste in general	350	m ³ /y	Organic fertilizer	350	m ³ /y
16	<i>"La Vaquita" Veal Factory</i>	Small pieces of leather for shoe making Shavings of leather for shoe making	4,000 80	m ² /y t/y	To manufacture the gloves used for cutting cane For conglomerates		
17	<i>Antillana de Acero Factory (Steel factory)</i>	Fragmented silica sand. Metal scraps Shells from the mill	720 1,055 100	t/y t/y t/y	In other activities that do not require special granulometry For steel melting Other uses	720 1,055 100	t/y t/y t/y
18	<i>"Guido Lopez" Beer Enterprise</i>	Bran	1,926	t/y	For animal consumption	1,926	t/y
19	<i>Havana Complex for Dairy Products</i>	Soy beans skin Metal scrap Reusable Plastics	95.6 136 31.5	t/y t/y t/y	For animal consumption As raw materials As raw materials for the production of high demand products.	95.6 136 31.5	t/y t/y t/y

Survey Data of Industries (3/4)

No.	Enterprises	Solid Waste	Quantity	Unit	Reuse	Quantity	Unit
20	<i>“9 de Abril” Textile Factory</i>	Textile remnant and cotton sweepings	1,102	kg/y	For the production of mattresses	1,102	kg/y
		Steel scraps	1,557	t/y	As raw materials	1,557	kg/y
21	<i>“Aulet y Casals” Joints Factory</i>	Steel scraps	340	t/y	As raw materials	245	t/y
22	<i>Regil Roasting Factory</i>	Shells	235	t/y	For animal consumption	200	t/y
23	<i>“Diaz Machado” Fusing Factory. (Metal fittings plant)</i>	Scunps, defective parts, metal chips, shavings, and strapping scraps.	400	t/y	As raw materials	400	t/y
24	<i>Factory for Guarina Ice creams</i>	Boxes 125 cc	500	u/y	As raw materials	480	u/y
		Boxes 250 cc	900	u/y	As raw materials	850	u/y
		Large buckets of 5.5	1,400	u/y	As raw materials	1,150	u/y
		Pots of 2 L	30	u/y	As raw materials	25	u/y
		Pots of ½	130	u/y	As raw materials	130	u/y
25	<i>“La Lechera” Pasteurizing Factory</i>	Sweepings	3.32	t	For animal consumption 3.32 t	3.32	t
26	<i>INDAL</i>	Fish offal	203	t/y	For animal consumption	203	t/y
27	<i>Glass Factory</i>	Broken glass	1,200	t/y	It is reinserted in the production process	1,080	t/y
		Mold of rejected cast iron	7		It is given to Vulcano forging center	7	t/y
		Iron scraps		t/y			
		Remnants of cardboard and packing	250	t/y	As raw materials	250	t/y
		Sand rejected by the sieve	App 5	t/y	As raw materials	4.75	t/y
28	<i>COPEXTEL</i>		35	t/y	To build houses for the workers.	33.5	t/y
		Plastics	7	t/y	They are recycled at the same enterprise	7	t/y
		Ferrous metals	22	t/y	As raw materials	22	t/y
		Non-ferrous metals	11	t/y	As raw materials	11	t/y
		Paper and cardboard	3	t/y	As raw materials	3	t/y
29	<i>“Chenard Piña” Factory</i>	Sweepings for the production of powder soft drinks, jellies, custards, chocolate, small cakes, and flavored desserts (all in powder)	1,040	t/y	As raw materials	1,040	t/y

Survey Data of Industries (4/4)

No.	Enterprises	Solid Waste	Quantity	Unit	Reuse	Quantity	Unit
30	<i>"J.A. Echeverria" Cereals Factory</i>	Bran, thick and fine bran of wheat, also wheat germ derived from the production of wheat flour	36,000	t/y	Fodder and human consumption	36,000	t/y
31	<i>"Nico Lopez" Refinery</i>	The recovered slop in the treatment system	14	t	Mainly, it is reinserted in the distillation plant		
32	<i>PRODAL Enterprise</i>	Solid waste from the production	576	t/y	Animal consumption	576	t/y
33	<i>T. Lima Grains Mill</i>	Bran, thick and fine bran of wheat, also wheat germ derived from the production of wheat flour	9,500	t/y	Fodder and human consumption	9,500	t/y
34	<i>Roasting Factory for Pilon Coffee</i>	Shells	1,050	t/y	For animal consumption	970	t/y

Data Source: CITMA 2003

Remarks:

Kg: kilogram

t/y: tons per year

u: units

t: ton

B: bag

cb/y: cardboards per year

NR: not reused

u/y: unit per year

Table. The Result of QA Survey (1/4)

No.	Item	Answer				
1	Name	Mario Muñoz Pharmaceuticals Lab	La Estrella Candy Factory	PRODAL Enterprise	INDAL	Habana Dairy Complex
2	Total staff	96	427	1 000	300	1 124
3	Address of the factory	Hacendado #1, Habana Vieja	Calle Vega y Via Blanca, Cerro	Pereira y Litoral s/n . Regla	Calle Hacendado # 55, H. Vieja	Ave Monumental Km 23 1/2, Cotorro
4	Construction year	1939		1964	1964	1974
5	Type of product(s)	Natural medicine and medicine obtained by synthesis	Chocolates, candies, cookies (1 643 ton/y)	Sausages and canned chicken	Fish sausages and canned food	Natural yogurt, milk, ice cream, cheese
	a) Yield	See remarks	all mentioned above (149.36 ton /m)	all mentioned above (496 t/m)	canned food (1 700 t/y)	cheese (1 200 t/y) ice cream (1 480 000 gallons/year) milk (7 988 t/y) yogurt (2 733 t/y)
6	Amount of generated waste					
	a) Urban solid waste in m3/day	0.048	0.21	0.5	0.15	0.56
	b) Industrial waste in m3/day	-2	0.7			0.3
7	Type of hazardous waste	NA	NA	NA	NA	NA
8	No. of Containers and Ampirolls					
	a) Containers (of 0.8 m3)	2	2	2	2	3
	b) Ampirolls					
9	Frequency of collection in a week	3 times	2 times (done by the enterprise)	2 times (done by the enterprise)	2 times (done by the enterprise)	2 times (done by the enterprise)
10	Segregation of waste for collection	Yes	Yes	Yes	Yes	Yes
	a) Examples	Glass, cardboard, paper, polyethylene bags	Cardboard boxes	Cardboard	Wood	Plastics, metal scraps
11	Contract for transport to dumping site or waste treatment	Yes	No	No	No	No
	a) Name of the enterprise	Aurora				
	b) Scope of the contract	Collect and discharge at dumping site				
	c) Monthly cost	120 Cuban pesos				
12	Dumping site used for industrial waste and USW	Ocho Vias	Ocho Vias	Ocho Vias	Ocho Vias	Ocho Vias
13	Amount of waste carried to dumping site in m3 per week	0.3	1.3	3	1	5
14	Frequency of discharge at the dumping site per week	3 times	2 times	2 times	2 times	2 times
15	Need for treatment equipment or facilities as to industrial waste	No	No	No	No	No
	a) Name the equipment					
16	Plans of building or installing a new treatment plant	No	No	No	No	No
	a) Mention date					
17	waste	Yes	Yes	Yes	Yes	Yes
	In your opinion, how the hazardous waste management should be done	I recommend the implementation of treatment systems by every factory	I recommend the implementation of treatment systems by every factory	I recommend the implementation of treatment systems by every factory	I recommend the implementation of treatment systems by every factory	I recommend the implementation of treatment systems by every factory
18	Do you wish that the capital's current environmental conditions continue?	No, but I would only agree to accept changes that do not harm the environment	No, but I would only agree to accept changes that do not harm the environment	No, but I would only agree to accept changes that do not harm the environment	No, but I would only agree to accept changes that do not harm the environment	No, but I would only agree to accept changes that do not harm the environment
19	Remarks:	Natural products: Vimang - 1.5 -2 ton/month Propolis extract - 100-150kg/month Aloe extract - 2 500 l/month Aloe shampoo- 20 000 containers of 200 ml/month	Reuse of waste: cardboard boxes-1 200 for raw material sweepings- 2 000 t /y for animal consumption	Of the waste generated by the production of canned chicken and sausages 270 t/y are devoted to animal foods. * The non hazardous waste is reused in the production of animal foods.	203 t/y of fish waste is used in the production of animal foods	Reuse of waste: soy shells - 95.6 t/y for animal foods metal scraps- 136 t/y for raw materials recyclable plastic- 31.5 t/y for raw material

RME : Law materials Recovery Enterprise

Table. The Result of QA Survey (2/4)

Item	Answer				
	Beatriz Pasteurizing Factory	El Lucero Pasteurizing Factory	Guarina Ice creams Factory	Coppelia Ice creams Factory	Suchel Camacho
Name					
Total staff	220	360	120	180	240
Address of the factory	Sta. Beatriz # 71 e/1ra y 2da, Vibora, Arroyo Naranjo	Carretera Lucero # 35, Calzada Managua, Arroyo Naranjo	Loncho 54, esquina Via Blanca, H. Vieja	ve. Independencia, Km 7 1/2 , Boyeros	Boyeros
Construction year			1933		
Type of products)	Natural yogurt, soy yogurt, goat's milk	Concentrated milk, fresh cream, soy milk	Ice cream production	Ice creams	Perfumes, toilet soap, detergent
a) Yield	Natural yogurt - 3 612 t/y Soy yogurt - 5 800 t/y Goat's milk - 60 t/y	Concentrated milk- 14 130 t/y Fresh cream- 20t/y milk- 860 t/y Soy	Ice creams - 700 gallons per year	Ice creams - 980 gallons per day	Total production - 114.6 t/y
Amount of generated waste					
a) Urban solid waste in m3/day	0.11	0.18	0.06	0.09	0.12
b) Industrial waste in m3/day					0.45
Type of hazardous waste	NA	NA	NA	NA	NA
No. of Containers and Amplirolls					
a) Containers (of 0.8 m3)	2	2	2	2	3
b) Amplirolls					
Frequency of collection in a week	1 time (done by the enterprise)	2 times (done by the enterprise)	1 time	1 time	2 times
Segregation of waste for collection	Yes	Yes	Yes	Yes	Yes
a) Examples	Glass, paper, plastic buckets	Broken plastic boxes	Boxes and plastic pots	Paper, cans, sacks, plastic buckets	Glass, plastics, boxes, cardboards
Contract for transport to dumping site or waste treatment	No	No	No	No	No
a) Name of the enterprise					
b) Scope of the contract					
c) Monthly cost					
Dumping site used for industrial waste and USW	Ocho Vias	Ocho Vias	Ocho Vias	Ocho Vias	Ocho Vias
Amount of waste carried to dumping site in m3 per week	0.11	1.08	0.36	0.54	3.4
Frequency of discharge at the dumping site per week	1 time	2 times	1 time	1 time	2 times
Need for treatment equipment or facilities as to industrial waste	No	No	No	No	No
a) Name the equipment					
Plans of building or installing a new treatment plant	No	No	No	No	No
a) Mention date					
Will to monitor hazardous and infectious waste	Yes	Yes	Yes	Yes	Yes
In your opinion, how the hazardous waste management should be done	I recommend the implementation of the treatment system by every factory	I recommend the implementation of the treatment system by every factory	I recommend the implementation of the treatment system by every factory	I recommend the implementation of the treatment system by every factory	I recommend the implementation of the treatment system by every factory
Do you wish that the capital's current environmental conditions continue?	No, but I would only agree to accept changes that do not harm the environment	No, but I would only agree to accept cahnges that do not harm the environment	No, but I would only agree to accept changes that do not harm the environment	No, but I would only agree to accept changes that do not harm the environment	No, but I would only agree to accept the ones that do not harm the environment
Remarks:	Reuse of waste: Paper - 5 800 sacks for cereal boxes Plastic buckets - 850 for yogurt and ice cream pots White glass - 30 t for RME. 125 cc pots - 3kg/y are not reusable	Reuse of waste: 300 boxes per year are devoted to recycling activities * Industrial waste is reused in the production process	Reuse of waste: 125 cc boxes - 500 u/y for RME 250 cc boxes - 900 u/y for RME 1 liter pots - 300 u/y for RME 1/2 liter pots - 1 30 u/y for RME *	Reuse of waste: Paper - 1 833 t/y for RME 5 gallons cans - 437 u/y for RME Polypropylene sacks - 250 u/y for RME Plastic buckets 32 000 u/y for RME	Reuse of the waste: Plastic containers - 56 t/y for RME Glass containers - 43 t/y for RME Cardboard boxes - 25 t/y for RME

Table. The Result of QA Survey (3/4)

No.	Item	Answer			
		Guido Pérez brewery	Antillana de Acero(Steelworks)	Nico López Refinery	Power Station Maintenance Company
1	Name				
2	Total staff	520	1167	700	320
3	Address of the factory	Carretera Central, km 18, Cotorro	20 # 10522, Cotorro	Via Blanca y Belot	Calle 100 # 69, Lisa
4	Construction year	1948	1961	1955	
5	Type of products)	Beer	Steelworks	Oil by-products(gasoline,LP6, Asphalt, Kerosene, Diesel)	Manufacture of Air-conditioning systems, repair of electric fans, repair of high-voltage transformers, manufacture of parts
	a) Yield	1524190 packs/year	plain and corrugated bars: 5833.3 kg/month sheets: 1666666 kg/m reinforcement beams: 1833333kg/m	1449692.83 m³/y total production	
6	Amount of generated waste				
	a) Urban solid waste in m3/day	0.26	0.58	0.35	0.16
	b) Industrial waste in m3/day				
7	Type of hazardous waste	NA	NA	NA	NA
8	No. of Containers and Amplirolls				
	a) Containers (of 0.8 m3)	2	5	3	2
	b) Amplirolls		2		
9	Frequency of collection in a week	1 time	2 times (done by the enterprise)	2 times (done by the enterprise)	2 times
10	Segregation of waste for collection	Yes	Yes	Yes	Yes
	a) Examples	Glass	steel scrap)	Paper, Slop	
11	Contract for transport to dumping site or waste treatment	No	No	No	No
	a) Name of the enterprise				
	b) Scope of the contract				
	c) Monthly cost				
12	Dumping site used for industrial waste and USW	Ocho Vias	Ocho Vias	Ocho Vias	Ocho Vias
13	Amount of waste carried to dumping site in m3 per week	1.56	3.48	2.1	1
14	Frequency of discharge at the dumping site per week	1 time	2 times	2 times	2 times
15	Need for treatment equipment or facilities as to industrial waste	No	No	No	No
	a) Name the equipment				
16	Plans of building or installing a new treatment plant	No	No	No	No
	a) Mention date				
17	Will to monitor hazardous and infectious waste	Yes	Yes	Yes	Yes
18	In your opinion, how the hazardous waste management should be done	I recommend the implementation of the treatment system by every factory	I recommend the implementation of the treatment system by every factory	I recommend the implementation of the treatment system by every factory	I recommend the implementation of the treatment system by every factory
	Do you wish that the capital's current environmental conditions continue?	No, but I would only agree to accept changes that do not harm the environment	No, but I would only agree to accept changes that do not harm the environment	No, but I would only agree to accept changes that do not harm the environment	No, but I would only agree to accept changes that do not harm the environment
19	Remarks:				
20	Reuse of waste:	Reuse of waste: use 1926 mt/y bran for animal feed	Reuse of waste: silica sand for other works-720 t/y scrap to recycle 1055 t/y filings for other uses 100 t/y	Reuse of waste: The solid waste similar to the domestic waste are disposed with the company's trucks Slop recovered at the treatment systems-14 t/m to inject to distillation plant	Reuse of waste:

Table. The Result of QA Survey (4/4)

No.	Item	Answer				
		Pilón Coffee Roasting Factory	El Lucero Pasteurizing Factory	Guarina Ice creams Factory	Coppelia Ice creams Factory	Suchel Camacho
1	Name					
2	Total staff	80	360	120	180	240
3	Address of the factory	26 y 51, Plaza	Carretera Lucero # 35, Calzada Managua, Arroyo Naranjo	Concho 54, esquina Via Blanca, Vieja	Ave. Independencia, Km 7 1/2, Boyeros	Boyeros
4	Construction year	1950		1933		
5	Type of products)	Coffee	Concentrated milk, fresh cream, soy milk	Icecream production	Ice creams	Perfumes, toilet soap, detergent
	a) Yield	Coffee - 604.7 t/y	Concentrated milk- 14 130 t/y Fresh cream- 20t/y Soy milk- 860 t/y	Ice creams - 700 gallons per year	Ice creams - 980 gallons per day	Total production - 114.6 t/y
6	Amount of generated waste					
	a) Urban solid waste in m3/day	0.04	0.18	0.06	0.09	0.12
	b) Industrial waste in m3/day					0.45
7	Type of hazardous waste	NA	NA	NA	NA	NA
8	No. of Containers and Amplirolls					
	a) Containers (of 0.8 m3)	2	2	2	2	3
	b) Amplirolls					
9	Frequency of collection in a week	1 time (done by the enterprise)	2 times (done by the enterprise)	1 time	1 time	2 times
10	Segregation of waste for collection	Yes	Yes	Yes	Yes	Yes
	a) Examples	Glass, paper, plastic buckets	Broken plastic boxes	Boxes and plastic pots	Paper, cans, sacks, plastic buckets	Glass, plastics, boxes, cardboards
11	Contract for transport to dumping site or waste treatment	No	No	No	No	No
	a) Name of the enterprise					
	b) Scope of the contract					
	c) Monthly cost					
12	Dumping site used for industrial waste and USW	Ocho Vias	Ocho Vias	Ocho Vias	Ocho Vias	Ocho Vias
13	Amount of waste carried to dumping site in m3 per week	0.11	1.08	0.36	0.54	3.4
14	Frequency of discharge at the dumping site per week	1 time	2 times	1 time	1 time	2 times
15	Need for treatment equipment or facilities as to industrial waste	No	No	No	No	No
	a) Name the equipment					
16	Plans of building or installing a new treatment plant	No	No	No	No	No
	a) Mention date					
17	Will to monitor hazardous and infectious waste	Yes	Yes	Yes	Yes	Yes
18	In your opinion, how the hazardous waste management should be done	I recommend the implementation of the treatment system by every factory	I recommend the implementation of the treatment system by every factory	I recommend the implementation of the treatment system by every factory	I recommend the implementation of the treatment system by every factory	I recommend the implementation of the treatment system by every factory
	Do you wish that the capital's current environmental conditions continue?	No, but I would only agree to accept changes that do not harm the environment	No, but I would only agree to accept changes that do not harm the environment	No, but I would only agree to accept changes that do not harm the environment	No, but I would only agree to accept changes that do not harm the environment	No, but I would only agree to accept the ones that do not harm the environment
19	Remarks:	Reuse of waste: Paper - 5 800 sacks for cereal boxes Plastic buckets - 850 for yogurt and ice cream pots White glass - 30 t for RME. 125 cc pots - 3kg/y are not reusable	Reuse of waste: 300 boxes per year are devoted to recycling activities * Industrial waste is reused in the production process	Reuse of waste: 125 cc boxes - 500 u/y for RME 250 cc boxes - 900 u/y for RME 1 liter pots - 300 u/y for RME 1/2 liter pots - 1 30 u/y for RME *	Reuse of waste: Paper - 1 833 t/y for RME 5 gallons cans - 437 u/y for RME Polypropylene sacks - 250 u/y for RME Plastic buckets 32 000 u/y for RME	Reuse of the waste: Plastic containers - 56 t/y for RME Glass containers - 43 t/y for RME Cardboard boxes - 25 t/y for RME

E. Industrial and Medical Waste:

E2 Questionnaire Survey for Hospitals

E2 QUESTIONNAIRE SURVEY TO HOSPITAL

1. Objective of Survey

To collect information about the existing conditions and opinions on the medical solid waste management system in hospitals in Havana City and problem issues, and future plan for treatment of generated waste in hospitals.

2. Area Subject to Survey and Number of Sampling

5 hospitals located inside of Havana City

3. Method of Survey

Data collection with questionnaire, by means of direct interview by visit or indirect inquiry by mailing to sample hospitals

4. Main Items Included in Questionnaire

Subject	Questions
General conditions	Name of hospital, Number of beds, Number of doctors and staff, Constructed/Established year, etc.
Conditions of waste	Waste generation, Quantity, Type of waste, Number and type of incinerators, Number of bins/containers, etc.
Collection of waste	Times of waste collection per week, Segregation and separate collection, Operation company (organization), Necessity of the segregation, etc.
Recycling	Items of recycling,
Disposal and dumping of waste	Name of dumping site, Operation of disposal, In charge of transportation and dumping, Methodology of treatment, Monitoring, Waste treatment system, etc.
Future Plan	Future plan, etc.

5. Analysis and Data Processing

Being based on the results of the answered questionnaires:

- To analyze the existing conditions of medical waste disposal and treatment
- To clarify issues related to medical waste and environmental conditions
- To statistically edit the survey data, especially for generated hazardous waste

6. Survey Duration

This survey was conducted in the last ten days of March, 2004.

7. Output

- Survey Reports
- Filled questionnaires

Date: _____

QUESTIONNAIRE TO HOSPITALS

1. Name of hospital: _____

2. Number of beds: _____

3. Number of doctors and staff: _____

4. Constructed/Established year: _____

5. Type of hospital: _____

6. Volume of generated waste in hospital (total =a+b):

6.1 Municipal solid waste (a): _____ m³/day

6.2 Medical waste (b): _____ m³/day

(Breakdown) :

- Hazardous/ infectious waste: _____ m³/day

- Non Hazardous/ infectious waste: _____ m³/day

- Non flammable waste: _____ m³/day

7. Is there incinerator in your hospital?

7.1 Yes 7.2 No

8. For those who answered “Yes”, please answer following:

Number: _____ set

Model: _____

Capacity: _____ kg/day

Year of Construction/Installation: _____

9. Number of bins and containers

Bins: _____ Nos.

Containers (for medical waste): _____ Nos.

10. Times of waste collection per week: _____ Times

11. Do you carry out segregation and separate collection for medical waste?

11.1 Yes 11.2 No

12. For those who answered “Yes”, please describe categories:

Example: Example; syringe, clothes, infectious waste, chemicals, bottles, glass

13. Do you have a contract of waste transportation to dumping site and/or treatment of waste?

13.1 Yes 13.2 No

14. For those who answered “Yes”, please describe following:

14.1 Name of operation companies: _____

14.2 Scope of contract: _____

14.3 Amount (\$) _____ /month

15. Do you carry out treatment of hazardous/infectious waste?

15.1 Yes 15.2 No

16. For those who answered “Yes”, please describe methodology

17. Do you have a contract of waste transportation and /or treatment of waste?

17.1 Yes 17.2 No

18. For those who answered “Yes”, please answer following:

Name of Operation Company: _____

Scope of contract: _____

Amount (\$): _____/month

19. Dumping site of medical waste and municipal solid waste, please select the location:

- 1) Calle 100
- 2) Guanabacoa
- 3) Ocho Vias
- 4) Municipal landfill
- 5) Provincial landfill
- 6) Others

20. Volume of solid waste dumping to landfill site: _____ m³/day

Number of Bin: _____ Nos.

21. Times of dumping to landfill site per week: _____ Times

22. Do you want equipment or facilities for treatment of medical waste?

22.1 Yes 22.2 No

23. For those who answered “Yes”, please describe required items:

24. Do you have plans of construction/ installation of new incinerators for medical waste?

24.1 Yes 24.2 No

25. For those who answered “Yes”, please describe proposed year: _____

26. Do you have willing to carry out monitoring of hazardous/infectious waste?

26.1 Yes 26.2 No

27. How do you think treatment of hazardous/infectious waste?

27.1 Would like to do self treatment in the hospital

27.2 Would like to request other company/organization by contract

27.3 Recommend construction of centralized plant for treatment

27.4 No idea

28. If you have comments, opinion and troubles for the medical waste management, please describe below.

Thank you very much for your kind cooperation.

Survey Data of Questionnaire for Hospitals

Survey Data of Hospital

No	Item	Answers				
1	Name of Hospital	<i>America Arias</i>	<i>Calixto Garcia</i>	<i>Miguel Enrique</i>	<i>Pediatrico de Centro Habana</i>	<i>Salvador Allende</i>
2	No. of beds	273	1 000	897	303	1 085
3	Total staff	380	2 700	1 200	430	1 548
4	Construction year	1892	1896	1891	1895	1886
5	Type of Hospital	Maternity	Clinical and Surgical	Clinical and Surgical	Pedriatic	Teaching Clin. & Surgical
6	Amount of generated waste					
	a) MSW in m ³ /day	1.6	6.7	5.3	1.8	6.5
	b) Medical waste in m ³ /day	0.2	1.6	1.3	0.2	1.62
7	Incinerator at the hospital	Yes	Yes	Yes	Yes	Yes (under repair)
	a) Quantity	1	2	1	1	1
	b) Model	Creole	Creole	Creole	Creole	Creole
	c) Capacity in kg/day	65	300	250	70	300
8	Year of installation	100 years ago	~100 years ago	~1891	~100 years ago	N/A
9	No. of Containers and Amplirolls					
	a) Containers	6	35	6	15	28
	b) Amplirolls					
10	Frequency of collection	Daily	Daily	Daily	Daily	Daily
11	Segregation waste for collection	Yes	Yes	Yes	Yes	Yes
	a) Examples	(all mentioned in the questionnaire)	(all mentioned in the questionnaire)	(all mentioned in the questionnaire)	(all mentioned in the questionnaire)	(all mentioned in the questionnaire)
12	Contract for transport to dumping site or waste treatment	Yes	Yes	Yes	Yes	Yes
	a) Name of the enterprise	<i>Aurora Hospitals</i>	<i>Aurora Hospitals</i>	<i>Aurora Hospitals</i>	<i>Aurora Hospitals</i>	<i>Aurora Hospitals</i>
	b) Scope of the contract	free of charge	free of charge	free of charge	free of charge	free of charge
	c) Monthly cost	free of charge	free of charge	free of charge	free of charge	free of charge
13	Treatment for hazardous and infectious waste	Yes	Yes	Yes	Yes	Yes
	a) Method used	incineration	incineration	incineration	incineration	incineration
14	Contract for waste treatment or transport	Yes	Yes	Yes	Yes	Yes
	a) Name of the enterprise	Communal	Communal	Communal	Communal	Communal
	b) Scope of the contract	free of charge	free of charge	free of charge	free of charge	free of charge

Survey Data of Hospital (Continue)

	c) Monthly cost	free of charge	free of charge	free of charge	free of charge	free of charge
15	Dumping site used for hospital waste and MSW	Calle 100	Calle 100	Calle 100	Calle 100	Calle 100
16	Amount of waste carried to dumping site in m3	1.6	6.7	5,3	1,8	6,5
	a) No. of containers	6	35	6	15	28
17	Frequency of discharge at the dumping site	Daily	Daily	Daily	Daily	-
18	Need for treatment equipment as to hospital waste	Yes	Yes	Yes	Yes	Yes
	a) Name the equipment	Furnace type incinerator	Furnace type incinerator (more modern)	Furnace type incinerator (two chambers)	Furnace type incinerator	Furnace type incinerator (two chambers)
19	Plans of building or installing a new incinerator	Yes	Yes	Yes	Yes	Yes
	a) Mention date	In the next 3-years term	In the next 3-years term	In the next 3-years term	In the next 3-years term	In the next 3-years term
	Will to monitor hazardous and infectious waste	Yes	Yes	Yes	Yes	Yes
20	In your opinion, how the hazardous waste management should be done	*Waste management shall be done every hospitals	*Waste management shall be done every hospitals	*Waste management shall be done every hospitals	*Waste management shall be done every hospitals	*Waste management shall be done every hospitals
21	Remarks:	*Continue improving the hospital waste management program, that includes the systematic monitoring of this activity.	*Continue improving the hospital waste management program, that includes the systematic monitoring of this activity.	*Continue improving the hospital waste management program, that includes the systematic monitoring of this activity.	*Continue improving the hospital waste management program, that includes the systematic monitoring of this activity.	*Continue improving the hospital waste management program, that includes the systematic monitoring of this activity.