

**The Study
for
Development
of
the Rural Electrification Master Plan
in
Zambia

Final Report**

January 2008

Japan International Cooperation Agency
(JICA)

E D
J R
08-002

PREFACE

In response to a request from the Government of the Republic of Zambia, the Government of Japan decided to conduct a study for development of Rural Electrification Master Plan in Zambia and entrusted to the study to the Japan International Cooperation Agency (JICA).

JICA selected and dispatched a study team headed by Mr. Hitoshi Koyabu of Tokyo Electric Power Co., Inc. and consists of Tokyo Electric Power Co., Inc. between May 2006 and January 2008.

The team held discussions with the officials concerned of the Government of Zambia and conducted field surveys at the study area. Upon returning to Japan, the team conducted further studies and prepared this final report.

I hope that this report will contribute to the promotion of this project and to the enhancement of friendly relationship between our two countries.

Finally, I wish to express my sincere appreciation to the officials concerned of the Government of Zambia for their close cooperation extended to the study.

January 2008

Seiichi NAGATSUKA,

Vice President

Japan International Cooperation Agency

January 2008

Mr. Seiichi NAGATSUKA

Vice President

Japan International Cooperation Agency

Tokyo, Japan

Letter of Transmittal

We are pleased to submit to you the report of the Study for Development of Rural Electrification Master Plan in Zambia. The report reflects the comments made by Department of Energy, Ministry of Energy and Water Development in Zambia, Rural Electrification Authority and related institutions in the Republic of Zambia, as well as the advice of the related institutions of the Government of Japan.

This report presents appropriate rural electrification planning and recommendations on power system development from the viewpoint of financial perspective and environmental and social considerations in Zambia. Specifically, we evaluate the financial aspects of the plan on the basis of Least Life Time Costs calculated from the results of our field demand survey, and consider the system reliability and environmental friendliness. We firmly believe that it will help promote the rise in standards of living and industrial development in the country.

We wish to take this opportunity to express our sincere appreciate to the officials concerned of JICA, Ministry of Foreign Affairs and Ministry of Economy, Trade and Industry. We would also like to express our gratitude to the officials concerned of the Government of Zambia, Department of Energy, Ministry of Energy and Water Development in Zambia, Rural Electrification Authority, JICA Zambia Office and Embassy of Japan in the Republic of Zambia for their cooperation and assistance throughout our field survey.

Very truly yours,

Hitoshi KOYABU

Team Leader,

The Develop for Rural Electrification

Master Plan in Zambia

**The Study
for
Development
of
the Rural Electrification Master Plan
in
Zambia**

Final Report

Table of Contents

	Page
Lists of Tables and Figures	
Acronyms	
Chapter 1. Introduction.....	1-1
1.1. Background.....	1-1
1.2. Purpose of the Study	1-1
1.3. Scope of Works.....	1-2
1.4. Study Flow and Schedule.....	1-2
1.5. Study Team	1-2
1.6. Outline of Report	1-3
Chapter 2. General Profile of Zambia.....	2-1
2.1. Land.....	2-1
2.2. Administrative Organization and Local Social Structure.....	2-1
2.3. Population	2-1
2.4. Ethnic Composition, Language and Religion	2-4
2.5. Fertility, Mortality and Life Expectancy	2-4
2.6. Education and Literacy	2-5
2.7. Poverty and Living Standards	2-7
Chapter 3. Current Status of the Power Sector.....	3-1
3.1. Policy and Organizations	3-1
3.1.1. History of Electrification and Policy	3-1
3.1.2. Key Players of the Power Sector	3-2
3.1.3. Acts Related to Rural Electrification	3-3
3.1.4. Policy Related to the Renewable Energy	3-3
3.2. Rural Electrification Fund and Its Management	3-6
3.2.1. Rural Electrification Fund Scheme in Zambia	3-6
3.2.2. REA's Budget	3-7
3.2.3. The Way Forward.....	3-10
3.2.4. Rural Electrification Programme in Kenya.....	3-11
3.3. Power Supply and Demand	3-13
3.3.1. On-grid Power Plants	3-13
3.3.2. Off-grid Power Plants.....	3-15
3.3.3. Supply and Demand Balance (National Grid).....	3-21

3.3.4.	Seasonal and Daily Characteristics of Power Demand.....	3-23
3.3.5.	Power System Loss.....	3-25
3.3.6.	Electricity import/Export.....	3-26
3.4.	Electricity Tariff	3-29
3.4.1.	Electricity Tariff Structure.....	3-29
3.4.2.	Metering and Billing.....	3-32
3.5.	Financial Status of the Power Sector	3-34
3.5.1.	Financial Status of ZESCO.....	3-34
3.5.2.	Financial Status of Other Players in the Sector.....	3-38
Chapter 4.	Current Situation of Rural Society.....	4-1
4.1.	Functions of Rural Growth Centres and Local Communities	4-1
4.2.	Economic Activity in Rural Areas and Expected Effects after Electrification	4-2
4.3.	Rural Electrification and Energy Consumption	4-2
4.4.	Rural Development Plan	4-4
4.5.	Selection of Electrification Target.....	4-4
4.6.	Collected Sample Sizes	4-9
4.7.	Ability and Willingness to Pay.....	4-11
4.7.1.	Methodology to Assess Ability to Pay for Monthly Tariff.....	4-11
4.7.2.	Evaluation of Ability to Pay for Monthly Tariff	4-12
4.7.3.	Methodology to Assess Willingness to Pay	4-16
4.7.4.	Willingness to Pay for Monthly Tariff.....	4-16
4.7.5.	Willingness to Pay for Initial Cost.....	4-18
4.8.	Prioritized Property for Electrification Perceived by Unelectrified Residents	4-20
4.8.1.	Conjoint Analysis Method.....	4-20
4.8.2.	Conjoint Analysis Results.....	4-20
Chapter 5.	Potential Power Demand of Unelectrified RGCs.....	5-1
5.1.	Purposes of Potential Demand Forecast and Data Analysis Flow.....	5-1
5.2.	Estimation of Daily Load Curve/Peak Demand for Each Electrified RGC [Step 1].....	5-2
5.3.	Estimation of Daily Demand for Public Facilities	5-2
5.4.	Estimation of Daily Demand for Business Entities.....	5-6
5.5.	Estimation of Daily Demand for Hammer Mills.....	5-7
5.6.	Estimation of Daily Demand for Households	5-8
5.7.	Estimated Daily Load Curve and Peak Demand for Each Electrified RGC	5-9
5.8.	Selection of a Daily Peak Demand Forecast Method [Step 2]	5-12
5.8.1.	Relationship between Number of Households and Peak Demand of RGC.....	5-12
5.8.2.	Growth of Number of Households in Unelectrified RGCs.....	5-14
5.8.3.	Transition of Household Electrification Rate in Electrified RGCs.....	5-14
5.9.	Number of Hammer Mills in Unelectrified RGCs	5-15
5.9.1.	Other Assumptions for Demand Forecast	5-17
5.9.2.	Daily Peak Demand Forecast Method.....	5-17
5.10.	Forecast of Potential Demand for Unelectrified RGCs [Step 3]	5-19
Chapter 6.	Transmission System Analysis	6-1
6.1.	Purpose of the System Analysis	6-1
6.2.	Current Status of the Power Transmission System in Zambia	6-1
6.3.	Reinforcement Plan of Transmission System in Zambia	6-5
6.4.	Analysis of the Capacity of Transmission System.....	6-11
6.4.1.	Assumptions of the Analysis	6-11
6.4.2.	Transmission System as of 2010.....	6-14

6.4.3.	Transmission System in 2015	6-18
6.4.4.	Transmission system in 2020.....	6-22
6.4.5.	Transmission System in 2030	6-26
6.4.6.	Observations on the Simulation Results	6-30
Chapter 7.	Distribution System Planning	7-1
7.1.	Current Status of Distribution System	7-1
7.2.	Data Collection	7-2
7.2.1.	Specification of distribution system.....	7-2
7.2.2.	Unit Cost of Equipment.....	7-2
7.2.3.	Current Distribution Lines Extension Planning	7-3
7.3.	Review of Existing Distribution Extension Plans	7-9
7.4.	Preliminary Study for Planning Distribution Line Extension	7-9
7.4.1.	Assumptions of Distribution System Expansion Planning	7-9
7.4.2.	Flowchart of the Study	7-10
7.4.3.	Result of the Study	7-11
7.5.	Cost Estimate for Distribution Line Extension	7-17
7.5.1.	Condition.....	7-17
7.5.2.	Result of Cost Estimation	7-18
7.6.	Discussion on Low Cost Electrification	7-47
7.6.1.	Present Situation.....	7-47
7.6.2.	Present Situation.....	7-47
Chapter 8.	Micro-Hydropower Generation Planning.....	8-1
8.1.	Current Status of Micro-Hydropower Development.....	8-1
8.2.	Data Collection	8-1
8.2.1.	Rainfall Data	8-1
8.2.2.	River Flow Data	8-2
8.2.3.	Hydropower Potential for Electrification.....	8-4
8.3.	Review of Existing Hydropower Development Plans.....	8-5
8.3.1.	On-grid Hydropower Development Plans.....	8-5
8.3.2.	Off-grid Hydropower Development Plans	8-9
8.4.	Hydropower Potential Survey	8-12
8.4.1.	Method of Hydropower Potential Estimation.....	8-12
8.4.2.	Results of Hydropower Potential Survey	8-14
Chapter 9.	Solar Power Planning	9-1
9.1.	Current Status of Solar Power	9-1
9.1.1.	Renewable Energy Possibilities for Rural Electrification in Zambia	9-1
9.1.2.	Current Status of Solar Power Electrification	9-1
9.2.	Data Collection	9-7
9.2.1.	Solar Power Generation Potential	9-7
9.3.	Review of Existing Solar Power Development Plans	9-9
9.3.1.	Possibilities and Challenges of the Solar Power Development	9-9
9.3.2.	Lessons Learned from ESCO Projects	9-9
9.3.3.	Lessons Learned from GRZ Projects	9-10
9.4.	Local In-country Survey and Assessment of Existing Solar Power Generation Systems..	9-10
9.4.1.	Solar Energy Resource and Current Status in Zambia	9-10
9.4.2.	Assessment of Previous Solar Power Generation Projects	9-10
9.4.3.	Current Local Procurement Status of Solar Power Generation Systems	9-11
9.4.4.	Essential Agendas for Systematic and Rational Implementation of Solar Power Generation Projects.....	9-11
9.4.5.	Standardization of Implementation Plans, Applied Technologies and Equipment	

Specifications, and Development of Technical Manuals.....	9-12
9.4.6. Establishment of a System and Framework for Operation, Maintenance and Management of Facilities / Services.....	9-12
9.4.7. Policy for Rural Electrification Framework Using Solar Power Generation	9-12
9.4.8. Human Resource Development	9-13
9.4.9. Technical Training Plan.....	9-14
9.4.10. Significance of Solar Power Generation and Conclusion.....	9-14
9.5. Design and Specification of Solar Power Generation Systems	9-14
9.5.1. Design of Solar Power Generation Facilities	9-14
9.5.2. Standard Specification of Solar Power Generation Systems	9-14
9.6. Cost Assessment Method for Solar Power Generation System.....	9-16
Chapter 10. Other Renewable Energies Planning.....	10-1
10.1. Current Status of Other Renewable Energies	10-1
10.1.1. Renewable Energy in Zambia.....	10-1
10.2. Data Collection	10-2
10.2.1. Wind-power Potential.....	10-2
10.2.2. Biomass Potential.....	10-3
10.3. Review of Existing Other Renewable Energies Development Plans.....	10-4
10.3.1. Wind-power.....	10-4
10.3.2. Biomass	10-5
10.3.3. Others.....	10-5
Chapter 11. Environmental and Social Considerations.....	11-1
11.1. National Environmental Strategies and Legislation.....	11-1
11.1.1. National Policy on Environment.....	11-1
11.1.2. The Environmental Protection and Pollution Control Act, 1990.....	11-1
11.1.3. The EIA Regulations, 1997	11-1
11.1.4. Other Regulations.....	11-2
11.2. Environmental Process and Regulations Relating to Rural Electrification	11-2
11.2.1. Environmental Clearance Process.....	11-2
11.2.2. Projects which require Environmental Project Briefs	11-6
11.2.3. Projects that require Environmental Impact Statement (EIS).....	11-7
11.2.4. Review Fees	11-7
11.2.5. ZESCO's Environmental Management.....	11-8
11.2.6. REA's/MEWD's Environmental Management	11-9
11.3. Environmental and Social Considerations to Rural Electrification Master Plan	11-9
11.3.1. Environmental and Social Impact of Master Plan	11-9
11.3.2. Potential Social and Environmental Impacts of Rural Electrification Master Plan Sub-Projects	11-11
11.3.3. Possible Mitigation Measures	11-16
11.3.4. Alternative Rural Electrification Schemes and Their Impacts on Environment	11-18
Chapter 12. Case Studies	12-1
12.1. Distribution Grid Extension	12-1
12.1.1. Selection of the Distribution Line for Case Study.....	12-1
12.1.2. Method of Case Study	12-1
12.1.3. The Results of Site Survey	12-1
12.1.4. Result of Case Study	12-3
12.2. Small Hydropower Plant Development	12-3
12.2.1. Purpose of Case Study.....	12-3
12.2.2. Selection of Case Study Sites	12-4
12.2.3. Result of Case Study 1: Mujila Falls Lower Site	12-5
12.2.4. Result of Case Study 2 : Chilambwe Falls Site	12-23

12.2.5.	Proposed Method of Hydropower Plant Management.....	12-37
12.2.6.	Capacity Development	12-37
12.3.	Preliminary Environmental Impact Assessment (EIA) Activities.....	12-38
12.3.1.	Targets of Studies.....	12-38
12.3.2.	Survey Items.....	12-40
12.3.3.	Methodology	12-40
12.3.4.	Description of the Present Environment	12-41
12.3.5.	Environmental Impacts and Mitigation Measures.....	12-55
12.3.6.	Alternative Electrification Schemes.....	12-63
12.3.7.	Environmental Management Plan Framework	12-65
Chapter 13.	GIS Database Development.....	13-1
13.1.	Introduction of GIS	13-1
13.2.	The GIS Database	13-1
13.2.1.	Experience of Using GIS System.....	13-1
13.2.2.	Existing GIS Data.....	13-1
13.2.3.	Coordinates System of GIS database	13-3
13.2.4.	Newly Acquired GIS Data.....	13-4
13.2.5.	GIS Training.....	13-7
Chapter 14.	Rural Electrification Master Plan by 2030	14-1
14.1.	Purpose of Development of Master Plan and Development Flow.....	14-1
14.2.	Creation of Project Packages and Broken Down to Cases	14-2
14.3.	Selection of Optimal Electrification Method for Each RGC.....	14-3
14.3.1.	Definition of Unit Life Time Cost	14-3
14.3.2.	Results of Selecting Optimal Electrification Method.....	14-4
14.4.	Finalization of Electrification Priority of Project Package	14-5
14.4.1.	Calculation of Financial Indicators	14-5
14.4.2.	Final Electrification Priority of Project Package by Financial Indicators.....	14-6
14.5.	Allocation of Project Packages into Annual Project Phases	14-6
14.6.	Targeting Electrification Rate in 2030	14-23
Chapter 15.	Conclusion and Recommendation	15-1
15.1.	Conclusion	15-1
15.2.	Recommendation	15-2
15.2.1.	Practical Use of Master Plan.....	15-2
15.2.2.	Management of Rural Electrification Fund.....	15-2
15.2.3.	Increase of Electricity Access Rate.....	15-3
15.2.4.	Supporting Sustainable Electrification Business in Rural Area.....	15-3
 Appendices		
Appendix-A	Scope of Work for the Study for Development of the Rural Electrification Master Plan in Zambia	
Appendix-B	Map of Distribution System	
Appendix-C	Single Line Diagram of Distribution System	
Appendix-D	Case study of Distribution Line	
Appendix-E	Current Situation of Diesel Generation in Rural Area	
Appendix-F	FIRR & EIRR Calculation Sample	
Appendix G	Minutes of Meeting for the Rural Electrification Master Plan Project in Zambia	

List of Tables

		Page
Table 1-1	Members of JICA Study Team	1-2
Table 1-2	Schedule of the Study	1-6
Table 2-1	Populations, Area, Density and Growth Rate (2000 Census)	2-2
Table 2-2	Fertility, Crude Birth, Infant Mortality Rates and Life Expectancy at Birth	2-5
Table 2-3	Literacy Rate (5 years old and above)	2-5
Table 2-4	Percentage Distribution of Population by Highest Level of Education Attended.....	2-6
Table 2-5	Poverty Levels	2-7
Table 2-6	Poverty Trends from 1991 to 2004.....	2-8
Table 2-7	Poverty and Household Characteristics in 2004.....	2-9
Table 3-1	REA's Audited Income and Expenditure Account (Jan-Dec 2005)	3-8
Table 3-2	Rural Electrification Projects Approved by REA for Implementation in 2006.....	3-9
Table 3-3	Rural Electrification Projects Approved by REA for Implementation in 2007.....	3-10
Table 3-4	Number of Customers and Electricity Sales (Kenya's REP Scheme)	3-11
Table 3-5	"Profit and Loss Account" and "Assets" of Kenya REP	3-12
Table 3-6	Three Major Hydropower Plants in Zambia	3-13
Table 3-7	ZESCO's Small Hydropower Plants	3-14
Table 3-8	CEC's Gas Turbines	3-15
Table 3-9	ZESCO's Diesel Power Plants	3-16
Table 3-10	ZESCO's Revised Tariff (implemented in October 2007)	3-29
Table 3-11	Summary of ZESCO's Financial Statements.....	3-35
Table 3-12	CEC's Electricity Demand and Sales	3-38
Table 3-13	Summary of CEC's Financial Statements	3-38
Table 4-1	Percentage Distribution of Households by Main Source of Energy for Lighting.....	4-3
Table 4-2	Percentage Distribution of Households by Main Source of Energy for Cooking	4-3
Table 4-3	Unelectrified Rural Growth Centres with the Highest Priority in Each District	4-6
Table 4-4	Electrified Rural Growth Centres for Socio-Economic Survey	4-7
Table 4-5	Sampling Targets and Numbers for Socioeconomic Survey.....	4-8

Table 4-6	Inaccessible RGCs and Different Electrification Status	4-10
Table 4-7	Number of Surveyed RGCs by Province	4-11
Table 4-8	Collected Sample Sizes in Socio-economic Survey	4-11
Table 4-9	Analysis Results of Monthly Balance Sheet	4-14
Table 4-10	Price Categories Used in Double Bound Method for CVM	4-16
Table 4-11	Properties and Levels for Conjoint Analysis	4-20
Table 4-12	Combination of Properties in Preference Order.....	4-22
Table 5-1	Summary of Surveyed Electrified Rural Growth Centers.....	5-3
Table 5-2	Summary Table of Surveyed Public Facilities	5-2
Table 5-3	Summary Table of Surveyed Business Entities.....	5-6
Table 5-4	Summary Table of Surveyed Hammer Mills	5-7
Table 5-5	Summary Table of Surveyed Households	5-8
Table 5-6	Time Table of Daily Demand in Surveyed Electrified RGCs	5-10
Table 5-7	Peak Demand and Number of Households in Electrified RGCs	5-12
Table 5-8	Number of Hammer Mills and Unit Servicing Households in Surveyed RGCs	5-16
Table 5-9	Assumptions for Demand Forecast	5-18
Table 5-10	Sample Sheet to Select Daily Peak Demand in a RGC.....	5-18
Table 5-11	Temporary Electrification Priority of RGCs Based on Demand Criteria	5-20
Table 6-1	Transmission Lines of ZESCO as of June 2006 (330kV – 88kV).....	6-3
Table 6-2	Transmission lines of ZESCO as of June 2006 (66kV).....	6-4
Table 6-3	Transformers of ZESCO Substations as of 2006	6-5
Table 6-4	ZESCO's Existing Transmission Development Plan.....	6-6
Table 6-5	Projection of Peak Demand in Zambia	6-12
Table 6-6	Generation Development Plan of ZESCO	6-12
Table 6-7	Trading Power of Interconnection Line with Neighboring Countries	6-12
Table 6-8	Additional Necessary Reinforcement of Substations by 2010	6-14
Table 6-9	Additional Necessary Reinforcement of Transmission Lines by 2010.....	6-14
Table 6-10	Maximum Transmitting Capacity of each Substation as of 2010	6-15
Table 6-11	Additional Necessary Reinforcement of Substations by 2015	6-18
Table 6-12	Additional Necessary Reinforcement of Transmission Lines by 2015.....	6-18
Table 6-13	Maximum Transmitting Capacity of each Substation in 2015	6-19
Table 6-14	Additional Necessary Reinforcement of Substations by 2020	6-22
Table 6-15	Additional Necessary Reinforcement of Transmission Lines by 2020.....	6-22
Table 6-16	Maximum Transmitting Capacity of each Substation in 2020	6-23
Table 6-17	Additional Necessary Reinforcement of Substations by 2030	6-26

Table 6-18	Additional Necessary Reinforcement of Transmission Lines by 2030.....	6-26
Table 6-19	Maximum Transmitting Capacity of each Substation in 2030	6-27
Table 7-1	ZESCO's Operation and Maintenance Divisions	7-1
Table 7-2	ZESCO's Standard on Overhead Distribution Lines	7-2
Table 7-3	Unit Cost of Equipment	7-2
Table 7-4	Rural Electrification Projects slated for 2006 and their Scope of Works	7-3
Table 7-5	Condition for Analysis	7-11
Table 7-6-1	Total Demand and Number of RGC (Existing SS).....	7-13
Table 7-6-2	Total Demand and Number of RGC (Proposed SS by ZESCO)	7-15
Table 7-6-3	Total Demand and Number of RGC (Proposed SS by Consultant).....	7-16
Table 7-7-1	Result of Cost Estimation in each Package (Existing Substation)	7-19
Table 7-7-2	Result of Cost Estimation in each Package (Proposed Substation by ZESCO)	7-38
Table 7-7-3	Result of Cost Estimation in each Package (Proposed Substation by Consultant).....	7-40
Table 8-1	Rainfall Data (1963-1992 average)	8-1
Table 8-2	River Flow Data (Oct.1996 – Sep.2006).....	8-3
Table 8-3	Distance from Unelectrified RGCs to the Nearest Waterfall	8-4
Table 8-4	Planned On-grid HPP Projects.....	8-5
Table 8-5	Existing Plan of Extension/Renovation of Four Small Hydropower Plants	8-8
Table 8-6	Planned Off-grid HPP Projects.....	8-9
Table 8-7	Unit Price	8-13
Table 8-8	Project Summery of Upper Zambezi Site	8-17
Table 8-9	Project Summery of Mujila Falls Lower Site	8-19
Table 8-10	Project Summery of Mujila Falls Upper Site	8-21
Table 8-11	Project Summery of Kasanjiku Falls Site.....	8-24
Table 8-12	Project Summery of Chauka Matambu Falls Site	8-26
Table 8-13	Project Summery of Namukale Falls Site	8-33
Table 8-14	Project Summery of Chilambwe Falls Site	8-37
Table 8-15	Project Summery of Mambuluma Falls Site.....	8-38
Table 8-16	Project Summery of Chilongo Falls Site	8-44
Table 8-17	Summery of Surveyed Site in Western Province	8-46
Table 8-18	Summery of the Hydropower Potential Survey in Northwestern Province ...	8-50
Table 8-19	Summery of the Hydropower Potential Survey in Northern and Luapula Provinces	8-51

Table 9-1	SIDA-funded ESCOs	9-2
Table 9-2	Standard Equipment of SIDA-Funded SHS.....	9-2
Table 9-3	Standard Equipment of ZAMSIF-funded SHS	9-4
Table 9-4	ZAMSIF-installed SHS	9-5
Table 9-5	Specifications of SHS Equipment procured by GRZ (Residential Use).....	9-6
Table 9-6	Annual Global Solar Radiation by Region	9-8
Table 9-7	Average Daily Solar Power Generation (2002-2005).....	9-8
Table 9-8	Market research result about photovoltaics equipment in Zambia	9-11
Table 9-9	The electrical stakeholder and electrical role by photovoltaics	9-13
Table 9-10	Specification of photovoltaics (school)	9-15
Table 9-11	Specification of photovoltaics (ordinary homes)	9-15
Table 9-12	Specification of photovoltaics (commercial establishment).....	9-15
Table 10-1	Availability and Potential for Utilization of Renewable of Energy Resources and Technologies in Zambia	10-1
Table 10-2	Annual Average Wind Velocity in Zambia (2002-2005)	10-2
Table 10-3	Residue of Some Major Crops Grown in Zambia	10-3
Table 10-4	Rough Outline of Production in the Major Sugar Factories in Zambia	10-4
Table 10-5	Classification of Windmills by Size	10-4
Table 11-1	Review Fee Tariff.....	11-8
Table 11-2	Scoping of Social and Environmental Considerations	11-10
Table 11-3	Mitigation Measures for Adverse Social and Environmental Impacts	11-17
Table 12-1	Probable Hydropower Potential Sites.....	12-5
Table 12-2	Result of Social Survey in Kanyama and Kakoma RGCs	12-7
Table 12-3	Demand Forecast for Kanyama and Kakoma RGCs	12-7
Table 12-4	Generation Capacity of MFL Site	12-8
Table 12-5	Features of Plant and Facilities of Mujila Falls Lower Project.....	12-9
Table 12-6	Cost Estimation For Mujila Falls Lower Project	12-10
Table 12-7	Comparison of FIRR between One Phase and Two Phase Installation	12-11
Table 12-8	Comparison of FIRR among Three Tariff Settings for Case A-1	12-11
Table 12-9	Comparison of FIRR among Three Tariff Settings for Case A-2.....	12-12
Table 12-10	Financial Statements of Case A-1-1	12-13
Table 12-11	Financial Statements of Case A-1-2.....	12-14
Table 12-12	Financial Statements of Case A-1-3.....	12-15
Table 12-13	Financial Statements of Case A-2-1	12-16
Table 12-14	Financial Statements of Case A-2-2.....	12-17

Table 12-15	Financial Statements of Case A-2-3.....	12-18
Table 12-16	Result of Social Survey in Kapatu RGC	12-24
Table 12-17	Demand Forecast for Kapatu RGC	12-24
Table 12-18	Generation Capacity of Chilambwe Falls Site	12-25
Table 12-19	Comparison for Designed Discharge and Generation Cost.....	12-26
Table 12-20	Features of Plant and Facilities of Chilambwe Falls Project	12-27
Table 12-21	Cost Estimation For Chilambwe Falls Project.....	12-28
Table 12-22	Results of Financial Analysis for Chilambwe Falls Project	12-29
Table 12-23	Financial Statements of Case B-1	12-30
Table 12-24	Financial Statements of Case B-2.....	12-31
Table 12-25	Financial Statements of Case B-3.....	12-32
Table 12-26	Proposed Staff Members of Hydropower Plant	12-37
Table 12-27	Outline of Mujila Falls Lower and Chilambwe Falls mini-hydropower projects	12-40
Table 12-28	Potential Impacts and Mitigation Measures (Mujila Falls Lower Mini-Hydropower Station Site and areas along the route of associated 33kV distribution line).....	12-55
Table 12-29	Potential Impacts and Mitigation Measures (Chilambwe Falls Mini-Hydropower Station Site and areas along the route of associated 33kV distribution line).....	12-60
Table 12-30	Alternative Electrification Schemes	12-64
Table 13-1	GIS Database Obtained during the First Mission	13-2
Table 13-2	GIS Database Obtained during the Second Mission	13-3
Table 14-1	Assumed Life Time for Each Electrification Mode	14-4
Table 14-2	Number of Project Packages in Each Combination of Electrification Mode .	14-4
Table 14-3	Number of RGCs and Households Electrified by Each Mode	14-5
Table 14-4	Assumptions for Financial Indicator Calculation	14-5
Table 14-5	Final Electrification Priority of Project Packages by 2030.....	14-7
Table 14-6	Electrification Priority of Project Packages by Province.....	14-9
Table 14-7	Number of Project Packages and Electrification Mode for RGCs by Province	14-6
Table 14-8	Necessary Electrification Project Cost by 2030 in Each Mode	14-6
Table 14-9	Annual Project Phases by 2030	14-21
Table 14-10	Targeting Electrification Rate in 2030	14-23

List of Figures

		Page
Figure 1-1	Scope of Works	1-4
Figure 1-2	Flow of the Study	1-5
Figure 2-1	Provinces and Districts in Zambia	2-2
Figure 2-2	Population Projections	2-3
Figure 2-3	Populations, Area and Density by Province	2-3
Figure 2-4	Literacy Rates by District	2-6
Figure 3-1	Organization Chart of MEWD and DoE	3-4
Figure 3-2	Organization Chart of REA.....	3-4
Figure 3-3	Organization Chart of ZESCO.....	3-5
Figure 3-4	Electricity Sector Structure.....	3-5
Figure 3-5	Current Flow of Rural Electrification Fund (REF)	3-7
Figure 3-6	Difference between REF Levy and REA's Budget.....	3-8
Figure 3-7	Levy and Expenditure of Kenya REP Scheme	3-12
Figure 3-8	Pictures of Zengamina Hydropower Plant	3-17
Figure 3-9	Pictures of Nyangombe Hydropower Plant.....	3-18
Figure 3-10	Pictures of Mporokoso Hydropower Plant	3-19
Figure 3-11	Pictures of Luena River Hydropower Plant.....	3-20
Figure 3-12	Pictures of Mangongo Hydropower Plant	3-20
Figure 3-13	Electricity Generation (sent out to national grid).....	3-21
Figure 3-14	Domestic Electricity Consumption	3-22
Figure 3-15	Electricity Supply and Demand	3-22
Figure 3-16	Monthly Peak Load	3-23
Figure 3-17	Daily Load Curve	3-24
Figure 3-18	Annual Load Factor.....	3-25
Figure 3-19	Transmission/Distribution Loss	3-26
Figure 3-20	Electricity Import / Export.....	3-27
Figure 3-21	Annual Peak Demand and Available Capacity (national grid).....	3-27
Figure 3-22	Southern African Power Pool Interconnection	3-28
Figure 3-23	Average Selling Price.....	3-31
Figure 3-24	ZESCO's Powercut Workflow.....	3-32
Figure 3-25	Increase / Decrease of ZESCO's Trade Receivables	3-33
Figure 3-26	ZESCO's Annual Revenue.....	3-34
Figure 3-27	Total Cost of Electricity Supply	3-35

Figure 3-28	Capital Investment Financing.....	3-36
Figure 3-29	ZESCO's Capital Structure (Equities & Liabilities).....	3-36
Figure 3-30	Return on Assets (ROA) – International Comparison	3-37
Figure 3-31	Return on Equities (ROE) – International Comparison	3-37
Figure 4-1	Concept of Rural Growth Centre and Catchment Area.....	4-1
Figure 4-2	Electrification Rate (for Lighting) by Province.....	4-4
Figure 4-3	Willingness to Pay for Monthly Tariff	4-17
Figure 4-4	Willingness to Pay for Initial Cost.....	4-19
Figure 4-5	ZESCO Connection Fee, Average Income, and Willingness to Pay	4-18
Figure 4-6	Importance of 4 Properties for Rural Electrification	4-21
Figure 4-7	Summary of Utilities for Each Property	4-21
Figure 5-1	Flow Chart of Data Analysis for Potential Demand Forecast.....	5-1
Figure 5-2	Public Facilities' Daily Load Curves for Electrified RGC	5-4
Figure 5-3	Business Entity's Unit Average Daily Load Curve for Each Electrified RGC..	5-6
Figure 5-4	Hammer Mill's Unit Daily Load Curve for Each Electrified RGC	5-7
Figure 5-5	Household's Unit Daily Load Curve for Each Electrified RGC	5-8
Figure 5-6	Daily Load Curves for Electrified RGCs	5-9
Figure 5-7	Linear Regression Model for Peak Demand with Hammer Mills	5-13
Figure 5-8	Linear Regression Model for Peak Demand without Hammer Mills	5-13
Figure 5-9	Chronological Transition of Household Electrification Rate	5-14
Figure 5-10	Chronological Transition of Hammer Mill Electrification Rate	5-15
Figure 6-1	Transmission System Diagram of Zambia as of 2006	6-2
Figure 6-2	Transmission System Diagram of Zambia as of 2010	6-7
Figure 6-3	Transmission System Diagram of Zambia as of 2015	6-8
Figure 6-4	Transmission System Diagram of Zambia as of 2020	6-9
Figure 6-5	Transmission System Diagram of Zambia as of 2030	6-10
Figure 6-6	Image Diagram of Remaining Availability for Electrification Projects.....	6-13
Figure 6-7	Power Flow Diagram of the Base Scenario as of 2010	6-16
Figure 6-8	Image Diagram of Remaining Availability for Electrification Projects in 2010.....	6-17
Figure 6-9	Power Flow Diagram of the Base Scenario in 2015	6-20
Figure 6-10	Image Diagram of Remaining Availability for Electrification Projects in 2015.....	6-21
Figure 6-11	Power Flow Diagram of the Base Scenario in 2020	6-24

Figure 6-12	Image Diagram of Remaining Availability for Electrification Projects in 2020.....	6-25
Figure 6-13	Power Flow Diagram of the Base Scenario in 2030	6-28
Figure 6-14	Image Diagram of Remaining Availability for Electrification Projects as of 2030.....	6-29
Figure 7-1	Flowchart of the Study	7-10
Figure 7-2	Model and Formula for Analysis.....	7-12
Figure 8-1	Location of Meteorological Stations and River Flow Gauging Stations.....	8-2
Figure 8-2	Location of On-grid HPP Project Sites	8-6
Figure 8-3	Picture of Mumbotuta Falls	8-7
Figure 8-4	Locations of Off-grid HPP Project Sites	8-9
Figure 8-5	Picture of Chavuma Falls.....	8-10
Figure 8-6	Picture of Chikata Falls.....	8-10
Figure 8-7	Pictures of Shiwang'andu Project Site	8-11
Figure 8-8	Location of Hydropower Potential Site in Northwestern Province.....	8-14
Figure 8-9	Flow Duration Curve at Upper Zambezi Site	8-15
Figure 8-10	Pictures of Upper Zambezi Site.....	8-16
Figure 8-11	Flow Duration Curve at Mujila Falls Lower Site.....	8-17
Figure 8-12	Pictures of Mujila Falls Lower Site	8-18
Figure 8-13	Flow Duration Curve at Mujila Falls Upper Site.....	8-20
Figure 8-14	Pictures of Mujila Falls Upper Site	8-20
Figure 8-15	Picture of Tututu Falls Site.....	8-22
Figure 8-16	Flow Duration Curve at Kasanjiku Falls Site	8-22
Figure 8-17	Pictures of Kasanjiku Falls Site.....	8-23
Figure 8-18	Flow Duration Curve at Chauka Matambu Falls Site.....	8-25
Figure 8-19	Pictures of Chauka Matambu Falls Site	8-25
Figure 8-20	Flow Duration Curve at Luakela Falls Site	8-26
Figure 8-21	Picture of Lwakela Falls Site	8-27
Figure 8-22	Picture of Muwozi Falls Upper Site	8-27
Figure 8-23	Picture of Muwozi Falls Lower Site	8-28
Figure 8-24	Location of Hydropower Potential Site in Northern and Luapula Provinces.....	8-29
Figure 8-25	Pictures of Kalambo Falls Site	8-30
Figure 8-26	Picture of Mwanbezi Falls Site.....	8-31
Figure 8-27	Flow Duration Curve at Namukale Falls Site.....	8-31
Figure 8-28	Pictures of Namukale Falls Site	8-32
Figure 8-29	Picture of Ngozye Falls Site.....	8-34

Figure 8-30	Flow Duration Curve at Chilambwe Falls Site	8-34
Figure 8-31	Pictures of Chilambwe Falls Site.....	8-36
Figure 8-32	Flow Duration Curve at Mumbuluma Falls Site	8-37
Figure 8-33	Picture of Mumbuluma Falls Site.....	8-38
Figure 8-34	Picture of Lumangwe Falls Site.....	8-39
Figure 8-35	Picture of Kabwelme Falls Site	8-40
Figure 8-36	Flow Duration Curve at Pule Falls Site.....	8-40
Figure 8-37	Pictures of Pule Falls Site	8-41
Figure 8-38	Flow Duration Curve at Chilongo Falls Site.....	8-42
Figure 8-39	Pictures of Chilongo Falls Site	8-43
Figure 8-40	Pictures of Mumbuluma Falls II Site.....	8-45
Figure 8-41	Location of the Hydropower Potential Site in Western Province.....	8-46
Figure 8-42	Pictures of Surveyed Sites in Western Province	8-48
Figure 9-1	Organaization Structure of Chesco	9-3
Figure 9-2	Average Daily Load Curve over 21 Days	9-3
Figure 9-3	A House Equipped with a Solar Home System in Chipata.....	9-3
Figure 9-4	A House Equipped with a Solar Home System in Chipata.....	9-3
Figure 9-5	A house equipped with a Solar Home System in Lundazi	9-6
Figure 9-6	Solar Radiation Map of Zambia.....	9-8
Figure 10-1	Shiwang'andu – Chinsali District in Northern Province – Wind Power Generation.....	10-5
Figure 11-1	Environmental Clearance Process in Zambia.....	11-4
Figure 11-2	National Parks and Game Management Areas in Zambia.....	11-11
Figure 11-3	National Parks, Environmentally Sensitive Areas, Wetland Bird Habitat, and RGCs.....	11-12
Figure 11-4	Distribution of Ecosystem in Zambia.....	11-13
Figure 11-5	Distribution of Wetlands in Zambia.....	11-13
Figure 11-6	Forest Reserves in Zambia	11-14
Figure 12-1	Location of MFL Site and RGCs.....	12-6
Figure 12-2	Flow Duration Curve at MFL Site	12-8
Figure 12-3	Location of Chilambwe Falls Site and RGCs.....	12-23
Figure 12-4	Flow Duration Curve at Chilambwe Falls Site	12-25
Figure 12-5	Location of Mujila Mini-Hydropower Station and proposed electricity grid .	12-38

Figure 12-6	Location of Chilambwe Falls Mini-Hydropower Station and proposed electricity grid.....	12-39
Figure 12-7	Typical Miombo woodland vegetation in the study area	12-43
Figure 12-8	Riverine riparian forests along the Mujila stream.....	12-44
Figure 12-9	Typical Chitemene system of agriculture.....	12-45
Figure 12-10	Part of riverine riparian forest around Chilambwe Falls.....	12-50
Figure 13-1	Southern African UTM Zones.....	13-4
Figure 13-2	Distribution Network in Zambia	13-5
Figure 13-3	Rural Growth Centres Listed in Electrification Candidate	13-5
Figure 13-4	Example of Final GIS Database	13-6
Figure 13-5	GIS Training.....	13-7
Figure 14-1	Flowchart of Rural Electrification Master Plan Development	14-1
Figure 14-2	Concept of Project Package.....	14-2
Figure 14-3	Process of a Project Package Broken Down to Cases	14-3
Figure 14-4	Transition of Household Electrification Rates by 2030	14-23
Figure 14-5	Transition of Cumulative Number of Electrified RGCs and Rural Electrification Rate by 2030	14-24
Figure 14-6	Rural Electrification Map in 2030	14-24

Acronyms

ACSR	Aluminium Conductor Steel Reinforced
AfDB	African Development Bank
CA	Catchment Area
CBR	Crude Birth Rate
CEC	Copperbelt Energy Corporation
CHESCO	Chipata Energy Service Company
CSAA	Client Service Accounts Assistants
CSO	Central Statistics Office
DDACC	Direct Debit and Credit Clearing
DoE	Department of Energy
DWA	Department of Water Affairs
ECZ	Environmental Council of Zambia
EIA	Environmental Impact Assessment
EIRR	Economic Internal Rate of Margin
EIS	Environmental Impact Statement
EPPCA	Environmental Protection and Pollution Control Act
ERB	Energy Regulation Board
ESCO	Energy Service Company
ESU	Environment and Social Affairs Unit of ZESCO
FIRR	Financial Internal Rate of Return
FNDP	The Fifth National Development Plan
FY	Fiscal Year
GEF	Global Environmental Facility
GIS	Geographical Information System
GNI	Gross National Income
GRZ	Government of the Republic of Zambia
IEE	Initial Environmental Examination
IMR	Infant Mortality Rate
IPP	Independent Power Producer
JBIC	Japan Bank for International Corporation
JICA	Japan International Corporation Agency
K	(Zambia) Kwacha
KG-PS	Kafue Gorge Power Station
KNB-PS	Kariba North Bank Power Station
KPLC	Kenya Power & Lighting Company
KSh	Kenya Shilling
kW, MW	kilowatt, megawatt
kWh, MWh, GWh	kilowatthour, megawatthour, gigawatthour
LDC	Least Developed Countries
LEB	Life Expectancy at Birth
LESCO	Lundazi Energy Service Company

Mc-HP	Micro-hydropower plant
MEWD	Ministry of Energy and Water Development
MFNP	Ministry of Finance and National Planning
MTENR	Ministry of Tourism, Environment and Natural Resources
NEP	National Energy Policy
NESCO	Nyimba Energy Service Company
NRSE	New and Renewable Source of Energy
PB	Project Brief
PRP	Power Rehabilitation Project
REA	Rural Electrification Authority
REF	Rural Electrification Fund
REMP	Rural Electrification Master Plan
REP	Rural Electrification Programme
RGC	Rural Growth Centre
ROA	Return on Assets
SAPP	Southern African Power Pool
SEA	Strategic Environmental Assessment
TEPCO	Tokyo Electric Power Company, Inc.
TFR	Total Fertility Rate
Tr	Transformer
UNIDO	United Nations Industrial Development Organization
UTM	Universal Transverse Mercator
VF-PS	Victoria Falls Power Station
WB	World Bank
ZAMSIF	Zambia Social Investment Fund
ZCCM	Zambia Consolidated Copper Mines
ZESCO	Zambia Electricity Supply Corporation (Currently "ZESCO Ltd." is the company's official name)
ZMD	Zambia Meteorological Department

Chapter 1

Introduction

Chapter 1. Introduction

1.1. Background

Rural electrification has long been identified as a vehicle to eradicate poverty by stimulating the rural economy in the Republic of Zambia. In 1994, the Government of the Republic of Zambia (GRZ) established the Rural Electrification Fund (REF) by committing the sales tax on electricity, and has been trying to increase the electrification rate in rural area by executing projects funded by REF. The household electrification rate, however, still remains at approximately 20% countrywide, and only 2 –3% in rural area. As a mid-term target, achieving 35% of household electrification rate (50% in urban area and 15% in rural area) by 2010 was set in the Poverty Reduction Strategy Paper published in 2002. For aiming to achieve this goal, GRZ has been strengthening policies and institutions related to rural electrification. In December 2003, the Rural Electrification Act was enacted to establish Rural Electrification Authority (REA) and to improve the management of REF.

In order to enhance rural electrification efficiently, preparation of the Rural Electrification Master Plan in Zambia (REMP) was considered as an urgent issue, and GRZ requested the Government of Japan to assist the development of Master Plan in 2004. Accordingly, Japan International Cooperation Agency (JICA), an official agency responsible for the implementation of the technical cooperation program on behalf of the Government of Japan, sent a study team to Zambia for project formulation in September 2005, followed by the preliminary study team in January 2006. The study team held discussion with GRZ on the Scope of Work of the Master Plan Study, and execution of the study was approved.

JICA selected the Tokyo Electric Power Company, Inc. (TEPCO) as consultant to execute this Master Plan Study. The Study Team of TEPCO commenced the study in May 2006.

1.2. Purpose of the Study

The objective of the Master Plan Study is to formulate the Master Plan for rural electrification in Zambia up to the year 2030 and to bring about technology transfer to counterparts so that they can continue updating and implementing the Master plan by themselves.

The Study consists of the following items:

- (1) Rural Electrification Plan up to 2030
 - (a) Development of selection criteria for rural electrification projects
 - (b) Selection of candidate site for rural electrification considering socio-economic and technical aspects
 - (c) Selection of electrification methods
 - Extension of existing grid
 - Isolated mini-grid with renewable energy, such as mini- and micro-hydro power generation
 - Solar home system (SHS)
 - Mini-grid with diesel power generation, if none of the above is feasible
 - (d) Case study executions
- (2) Financial Plan for Rural Electrification
 - (a) Study on financing strategy
 - (b) Cost estimation of implementing the Master Plan at each phase
 - (c) Evaluation of the validity of rural electrification projects (EIRR / FIRR)

- (3) Policy Recommendations for Acceleration and Dissemination of Rural Electrification
 - (a) Organization structure for promoting rural electrification
 - (b) Operational management of Rural Electrification Fund
 - (c) Framework of promoting the participation of private sector (IPP and ESCO)
 - (d) Affordable initial connection fee and sustainable electricity tariff
 - (e) Policy on curbing the negative impact of electrification on society and environment
- (4) Development of Comprehensive Rural Electrification Program
 - (a) Implementation procedure of long-term rural electrification plan
 - (b) Prioritisation of execution plans
 - (c) Consensus-oriented rural electrification plan with donors; ex. Japanese Bank for International Cooperation (JBIC), African Development Bank (AfDB) and World Bank (WB)

1.3. Scope of Works

This study started at the beginning of May 2006, and is scheduled to continue until the beginning of December 2007. The terms of reference of work as provided to TEPCO was shown in Appendix-A. The scope of works is summarized in Figure 1-1.

1.4. Study Flow and Schedule

This study will be carried out in five stages and completed by December 2007. The flow and the schedule of the study are shown in

Figure 1-2 and Table 1-1 respectively.

1.5. Study Team

Member of the Study Team and their respective Zambian counterparts, are shown in Table 1-2.

Table 1-2 Members of JICA Study Team

No.	Position	Name	Zambian Counterpart
1	Team Leader Rural Electrification Planning Expert	Hitoshi Koyabu	Charles Mulenga
2	Deputy Team Leader Electrification Policy & Organization Expert	Tomoyuki Yamashita	Arnold Simwaba
3	Hydro Power Planning Expert	Takayuki Abe	Nkusuwila Silomba
4	Renewable-Energy-Based Rural Electrification Planning Expert	Genshiro Kano	Malama Chileshe
5	Transmission and Distribution Planning Expert	Kenichi Kitamura	Mushimbwa Fred
6	Socio Economic Expert	Yasushi Iida	Wankunda Siwakiwi Langiwe Chandi
7	Environmental and Social Impact Analysis Expert	Yasuharu Sato	Michael Mulasikwanda Mundu Mwila
8	GIS Database Development Expert	Atsushi Yuihara	Aggrey Siuluta C.Kasango / B.Mukala
9	Power System Analysis Expert	Takashi Chujo	William Sinkala
10	Project Coordinator	Osamu Matsuzaki	Patrick Mubanga

Note: List of Zambian counterpart is the one originally approved and does not reflect the personnel reshuffle during the Study period.

1.6. Outline of Report

This report consists of 15 chapters. Back ground, purpose, scope, schedule of the study, and so on are introduced in Chapter 1. General profile and current status of the power sector in Zambia are summarized in Chapter 2 and Chapter 3. The selection methods of electrification targets (Rural Growth Centers) in this master plan are explained in Chapter 4. The social aspect analysis results, such as ability and willingness to pay and prioritized property for electrification, are also shown in this chapter. The potential power demand for selected electrification targets is forecasted and an initial ranking for electrification for these targets is given in Chapter 5. Transmission system analysis, such as the capacity analysis of the system based on a simulation, is executed in Chapter 6. Plans for distribution system, micro-hydropower generation, solar power, and other renewable energies to realize rural electrification are provided in Chapter 7, Chapter 8, Chapter 9, and Chapter 10 respectively. Environmental and social considerations are explained in Chapter 11. Results of case studies (or pre feasibility studies), 3 sites for distribution lines, 2 sites for mini-hydropower, and 2 sites for environmental impact assessment, are introduced in Chapter 12. In Chapter 13, development process of GIS database is explained. The optimal electrification method for each target, final electrification priority based on financial indicators, and project execution phase from 2008 to 2030 are specified as a comprehensive rural electrification master plan in Chapter 14. Finally, conclusion and recommendation are provided in Chapter 15.




Figure 1-1 Scope of Works




Figure 1-2 Flow of the Study

Table 1-1 Schedule of the Study

Stage	Activity	2006												2007												Output
		5	6	7	8	9	10	11	12	1	2	3	4	5	6	7	8	9	10	11	12					
<Stage 1> Valid Policy Recommendation	1-1 Review and analyze related policies and legislations	■																					<Stage 1>			
	1-2 Review and analyze related programmes implemented by other development donors	■																								
	1-3 Discuss policies regarding rural electrification promotion based on information obtained and study activity outputs			■																						
	1-4 Discuss implementation frameworks for rural electrification promotion based on information obtained and study activity outputs																									
<Stage 2> Practical GIS Database System Development	2-1 Collect information on the current status of rural electrification in the rural areas	■																					<Stage 2> a. GIS Database			
	2-2 Collect information from rural electrification and local development agencies/institutions	■																								
	2-3 Review existing rural electrification projects	■																								
	2-4 Collect information on power facility development and grid extension plans	■																								
	2-5 Assess the potential of renewable energy development																									
	2-6 Collect data/information on rural socio-economy (by deployment of local experts)																									
	2-7 Formulate GIS database system																									
<Stage 3> Electrification Target and Supply Method Selection Criteria Development	3-1 Hold unelectrified village selection workshops - 1st WS: Preliminary workshop in Lusaka - 2nd WS: Province workshops in nine provincial capitals - 3rd WS: Dissemination workshop in Lusaka		■									■											<Stage 3> b. Criteria for Prioritizing Electrification Target Village and Selecting Rural Electrification Method c. Socio-economic Survey Data/Results d. Workshop Proceedings			
	3-2 Review technical standards such as design, construction, and safety standards for rural electrification			■																						
	3-3 Discuss low-cost electrification modes			■																						
	3-4 Review existing selection criteria for towns to be electrified			■																						
	3-5 Discuss demand-side selection criteria for electrification																									
	3-6 Discuss supply-side selection criteria for electrification																									
	3-7 Propose a selection criteria for rural electrification project																									
	3-8 Prioritize towns to be electrified and choose optimal modes of electrification																									
<Stage 4> Drafting Master Plan with Policy Recommendations	4-1 Formulate a electrification schedule up to 2030																						<Stage 4> e. Draft Master Plan with Policy Recommendation			
	4-2 Discuss and propose institutional frameworks for rural electrification fund management as well as system operation and maintenance																									
	4-3 Discuss and propose effective billing management systems and organizational arrangement																									
<Stage 5> Case Study Executions and Final Master Plan Development	5-1 Select pilot study sites																						<Stage 5> f. Case Study Results g. Master Plan with Policy Recommendation			
	5-2 Formulate a rural electrification plan through public participation (Rural electrification public awareness workshop)																									
	5-3 Plan and conduct Pre-Feasibility Studies																									
	5-4 Hold rural electrification seminars (three times during a study period)		■																							
	5-5 Coordinate and agree with local residential offices of development donor institutions on approach & methodology and contents of the Study		■																							
	5-6 Discuss with the JBIC (Tokyo) WB (Washington DC) and AfDB (Tunis)																									
	5-7 Develop and strengthen organizational and human capacity through OJT																									
	5-8 Conduct counterpart training programs in Japan																									
	5-9 Discuss methodology to promote indigenous technology for the promotion of rural electrification																									
Reporting Schedule																										

Chapter 2

General Profile of Zambia

Chapter 2. General Profile of Zambia

2.1. Land

Zambia used to be the colony of United Kingdom and gained its independence on 24th October 1964. The country is located in southern Africa, with the area of 752,614 square kilometres. Zambia is a land-locked country sharing borders with the Democratic Republic of the Congo (DR Congo) and Tanzania to the north; Malawi and Mozambique to the east; Zimbabwe and Botswana to the south; Namibia to the south-west and Angola to the west.

2.2. Administrative Organization and Local Social Structure

Lusaka is the capital city of Zambia and the seat of Government. The Government comprises the Central and Local Authorities. The province is the highest level of local administration of Zambia, and there are nine provinces, namely Central, Copperbelt, Eastern, Luapula, Lusaka, Northern, North-Western, Southern and Western provinces. The provinces are broken down into 72 districts, as seen in Figure 2-1. Districts are further broken down into wards, which are the smallest unit of local administration. There are 1,286 wards in total as of the Census of 2000.

2.3. Population

The census of Population and Housing has been executed by GRZ once in a decade. The total population of Zambia has been increasing from 5.7 million of the 1980 Census to 7.8 million of the 1990 Census, then 9.8 million of the 2000 Census. Population growth is getting moderate gradually, from 3.1% p.a. in 1970s (1970-1980) to 2.7% p.a. in 1980s (1980-1990), then 2.4% p.a. in 1990s (1990-2000).

Breaking down the population by Provinces, Copperbelt Province with 1,581,221 people is the largest Province in population (or 16.1% of the country's total population) according to the Census in 2000. The smallest Province in population is North-Western Province, with 583,350 people or 5.9 % of total population. Provinces with high population growth in 1990s are Lusaka (3.4% p.a.), Luapula (3.2% p.a.), and Northern (3.1% p.a.). Copperbelt Province recorded the population growth rate of 0.8% p.a., the lowest among 9 Provinces during the decade (refer to Table 2-1).

According to the population projections published by the Central Statistics Office, 34.6% of the population (or 3.9 million out of 11.4 million total population) is estimated to live in urban area while the remaining 65.4% (or 7.5 million) is estimated to reside in rural area. Lusaka and Copperbelt Provinces have high percentage of urban population at 82% and 81 % respectively, while that in Eastern Province is only 9%. Urban population is expected to increase from 3.9 million in 2005 to 5.6 million in 2025 at the average annual growth rate of 1.75%. Rural population is estimated to grow more rapidly at the average annual growth rate of 3.34%: from 7.5 million in 2005 to 14.4 million in 2025. In total, Zambia's population is expected to grow at 2.84% per annum up to 2025, and to reach approximately 20 million by 2025 from 11.4 million in 2005, as shown in Figure 2-2.

Population density has been increasing from an average of 5.4 people/km² in 1970 to 7.5 people/km² in 1980, 9.8 people/km² in 1990, and 13.0 people/km² in 2000. Population density of each Province reveals the significant gap between Provinces with high density (e.g. Lusaka: 63.5 people/km² in 2000) and those with low density (e.g. North-Western: 4.6 people/km²), as shown in Table 2-1 and Figure 2-3).



Source: JICA Zambia Office Web Site
 (<http://www.jica.go.jp/zambia/activities/haichi.html>)

Figure 2-1 Provinces and Districts in Zambia

Table 2-1 Populations, Area, Density and Growth Rate (2000 Census)

	Population (% of total population) 2000	Population Density [person/km ²] 2000	Annual Growth Rate [%] 1990 – 2000	Area [km ²]
Zambia	9,806,185 (100.0%)	13.0	2.4%	752,612
<i>Central</i>	1,012,257 (10.3%)	10.7	2.7%	94,394
<i>Copperbelt</i>	1,581,221 (16.1%)	50.5	0.8%	31,328
<i>Eastern</i>	1,226,767 (12.5%)	17.8	2.0%	69,106
<i>Luapula</i>	775,353 (7.9%)	15.3	3.2%	50,567
<i>Lusaka</i>	1,391,329 (14.2%)	63.5	3.4%	21,896
<i>Northern</i>	1,258,696 (12.8%)	8.5	3.1%	147,827
<i>North-Western</i>	583,350 (5.9%)	4.6	2.9%	125,826
<i>Southern</i>	1,212,124 (12.4%)	14.2	2.3%	85,283
<i>Western</i>	765,088 (7.8%)	6.1	1.8%	126,385

Source: Summary Report 2000 Census of Population and Housing
 (Central Statistical Office, November 2003)




Figure 2-2 Population Projections




Figure 2-3 Populations, Area and Density by Province

2.4. Ethnic Composition, Language and Religion

The overwhelming majority of Zambian people are ethnically African, with the variety of 73 tribes, while there also exist some minorities, such as Europeans, who mostly derive from immigrants since the modern times. Although each of these African tribes has its own vernacular language, English is used as the official language of Zambia and most of urban residents speak it fluently. In rural areas, communication in daily life is usually done in vernacular languages, which can be roughly divided into seven major groups: Bemba, Kaonde, Lozi, Lunda, Luvale, Nyanja and Tonga. Bemba is spoken in Northern, Luapula, Copperbelt, and Central Provinces. Kaonde, Lunda and Luvale languages are commonly used in North-Western Province. Lozi is commonly used in Western Province. Nyanja is spoken in Eastern and Lusaka provinces. Tonga is spoken in Southern Province.

The predominant religion in Zambia is Christianity, among which Roman Catholic is said to be the majority, while various traditional religions also exist, which is especially believed in rural area.

2.5. Fertility, Mortality and Life Expectancy

Total Fertility Rate (TFR), which is defined as the number of births a woman will have assuming that she survives to the end of her childbearing age, namely 50 years old, is estimated at 5.8 in 2004. TFR is higher in rural area (6.6) than that in urban area (4.5), which is considered to be the main drive of higher population growth in rural area than that in urban area, as discussed in Section 2.3. despite the general trend of migration from rural area to urban area. TFR in Luapula Province is 7.0, the highest among 9 Provinces, while that in Lusaka Province is the lowest at 4.3.

Crude Birth Rate (CBR), which is defined as the number of births that occurred in the 12-month period prior to the census against 1,000 people, is about 47.1 in urban area and 39.3 in rural area respectively. The average CBR of the whole nation is 44.2 in 2004. Among Provinces, Lusaka Province has the lowest CBR (37.6), followed by Copperbelt Province (39.3) while the highest CBR was recorded in Northern Province (48.4).

Infant Mortality Rate (IMR), which is defined as the number of deaths in a year that occurred to infants under one year of age against 1,000 live births, is higher in rural area (117 in 2000 and 91 in 2004) than urban area (91 in 2000 and 75 in 2004). Luapula Province saw the highest IMR among 9 Provinces both in 2000 (132) and 2004 (108), while the lowest IMR among Provinces is that in North-Western Province in 2000 (83) and that in Lusaka Province in 2004 (67). In comparison between 2000 and 2004 data, IMR improved in all Provinces.

Life Expectancy at Birth (LEB), which is defined as the average number of year that a newly born babies would live if subjected to the prevailing mortality conditions, is 52.4 in 2004, prolonged by 2.4 years from 50.0 in 2000. No significant difference in LEB was found between rural and urban areas as of 2004 though, according to the statistics of 2000, LEB in urban area was rather higher than that in rural area. The same trend is observed in the statistics broken down by sex, in that a significant difference is of LEB found between both sexes in 2004 though in 2004 female LEB was considerably higher than male's. Copperbelt Province (57.6 years) indicates the highest LEB among Provinces in 2004 while Northern Province (45.5 years) saw the lowest.

Table 2-2 Fertility, Crude Birth, Infant Mortality Rates and Life Expectancy at Birth

Area / Sex / Province	TFR		CBR		IMR		LEB	
	2000	2004	2000	2004	2000	2004	2000	2004
Zambia Total	6.0	5.8	–	44.2	110	83	50.0	52.4
Rural	6.7	6.6	–	47.1	117	91	48.0	50.5
Urban	4.9	4.5	–	39.3	91	75	54.0	50.0
Male	–	–	–	–	–	–	48.0	52.3
Female	–	–	–	–	–	–	52.0	52.6
Central	6.1	6.0	–	44.6	100	70	52.0	55.0
Copperbelt	5.2	4.8	–	39.3	91	63	54.0	57.6
Eastern	6.7	6.6	–	46.7	129	100	46.0	47.0
Luapula	7.1	7.0	–	46.9	132	108	45.0	47.5
Lusaka	4.6	4.3	–	37.6	88	67	54.0	54.1
Northern	7.0	6.7	–	48.4	130	100	46.0	45.5
North-Western	6.6	6.4	–	46.1	83	74	56.0	55.6
Southern	6.3	6.1	–	45.2	93	79	53.0	51.6
Western	5.9	5.9	–	44.3	140	104	44.0	48.2

Source: Selected Socio-Economic Indicators 2003-2004
(Central Statistical Office, November 2003)

2.6. Education and Literacy


A large segment of the Zambian Population remains uneducated and illiterate. As shown in Table 2-3, literacy rate of the population aged 5 years old and above is 55.3% as of 2000. And no improvement has been seen compared to that as of 1990. There's a significant gap in literacy rate between rural area (45.0% in 2000) and urban area (73.5% in 2000), which is also observed in Figure 2-4 that illustrates the literacy rate of each District: Districts in Copperbelt Province, Lusaka, Livingstone, and Kabwe Districts, which are mostly categorized as urban area, are showing a relatively high literacy rate while Eastern Province recorded the lowest literacy rate among 9 Provinces. On top of that, the comparison between 1990 and 2000 data indicates a growing gap of literacy rate between urban and rural areas: literacy rate in urban area saw improvement more or less in all Provinces while in rural area not remarkable improvement is observed (except Lusaka Province). The problem of illiteracy lies more common in rural area than urban area.

There is also a significant gap in literacy rate regarding sex, that is, the literacy rate of female population (49.8% in 2000) is much lower than that of male population (61.1%), and no remarkable mitigation of this gap can be seen during the decade with some exceptions (Western Province).

Table 2-3 Literacy Rate (5 years old and above)

	1990					2000				
	Total	Rural	Urban	Male	Female	Total	Rural	Urban	Male	Female
Zambia Total	55.3%	44.7%	71.5%	61.6%	49.2%	55.3%	45.0%	73.5%	61.1%	49.8%
Central	56.2%	50.3%	70.0%	61.8%	50.6%	55.8%	50.4%	71.8%	60.8%	50.9%
Copperbelt	69.9%	53.4%	72.7%	74.2%	65.4%	70.5%	52.6%	75.3%	74.3%	66.8%
Eastern	37.7%	34.9%	65.8%	45.8%	30.8%	37.9%	35.0%	67.1%	45.5%	30.8%
Luapula	49.4%	46.5%	64.9%	56.9%	42.4%	48.4%	45.3%	68.2%	56.0%	41.2%
Lusaka	68.6%	50.3%	72.0%	73.5%	63.6%	70.1%	55.0%	73.3%	74.7%	65.5%
Northern	47.5%	44.2%	67.3%	55.5%	40.1%	47.0%	43.3%	68.7%	55.3%	39.3%
North-Western	42.4%	38.3%	66.4%	50.4%	35.1%	43.4%	40.1%	67.0%	50.5%	36.6%
Southern	56.5%	51.4%	72.5%	61.1%	52.1%	56.2%	50.5%	76.0%	60.2%	52.3%
Western	48.1%	44.9%	69.3%	54.2%	42.9%	50.6%	46.7%	77.9%	55.3%	46.4%

Source: 2000 Census Analytical Report
(Central Statistical Office, October 2004)



Source: Census Atlas 2000
(Central Statistical Office, November 2003)

Figure 2-4 Literacy Rates by District

The level of education is summarized in Table 2-4. In Zambia, 27.2% of the population aged 5 years and above have had no formal education, 25.9% completed lower primary (4 years or less), 24.5% completed upper primary (5-7 years), 10.7% accomplished junior secondary (8-9 years), and 9.0% accomplished senior secondary (10-12 years). Only 1.2% of the population has completed Grade 12 Graduate Certification with A level, and 1.5% completed Bachelor’s degree or above. 24.6% of males and 29.7% of females have never had any formal education, and more males have attained secondary school or higher levels than females. There is also a gap in education level between urban population and rural population: about 40% of urban people completed secondary school or higher while less than 13% of rural population had same opportunity.

Table 2-4 Percentage Distribution of Population by Highest Level of Education Attended

	Highest Level of Education							Total
	None	Lower Primary (1 - 4)	Upper Primary (5 - 7)	Junior Secondary (8 - 9)	Senior Secondary (10 - 12)	Grade 12 GCE (A) / Collage / Undergraduate	Bachelors Degree and Above	
Zambia Total	27.2%	25.9%	24.5%	10.7%	9.0%	1.2%	1.5%	100.0%
Male	24.6%	25.1%	24.3%	11.3%	11.5%	1.3%	1.9%	100.0%
Female	29.7%	26.7%	24.8%	10.1%	6.5%	1.0%	1.2%	100.0%
Rural	33.0%	29.6%	25.0%	7.6%	3.8%	0.5%	0.5%	100.0%
Male	29.4%	29.0%	26.1%	8.8%	5.4%	0.6%	0.7%	100.0%
Female	36.4%	30.1%	24.0%	6.3%	2.5%	0.4%	0.3%	100.0%
Urban	16.9%	19.5%	23.7%	16.2%	18.0%	2.4%	3.3%	100.0%
Male	16.1%	18.1%	21.0%	15.6%	22.4%	2.6%	4.2%	100.0%
Female	17.7%	20.8%	26.3%	16.7%	13.7%	2.2%	2.6%	100.0%

Source: Selected Socio-Economic Indicators 2003-2004
(Central Statistical Office, January 2006)

2.7. Poverty and Living Standards

In Zambia, poverty line is set based on the Food-Energy Intake (FEI) approach. The methodology of this approach is to establish a monetary value, at which the predetermined average food energy requirements for normal bodily functions are met, i.e. the minimum intake of 2,094 calories per day per person. People in the Extremely Poor status cannot afford to meet the basic minimum food requirements, even if they allocate all the expenditure on food. Households whose total monthly expenditure is less than K78,223 per adult equivalent at 2004 price level are categorized as “extremely poor”. People who can afford the basic minimum food requirements but cannot afford minimum basic non-food items, such as health, shelter, and education, are categorized as “moderately poor”, i.e. K111,747 per adult equivalent. Poverty lines at “extremely poor” and “moderately poor” levels from 1991 to 2004 are summarized in Table 2-5. People whose expenditure exceeds the upper poverty line (or the expenditures on basic minimum food requirements as well as minimum basic non-food items) are categorized as “non poor”.

Table 2-5 Poverty Levels

	(K/adult/month)					
Year	1991	1993	1996	1998	2002	2004
Extremely Poor	961	5,910	20,181	32,861	64,530	78,223
Moderately Poor	1,380	8,480	28,979	47,187	92,185	111,747

Source: Living Conditions Monitoring Survey Report 2004
(Central Statistical Office, December 2006)

Trends of population living in poverty from 1991 to 2004 are summarized in Table 2-6. Poverty ratio saw an improvement recently, dropping from 73% in 1998 to 68% in 2004, after the period of stagnation during 1990s, when the country experienced economic recession triggered by drought and falling copper prices, the country’s main export. In rural area, the poverty ratio dropped remarkably from 88% in 1991 to 78% in 2004, though there was a reverse trend in early 1990s. In urban area, the poverty ratio worsened in 1990s increasing from 49% in 1991 to 56% in 1998, though it improved slightly afterwards, dropping to 53% in 2004, which is considered due to the overall economic recovery in 2000s. The improving trend in rural area and the worsening trend in urban area might be a trade-off caused by the population migration, by which those people in villages who are too poor to earn minimum requirement to sustain their lives settled in so-called peri-urban area.

Broken down by province, the poverty ratio saw an improvement in all Provinces from 1998 to 2004, but the trend between 1993 and 1998 shows a clear contrast among Provinces: considerable worsening is observed in Copperbelt (from 49% to 65%) and Lusaka (from 39% to 53%) Provinces while in other Provinces the poverty ratio improved more or less during the same period, especially in Eastern (from 91% to 79%), North-Western (from 88% to 77%), and Southern (from 87% to 75%) Provinces.

Table 2-6 Poverty Trends from 1991 to 2004

		1991	1993	1996	1998	2004
Zambia Total	Poverty Ratio	70%	74%	69%	73%	68%
	Extremely Poor	58%	61%	53%	58%	53%
	Moderately Poor	12%	13%	16%	15%	15%
Rural	Poverty Ratio	88%	92%	82%	83%	78%
	Extremely Poor	81%	84%	68%	71%	65%
	Moderately Poor	7%	8%	14%	12%	13%
Urban	Poverty Ratio	49%	45%	46%	56%	53%
	Extremely Poor	32%	24%	27%	36%	34%
	Moderately Poor	17%	21%	19%	20%	19%
Central	Poverty Ratio	70%	81%	74%	77%	76%
	Extremely Poor	56%	71%	59%	63%	63%
	Moderately Poor	14%	10%	15%	14%	13%
Copperbelt	Poverty Ratio	61%	49%	56%	65%	56%
	Extremely Poor	44%	28%	33%	47%	38%
	Moderately Poor	17%	21%	23%	18%	18%
Eastern	Poverty Ratio	85%	91%	82%	79%	70%
	Extremely Poor	76%	81%	70%	66%	57%
	Moderately Poor	9%	10%	12%	13%	13%
Luapula	Poverty Ratio	84%	88%	78%	82%	79%
	Extremely Poor	73%	79%	64%	69%	64%
	Moderately Poor	11%	9%	14%	13%	15%
Lusaka	Poverty Ratio	31%	39%	38%	53%	48%
	Extremely Poor	19%	24%	22%	35%	29%
	Moderately Poor	12%	15%	16%	18%	19%
Northern	Poverty Ratio	84%	86%	84%	81%	74%
	Extremely Poor	76%	72%	69%	66%	60%
	Moderately Poor	8%	14%	15%	15%	14%
North-Western	Poverty Ratio	75%	88%	80%	77%	76%
	Extremely Poor	65%	76%	65%	64%	61%
	Moderately Poor	10%	12%	15%	13%	15%
Southern	Poverty Ratio	79%	87%	76%	75%	69%
	Extremely Poor	69%	76%	59%	59%	54%
	Moderately Poor	10%	11%	17%	16%	15%
Western	Poverty Ratio	84%	91%	84%	89%	83%
	Extremely Poor	76%	84%	74%	78%	73%
	Moderately Poor	8%	7%	10%	11%	10%

Source: Living Conditions Monitoring Survey Report 2004
(Central Statistical Office, December 2006)

Relations between poverty and household characteristics in 2004 are summarized in Table 2-7. Regarding household head, there are more female-headed households below the Poverty Lines (71%) than male-headed ones (66%), and especially household in “extreme poverty” is more prevalent for female-headed ones (57%) than male-headed ones (51%), though the difference might not be too serious. Households headed by an old person are more likely to be below the Poverty Line, especially in “extremely poor” category.

Education level of household head shows strong correlation to the poverty status. Poverty ratio of households headed by a person with no educational background is 81%; among which 70% is categorized in “extremely poor”. On the other hand, poverty ratio of households headed by a person

with tertiary education stays as low as 30%, among which 16% is categorized in “extremely poor”. The incident of poverty also worsens with the increase of household size. Only 32% of single-person households are living below the poverty line, while the 73% of households with family of six or more members are categorized as living below poverty line. This correlation becomes clearer when the poverty status is limited to “extremely poor”.

Table 2-7 Poverty and Household Characteristics in 2004

	Poverty Status				Total Population
	Poor			Non Poor	
	Extremely	Moderately	Total		
Zambia Total	53%	15%	68%	32%	10,898,614
Rural/Urban					
Rural	65%	13%	78%	22%	6,632,709
Urban	34%	18%	53%	47%	4,265,905
Sex of Household Head					
Male	51%	15%	66%	34%	8,815,110
Female	57%	14%	71%	29%	2,106,981
Age of Household Head					
12 – 19	23%	42%	65%	35%	27,716
20 – 29	43%	16%	59%	41%	1,604,459
30 – 59	52%	15%	67%	33%	7,860,620
60 +	66%	12%	78%	22%	1,429,296
Education of Household Head					
None	70%	11%	81%	19%	1,185,678
Primary School	63%	14%	77%	23%	4,781,457
Secondary	43%	17%	60%	40%	4,108,386
Tertiary	16%	14%	30%	70%	846,570
Household Size					
1	22%	10%	32%	68%	112,910
2 – 3	34%	17%	51%	49%	1,280,614
4 – 5	48%	16%	64%	36%	2,914,579
6 +	59%	14%	73%	27%	6,613,988
Province					
Central	63%	12%	76%	24%	1,130,372
Copperbelt	38%	18%	56%	44%	1,650,981
Eastern	57%	13%	70%	30%	1,507,974
Luapula	64%	15%	79%	21%	859,170
Lusaka	29%	19%	48%	52%	1,526,381
Northern	60%	14%	74%	26%	1,400,650
North-Western	61%	15%	76%	24%	649,414
Southern	54%	14%	69%	31%	1,352,699
Western	73%	10%	83%	17%	820,973

Source: Living Conditions Monitoring Survey Report 2004
(Central Statistical Office, December 2006)

Chapter 3

**Current Status
of
the Power Sector**

Chapter 3. Current Status of the Power Sector

3.1. Policy and Organizations

3.1.1. History of Electrification and Policy

Rural Electrification in Zambia dates back to the colonial period when electricity lines were extended to European settler farmers in rural areas. Since Zambia's independence in 1964, the electrification of district administrative centres has received high priority. As a result, nearly all the district centres have been electrified either through national grid or by isolated grid systems supplied from micro-hydro power stations or diesel generators.

On the other hand, household electrification, especially in rural areas, has not made significant progress due to the high capital costs involved. The wide scatter of the Zambian rural population raises the cost of building distribution lines, especially as most villages are distant from the national electricity grid.

The Government has funded electrification projects from annual national budgets since the early 1980s. However, the funds proved inadequate for the large number of projects embarked upon, which prolonged completion times.

In January 1994, the Government established the Rural Electrification Fund (REF) under the Ministry of Energy and Water Development (MEWD) in order to increase the funding and improve the management of the rural electrification programme. A levy of 3.45% on electricity consumption was introduced and the Ministry of Energy and Water Development was charged with ensuring that the funds allocated to the REF were disbursed in accordance with the best principles of transparency and accountability.

Accordingly in January 1995, MEWD issued the "Guidelines on Selection of Rural Electrification Projects for Funding by Government", which outlined the procedure of selecting projects proposed by Provincial Planning Units for support from the REF. The criteria were in two categories: primary and secondary considerations. The primary considerations consisted of (1) economic aspects, (2) regional distribution, and (3) social aspects. "Economic aspects" were to be evaluated from the aspects of agricultural development potential and the evidence of industrial/commercial growth. "Regional distribution" was also a key factor to ensure that the projects were equitably distributed in the country. "Social aspects" gave due consideration to the electrification of public facilities, such as hospitals, clinics, health centres, schools and community centres.

The secondary considerations comprised (1) technical aspects and (2) willingness of recipients to contribute to the capital cost and the cost of internal wiring. "Technical aspects" were the selection criteria of the most suitable electrification method among all possible options, such as grid extension, micro-hydro, SHS, and diesel. The last criterion, "willingness of recipients" was intended to avoid supplying electricity to areas where the target communities were unprepared for it. For that reason, preference was given to communities that demonstrated capacity to meet part of the project capital cost and/or a practical willingness to meet the cost of internal wiring of their houses/buildings. Based on these five criteria, MEWD developed a scoring system for ranking projects for funding.

Despite the development of the REF and the adoption of project selection criteria in the mid-1990s, rural electrification did not take off as expected. Although the REF was established as Government Excise Duty collected exclusively for financing rural electrification projects, a portion of the levy was actually diverted to the Government's general-account. In addition, it is often pointed out that the selection criteria were not strictly adhered to. To improve matters, the Rural Electrification Authority (REA) was established in 2004 under MEWD as an independent administrator to manage REF. The main responsibilities of REA are to elaborate annual electrification programs, to implement approved rural electrification projects using the REF, and to monitor the status of projects contracted to institutions/organizations/companies in order to ensure that they fulfil their obligations

and perform in accordance with set standards. MEWD / REA with the assistance from JICA undertook the development of Rural Electrification Master Plan (REMP) inline with Zambia's Vision 2030.

3.1.2. Key Players of the Power Sector

The overall responsibility for energy administration and policy formulation lies with the **Ministry of Energy and Water Development (MEWD)**. The organizational chart of MEWD, focusing on the Department of Energy (DoE) is summarized in Figure 3-1.

The **Rural Electrification Authority (REA)** is a statutory body created under the MEWD through the enactment of the Rural Electrification Act No. 20 of 2003. Functions of REA are as follows:

- Administer and manage REF
- Develop, implement and update REMP for systematic electrification of rural area
- Promote utilization of available rural electrification technological options to enhance the contribution of energy to develop agriculture, manufacturing, mining and other economic activities in rural area
- Mobilize funds from within and outside of Zambia to support rural electrification
- Offer, on a competitive basis, the opportunity of rural electrification projects for contractors and developers, and periodically publish information on programs being carried out
- Design and offer, on a competitive basis, smart subsidies for the capital cost of projects to enhance energy supply for development in rural areas
- In conjunction with stakeholders, develop mechanisms of the operation of grid network for rural electrification and other rural energy supply networks
- Finance project preparation studies for rural electrification projects in accordance with guidelines that are developed and approved by the Authority
- Provide recommendations to the Government for the enhancement of access to electricity by the rural population
- Undertake such other activities as are conducive or incidental to the performance of its functions under the Act.

The current organization chart of REA is shown in Figure 3-2.

The **Energy Regulation Board (ERB)**, formed through an Act of Parliament of 1995, is responsible for licensing generating plants, regulating transmission and distribution operations, regulating power tariffs, especially retails, and mediating conflicts regarding these issues.

ZESCO Limited, is a vertically integrated public power utility, with the functions of generation, transmission, and distribution. The organizational chart of ZESCO is shown in Figure 3-3. ZESCO owns most of the power stations, transmission lines, and distribution facilities in Zambia, including small hydro and diesel power plants. ZESCO is undergoing commercialisation to improve its performance though the Government still retains 100% stake in the company. ZESCO sells approximately half of its electricity to the Copperbelt Energy Corporation and the remaining half to its own retail customers through its own transmission and distribution networks.

The **Copperbelt Energy Corporation (CEC)** is a private power utility that owns and controls small gas power plants, 220kV and 66kV transmission lines, and distribution facilities in Copperbelt Province. CEC used to be a division of Zambia Consolidated Copper Mines (ZCCM) but was separated as a private entity in November 1997. CEC has most of the mining and large industrial customers that are supplied at 66kV or higher voltage in Copperbelt Province as its customers, while small customers within CEC's service area are supplied by ZESCO.

The **Lunsemfwa Hydropower Company Plc** is a private Independent Power Producer (IPP) that owns Mulungushi and Lunsemfwa Hydropower Stations with the total capacity of 38MW. The

largest shareholder is ESKOM, the power utility of South Africa, who has 51% of the stake.

In some rural areas where ZESCO's national grids do not cover, small IPP and Non-Governmental Organizations (NGOs) are supplying electricity with either small hydro or diesel power plant through the isolated distribution network. In Eastern Province, there are three **Energy Service Companies (ESCOs)** established with the support from international donor agencies. ESCOs are leasing Solar Home Systems to several hundred of households and collecting a fixed monthly fee.

The overall structure of electricity sector in Zambia is summarized in Figure 3-4.

3.1.3. Acts Related to Rural Electrification

There are three main statutes related to rural electrification: Electricity Act (enacted in April 1995 and amended in December 2003), Energy Regulation Act (enacted in April 1995), and Rural Electrification Act (enacted in December 2003).

The **Electricity Act** was enacted to regulate the generation, transmission, distribution, and supply of electricity. This Act was amended in 2003.

The **Energy Regulation Act** was enacted to establish the Energy Regulation Board and to define its functions and responsibilities, and to manage the licensing of undertaking for the production of energy or production or handling of certain fuels.

The **Rural Electrification Act** was enacted to establish Rural Electrification Authority and to define its functions and to provide for matters connected with or incidents to the foregoing.

3.1.4. Policy Related to the Renewable Energy

Currently, firewood and charcoal account for 80% of Zambia's total energy consumption. From the viewpoint of environmental conservation, GRZ has been promoting the efficient use of wood fuels and the reduction of charcoal consumption by 400,000 tonnes by 2010. As a country that imports 100% of the petroleum consumed domestically, the Government recognizes the importance of New and Renewable Sources of Energy (NRSE). The Policies regarding NRSE as stated in the revised National Energy Policy of 2007 are as follows:

- Promotion of the NRSE technology
- Promotion of the wider application of NRSE technology
- Promotion of information dissemination on the use of NRSE
- Promotion of education, research and training in NRSE at various levels




Figure 3-1 Organization Chart of MEWD and DoE




Figure 3-2 Organization Chart of REA





Figure 3-3 Organization Chart of ZESCO



Source: ZESCO Statistical Yearbook of Electricity Energy 2005/2006 ¹

Figure 3-4 Electricity Sector Structure

¹ CEC's "Distribution Network" in Figure 3-4 means electricity supply to customers with high-voltage lines (66kV or higher), not in a narrower sense of distribution lines (33kV or lower).

3.2. Rural Electrification Fund and Its Management

3.2.1. Rural Electrification Fund Scheme in Zambia

ZESCO's customers are obliged to pay Government Excise Duty on their monthly electricity bills. This Excise Duty amounts to 5% of total electricity bill which is broken down as follows: 3% is appropriated for Rural Electrification Fund (REF), which is used to finance rural electrification projects and 2% is for the other Government programs. ZESCO's bulk supply to CEC and exports are exempt from this Government Excise Duty.

The 3% levy was originally established in 1995, but this scheme did not work well for the following reasons:

- Revenues and expenses of REF were not separated from those of the Government's general account budget, thus the disbursements to the REF were delayed.
- MEWD was responsible for selecting rural electrification projects to be financed using REF, but did not have enough capacity to assign its staff to investigate and evaluate the cost and benefit of proposed rural electrification projects and to manage ongoing projects.
- ZESCO was a contractor but at the same time it was responsible for planning and managing of rural electrification projects.

Figure 3-5 is a flow chart illustrating the raising and release of REF. The 5% Excise Duty, is collected by ZESCO on behalf of Government. Ministry of Finance and National Planning (MFNP) appropriates 3% for REF, however the amount allocated to REA as REF does not exactly match this 3%, because REA receives its income based on a budget approved by the Government, and not the exact amount that MFNP receives from ZESCO.

It is expected that once the REMP is finalized REA will be able to attract loans, grants and donations from international cooperating partners to augment the REF.




Figure 3-5 Current Flow of Rural Electrification Fund (REF)

3.2.2. REA's Budget

The initial budgetary allocation to REA for the year 2005 was K11.3 billion, which roughly matches the expected REF levy for the year, that is, 3% of ZESCO's revenue from retail sales (K353 billion in FY 2004/05). And according to this budget, REA's expenditure would consist of K1.3 billion for administration and K10 billion for projects. As opposed to this original plan, however, REF release for projects in 2005 was done by MEWD while REA only handled funds for own operation and management.

The first audited accounts of income and expenditure for the year 2005 (from 1st January to 31st December) for REA, together with the pre-audit statement of FY 2004, are summarized in Table 3-1. REA's income for FY2005 was around K5.7 billion, about half of that was originally budgeted, and REF release is not accounted for in this statement². REA's expenditure was about K1.3 billion for its operations and related costs, and the remainder, about K4.4 billion, was carried forward to the next year.

² REA had planned its first release of REF in the name of REA by the end of 2005, however, due to the delay in Government approval, it was postponed to 2006.

Table 3-1 REA's Audited Income and Expenditure Account (Jan-Dec 2005)

	(K1,000)		(1,000US\$)	
	FY2004	FY2005	FY2004	FY2005
Income	348,750	5,674,053	(91.8)	(1,493.2)
Expenditure				
Administration	156,530	545,835	(41.2)	(143.6)
Personnel	2,355	546,398	(0.6)	(128.3)
Board Expenses	50,218	111,320	(13.2)	(29.3)
Movable Assets	13,597	75,449	(3.6)	(19.9)
Bank Charge	589	2,251	(0.2)	(0.6)
Miscellaneous	1,348	15,145	(0.4)	(4.0)
	224,638	1,296,398	(59.1)	(341.2)
Surplus	124,112	4,377,656	(32.7)	(1,152.0)

Note: Exchange rate of 1US\$ = K3,800 was applied for currency conversion

The gap between REA's initial budget (K11.3 billion) and its actual income (K5.7 billion) is partly covered by the REF release from the MEWD, which, according to ZESCO's internal report, was about K3.8 billion in 2005. Clearly the gap between the two figures needed to be closed.

In 2006, REA took over the full responsibility of managing REF. After the signing the Project Implementation Agreement with ZESCO in May 2006, REA published the list of rural electrification projects to be executed in 2006 (see Table 3-2). In its 2006 budget, K11.66 billion was allocated to REA, of which 90% (K10.44 billion) was released for rural electrification projects. REA's financial statements of FY2006, which covers not only its own administration costs but also the REF release for projects, are still in progress and are expected to be completed by the end of 2007.

Figure 3-6 summarizes the difference between REF levy and REA's budget.


**Figure 3-6 Difference between REF Levy and REA's Budget**

Table 3-2 Rural Electrification Projects Approved by REA for Implementation in 2006

(K million)			
Province	Project Name	Estimate Cost	2006 Allocation
Central	Mungule's Area – Phase 1 Clinic Court & Mutakwa School	920	500
	Mutombe Basic School	250	250
	Nambala High School	443	443
	Serenje's Area Muzamene Basic School	215	215
Copperbelt	Lubendo Basic School	181	181
	Mushili School	175	175
	Kabushi – Phase 1	6,000	500
	Kankoyo	1,231	231
Eastern	Mphamba School	112	112
	Mtenguleni's Area Katinta Basic School, Chipungu RHC & Chankanga Basic School	630	630
	Ndake Area – Ndake Basic School, Court House, Ndake RHC	500	500
	Lumezi	3,424	500
Luapula	Lukwesa High School	87	87
	Bakashiwa Home Care	85	85
	Nsengaila Basic Schools	45	45
	Nshungu Basic Schools	75	75
	Mashitolo Basic Schools	55	55
	Mambilima Mwenge Basic School	62	62
	Lubansa & Kalasa Basic Schools	64	64
	Chabilikila School	80	80
Lusaka	Palabana	200	–
	Mupelekese Area (Schools & Health Centres)	1,200	–
	Luangwa	1,200	–
North-Western	Kamiteto Primary Schools	168	168
	R.Mwepu Primary Schools	67	–
	Kisalala Primary Schools	126	–
	Tumvwananai Primary Schools	9	9
	Kapijimpanga Primary Schools	134	134
	Kaimbwe School	527	–
	Chitokoloki Mission *	N.A.	100
Zengamene *	N.A.	100	
Northern	Chikwanda Basic School, Court House, Market & RHC	100	100
	Luwingu High School	93	93
	Saili Basic School	77	77
	Kaputa to the Grid – Phase 1	12,000	1,000
	Chozi- Waitwika Area	535	535
	Mpumba Basic School & Court House	221	221
	Mulilansolo – Phase 1	2,500	243
	Kafwimbi's Area	784	–
Chitimukulu RHC & Police Kapolyo Basic And Kanyanta Basic School	543	543	
Southern	Sianjalika's Area – School And RHC	73	73
	Sikalongo Mission – Choma	567	–
	Mwanachingala's Area - School And RHC	42	42
	Gwembe Tonga	200	200
	Nansenga Basic Mulawo APU, Kaunga Basic, Kaunga Basic and Malala Basic Schools	250	250
	Choongo's Area – Ntema Basic School	200	200
Western	Shang'ombo – Phase 1	3,500	1,000
	Luampa Mission	760	360
	Sikongo-Phase 1 (Kalabo Basic & Kalabo Farm Training Centre)	7,600	–
	Mwandi B School Royal Court & Market	200	200
	Kaoma to the Grid	N.A.	N.A.
	Lukulu	N.A.	N.A.
Total		48,512	10,439

Note: "Chitokoloki Mission" and "Zengamene" projects in North-Western Province are micro-hydro projects contracted to private investors, not ZESCO

In FY 2007 REA's total budget was K23.21 billion, whose source consisted of the REF levy (about K13 billion) and additional Government funding amounting to about K10 billion. According to REA, 78% (about K18 billion) of the budget would be allocated to rural electrification projects (16 grid extension projects, 1 pre-feasibility study for a mini hydro, and 2 solar panel installation projects, refer to Table 3-3), and the remaining 22% (about K5 billion) for REA's administrative costs. ZESCO was expected to undertake 7 projects out of the 16 grid extension projects (including the continuation of 4 ongoing projects), while the remaining 9 projects were expected to be carried out by private entities on a turnkey basis. The selection of private entities to undertake the projects (9 projects are grouped into 5 lots) would through a tender process,.

Table 3-3 Rural Electrification Projects Approved by REA for Implementation in 2007

Province	District	Project Name	Note
Central	Chibombo	Mungule's Area – Phase II (Mungule Clinic & Court and Mutakwa School)	Grid extension by ZESCO
Central	Chibombo	Moombo Clinic & School	Grid extension by private sector (Lot-1)
Central	Chibombo	Kayosha Basic School & Rural Health (RH) Centre	Grid extension by private sector (Lot-1)
Copperbelt	Mpongwe	Machiya Basic School, RH Centre & GRZ Offices	Grid extension by private sector (Lot-2)
Eastern	Chipata	Undi RH Centre, Undi School & Local Court	Grid extension by private sector (Lot-3)
Eastern	Lundazi	Mwase	Grid extension by private sector (Lot-3)
Eastern	Chama	Chama	Grid extension by ZESCO
Luapula	Mansa	Mutiti, Chimfula, Kalaba, Lupende & Chibinda	Grid extension by private sector (Lot-4)
Luapula	Milenge	Pre-feasibility Study for a Mini-hydro at Mumbotuta Falls	Pre-FS for mini-hydro
Lusaka	Kafue	Chipapa School & Clinic	Grid extension by private sector (Lot-1)
North-Western	Kasempa	Kaimbwe School	Grid extension by ZESCO
North-Western	Kasempa	Selauke School & RH Centre	Grid extension by private sector (Lot-2)
Northern	Kaputa	Kaputa to the Grid – Phase II	Grid extension by ZESCO
Northern	Chinsali	Muliansolo – Phase II	Grid extension by ZESCO
Southern	Sinazongwe	Gwembe Tonga: Ngoma Basic School & RH Centre	Grid extension by private sector (Lot-5)
Western	Kaoma	Luampa Mission	Grid extension by ZESCO
Western	Kalabo	Sikongo – Phase II	Grid extension by ZESCO
Luapula	Samfya	Rural Solar Energy Systems	Solar panel installation in partnership with UNIDO
Various Areas		Solar Energy Systems	Continuation of ongoing projects

3.2.3. The Way Forward

An important observation regarding REA's accounting system was that it consisted only of cash accounting. Thus no distinction was made between capital expenditure and operating expenses, a system typical of Government financial reporting. There were no "balance sheets" or "profit and loss accounts" which could be used to assess the effectiveness of the capital expenditures.

According to the policy of REF, funds released for rural electrification projects to ZESCO (or other contractors if any) were treated as grants. REA did not account for these releases as "assets", which should be recorded by ZESCO as "Capital Grants and Contributions" (= liabilities) in its balance sheet. Similarly ZESCO, did not keep maintain separate accounts of the fixed (tangible) assets that acquired through the REF. Thus no information at all was available on the performance of the rural

electrification schemes. In cases where revenues from such REF schemes fell short of the operating cost, the losses were generally covered by ZESCO's total revenue without clear distinction. The Study Team recommends that REA, which is responsible not only for each year's fund allocation but also for monitoring the performance of released REF, should consider developing "balance sheet" and "profit and loss account" of REF schemes in close coordination with ZESCO, in order to improve the monitoring of the effectiveness of the Fund.

3.2.4. Rural Electrification Programme in Kenya

Kenya's Rural Electrification Programme (REP) is an example of more advanced and established scheme of rural electrification than Zambia's in that Kenyan scheme can provide statistical data regularly that are useful for monitoring its performance.

REP in Kenya was established in 1973 under the agreement between the Government of Kenya and East African Power & Lightning Company, predecessor of the existing Kenya Power & Lighting Company Limited (KPLC). The REP is funded through the Government, whose fund source is not only REP levy collected by KPLC (5% on "all electricity consumed in the country") but also donor-funding that is usually financed as project-based. Its conspicuous difference from Zambian scheme is the ownership of facilities. Under the Kenyan scheme, any property acquired by REP remains the property of the Government even after the completion of construction works, and KPLC, which is virtually the monopoly in transmission and distribution, only acts as a management agent to contract distribution lines extension and electricity supply on behalf of the Government. KPLC provides the customers of REP with same services as KPLC's own customers, that is, the same electricity tariff is applied universally whether it's for REP customers or KPLC's own customers.

Financial statements ("balance sheet" and "profit and loss accounts") of REP are compiled by KPLC staff, but separately from those of KPLC. These financial statements are reported to the Government (Ministry of Energy), who audits them with the support of hired external auditors.

REP's operational and financial performances are summarized in KPLC's annual report.

Table 3-4 shows the number of customers under REP scheme and the electricity sold to them. The number of customers as of June 2006 is about 110,000, or about 16% of KPLC's own customers, and the electricity sales is 186 GWh, about 4% of KPLC's own electricity sales that include large industrial customers. Both the number of customers and the electricity sales have grown by 54% for the past 5 years, which is a little higher than those of KPLC's own customers respectively.

Table 3-4 Number of Customers and Electricity Sales (Kenya's REP Scheme)

		2000/01	2001/02	2002/03	2003/04	2004/05	2005/06	FY05/06 against FY00/01
Customers	REP	71,718	78,941	87,175	93,442	101,789	110,724	154%
	KPLC	465,361	514,680	556,099	592,752	633,355	691,525	149%
Electricity Sales (GWh)	REP	121	130	147	150	164	186	154%
	KPLC	3,091	3,498	3,654	3,940	4,200	4,420	143%

Source: KPLC Annual Report

Note: Statistics of KPLC exclude REP scheme

Table 3-5 shows the profit and loss account of REP. The REP scheme has been in the red, but the loss margin has shown improvement recently, from -115% in FY2001/02 to -53% in FY2005/06. The book value of REP's assets as of June 2006 is 8,277 million KSh, about 20% of KPLC's own assets (38,729 million KSh). The ratio of annual net loss against assets generates an indicator similar to return on assets (ROA), which was around -10% for the past 3 years. This operating loss belongs to the Government thus the levy is also used for compensating for the operating loss of REP.


Table 3-5 “Profit and Loss Account” and “Assets” of Kenya REP

	(million KSh)					(million US\$)
	2001/02	2002/03	2003/04	2004/05	2005/06	2005/06
Revenue from Electricity Sales (A)	979	1,006	978	1,208	1,539	22.0
Operating Cost (B)	2,103	1,932	1,681	1,912	2,347	33.5
Net Operating Loss (C) = (A)-(B)	-1,124	-927	-703	-704	-808	-11.5
(C) / (A)	-115%	-92%	-72%	-58%	-53%	-53%
Assets (D)	5,777	6,694	7,066	7,634	8,277	118.2
(C) / (D)	-19%	-14%	-10%	-9%	-10%	-10%

Source: KPLC Annual Report

Note: Exchange rate of 1US\$ = 70KSh is applied for currency conversion

Figure 3-7 shows the balance between REP levy, i.e.5% of electricity sales collected by KPLC, and expenditure for property acquisition (capital expenditure for REP projects) under this scheme.



Note: Numbers in parentheses are the values in million US\$ (1US\$ = 70KSh)

Figure 3-7 Levy and Expenditure of Kenya REP Scheme

These numbers conceptually corresponds to Figure 3-6 in Zambia’s case. As seen in the chart, annual expenditure for projects is less than the collected levy except in FY2002/03, and the surplus is reserved for compensating for REP’s operating loss.

According to MoE and KPLC, REP’s assets will be transferred to KPLC in the future when the assets become as profitable as KPLC’s own, but so far no asset transfer has been made or even discussed.

This Kenyan scheme also has drawbacks, especially in that REP’s operation is excluded from KPLC’s financial performance, thus little incentive may be imposed to KPLC to improve the profitability than in Zambia’s case, where the ownership of assets is transferred to ZESCO once the

construction works are completed and ZESCO has to take the responsibility to improve profitability³. However, Zambia's rural electrification scheme, which is still at the very early stage to grasp its financial status, has a lot to learn from the scheme of other countries like Kenya, where at least the tools for monitoring the performance of rural electrification projects are considerably developed.

3.3. Power Supply and Demand

3.3.1. On-grid Power Plants

(1) ZESCO's Major Hydropower Plants

ZESCO owns three large hydropower plants, and on all of them major works were under way under a Power Rehabilitation Project (PRP). Table 3-6 shows the details of the major hydropower plants. In FY 2004/05, they generated in total 8,816GWh, which almost matches the electricity consumption in Zambia.

Table 3-6 Three Major Hydropower Plants in Zambia

Name of Power Station	Kariba North Bank	Kafue Gorge	Victoria Falls	
Number of Units	4	6	14	
Original Installed Capacity	600MW	930MW	108MW	
Available Capacity (Mar.2007)	510MW	750MW	108MW	
Expected Capacity after Rehabilitation	720MW	990MW	108MW (Completed)	
Electricity Generation	FY2001/02	2,886GWh	5,570GWh	602GWh
	FY2002/03	2,790GWh	4,806GWh	448GWh
	FY2003/03	3,158GWh	4,668GWh	354GWh
	FY2004/05	3,644GWh	4,073GWh	269GWh
	FY2005/06	3,661GWh	4,619GWh	537GWh
	FY2006/07	3,949GWh	5,034GWh	674GWh

Source: ZESCO Annual Report

(a) Kariba North Bank Power Station

Kariba North Bank Power Station (KNB-PS), which is located in Southern Province, was commissioned in 1976. KNB is connected with Leopards Substation via 330kV transmission lines. This power station used to belong to the Kariba North Bank Company Limited (KNBC), a company in which the Government had 100% stake and sold all of its electricity generation to ZESCO. In June 2004 the KNBC was formally integrated with ZESCO.

KNB-PS consists of four 150MW units each. The rehabilitation works for Units 1 and 2 were finished in 2005, and the unit outputs of these 2 units were upgraded to 180MW each. The rehabilitation works for unit 3 and 4 were also scheduled for completion from 2007 and 2008, increasing their outputs to 180MW as well. Thus the total capacity of KNB-PS will be increased to 720MW after the completion of rehabilitation works.

³ In fact, KPLC is obliged to improve the profitability of REP to a certain extent by promising to achieve numerical targets regarding rural electrification, as a part of the Performance Contract agreed between the Government and power utilities (in this case, KPLC), that are also state-owned companies, at the beginning of every fiscal year. Achievement of the numerical targets is monitored by the Government for evaluating the performance of power utilities, which, according to the Government, may also affect the managers' remuneration.

(b) Kafue Gorge Power Station

Kafue Gorge Power Plant (KG-PS), located in Southern Province bordering on Lusaka Province with Kafue River, is the biggest power plant in Zambia. KG-PS is connected to Leopards Hill Substation via 330 kV transmission lines. The six-150MW-units power station have been the central pillar of Zambia's power supply since its inauguration in 1971. The rehabilitation works at Units 3 and 4 were completed at the end of FY2005/06. It was planned to rehabilitate, the rest of the units by 2008. After the rehabilitation, the unit output will be increased to 165 MW, raising the total plant capacity to 990MW.

(c) Victoria Falls Power Station

Victoria Falls Power Station (VF-PS), which is located in Southern Province, was commissioned in 1938. This hydropower station consists of 3 groups of turbines that are called "Station A", "Station B" and "Station C" respectively. Station A has two 1MW units and two 3MW units (8MW in total), Station B has six 10MW units (60MW), and Station C has four 10MW units (40MW). The total output of these fourteen units of VF-PS is 108 MW. With the completion of rehabilitation works in FY2005/06, VF-PS recovered its original available capacity. VF-PS is connected to Muzuma Substation via 220 kV transmission lines.

(2) ZESCO's Small Hydropower Plants

Table 3-7 shows ZESCO's four small hydropower plants.

Table 3-7 ZESCO's Small Hydropower Plants

Name		Lusiwasi	Musonda	Chishimba	Lunzua
Province		Central	Luapula	Northern	Northern
Installed Capacity		12MW	5MW	6MW	0.75MW
Available Capacity (Mar.2007)		9MW	5MW	5MW	0.75MW
Number of Units		3MW x 4	1MW x 5	1.2MW x 4 0.3MW X4	0.25MW x 3
Electricity Generation	FY2001/02	9.8GWh	17.7GWh	5.5GWh	2.0GWh
	FY2002/03	15.7GWh	15.8GWh	7.0GWh	2.7GWh
	FY2003/03	17.7GWh	15.4GWh	16.6GWh	1.1GWh
	FY2004/05	13.7GWh	17.2GWh	16.9GWh	1.7GWh
	FY2005/06	3.7GWh	17.0GWh	16.3GWh	1.7GWh
	FY2006/07	33.8GWh	16.0GWh	11.9GWh	1.4GWh

Source: ZESCO Annual Report

Lusiwasi HP is synchronized to the grid. The other three HPs are also connected to the grid via transmission line, but since they do not have synchronizer they must be isolated from the grid by circuit breakers. ZESCO planned not only to synchronize these three HPs to the grid by but also to renovate and increase their capacities. Details of these expansion plans are given in Chapter 8.

(3) Generating Facilities of Other Private Companies

(a) Lunsemfwa Hydropower Company

Lunsemfwa Hydropower Company (LHPC) is an independent power producer (IPP). The largest shareholder of LHPC is ESKOM, the power utility of South Africa with a 51% stake. LHPC owns two Hydropower Stations, namely, Lunsemfwa Hydropower Plant (18MW) located in Mkushi District and Mulungushi Hydropower Plant (20MW) in Kabwe District. LHPC sells all its electricity to ZESCO under a long term Power Purchase Agreement (PPA). LHPC's electricity supply to ZESCO was 225GWh in FY2004/05 and 139GWh in FY2005/06, representing 2.7% and 1.6% of the total supply in Zambia.

The Zambian Government plans to liberalize the electricity market so that IPPs such as LHPC

can supply electricity directly to large customers through ZESCO's transmission lines.

(b) Copperbelt Energy Corporation

Copperbelt Energy Corporation (CEC) buys electricity from ZESCO on a long-term PPA to supply its customers, mostly the mining companies on the Copperbelt, . CEC's power demand constitutes about half of Zambia's total electricity demand, and its power system, wheels power export from DR Congo to Zimbabwe and South Africa. The CEC system handles about 70% of the electricity running through Zambia's national grid.

CEC operates an 80 MW emergency gas turbine station and the transmission and distribution networks consists of 808 kilometres of overhead lines and 36 high voltage substations. Table 3-8 gives the details of CEC's four emergency gas turbines.

Table 3-8 CEC's Gas Turbines

Name	Bancroft	Luano	Maclaren	Kankoyo
Installed Capacity	20MW	40MW	10MW	10MW
Available Capacity	20MW	40MW	10MW	10MW
Number of Unit	2	2	1	1
Unit Capacity	10MW	20MW	10MW	10MW
Generation (FY2005)	310kWh	677kWh	422kWh	303kWh

Source: CEC

(c) Konkola Copper Mines

Konkola Copper Mines (KCM) owns a 20MW Nkana Gas Thermal Power Plant located in Kitwe District, Copperbelt Province. KCM is the leading copper mining company in Zambia and purchases electricity from CEC while its own Nkana Gas thermal Power Plant is maintained as an emergency standby facility.

3.3.2. Off-grid Power Plants

(1) Off-grid Power Generation in Zambia

Off-grid power generation plays an important role of supplying electricity to areas that are remote from the national grid. A possible mode of electrifying these areas is power supply through isolated small distribution networks, called "micro-grids". These may be powered by diesel or hydropower plant. However, in some areas where even an isolated grid is not economically viable, a solar home system (SHS) is another alternative electricity supply, Details of this are discussed in Chapter 9.

The Zambian Government has shown strong interest in the research and development of renewable energy sources, such as biomass and geo-thermal, as sustainable means of electricity supply in remote areas.

(2) Diesel Generation

ZESCO has diesel power plants in some remote areas, and about half of them are located in North-Western Province. Table 3-9 shows the list of these diesel power plants. Taking into account the high cost of fossil fuels and their negative impact on the environment, these diesel power plants are unsustainable. ZESCO had plans to replace them by connecting to the national grid or with renewable energy sources such as micro-hydro. Along these lines, Kaoma diesel power plant in Western Province and Kasempa diesel power plant in North-Western Province ceased operations following the connection of their supply areas to the national grid. In FY2004/05, the sales revenue

by diesel generation was only K1,319 million, which was only 6% of their fuel cost of K20,844 million.

Contrary to this general trend, however, some new diesel power plants have been installed and inaugurated recently, which is in line with the Government's policy to electrify all the 72 District Administrative Centres (DAC). This is the only feasible means of supplying DACs that are too remotely located from existing distribution lines. Examples are the Chavuma diesel power plant that started commercial operations in FY2004/05, followed by Shang'ombo diesel power plant in Western Province, which was under construction at the time of reporting and was expected to start operations in January 2007.

Table 3-9 ZESCO's Diesel Power Plants

Name	Province	Capacity	Generation (FY2006/07)
Chama	Eastern	263kW	828MWh
Luangwa	Lusaka	732kW	756MWh
Kaputa	Northern	486kW	1,196MWh
Mwinilunga	North-Western	1,430kW	2,729MWh
Kabompo	North-Western	1,560kW	2,599MWh
Zambezi	North-Western	800kW	2,075MWh
Chavuma	North-Western	690kW	688MWh
Mufumbwe	North-Western	320kW	933MWh
Kasempa (operation suspended)	North-Western	530kW	N.A.
Kaoma (operation suspended)	Western	2,620kW	N.A.
Lukulu	Western	512kW	1,140MWh

Source: ZESCO Annual Report

(3) Micro-Hydro Power Generation

There are many micro hydropower plants owned and managed by local community or local residents especially in remote areas of Zambia. These HPs supply electricity to some specific place or areas via isolated micro-grids. Details of these micro HPs are described below. The information on micro HPs is scanty and unreliable. It is possible that there are more micro HPs than indicated by the data from either DoE or REA.

(a) Zengamina Hydropower Plant

Zengamina HP is located 95km north of Mwinilunga District centre, North-Western Province. It uses the water of Zambezi River for power generation, and a 700 kW cross-flow turbine manufactured by Ossberger was installed. The plant started commercial operation in July 2007, supplying electricity to a hospital, clinics, schools, small business and households in Ikelenge RGC and Nyakaseya RGC.

Zengamina Power Company owns and operates this Power Plant. The company offers two types of electricity tariffs to its customers. One is a prepaid-fixed charge of 10US\$ per month for which the maximum current is limited at one ampere. The other is commodity charge, which consists of 12.5US\$ per month for basic charge and 11US Cents per kWh for electricity usage. Zengamina also plans to adopt another option of cheaper 8US Cents tariff for electricity usage from midnight to 6:00 AM, and for community services like the hospital. The connection fee is fixed at 65US\$ for low-end customers, rising to 200US\$ for a three phase metered connection. These tariffs are quite different from those of ZESCO. Zengamina HP reasons that its low connection fee enables many customers to afford a connection, while the high electricity charge encourages them to use electricity carefully.. In the micro-grid system such as Zengamina HP, limited electricity must be supplied to as many people as possible. Therefore, this type of tariff is suitable for a rural electrification program.

Nevertheless, these two RGCs have quite large potential demand, and Zengamina Power Company expects that the demand will exceed the maximum capacity of Zengamina HP in eight years. In

anticipation of this, there are plans to construct a new 1,000kW hydropower plant upstream of the existing scheme, including a storage dam (this site was visited by the Study Team and is described in Chapter 8 of this report). Furthermore, the storage dam to be installed at the upper site could enhance the efficiency of water usage, allowing the existing Zengamina HP to use more water for power generation. There are also plans to install the second turbine-generator unit with another 700 kW capacity at the existing Zengamina HP, where the first and end section of second penstock and a bed for second turbine have already been installed. Figure 3-8 shows pictures of Zengamina HP.



a) Weir



b) Silt basin and water channel



c) Penstock and powerhouse



d) Turbine



e) Switchyard



f) Office

Figure 3-8 Pictures of Zengamina Hydropower Plant

(b) Nyangombe Hydropower Plant

Nyangombe HP is located about 15 km southeast of Mwinilunga District centre, North-Western

Province. In use is a Cross-flow turbine manufactured by Ossberger with a maximum capacity of 73kW. The plant is owned by the corporative of local residents at Nyangombe and is operated by the resident engineer. The electricity is supplied only to the institution, hammer mill and residences at Nyangombe, and it is not used for commercial purpose. Figure 3-9 shows pictures of Nyangombe HP.



a) Place of the resident



b) Water channel



c) Powerhouse



d) Turbine

Figure 3-9 Pictures of Nyangombe Hydropower Plant

(c) Sachibondu Hydropower Plant

Sachibondu HP is located about 25km north of Mwinilunga District centre, North-Western Province. This operation is a 15 kW Cross-flow turbine, owned and operated by a mechanic at the corporative of local residents, and there are no commercial sales, as it is solely for own use.

(d) Lwawu Hydropower Plant

Lwawu HP is located very close to the border with Republic of Angola, about 45 km west of Mwinilunga District centre, North-Western Province. Its generation capacity is 50 kW. Lwawu Mission owns and manages this plant to supply electricity to the institution, a hammer mill and to the residents.

(e) Mutanda Hydropower Plant

The Technology Development and Advisory Unit (TDAU) of the University of Zambia installed 2.5 kW micro-hydro turbine in early 1990s at Mutanda Centre, situated 35 km west of Solwezi, North-Western Province. This power plant was on the Mapunga River and used to supply electricity to a hammer mill, a compressor and a generator. However the supply was inadequate for the ever-increasing local demand. Hence TDAU and Mutanda Evangelical Centre conducted the Pre-investment study on the expansion of the capacity up to 200 kW in 2001. However, this plan was superseded by a 33 kV connection to the national grid.

(f) Mporokoso Hydropower Plant

Mporokoso HP is located in the Mporokoso District centre, Northern Province. This plant is designed and manufactured by a local citizen. The water from a nearby swamp has been dammed by rocks, and then transferred to a turbine via water channel made from cut drums. The turbine is also made from scrapped wheels and drum cut in the shape of runner blade. The flush of water passes through the lower side of horizontal-shaft-type turbine, so this turbine can be categorized as a kind of undershot water wheel. The maximum output is about 5 kW, and the electricity is consumed mainly by the owner, but he also sells electricity to neighbours through a battery charging service. Figure 3-10 shows pictures of Mporokoso HP.




Figure 3-10 Pictures of Mporokoso Hydropower Plant

(g) Luena River Hydropower Plant

Luena River Hydropower Plant is located about 70 km northwest of Kaoma District centre, Western Province, in Mayukwayukwa Refugee Settlement. This HP is owned and managed by UNHCR (Office of the United Nations High Commissioner for Refugees), and supplies electricity free of charge to 64 households in the settlement. The capacity of Italian Propeller turbine was 24 kW, but its capacity has reduced with age. The plant is operated and maintained by two engineers (mechanical and electrical) trained by the turbine manufacturer. The UNHCR meets all the Operation and Maintenance costs. Figure 3-11 shows pictures of Luena River HP.



Figure 3-11 Pictures of Luena River Hydropower Plant

(h) Mangongo Hydropower Plant

Mangongo Hydropower Plant is located in Mangongo Mission, about 35 km northeast of Kaoma District centre, Western Province. Mangongo Mission owns this 17 kW hydropower plant and supplies electricity to the church, clinic, and 54 households. Public facilities are exempted from electricity charges, but the households pay a flat-rate electricity charge of K10,000 per month. Figure 3-12 shows pictures of Mangongo HP.



Figure 3-12 Pictures of Mangongo Hydropower Plant

3.3.3. Supply and Demand Balance (National Grid)

After about a decade's slump from mid 1980s, total electricity generation has been gradually recovering since 1997, when ZESCO started the implementation of the Power Rehabilitation Project (PRP) at Kariba North Power Station (installed capacity: 660MW, upgraded from original 600MW), which is in a few years followed by PRPs at Kafue Gorge (installed capacity: 900MW) and Victoria Falls (installed capacity: 108MW) Power Stations. Since FY 2000/01 these power stations have steadily sent out more than 8,000GWh per year. The increase of power generation from FY2004/05 (8,192GWh) to FY2006/07 (9,787GWh) is mainly due to the completion of some rehabilitation works of hydropower stations.

Lunsemfwa Hydropower Company, which owns Mulungushi (20 MW) and Lunsemfwa (18 MW) hydropower stations and is currently the sole IPP to sell electricity to ZESCO's national grid, accounts for less than 3% of the electricity supply countrywide.




Figure 3-13 Electricity Generation (sent out to national grid)

Total domestic electricity consumption on ZESCO's national grid (bulk deliveries, including distribution loss) changed little through the 1990s, when the small increase of electricity consumption in ZESCO's distribution system was offset by a decline of power demand of the copper mining industry currently supplied by CEC. In 2000 consumption started growing rapidly due to the recovery of mining industry. In the six years from FY2000/01 to FY2006/07 national electricity consumption increased by about 34% from 6,724 GWh to 8,421 GWh




Figure 3-14 Domestic Electricity Consumption

Figure 3-15 illustrates the balance between electricity supply and demand. Until early 1990s annual power generation in general overwhelmed domestic consumption, and this allowed Zambia to be a regional power exporter. This excess became smaller and imports began to increase in the 1990s, though the balance varied year-by-year depending mainly on the availability of generation plant. In the 2000s, as the domestic electricity consumption started increasing rapidly, the supply-demand balance has become tighter still. The Power Rehabilitation Projects and new generation projects, namely Kafue Gorge Lower Hydroelectric Power Project (750MW), Kariba North Power Station Extension Project (300MW), and Itzhi-tezhi Hydropower Project (120MW), when completed, were expected to mitigate this situation. However, if demand continues to grow at the current pace, the supply-demand balance could be even tighter.




Figure 3-15 Electricity Supply and Demand

3.3.4. Seasonal and Daily Characteristics of Power Demand

Figure 3-16 shows the monthly peak demand of ZESCO’s national grid for the past 6 years (from FY2001/02 to FY2006/07), and the numbered points in the chart indicate each year’s peak demand. For the six-year period up to 2006/07 the annual peak load grew from 1,088 MW to 1,393 MW, an increase of about 22% increase. For the past 6 years, the annual peak load occurred in the winter, months between May and July.

As seen in the chart, there are significant variations of the peak load demand curve from year to year. Until FY2002/03 little fluctuation has been observed in every month’s peak load, for example, the peak load of August 2002, the lowest in 12 months, was 1,053MW, which is 94.1% of the year’s peak load (1,119MW in June 2002). This ratio still remained at 91.5% in FY2003/04 and each month’s peak load was higher than that of previous year. In FY2004/05 the monthly peak load started fluctuating significantly: November 2004’s peak load dropped to 974MW, which is the lowest in the past 5 years and its ratio against that of June 2004, the year’s highest, also went down to 75.2%. This significant fluctuation in monthly peak load is also observed in the next FY2005/06: September 2005’s peak load, the lowest among 12months, was 1,056MW and remained at 79.4% of that of annual peak load (1,330MW in July 2005). In November 2005 the monthly peak load rose considerably from the previous month, and this shows a sharp contrast against the previous year, when the peak demand sharply dropped in November. The fluctuation of monthly peak load was mitigated in FY2006/07 and the lowest monthly peak load among 12 months (1,273MW in August 2006) was as high as 91.4% of annual peak load (1,393MW in June 2006).

ZESCO has not given details to explain this trend, but the following hypotheses to clarify this might be possible as far as we assume that these numbers are statistically consistent.

- The increase of electricity consumption for residential use, which is especially remarkable between FY2003/04 (2,052GWh) and FY2004/05 (2,542GWh), has made power consumption more sensitive to weather changes.
- ZESCO’s reduction of losses, makes the total system load more responsive to the end-users’ actual power consumption. This is also evidenced by the improvement of distribution losses from 20.9% in FY2003/04 to 18.1% in FY2004/05 (discussed in Section 3.3.5). In the same vein, the relatively stable trend of monthly peak load in FY2006/07 may be more or less related to the worsened distribution losses (25.2%).




Figure 3-16 Monthly Peak Load

Figure 3-17 shows the daily load of ZESCO’s national grid system. In its annual “Statistics Yearbook of Electric Energy”, ZESCO provides “typical” daily load curves, but does not indicate the

date when the data were recorded. However, since the “typical” load curve in for 2005/06” is different from that for 2004/05, it is assumed that the former reflects the newer load data than the latter.

Here we can observe similar changes in the monthly peak load. The red line in the figure, that is, the later daily load curve, shows a larger gap between the peak and bottom loads than the older daily load curve, or the blue line in the figure. This change is considered consistent with the two hypotheses discussed about the monthly peak load.

Another significant difference between the new and the old load curves is that the new load curve shows a second peak in the morning (7:00) besides the highest peak in the evening (19:00) while the old daily load curve only shows a maximum demand in the evening and a relatively flat load throughout the daytime. This change is also considered consistent with the increase of electricity consumption for residential use, which by nature has two peaks, breakfast time and dinner time while during the daytime between them, when family members are out for work or study, the power demand is relatively low.




Figure 3-17 Daily Load Curve

Reflecting the changes of load curve, whose shape is getting steeper both annually and daily, the load factor, which is the ratio of system consumption (MWh) against peak demand (MW), dropped, though not drastically, from 76.1% in FY2002/03 to 71.4% in FY2003/04, but it has seen a slight improvement since then.




Figure 3-18 Annual Load Factor

3.3.5. Power System Losses

ZESCO’s transmission loss is or the difference between the total energy sent out to the network (including power purchase and import) and the bulk delivery (including power wholesale and export), against the total energy sent out. The transmission loss has been kept stable and low at 3% since late 1980s.

Distribution loss, is the difference between the bulk delivery (only to ZESCO’s distribution network) and end-user consumption metered by ZESCO. The distribution losses has seen a reduction since FY2000/01, but increased again in FY2006/07.

The total system energy losses, which comprise both transmission losses and distribution losses, is between transmission loss rate and distribution loss rate⁴. This is because that about half of the energy is delivered for wholesale (to CEC, Kansanshi Mining Plc., and First Quantum Minerals Ltd.) and export, both of which are not affected by distribution loss⁵. The gradual increase of total system losses is mainly attributed to the fact that the consumption of ZESCO’s retail customers has grown as a proportion of total energy supply.

⁴ When the energy is mostly, if not all, supplied through distribution lines, total system energy loss rate becomes higher than both transmission and distribution loss rates.

⁵ Except the energy export through ZESCO’s distribution lines to border areas in neighbouring countries, which is minor in total energy supply




Figure 3-19 Transmission/Distribution Loss

3.3.6. Electricity import/Export

As already discussed in Section 3.3.3, balance between electricity supply and demand has been tighter and more dependent on imports than ever.

Figure 3-20 shows ZESCO’s electricity import and export for the previous 4 years, broken down by trading partners⁶. In FY2004/05 ZESCO’s annual electricity import exceeded electricity export, which meant that Zambia that had long been a power exporter in the region turned into a net importer. With the completion of some Power Rehabilitation Projects (PRPs), ZESCO gained additional electricity supply and returned to the status of net exporter in FY2005/06.

ESKOM of South Africa was ZESCO’s largest trading partner in both import and export. ZESCO’s exports to ESKOM increased in FY2006/07 after the decreasing trend for the past years. Export to ZESA of Zimbabwe was a rapidly increasing trend, and was related to the serious shortfall of supply in Zimbabwe.

⁶ The import and export data in this chart are different from those in Figure 3-15, which includes ZESCO’s energy loss caused by wheeling (from SNEL to ZESA and ESKOM) and so on.




Figure 3-20 Electricity Import / Export

The main reason why Zambia needed to import electricity despite its inherent capacity to export was the hourly mismatch between domestic power demand and generation capacity in Zambia. Figure 3-21 shows the comparison between the annual peak demand and the year’s available capacity of power plants on the national grid⁷. In FY2004/05, the national grid recorded the peak demand of 1,294MW; but the generation capacity (1,148MW) covered only 88.7%, ZESCO had to import the deficit during peak hours. In FY2005/06 and FY2006/07, with the completion of rehabilitation projects, the generation capacity became higher than the peak demand, but the margin was insufficient when transmission losses (3-4%) and an operation reserve were taken into account. Therefore imports during peak hours were still needed. At the same time, there was sufficient capacity during off-peak hours for Zambia to export..




Figure 3-21 Annual Peak Demand and Available Capacity (national grid)

⁷ ZESCO’s small hydropower stations and CEC’s gas turbine stations are not considered because they are not expected to work with full capacity to cover the peak demand of the whole grid.

The unit cost of the base-load exports was much less than the unit cost of the peak-load imports. As shown in Figure 3-23, ZESCO’s average export price is lower than 30 K/kWh until FY2004/05, much lower than its average unit cost, though it increased to about 70 K/kWh in FY2005/06, while the average import price is estimated at much higher than that⁸ though the specific information was not available to the Study Team. In other words, the value of exports was much less than the cost of imports.

Despite ZESCO’s diminishing excess for export, Zambia’s role as a hub of electricity supply in the region, namely Southern African Power Pool (SAPP), the regional power trading framework, is expected to gain importance in the future. ZESCO’s transmission lines that run across the country from Copperbelt to Livingstone, is not only a backbone of the country’s power system but also a part of international connection that wheels electricity generated in DR Congo to Zimbabwe and South Africa, the power importers. ZESCO is planning to extend 330kV transmission lines to North-Western Province to build another inter-connector with DR Congo and to enhance international power trade. In addition, studies on the extension of 220kV lines from Livingstone to Namibia, the Zambia-Tanzania-Kenya (ZTK) Interconnection Project, and interconnection with Malawi were underway (refer to Figure 3-22). These grid extension projects were also expected to enhance the capacity and stability of electricity supply to remote area in North-Western, Western, Northern, and Eastern Provinces.




Figure 3-22 Southern African Power Pool Interconnection

⁸ According to ZESCO’s financial statements of FY2005/06, the year’s cost of sales is K149,487 million, which is supposed to mainly consist of electricity import and purchase because ZESCO expenses very small amount on fossil fuel. Meanwhile, ZESCO imported 195GWh and purchased 139GWh for the year, thus the unit imported and purchased price is estimated at 448 K/kWh. In the same way, the unit imported and purchased prices for FY2004/05, FY2003/04 and FY2002/03 are estimated at 262 K/kWh, 417 K/kWh and 388 K/kWh respectively.

3.4. Electricity Tariff

3.4.1. Electricity Tariff Structure

Section 7 of the Electricity Act, CAP433 of the laws of Zambia, states that charges made by “an undertaking”, i.e. ZESCO or any other electricity service companies if they exist, “shall be determined in accordance with the licence governing the undertaking”. Therefore, ZESCO’s tariff to its customers, except those to whom ZESCO provides bulk supply, is regulated and needs the approval of the Energy Regulation Board (ERB). Section 8 of the Electricity Act states that “an undertaking” needs to give notice of any proposal to vary or alter the charges, which comes into effect 30 days after the notice unless the consumer applies to ERB to review the proposal.”

Table 3-10 was ZESCO’s revised tariff, proposed and implemented in October 2007. Unlike the previous tariff revision in May 2005, where 11% increase was applied to all customer categories, this time different increase rate was applied to each customer category; 45% for residential, 49-50% for commercial and social services, and 70-75% for large customers, thus the impact of tariff increase is slightly mitigated for households compared to other categories.

Table 3-10 ZESCO’s Revised Tariff (implemented in October 2007)

1. UNMETERED RESIDENTIAL TARIFFS		Current Tariff	Old Tariff
Consumption up to 2 Amps	(K/month)	7,121	4,911
Consumption between 2-15 Amps	(K/month)	25,767	17,770
2. METERED RESIDENTIAL TARIFFS (Capacity up to 15kVA)		Current Tariff	Old Tariff
Energy charge	up to 300kWh (K/kWh)	102	70
	301 to 700kWh (K/kWh)	145	100
	above 700kWh (K/kWh)	236	163
Fixed monthly charge	(K/month)	8,475	5,845
Pre-paid (Energy charge)	(K/kWh)	161	111
3. COMMERCIAL TARIFFS⁹ (Capacity up to 15kVA)		Current Tariff	Old Tariff
Energy charge	(K/kWh)	245	163
Fixed monthly charge	(K/month)	43,841	29,227
4. SOCIAL SERVICES TARIFFS¹⁰		Current Tariff	Old Tariff
Energy charge	(K/kWh)	201	135
Fixed monthly charge	(K/month)	34,839	23,382
5. MAXIMUM DEMAND TARIFFS		Current Tariff	Old Tariff
MD1: Capacity between 16 - 300kVA			
MD charge	(K/kVA/month)	11,803	6,943
Energy charge	(K/kWh)	170	100
Fixed monthly charge	(K/month)	115,603	68,200
MD2: Capacity between 300-2,000kVA			
MD charge	(K/kVA/month)	22,083	12,990
Energy charge	(K/kWh)	145	85
Fixed monthly charge	(K/month)	231,205	136,003
MD3: Capacity between 2,00-7,500kVA			
MD charge	(K/kVA/month)	34,277	19,587
Energy charge	(K/kWh)	110	63
Fixed monthly charge	(K/month)	476,011	272,006
MD4: Capacity above 7,500kVA			
MD charge	(K/kVA/month)	34,468	19,696
Energy charge	(K/kWh)	91	52
Fixed monthly charge	(K/month)	952,021	544,012

⁹ “Commercial” here includes industrial and agricultural energy usage.

¹⁰ Schools, hospitals, orphanages, churches, water pumping, street lighting etc.

Customers who were not metered were charged monthly fixed tariff. According to ZESCO, Northern Regional Office, about 30% of customers of its service area in Northern Province¹¹ were not metered.

For metered customers whose capacity did not exceed 15kVA, ZESCO offered three different tariffs depending on customer class, that is, residential, commercial, and social services. The tariff for each of these consists of monthly fixed charge (K/month) and energy charge (K/kWh). The same fixed charge applies to all three classes. The unit energy price for residential customers increases progressively with three steps, that is, 70 K/kWh for the first 300kWh consumption, 100 K/kWh for the next 400kWh consumption (301-700kWh), and 163 K/kWh for the consumption above 700kWh. This progressive unit price system for residential customers is commonly adopted in many countries, for the following reasons:

- To mitigate the burden of poor households
- To encourage energy conservation and to restrain waste (in some countries where energy conservation is a policy priority issue)

Thus the first threshold (between the first and the second lowest steps) is usually set at a level that is considered to be the minimum monthly electricity consumption for a household's subsistence. Typically this is between 20 kWh and 50 kWh per month in developing countries. In Japan where the assumed "lowest level of lifestyle for subsistence" is higher than in developing countries, this first threshold is 120 kWh/month. In the ZESCO's tariff system, the first threshold was set at 300 kWh/month, which is higher than generally adopted in other countries. This is equivalent to the second threshold in Japan¹², where "300kWh/month" approximately corresponds to an average electricity consumption of a household. ZESCO referred to the low unit price for the first 300 kWh "Life-line Tariff", justified on the basis that, "the 300 units are enough to use in a 2 to 3 roomed house. The units can be used for cooking on a 2 plate cooker, radio and lighting"¹³. For "Commercial" and "Social Services" customer types, only a single unit energy price is applied respectively regardless of monthly consumption.

ZESCO's tariff for large customers, whose capacity is more than 15kVA, is called "Maximum Demand Tariff (MD)", and consists of three parts, that is, fixed monthly charge (K/month, for each customer), MD charge (K/kVA/month), and energy charge (K/kWh). MD Tariff has four sub-categories depending on the capacity, namely MD1 (capacity 16-300kVA), MD2 (301-2,000kVA), MD3 (2,001-7,500kVA) and MD4 (above 7,500kVA), and different tariff is applied to each category.

Since in Zambia the source of energy supply is almost entirely from hydropower, there is no automatic adjustment of the unit energy price with fluctuations of fuel costs.

In addition to the price in the electricity tariff, customers were also charged a Government Excise Duty, which was 5% of every electricity bill, and 17.5% VAT. Of the Government Excise Duty, 3% was appropriated for the Rural Electrification Fund (REF, also refer to Section 3.2).

The graphs in Figure 3-23 show ZESCO's average selling price to different customer categories¹⁴, such as "Residential", "Non-residential (ZESCO retail)", "Bulk Sales to Mining Industry (CEC etc.)", and "Export", together with the average cost of electricity supply¹⁵ as bar chart in background. As

¹¹ The service area of ZESCO's Northern Regional Office is not exactly the same as the area of Northern Province. A part of the province is covered by Luapula Regional Office.

¹² 9 out of Japan's 10 power utilities set this second threshold at "300kWh/month", while the Hokkaido Electric Power Company, the only exception, set this threshold at "280kWh/month" that also used to be the standard for other 9 utilities until 1990s. "120kWh/month" has been uniformly adopted by all Japanese utilities since the three-steps progressive unit price was applied in Japan in mid-1970s.

¹³ Source: ZESCO Website <http://www.zesco.co.zm/why-pay-for-elec.html>

¹⁴ ZESCO's "Statistics Yearbook of Electric Energy" changed the classification of power consumption from its "2005/06" edition. For this reason, data of average selling price for FY2005/06 may not be consistent with those in the past.

¹⁵ Definition of "Cost of Electricity Supply" is same as that of Figure 3-27 to be discussed in Section 3.5.1.

observed in the Figure, average selling price for residential customers is relatively low, even lower than the average cost of electricity supply. On the other hand, average selling price to customers other than residential, such as commercial, industrial and agricultural customers, is far higher than that of residential customers and the average cost of electricity supply. A significant gap between residential and non-residential selling prices is also confirmed in the tariff table (Table 3-10), according to which “Commercial Tariffs” must always be higher than “Metered Residential Tariffs” with same electricity consumption. Taking into consideration that the average unit selling price of residential customers would be by nature a little higher than that of non-residential customers if the tariffs were set strictly reflecting the marginal unit cost of supply¹⁶, we can observe the existence of cross-subsidization from non-residential tariff to residential tariff to benefit residential customers while total revenue balances with total cost of supply. This cross-subsidization, however, should be evaluated taking into account the residential customers’ affordability to pay for electricity.




Figure 3-23 Average Selling Price

¹⁶ Almost all residential customers are supplied with low-voltage (400/230V) and thus have to pay the cost of using low-voltage distribution lines while many non-residential customers do not need to share the cost of low-voltage lines because they are supplied electricity from 11kV distribution lines. In addition, load factor of non-residential customers, especially industrial, is generally apt to be higher than that of residential customers, and high load factor helps reduce average fixed cost (= fixed cost divided by electricity consumption).

3.4.2. Metering and Billing

In common with the practice in other countries, electricity consumption of ZESCO’s metered customers have their meters read at regular intervals, and a bill is issued to each customer monthly. ZESCO’s meter readers, called “Client Service Accounts Assistants (CSAA)” off-load the metered data to ZESCO’s customer database at District Office, which is linked to the company’s billing system. According to ZESCO, this “metering – billing” process takes a few days to complete. In some regions, especially in urban area, ZESCO started using a handheld metering terminal so that the collected readings are easily off-loaded to the customer database.

Electricity bills may be paid either in cash or by cheque at ZESCO’s Customer Service Centres or it is also possible to debit the amount automatically from a customers’ bank account. ZESCO is encouraging the customers to make use of this Direct Debit and Credit Clearing (DDACC) service, offering incentives that include a 5% discount on the bill.

ZESCO’s power cut policy against customers who fail to pay electricity bills is generally the same as the one adopted by power utilities of other countries. Customers that fail to pay bills for more than two months receive a notice of disconnection. Another notice to urge the payment may be issued again 48 hours prior to the disconnection in some cases. Disconnected customers have to pay at least 75% of the total bill, together with some penalties, for reconnection. The remaining 25% of the bill has to be paid within 3 months for supply to be maintained. Figure 3-24 illustrates a workflow of ZESCO’s Power Cut Policy¹⁷, though actual implementation of the policy might be more flexible case by case.




Figure 3-24 ZESCO’s Powercut Workflow

Figure 3-25 shows ZESCO’s trade receivables, i.e. uncollected revenue that is accounted for as current assets in balance sheet, for the past 5 years, and its annual increase or decrease. In FY 2001/02 the trade receivables increased by K175 billion (about +50%) and the remaining balance reached K524 billion, which reached almost the same amount as ZESCO’s revenue of that year (K537 billion). In other words, about one third of ZESCO’s revenue of that year was not collected. It was not until then that ZESCO seriously took on managing non-performing trade receivables.

There are two factors that affect the increase and decrease of trade receivables:

- Failure to collect revenue of the year (= increase) or collection of trade receivables in the past (= decrease)
- Writing-off of a part of trade receivables as “provisions for doubtful debt”, which is accounted for as “loss” in income statement (= decrease)

ZESCO continuously needs to write off a part of its trade receivables that it does not expect to be able

¹⁷ Source: ZESCO Website <http://www.zesco.co.zm/p-cut.html>

to collect in the future by offsetting this with the profit, in order to prevent the swelling of non-performing assets.

The bar chart in the lower half of Figure 3-25 is the breakdown of increase/decrease of trade receivables by abovementioned factors. During FY2002/03 ZESCO's trade receivables decreased by K183 billion, which is mostly due to ZESCO's writing-off of K180 billion trade receivables. This K180 billion is equal to 28% of ZESCO's total revenue of the year and roughly corresponds to the huge increase of trade receivables in the previous fiscal year (K175 billion). ZESCO wrote off K140 billion out of K180 billion through "Debt Swap" with GRZ, by which ZESCO's receivables from GRZ were offset with the interest-bearing borrowings that the company owed to GRZ. Improvement of revenue collection also helped the decrease of trade receivables in FY2002/03: this -K3 billion appears modest compared to the remaining amount, but is a remarkable improvement taking into account the rapidly worsened revenue collection in the past. Since then, outstanding trade receivables have been kept relatively stable.

In order to enhance revenue collection and thus to reduce trade receivables, ZESCO embarked on a project to install prepayment meters. The pilot scheme started in 2002 with 1,000 customers in Lusaka, and in March 2006 the project moved on to Phase 1, in which 24,000 prepaid meters were installed.




Figure 3-25 Increase / Decrease of ZESCO's Trade Receivables

3.5. Financial Status of the Power Sector

3.5.1. Financial Status of ZESCO

(1) Electricity Revenue and Cost

In line with the growth of electricity demand, ZESCO’s annual revenue has seen a rapid increase, with 82% growth from K477 billion in FY2000/01 to K869 billion in FY2006/07. The increase in revenue owes considerably to the mining sector (mostly CEC), which accounts for about half of ZESCO’s total revenue. The dip of total revenue in FY2005/06, decreasing from K783 billion in the previous year, is mainly due to the -8% drop in the revenue from mining sector (K374 billion). The revenue from mining sector decreased despite the steady increase of the sector’s electricity consumption (3.5% increase from 3,952GWh in FY2004/05 to 4,091GWh in FY2005/06: refer to Figure 3-14). The dip was caused by the fact that the CEC tariff was denominated in US\$ and for that year the Zambia Kwacha appreciated against US\$, thus decreasing the Kwacha revenues. Similarly, the Kwacha’s depreciation against US\$ in FY2006/07 raised ZESCO’s revenue from mining sector of the year, as well as its total revenue. Revenue from ZESCO’s retail customers, i.e. revenue excluding export and mining, continued increasing as a whole, though there has been some fluctuation for each customer category.




Figure 3-26 ZESCO’s Annual Revenue

ZESCO’s total cost of electricity supply, which comprises not only direct costs (e.g. power purchase, import, fuel cost) but also indirect costs (e.g. staff costs, depreciation, financial costs) and taxation, is shown in Figure 3-27. A conspicuous increase can be seen in staff costs, swelling about 3.8 times from K115 billion in FY 2000/01 to K430 billion in FY2006/07, despite that the number of employees decreased from 3,963 as at end of FY 2000/01 to 3,603 as at end of FY2006/07. According to ZESCO, the growth of staff cost is due to the increase of temporary employees who are not counted in the “number of employees”, and to the rise in their unit cost following the Government’s instruction. The financial cost decreased from K49 billion in FY 2001/02 to K21 billion in FY2006/07, which is due to the company’s reduced dependence on bridging loans such as bank overdraft and short-term borrowings that have high interest rates. The total cost of supply is also affected by foreign exchange gains/losses (changed from K183 gain in FY2005/06 to K173 loss in FY2006/07), which mainly derives from the fluctuation in Kwacha value of long-term loans.




Figure 3-27 Total Cost of Electricity Supply

The difference between annual revenue (Figure 3-26) and total cost (Figure 3-27) is equal to “profit after taxation”. In FY 2006/07, ZESCO made the loss of K156 billion, which is mainly due to the abovementioned huge foreign exchange loss, but it should be noted that ZESCO’s profitability fundamentals have been weak even without foreign exchange effects considering that the operating profit/loss subtracting foreign exchange gain/loss was negative in FY2005/06 and FY2006/07.

ZESCO’s financial statements are summarized in Table 3-11.

Table 3-11 Summary of ZESCO’s Financial Statements

	2000/01	2001/02	2002/03	2003/04	2004/05	2005/06	2006/07
Turnover (A)	477,398	536,583	646,515	717,373	782,641	768,915	868,725
Cost of Sales (B)	96,359	106,355	138,954	176,362	-168,384	149,487	163,011
Gross Profit (C) = (A) - (B)	381,039	430,228	507,561	541,011	614,257	619,428	705,714
Other Operating Costs (D) *	267,644	358,182	388,852	452,444	563,141	489,207	902,650
Operating Profit (E) = (C) - (D)	113,395	72,046	118,709	88,567	51,116	130,221	-196,936
Financial Cost (F)	33,870	49,277	15,764	12,063	15,412	11,070	21,276
Exceptional Items (G)	-	8,395	-	-	-	-	-
Profit before Tax (H)=(E)-(F)-(G)	79,525	14,374	102,945	76,504	35,704	119,151	-218,212
Taxation (I)	41,420	47,151	37,732	34,828	71	76,812	-62,117
Profit after Tax (J) = (H) - (I)	38,105	-32,777	65,213	41,676	35,633	42,339	-156,095
Assets (K)	1,831,680	2,133,633	2,271,147	2,636,002	3,499,240	3,693,644	3,979,596
ROA = (E) / average(K) **	6.4%	3.6%	5.4%	3.6%	1.7%	3.6%	-5.1%
Equities	1,271,965	1,239,188	1,276,535	1,303,211	1,688,291	1,730,630	1,574,535
Liabilities	559,715	894,445	994,612	1,332,791	1,810,949	1,963,014	2,405,061

Source: ZESCO Financial Statements

Note: Miscellaneous incomes (e.g. interest income) are subtracted in “Other Operating Costs”
 ROA = Operating profit / {(this year’s total asset + previous year’s total assets) / 2}

(2) Capital Structure

ZESCO spent heavily on capital projects such as rehabilitation of hydropower stations, which led to the rapid growth of total assets (more than twice from K1,832 billion in FY2000/01 to K3,980 billion in FY2006/07). Little of the capital expenditure was covered by ZESCO’s own funds¹⁸, as shown in Figure 3-28. The company’s financing has been dependent on liabilities, such as borrowings, capital grants and customers’ contribution, than equities, which is evidenced as a gradually worsening Debt/Equity ratio seen in Figure 3-29.




Figure 3-28 Capital Investment Financing





Figure 3-29 ZESCO's Capital Structure (Equities & Liabilities)

¹⁸ Here defined as “Operating cash flow + Disposal of tangible assets + Interest received” in the cash flow statement

(3) International Comparison (Profitability Indicator)


Figure 3-30 and Figure 3-31 show ZESCO’s return on assets (ROA) and return on equity (ROE) for the past 4 years, in comparison with that of ESKOM (South Africa)¹⁹ and KPLC/KenGen (Kenya)²⁰, who have relatively advanced management in the region and disclose their financial statements to the public. Both ROA and ROE show a similar trend. ESKOM, the largest power utility in Africa, keeps around 8-12% of ROA and ROE, and has the highest profitability among these three countries. The profitability of Kenyan sector is at close level to that of ZESCO’s, but while Kenya’s electricity sector has steadily improved profitability, ZESCO’s profitability has seen a decreasing trend.



Source: Financial Statements of each company

Figure 3-30 Return on Assets (ROA) – International Comparison

Note: ROA = Operating profit / {(this year’s total asset + previous year’s total assets) / 2}



Source: Financial Statements of each company

Figure 3-31 Return on Equity (ROE) – International Comparison

Note: ROE = Profit after tax / {(this year’s shareholders’ equities + previous year’s shareholders’ equities) / 2}

¹⁹ ESKOM shifted its fiscal year from “January-December” to “April-March” in 2004, and FY2004/05 as transition period lasted irregularly 15-months long (Jan 2004-Mar 2005). ESKOM’s indicators of FY2004/05 were amended to 12-months base for comparison.

²⁰ Kenya’s electricity sector has two major utilities, KPLC (transmission/distribution) and KenGen (generation). For evaluating the performance of power sector as a “vertically integrated utility”, financial statements of these two utilities are consolidated by offsetting transactions between them. Kenya’s fiscal year starts 1st July and ends 30th June.

3.5.2. Financial Status of Other Players in the Sector

(1) Copperbelt Energy Corporation (CEC)

Copperbelt Energy Corporation Plc (CEC) also publicizes its financial statements annually like ZESCO. CEC, which used to be a division of the defunct Zambia Consolidated Copper Mines (ZCCM), the Government-led company, and whose revenue mostly depends on the mining industry, the largest export industry of Zambia, records its financial statements in US\$. The unit prices of power purchase from ZESCO and sales to its customers are also set in US\$, which means that mining companies, whose cost of production depends a lot on electricity, hedges the risk of exchange rate fluctuation regarding electricity cost in US\$ value, and so does CEC the cost of power purchase from ZESCO, and as a result the risk is borne by ZESCO in the end, which is evidenced as the dip in ZESCO's revenue in FY2005/06 (refer to Section 3.5.1). CEC's unit selling price to its customers was around 3US\$/kWh for some years in the past.

Table 3-12 CEC's Electricity Demand and Sales

	2001	2002	2003	2004	2005
Maximum Demand (MW)	451.70	475.86	491.31	505.08	503.89
Electricity Sales to Customers (GWh)	3,354	3,578	3,689	3,818	3,734
Unit Selling Price (US\$/kWh)	3.15	3.08	3.11	3.15	3.27

Source: CEC Financial Statements

Table 3-13 is the summary of CEC's financial statements for the past 5 years. The gross profit margin, i.e. the ratio of gross profit against revenue, has been stable at around 30%. This fact indicates that CEC's selling price to its customers is linked to the purchase price from ZESCO, which accounts for most of CEC's cost of sales, so that CEC receives 30% gross profit margin.

Table 3-13 Summary of CEC's Financial Statements

	2001	2002	2003	2004	2005
	(1,000 US\$)				
Revenue (A)	105,624	110,128	114,874	120,348	122,164
Cost of Sales (B)	73,217	78,506	82,097	85,239	85,797
Gross Profit (C) = (A)–(B)	32,407	31,622	32,777	35,109	36,367
Gross Profit Margin (C) / (A)	30.7%	28.7%	28.5%	29.2%	29.8%
Other Operating Costs (D)	17,397	7,469	17,551	16,444	21,127
Operating Profit (E) = (C)–(D)	15,010	24,153	15,226	18,665	15,240
Profit after Tax (F)	8,547	15,012	10,069	11,842	8,241
Dividends (G)	18,000	25,000	20,000	20,500	9,900
Payout Ratio = (G) / (F)	211%	167%	199%	173%	120%
Assets (H)	168,574	157,123	148,566	142,361	136,505
ROA = (E) / average(H)*	N.A.	14.8%	10.0%	12.8%	10.9%

Source: CEC Financial Statements

Another issue to be noted regarding the financial statements is that CEC's payout ratio, which is the ratio of dividends for shareholders against profit after tax, has been higher than 100%, which means that CEC has paid higher dividends than a year's profit retained for shareholders. The additional source of high dividends derives from the following:

- Depreciation of fixed assets: CEC's annual capital investment has been almost below the depreciation of the year
- Collection of trade receivables in the past

Return on Assets (ROA) of CEC for the past 4 years has been above 10%, which is by far higher than that of ZESCO during the same period (1.7%–5.4%).

CEC plays an important role in Zambia's electricity sector, not only because CEC purchases about half of ZESCO's electricity sales but also it owns a part of transmission lines interconnected with DR Congo to wheel electricity from DR Congo to Zimbabwe and South Africa and, in part, Zambia. In February 2006, Zambian Energy Corporation (Zam-En), a consortium of Zambian and foreign investors, acquired 77% stake in CEC from National Grid of the United Kingdom and Cinergy Global Power of the United States. The remaining shares are owned by the Zambian Government through ZCCM-Investment Holdings Plc (20%) and Local Technical Team of Power Division (3%).

(2) Others

Other players in Zambia's electricity sector, such as Lunsemfwa Hydro Power Company, an IPP in which ESKOM of South Africa has 51% stake, and some small ESCOs that install solar home systems on customers' premises, do not disclose their financial statements. According to an interview that the Study Team had with some ESCOs operating in Eastern Province, their financial performance has been worsening due to the sluggish revenue collection.

Chapter 4

**Current Situation
of
Rural Society**

Chapter 4. Current Situation of Rural Society

4.1. Functions of Rural Growth Centres and Local Communities

Villages in Zambia are in general located along the roads and rivers. A typical rural village consists of group of houses and in many cases does not include core facilities, such as schools, clinics, churches, and market. The style of these villages reflects cultural factors especially the long-established tradition by which relatives tend to live together. Government has defined a Rural Growth Centres (RGC) as a rural locality with a high concentration of residential settlements and which is the centre of rural economic activities. An RGC provides services to residents of the RGC and those in the catchment area (CA) that surrounds the RGC. Typically people go to an RGC in order to sell their agricultural produce and handicrafts, to purchase daily necessities and to access public services (refer to Figure 4-1).




Figure 4-1 Concept of Rural Growth Centre and Catchment Area

In addition to the grocery shops and markets found at RGCs, there are also electrified hammer mills, which are used to produce maize meal for making “Nsima”, the Zambian staple. In larger RGCs, there are also small factories, restaurants, bars and other social services. The RGCs function as a centre of daily life and activities in rural areas. Among the residents of the RGC are to be found public workers like doctors, nurses, teachers and police officers.

Local community groups have been established and they operate from public places like community halls or recreation centres within RGCs. In many cases, there are also local community groups that contribute to the development of infrastructure and public facilities, acting as recipient organizations of funds from NGOs and international donors.

For example, the Zambia Social Investment Fund (ZAMSIF), established with the assistance of the World Bank, supports the development of infrastructure like schools, clinics, boreholes, roads and bridges. In order to receive funds from ZAMSIF, the resident community establishes a committee for each project, known as the ZAMSIF Project Management Committee. Besides receiving

construction materials from ZAMSIF, the Committee is required to provide a construction labour force drawn from the villages and to contribute any necessary additional materials. On completion, the maintenance of the facility is primarily the responsibility of the Committee; however the Zambian government dispatches salaried doctors for newly constructed clinics and teachers for newly constructed schools. This model could be adapted for rural electrification projects by entrusting a village cooperative with the operation and maintenance works of electric facilities and/or tariff collection.

The size of the CA seems to vary from one district to another: for example, in the North-Western Province a CA is within approximately 8 km radius of the RGC, while that in Eastern Province is within 10 to 16 km radius of the RGC. In addition, for the Eastern Province, a kind of sub-RGC is observed within the CA. This is a much smaller and less developed unit than the main RGC and typically consists of grocery shops only.

4.2. Economic Activity in Rural Areas and Expected Effects after Electrification

Villagers wishing to sell their crops and products at the RGC market pay a fee. They purchase miscellaneous goods at grocery shops, or have their maize ground at electrified hammer mills in the RGCs. It can be expected therefore that there is potential demand in the unelectrified RGCs, from economic activities such as refrigeration in grocery shops and the addition of electric hammer mills.

In unelectrified RGCs, paraffin is utilized as fuel for refrigerators in grocery shops. Supply of stable electricity is expected to provide a strong possibility that paraffin refrigerator users will shift to electric refrigerators. Clinics and dairy farmers in unelectrified RGCs, that store vaccines (for human and livestock respectively) in refrigerators powered by unstable SHS, will also be the beneficiaries of electrification.

In unelectrified RGCs, hammer/maize mills with capacity of about 15kW are driven by privately owned diesel generators, and the owners charge K800 to K3,000 as the fee for grinding a bucket of maize. An increase of hammer/maize mill businesses may be expected if electricity is supplied through by extending the distribution lines at reasonable costs. Price reduction of milling fees, as a result of market competition, may also occur with entrance of mill owners, which is also expected to trigger other secondary impacts.

4.3. Rural Electrification and Energy Consumption

As shown in Table 4-1, the electrification rate for households is 20.3% in Zambia as of 2004. Of the 61% of the population that live in rural areas, only 3.1% currently has access to electricity. Broken down regionally, electrification rate in each Province is as follows in the descending order: 46.1% in Lusaka, 44.3% in Copperbelt, 15.7% in Southern, 12.4% in Central, 11.1% in North Western, 9.6% in Northern, 8.2% in Eastern, 4.4% in Luapula, and 4.2% in Western (refer to Figure 4-2).

Households using kerosene/paraffin as a major source of lighting are 45.7% of total households countrywide. Candle is used by 18.1 % of the households. The remaining are the households using diesel at 7.4%, wood fire at 6.1% and other energy sources at 1.4% for lighting. In rural area, kerosene/paraffin is the most commonly used source of lighting energy with 62.3% of households (especially high in Luapula Province by 80.9% and Northern Province by 70.4%), and diesel is the secondary major source of it. Since fossil fuel is expensive, especially in rural area, kerosene/paraffin and diesel users for their lighting energy are likely to be able to pay for the electricity tariff, once it has become available.

In order to receive electricity supply from ZESCO, however, expensive down payment is charged as the connection fee: Single-phase overhead for K2,873,000 and three-phase overhead for

K4,887,000 in rural area as of 2005. This initial cost is one of the big hurdles for the promotion of rural electrification.

According to the “*Living Conditions Monitoring Survey 2004*” conducted by the Central Statistics Office (CSO), the majority of Zambians (84.9% in rural area and 54.2% in whole country) use collected firewood and only 1.7 % of households in rural area use electricity as their main source of energy for cooking (refer to Table 4-2).

Table 4-1 Percentage Distribution of Households by Main Source of Energy for Lighting

		Kerosene / Paraffin	Electricity	Candle	Diesel	Wood Fire	Others	None	Total	Total No. of Households	% of Total Population
Zambia Total	Total	45.7%	20.3%	18.1%	7.4%	6.1%	1.4%	0.9%	100.0%	2,110,640	100.0%
	Rural	62.3%	3.1%	9.7%	11.6%	9.9%	2.0%	1.5%	100.0%	1,288,065	61.0%
	Urban	19.5%	47.6%	31.5%	0.9%	0.2%	0.3%	0.1%	100.0%	822,575	39.0%
Provinces	Central	53.8%	12.4%	16.8%	13.3%	1.9%	1.3%	0.6%	100.0%	207,197	9.8%
	Copperbelt	29.2%	44.3%	20.7%	4.2%	0.9%	0.6%	0.1%	100.0%	311,712	14.8%
	Eastern	61.3%	8.2%	13.3%	8.7%	5.4%	1.6%	1.5%	100.0%	290,224	13.8%
	Luapula	80.9%	4.4%	4.1%	0.4%	9.5%	0.4%	0.4%	100.0%	171,659	8.1%
	Lusaka	12.6%	46.1%	39.8%	0.5%	0.2%	0.6%	0.2%	100.0%	309,949	14.7%
	Northern	70.4%	9.6%	5.3%	5.3%	7.4%	1.2%	0.9%	100.0%	275,266	13.0%
	North-Western	36.7%	11.1%	14.3%	22.0%	13.7%	1.4%	0.8%	100.0%	125,814	6.0%
	Southern	41.4%	15.7%	19.5%	15.5%	5.3%	1.1%	1.4%	100.0%	252,423	12.0%
Western	39.2%	4.2%	19.3%	4.5%	23.9%	5.5%	3.4%	100.0%	166,219	7.9%	

Source: Living Conditions Monitoring Survey Report 2004
(Central Statistical Office, December 2006)

Table 4-2 Percentage Distribution of Households by Main Source of Energy for Cooking

		Collected Firewood	Purchased Firewood	Own Produced Charcoal	Purchased Charcoal	Coal	Kerosene / Paraffin / Gas	Electricity	Others	Total
Zambia Total	Total	54.2%	1.9%	3.5%	23.8%	0.0%	0.2%	16.2%	0.1%	100.0%
	Rural	84.9%	1.7%	4.7%	6.6%	0.0%	0.2%	1.7%	0.2%	100.0%
	Urban	5.6%	2.2%	1.5%	51.1%	0.0%	0.2%	39.3%	0.0%	100.0%
Provinces	Central	68.2%	1.8%	1.0%	19.4%	0.0%	0.2%	9.3%	0.1%	100.0%
	Copperbelt	16.0%	1.4%	3.6%	41.7%	—	0.2%	37.0%	0.1%	100.0%
	Eastern	76.9%	2.7%	0.5%	14.6%	—	0.3%	4.9%	0.3%	100.0%
	Luapula	45.8%	3.1%	24.0%	24.4%	—	0.1%	2.4%	0.2%	100.0%
	Lusaka	10.7%	0.8%	0.8%	47.3%	0.0%	0.2%	40.2%	0.0%	100.0%
	Northern	75.2%	1.0%	3.2%	14.0%	0.1%	0.2%	6.4%	0.0%	100.0%
	North-Western	71.7%	1.5%	2.3%	15.9%	0.1%	0.5%	7.7%	0.2%	100.0%
	Southern	71.1%	2.5%	0.7%	13.4%	0.1%	0.2%	12.0%	0.1%	100.0%
Western	88.3%	3.8%	0.6%	3.6%	—	0.2%	3.2%	0.4%	100.0%	

Source: Living Conditions Monitoring Survey Report 2004
(Central Statistical Office, December 2006)




Figure 4-2 Electrification Rate (for Lighting) by Province

4.4. Rural Development Plan

The Fifth National Development Plan 2006 - 2010 (FNDP) states that the overall goal of the energy sector is “To ensure availability and accessibility to adequate and reliable supply of energy from various sources at the lowest total economic, social and environmental cost consistent with national development goals of sustained growth, employment generation and poverty reduction.”

Rural development plans, however, tend to be drafted by each District in accordance with the decentralization policy. Thus, all information regarding rural development plans is neither aggregated in the Central Government nor shared among related Ministries/Organizations, such as Ministry of Local Government and Housing, Ministry of Health, Ministry of Education, Ministry of Agriculture and Cooperatives, Ministry of Energy and Water Development, and Rural Electrification Authority. These Ministries involved with the development of rural areas do not possess even basic information, such as number, names, location, and electrification status of RGCs in each District, population and number of households/business entities/public facilities in each RGC, etc. Although the Ministry of Education and the Ministry of Health have plans for the improvement of schools and hospitals/clinics, there is no centralized information regarding rural development plans and very little information is shared among Ministries. In addition, sharing of information regarding rural electrification and arrangements among DoE, REA and ZESCO have not been satisfactorily.

4.5. Selection of Electrification Target

Household access to electricity in the rural areas of Zambia is very low and was estimated as 3.1% in 2004. Even RGCs, which are the centers for rural economic activities and where public facilities such as schools and clinics are in place, are mostly not electrified. Electrification of a RGC

contributes to the growth of the community market and improves the quality of public services such as education and health care that the Zambian government accords high priority. In other words, electrification of an RGC will benefit residents not only in the RGC but also in its CA. In addition, business entities generally have sufficient income to afford the connection fee and the monthly electricity tariff, resulting in a boost to the local economy. Therefore, the first REMP Workshop held in Lusaka in June 2006 resolved that the RGCs shall be the main targets of the Rural Electrification Master Plan.

Three basic strategies, listed below, were defined for executing the Rural Electrification Master Plan Study. The goals were 1) maintaining transparency in the selection of electrification targets, 2) providing equal framework for the electrification of the whole country, and 3) being consistent with national policies of decentralized planning.

- Make a long list of all unelectrified RGCs in the country based on the data submitted from each District
- Verify the electrification priority of RGCs in each district submitted by District planners
- Finalize the electrification priority of all RGCs based on the size of potential demand, economical efficiency, and socio-economical consideration

To compile a comprehensive list of all unelectrified RGCs nation-wide, it was necessary to collect the data of all the existing unelectrified RGCs in each of the 72 Districts. As stated in the previous section, this information is not available anywhere in the Government structure. Therefore, as an important task of this Study, basic demographic data and locations of both electrified and unelectrified RGCs in each District were investigated and compiled in a systematic uniformed format. At the First REMP Workshop held in Lusaka, Data Collection Sheets and Topographic Maps were distributed to each Provincial representative, who then forwarded them to District Planners to fill in the information of unelectrified RGCs that district planners consider should be given priority for electrification. These data sheets were submitted by District Planners during the Second REMP Workshop held at each of 9 Provincial Centres in November 2006 (except the one in Northern Province that was held in August 2006). The location, demographical data and their electrification status, as well as the priority of RGCs for electrification in each District, are specified in the Data Collection Sheets. Among the long list of all 1,217 unelectrified RGCs, the first prioritised RGCs to be electrified in each District, together with their reasons for selection, are short listed in Table 4-3.

The first ranked RGC in each District (except Lusaka District, which is 100% urban area and thus shall be excluded from the Study's target) were also selected as the target of socio-economic survey executed as part of this Study: The seventy-one (71) unelectrified RGCs from each District, together with 19 electrified RGCs, were selected for the field survey. The selection of 19 electrified RGCs, summarized in Table 4-4, was based on the information (such as locations and duration after electrification) provided by ZESCO Regional Offices in parallel with the Provincial Workshops. Information of these electrified RGCs also needed to be checked thoroughly in order to develop profiles of electricity consumption from which estimates of potential electricity demand of unelectrified RGCs would be derived. Through the said processes, 90 RGCs in total were selected as survey targets. The main informants interviewed and the sample RGCs are summarized in Table 4-5.

Table 4-3 Unelectrified Rural Growth Centres with the Highest Priority in Each District

	District	Ward	Rural Growth Centre	Reasons for Selection
Central Province	1 Chibombo	Kakoma	Shimukuni	Population, schools, health, trading, farming (food reserve & tobacco Scheme), access road, distance from existing distribution line
	2 Kabwe	Mpima	Mpima	Schools, health, social services, farming (food reserve, irrigation), access road, distance from existing distribution line
	3 Kapiri Mposhi	Luanchele	Chipepo	School, chief palace, local court, rural health, agricultural activities
	4 Mkushi	Kamimbya	Old Mkushi	Population, schools, health, gem stone mining, shops/social services, farming (food reserve & tobacco Scheme), police post, access road, distance from existing distribution line
	5 Mumbwa	Kalwanyembe	Mumbwa Big Concession	Farming, mining, population, schools, rural health centres, tourism
	6 Serenje	Chibale	Chibale	Population, schools, health, shops/social services, farming (food reserve & tobacco Scheme)
Copperbelt Province	7 Chiliabombwe	Anoya Zulu	Mungomba	Population, schools, health, community centre, Farming/farming (food reserve), access road, distance from existing distribution line
	8 Chingola	Kapisha	Kamiteta	Population, schools, Farm Block/farming, Cooperative, access road
	9 Kalulushi	Ichimpe	Kameme	Schools, health, Farm Block, agriculture, access road
	10 Kitwe	Limaposa	Kakolo	Schools, health, community centre, orphanage, NGO cooperative for farmers, access road, distance from existing distribution line
	11 Luanshya	Chitwi	Kafubu	Population, schools, health, community centre, Farming Block/farming, Farmers Union
	12 Lufwanyama	(N.A.)	Emerald Mining Area	Mining emerald, schools, health, clubs cooperative, access road, shops/social services
	13 Masaiti	Mutaba	Mutaba	Population, schools, health, shops/social services, farmers cooperative (women's) access road
	14 Mpongwe	Mikata	Mikata	Schools, health, shops/social services, farming/cooperatives, distance from existing distribution line
15 Mufulira	Mutundu	Mutundu North	Schools, health, shops/business, cooperative Farm Block, access road	
16 Ndola	Kavu	Kanglonga	Schools, health, shops/businesses, Farm Block/farming cooperative, access road, distance from existing distribution line	
Eastern Province	17 Chadiza	Kamini	Mlolo	Population, schools, health, shops/businesses, resettlement scheme, farming cooperative, access road
	18 Chama	Kalinkhu	Kalinkhu	Population, schools, health, shops/businesses, hammer mill, farmers cooperative
	19 Chipata	(N.A.)	Chiparamba	Population, schools, health, social services, farming (food reserve & tobacco scheme), access road, distance from existing distribution line
	20 Katete	Kapangulula	Kagoro	Population, schools, health, shops/businesses, farm block, farmers union, food reserve, tobacco scheme, access road
	21 Lundazi	Chimaliro	Mwase	Population, schools, health, shops/businesses, hammer mills, NGO farmers cooperative,
	22 Mambwe	Mphomwa	Mphomwa Tse-tse	Schools, shops/businesses, farmers cooperative, access road distribution line
	23 Nyimba	Ngozi	Chipembe	Population, secondary schools, shops/businesses, restaurants, small factories, farmers cooperative, access road, distance from existing distribution line
	24 Petauke	Matambazi	Kapungwe	Population, schools, shops, farm block, farmers cooperative, access road from existing distribution line
Luapula Province	25 Chiengi	Lunchinda	Lupiya	Schools, shops/businesses, hammer mills, farm blocks, farmers cooperatives, access road,
	26 Kawambwa	Mulunda	Chama	Population, schools/health, shops/businesses, hammer mill, farm block, access road,
	27 Mansa	Chibeleka	Kasongwa Sub Boma	Population, schools/health, shops/businesses, hammer mill, farmers cooperatives, access road
	28 Milenge	Mikula	Tayali	Population, schools/health, shops/businesses, hammer mill, farmers cooperatives, access road
	29 Mwense	Mpasa	Katuta	Schools/health, shops, hammer mill, farm block, farmers cooperatives, access road
	30 Nchelenge	Chilongo	Chilongo	Population, schools, small factory, hammer mill, access road
31 Samfya	Kapata	Chinsanka	Population, primary schools, shops/businesses/market, hammer mill, farm block, farmers cooperatives, access road distribution line	
Lusaka Province	32 Chongwe	Bunda Bunda	Chinyunyu	Schools/health, shops/businesses, market, hammer mill, farm block, farmers cooperatives, access road, distance from existing distribution line
	33 Kafue	Malundu	Chipapa	Population, schools/health, shops/businesses, market, hammer mill, farm block, farmers cooperatives, access road, distance from existing distribution line
	34 Luangwa	Dzalo	Luangwa Boma	Population, schools/health, shops/businesses, hammer mill, farm block, farmers cooperatives, access road, distance from existing distribution line
	- Lusaka	-	-	* No candidate RGC was selected from Lusaka District, where 100% of the population lives in "urban" area.
Northern Province	35 Chilubi	Santa Maria	Kambashi	Schools/health, shops/businesses, fishing, small industries, hammer mill, distance from existing distribution line
	36 Chinsali	Mukumbi	Shiwangandu	Micro-hydro potential, population, schools/health, shops/businesses/small industries, tourism, hammer mill, farmers cooperative, access road, distance from existing distribution line
	37 Isoka	Kalansa	Muyombe	Schools/health, shops/businesses/markets, hammer mill, access road
	38 Kaputa	(N.A.)	Nsama Sub Boma	(No info available)
	39 Kasama	Musowa	Kachuma	Population, schools, shops, hammer mill, farm block, farmers cooperatives, access road
	40 Luwingu	(N.A.)	Masonde	(No info available)
	41 Mbala	Lapisha	Chimula	Population, schools/health, shops/businesses, hammer mill, farm block, farmers cooperatives, access road
	42 Mpika	Chibwa	Kanchibiya	Schools/health, shops/businesses, hammer mill, farm block, farmers cooperatives, access road
	43 Mporokoso	Kalungwishi	Mukupakaoma	Micro-hydro potential, population, schools/health, shops/businesses/markets, hammer mill, farm block, farmers cooperatives
	44 Mpulungu	Kapembwa	Kasaba Bay	(No info available)
45 Mungwi	Mpanda	Makasa	Schools/health, shops/businesses, farmers cooperatives, (food reserve & tobacco Scheme), access road, distance from existing distribution line	
46 Nakonde	Isunda	Wulongo	Population, schools/health, shops/businesses, hammer mill, farm block, farmers cooperatives, access road, distance from existing distribution line	
North-Western Province	47 Chavuma	Chivombo	Chivombo	Micro-hydro potential, Population, schools/health, shops, hammer mill, farm block, farmers cooperatives, access road, distance from existing distribution line
	48 Kabompo	Kashinakazhi	Kashinakazhi	Population, schools/health, shops/market, farmers cooperatives, access road
	49 Kasempa	Nselauke	Nselauke	Population, schools/health, shops/businesses/market, hammer mill, farmers cooperatives, access road, distance from existing distribution line
	50 Mufumbwe	Matushi	Matushi	Population, schools/health, shops/market, hammer mill, farm block, farmers cooperatives, access road, distance from existing distribution line
	51 Mwinilunga	Ntambu	Ntambu	Micro-hydro potential, population, schools/health, shops/businesses/markets, hammer mill, farmers cooperatives, access road
	52 Solwezi	Mumena	Mumena	Population, schools/health, shops/businesses/market, hammer mill
	53 Zambezi	Chitokoloki	Chitokoloki	Micro-hydro potential, population, schools/health, shops/businesses/market/small factory, hammer mill, farm block, farmers cooperatives, access road
Southern Province	54 Choma	Hamaundu	Kachomba	Population, schools, Courts, health, community centre, farming (food reserve), access road
	55 Gwembe	Chibuwe	Siabwengo	Fishing camp, schools, health, social services, distance from existing distribution line
	56 Itezhi-tezhi	Lubanda	Lubanda	Schools, health, social services, Farm Block/farming, food reserve, agric camp, Vet Camp, groceries/shops, hammer mills
	57 Kalomo	Mbwiko	Napatizya	Schools, health, social services, Farm Block/farming, food reserve, agric camp, Vet Camp, groceries/shops, hammer mills
	58 Kazungula	Sekute	Mambova	Schools, health, community centre, Agric depot
	59 Livingstone	Kasiya	Kasiya	Population, schools, health, social services, farm Block/farming (food reserve & tobacco Scheme), access road, distance from existing distribution line
	60 Mazabuka	Magoye	Ngwezi	Population, schools, health, social services, farming (food reserve & tobacco Scheme), access road, distance from existing distribution line
	61 Monze	Choongo East	Kamuzya East	Agriculture, population, social amenities, schools, health, food reserve, distance from existing distribution line
	62 Namwala	Bambwe	Bambwe	Cattle faring, palaces, population, schools, health, (food reserve & tobacco Scheme), access road, distance from existing distribution line
	63 Siavonga	Nanyanga	Namoomba	Population, schools, health, social services, farming (food reserve & tobacco Scheme), access road, distance from existing distribution line
64 Sinazongwe	Malima	Sinakaimbi	Farmers Training Centre, Population, schools, health, business facilities, farming, access road, distance from existing distribution line	
Western Province	65 Kalabo	Maala	Sikongo	Population, schools/health, shops/businesses, hammer mill, farm block, farmers cooperatives, access road
	66 Kaoma	Nkeyama	Nkeyama	Population, schools/health, shops/businesses, hammer mills, farm block, farmers cooperatives, (tobacco Scheme), access road
	67 Lukulu	(N.A.)	Lukulu Boma	Population, schools/health, shops/businesses, markets, hammer mill, farm block, access road
	68 Mongu	Nangula	Nangula	Population, schools/health, shops/businesses/small industries, hammer mill, food reserve, access road
	69 Senanga	Muoyo	Sianda	Schools, shops/businesses, market, small factories, hammer mill, farmers cooperatives, access road, distance from existing distribution line
	70 Sesheke	Sichili	Sichili	Schools/health, shops/businesses/small industries, hammer mill, farmers cooperatives, access road
	71 Shang'ombo	Simu	Shang'ombo	Population, schools/health, shops/businesses/small industries, hammer mill, farm block, NGO farmers cooperatives, access road, distance from

Table 4-4 Electrified Rural Growth Centres for Socio-Economic Survey

		District	Ward	Rural Growth Centre
<u>Central Province</u>	1	Kapiri Mposhi	(N.A)	Mpula
	2	Kabwe	Mpunde	Mpunde
<u>Copperbelt Province</u>	3	Ndola	Kafulafuta	Mishikishi
	4	Ndola	Kafulafuta	Chiwala
<u>Luapula Province</u>	5	Nchelenge	Kasamba	Kambwali
	6	Mansa	Luapula	Chembe
	7	Kawambwa	(N.A)	Munkanta
	8	Mansa	(N.A)	Luamfumu
<u>Lusaka Province</u>	9	Chongwe	Nakatindi	Nchute
	10	Kafue	Chiawa	Chiawa
<u>Northern Province</u>	11	Kasama	Chamfubu	Nseluka
<u>North-Western Province</u>	12	Mwinilunga	(N.A)	Kabanda
	13	Solwezi	(N.A)	Kapinjimpanga
<u>Southern Province</u>	14	Livingstone	Mukuni	Mukuni Village
	15	Choma	Singani	Mochipapa
	16	Livingstone	Musokotwane	Musokotwane Village
	17	Livingstone	(N.A)	Mwandi Village
<u>Western Province</u>	18	Senanga	Imatonga	Senanga
	19	Mongu	Sefula	Sefula

Table 4-5 Sampling Targets and Numbers for Socioeconomic Survey

Type of RGCs	Sampling Items	Sampling Target & Number	Sampling Method
All RGCs	Characteristics of each RGC	<u>90 RGCs</u> (71 Unelectrified +19 Electrified)	<ul style="list-style-type: none"> - Data collection at Central Statistical Office (CSO) - Measurement by enumerators - Interview with key informants (any of the following institutions), using the prepared questionnaire: <ol style="list-style-type: none"> 1) District Commissioners 2) District ZESCO Managers 3) Local Institutions of Local Government and Housing officials in the RGC (Councils) 4) Local Ministry of Health officials in the RGC 5) Local Ministry of Education officials in the RGC 6) Local Ministry of Agriculture officials in the RGC 7) Local Community Development Officials in the RGC 8) Representatives of Business Associations in the RGC 9) Representatives of Farmers' Associations in the RGC 10) Representatives of Residents in the RGC 11) Ministry of Community Development and Social Services
Unelectrified RGCs	Characteristics of unelectrified public facilities, households, and business entities, such as potential power demand	<u>All public facilities</u> in 71 Unelectrified RGCs	- Individual interview with representatives of all public facilities, such as hospitals, clinics, schools, police post, post office, immigration office and so on, using prepared questionnaires.
		13 interviewees (7 households + 6 business owners) per RGC Total sampling number: <u>923</u> (= 13 x 71RGCs)	- Individual interview with randomly selected unelectrified households and business owners in each RGC, using prepared questionnaires.
Electrified RGCs	Characteristics of electrified public facilities, households, and business entities, such as consumption record and demand growth	<u>All public facilities</u> in 19 Electrified RGCs	- Individual interview with representatives of all public facilities, such as hospital, clinic, school, police, post office, immigration office and so on, using prepared questionnaires
		20 interviewees (14 households + 6 business owners) per RGC Total sampling number: <u>380</u> (= 20 x 19RGCs)	- Individual interview with randomly selected electrified households and business owners in each RGC, using prepared questionnaires.
	Characteristics of unelectrified households and business entities, such as seasons why still not electrified	10 interviewees (6 households + 4 business owners) per RGC Total sampling number: <u>190</u> (= 10 x 19RGCs)	- Individual interview with randomly selected households and business owners in each RGC, who have not received electricity, using prepared questionnaires.

4.6. Collected Sample Sizes

In the socio-economic survey, data necessary for the analysis in both the technical and social aspects of the 90 RGCs – 71 unelectrified and 19 electrified – were collected from four different types of interviewees: 1) household representatives, 2) business owners, 3) representatives of each public facility, and 4) key-informants of each RGC. The socio-economic survey took place from December 2006 to February 2007. Among 71 targeted unelectrified RGCs, 11 RGCs were not accessible due to the heavy rains that made it impossible to use access roads. For these 11 unelectrified RGCs, 8 RGCs were replaced by other unelectrified RGCs in the same District of the originally targeted RGCs; 1 RGC was substituted by an electrified RGC; and 2 RGCs (Kalinku in Eastern Province and Ntambu in North Western Province, were unaccessible) were unable to be replaced at all, as shown in Table 4-6. In addition, 4 RGCs (Mpima in Central Province, Kangonga in Copperbelt Province, Luangwa Boma in Lusaka Province, and Lukulu Boma in Western Province) considered as unelectrified were found to be electrified, while 1 RGC (Nchute in Lusaka Province) considered as electrified were detected as unelectrified in the survey. As a result, data was collected from 23 electrified and 65 unelectrified RGCs: 4 more electrified and 6 less unelectrified RGCs than the targeted numbers. The number of surveyed RGCs by Province is summarised in Table 4-7.

Out of these 88 RGCs, socio-economic data were collected from 681 households, 379 business entities, 267 public facilities and 88 key-informants as summarized in Table 4-8. The actual collected data were less than the targeted numbers: 78% for households and 62% for business entities. The situations above arose because the connected households in electrified RGCs and the business entities existing in the surveyed RGCs were less than the targeted numbers.

Although the sample sizes were smaller than the targeted numbers, the analysis used these data as they were the only primary data available, no secondary data were substitutable, and they were the most reliable information collected using the questionnaire designed by the Study Team. No secondary data were available.

Table 4-6 Inaccessible RGCs and Different Electrification Status

	District	Ward	Rural Growth Centre	Note	Replacement	Elec. Status	
<u>Central Province</u>	1 Chibombo	Kakoma	Shimukuni	Electrified			
	2 Kabwe	Mpima	Mpima				
	3 Kapiri Mposhi	Luanchele	Chipepo				
	4 Mkushi	Kamimbya	Old Mkushi				
	5 Mumbwa	Kalwanyembe	Mumbwa Big Concession				
	6 Serenje	Chibale	Chibale				
<u>Copperbelt Province</u>	7 Chiliabombwe	Anoya Zulu	Mungomba				
	8 Chingola	Kapisha	Kamiteta				
	9 Kalulushi	Ichimpe	Kameme				
	10 Kitwe	Limaposa	Kakolo				
	11 Luanshya	Chitwi	Kafubu				
	12 Lufwanyama	(N.A.)	Emerald Mining Area				
	13 Masaiti	Mutaba	Mutaba				
	14 Mpongwe	Mikata	Mikata				
	15 Mufulira	Mutundu	Mutundu North				
	16 Ndola	Kavu	Kanglonga				Electrified
<u>Eastern Province</u>	17 Chadiza	Kamini	Mlolo	Inaccessible	No Place	-	
	18 Chama	Kalinkhu	Kalinkhu				
	19 Chipata	(N.A.)	Chiparamba				
	20 Katete	Kapangulula	Kagoro				
	21 Lundazi	Chimaliro	Mwase				
	22 Mambwe	Mphomwa	Mphomwa Tse-tse				
	23 Nyimba	Ngozi	Chipembe				
	24 Petauke	Matambazi	Kapungwe				
	<u>Luapula Province</u>	25 Chiengi	Lunchinda				Lupiya
26 Kawambwa		Mulunda	Chama	Inaccessible	Mushota	Unelectrified	
27 Mansa		Chibeleka	Kasongwa Sub Boma				
28 Milenge		Mikula	Tayali				
29 Mwense		Mpasa	Katuta				
30 Nchelenge		Chilongo	Chilongo				
31 Samfya		Kapata	Chinsanka				
<u>Lusaka Province</u>	32 Chongwe	Bunda Bunda	Chinyunyu	Electrified			
	33 Kafue	Malundu	Chipapa				
	34 Luangwa	Dzalo	Luangwa Boma				
	- Lusaka	-	-				
<u>Northern Province</u>	35 Chilubi	Santa Maria	Kambashi	Inaccessible	Matipa	Unelectrified	
	36 Chinsali	Mukumbi	Shiwangandu				
	37 Isoka	Kalansa	Muyombe				
	38 Kaputa	(N.A.)	Nsama Sub Boma				
	39 Kasama	Musowa	Kachuma				
	40 Luwingu	(N.A.)	Masonde				
	41 Mbala	Lapisha	Chimula				
	42 Mpika	Chibwa	Kanchibiya				
	43 Mporokoso	Kalungwishi	Mukupakaoma				
	44 Mpulungu	Kapembwa	Kasaba Bay				Inaccessible
45 Mungwi	Mpanda	Makasa	Inaccessible	Rosa	Unelectrified		
46 Nakonde	Isunda	Wulongo					
<u>North-Western Province</u>	47 Chavuma	Chivombo	Chivombo	Inaccessible	No Place	-	
	48 Kabompo	Kashinakazhi	Kashinakazhi				
	49 Kasempa	Nselauke	Nselauke				
	50 Mufumbwe	Matushi	Matushi				
	51 Mwinilunga	Ntambu	Ntambu				
	52 Solwezi	Mumena	Mumena				
	53 Zambezi	Chitokoloki	Chitokoloki				
	54 Choma	Hamaundu	Kachomba				
<u>Southern Province</u>	55 Gwembe	Chibuwe	Siabwengo	Inaccessible	Kabanga	Unelectrified	
	56 Itzhi-tezhi	Lubanda	Lubanda				
	57 Kalomo	Mbwiko	Napatizya				
	58 Kazungula	Sekute	Mambova				
	59 Livingstone	Kasiya	Kasiya				
	60 Mazabuka	Magoye	Ngwezi				
	61 Monze	Choongo East	Kamuzya East				
	62 Namwala	Bambwe	Bambwe				
	63 Siavonga	Nanyanga	Namoomba				
	64 Sinazongwe	Malima	Sinakaimbi				
<u>Western Province</u>	65 Kalabo	Maala	Sikongo	Inaccessible	Nangweshi	Unelectrified	
	66 Kaoma	Nkeyama	Nkeyama				
	67 Lukulu	(N.A.)	Lukulu Boma				Electrified
	68 Mongu	Nangula	Nangula				
	69 Senanga	Muoyo	Sianda				
	70 Sesheke	Sichili	Sichili				
	71 Shang'ombo	Simu	Shang'ombo				Inaccessible

Table 4-7 Number of Surveyed RGCs by Province

Province	Electrified	Unelectrified	Total
Central	3	5	8
Copperbelt	3	9	12
Eastern	0	7	7
Luapula	5	6	11
Lusaka	2	2	5
Northern	1	12	13
North Western	2	6	8
Southern	4	11	15
Western	3	7	9
Total	23	65	88

Table 4-8 Collected Sample Sizes in Socio-economic Survey

	TARGET			ACHIEVEMENT			
	Electrified	Unelectrified	Total	Electrified	Unelectrified	Total	%
RGCs	19	71	90	23	65	88	98
1) Households	380	497	877	246	435	681	78
2) Business Entities	190	426	616	124	255	379	62
<i>Sub-total</i>	<i>570</i>	<i>923</i>	<i>1,493</i>	<i>370</i>	<i>690</i>	<i>1,060</i>	<i>71</i>
3) Public Facility	All	All	-	149	118	267	-

4.7. Ability and Willingness to Pay

In order to analyse the connection costs and the monthly electricity tariff, this socio-economic survey investigates the amount that customers pay in electrified RGCs. The ability to pay for a monthly tariff is estimated from the current expenditures by the interviewed households on alternative energy forms in unelectrified RGCs including firewood, paraffin, charcoal and storage batteries. To determine the amount that villagers in unelectrified RGCs are willing to pay for the initial connection cost and the monthly tariff, a randomly selected sample was interviewed applying the Contingent Valuation Method (CVM). To estimate how the interviewees value the initial cost and monthly tariff, in comparison with urgency (years that they are ready to wait until receiving electricity) and daily consumable duration, Conjoint Analysis was applied in the socio-economic survey. The technique was mainly developed as a widely used factor analysis method in the field of marketing research, to identify a product with the best combination of factors/attributes for consumers.

4.7.1. Methodology to Assess Ability to Pay for Monthly Tariff

In the socio-economic survey, data (or balance sheet) of a monthly income and expenditure was collected from households and business entities to assess income, energy cost, ZESCO tariff (only for electrified households), ratio of energy cost to income, ratio of ZESCO tariff to income (only for electrified households), and ratio of ZESCO tariff to energy cost (only for electrified households). The analysis was carried out by classifying respondents into 8 categories: 1) electrified households, 2) electrified business entities, 3) unconnected households, 4) unconnected business entities in electrified RGCs; and 5) unelectrified households, 6) unelectrified business entities, 7) households with stand alone generator, 8) business entities with stand alone generator in unelectrified RGCs. Unconnected households and business entities are those who are not connected to a ZESCO distribution line even though they live in electrified RGCs. Stand alone generator is either solar home system or diesel generator. Among all collected data, only reliable data, whose total income and total expenditures were balanced, were used in the analysis. Therefore, only 301 effective data out of 1,060 collected data were used for the analysis.

4.7.2. Evaluation of Ability to Pay for Monthly Tariff

The analysis results and significance different test results by non-parametric test (Mann-Whitney U) for all the possible combination of 8 respondent categories are summarized in Table 4-9. Key findings focusing on unelectrified households and business entities in unelectrified RGCs are as follows.

(A) Monthly Income (Section (A) in Table 4-9)

The average monthly income (AMI) for unelectrified households in unelectrified RGCs was determined as K910,757. This is significantly lower than the corresponding figures in electrified RGCs, which are K1,163,721 for electrified households and K1,299,833 for households with stand alone generator (with 5% level), but higher than for unconnected households in electrified RGCs at K640,000 (with 10% level). Thus, the average incomes in unelectrified households in unelectrified RGCs is better than those for unconnected ones in electrified RGCs, but not as good as the electrified ones in electrified RGCs. [Note: Average monthly household income as of 2004 is K334,308 in rural areas, K760,629 in urban areas, and K502,030 for the whole country. *Living Condition Monitoring Survey Report 2004, Central Statistical Office, December 2005*]

The AMI for business entities in unelectrified RGCs was K4,456,118, and this value is higher than that for electrified business entities in electrified RGCs at K2,805,067, for unconnected business entities in electrified RGCs at 2,403,667, and for business entities with stand alone generator at K2,800,000. These differences, however, are not significant even with 10% level. Therefore, income level for surveyed business entities in unelectrified RGCs is as good as that for electrified ones in electrified RGCs. As expected, the AMI for business entities was generally higher than that for households.

(B) Monthly Energy Cost (Section (B) in Table 4-9)

The Average Monthly Energy Cost (AMEC) for unelectrified households in unelectrified RGCs is K59,141, and this is significantly lower than that for electrified households in electrified RGCs at K87,118 (with 1% level), but is significantly different from neither that for households with stand alone generator at K63,025 nor that for unconnected households in electrified RGCs at K53,525 (even with 10% level). Since monthly income for unelectrified households is lower than electrified households, it is not surprising that AMEC for unelectrified households are also lower than electrified households.

The AMEC for business entities in unelectrified RGCs is K75,315, and this is significantly lower than that for electrified business entities in electrified RGCs at K308,653. While monthly income between electrified and unelectrified business entities are not significantly different (in fact, the value for unelectrified business entities are larger than unelectrified ones), it seems that surveyed unelectrified business entities are affordable to pay more for energy cost.

(C) Monthly ZESCO Tariff (Section (C) in Table 4-9)

Average Monthly ZESCO Tariff (AMZT) paid by households is K52,286, while that by business entities is K201,600: business entities expense approximately 4 times on monthly ZESCO tariffs compared to households. They are significantly different with 5% significance level.

(D) Ratio of Energy Cost to Income (Section (D) in Table 4-9)

The average Ratio of monthly Energy Cost to monthly Income (RECI) for unelectrified households in unelectrified RGCs is 0.108, and this is significantly larger than that for households with stand alone generator at 0.048 (with 1% significance level), but is not different from electrified households at 0.118 and unconnected ones at 0.134, even with 10% significance level. Thus, RECI is approximately 11% for both electrified households by ZESCO and unelectrified households.

RECI for business entities in unelectrified RGCs is 0.057, and this is significantly lower than that for electrified business entities in electrified RGCs at 0.165.

(E) Ratio of ZESCO Tariff to Income (Section (E) in Table 4-9)

The average Rate of monthly ZESCO Tariff to monthly Income (RZTI) for households is 0.066, while that for business entities is 0.081. They are not significantly different even with 10% significance level, and thus approximately 6 to 8% of income is consumed by ZESCO customers no matter whether they are households or business entities.

(F) Ratio of ZESCO Tariff to Energy Cost (Section (F) in Table 4-9)

The average Rate of monthly ZESCO Tariff to monthly Energy Cost (RZTEC) for households is 0.623, while that for business entities is 0.819. They are significantly different with 1% significance level. Therefore, both business entities and households still use energy other than electricity even after electrification, but business entities seem to shift from alternative energy to electricity more remarkably than households: business entities consume less than 20% of energy cost for alternative energy after the electrification, while households still spend approximately 40% of energy cost for it.

Based on the key findings above, it is estimated that unelectrified business entities are more likely to afford monthly electricity tariff than households. By assuming that 60% of the current monthly energy expenditure could be switched to the electricity consumption for unelectrified households and 80% for unelectrified business entities after the electrification, estimated ability to pay for monthly electricity tariffs are at least K35,485 (=K59,141*0.6) for households and K60,252 (=K75,315*0.8) for business entities respectively.

Table 4-9 Analysis Results of Monthly Balance Sheet (1/2)

(A) Monthly Income [= Monthly Expenditure]

		Sample #	Average	St. Dev.	Median	LB of 95% CI	UB of 95% CI	Skewness	Kurtosis
Electrified RGC	1. Electrified HH	28	1,163,721	705,739	970,000	890,065	1,437,378	0.408	-0.631
	2. Electrified BE	15	2,805,067	2,649,242	2,600,000	1,337,965	4,272,168	1.326	1.414
	3. Unconnected HH	20	640,000	816,488	350,000	257,872	1,022,128	2.747	8.158
	4. Unconnected BE	9	2,403,667	1,981,515	1,600,000	880,539	3,926,794	1.883	3.535
Unelectrified RGC	5. Unelectrified HH	129	910,757	1,228,944	680,000	696,660	1,124,854	4.673	27.841
	6. Unelectrified BE	81	4,456,118	7,255,342	2,100,000	2,851,830	6,060,406	3.330	12.207
	7. HH with Stand Alone Generator	12	1,299,833	572,480	1,180,000	936,097	1,663,570	0.966	0.260
	8. BE with Stand Alone Generator	7	2,800,000	1,802,776	2,800,000	1,132,711	4,467,289	0.484	-1.146

		Electrified RGC				Unelectrified RGC			
		1. Electrified HH	2. Electrified BE	3. Unconnected HH	4. Unconnected BE	5. Unelectrified HH	6. Unelectrified BE	7. HH with Generator	8. BE with Generator
Electrified RGC	1. Electrified HH	133.0 (0.050)**	135.0 (0.002)*	68.0 (0.040)**	1218.5 (0.007)*	662.5 (0.001)*	144.0 (0.479)	43.5 (0.025)**	
	2. Electrified BE	64.0 (0.002)*	57.5 (0.002)*	15.5 (0.000)*	476.0 (0.001)*	566.5 (0.679)	63.5 (0.196)	45.5 (0.622)	
	3. Unconnected HH	64.0 (0.040)**	64.0 (0.835)	15.5 (0.000)*	983.0 (0.087)**	222.0 (0.000)*	31.0 (0.001)*	10.0 (0.001)*	
	4. Unconnected BE	68.0 (0.040)**	64.0 (0.835)	15.5 (0.000)*	170.0 (0.000)*	350.5 (0.851)	32.0 (0.117)	27.0 (0.633)	
Unelectrified RGC	5. Unelectrified HH	1218.5 (0.007)*	476.0 (0.001)*	983.0 (0.087)**	170.0 (0.000)*	2143.5 (0.000)*	375.0 (0.003)*	113.5 (0.001)*	
	6. Unelectrified BE	662.5 (0.001)*	566.5 (0.679)	222.0 (0.000)*	350.5 (0.851)	2143.5 (0.000)*	339.5 (0.093)	259.5 (0.711)	
	7. HH with Generator	144.0 (0.479)	63.5 (0.196)	31.0 (0.001)*	32.0 (0.117)	375.0 (0.003)*	339.5 (0.093)	19.0 (0.052)**	
	8. BE with Generator	43.5 (0.025)**	45.5 (0.622)	10.0 (0.001)*	27.0 (0.633)	113.5 (0.001)*	259.5 (0.711)	19.0 (0.052)**	

(B) Monthly Energy Cost

		Sample #	Average	St. Dev.	Median	LB of 95% CI	UB of 95% CI	Skewness	Kurtosis
Electrified RGC	1. Electrified HH	28	87,118	37,728	80,750	72,489	101,747	0.334	-0.586
	2. Electrified BE	15	308,653	501,705	116,000	30,819	586,488	2.408	5.335
	3. Unconnected HH	20	53,525	47,270	34,500	31,402	75,648	1.045	-0.309
	4. Unconnected BE	9	101,267	107,891	60,000	18,334	184,199	1.387	1.192
Unelectrified RGC	5. Unelectrified HH	129	59,141	49,182	50,600	50,573	67,709	2.395	10.373
	6. Unelectrified BE	81	75,315	70,731	53,000	59,675	90,955	1.887	4.311
	7. HH with Stand Alone Generator	12	63,025	63,909	51,500	22,419	103,631	2.024	4.909
	8. BE with Stand Alone Generator	7	736,000	1,460,099	100,000	-614,366	2,086,366	2.499	6.355

		Electrified RGC				Unelectrified RGC			
		1. Electrified HH	2. Electrified BE	3. Unconnected HH	4. Unconnected BE	5. Unelectrified HH	6. Unelectrified BE	7. HH with Generator	8. BE with Generator
Electrified RGC	1. Electrified HH	159.0 (0.194)	142.0 (0.004)*	106.0 (0.457)	1003.5 (0.000)*	801.5 (0.021)**	96.0 (0.034)**	92.5 (0.821)	
	2. Electrified BE	67.5 (0.006)*	67.5 (0.006)*	46.0 (0.199)	474.0 (0.001)*	356.5 (0.011)**	41.0 (0.017)**	50.5 (0.888)	
	3. Unconnected HH	67.5 (0.004)*	67.5 (0.006)*	46.0 (0.199)	1145.0 (0.419)	660.5 (0.202)	115.0 (0.846)	45.5 (0.175)	
	4. Unconnected BE	105.0 (0.457)	46.0 (0.199)	67.0 (0.278)	496.0 (0.466)	342.0 (0.762)	43.5 (0.454)	24.0 (0.427)	
Unelectrified RGC	5. Unelectrified HH	1003.5 (0.000)*	474.0 (0.001)*	1145.0 (0.419)	496.0 (0.466)	4749.0 (0.267)	768.0 (0.965)	324.0 (0.209)	
	6. Unelectrified BE	801.5 (0.021)**	356.5 (0.011)**	46.0 (0.202)	342.0 (0.762)	4749.0 (0.267)	426.0 (0.491)	212.0 (0.270)	
	7. HH with Generator	96.0 (0.034)**	41.0 (0.017)**	115.0 (0.846)	43.5 (0.454)	768.0 (0.965)	426.0 (0.491)	29.0 (0.271)	
	8. BE with Generator	92.5 (0.821)	50.5 (0.888)	45.5 (0.175)	24.0 (0.427)	324.0 (0.209)	212.0 (0.270)	29.0 (0.271)	

(C) Monthly ZESCO Tariff

		Sample #	Average	St. Dev.	Median	LB of 95% CI	UB of 95% CI	Skewness	Kurtosis
Electrified RGC	1. Electrified HH	28	52,286	31,061	46,500	40,241	64,330	1.407	2.465
	2. Electrified BE	15	201,600	419,889	87,000	-30,927	434,127	3.710	14.070
	3. Unconnected HH	-	-	-	-	-	-	-	-
	4. Unconnected BE	-	-	-	-	-	-	-	-
Unelectrified RGC	5. Unelectrified HH	-	-	-	-	-	-	-	-
	6. Unelectrified BE	-	-	-	-	-	-	-	-
	7. HH with Stand Alone Generator	-	-	-	-	-	-	-	-
	8. BE with Stand Alone Generator	-	-	-	-	-	-	-	-

		Electrified RGC				Unelectrified RGC			
		1. Electrified HH	2. Electrified BE	3. Unconnected HH	4. Unconnected BE	5. Unelectrified HH	6. Unelectrified BE	7. HH with Generator	8. BE with Generator
Electrified RGC	1. Electrified HH	113.5 (0.014)**							
	2. Electrified BE	113.5 (0.014)**							
	3. Unconnected HH								
	4. Unconnected BE								
Unelectrified RGC	5. Unelectrified HH								
	6. Unelectrified BE								
	7. HH with Generator								
	8. BE with Generator								

[Note]

Upper: Mann-Whitney's U Value
Lower: (P-Value)

* : Significantly different with 1% level
** : Significantly different with 5% level
***: Significantly different with 10% level

Table 4-9 Analysis Results of Monthly Balance Sheet (2/2)

(D) Energy Cost/Income Rate [= (B) / (A)]

		Sample #	Average	St. Dev.	Median	LB of 95% CI	UB of 95% CI	Skewness	Kurtosis
Electrified RGC	1. Electrified HH	28	0.118	0.105	0.078	0.077	0.159	1.888	3.093
	2. Electrified BE	15	0.165	0.246	0.057	0.029	0.302	2.830	8.919
	3. Unconnected HH	20	0.134	0.115	0.089	0.080	0.188	1.689	3.196
	4. Unconnected BE	9	0.056	0.069	0.029	0.003	0.109	2.012	3.982
Unelectrified RGC	5. Unelectrified HH	129	0.108	0.091	0.083	0.092	0.124	2.208	6.274
	6. Unelectrified BE	81	0.057	0.092	0.023	0.036	0.077	2.852	8.252
	7. HH with Stand Alone Generator	12	0.048	0.035	0.045	0.026	0.071	0.307	-1.608
	8. BE with Stand Alone Generator	7	0.167	0.251	0.083	-0.065	0.399	2.255	5.292

		Electrified RGC				Unelectrified RGC			
		1. Electrified HH	2. Electrified BE	3. Unconnected HH	4. Unconnected BE	5. Unelectrified HH	6. Unelectrified BE	7. HH with Generator	8. BE with Generator
Electrified RGC	1. Electrified HH	183.5	244.5	52.5	1760.5	423.0	84.0	86.5	
	2. Electrified BE	(0.499)	(0.458)	(0.009)*	(0.835)	(0.000)*	(0.013)**	(0.635)	
	3. Unconnected HH	183.5	129.0	40.5	901.5	316.0	60.0	49.0	
	4. Unconnected BE	(0.499)	(0.484)	(0.107)	(0.666)	(0.003)*	(0.143)	(0.805)	
Unelectrified RGC	5. Unelectrified HH	244.5	129.0	38.0	1123.5	307.0	55.0	58.5	
	6. Unelectrified BE	(0.458)	(0.484)	(0.014)**	(0.354)	(0.000)*	(0.011)**	(0.524)	
	7. HH with Generator	52.5	40.5	38.0	289.0	325.0	51.5	22.0	
	8. BE with Generator	(0.009)*	(0.107)	(0.014)**	(0.012)**	(0.595)	(0.859)	(0.315)	
	5. Unelectrified HH	1760.5	901.5	1123.5	289.0	2175.5	387.0	416.5	
	6. Unelectrified BE	(0.835)	(0.666)	(0.354)	(0.012)**	(0.000)*	(0.004)*	(0.745)	
	7. HH with Generator	423.0	316.0	307.0	325.0	2175.5	388.0	181.0	
	8. BE with Generator	(0.000)*	(0.003)*	(0.000)*	(0.595)	(0.000)*	(0.261)	(0.114)	

(E) ZESCO Tariff/Income Rate [= (C) / (A)]

		Sample #	Average	St. Dev.	Median	LB of 95% CI	UB of 95% CI	Skewness	Kurtosis
Electrified RGC	1. Electrified HH	28	0.066	0.058	0.053	0.044	0.088	2.878	10.900
	2. Electrified BE	15	0.081	0.069	0.054	0.043	0.119	0.974	-0.480
	3. Unconnected HH	-	-	-	-	-	-	-	-
	4. Unconnected BE	-	-	-	-	-	-	-	-
Unelectrified RGC	5. Unelectrified HH	-	-	-	-	-	-	-	-
	6. Unelectrified BE	-	-	-	-	-	-	-	-
	7. HH with Stand Alone Generator	-	-	-	-	-	-	-	-
	8. BE with Stand Alone Generator	-	-	-	-	-	-	-	-

		Electrified RGC				Unelectrified RGC			
		1. Electrified HH	2. Electrified BE	3. Unconnected HH	4. Unconnected BE	5. Unelectrified HH	6. Unelectrified BE	7. HH with Generator	8. BE with Generator
Electrified RGC	1. Electrified HH	198.0	198.0						
	2. Electrified BE	(0.760)	(0.760)						
	3. Unconnected HH								
	4. Unconnected BE								
Unelectrified RGC	5. Unelectrified HH								
	6. Unelectrified BE								
	7. HH with Generator								
	8. BE with Generator								

(F) ZESCO Tariff/Energy Cost Rate [= (C) / (B)]

		Sample #	Average	St. Dev.	Median	LB of 95% CI	UB of 95% CI	Skewness	Kurtosis
Electrified RGC	1. Electrified HH	28	0.623	0.235	0.686	0.532	0.714	-0.481	-0.751
	2. Electrified BE	15	0.819	0.296	0.958	0.655	0.983	-1.932	2.782
	3. Unconnected HH	-	-	-	-	-	-	-	-
	4. Unconnected BE	-	-	-	-	-	-	-	-
Unelectrified RGC	5. Unelectrified HH	-	-	-	-	-	-	-	-
	6. Unelectrified BE	-	-	-	-	-	-	-	-
	7. HH with Stand Alone Generator	-	-	-	-	-	-	-	-
	8. BE with Stand Alone Generator	-	-	-	-	-	-	-	-

		Electrified RGC				Unelectrified RGC			
		1. Electrified HH	2. Electrified BE	3. Unconnected HH	4. Unconnected BE	5. Unelectrified HH	6. Unelectrified BE	7. HH with Generator	8. BE with Generator
Electrified RGC	1. Electrified HH	96.0	96.0						
	2. Electrified BE	(0.004)*	(0.004)*						
	3. Unconnected HH								
	4. Unconnected BE								
Unelectrified RGC	5. Unelectrified HH								
	6. Unelectrified BE								
	7. HH with Generator								
	8. BE with Generator								

[Note]

Upper: Mann-Whitney's U Value
Lower: (P-Value)

* : Significantly different with 1% level
** : Significantly different with 5% level
***: Significantly different with 10% level

4.7.3. Methodology to Assess Willingness to Pay

To analyze residents’ willingness to pay for initial cost (such as ZESCO line connection fee, contribution for micro/mini hydropower plant, and solar home system installation) and monthly tariff in unelectrified RGCs, Contingent Valuation Method (CVM) was adopted. Regarding the energy consumption mode, four (4) scenarios were prepared:

- Scenario 1: No electricity
- Scenario 2: Electricity supplied by Solar Home System (SHS)
- Scenario 3: Electricity supplied by micro/mini hydropower plant with isolated distribution network
- Scenario 4: Electricity supplied by ZESCO distribution line

Details of each scenario were explained to interviewees from enumerators, and by comparing Scenario 1 to each of Scenario 2, 3, and 4, their willingness to pay for initial cost and monthly tariff were asked by the double bound method. In the double bound method, the firstly asked prices were randomly selected either K1,000,000, K1,500,000, K2,000,000, K3,000,000, or K4,000,000 for initial cost; and either K10,000, K15,000, K20,000, K30,000, or K40,000 for monthly tariff. When an interviewee was willing to pay for the first asked price, one step higher price was asked; while when an interviewee was not willing to pay for the first asked price, one step lower price was asked. For example, if an interviewee was asked K4,000,000 for the initial cost in the first question and expressed the willingness to pay (or answered “yes”) for the price, whether the interviewee is willing to pay at K5,000,000 for the initial cost is asked as the second question. Another example is that if an interviewee disagreed on the monthly tariff at K10,000, the interviewee is asked K5,000 in the second question (refer to Table 4-10). Data was collected from 784 households and business entities in total.

Table 4-10 Price Categories Used in Double Bound Method for CVM


Initial Cost	K500,000, K1,000,000, K1,500,000, K2,000,000, K3,000,000, K4,000,000, K5,000,000
Monthly Tariff	K5,000, K10,000, K15,000, K20,000, K30,000, K40,000, K50,000

4.7.4. Willingness to Pay for Monthly Tariff

Analysis results regarding willingness to pay for monthly tariff for each of electrification methods (SHS, micro/mini hydro, and ZESCO distribution line) are summarized in Figure 4-3. By comparing the middle average values obtained by Turnbull method (non-parametric method) for each method, SHS at K32,634 is the lowest, micro/mini hydropower at K33,227 is the middle, and ZESCO distribution line at K37,194 is the highest. These results indicate that the willingness to pay for monthly tariff becomes higher as convenience (such as usable duration and amount) and reliability of supplied electricity are better. The willingness to pay for monthly tariff for ZESCO service shows quite close value to the estimated households’ ability to pay at K35,485 in the section 4.7.2.


These values, however, could be underestimated as more than 30% of interviewees still expressed the willingness to pay at K50,000 for ZESCO service: price categories selected in double bound method for monthly tariff was low.

(A) Solar Home System




	Average
Lower Bound	28,949
Middle	32,634
Upper Bound	36,320

(B) Micro/Mini Hydropower Plant



	Average
Lower Bound	29,840
Middle	33,227
Upper Bound	36,615

(C) ZESCO Distribution Line



	Average
Lower Bound	34,131
Middle	37,197
Upper Bound	40,263

Figure 4-3 Willingness to Pay for Monthly Tariff

4.7.5. Willingness to Pay for Initial Cost

Analysis results regarding willingness to pay for initial cost for each of electrification methods (SHS, micro/mini hydro, and ZESCO distribution line) are summarized in Figure 4-4 (on the next page). By comparing the middle average values obtained by Turnbull method (non-parametric method) for each method, initial cost for SHS at K2,105,556 and that for micro/mini hydropower at K2,118,646 are similar, while that for ZESCO distribution line at K2,508,483 is much higher than the others. These results indicate that unelectrified residents wish to receive electricity from ZESCO distribution line, even if they need to pay more initial cost than SHS or micro/mini hydropower with isolated grid.

Figure 4-5 shows actual connection fee for both 1 phase and 3 phase charged by ZESCO in each of urban, peri-urban, and rural areas. ZESCO charges higher connection fee in rural areas (K4,887,000 for 3 phase and K2,873,000 for 1 phase) than urban and peri-urban. The connection fee for 1 phase in rural area is slightly more expensive than the average willingness to pay for ZESCO connection by the socio-economic surveyed residents in unelectrified RGCs. Since the average monthly household income in unelectrified RGCs is K910,757 (refer to section 4.7.2.), connection fee for 1 phase is about 3 times and that for 3 phase is more than 5 times of it. The average monthly business entity income in unelectrified RGCs (K4,456,118) is close to the 3 phase connection fee, and thus business entities seem to reasonably afford it.

As a socio-economic survey result, it was found that approximately 20% of households have connected to ZESCO in the electrified RGCs (details are shown in Table 5-1). In Figure 4-4, the willingness to pay for 20% of residents in unelectrified RGCs is approximately K3,800,000, which is coincidentally similar to the average connection fee of 1 phase and 3 phase in rural areas.






Figure 4-5 ZESCO Connection Fee, Average Income, and Willingness to Pay

(A) Solar Home System




Average
 Lower Bound 1,771,541
 Middle 2,105,566
 Upper Bound 2,439,591

(B) Micro/Mini Hydropower Plant



Average
 Lower Bound 1,798,665
 Middle 2,118,646
 Upper Bound 2,438,627

(C) ZESCO Distribution Line



Average
 Lower Bound 2,153,636
 Middle 2,508,483
 Upper Bound 2,863,331

Figure 4-4 Willingness to Pay for Initial Cost

4.8. Prioritized Property for Electrification Perceived by Unelectrified Residents

The Study sought to establish for unconnected residents, which factors among the following they perceived to be most important for the future electrification: 1) urgency, 2) duration, 3) initial cost, and 4) monthly tariff. The information obtained was analyzed to provide a background for designing the necessary political interventions and measures to promote rural electrification. Conjoint Analysis, explained earlier in this report was applied to the collected data.

4.8.1. Conjoint Analysis Method

As shown in Table 4-11, three levels were used for each of the four selected factors. Among 81 (=3⁴) possible combinations for 4 factors with each 3 levels, 11 combinations (including 2 hold out combinations to be used to confirm the accuracy of the data analysis) are selected by orthogonal design method (to minimize the number of combination necessary to the analysis) to create conjoint cards. Interviewees are asked to make a ranking order for these 11 cards based on their preference for the combinations shown in each card.

Table 4-11 Properties and Levels for Conjoint Analysis

Property	Definition	Levels
1) Urgency	How soon does an interviewee wish to receive electricity.	2, 5, 15 years
2) Duration	How many hours does an interviewee wish to use electricity per day.	5, 10, 24 hours/day
3) Initial Cost	One time cost, such as ZESCO line connection fee, contribution for micro/mini hydropower plant, and solar home system installation, required to commence using electricity.	K1,700,000, K3,200,000, K4,700,000
4) Monthly Tariff	Monthly electricity cost charged by electricity supplier or savings for the future maintenance of electrification facilities.	K8,000/month, K24,000/month, K40,000/month

4.8.2. Conjoint Analysis Results

Data from 761 interviewees were analyzed using statistical analysis package SPSS. As shown in Figure 4-6, Duration was the most important property (35%), followed by Urgency (26%), Monthly Tariff (20%), and Initial Cost (19%). Regarding Duration, usage of 24 hours per day was the most preferable (as shown in (B) in Figure 4-7). Interesting finding, however, was that the second favorable Duration was not 10 hours, but 5 hours. This result might be caused as most of interviewees live in place where is no hydro potential, and thus electrification by micro/mini hydro for 10 hours per day seems difficult to imagine. Other than Duration, analysis results are ordinary: unelectrified residents want to be electrified in short waiting time, with minimum initial cost and monthly tariff.

Among all the possible 81 combination, the most favourable one selected by the interviewees is “receive electricity within 2 years for 24 hours usage by K1,700,000 initial cost and K24,000 monthly tariff” based on BTL (Bradley-Terry-Luce) utility evaluation rate (refer to Table 4-12). The second preference is “receive electricity within 2 years for 5 hours usage by K1,700,000 initial cost and K24,000 monthly tariff.” Therefore, it could be said that even limited usage by SHS, unelectrified residents wish to be electrified soon by the minimum initial cost but reasonable monthly tariff.




Figure 4-6 Importance of 4 Properties for Rural Electrification




Figure 4-7 Summary of Utilities for Each Property

Table 4-12 Combination of Properties in Preference Order

Urgency	Duration	Initial Fee	Monthly Fee	BTL
2years	24hours	K 1,700,000	K 24,000/month	19.26%
2years	5hours	K 1,700,000	K 24,000/month	18.66%
5years	24hours	K 1,700,000	K 24,000/month	17.80%
5years	5hours	K 1,700,000	K 24,000/month	17.20%
15years	24hours	K 1,700,000	K 24,000/month	13.84%
15years	5hours	K 1,700,000	K 24,000/month	13.24%

Chapter 5

Potential Power Demand of Unelectrified RGCs

Chapter 5. Potential Power Demand of Unelectrified RGCs

5.1. Purposes of Potential Demand Forecast and Data Analysis Flow

To determine the required specifications of the electrification equipment and facilities, and to select the economically optimal electrification method for each unelectrified RGC, it was necessary to forecast the potential power demand for each unelectrified RGC. The potential demand would also be among the criteria for prioritizing the unelectrified RGCs: the greater the potential demand, the higher the priority accorded to an RGC.

In this study, the potential demand for each unelectrified RGC was forecasted based on the current consumption trends in electrified RGCs as captured by the socio-economic survey. A flow chart of data analysis for the potential demand forecast is shown in Figure 5-1. The first step of the analysis consisted of estimation of an average Daily Load Curve per unit of facility for each of the following four different types of consumers in electrified RGCs: 1) Public Facilities, 2) Business Entities, 3) Hammer Mills and 4) Households. By multiplying the unitary average daily load curve by the number of existing facilities in a RGC for each type and then adding them all together, the daily load curves and daily peak demands were estimated for all electrified RGCs participating in the survey. The second step of the analysis was the selection of a “Peak Demand Forecast Method”. Adaptability of a linear regression model to estimate the daily peak demand in electrified RGCs, derived from the relationship between the number of households and the estimated peak demands in electrified RGCs (calculated in the first step), was tested. The third step of the analysis was to forecast the potential demand for each of 1,217 unelectrified RGCs based on the selected method in the second step. Details of each step are explained in the following sections.




Figure 5-1 Flow Chart of Data Analysis for Potential Demand Forecast

5.2. Estimation of Daily Load Curve/Peak Demand for Each Electrified RGC [Step 1]

From the socio-economic survey results and the national census data, statistics regarding the number of existing facilities and the number of these facilities already electrified were obtained for each electrified RGC and for each type of consumer (Public Facilities, Business Entities, Hammer Mills and Households), as shown in Table 5-1 (on the next page). Firstly, an average daily load curve per unit for each type of customer was obtained. Then, the total daily demand of electrified RGCs studied in this survey was found by multiplying the curve data by the existing number of each type of facility in a RGC and adding them altogether.

5.3. Estimation of Daily Demand for Public Facilities

The socio-economic survey results showed that there are 249 public facilities in the investigated 23 electrified RGCs. Among the total of 249 facilities, 107 have been electrified. Data collected from 49 electrified public facilities were used to create the electricity demand curves. Table 5-2 summarizes the results of the investigation regarding public facilities.

On the data collection sheet used in the survey, public facilities were categorized in 18 types as indicated in Table 5-2. Significant data was collected from the following 14 types of public facilities: Basic/Primary School, Secondary School, Hospital, Health Center/Clinic, Police Post/Station, Post Office, Church, Community Center, Agriculture Depot, Orphanage, Central Government Office, District Government Office, and others. Data from four other types of public facilities – Mosque, Provincial Government Office, Local Administration Office and Court – could not be collected. Therefore a daily load curve per unit was created for each of the 14 specific types of public facilities. The average daily demand of these 14 types was applied to the four public facility types from which no data could be collected. Figure 5-1 shows the daily load curve for each of the 14 public facility types as well as an average curve representative for all these facility types except Hospital of which indicates much different (larger) power demand from others.

The daily load curve data per unit multiplied by the number of electrified units for each type in a RGC (shown in Table 8-2) resulted in the daily load curves of public facilities for electrified RGCs.

Table 5-2 Summary Table of Surveyed Public Facilities

Public Facility	Existing	Electrified	Elec. Rate	Available Load Data
1) Basic/Primary School	26	16	61.5%	13
2) Secondary School	13	12	92.3%	1
3) Tertiary School	5	3	60.0%	2
4) Hospital	2	2	100.0%	1
5) Health Center/Clinic	16	16	100.0%	14
6) Police Post/Station	8	8	100.0%	3
7) Post Office	4	3	75.0%	2
8) Church	113	13	11.5%	4
9) Mosque	1	0	0.0%	0
10) Community Center	5	2	40.0%	1
11) Agriculture Depot	10	5	50.0%	2
12) Orphanage	6	1	16.7%	1
13) Central Government Office	1	1	100.0%	1
14) Provincial Government Office	2	2	100.0%	0
15) District Government Office	15	14	93.3%	1
16) Local Administration Office	2	1	50.0%	0
17) Court	10	2	20.0%	0
18) Other	10	6	60.0%	3
Total	249	107	43.0%	49

Table 5-1 Summary of Surveyed Electrified Rural Growth Centers

RGC	Province	RGC Electrification Year	Public Facility			Business Entity			Maize Mill			Household			Year After Elec.
			Existing in RGC	Electrified	Elec. Rate	Existing in RGC	Electrified	Elec. Rate	Existing in RGC	Electrified	Elec. Rate	Existing in RGC	Electrified	Elec. Rate	
MP/MA	CENTRAL	2006	8	2	25.0%	1	0	0.0%	4	0	0.0%	1	1	100.0%	1
MP/MA	CENTRAL	1994	10	2	20.0%	729	434	59.5%	3	3	100.0%	70	0	0.0%	13
MP/UNDE	CENTRAL	2003	1	0	0.0%	12	5	41.7%	2	0	0.0%	500	20	4.0%	4
MISHIKUSHI	COPPERBELT	2002	11	3	27.3%	24	14	58.3%	4	3	75.0%	350	5	1.4%	5
CH/WALA	COPPERBELT	2005	20	4	20.0%	14	5	35.7%	2	2	100.0%	225	6	2.7%	2
KANGONGA	COPPERBELT	1996	7	7	100.0%	17	3	17.6%	1	1	100.0%	140	2	1.4%	11
CHEMBE	LUAPULA	2006	25	9	36.0%	18	3	16.7%	2	0	0.0%	215	27	12.6%	1
LUANAFUMU	LUAPULA	1973	3	2	66.7%	3	3	100.0%	1	0	0.0%	200	200	100.0%	34
KALOBWA	LUAPULA	2002	3	1	33.3%	5	4	80.0%	1	1	100.0%	50	6	12.0%	5
KAMBWALI	LUAPULA	1987	7	1	14.3%	4	3	75.0%	3	2	66.7%	400	12	3.0%	20
MUNIKANTA	LUAPULA	2006	14	5	35.7%	27	15	55.6%	2	2	100.0%	777	59	7.6%	1
CH/WA	LUSAKA	2001	14	5	35.7%	12	5	41.7%	1	1	100.0%	1,120	15	1.3%	6
LIANGWA BOMA	LUSAKA	1970	13	10	76.9%	95	40	42.1%	3	3	100.0%	580	214	36.9%	37
KAP/MPANGA	NORTH WESTERN	2004	10	4	40.0%	2	1	50.0%	1	1	100.0%	250	0	0.0%	3
KABANDA	NORTH WESTERN	-	14	2	14.3%	108	30	27.8%	15	5	33.3%	500	8	1.6%	-
NSELUKA	NORTHERN	2003	8	3	37.5%	28	7	25.0%	4	4	100.0%	486	20	4.1%	4
MUCHPAPA	SOUTHERN	1966	8	3	37.5%	6	2	33.3%	1	1	100.0%	47	30	63.8%	41
MUSKOTWANIE	SOUTHERN	1970	10	3	30.0%	6	2	33.3%	1	1	100.0%	500	25	5.0%	37
MUKUNI VILLAGE	SOUTHERN	1996	10	3	30.0%	54	22	40.7%	2	2	100.0%	639	26	4.1%	11
MWANDI	SOUTHERN	-	11	5	45.5%	68	66	97.1%	2	2	100.0%	410	110	26.8%	-
LUKULU BOMA	WESTERN	1988	26	24	92.3%	43	33	76.7%	17	7	41.2%	323	100	31.0%	19
SEFULA	WESTERN	1969	8	7	87.5%	31	14	45.2%	3	3	100.0%	170	130	76.5%	18
SE/NANGA	WESTERN	1976	8	2	25.0%	12	1	8.3%	2	0	0.0%	800	26	3.3%	31
Total			249	107	-	1,319	712	-	77	44	-	8,753	1,042	-	-
Average			10.8	4.7	40.5%	57.3	31.0	46.1%	3.3	1.9	70.3%	360.6	45.3	21.7%	-




Figure 5-2 Public Facilities' Daily Load Curves for Electrified RGC (2/2)

5.4. Estimation of Daily Demand for Business Entities

Survey results indicated that there are 1,319 business entities operating in the electrified RGCs investigated in this survey. Among them, 712 have been electrified. Data utilized for the calculation of electricity demand curves was collected from 32 of these electrified business entities. Table 5-3 summarizes the investigation results regarding business entities.

Figure 5-3 shows the average daily load curves per business entity in each of the 8 electrified RGCs (from a total of 23 surveyed RGCs). Data from these average daily load curves multiplied by the number of electrified business entities in a RGC (indicated in Table 5-3) resulted in the daily load curves of business entities for electrified RGCs.

Table 5-3 Summary Table of Surveyed Business Entities

RGC	Province	Business Entity			Available Load Data
		Existing in RGC	Electrified	Elec. Rate	
MPIMA	CENTRAL	1	0	0.0%	-
MPULA	CENTRAL	729	434	59.5%	-
MPUNDE	CENTRAL	12	5	41.7%	-
MISHIKISHI	COPPERBELT	24	14	58.3%	5
CHIWALA	COPPERBELT	14	5	35.7%	-
KANGONGA	COPPERBELT	17	3	17.6%	-
CHEMBE	LUAPULA	18	3	16.7%	3
LUAMFUMU	LUAPULA	3	3	100.0%	2
KALOBWA	LUAPULA	5	4	80.0%	3
KAMBWALI	LUAPULA	4	3	75.0%	3
MUNKANTA	LUAPULA	27	15	55.6%	4
CHIAWA	LUSAKA	12	5	41.7%	5
LUANGWA BOMA	LUSAKA	95	40	42.1%	-
KAPIJIMPANGA	NORTH WESTERN	2	1	50.0%	-
KABANDA	NORTH WESTERN	108	30	27.8%	-
NSELUKA	NORTHERN	28	7	25.0%	7
MOCHIPAPA	SOUTHERN	6	2	33.3%	-
MUSOKOTWANE	SOUTHERN	6	2	33.3%	-
MUKUNI VILLAGE	SOUTHERN	54	22	40.7%	-
MWANDI	SOUTHERN	68	66	97.1%	-
LUKULU BOMA	WESTERN	43	33	76.7%	-
SEFULA	WESTERN	31	14	45.2%	-
SELANGA	WESTERN	12	1	8.3%	-
Total		1,319	712	-	32
Average		57.3	31.0	46.1%	4.0




Figure 5-3 Business Entity’s Unit Average Daily Load Curve for Each Electrified RGC




Figure 5-2 Public Facilities' Daily Load Curves for Electrified RGC (1/2)

5.5. Estimation of Daily Demand for Hammer Mills

Results showed that there are 77 hammer mills in the electrified RGCs surveyed, and 44 of them were electrified. The average electrification rate is 70.3%, which is relatively high compared to the rate of 46.1% for business entities (refer to Table 5-3). The unitary capacity of 15 kW/unit for hammer mills is large, and 3.3 units are installed in each RGC on average. Therefore, hammer mills are considered to be one of the major electricity users, probably the largest consumers, in a RGC, thus necessitating distinction from other business entities in this study. Table 5-4 summarizes the study results on hammer mills.

The unit capacity of hammer mills – 15 kW – multiplied by the number of electrified hammer mills in a RGC (shown in Table 5-4) and by the operation hours – generally from 7:00 to 19:00 – resulted in the daily load curves of hammer mills for the electrified RGCs.

Table 5-4 Summary Table of Surveyed Hammer Mills

RGC	Province	Business Entity			Available Load Data
		Existing in RGC	Electrified	Elec. Rate	
MPIMA	CENTRAL	4	0	0.0%	-
MPULA	CENTRAL	3	3	100.0%	-
MPUNDE	CENTRAL	2	0	0.0%	-
MISHIKISHI	COPPERBELT	4	3	75.0%	1
CHIWALA	COPPERBELT	2	2	100.0%	-
KANGONGA	COPPERBELT	1	1	100.0%	-
CHEMBE	LUAPULA	2	0	0.0%	-
LUAMFUMU	LUAPULA	1	0	0.0%	-
KALOBWA	LUAPULA	1	1	100.0%	1
KAMBWALI	LUAPULA	3	2	66.7%	2
MUNKANTA	LUAPULA	2	2	100.0%	-
CHIAWA	LUSAKA	1	1	100.0%	1
LUANGWA BOMA	LUSAKA	3	3	100.0%	-
KAPIJIMPANGA	NORTH WESTERN	1	1	100.0%	-
KABANDA	NORTH WESTERN	15	5	33.3%	-
NSELUKA	NORTHERN	4	4	100.0%	-
MOCHIPAPA	SOUTHERN	1	1	100.0%	-
MUSOKOTWANE	SOUTHERN	1	1	100.0%	-
MUKUNI VILLAGE	SOUTHERN	2	2	100.0%	-
MWANDI	SOUTHERN	2	2	100.0%	-
LUKULU BOMA	WESTERN	17	7	41.2%	-
SEFULA	WESTERN	3	3	100.0%	-
SENANGA	WESTERN	2	0	0.0%	-
Total		77	44	-	5
Average		3.3	1.9	70.3%	1.3




Figure 5-4 Hammer Mill’s Unit Daily Load Curve for Each Electrified RGC

5.6. Estimation of Daily Demand for Households

The results showed that there were 8,753 households in the 23 electrified RGCs surveyed. Of these, 1,042 households have been electrified. The data utilized for the calculation of electricity demand curves were collected from 83 of the electrified households. Table 5-5 summarizes the study results on households.

Figure 5-5 shows the average daily load curves of households in each of the 10 electrified RGCs (from a total of 23 surveyed RGCs). Data from these average daily load curves multiplied by the number of electrified households in a RGC (shown in Table 5-5), resulted in the daily load curves of households for the electrified RGCs.

Table 5-5 Summary Table of Surveyed Households

RGC	Province	Household			Available Load Data
		Existing in RGC	Electrified	Elec. Rate	
MPIMA	CENTRAL	1	1	100.0%	-
MPULA	CENTRAL	70	0	0.0%	-
MPUNDE	CENTRAL	500	20	4.0%	-
MISHIKISHI	COPPERBELT	350	5	1.4%	4
CHIWALA	COPPERBELT	225	6	2.7%	6
KANGONGA	COPPERBELT	140	2	1.4%	2
CHEMBE	LUAPULA	215	27	12.6%	14
LUAMFUMU	LUAPULA	200	200	100.0%	5
KALOBWA	LUAPULA	50	6	12.0%	6
KAMBWALI	LUAPULA	400	12	3.0%	12
MUNKANTA	LUAPULA	777	59	7.6%	8
CHIAWA	LUSAKA	1,120	15	1.3%	7
LUANGWA BOMA	LUSAKA	580	214	36.9%	-
KAPIJIMPANGA	NORTH WESTERN	250	0	0.0%	-
KABANDA	NORTH WESTERN	500	8	1.6%	-
NSELUKA	NORTHERN	486	20	4.1%	19
MOCHIPAPA	SOUTHERN	47	30	63.8%	-
MUSOKOTWANE	SOUTHERN	500	25	5.0%	-
MUKUNI VILLAGE	SOUTHERN	639	26	4.1%	-
MWANDI	SOUTHERN	410	110	26.8%	-
LUKULU BOMA	WESTERN	323	100	31.0%	-
SEFULA	WESTERN	170	130	76.5%	-
SELANGA	WESTERN	800	26	3.3%	-
Total		8,753	1,042	-	83
Average		380.6	45.3	21.7%	8.3




Figure 5-5 Household's Unit Daily Load Curve for Each Electrified RGC

5.7. Estimated Daily Load Curve and Peak Demand for Each Electrified RGC

A daily load curve for each electrified RGC surveyed was estimated by adding up the daily load curves of the four different types of consumer: 1) Public Facilities, 2) Business Entities, 3) Hammer Mills and 4) Households. The results of this calculation are shown in Figure 5-6, identifying the estimated daily load curves for each electrified RGC included in the survey. The daily load curves for only 8 of the 23 electrified RGCs surveyed, are plotted, since data of the 15 RGCs was insufficient to create demand curves. Hourly loads for all RGCs, which are related to the demand curves, are shown in Table 5-6. In this table, the daily peak demand for each electrified RGCs is underlined.

Based on these results, features of electricity consumption of RGCs located in the rural areas of Zambia, as provided below, were delineated.

- 1) Of the total amount of electricity consumption in a RGC, the contribution of hammer mills is high.
- 2) The daily peak demand of a RGC occurs mostly in the evening from 18:00 to 19:00, coinciding with dinnertime, during which the electricity consumption for food preparation overlaps with the operation of hammer mills.




Figure 5-6 Daily Load Curves for Electrified RGCs

Table 5-6 Time Table of Daily Demand in Surveyed Electrified RGCs (1/2)

RGC (Province)	Type of Users	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00
MISHIKISHI (COPPERBELT)	Public Facility	1,893	1,601	1,601	1,601	1,601	1,601	1,911	1,911	1,025	1,025	1,025	1,025	1,071	1,071	1,071	1,071	1,071	1,071	942	1,036	1,036	1,009	1,009	961
	Business Entity	126	0	0	0	0	0	0	7	7	119	168	168	168	126	126	56	56	56	307	307	265	249	249	182
	Hammer Mill	0	0	0	0	0	0	0	0	0	0	0	45,000	45,000	45,000	45,000	45,000	45,000	45,000	0	0	0	0	0	0
	Household	0	0	0	0	0	0	131	131	169	38	38	38	38	38	38	240	240	401	542	586	647	407	114	0
	Daily Load	1,706	1,601	1,601	1,601	1,601	1,601	1,601	2,053	2,053	1,206	1,181	1,230	1,230	1,282	1,282	1,340	1,373	1,373	1,332	1,790	1,932	1,951	1,665	1,373
D.E.c. Hammer Mill	1,706	1,601	1,601	1,601	1,601	1,601	1,601	2,053	2,053	1,206	1,181	1,230	1,230	1,282	1,282	1,340	1,373	1,373	1,332	1,790	1,932	1,951	1,665	1,373	1,149
CHEMBE (LUAPULA)	Public Facility	1,806	1,806	1,806	1,806	1,806	1,806	1,412	1,412	2,063	2,064	1,806	1,742	1,751	1,496	1,485	1,476	1,786	2,984	2,983	2,965	2,949	2,506	2,426	2,383
	Business Entity	173	173	173	173	173	182	206	206	225	169	169	225	216	216	216	159	159	900	1,032	1,130	1,505	1,496	1,496	1,417
	Hammer Mill	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Household	3,664	3,664	3,664	3,664	3,664	4,677	6,347	7,457	7,102	6,719	5,736	7,691	10,400	8,657	8,211	7,245	6,391	7,746	12,446	15,024	12,045	9,626	9,503	8,462
	Daily Load	5,645	5,645	5,645	5,645	5,645	6,381	8,181	9,075	9,381	8,988	7,735	9,391	12,376	10,339	9,911	8,881	8,338	11,682	16,372	19,118	16,459	13,629	13,427	12,262
D.E.c. Hammer Mill	5,645	5,645	5,645	5,645	5,645	6,381	8,181	9,075	9,381	8,988	7,735	9,391	12,376	10,339	9,911	8,881	8,338	11,682	16,372	19,118	16,459	13,629	13,427	12,262	
KALOBWA (LUAPULA)	Public Facility	400	400	400	400	400	400	400	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Business Entity	161	161	161	161	161	161	160	173	247	160	160	200	2,500	2,500	240	367	1,833	1,121	321	3,169	3,149	883	708	251
	Hammer Mill	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Household	504	504	504	504	504	504	504	948	426	426	405	295	500	500	500	305	305	915	1,073	1,328	1,332	1,167	942	514
	Daily Load	1,065	1,065	1,065	1,065	1,065	1,120	1,772	16,121	17,884	15,618	15,565	15,575	18,080	15,820	15,732	17,218	17,122	16,400	19,327	19,881	2,446	2,050	1,175	1,192
D.E.c. Hammer Mill	1,065	1,065	1,065	1,065	1,120	1,772	1,727	2,884	678	505	575	3,080	620	752	2,278	2,722	7,420	4,887	2,449	2,050	2,050	1,175	1,192		
KAMBWALI (LUAPULA)	Public Facility	780	780	780	780	780	780	300	300	300	300	300	300	300	300	300	300	300	780	780	836	836	836	836	
	Business Entity	542	542	542	542	542	542	542	366	366	1,696	2,008	2,008	2,008	2,008	2,008	2,008	2,008	2,008	506	817	843	840	840	
	Hammer Mill	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	Household	1,946	1,626	1,606	1,426	1,426	1,426	1,426	1,305	1,946	1,873	1,755	1,300	2,269	2,269	1,865	1,165	1,200	1,256	4,348	4,693	3,916	3,316	3,267	2,879
	Daily Load	3,276	2,950	2,930	2,780	2,780	2,780	2,592	24,147	24,936	24,540	23,305	27,501	26,963	24,933	23,879	25,353	26,007	24,648	28,000	28,261	27,591	4,932	4,941	4,255
D.E.c. Hammer Mill	3,276	2,930	2,930	2,780	2,780	2,780	2,592	2,427	2,596	2,540	4,305	3,307	2,903	2,903	7,879	3,359	4,007	2,543	6,000	6,207	5,397	4,992	4,947	4,255	
LUAMFUMU (LUAPULA)	Public Facility	541	541	541	541	541	541	467	606	974	962	977	423	448	466	504	797	780	785	842	846	946	929	923	
	Business Entity	1,692	1,692	1,692	1,692	1,692	1,692	2,412	2,412	2,412	2,412	2,412	2,412	2,412	2,412	2,412	2,412	2,412	2,506	1,961	1,936	1,936	1,786	1,692	
	Hammer Mill	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	Household	57,120	57,120	57,120	57,120	57,120	57,120	78,720	77,920	77,920	77,960	78,960	78,920	100,320	98,520	98,520	79,320	77,920	76,720	76,720	143,120	130,720	130,720	97,520	74,120
	Daily Load	59,353	59,353	59,353	59,353	59,353	59,753	81,599	81,156	81,306	81,324	82,349	81,755	103,180	101,336	82,236	81,129	79,912	80,016	145,948	145,902	133,603	133,603	103,564	100,229
D.E.c. Hammer Mill	59,353	59,353	59,353	59,353	59,753	81,599	81,156	81,306	81,324	82,349	81,755	103,180	101,336	82,236	81,129	79,912	80,016	145,948	145,902	133,603	133,603	103,564	100,229		
MUNKANTA (LUAPULA)	Public Facility	1,917	1,917	1,917	1,917	1,917	1,917	3,357	1,917	4,421	4,421	4,612	4,112	4,112	2,672	4,362	3,925	5,075	4,576	5,364	5,167	4,817	4,817	4,806	
	Business Entity	2,025	1,763	1,763	1,763	1,763	1,819	506	2,261	2,261	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	2,456	12,600	12,600	9,506	2,196	
	Hammer Mill	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	Household	4,996	3,245	3,245	3,245	3,245	3,666	6,453	17,554	17,554	17,554	17,200	17,276	16,361	13,913	9,657	11,646	11,646	11,200	11,200	17,425	17,425	12,408	7,162	
	Daily Load	8,938	6,935	6,935	6,935	6,935	8,863	38,877	54,537	54,336	53,932	57,806	56,836	47,448	45,072	46,535	47,420	48,334	65,984	69,426	94,646	94,646	29,835	23,075	
D.E.c. Hammer Mill	8,938	6,935	6,935	6,935	6,935	8,863	38,877	54,537	54,336	53,932	57,806	56,836	47,448	45,072	46,535	47,420	48,334	65,984	69,426	94,646	94,646	29,835	23,075		

Table 5-6 Time Table of Daily Demand in Surveyed Electrified RGCs (2/2)

RGC (Province)	Type of Users	000	100	200	300	400	500	600	700	800	900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	
CHIAWA (LUSAKA)	Public Facility	1,263	1,263	1,263	1,263	1,263	1,263	1,263	1,111	1,320	1,299	1,246	1,233	1,328	1,061	1,118	1,102	1,226	1,876	1,961	2,041	2,127	1,961	1,879	1,819	
	Business Entity	200	200	200	200	200	200	200	275	265	265	265	265	265	310	301	801	800	300	796	960	960	840	740	445	
	Hammer Mill	0	0	0	0	0	0	0	15,000	15,000	15,000	15,000	15,000	15,000	15,000	15,000	15,000	15,000	15,000	15,000	15,000	0	0	0	0	
	Household	3,889	3,889	3,889	3,461	3,332	2,196	5,204	6,171	5,652	1,329	1,306	1,306	1,539	6,000	4,982	3,836	2,711	2,649	2,890	7,106	7,153	4,518	4,463	3,793	4,146
	Daily Load	5,493	5,493	5,493	5,064	4,936	3,714	22,777	22,558	22,562	17,916	18,133	18,133	18,218	22,619	21,373	20,254	19,614	19,675	20,068	24,653	25,784	7,635	7,354	6,410	6,411
DL e.c. Hammer Mill		5,493	5,493	5,493	5,064	4,936	3,714	7,777	7,558	7,262	2,973	3,133	3,218	7,673	6,373	5,254	4,674	4,673	5,048	9,833	10,784	7,035	7,254	6,472	6,477	
NSELUKA (NORTHERN)	Public Facility	561	561	561	561	561	561	561	1,531	445	157	157	157	157	157	157	157	157	157	1,592	1,629	1,629	606	606	561	
	Business Entity	1,552	1,552	1,552	1,552	1,552	1,552	2,967	3,030	3,442	897	844	2,613	3,106	1,412	1,023	1,007	1,457	1,010	4,541	5,244	2,782	2,424	2,131	2,009	
	Hammer Mill	0	0	0	0	0	0	0	60,000	60,000	60,000	60,000	60,000	60,000	60,000	60,000	60,000	60,000	60,000	60,000	60,000	60,000	0	0	0	
	Household	2,660	2,639	2,639	2,577	2,577	2,577	4,399	6,119	3,774	2,646	2,206	3,916	5,597	4,071	2,686	2,453	2,541	3,066	5,263	7,890	5,460	4,386	4,032	3,496	
	Daily Load	4,773	4,732	4,732	4,690	4,690	5,708	8,348	70,631	67,661	63,701	63,206	66,888	68,656	65,640	63,864	63,617	64,165	64,365	71,667	74,733	8,891	7,418	6,773	6,968	
DL e.c. Hammer Mill		4,773	4,732	4,732	4,690	4,690	3,708	8,048	10,681	7,600	3,701	3,203	6,688	8,650	5,940	3,864	3,677	4,155	4,265	71,007	14,733	8,897	7,418	6,773	6,968	

5.8. Selection of a Daily Peak Demand Forecast Method [Step 2]

5.8.1. Relationship between Number of Households and Peak Demand of RGC

One of the characteristics of hammer mills is that they consume a considerably greater amount of electricity than other types of consumers – public facilities, business entities and households, as explained in a previous section. In addition to this characteristic, there is no significant correlation between the scale of RGCs and the number of hammer mills installed in them. Therefore, adaptability of a linear regression model to a daily peak demand forecast for an unelectrified RGC was tested in two cases: daily peak demand with and without consumption of hammer mills.

The relationship between the number of households and the daily peak demand, with hammer mills and without hammer mills, for each of the RGCs are plotted in Figure 5-7 and 5-8 respectively, based on Table 5-7 developed from data shown in Table 5-6. In both cases, no relation between the number of households and the daily peak demand were observed. Neither provincial/regional nor years after electrification tendency was found. Developed linear regression model for both cases showed negative slope, meaning the larger the number of households in a RGC, the less peak demand in a RGC, and this model indication was absolutely unrealistic. In fact, the model's coefficient of determination (R^2) is as low as 0.0135 and 0.0376 respectively. Therefore, it was safely concluded that the linear regression model having the number of households as an explanatory variable was not applicable to forecast the peak demand in a RGC.

Table 5-7 Peak Demand and Number of Households in Electrified RGCs

RGC	Province	Peak Load (W)	Peak Load Except Hammer Mills (W)	Number of Households	Year after Elec.
MISHIKISHI	COPPERBELT	46,534	2,093	350	5
CHEMBE	LUAPULA	19,118	19,118	215	1
KALOBWA	LUAPULA	19,927	4,927	50	5
KAMBWALI	LUAPULA	28,261	6,261	400	20
LUAMFUMU	LUAPULA	145,943	145,943	200	34
MUNKANTA	LUAPULA	69,476	39,476	777	1
CHIAWA	LUSAKA	25,784	10,784	1,120	6
NSELUKA	NORTHERN	74,733	14,733	486	4
All RGCs Average		53,722	30,417	450	9.5




Figure 5-7 Linear Regression Model for Peak Demand with Hammer Mills




Figure 5-8 Linear Regression Model for Peak Demand without Hammer Mills

5.8.4. Number of Hammer Mills in Unelectrified RGCs

In order to forecast the potential demand in unelectrified RGCs in 2030, an increase in the number of hammer mills needs to be taken into account, as well as the number of households as explained in the section 5.8.2. The results of the socio-economic survey indicated that each hammer mill provides services to an average of 179 households in electrified RGCs, while it provides services to an average of 172 households in unelectrified RGCs, as shown in Tables 5-8 (on the next page). The average number of households served per hammer mill (179 in electrified RGC and 172 in unelectrified RGC), however, is not statistically different between electrified and unelectrified RGC with the significance level of 95%. Therefore, disregarding the electrification status, the total average of per unit hammer mill service ratio by 174 households are adopted to forecast installed number of hammer mill in each RGC in 2030.

Among 23 RGCs listed in Table 5-1, the relationship between the hammer mill electrification rates and the year after electrification for 19 electrified RGCs (except Kabanda and Mwandi RGCs that electrification years were uncertain) were plotted in Figure 5-10. As the figure shows, there is no relationship between them. Thus, the chronological transition (escalation) of hammer mill electrification rate is disregarded in the potential demand forecast.

Taken into account above findings, Equation 5-2 indicates how the number of hammer mills in each RGC in 2030 is forecasted by using the data as of 2006.

$$\begin{aligned}
 X_{HM [2030]} &= X_{HH [2030]} / HMSR \\
 &= 1.986 \times X_{HH [2006]} / 174 \\
 &= 0.0113 \times X_{HH [2006]}
 \end{aligned}
 \tag{Equation 5-2}$$

$X_{HM [2030]}$: Forecasted Number of Hammer Mills in a RGC in 2030 (refer to Equation 5-1)

$X_{HH [2030]}$: Forecasted Number of Households in a RGC in 2030

$X_{HH [2006]}$: Number of Households in a RGC in 2006 (data submitted by district planners)

HMSR : A Unit Hammer Mill Service Ratio = 174 Household/Hammer Mill




Figure 5-10 Chronological Transition of Hammer Mill Electrification Rate

5.8.2. Growth of Number of Households in Unelectrified RGCs

Number of households in each of 1,217 unelectrified RGCs as of 2006 has been obtained as a part of data submitted from the district planners in November 2006. To forecast potential demand in 2030, the target year of the rural electrification master plan, an increase rate in the number of households for unelectrified RGCs needs to be taken into account. Household growth rate, however, is not officially available even in the census report, while population growth rate with AIDs at 2.9% per annum up to 2025 is announced in “Population Projection Report” published by Central Statistics Office in November 2003. Therefore, this population growth rate is substituted as the household growth rate, and assumed to maintain at the same rate by 2030. Equation 5-1 indicates how the number of households in each RGC in 2030 is forecasted by using the data as of 2006.

$$X_{HH [2030]} = X_{HH [2006]} \times (1+0.029)^{24} = 1.986 \times X_{HH [2006]} \tag{Equation 5-1}$$

$X_{HH [2030]}$: Forecasted Number of Households in a RGC in 2030

$X_{HH [2006]}$: Number of Households in a RGC in 2006 (data submitted by district planners)

5.8.3. Transition of Household Electrification Rate in Electrified RGCs

Among 23 RGCs listed in Table 5-1, the relationship between the household electrification rates and the year after electrification for 21 electrified RGCs (except Kabanda and Mwandi RGCs that electrification years were uncertain) were plotted in Figure 5-9. In general, it is expected that the household electrification rate increases according to the length (or years) after the electrification. Based on the collected data by the socio-economic survey, however, there are no relationships between them, even if provincial/regional aspects and the total number of households in RGCs are taken into consideration. Therefore, there is no convincing information regarding the chronological transition (escalation) of household electrification rate considered in the potential demand forecast.




Figure 5-9 Chronological Transition of Household Electrification Rate

Table 5-8 Number of Hammer Mills and Unit Servicing Households in Surveyed RGCs

RGC	Province	Status	HM in RGC	HH in RGC	HH per HM
MPULA	CENTRAL	Electrified	3	70	23
CHIPEPO	CENTRAL	Un-Electrified	1	583	583
MPUNDE	CENTRAL	Electrified	2	500	250
CHIBALE	CENTRAL	Un-Electrified	2	250	125
OLD MKUSHI	CENTRAL	Un-Electrified	2	440	220
SHIMOKUNI	CENTRAL	Un-Electrified	5	300	60
MUMBWA BIG CONCESSION	CENTRAL	Un-Electrified	4	85	21
MISHIKISHI	COPPERBELT	Electrified	4	350	88
MUTABA	COPPERBELT	Un-Electrified	2	30	15
MIKATA	COPPERBELT	Un-Electrified	2	38	19
CHIWALA	COPPERBELT	Electrified	2	225	113
KANGONGA	COPPERBELT	Electrified	1	750	750
KAMEME	COPPERBELT	Un-Electrified	0	100	-
KAKOLO	COPPERBELT	Un-Electrified	2	88	44
MUTUNDU	COPPERBELT	Un-Electrified	0	188	-
KAFUBU	COPPERBELT	Un-Electrified	2	100	50
LUFWANYAMA EMMARALD MINING AREA	COPPERBELT	Un-Electrified	-	0	-
MUNGOMBA	COPPERBELT	Un-Electrified	0	50	-
KAMITETA	COPPERBELT	Un-Electrified	-	10	-
KAPUNGWE	EASTERN	Un-Electrified	-	2,000	-
CHIPEMBE	EASTERN	Un-Electrified	1	128	128
MPOMWA TSE-TSE	EASTERN	Un-Electrified	3	750	250
MWASE	EASTERN	Un-Electrified	2	750	375
MLOLO	EASTERN	Un-Electrified	2	662	331
KAGORO	EASTERN	Un-Electrified	1	30	30
CHEMBE	LUAPULA	Electrified	2	215	108
KASONGWA SUB-BOMA	LUAPULA	Un-Electrified	2	474	237
LUAMFUMU	LUAPULA	Electrified	1	200	200
MILENGE	LUAPULA	Un-Electrified	0	780	-
CHINSANKA	LUAPULA	Un-Electrified	2	1,800	900
MUSHOTA	LUAPULA	Un-Electrified	2	443	222
KALOBWA	LUAPULA	Electrified	1	50	50
KATUTA	LUAPULA	Un-Electrified	1	155	155
CHILONGO	LUAPULA	Un-Electrified	-	950	-
KANBWALI	LUAPULA	Electrified	3	400	133
MUNKANTA	LUAPULA	Electrified	2	777	389
CHIAWA	LUSAKA	Electrified	1	112	112
NCHUTE	LUSAKA	Un-Electrified	1	93	93
CHINYUNYU	LUSAKA	Un-Electrified	1	247	247
CHIPAPA	LUSAKA	Un-Electrified	-	133	-
LUANGWA BOMA	LUSAKA	Electrified	3	580	193
KAPIJIMPANGA	NORTH WESTERN	Electrified	1	250	250
MUMEMA	NORTH WESTERN	Un-Electrified	4	163	41
NSELAUKE	NORTH WESTERN	Un-Electrified	9	275	31
MATUSHI	NORTH WESTERN	Un-Electrified	4	1,500	375
CHITOKOLOKI	NORTH WESTERN	Un-Electrified	3	1,000	333
CHIVOMBO	NORTH WESTERN	Un-Electrified	2	40	20
KASHINAKAZI	NORTH WESTERN	Un-Electrified	0	106	-
KABANDA	NORTH WESTERN	Electrified	15	500	33
SHIWANG'ANDU	NORTHERN	Un-Electrified	2	40	20
KANCHIBIYA	NORTHERN	Un-Electrified	-	50	-
CHITIMBWA	NORTHERN	Un-Electrified	4	230	58
CHIMULA	NORTHERN	Un-Electrified	0	100	-
ROSA	NORTHERN	Un-Electrified	1	416	416
MASONDE	NORTHERN	Un-Electrified	-	200	-
WULONGO	NORTHERN	Un-Electrified	0	200	-
NSAMA SUB-BOMA	NORTHERN	Un-Electrified	3	297	99
KACHUMU	NORTHERN	Un-Electrified	-	30	-
MUKUPA KAOMA	NORTHERN	Un-Electrified	3	202	67
MATIPA	NORTHERN	Un-Electrified	4	435	109
NSELUKA	NORTHERN	Electrified	4	486	122
NAMOOMBA	SOUTHERN	Un-Electrified	1	132	132
NGWEZI	SOUTHERN	Un-Electrified	-	15	-
KAUMUZYA EAST	SOUTHERN	Un-Electrified	-	69	-
SINAKAIMBI	SOUTHERN	Un-Electrified	-	17	-
MOCHIPAPA	SOUTHERN	Electrified	1	47	47
MAMBOVA	SOUTHERN	Un-Electrified	-	144	-
SIABWENGO	SOUTHERN	Un-Electrified	1	22	22
KASIYA	SOUTHERN	Un-Electrified	1	170	170
KANCHOMBA	SOUTHERN	Un-Electrified	0	600	-
MUSOKOTWANE	SOUTHERN	Electrified	1	71	71
KABANGA	SOUTHERN	Un-Electrified	2	422	211
MUKUNI VILLAGE	SOUTHERN	Electrified	2	639	320
BAMBWE	SOUTHERN	Un-Electrified	1	166	166
LUBANDA	SOUTHERN	Un-Electrified	2	200	100
MWANDI	SOUTHERN	Electrified	2	410	205
LUKULU BOMA	WESTERN	Electrified	17	323	19
SEFULA	WESTERN	Electrified	3	170	57
SIANDA	WESTERN	Un-Electrified	1	230	230
SIOMA	WESTERN	Un-Electrified	2	400	200
NANGWESHI	WESTERN	Un-Electrified	3	600	200
SENANGA	WESTERN	Electrified	2	800	400
NANGULA	WESTERN	Un-Electrified	0	26	-
NKEYEMA	WESTERN	Un-Electrified	5	428	86
SICHILI	WESTERN	Un-Electrified	7	150	21
Average			2	337	174
(St. Dev)			(2.8)	(370.4)	(171.4)
Average for Electrified RGC			3	360	179
(St. Dev)			(4.2)	(243.3)	(170.4)
Average for Unelectrified RGC			2	329	172
(St. Dev)			(1.8)	(406.9)	(174.0)

5.8.5. Other Assumptions for Demand Forecast

In addition to the numbers of households and hammer mills in a RGC, the numbers of public facilities and business entities in a RGC in 2030 also need to be assumed to forecast potential electricity demand. However, neither baseline data, such as the numbers of public facilities and business entities in each of RGCs before electrified, nor the official increase rate of these numbers are available as a secondary data. Therefore, as a most intelligent estimation, the population growth rate (2.9% per annum) is substituted as the growth rates of both public facilities and business entities. Equation 5-3 and 5-4 indicates how the number of each type of public facilities and business entities in each RGC in 2030 are forecasted by using the data as of 2006. Since the chronological transitions (escalations) of household and hammer mill electrification rate are disregarded, those for public facilities and business entities are also neglected in the potential demand forecast.

$$X_{\text{PFI}} [2030] = X_{\text{PFI}} [2006] \times (1+0.029)^{24} = 1.986 \times X_{\text{PFI}} [2006] \quad (\text{Equation 5-3})$$

$X_{\text{PFI}} [2030]$: Forecasted Number of Public Facility Type i in a RGC in 2030

$X_{\text{PFI}} [2006]$: Number of Public Facility Type i in a RGC in 2006 (data submitted by district planners)

i : Type of Public Facility shown in Table 5-2 ($i = 1 \sim 18$)

$$X_{\text{BE}} [2030] = X_{\text{BE}} [2006] \times (1+0.029)^{24} = 1.986 \times X_{\text{BE}} [2006] \quad (\text{Equation 5-4})$$

$X_{\text{BE}} [2030]$: Forecasted Number of Business Entities in a RGC in 2030

$X_{\text{BE}} [2006]$: Number of Business Entities in a RGC in 2006 (data submitted by district planners)

5.8.6. Daily Peak Demand Forecast Method

As studied in the section 5.8.1., the linear regression model does not work to forecast the daily peak demand in a RGC. On the other hand, unit daily load curves for all types of consumers – each type of Public Facilities, Business Entities, Hammer Mills, and Households – have been captured utilizing data collected by the socio-economic survey. In addition, the numbers of each type of Public Facilities, Business Entities, Hammer Mills, and Households in each of 1,217 unelectrified RGCs in 2030 are assumable based on the obtained basic RGC data as of 2006 from the district planners (refer to Equation 5-1, 5-2, 5-3 and 5-4). Therefore, in the same manner explained in the Section 5.7 to estimate daily load curve and peak demand for 8 electrified RGCs, the method of adding up the daily load curves for different types of consumers will be adopted. Assumptions for demand forecast, such as growth rates and unit daily load timetables for each type of consumers, are summarized in Table 5-9. Steps to create potential daily load curve for each of 1,217 RGCs are explained as follows and illustrated with a sample sheet shown in Table 5-10.

- Step A: Assume the numbers of Public Facilities, Business Entities, Hammer Mills, and Households in a RGC in 2030 by using Equation 5-1, 5-2, 5-3 and 5-4
- Step B: Multiply electrification rates of Public Facilities in each type, Business Entities, Hammer Mills, and Households by the number of them in 2030 obtained in Step A. Then, the numbers of electrified Public Facilities, Business Entities, Hammer Mills, and Households in a RGC in 2030 will be obtained.
- Step C: Multiply the numbers of electrified consumers obtained in Step B by the unit daily load timetables for each type of consumers shown in Table 5-9 to create the daily load timetables.
- Step D: Sum up the daily load timetables for each type of consumers and create the potential daily load table for a RGC.
- Step E: Select the maximum daily load as the daily peak demand for each RGC and use it as a design capacity of electrification facilities.

In the electrified RGCs, actual electrification rates of Business Entities, Hammer Mills, and Households are shown in Table 5-1, and these of Public Facilities in different types are summarized on Table 5-2. In Step B, however, 100% of electrification rates, instead of the actual electrification rates, for all types of consumers are adopted. This assumption that all of the Public Facilities, Business Entities, Hammer Mills, and Households in the 1,217 RGCs are electrified by 2030 seems to result in over estimation of the potential demand. However, as DoE and REA are planning to extend the electrification area from the 1,217 RGCs to the villages in the catchment areas of these RGCs after 2030, some supply margin on the design capacity of the electrification facilities needs to be considered, to be on the safe side. Therefore, after the discussions with DoE and REA, it was decided to apply 100% electrification rates for all the types of consumers to forecast the daily load of each RGC.

5.9. Forecast of Potential Demand for Unelectrified RGCs [Step 3]

Table 5-11 (from next page) shows the calculation result of the forecasted potential daily peak demand for the long listed 1,217 unelectrified RGCs. Among these unelectrified RGCs, BOMA (District Center) are give priority over the other RGCs. Then, RGCs other than BOMA are ranked by the size of potential demand (application of “Demand Criteria”). This is the temporary electrification order for 1,217 RGCs.

Table 5-11 Temporary Electrification Priority of RGCs Based on Demand Criteria (1/13)

Ranking	RGC	District	Priority	Province	# of HHs (2006)	# of HHs (2030)	Daily Max Load
1	Mpulungu Central	Mpulungu	4	Northern	2,000	3,972	2,200,731
2	Mwinilunga Boma	Mwinilunga	0	North-Western	1,900	3,774	2,093,225
3	Shangombo	Shangombo	1	Western	1,100	2,185	1,277,541
4	Boma	Luangwa	1	Lusaka	580	1,152	752,118
5	Chienge	Chienge	6	Luapula	560	1,113	642,046
6	Mpongwe	Mpongwe	22	Copperbelt	441	876	499,270
7	Nsama Sub Boma	Kaputa	1	Northern	441	876	499,270
8	Talayi	Milenge	1	Luapula	202	402	241,663
9	KPG Market	Kapiri Mposhi	22	Central	7,400	14,697	8,141,484
10	Chisanga	Kasama	9	Northern	5,000	9,930	5,530,061
11	Chindenza School	Katete	3	Eastern	5,000	9,930	5,515,225
12	Mtandaza RHC	Katete	5	Eastern	5,000	9,930	5,509,327
13	Kagoro	Katete	1	Eastern	4,000	7,944	4,401,462
14	Sikapila	Mporokoso	2	Northern	3,646	7,241	4,012,551
15	Kauwe	Kazungula	14	Southern	3,511	6,973	3,927,399
16	Palace Chipepo Mukuni-Ngombe	Kapiri Mposhi	23	Central	3,500	6,951	3,847,529
17	Twapia	Ndola	2	Copperbelt	3,333	6,620	3,735,864
18	Nchembwe	Kapiri Mposhi	20	Central	3,100	6,157	3,416,570
19	Kapungwe	Petauke	1	Eastern	3,084	6,125	3,407,622
20	Nyamphinga	Petauke	10	Eastern	3,084	6,125	3,405,327
21	Chikalawa	Petauke	12	Eastern	3,084	6,125	3,402,990
22	Mwanjwanthuthu	Petauke	3	Eastern	3,036	6,030	3,345,943
23	Kasenengwa Rural Centre	Chipata	5	Eastern	3,000	5,958	3,321,933
24	Kamphambe	Katete	7	Eastern	3,000	5,958	3,308,596
25	Sikatengwa	Lundazi	22	Eastern	2,949	5,857	3,246,409
26	Mushili	Samfya	18	Luapula	2,751	5,464	3,032,798
27	Madimawe Rural Health Centre	Chipata	8	Eastern	2,667	5,297	2,953,674
28	Matonje	Petauke	13	Eastern	2,587	5,138	2,851,518
29	Mumbi	Petauke	5	Eastern	2,503	4,971	2,762,099
30	Kawama East	Mufulira	6	Copperbelt	2,448	4,862	2,732,408
31	Chimutende,	Katete	2	Eastern	2,472	4,910	2,728,967
32	Thendere	Isoka	4	Northern	2,400	4,767	2,698,020
33	Nitpo	Isoka	7	Northern	2,420	4,807	2,685,921
34	Chinkhombe	Katete	13	Eastern	2,385	4,737	2,634,234
35	Mushindomo	Solwezi	21	North-Western	2,380	4,727	2,628,469
36	Mulekatembo	Isoka	5	Northern	2,350	4,667	2,618,045
37	Kaula	Kabompo	14	North-Western	2,350	4,667	2,585,437
38	Lukulu Township	Lukulu	1	Western	2,012	3,996	2,512,048
39	Nande	Senanga	8	Western	2,148	4,266	2,393,483
40	George Camp	Ndola	4	Copperbelt	2,165	4,300	2,383,973
41	Sansamwente	Isoka	8	Northern	2,120	4,211	2,368,121
42	Chipashi Island	Nchelenge	13	Luapula	2,114	4,199	2,341,746
43	Kasheke	Mongu	38	Western	2,100	4,171	2,308,704
44	Musakashi	Kalulushi	2	Copperbelt	2,000	3,972	2,251,135
45	Nyembe	Katete	10	Eastern	2,000	3,972	2,210,561
46	Sirunga	Senanga	5	Western	1,990	3,953	2,207,358
47	Muchabi	Mumbwa	8	Central	2,000	3,972	2,202,071
48	Mng'omba School	Katete	4	Eastern	2,000	3,972	2,200,731
49	Makuku	Mongu	36	Western	2,000	3,972	2,200,731
50	Kaulu	Petauke	7	Eastern	1,988	3,949	2,192,975
51	Mukupakaoma	Mporokoso	1	Northern	1,974	3,921	2,176,903
52	Lui-mwemba	Senanga	4	Western	1,935	3,843	2,165,744
53	Namabuka	Senanga	18	Western	1,935	3,843	2,154,070
54	Chishamwamba	Mporokoso	5	Northern	1,930	3,833	2,135,790
55	Mwimba	Lundazi	24	Eastern	1,842	3,659	2,039,496
56	Lukulu HC, Sch, Mkt	Mpika	8	Northern	1,800	3,575	2,011,559
57	Matipa	Chilubi	2	Northern	1,817	3,609	2,001,136
58	Ikelenge	Mwinilunga	2	North-Western	1,763	3,502	1,995,148
59	Likondwana	Shangombo	17	Western	1,800	3,575	1,990,633
60	Chitoshi	Mporokoso	3	Northern	1,730	3,436	1,905,310
61	Nasilimwe	Senanga	13	Western	1,634	3,246	1,823,877
62	Mulundu	Mwense	20	Luapula	1,584	3,146	1,822,353
63	Nyamphande NSS	Petauke	4	Eastern	1,650	3,277	1,819,103
64	Monde	Petauke	9	Eastern	1,650	3,277	1,817,477
65	Nasilimwe_	Senanga	15	Western	1,634	3,246	1,817,115
66	Nalolo	Senanga	7	Western	1,634	3,246	1,810,953
67	Sasali	Petauke	6	Eastern	1,608	3,194	1,781,938
68	Chikowa	Petauke	8	Eastern	1,608	3,194	1,780,008
69	Liliachi	Senanga	3	Western	1,533	3,045	1,715,109
70	Nangucha	Senanga	9	Western	1,511	3,001	1,699,508
71	Chitawe RHC	Katete	6	Eastern	1,500	2,979	1,661,798
72	Bwalinge	Luwingu	25	Northern	1,500	2,979	1,661,798
73	Murundu	Mufulira	4	Copperbelt	1,476	2,932	1,658,437
74	Luansobe	Mufulira	2	Copperbelt	1,488	2,956	1,651,057
75	Kaunga Mashi	Shangombo	15	Western	1,474	2,928	1,626,387
76	SITULU	Kalabo	29	Western	1,472	2,924	1,621,102
77	Big Concession	Mumbwa	1	Central	1,463	2,906	1,612,692
78	Township	Kawambwa	9	Luapula	1,281	2,545	1,608,850
79	Chasela	Lundazi	25	Eastern	1,444	2,868	1,594,939
80	Lwanda	Kalabo	22	Western	1,436	2,852	1,591,204
81	Ngundi	Senanga	14	Western	1,398	2,777	1,557,863
82	Silumbi	Senanga	6	Western	1,398	2,777	1,554,040
83	Muyombe	Isoka	1	Northern	1,340	2,662	1,543,584
84	Misolo	Petauke	11	Eastern	1,398	2,777	1,541,581
85	Kazabami	Kaoma	42	Western	1,385	2,751	1,525,276
86	Kafumbwe School	Katete	14	Eastern	1,308	2,598	1,468,131
87	Natukoma	Shangombo	8	Western	1,312	2,606	1,452,188
88	Chinyingi	Zambezi	18	North-Western	1,307	2,596	1,437,859
89	Mbeza	Namwala	5	Southern	1,283	2,548	1,433,278
90	Kawanda	Kabompo	13	North-Western	1,300	2,582	1,431,318
91	Kaba Hill	Kaoma	39	Western	1,287	2,556	1,420,511
92	Mulela	Mpongwe	12	Copperbelt	1,270	2,523	1,408,669
93	St. Anthony	Mpongwe	21	Copperbelt	1,270	2,523	1,403,754
94	Nakamborna (Namakaka)	Namwala	11	Southern	1,250	2,483	1,398,475
95	Kafwimbi	Isoka	2	Northern	1,230	2,443	1,388,576
96	Kapatu	Mporokoso	14	Northern	1,200	2,384	1,369,252
97	Chilasa	Katete	8	Eastern	1,215	2,413	1,337,361
98	Katibunga	Mpika	5	Northern	1,200	2,384	1,335,519
99	Lukali Community School	Kabwe	6	Central	1,200	2,384	1,328,418
100	Sinde	Kazungula	15	Southern	1,200	2,384	1,323,812

Table 5-11 Temporary Electrification Priority of RGCs Based on Demand Criteria (2/13)

Ranking	RGC	District	Priority	Province	# of HHs (2006)	# of HHs (2030)	Daily Max Load
101	Mwiima	Chilubi	14	Northern	1,192	2,368	1,316,337
102	Chalabesa Hospital	Mpika	4	Northern	1,167	2,318	1,303,700
103	Kawungu	Isoka	3	Northern	1,125	2,235	1,251,248
104	Kampumbu (Kamrinsu)	Isoka	6	Northern	1,102	2,189	1,231,982
105	Muwele	Mpika	17	Northern	1,100	2,185	1,228,814
106	Moolola	Namwala	2	Southern	1,083	2,151	1,221,232
107	Mupamadzi Farm Block	Mpika	3	Northern	1,100	2,185	1,221,213
108	Chilanga	Mambwe	13	Eastern	1,100	2,185	1,215,839
109	Katutwa	Mporokoso	9	Northern	1,100	2,185	1,215,839
110	Mwense	Mwense	18	Luapula	1,013	2,012	1,212,634
111	Ukwimi	Petauke	2	Eastern	1,070	2,125	1,194,181
112	Kasaba	Samfa	16	Luapula	1,023	2,032	1,193,337
113	Mpepo HC, Sch, Palace	Mpika	6	Northern	1,050	2,086	1,178,152
114	Itapa	Namwala	3	Southern	1,000	1,986	1,146,383
115	Mbati	Mpika	18	Northern	1,000	1,986	1,145,733
116	Sipuma	Shangombo	16	Western	1,023	2,032	1,132,773
117	Mulele	Shangombo	9	Western	1,017	2,020	1,128,725
118	Kaindu	Mumbwa	11	Central	1,000	1,986	1,125,917
119	Baambwe	Namwala	1	Southern	1,000	1,986	1,125,502
120	Simakumba	Lukulu	7	Western	1,000	1,986	1,116,242
121	Kaunga Lueti	Senanga	11	Western	992	1,971	1,115,114
122	Mansha Farm Block	Mpika	2	Northern	1,000	1,986	1,114,908
123	Tuuwa	Kalabo	26	Western	1,006	1,998	1,113,472
124	Nile Kapambwe	Nchelenge	4	Luapula	1,000	1,986	1,112,230
125	Matunga School	Katete	12	Eastern	1,000	1,986	1,108,465
126	Naviluri	Chadiza	7	Eastern	1,000	1,986	1,107,865
127	Mano	Samfa	19	Luapula	1,000	1,986	1,107,865
128	Munshinga	Luwingu	23	Northern	1,000	1,986	1,107,865
129	Likutwe	Mongu	37	Western	1,000	1,986	1,107,865
130	Chifulube	Luanshya	2	Copperbelt	992	1,971	1,106,950
131	Kalio	Chingola	3	Copperbelt	953	1,893	1,079,160
132	Mutenda	Chingola	6	Copperbelt	954	1,895	1,078,866
133	Kamiteta	Chingola	1	Copperbelt	950	1,887	1,069,442
134	Mutaba	Masaiti	1	Copperbelt	960	1,907	1,061,796
135	Mutundu North (Conner Bar)	Mfulira	1	Copperbelt	952	1,891	1,061,520
136	Chinsanka	Samfa	1	Luapula	914	1,816	1,049,654
137	Lukwesa	Mwense	14	Luapula	944	1,875	1,040,539
138	Mabo Kafutuma	Nchelenge	14	Luapula	932	1,851	1,036,124
139	Musangu	Mwense	15	Luapula	917	1,822	1,034,612
140	Ngabo	Namwala	7	Southern	917	1,822	1,021,934
141	Beshe	Shangombo	10	Western	912	1,812	1,017,937
142	Chilese	Masaiti	13	Copperbelt	909	1,806	1,017,488
143	Lubwe	Samfa	17	Luapula	841	1,671	1,015,104
144	Kaf GRZ	Masaiti	3	Copperbelt	909	1,806	1,013,898
145	Mupambe	Mfulira	7	Copperbelt	900	1,788	1,000,359
146	Ncheke	Mambwe	12	Eastern	900	1,788	1,000,359
147	Kanfinsa	Luwingu	24	Northern	900	1,788	1,000,359
148	Chilwa	Kapiri Mposhi	9	Central	892	1,772	996,433
149	Mata	Senanga	10	Western	878	1,744	993,470
150	Songa	Senanga	12	Western	878	1,744	992,378
151	Mwanamwalye	Senanga	16	Western	878	1,744	988,485
152	Kantanta	Chilubi	13	Northern	887	1,762	988,212
153	Chichile	Chilubi	6	Northern	863	1,714	950,786
154	Luamba	Kaoma	40	Western	860	1,708	947,983
155	Mwase	Lundazi	1	Eastern	797	1,583	947,541
156	Mumba	Mumbwa	14	Central	850	1,689	940,446
157	Mofu R4	Chilubi	16	Northern	849	1,687	938,172
158	Muchila	Namwala	6	Southern	833	1,655	937,271
159	Kantengwa	Namwala	9	Southern	833	1,655	935,323
160	Nangula	Mongu	1	Western	821	1,631	930,972
161	Matondo	Zambezi	14	North-Western	840	1,669	929,762
162	Liangati	Senanga	21	Western	800	1,589	927,702
163	Ipafu	Chingola	4	Copperbelt	800	1,589	926,433
164	Emusa	Lundazi	2	Eastern	797	1,583	926,078
165	Lukalany	Mongu	4	Western	834	1,657	925,496
166	Kalengola	Shangombo	6	Western	826	1,641	925,019
167	Nangweshi	Shangombo	4	Western	800	1,589	924,841
168	Chiwele	Chilubi	11	Northern	824	1,637	914,812
169	Josias Chiwala Farm	Kabwe	7	Central	820	1,629	914,309
170	Mupapa	Masaiti	5	Copperbelt	818	1,625	913,649
171	Kataba	Senanga	17	Western	799	1,587	910,948
172	Kachuma	Kasama	1	Northern	805	1,599	900,733
173	Chilanga	Mambwe	9	Eastern	800	1,589	897,768
174	Mwansabombwe	Kawambwa	15	Luapula	750	1,490	893,832
175	keezwa	Mumbwa	7	Central	800	1,589	893,726
176	Katanhsya	Samfa	7	Luapula	786	1,561	893,334
177	Maimwene settlement	Mumbwa	5	Central	800	1,589	892,386
178	Kawasa	Chilubi	15	Northern	800	1,589	892,386
179	Isoko	Mpulungu	6	Northern	800	1,589	892,386
180	Chilumba	Mpulungu	12	Northern	800	1,589	892,386
181	Dipalata	Zambezi	5	North-Western	800	1,589	892,386
182	Ikabako	Mongu	40	Western	800	1,589	892,386
183	Mimbula Block	Chingola	2	Copperbelt	780	1,550	870,943
184	Kabole	Chiengi	7	Luapula	730	1,450	867,114
185	Chabukasansha	Chilubi	23	Northern	787	1,563	865,238
186	Kambashi	Chilubi	1	Northern	715	1,420	861,662
187	Mwansakombe	Samfa	14	Luapula	767	1,524	856,639
188	Kangomba Health Centre	Kabwe	10	Central	770	1,530	852,925
189	Mayuka	Chilubi	5	Northern	762	1,514	842,346
190	Ichila	Namwala	13	Southern	750	1,490	839,343
191	Siluwe	Kalabo	23	Western	755	1,500	835,805
192	Mokambo	Mfulira	3	Copperbelt	719	1,428	832,900
193	Lambwe Chomba	Chiengi	2	Luapula	720	1,430	832,044
194	Kaande	Mongu	13	Western	746	1,482	827,395
195	Mundubi	Samfa	15	Luapula	716	1,422	815,642
196	Sianda	Senanga	1	Western	711	1,413	807,323
197	Mununga	Chiengi	9	Luapula	710	1,411	805,208
198	Sitoti	Shangombo	5	Western	710	1,411	799,948
199	Mutomena	Shangombo	7	Western	706	1,403	797,194
200	Madziyera	Chadiza	13	Eastern	710	1,411	794,224

Table 5-11 Temporary Electrification Priority of RGCs Based on Demand Criteria (3/13)

Ranking	RGC	District	Priority	Province	# of HHs (2006)	# of HHs (2030)	Daily Max Load
201	Kashitu	Chilubi	18	Northern	705	1,401	792,232
202	Katima	Sesheke	3	Western	685	1,361	790,330
203	Kasamanda	Mambwe	4	Eastern	670	1,331	784,002
204	Chiwena	Mumbwa	15	Central	700	1,391	775,152
205	Chibwika	Mwinilunga	8	North-Western	697	1,385	773,525
206	Sakandingo	Kabompo	2	North-Western	685	1,361	771,159
207	Mutamba	Mufulira	8	Copperbelt	700	1,391	769,880
208	Zingalume	Chadiza	15	Eastern	700	1,391	769,880
209	Isunga	Mpungu	13	Northern	700	1,391	769,880
210	Milomboyi	Zambezi	12	North-Western	700	1,391	769,880
211	Mubili	Chilubi	7	Northern	691	1,373	761,470
212	Shinono	Kaoma	7	Western	656	1,303	760,211
213	Matebele	Shangombo	11	Western	680	1,351	759,172
214	Nyela	Nakonde	6	Northern	656	1,303	758,766
215	Mabo-Ninge	Samfa	6	Luapula	648	1,287	758,703
216	Lubunda	Mwense	17	Luapula	664	1,319	751,284
217	Putu	Chiengi	5	Luapula	620	1,232	749,854
218	Katongo Kapala	Mpika	12	Northern	650	1,291	729,504
219	Egichakeni	Lundazi	5	Eastern	638	1,268	728,160
220	Miulwe	Mongu	22	Western	655	1,301	727,831
221	Kambowa	Masaiti	8	Copperbelt	650	1,291	727,603
222	Twingi	Samfa	3	Luapula	640	1,272	726,560
223	Magumwi	Sesheke	11	Western	651	1,293	726,119
224	Mufubushi Resettlement	Mpika	7	Northern	650	1,291	725,870
225	Nkhangwa	Lundazi	19	Eastern	640	1,272	723,299
226	Mukangu	Mongu	30	Western	648	1,287	721,290
227	Chilolwa	Nakonde	4	Northern	600	1,192	721,029
228	M_Mphanga	Lundazi	4	Eastern	618	1,228	718,733
229	Nakato	Mongu	16	Western	645	1,281	718,487
230	Lucembe	Mpika	11	Northern	620	1,232	709,285
231	Lupiya	Chiengi	1	Luapula	600	1,192	708,616
232	Mulenga M	Mporokoso	16	Northern	600	1,192	707,346
233	Lwata	Luwingu	25	Northern	630	1,252	704,938
234	Chilubula	Kasama	11	Northern	615	1,222	704,161
235	Mchereka	Lundazi	13	Eastern	618	1,228	701,009
236	Kawena	Chilubi	9	Northern	623	1,238	698,397
237	Mwenda	Mwense	21	Luapula	600	1,192	687,254
238	Kakolo	Kitwe	1	Copperbelt	600	1,192	679,323
239	Nawinda	Sesheke	10	Western	613	1,218	676,829
240	Kasembe	Chiengi	3	Luapula	590	1,172	675,608
241	Chiunda Ponde	Mpika	15	Northern	590	1,172	674,171
242	Chipepa	Kawambwa	13	Luapula	603	1,198	672,612
243	Mpusu	Mumbwa	12	Central	600	1,192	671,111
244	Keyana	Shangombo	18	Western	601	1,194	666,256
245	Kapeya Farms	Katete	9	Eastern	600	1,192	665,346
246	Ndau	Mongu	20	Western	603	1,198	664,709
247	Nambolomoka	Shangombo	20	Western	600	1,192	664,229
248	Chinunda	Chipata	11	Eastern	600	1,192	663,246
249	Lukulu RR Scheme	Kasama	13	Northern	600	1,192	662,506
250	Mbilimwenge	Samfa	5	Luapula	586	1,164	662,018
251	Mawawa	Mongu	10	Western	600	1,192	661,906
252	Sinjembela	Shangombo	14	Western	593	1,178	659,764
253	Makaba	Namwala	8	Southern	583	1,158	657,604
254	Kasanka	Samfa	2	Luapula	565	1,123	655,828
255	Chalabesa	Mporokoso	11	Northern	590	1,172	653,590
256	Lukweta	Mongu	12	Western	584	1,160	646,956
257	Mayukwayukwa	Kaoma	9	Western	564	1,121	644,531
258	Kaloko	Masaiti	2	Copperbelt	571	1,134	644,123
259	Mnauke	Lundazi	15	Eastern	571	1,134	637,758
260	Henry Kapata	Kasama	10	Northern	570	1,132	636,868
261	Mutotosho	Mporokoso	7	Northern	573	1,138	636,677
262	Muchinshi	Chingola	5	Copperbelt	537	1,067	636,432
263	Sibukail	Senanga	2	Western	554	1,101	635,651
264	Nalwei	Mongu	2	Western	566	1,125	631,696
265	Kapala	Mwense	13	Luapula	567	1,127	630,604
266	Kalumwange	Kaoma	3	Western	553	1,099	629,225
267	Luampungu	Sesheke	16	Western	554	1,101	621,073
268	Mule	Chilubi	21	Northern	551	1,095	616,587
269	Chikumbi	Masaiti	9	Copperbelt	539	1,071	613,110
270	Malaila	Mporokoso	15	Northern	510	1,013	608,717
271	Kanama	Chilubi	20	Northern	542	1,077	608,178
272	Kanama	Chilubi	24	Northern	542	1,077	608,178
273	Ilendela	Nakonde	2	Northern	514	1,021	607,530
274	Chinondo	Masaiti	4	Copperbelt	530	1,053	606,768
275	Kaf Miss	Masaiti	12	Copperbelt	532	1,057	604,603
276	Likungu	Zambezi	15	North-Western	534	1,061	600,703
277	Mporokoso	Mporokoso	13	Northern	500	993	599,994
278	Wulongo	Nakonde	1	Northern	500	993	599,967
279	Kantongo	Nakonde	3	Northern	500	993	589,901
280	Mushota	Kawambwa	2	Luapula	500	993	587,344
281	Nsefu	Mambwe	7	Eastern	523	1,039	583,496
282	Shibuyunji	Mumbwa	2	Central	500	993	580,710
283	Namakube	Monze	22	Southern	514	1,021	579,258
284	Mwewa	Samfa	13	Luapula	501	995	579,257
285	Sakania	Ndola	3	Copperbelt	500	993	578,859
286	Kaanja	Shangombo	13	Western	518	1,029	577,460
287	Nasange	Mongu	28	Western	525	1,043	577,293
288	Salanga	Kawambwa	8	Luapula	500	993	577,010
289	Kanchibiya Farm Block	Mpika	1	Northern	515	1,023	573,628
290	Sioma	Shangombo	2	Western	500	993	573,556
291	Makunka	Kazungula	4	Southern	482	958	573,137
292	Kamphasa	Mambwe	14	Eastern	520	1,033	572,621
293	Niko	Namwala	4	Southern	500	993	571,985
294	Mukungule	Mpika	14	Northern	492	978	569,414
295	Kawiku	Mwinilunga	20	North-Western	512	1,017	568,904
296	St. Joseph	Lufwanyama	42	Copperbelt	500	993	568,157
297	Namono	Shangombo	19	Western	512	1,017	567,469
298	Malama	Mporokoso	12	Northern	513	1,019	566,080
299	Kabinga	Mpika	16	Northern	493	980	564,767
300	Rufunsa	Chongwe	2	Lusaka	507	1,007	563,380

Table 5-11 Temporary Electrification Priority of RGCs Based on Demand Criteria (4/13)

Ranking	RGC	District	Priority	Province	# of HHs (2006)	# of HHs (2030)	Daily Max Load
301	Mukumbo	Lufwanyama	12	Copperbelt	500	993	562.696
302	Kanyemba	Mwense	8	Luapula	500	993	559.250
303	Ncheke	Mambwe	8	Eastern	500	993	558.267
304	Kapofu	Chilubi	10	Northern	504	1,001	557.670
305	Kalundwans	Mongu	5	Western	502	997	555.802
306	Lukanga	Mpongwe	4	Copperbelt	500	993	553.933
307	Kapirimpika	Chadiza	12	Eastern	500	993	553.933
308	Isanganu	Luwingu	24	Northern	500	993	553.933
309	Mudunyama	Mwinilunga	21	North-Western	500	993	553.933
310	Chitupila	Chilubi	8	Northern	499	991	552.998
311	Luandui	Mongu	34	Western	499	991	552.998
312	Simulumbe	Mongu	3	Western	493	980	548.202
313	Mabumbu	Sesheke	7	Western	490	974	547.722
314	Kalobwa	Chiengi	12	Luapula	475	944	547.328
315	Mweeke	Mongu	23	Western	490	974	545.056
316	Nkhoko	Mambwe	5	Eastern	480	954	542.995
317	Chasefu	Lundazi	6	Eastern	473	940	537.890
318	Chalata	Mkushi	2	Central	441	876	537.200
319	Emerald Mining Area	Lufwanyama	1	Copperbelt	441	876	535.746
320	Chambeshi Sch, Mkt	Mpika	9	Northern	450	894	534.029
321	Chipunka	Kawambwa	18	Luapula	455	904	533.907
322	Kalembwe	Chiengi	10	Luapula	450	894	533.146
323	Ntambu	Mwinilunga	1	North-Western	416	827	532.399
324	Nsumbu RH	Chilubi	19	Northern	476	946	531.974
325	Namengo	Mongu	26	Western	476	946	531.974
326	Niola Camp	Monze	27	Southern	450	894	529.553
327	Ngoli	Mungwi	3	Northern	472	938	528.237
328	Chibale	Serenje	1	Central	441	876	521.726
329	Myooye	Mumbwa	3	Central	450	894	521.326
330	Mukando	Serenje	3	Central	441	876	519.945
331	Itumbi	Itezhi-tezhi	4	Southern	462	918	518.892
332	Kawama	Chilabombwe	3	Copperbelt	450	894	518.757
333	Fikola	Kapiri Mposhi	15	Central	441	876	518.472
334	Chishimba	Kasama	12	Northern	450	894	516.229
335	Chilumba	Kapiri Mposhi	12	Central	441	876	514.483
336	Nankaga	Kafue	6	Lusaka	441	876	513.777
337	Bbombo	Monze	29	Southern	450	894	513.461
338	Fube	Chilubi	4	Northern	456	906	513.286
339	Nchimishi	Serenje	2	Central	441	876	512.769
340	Chancomo	Kapiri Mposhi	14	Central	441	876	512.245
341	Old Mkushi	Mkushi	1	Central	421	837	510.794
342	Kafulu	Kapiri Mposhi	18	Central	441	876	510.550
343	Mpelembe	Serenje	7	Central	441	876	509.458
344	Ndabala	Serenje	6	Central	441	876	508.668
345	Kabweza	Kafue	9	Lusaka	441	876	508.564
346	Kabanga	Kalomo	2	Southern	441	876	508.325
347	Muyembe	Zambezi	19	North-Western	450	894	507.680
348	Nielele	Serenje	4	Central	441	876	506.508
349	Chailo	Serenje	5	Central	441	876	506.151
350	Ltande	Mongu	29	Western	448	890	505.811
351	Nkandanzovu	Kalomo	3	Southern	441	876	505.526
352	Napatizya	Kalomo	1	Southern	441	876	505.143
353	Mbereshi	Kawambwa	17	Luapula	400	795	504.582
354	Lunchu	Kapiri Mposhi	4	Central	441	876	503.993
355	Mukubwe	Kapiri Mposhi	10	Central	441	876	503.993
356	Kaungeta	Mongu	14	Western	446	886	503.942
357	Gibson	Serenje	8	Central	441	876	503.726
358	Machende	Serenje	9	Central	441	876	503.202
359	Luyaba	Kalomo	4	Southern	441	876	503.085
360	Kanchele	Kalomo	6	Southern	441	876	503.085
361	Bbilibi	Kalomo	7	Southern	441	876	503.085
362	Chilala	Kalomo	8	Southern	441	876	503.085
363	Mabombo	Kalomo	9	Southern	441	876	503.085
364	Likumbo	Kapiri Mposhi	3	Central	441	876	502.957
365	Kasukwe	Kalomo	5	Southern	441	876	502.593
366	Nakatambo	Serenje	13	Central	441	876	502.429
367	Kofi Kunda	Serenje	16	Central	441	876	502.219
368	Sichili	Sesheke	1	Western	402	799	502.063
369	Katikululu	Serenje	11	Central	441	876	501.955
370	Katongo	Serenje	12	Central	441	876	501.767
371	Kafumba	Kapiri Mposhi	13	Central	441	876	501.703
372	Mphamba	Lundazi	21	Eastern	441	876	501.670
373	Mubalashi	Kapiri Mposhi	16	Central	441	876	500.983
374	Simakakata	Kalomo	10	Southern	441	876	500.953
375	Mutala	Kalomo	11	Southern	441	876	500.953
376	Darphan	Kalomo	14	Southern	441	876	500.953
377	Lukanda	Kapiri Mposhi	6	Central	441	876	500.610
378	Chipundu	Serenje	10	Central	441	876	500.610
379	Maijo	Serenje	17	Central	441	876	500.610
380	C. Sali	Serenje	18	Central	441	876	500.610
381	Kawama	Serenje	19	Central	441	876	500.610
382	Masase	Serenje	20	Central	441	876	500.610
383	Mpande	Serenje	21	Central	441	876	500.610
384	C. Serenje	Serenje	22	Central	441	876	500.610
385	Chisale	Katete	15	Eastern	441	876	500.610
386	Kafunka	Katete	16	Eastern	441	876	500.610
387	Kazonde	Lundazi	23	Eastern	441	876	500.363
388	Chikoli	Kalomo	12	Southern	441	876	499.613
389	Kinnertone	Kalomo	13	Southern	441	876	499.613
390	Mubofwa	Kapiri Mposhi	5	Central	441	876	499.270
391	Lubuto	Kapiri Mposhi	17	Central	441	876	499.270
392	Kaswende	Kapiri Mposhi	19	Central	441	876	499.270
393	Masansa	Kapiri Mposhi	21	Central	441	876	499.270
394	Musangashi	Serenje	14	Central	441	876	499.270
395	Nsala	Serenje	15	Central	441	876	499.270
396	Ibenga	Mpongwe	23	Copperbelt	441	876	499.270
397	Chikonka	Chadiza	8	Eastern	441	876	499.270
398	Mchenjera	Chadiza	9	Eastern	441	876	499.270
399	Chigwe	Chadiza	10	Eastern	441	876	499.270
400	Kapachi	Chadiza	11	Eastern	441	876	499.270

Table 5-11 Temporary Electrification Priority of RGCs Based on Demand Criteria (5/13)

Ranking	RGC	District	Priority	Province	# of HHs (2006)	# of HHs (2030)	Daily Max Load
401	Kalemba	Chadiza	14	Eastern	441	876	499,270
402	Kaozi Settlement	Chama	2	Eastern	441	876	499,270
403	Kalimankonde	Samfa	20	Luapula	441	876	499,270
404	Kapilibila	Samfa	21	Luapula	441	876	499,270
405	Kapumbu	Samfa	22	Luapula	441	876	499,270
406	Maela	Chilubi	12	Northern	441	876	499,270
407	Bukotelo	Chilubi	17	Northern	441	876	499,270
408	Chilamba	Chilubi	22	Northern	441	876	499,270
409	Kampinda	Kaputa	2	Northern	441	876	499,270
410	Munwa	Kaputa	3	Northern	441	876	499,270
411	Masonde Farming Block	Luwingu	1	Northern	441	876	499,270
412	Ipusukilo Mission	Luwingu	2	Northern	441	876	499,270
413	Njeke Basic School	Luwingu	3	Northern	441	876	499,270
414	Chiponde Basic School and Chief Chipalo's Palace	Luwingu	4	Northern	441	876	499,270
415	Chitofwe Basic School	Luwingu	5	Northern	441	876	499,270
416	Tolopa Basic School	Luwingu	6	Northern	441	876	499,270
417	Nsanja Basic School	Luwingu	7	Northern	441	876	499,270
418	Menga Basic School and Clinic	Luwingu	8	Northern	441	876	499,270
419	Chakungubala Basic School	Luwingu	9	Northern	441	876	499,270
420	Lwenge Basic School	Luwingu	10	Northern	441	876	499,270
421	Laurent Chita Basic School and Clinic	Luwingu	11	Northern	441	876	499,270
422	Mufili Basic School	Luwingu	12	Northern	441	876	499,270
423	Makolongo Basic School	Luwingu	13	Northern	441	876	499,270
424	Lwena Basic School and Clinic	Luwingu	14	Northern	441	876	499,270
425	Tungati Basic School and Clinic	Luwingu	15	Northern	441	876	499,270
426	Saili Basic School	Luwingu	16	Northern	441	876	499,270
427	Chikumanino Market	Luwingu	17	Northern	441	876	499,270
428	Isandulula Peri-urban Community	Luwingu	18	Northern	441	876	499,270
429	Chief Tungati's Palace and School	Luwingu	19	Northern	441	876	499,270
430	Kapisha School	Luwingu	20	Northern	441	876	499,270
431	Lupili Market	Luwingu	21	Northern	441	876	499,270
432	Nsombo	Luwingu	22	Northern	441	876	499,270
433	Chiwala	Mporokoso	4	Northern	441	876	499,270
434	Samende	Kabompo	10	North-Western	441	876	499,270
435	Kalumbu	Kalabo	24	Western	441	876	499,270
436	LULANUNYI	Kalabo	27	Western	441	876	499,270
437	Kapili	Kaoma	41	Western	441	876	499,270
438	Kanglonga	Ndola	1	Copperbelt	400	795	496,733
439	Mwembeshi_mano	Kafue	8	Lusaka	400	795	494,497
440	Chewe	Mporokoso	17	Northern	400	795	491,867
441	Z Chanda	Mporokoso	18	Northern	400	795	491,867
442	Namakwi	Kasama	8	Northern	430	854	491,428
443	Chiawa Central	Kafue	4	Lusaka	425	845	488,291
444	Kafweku	Mwinilunga	15	North-Western	435	864	484,388
445	Miponda	Samfa	4	Luapula	431	856	483,959
446	Nyakaseya	Mwinilunga	3	North-Western	400	795	482,400
447	Kopa	Mpika	10	Northern	410	815	478,208
448	Shitwa	Kaoma	5	Western	423	841	477,944
449	Shimukuni	Chibombo	1	Central	400	795	477,768
450	Ngwezi	Mazabuka	1	Southern	410	815	476,507
451	Kambwali	Nchelenge	20	Luapula	420	835	475,457
452	Loazamba	Sesheke	21	Western	428	850	474,491
453	Matala	Mumbwa	18	Central	420	835	474,319
454	Kalabwe	Mporokoso	10	Northern	425	845	471,157
455	Nyengo	Kalabo	25	Western	425	845	469,787
456	Mukuma	Kawambwa	5	Luapula	402	799	469,068
457	Nalikwanda	Mongu	19	Western	424	843	468,852
458	Mwabu	Chiengi	4	Luapula	408	811	468,579
459	Mukunta	Chiengi	8	Luapula	400	795	466,175
460	Sitoya	Mongu	9	Western	420	835	465,115
461	Chikomem	Lundazi	3	Eastern	402	799	464,791
462	Mushima	Mufumbwe	5	North-Western	400	795	462,739
463	Mpidi	Zambezi	3	North-Western	392	779	462,282
464	Waya	Chibombo	4	Central	400	795	460,856
465	Bwina	Sesheke	9	Western	412	819	460,758
466	Kashikishi	Nchelenge	19	Luapula	380	755	460,646
467	Lufubu	Kawambwa	12	Luapula	400	795	459,639
468	Nshinda	Nchelenge	11	Luapula	400	795	458,771
469	Mushiwala	Kaoma	10	Western	409	813	458,512
470	Lyamunale	Kaoma	18	Western	410	815	458,481
471	Mbanga	Lukulu	9	Western	400	795	456,110
472	Mbalango Mine Farm Block	Lufwanyama	3	Copperbelt	400	795	456,023
473	Mitete	Lukulu	4	Western	392	779	454,254
474	Mumpolokoso	Mwense	5	Luapula	400	795	454,131
475	Kafulwe	Chiengi	13	Luapula	395	785	453,372
476	Kanongesha	Mwinilunga	7	North-Western	384	763	453,001
477	Mukumbi	Solwezi	12	North-Western	400	795	451,040
478	Tumva	Solwezi	18	North-Western	400	795	450,185
479	Mwange	Zambezi	13	North-Western	402	799	448,295
480	Kakeki	Zambezi	8	North-Western	400	795	446,426
481	Mombo	Mongu	39	Western	400	795	446,426
482	Mununshi	Mwense	12	Luapula	383	761	444,859
483	Kama	Mongu	18	Western	398	791	444,558
484	KALUWA	Kalabo	28	Western	396	787	442,689
485	Kashiba	Mwense	19	Luapula	378	751	441,089
486	Nkeyama	Kaoma	1	Western	351	698	440,575
487	Chibale	Chama	7	Eastern	389	773	436,148
488	Ikwichi	Mongu	21	Western	386	767	433,345
489	Mangango	Kaoma	4	Western	336	668	432,057
490	Chitokoloki	Zambezi	1	North-Western	350	696	431,271
491	Kimsala	Solwezi	19	North-Western	380	755	431,154
492	Munwa Basic School	Kabwe	8	Central	380	755	430,062
493	Mwandi	Sesheke	4	Western	326	648	425,519
494	Nandombe	Mongu	27	Western	376	747	424,001
495	Kaumba	Monze	26	Southern	360	715	422,323
496	Ntambo Agricultural Camp	Monze	24	Southern	360	715	420,699
497	Samuteba	Mwinilunga	12	North-Western	361	717	419,984
498	Chiwoma	Mwinilunga	14	North-Western	361	717	418,075
499	Kapoche	Luangwa	11	Lusaka	364	723	414,128
500	Loona	Mongu	11	Western	364	723	412,788

Table 5-11 Temporary Electrification Priority of RGCs Based on Demand Criteria (6/13)

Ranking	RGC	District	Priority	Province	# of HHs (2006)	# of HHs (2030)	Daily Max Load
501	Chinkuli	Chongwe	6	Lusaka	361	717	411,325
502	Kenani	Nchelenge	15	Luapula	354	704	408,658
503	Litawa	Mongu	33	Western	359	713	408,116
504	Chipili	Mwense	22	Luapula	350	696	406,717
505	Nkumbi	Mkushi	13	Central	328	652	405,008
506	Mwalilia	Luangwa	7	Lusaka	352	700	403,382
507	Katondwe	Luangwa	3	Lusaka	328	652	400,875
508	Mphomwa	Mambwe	2	Eastern	350	696	392,921
509	Chikowa	Mambwe	11	Eastern	350	696	391,226
510	Bwalya Mponda	Samfa	8	Luapula	335	666	390,649
511	Munkonge	Kasama	7	Northern	339	674	389,643
512	Mwamba	Kasama	5	Northern	345	686	389,542
513	Sunkutu	Mporokoso	8	Northern	350	696	385,173
514	Nangili	Mongu	35	Western	350	696	385,173
515	Ngangu	Mongu	25	Western	349	694	384,239
516	Hoya	Lundazi	18	Eastern	337	670	383,556
517	St. Mary's	Lufwanyama	8	Copperbelt	330	656	381,475
518	Lulambo	Mongu	32	Western	344	684	379,567
519	Kambilombilo	Lufwanyama	2	Copperbelt	330	656	379,524
520	Kasomalunga	Samfa	9	Luapula	315	626	377,867
521	Mukutuma	Lufwanyama	7	Copperbelt	330	656	377,132
522	Funqulwe	Lufwanyama	9	Copperbelt	330	656	375,231
523	Milopa	Lufwanyama	15	Copperbelt	330	656	375,139
524	Kafubu Depot	Kalulushi	4	Copperbelt	300	596	374,770
525	Nkana	Lufwanyama	40	Copperbelt	300	596	373,009
526	Sambula	Chiengi	11	Luapula	320	636	370,925
527	Lumwana	Mwinilunga	5	North-Western	310	616	370,693
528	Shapopa	Namwala	14	Southern	333	662	369,631
529	Maposa	Ndola	5	Copperbelt	333	662	369,288
530	Namayula	Lukulu	17	Western	323	642	368,645
531	Mulobezi	Sesheke	2	Western	307	610	367,642
532	Kamifungo	Masaiti	6	Copperbelt	326	648	365,180
533	Katoba	Chongwe	5	Lusaka	325	646	364,363
534	Chondwe	Masaiti	10	Copperbelt	324	644	364,295
535	Mangwere	Chama	4	Eastern	327	650	363,682
536	Mateko	Solwezi	9	North-Western	320	636	360,900
537	Chitope	Luangwa	2	Lusaka	313	622	359,499
538	Kangwena	Solwezi	17	North-Western	320	636	359,464
539	Kapiji	Solwezi	3	North-Western	320	636	358,194
540	Luangwa Bridge	Chongwe	11	Lusaka	317	630	357,135
541	Kanyenshya Resettlement Scheme	Mkushi	20	Central	300	596	355,572
542	Nyakulena	Zambezi	2	North-Western	300	596	355,014
543	Chama	Kawambwa	1	Luapula	306	608	354,086
544	Mapunga	Solwezi	4	North-Western	300	596	353,470
545	Kameme	Kalulushi	1	Copperbelt	300	596	353,258
546	Luminu	Mwense	3	Luapula	300	596	353,130
547	Madzimoyo Sec. School	Chipata	4	Eastern	312	620	352,346
548	Kapichila	Lundazi	10	Eastern	298	592	351,880
549	Iponga	Chibombo	5	Central	300	596	351,402
550	Lungo	Kitwe	2	Copperbelt	300	596	350,986
551	Mphomwa Tse-tse	Mambwe	1	Eastern	300	596	350,636
552	Kakoma	Mwinilunga	17	North-Western	301	598	349,711
553	Mabinga	Chama	3	Eastern	311	618	348,732
554	Kambila	Lufwanyama	25	Copperbelt	300	596	348,374
555	Munyama	Siavonga	4	Southern	300	596	347,903
556	Tomu	Mwinilunga	13	North-Western	299	594	345,609
557	Shantumbu	Kafue	2	Lusaka	300	596	343,880
558	Musaka	Solwezi	13	North-Western	300	596	341,571
559	Sanda	Solwezi	7	North-Western	300	596	340,776
560	Nalubanda	Mumbwa	9	Central	300	596	339,793
561	Chiparamba	Chipata	1	Eastern	300	596	339,793
562	Council Farm	Kitwe	5	Copperbelt	300	596	338,453
563	Kapara	Chipata	3	Eastern	300	596	338,453
564	Lwatambo	Zambezi	7	North-Western	300	596	338,453
565	Liyovu	Zambezi	16	North-Western	300	596	338,453
566	Kashona	Zambezi	20	North-Western	300	596	338,453
567	Nshinso	Mkushi	4	Central	274	545	333,277
568	Chibondo	Mwense	6	Luapula	286	568	331,431
569	Kikonge	Mufumbwe	12	North-Western	280	557	330,510
570	Jimbe	Mwinilunga	9	North-Western	281	559	329,200
571	Mujima	Solwezi	5	North-Western	280	557	327,625
572	Nakanjoli	Mumbwa	21	Central	280	557	327,471
573	Chiombo	Kasama	6	Northern	270	537	327,076
574	Bweengwa	Monze	17	Southern	275	547	326,866
575	Ndungu	Kabompo	11	North-Western	286	568	325,371
576	Kibanza	Solwezi	20	North-Western	280	557	325,361
577	Tapo	Mongu	24	Western	285	566	324,437
578	Musele	Solwezi	14	North-Western	280	557	323,648
579	Shilenda	Solwezi	10	North-Western	280	557	322,555
580	Ndanda	Mongu	6	Western	280	557	320,232
581	Kaputa	Nchelenge	6	Luapula	277	551	319,797
582	Katuntulu Com. School	Kabwe	5	Central	265	527	318,227
583	Kabuta Central	Nchelenge	18	Luapula	245	487	317,875
584	Ushaa	Mongu	7	Western	277	551	317,429
585	Lusu	Sesheke	8	Western	274	545	316,308
586	Mugula mano	Kafue	3	Lusaka	265	527	315,466
587	Lalafuta	Mufumbwe	16	North-Western	266	529	313,793
588	Kapongo	Kafue	7	Lusaka	270	537	313,599
589	Lumimba	Lundazi	12	Eastern	264	525	313,187
590	Kaunga	Luangwa	5	Lusaka	268	533	312,382
591	Kayuni	Monze	3	Southern	264	525	311,692
592	Chinyunyu	Chongwe	1	Lusaka	247	491	309,207
593	Masansa	Mkushi	12	Central	218	433	309,065
594	Namilauji	Kaoma	6	Western	260	517	304,420
595	Koni Bunda Community	Kabwe	9	Central	250	497	297,011
596	Simabui	Choma	10	Southern	250	497	295,863
597	Nselauke	Kasempa	1	North-Western	238	473	295,305
598	Munsakamba	Mkushi	7	Central	246	489	294,881
599	Chapula	Lufwanyama	41	Copperbelt	250	497	293,937
600	Kansoka	Lufwanyama	10	Copperbelt	250	497	293,555

Table 5-11 Temporary Electrification Priority of RGCs Based on Demand Criteria (7/13)

Ranking	RGC	District	Priority	Province	# of HHs (2006)	# of HHs (2030)	Daily Max Load
601	Chiswo Agric Camp	Monze	19	Southern	250	497	292.062
602	Matushi	Mufumbwe	1	North-Western	250	497	291.817
603	Kafulamase Basic School	Kabwe	4	Central	260	517	291.233
604	Mumena	Solwezi	1	North-Western	248	493	290.622
605	Keemba	Monze	13	Southern	250	497	290.582
606	Sitwe	Chama	11	Eastern	262	521	288.413
607	Lweeta Agric Camp	Monze	20	Southern	250	497	288.390
608	Shombe	Lufwanyama	11	Copperbelt	250	497	287.930
609	Mujika	Monze	25	Southern	250	497	287.787
610	Kamalamba	Solwezi	8	North-Western	260	517	287.527
611	Kamiliambo	Mumbwa	13	Central	250	497	287.388
612	Siwa	Mongu	15	Western	258	513	284.675
613	Chikanda	Mumbwa	22	Central	250	497	284.438
614	Chifunda	Chama	6	Eastern	244	485	284.373
615	Chilongo (Mtepuke)	Nchelenge	1	Luapula	251	499	283.154
616	Saw-Mills	Lufwanyama	6	Copperbelt	250	497	282.974
617	Namitone	Mongu	17	Western	256	509	282.806
618	Kasomo	Chinsali	23	Northern	246	489	282.026
619	Chikola	Solwezi	16	North-Western	250	497	281.644
620	Kamphasa	Mambwe	10	Eastern	250	497	281.534
621	Nyamanongo	Chongwe	10	Lusaka	253	503	281.343
622	Mulonga	Solwezi	6	North-Western	250	497	280.208
623	Lundu	Chama	8	Eastern	253	503	280.003
624	Chaanga	Siavonga	6	Southern	250	497	279.866
625	Longe	Kaoma	25	Western	244	485	279.860
626	Mpale_Tuyu	Mkushi	9	Central	232	461	279.842
627	Kashinakazhi	Kabompo	1	North-Western	250	497	279.815
628	Konikalila	Samfa	11	Luapula	246	489	279.449
629	Mukulushi	Chibombo	3	Central	250	497	279.225
630	Lukulu North	Kasama	2	Northern	250	497	278.913
631	Chibwe	Kawambwa	14	Luapula	240	477	278.386
632	Kaminzeke	Mufumbwe	4	North-Western	240	477	277.841
633	Mphuka	Luangwa	6	Lusaka	249	495	277.249
634	Chamanza Resettlement	Kalulushi	9	Copperbelt	250	497	277.200
635	Chikowa	Mambwe	15	Eastern	250	497	277.200
636	Kambobe	Mporokoso	6	Northern	250	497	277.200
637	Ndondo	Mongu	31	Western	250	497	277.200
638	Kafironda	Mfulira	5	Copperbelt	221	439	277.002
639	Mulonga	Mwense	16	Luapula	234	465	276.757
640	Naluama	Mazabuka	2	Southern	226	449	273.738
641	Lubuka	Kaoma	24	Western	236	469	272.024
642	Sianyoolo	Siavonga	3	Southern	230	457	267.303
643	Kasalamakanga	Mkushi	15	Central	219	435	266.801
644	Mwanambuyu	Kaoma	22	Western	233	463	265.741
645	Mulwa	Kaoma	38	Western	233	463	264.648
646	Mbanyutu	Kaoma	11	Western	230	457	264.263
647	Musa	Kasama	3	Northern	230	457	263.298
648	U_Lunsemfwa	Mkushi	8	Central	215	427	262.379
649	Kampampi (Chipakila)	Nchelenge	2	Luapula	226	449	262.355
650	Nsamba	Samfa	10	Luapula	223	443	262.259
651	Nalutanga	Monze	18	Southern	225	447	261.478
652	Chinyaku Palace	Chipata	9	Eastern	230	457	261.192
653	Chiyota	Chongwe	7	Lusaka	231	459	260.786
654	Miluji	Mufumbwe	10	North-Western	220	437	259.943
655	Lui	Kaoma	13	Western	215	427	259.437
656	Mwito	Lukulu	5	Western	214	425	258.845
657	Kakulunda	Lukulu	8	Western	227	451	258.827
658	Muyondoti	Lukulu	13	Western	227	451	258.827
659	Mukangala	Mwinilunga	19	North-Western	225	447	257.598
660	Kalwelwe Rail Station	Kabwe	3	Central	220	437	257.280
661	Lwakela	Mwinilunga	18	North-Western	216	429	256.943
662	Manga	Chama	5	Eastern	227	451	255.709
663	Chisengisengi	Mwinilunga	6	North-Western	220	437	255.585
664	Chitimbwa RHC	Mpulungu	2	Northern	226	449	254.774
665	Nabwalya	Mpika	13	Northern	215	427	254.389
666	Mukonshi	Mwense	7	Luapula	216	429	254.251
667	Kamapanda	Mwinilunga	16	North-Western	211	420	254.174
668	Mitambali	Lundazi	17	Eastern	216	429	253.788
669	Kanchomba	Choma	1	Southern	200	398	253.460
670	Mapamba	Chama	12	Eastern	223	443	253.342
671	Kampenba	Mwinilunga	10	North-Western	220	437	253.269
672	Kanyama	Mwinilunga	4	North-Western	210	418	252.430
673	Musonweji	Mufumbwe	15	North-Western	212	422	250.471
674	Musende	Mpulungu	3	Northern	220	437	249.168
675	Manyinga	Kabompo	15	North-Western	220	437	249.168
676	Nalusanga	Mumbwa	17	Central	200	398	248.999
677	Lubansa	Chiliabombwe	5	Copperbelt	180	358	248.801
678	Chamuka	Chibombo	17	Central	200	398	248.121
679	Njonjolo	Kaoma	16	Western	214	425	247.579
680	Mpima Dairy Scheme Shed	Kabwe	1	Central	210	418	247.513
681	Shabo (Kapambwe	Nchelenge	16	Luapula	212	422	247.185
682	Mingomba	Chiliabombwe	1	Copperbelt	210	418	246.422
683	Mwalumina	Chongwe	9	Lusaka	217	431	246.365
684	Chiyobola Agricultural Camp	Monze	21	Southern	200	398	244.503
685	Lwabwe	Kasama	4	Northern	210	418	243.699
686	Lusinina	Sesheke	12	Western	211	420	243.593
687	Sikusi	Mongu	8	Western	214	425	243.561
688	Malali	Mkushi	14	Central	200	398	243.274
689	Chipapa VC	Kafue	1	Lusaka	197	392	243.265
690	Kapupulu	Luanshya	3	Copperbelt	209	416	243.005
691	Kayambi	Mungwi	14	Northern	200	398	241.760
692	Munyama B. School	Kabwe	2	Central	200	398	241.644
693	Chisha	Mpulungu	11	Northern	210	418	241.631
694	Mubamba	Nchelenge	9	Luapula	201	400	240.844
695	Lukau	Lukulu	10	Western	208	414	240.790
696	Haatontola	Monze	28	Southern	200	398	240.661
697	Naimbu	Lukulu	11	Western	202	402	240.209
698	Siachele	Mumbwa	6	Central	200	398	240.151
699	Kachenge	Choma	12	Southern	200	398	239.911
700	Kashima W	Mufumbwe	2	North-Western	200	398	239.854

Table 5-11 Temporary Electrification Priority of RGCs Based on Demand Criteria (8/13)

Ranking	RGC	District	Priority	Province	# of HHs (2006)	# of HHs (2030)	Daily Max Load
701	Kapuku Fish Camp	Chibombo	2	Central	200	398	239,821
702	Manyonyo	Mazabuka	5	Southern	200	398	239,680
703	Chunga	Chinsali	14	Northern	200	398	239,635
704	Chizuzu	Zambezi	4	North-Western	200	398	239,525
705	Sumi	Senanga	19	Western	200	398	238,555
706	Manuele	Luangwa	9	Lusaka	204	406	237,991
707	Singani	Choma	5	Southern	200	398	237,259
708	Chisengu	Mambwe	3	Eastern	200	398	237,247
709	Chinonwe	Lukulu	15	Western	200	398	237,247
710	Namoomba	Siavonga	1	Southern	200	398	237,033
711	Mutipula	Mwense	4	Luapula	200	398	236,698
712	Kalilele	Solwezi	2	North-Western	200	398	236,562
713	Namateba Agricultural Camp	Monze	23	Southern	200	398	235,978
714	Malengo	Siavonga	8	Southern	200	398	235,710
715	Salujinga	Mwinilunga	11	North-Western	201	400	235,640
716	Chisakila	Kafue	12	Lusaka	200	398	234,938
717	Dongwe	Lukulu	2	Western	200	398	234,687
718	Chovwe	Solwezi	15	North-Western	200	398	234,363
719	Mukulaikwa	Mumbwa	4	Central	200	398	233,380
720	Mumbezi	Solwezi	11	North-Western	200	398	233,273
721	Nwanachmgurela	Mazabuka	3	Southern	180	358	233,188
722	Kenje	Chipata	10	Eastern	199	396	232,693
723	Naluvwi	Mumbwa	10	Central	200	398	232,287
724	Makolongo	Mkushi	16	Central	187	372	232,065
725	Luela	Kalulushi	5	Copperbelt	200	398	231,632
726	Kakaro	Luangwa	10	Lusaka	198	394	231,401
727	Kalimeta	Katete	11	Eastern	200	398	230,947
728	Katamba	Chilubi	3	Northern	200	398	230,947
729	Iyendwe	Mputungu	7	Northern	200	398	230,947
730	Katontu	Zambezi	9	North-Western	200	398	230,947
731	Kmgubudu	Chipata	2	Eastern	198	394	230,418
732	Mutima	Mwense	9	Luapula	190	378	229,869
733	Khulamayen	Lundazi	20	Eastern	187	372	229,729
734	Kakwacha	Lukulu	14	Western	194	386	229,675
735	Kawama	Luanshya	4	Copperbelt	182	362	228,357
736	Naliele	Kaoma	14	Western	192	382	227,490
737	Lishiko	Kafue	5	Lusaka	190	378	226,622
738	Watopa	Lukulu	3	Western	183	364	225,747
739	Chungu Agric Camp	Monze	14	Southern	190	378	225,309
740	Mwata	Lundazi	11	Eastern	187	372	224,814
741	Nambwa	Mumbwa	20	Central	180	358	224,412
742	Kasupe	Kafue	13	Lusaka	180	358	223,703
743	Kalengwa	Mufumbwe	6	North-Western	180	358	222,944
744	Kazembe	Lundazi	8	Eastern	182	362	222,702
745	Lupui	Lukulu	6	Western	186	370	221,966
746	Kabosha	Nchelenge	10	Luapula	190	378	221,603
747	Mangonza	Choma	11	Southern	180	358	221,520
748	Munyambala	Mufumbwe	9	North-Western	178	354	220,434
749	Maguya	Chipata	6	Eastern	185	365	219,611
750	Neganega	Mazabuka	4	Southern	173	344	218,307
751	Lishuwa	Lukulu	12	Western	179	356	217,716
752	Kalundu	Mwense	2	Luapula	179	356	217,094
753	Kawaya	Lukulu	18	Western	181	360	215,561
754	Mumila	Mputungu	8	Northern	180	358	212,259
755	Kafubu	Luanshya	1	Copperbelt	146	290	203,050
756	Shukwe	Mufumbwe	7	North-Western	170	338	199,771
757	Milopa	Lufwanyama	5	Copperbelt	160	318	196,375
758	Mbabala	Samfa	12	Luapula	173	344	196,362
759	Nkole	Kapiri Mposhi	2	Central	169	336	196,236
760	Kansoka	Lufwanyama	39	Copperbelt	160	318	195,180
761	Kantende	Lufwanyama	26	Copperbelt	160	318	194,000
762	Kabapupu	Mufumbwe	11	North-Western	168	334	193,439
763	Waya	Kapiri Mposhi	8	Central	159	316	192,982
764	Mafungautsi	Kafue	15	Lusaka	160	318	192,811
765	Chikupili	Mkushi	5	Central	149	296	192,544
766	Upper Kaleya	Mazabuka	6	Southern	158	314	191,921
767	Chipepo	Gwembe	5	Southern	159	316	191,858
768	Chiriwe	Luangwa	8	Lusaka	169	336	191,005
769	Likapai	Lukulu	16	Western	169	336	190,972
770	Mamvule	Mumbwa	23	Central	160	318	190,724
771	Kapilamikwa	Lufwanyama	19	Copperbelt	160	318	187,865
772	Kansoka	Lufwanyama	16	Copperbelt	160	318	187,522
773	Mazaba	Sesheke	19	Western	167	332	187,480
774	Funda	Lufwanyama	32	Copperbelt	160	318	187,180
775	Phikamalaza	Lundazi	9	Eastern	159	316	186,977
776	Milulu Mitambo	Lufwanyama	14	Copperbelt	160	318	186,694
777	Tukunka	Kafue	14	Lusaka	160	318	186,566
778	Kamabuta	Mufumbwe	3	North-Western	160	318	185,556
779	Maggobo	Mazabuka	8	Southern	150	298	185,181
780	Moyo	Choma	3	Southern	150	298	183,456
781	Milulu Kabamba	Lufwanyama	30	Copperbelt	160	318	182,548
782	ZASP	Lundazi	16	Eastern	159	316	181,395
783	Malende	Monze	4	Southern	156	310	180,732
784	Katuta	Mwense	1	Luapula	155	308	180,633
785	Kalundu	Namwala	10	Southern	160	318	180,582
786	Silumbu	Sesheke	20	Western	158	314	180,163
787	Minsenga	Kalulushi	11	Copperbelt	145	288	179,857
788	Nchakwa	Lufwanyama	23	Copperbelt	160	318	179,554
789	Nteme	Monze	12	Southern	150	298	179,001
790	Lukwesa	Nchelenge	12	Luapula	150	298	178,184
791	Lengwe	Kawambwa	7	Luapula	150	298	177,648
792	Chibuluma	Mumbwa	16	Central	150	298	177,448
793	Lipumpu	Sesheke	5	Western	148	294	176,774
794	Kasapa	Chilibombwe	2	Copperbelt	150	298	176,574
795	Kasompa	Sesheke	18	Western	156	310	176,516
796	Mulumbu	Milenge	3	Luapula	157	312	175,767
797	Siambabala	Gwembe	11	Southern	153	304	175,736
798	Kangalati	Lufwanyama	34	Copperbelt	150	298	175,512
799	Mbaya Musuma	Mazabuka	7	Southern	138	275	173,338
800	Malundu	Monze	16	Southern	135	269	171,350

Table 5-11 Temporary Electrification Priority of RGCs Based on Demand Criteria (9/13)

Ranking	RGC	District	Priority	Province	# of HHs (2006)	# of HHs (2030)	Daily Max Load
801	Myamdafuka	Mufumbwe	14	North-Western	150	298	171,252
802	Maguya	Chipata	7	Eastern	152	302	171,095
803	Chisau	Mungwi	17	Northern	150	298	170,567
804	Chitina	Mkushi	19	Central	135	269	170,269
805	Kalombe	Mkushi	17	Central	139	277	170,074
806	Mulangwa	Kafue	11	Lusaka	149	296	169,975
807	Manyemunyemu	Kazungula	10	Southern	119	237	169,759
808	Tanganyika	Mpungu	5	Northern	150	298	169,227
809	Posa, Muzabwera, Mupata (Itimbwe)	Mpungu	9	Northern	150	298	169,227
810	Vyamba	Mpungu	10	Northern	150	298	169,227
811	Lukunyi	Zambezi	10	North-Western	150	298	169,227
812	Chitimukulu	Mungwi	10	Northern	140	279	169,197
813	Mushukula	Sesheke	15	Western	145	288	168,358
814	Mambova	Kazungula	1	Southern	92	183	168,124
815	Chikakala	Mpika	20	Northern	140	279	168,085
816	Bulbe	Lundazi	14	Eastern	143	284	167,601
817	Chipembe	Nyimba	1	Eastern	128	255	167,510
818	Musofu	Mkushi	3	Central	123	245	167,450
819	Mwalede	Sinazongwe	15	Southern	140	279	166,948
820	Ketani	Chinsali	9	Northern	138	275	166,702
821	Kashima E	Mufumbwe	8	North-Western	136	271	164,238
822	Simango	Kazungula	11	South-Western	130	259	163,326
823	Lufila	Mpika	19	Northern	130	259	163,016
824	Muzuri (Kamuzya East)	Monze	1	Southern	138	275	162,529
825	Lumpuma	Lufwanyama	4	Copperbelt	127	253	162,251
826	Luashimba	Kapiri Mposhi	7	Central	120	239	162,234
827	Kazungula	Monze	32	Southern	138	275	162,187
828	Bankaila	Monze	15	Southern	130	259	161,438
829	Chilimina	Chililabombwe	7	Copperbelt	135	269	161,162
830	Kalinkhu	Chama	1	Eastern	138	275	160,880
831	Nkulungwe	Chinsali	18	Northern	127	253	160,466
832	Mukamunga	Choma	2	Southern	135	269	160,310
833	Imusho	Sesheke	13	Western	136	271	160,073
834	Lumwana	Lufwanyama	24	Copperbelt	130	259	159,957
835	Chilombo	Chinsali	13	Northern	133	265	159,191
836	Chitimba	Chinsali	20	Northern	133	265	159,081
837	Makasa	Mungwi	1	Northern	133	265	159,002
838	Kandende	Kaoma	36	Western	133	265	157,548
839	Chiteve	Kabompo	12	North-Western	137	273	157,546
840	Musunungu	Kawambwa	20	Luapula	115	229	157,505
841	Kavalamanja	Luangwa	12	Lusaka	132	263	156,507
842	Nchelenge boma	Nchelenge	17	Luapula	97	193	156,201
843	Chiyengele	Kabompo	4	North-Western	93	185	156,045
844	Chimba	Mungwi	6	Northern	135	269	155,678
845	Siamejele	Sinazongwe	19	Southern	131	261	154,249
846	Sanjongo	Chavuma	2	North-Western	132	263	154,215
847	Shimwalule	Chinsali	27	Northern	125	249	153,572
848	Kabila	Mwense	10	Luapula	129	257	153,422
849	Kabele	Kasempa	12	North-Western	128	255	153,185
850	Mumba	Mungwi	8	Northern	128	255	153,069
851	Kanselele	Chama	10	Eastern	132	263	152,874
852	Hangoma	Gwembe	4	Southern	132	263	152,874
853	Mufwaya	Kawambwa	10	Luapula	120	239	152,757
854	Hufwa	Monze	8	Southern	130	259	152,688
855	Dengwe	Kasempa	5	North-Western	129	257	152,097
856	Mimpongo	Kaoma	33	Western	129	257	152,097
857	Luangwa Sec	Luangwa	4	Lusaka	127	253	152,092
858	Nyango	Kaoma	8	Western	126	251	151,693
859	Kasongwa sub boma	Mansa	1	Luapula	98	195	150,908
860	Kanyangala	Kafue	10	Lusaka	125	249	150,668
861	Masuku	Choma	7	Southern	120	239	150,660
862	Nyawa Central	Kazungula	3	Southern	90	179	150,526
863	Manungu A	Monze	9	Southern	103	205	150,477
864	Muyembe	Kawambwa	19	Luapula	120	239	150,437
865	Fitobaula	Chililabombwe	4	Copperbelt	120	239	150,173
866	Mukolo	Kabompo	3	North-Western	100	199	150,019
867	Kantenda	Kasempa	4	North-Western	122	243	149,979
868	Ndasa	Mungwi	9	Northern	128	255	149,137
869	Mandia	Kazungula	12	Southern	120	239	149,067
870	Shemu	Nakonde	5	Northern	114	227	148,770
871	Kakhoma	Chavuma	6	North-Western	120	239	148,751
872	Siampande	Gwembe	10	Southern	121	241	148,611
873	Katimba	Monze	30	Southern	120	239	147,443
874	Lulii	Mumbwa	19	Central	110	219	147,420
875	Chisangwa	Kalulushi	7	Copperbelt	120	239	147,277
876	Simeweendengwe	Monze	10	Southern	120	239	147,277
877	Lwimba	Chongwe	3	Lusaka	110	219	146,030
878	Hakasenke	Monze	6	Southern	120	239	145,808
879	Mulakupikwa	Chinsali	3	Northern	105	209	145,633
880	Mukandamina	Kaoma	34	Western	122	243	145,556
881	Senamba	Sesheke	17	Western	121	241	144,621
882	Chiluli	Kaoma	29	Western	120	239	144,372
883	Misaka	Kitwe	4	Copperbelt	120	239	141,662
884	Chifulo	Mungwi	12	Northern	120	239	141,662
885	Kakoto	Zambezi	17	North-Western	120	239	141,662
886	Kanyembo	Nchelenge	7	Luapula	100	199	141,162
887	Shivuma	Kasempa	14	North-Western	111	221	140,702
888	Kahokoto	Kaoma	37	Western	116	231	140,635
889	Chikanda	Chinsali	4	Northern	115	229	140,296
890	Mpungu	Kasempa	7	North-Western	110	219	139,768
891	Malvango	Sinazongwe	7	Southern	110	219	139,625
892	Mwatishi Farm block 2	Nchelenge	3	Luapula	112	223	139,102
893	Mayumbelo	Livingstone	9	Southern	117	233	138,858
894	Manungu B	Monze	5	Southern	105	209	138,611
895	Hamusankwa	Monze	11	Southern	108	215	137,932
896	Kalobolelwa	Sesheke	6	Western	108	215	137,842
897	Nguba	Kazungula	7	Southern	91	181	136,715
898	Katungulu	Kawambwa	11	Luapula	110	219	136,633
899	Napenzi	Livingstone	4	Southern	113	225	136,461
900	Sianqwaze	Gwembe	7	Southern	106	211	136,207

Table 5-11 Temporary Electrification Priority of RGCs Based on Demand Criteria (10/13)

Ranking	RGC	District	Priority	Province	# of HHs (2006)	# of HHs (2030)	Daily Max Load
901	Milambo	Milenge	5	Luapula	113	225	135.121
902	Kalela	Chinsali	16	Northern	101	201	135.078
903	Fibanga	Mkushi	18	Central	105	209	135.012
904	Kabangala	Chibombo	8	Central	100	199	134.978
905	Mtilizi Scheme	Nyimba	3	Eastern	108	215	134.459
906	Mwanya	Lundazi	7	Eastern	104	207	134.303
907	Hamapande	Monze	7	Southern	112	223	134.186
908	Chibote	Kawambwa	4	Luapula	90	179	132.179
909	Zemba	Chadiza	2	Eastern	90	179	132.063
910	Chungulo	Chinsali	24	Northern	97	193	131.341
911	Kalombe	Kasempa	6	North-Western	106	211	131.246
912	Mukamba	Kawambwa	16	Luapula	100	199	131.240
913	Chimbwese	Chinsali	12	Northern	103	205	131.049
914	Mulilo	Chama	9	Eastern	108	215	130.449
915	Lima	Lufwanyama	35	Copperbelt	100	199	129.900
916	Chilanga	Chinsali	10	Northern	97	193	129.484
917	Kundamfumu	Mansa	6	Luapula	98	195	128.885
918	Chimoto	Lufwanyama	22	Copperbelt	100	199	128.291
919	Kavumbo	Mbala	3	Northern	105	209	127.645
920	Mwachilele	Chongwe	8	Lusaka	103	205	127.117
921	Kamakuku	Kasempa	10	North-Western	95	189	126.975
922	Kakiakasa	Mufumbwe	13	North-Western	100	199	126.667
923	Lukoshi	Kalulushi	6	Copperbelt	100	199	126.310
924	Sinakaimbi	Sinazongwe	1	Southern	90	179	126.229
925	Kalombo	Chavuma	5	North-Western	92	183	126.118
926	Chombela	Chibombo	9	Central	100	199	125.964
927	Lingundu	Chavuma	12	North-Western	95	189	125.718
928	Sikoongo	Sivonga	10	Southern	100	199	125.297
929	Chamfubu	Mungwi	5	Northern	102	203	124.842
930	Namilongwe	Monze	33	Southern	89	177	124.650
931	Chilobwe	Kitwe	3	Copperbelt	100	199	124.066
932	Shikabeta	Chongwe	12	Lusaka	97	193	123.910
933	Kaputo	Nchelenge	5	Luapula	101	201	123.908
934	Muuka	Sinazongwe	12	Southern	94	187	123.732
935	Lima Com. School	Chipata	12	Eastern	100	199	122.973
936	Ishima	Zambezi	6	North-Western	100	199	122.973
937	Kayenge	Zambezi	11	North-Western	100	199	122.973
938	Sikongo	Kalabo	1	Western	98	195	122.445
939	Vizimumba Central	Nyimba	2	Eastern	90	179	122.339
940	Fumbwe	Lufwanyama	28	Copperbelt	90	179	122.050
941	Chama	Nchelenge	8	Luapula	97	193	121.948
942	Chaposwa	Gwembe	12	Southern	97	193	121.153
943	Kalweu Kasakalabwe	Lufwanyama	31	Copperbelt	90	179	120.213
944	Mboroma	Mkushi	10	Central	88	175	119.833
945	Munyati	Sinazongwe	5	Southern	90	179	119.697
946	Kamisamba	Chavuma	7	North-Western	90	179	119.632
947	M_Mfino	Mungwi	13	Northern	96	191	119.236
948	Manyati	Choma	9	Southern	91	181	117.972
949	Luson'a	Kabompo	8	North-Western	63	126	117.890
950	C_Weyaya	Mungwi	18	Northern	92	183	117.878
951	Nchute	Chongwe	4	Lusaka	93	185	117.773
952	Kalisha	Kalulushi	10	Copperbelt	90	179	117.647
953	Kamano	Chibombo	18	Central	90	179	117.380
954	Hofmeyre	Nyimba	7	Eastern	90	179	117.257
955	Sokontwe	Milenge	4	Luapula	91	181	116.530
956	Chinwandumba	Chavuma	4	North-Western	89	177	116.434
957	Mulala	Livingstone	5	Southern	93	185	116.433
958	Kanyafimbolo	Lufwanyama	37	Copperbelt	90	179	115.938
959	Nsampa	Mungwi	16	Northern	92	183	115.498
960	Chimula	Mbala	1	Northern	90	179	113.629
961	Kaka	Mbala	12	Northern	90	179	113.629
962	Siambebele	Kazungula	13	Southern	72	143	110.842
963	Kalaba	Mansa	8	Luapula	86	171	109.295
964	Mweemba	Sinazongwe	3	Southern	80	159	109.237
965	Chipepo	Kapiri Mposhi	1	Central	85	169	109.170
966	Siacheke	Gwembe	6	Southern	79	157	108.998
967	Ngwezi Matak	Kazungula	5	Southern	78	155	105.635
968	Ntoposhi	Mansa	7	Luapula	87	173	104.602
969	Lifwambula	Chibombo	12	Central	85	169	104.545
970	Nangoma	Senanga	20	Western	80	159	103.650
971	Nachanowe	Choma	8	Southern	86	171	103.390
972	Kabanda	Chinsali	11	Northern	80	159	101.194
973	Lombelombe	Kaoma	2	Western	86	171	100.304
974	Kanogo	Kasempa	11	North-Western	84	167	100.130
975	Kalulu	Mungwi	15	Northern	82	163	98.792
976	Nzala	Gwembe	13	Southern	86	171	98.541
977	Chingombe	Mkushi	11	Central	78	155	98.516
978	Mwalala	Chinsali	17	Northern	80	159	97.507
979	Lunga	Kasempa	3	North-Western	66	132	97.141
980	Kankunko_	Lufwanyama	33	Copperbelt	85	169	96.951
981	Lukolwe	Chavuma	3	North-Western	80	159	96.911
982	Kangalati	Lufwanyama	18	Copperbelt	85	169	96.907
983	Chikabuke	Lufwanyama	17	Copperbelt	85	169	96.733
984	Chantete	Lufwanyama	20	Copperbelt	85	169	95.968
985	Kafwambila	Sinazongwe	6	Southern	80	159	94.471
986	Kanenga	Chililabombwe	6	Copperbelt	80	159	94.427
987	Peleti	Mungwi	2	Northern	85	169	93.957
988	Gamela	Choma	4	Southern	80	159	92.648
989	Kambuya	Chavuma	8	North-Western	72	143	92.385
990	Chiyabi	Sinazongwe	4	Southern	80	159	92.318
991	Sinamalima	Sinazongwe	11	Southern	80	159	92.234
992	Siansalama	Sinazongwe	20	Southern	78	155	92.158
993	Chabulabwambe	Gwembe	8	Southern	82	163	92.137
994	Kayosha	Chibombo	10	Central	80	159	92.061
995	St-Pauls	Mbala	8	Northern	80	159	91.900
996	Michinka	Kalulushi	3	Copperbelt	80	159	91.311
997	Mulumbi	Milenge	6	Luapula	82	163	91.154
998	Siadazy	Livingstone	3	Southern	79	157	90.784
999	Namafulu	Sinazongwe	2	Southern	75	149	90.383
1000	Chowa	Chibombo	15	Central	68	136	90.288

Table 5-11 Temporary Electrification Priority of RGCs Based on Demand Criteria (11/13)

Ranking	RGC	District	Priority	Province	# of HHs (2006)	# of HHs (2030)	Daily Max Load
1001	Mandalo	Chavuma	9	North-Western	78	155	90,127
1002	Banamwaze	Itezhi-tezhi	5	Southern	79	157	89,691
1003	Kawimbe	Mbala	2	Northern	80	159	89,285
1004	Mpande	Mbala	4	Northern	80	159	89,285
1005	Mwiluzi	Mbala	6	Northern	80	159	89,285
1006	Senka	Mbala	15	Northern	80	159	89,285
1007	Mwamba	Mbala	16	Northern	80	159	89,285
1008	Zimba Hills Settlements	Kazungula	2	Southern	72	143	89,215
1009	Lubofu	Kasempa	13	North-Western	74	147	88,820
1010	Nashinga	Chinsali	5	Northern	70	140	88,630
1011	Fiwila	Mkushi	6	Central	48	96	88,139
1012	Vubwi	Chadiza	3	Eastern	60	120	88,134
1013	Kamakechi	Kasempa	2	North-Western	74	147	87,652
1014	Liumba	Kalabo	3	Western	78	155	87,416
1015	Nyamaluma	Mambwe	6	Eastern	75	149	86,922
1016	Shiwan'gandu area	Chinsali	1	Northern	60	120	85,651
1017	Ibwemunyama	Siavonga	2	Southern	70	140	84,167
1018	Momboshi	Chibombo	19	Central	55	110	82,923
1019	Musolo	Milenge	9	Luapula	73	145	82,744
1020	Muchinga	Mwense	11	Luapula	70	140	82,434
1021	Ma Hundred	Livingstone	6	Southern	71	142	81,343
1022	Siabwengo	Gwembe	1	Southern	68	136	79,865
1023	Nyangwali	Kabompo	5	North-Western	65	130	79,818
1024	Mukwikile	Chinsali	8	Northern	56	112	79,805
1025	Chinyongola	Chibombo	20	Central	62	124	79,743
1026	Silwili	Monze	2	Southern	65	130	79,728
1027	Namakaka	Namwala	12	Southern	50	100	78,889
1028	Lameck	Chinsali	19	Northern	60	120	78,303
1029	Sakurita	Livingstone	18	Southern	66	132	78,238
1030	Kanengo	Kawambwa	3	Luapula	60	120	78,186
1031	Mchimadzi Scheme	Nyimba	4	Eastern	62	124	77,901
1032	Mbesuma area	Chinsali	2	Northern	55	110	77,563
1033	Chimphanje	Nyimba	8	Eastern	66	132	77,356
1034	Nangombe	Sinazongwe	13	Southern	64	128	77,111
1035	Mibenge	Mansa	5	Luapula	54	108	76,530
1036	Chisengi	Kabompo	6	North-Western	60	120	76,453
1037	Musanya	Chinsali	6	Northern	50	100	76,254
1038	Taferansoni	Chadiza	5	Eastern	55	110	76,106
1039	Natebe	Livingstone	2	Southern	62	124	76,051
1040	Nyathanda	Chavuma	13	North-Western	65	130	75,736
1041	Gwena	Siavonga	9	Southern	60	120	75,463
1042	Chipete	Mansa	9	Luapula	56	112	75,405
1043	Mbila	Itezhi-tezhi	3	Southern	63	126	75,208
1044	Simuloongo	Gwembe	3	Southern	57	114	74,969
1045	Kalyongo	Mansa	17	Luapula	60	120	74,868
1046	Sikalinda Resettlement	Monze	31	Southern	60	120	74,770
1047	Chiwaula	Chadiza	4	Eastern	30	60	74,503
1048	Chimbola	Mungwi	7	Northern	62	124	74,241
1049	Chichele	Ndola	6	Copperbelt	63	126	73,868
1050	Mulinga	Kalabo	21	Western	63	126	73,868
1051	Muswishi	Chibombo	14	Central	45	90	73,682
1052	Kapolyo	Mungwi	11	Northern	61	122	73,339
1053	Mushingashi	Lufwanyama	21	Copperbelt	60	120	72,778
1054	Kampemba	Chinsali	28	Northern	60	120	72,404
1055	Kabombo	Kalulushi	8	Copperbelt	60	120	71,750
1056	Nyalugwe	Nyimba	14	Eastern	56	112	70,884
1057	Chimbele	Chinsali	7	Northern	50	100	70,356
1058	Chinkonkwelo	Kabompo	9	North-Western	46	92	70,143
1059	Siameja	Sinazongwe	14	Southern	48	96	69,849
1060	Mlolo	Chadiza	1	Eastern	50	100	69,735
1061	Kankwanda	Kaoma	32	Western	48	96	69,723
1062	Siatwiinda	Sinazongwe	8	Southern	57	114	69,601
1063	Lueti	Kalabo	9	Western	57	114	69,601
1064	Mundoza	Gwembe	9	Southern	56	112	69,293
1065	Rosa	Mungwi	4	Northern	56	112	68,667
1066	Musonko	Chinsali	26	Northern	45	90	68,219
1067	Nkenga	Kaoma	12	Western	43	86	68,155
1068	Mutiti	Mansa	10	Luapula	46	92	67,444
1069	Maako	Kasempa	8	North-Western	50	100	67,392
1070	Kalongwa	Kasempa	15	North-Western	49	98	67,234
1071	Mansa Resettlement Scheme	Mansa	2	Luapula	51	102	66,748
1072	Chinemu	Lufwanyama	13	Copperbelt	45	90	66,452
1073	Chambi	Chavuma	10	North-Western	52	104	65,957
1074	Ngweze	Sesheke	14	Western	52	104	65,957
1075	Ndoba	Mansa	11	Luapula	36	72	65,907
1076	Lukena	Kaoma	15	Western	49	98	65,897
1077	Makunku	Itezhi-tezhi	7	Southern	53	106	65,864
1078	Namusenga	Namwala	15	Southern	50	100	65,712
1079	Miyombe	Kasempa	9	North-Western	46	92	65,546
1080	Kasiya	Livingstone	1	Southern	50	100	64,496
1081	Chalubilo	Nyimba	11	Eastern	38	76	64,386
1082	No.57 (Lubanda)	Itezhi-tezhi	1	Southern	50	100	64,153
1083	Chikonkomene	Chibombo	13	Central	36	72	63,649
1084	Namasheshe	Kaoma	30	Western	42	84	63,495
1085	Mwerya	Sinazongwe	9	Southern	49	98	63,219
1086	Masongo	Chinsali	29	Northern	50	100	63,060
1087	Sekute	Kazungula	6	Southern	42	84	62,633
1088	Sulwegonde	Sinazongwe	18	Southern	45	90	61,790
1089	Namando	Kaoma	21	Western	46	92	61,315
1090	Kandole	Lufwanyama	36	Copperbelt	45	90	61,040
1091	Ndake	Nyimba	5	Eastern	42	84	60,863
1092	Chintu	Milenge	7	Luapula	49	98	60,786
1093	Kalale	Kaoma	17	Western	44	88	60,448
1094	Mano	Mansa	4	Luapula	44	88	60,207
1095	Wilison	Nyimba	10	Eastern	44	88	60,115
1096	kalasa kando	Mansa	16	Luapula	45	90	59,759
1097	Kabangama	Chinsali	25	Northern	34	68	58,980
1098	Syangwemu	Siavonga	7	Southern	40	80	58,820
1099	Kabunda	Mansa	13	Luapula	41	82	58,440
1100	Mukelangombe	Chavuma	11	North-Western	45	90	58,388

Table 5-11 Temporary Electrification Priority of RGCs Based on Demand Criteria (12/13)

Ranking	RGC	District	Priority	Province	# of HHs (2006)	# of HHs (2030)	Daily Max Load
1101	Namatindi	Kalabo	5	Western	45	90	58,388
1102	Chivombo	Chavuma	1	North-Western	40	80	58,146
1103	Mutenda	Lufwanyama	43	Copperbelt	45	90	58,076
1104	Muchinshi	Lufwanyama	44	Copperbelt	45	90	58,076
1105	Inonge	Livingstone	7	Southern	41	82	58,074
1106	Bukanda	Mansa	15	Luapula	42	84	58,049
1107	Chipe	Milenge	2	Luapula	41	82	57,243
1108	Muliro	Nyimba	16	Eastern	40	80	57,238
1109	Mulila Nsolo	Kafue	16	Lusaka	45	90	57,048
1110	Nakayembe	Kaoma	19	Western	41	82	56,429
1111	Kalongo Mwape	Nyimba	15	Eastern	41	82	56,344
1112	Namaloba	Kaoma	20	Western	40	80	56,052
1113	mbaso	Mansa	19	Luapula	38	76	55,825
1114	Malimba	Kazungula	8	Southern	21	42	55,790
1115	Lunyiwe Basic School	Kabompo	7	North-Western	36	72	55,779
1116	Mukunkiki	Kaoma	27	Western	41	82	55,679
1117	Loke West	Kalabo	10	Western	42	84	55,585
1118	Mudonki	Gwembe	2	Southern	42	84	55,571
1119	Dibbwi	Siavonga	5	Southern	40	80	55,042
1120	Chambula	Nyimba	9	Eastern	42	84	54,588
1121	Manje	Chadiza	6	Eastern	36	72	54,420
1122	Kafunda	Kaoma	31	Western	29	58	53,766
1123	Kalamba	Kawambwa	6	Luapula	40	80	53,747
1124	Muyumbana	Kalabo	7	Western	40	80	53,716
1125	Majeledi	Livingstone	16	Southern	41	82	53,311
1126	Sihole	Kalabo	2	Western	41	82	53,311
1127	Kasoma lwela	Mansa	3	Luapula	35	70	52,548
1128	Uningi	Mbala	9	Northern	40	80	52,376
1129	Kaluluzi	Mbala	11	Northern	40	80	52,376
1130	Matanga	Mbala	13	Northern	40	80	52,376
1131	Katapazi	Kazungula	9	Southern	31	62	52,355
1132	Shishamba	Kaoma	23	Western	36	72	52,314
1133	chisunka	Mansa	18	Luapula	35	70	51,508
1134	Lukola	Mansa	21	Luapula	34	68	51,104
1135	Mikula	Mansa	22	Luapula	35	70	51,010
1136	mwanachama	Mansa	20	Luapula	32	64	50,671
1137	Kalingindi	Nyimba	13	Eastern	36	72	50,605
1138	Kapanda	Mansa	14	Luapula	35	70	49,730
1139	Mulira	Nyimba	6	Eastern	34	68	49,679
1140	Afumba	Kaoma	28	Western	32	64	49,669
1141	Lwanya	Chinsali	21	Northern	30	60	49,288
1142	Mutwewankoko	Mansa	12	Luapula	34	68	49,138
1143	Kotinteden	Masaiti	7	Copperbelt	25	50	48,818
1144	Dengera	Sinazongwe	16	Southern	30	60	48,647
1145	Mulundumano	Kalabo	16	Western	36	72	48,639
1146	Muchenje	Chibombo	6	Central	26	52	48,542
1147	Chibuluma Mine Area	Lufwanyama	45	Copperbelt	35	70	47,704
1148	Kabimba	Choma	6	Southern	30	60	47,024
1149	Luchena	Itezhi-tezhi	2	Southern	30	60	46,448
1150	Kacholola	Nyimba	12	Eastern	32	64	46,241
1151	Nyambi 2	Kaoma	26	Western	29	58	46,116
1152	Chilele	Sinazongwe	10	Southern	21	42	45,495
1153	Kapopo	Chibombo	11	Central	30	60	45,058
1154	Sinde	Livingstone	14	Southern	32	64	44,901
1155	Ngoma	Sinazongwe	17	Southern	23	46	44,072
1156	Konja	Chinsali	15	Northern	20	40	44,042
1157	Kapimbe	Lufwanyama	29	Copperbelt	25	50	43,335
1158	Luela	Lufwanyama	27	Copperbelt	25	50	43,332
1159	Sumbi	Mbala	5	Northern	30	60	43,032
1160	Kalukanya	Mbala	7	Northern	30	60	43,032
1161	Chalele	Mbala	10	Northern	30	60	43,032
1162	Chisanzu	Mbala	14	Northern	30	60	43,032
1163	Kasaba Bay	Mpulungu	1	Northern	30	60	43,032
1164	Lutwi	Kalabo	12	Western	30	60	43,032
1165	Ngabwe	Kapiri Mposhi	11	Central	25	50	42,100
1166	Chikwasha	Nyimba	17	Eastern	29	58	42,098
1167	Kananga	Livingstone	20	Southern	29	58	42,098
1168	Kasosolo	Chibombo	16	Central	20	40	42,056
1169	Malekani	Chinsali	22	Northern	25	50	41,666
1170	Mahelituna	Livingstone	11	Southern	27	54	41,257
1171	Nguvu	Chavuma	14	North-Western	25	50	38,360
1172	Muwezwa	Itezhi-tezhi	6	Southern	24	48	37,426
1173	Sichilore	Livingstone	13	Southern	24	48	37,426
1174	Chipeso	Chibombo	7	Central	16	32	35,754
1175	Fidashi	Masaiti	15	Copperbelt	20	40	35,714
1176	Namatoya	Shangombo	12	Western	18	36	34,878
1177	Simwizi	Livingstone	17	Southern	21	42	34,623
1178	Chilizya	Livingstone	12	Southern	19	38	34,094
1179	Kuuli	Kalabo	4	Western	20	40	33,688
1180	Mishuwundu	Kalabo	17	Western	20	40	33,688
1181	Palace	Shangombo	3	Western	20	40	33,688
1182	Mubalu	Livingstone	15	Southern	19	38	32,754
1183	Sishekanu	Kalabo	18	Western	18	36	32,505
1184	Winda	Kaoma	35	Western	16	32	31,976
1185	Liuya	Kalabo	14	Western	18	36	31,819
1186	Matete	Masaiti	14	Copperbelt	15	30	31,042
1187	Katubia	Livingstone	10	Southern	17	34	30,885
1188	Kalenga	Kalabo	6	Western	15	30	30,356
1189	Liumena	Kalabo	11	Western	15	30	30,356
1190	Salati	Masaiti	11	Copperbelt	15	30	29,999
1191	Mbilisao	Nyimba	18	Eastern	15	30	29,016
1192	Munde	Kalabo	15	Western	15	30	29,016
1193	Malasha	Kalabo	19	Western	15	30	29,016
1194	Smachuma	Livingstone	8	Southern	14	28	28,424
1195	Zangala	Livingstone	19	Southern	13	26	27,147
1196	Salunda	Kalabo	8	Western	13	26	27,147
1197	Mwandi	Kalabo	13	Western	13	26	27,147
1198	Mikata	Mpongwe	1	Copperbelt	11	22	26,619
1199	Chipundu	Milenge	8	Luapula	8	16	22,475
1200	Chibuli	Mpongwe	7	Copperbelt	6	12	21,947

Table 5-11 Temporary Electrification Priority of RGCs Based on Demand Criteria (13/13)

Ranking	RGC	District	Priority	Province	# of HHs (2006)	# of HHs (2030)	Daily Max Load
1201	Munsongwe	Mpongwe	11	Copperbelt	6	12	21,947
1202	Mbalata	Kalabo	20	Western	7	14	21,541
1203	Mushipushi	Mpongwe	15	Copperbelt	4	8	21,170
1204	Munkunpa	Mpongwe	3	Copperbelt	5	10	21,012
1205	Chinwa	Mpongwe	9	Copperbelt	5	10	21,012
1206	Chowa	Mpongwe	10	Copperbelt	5	10	21,012
1207	Luswishi	Mpongwe	16	Copperbelt	5	10	21,012
1208	Shingwa	Mpongwe	8	Copperbelt	6	12	20,606
1209	Chitabale	Mpongwe	13	Copperbelt	4	8	20,078
1210	Machiya	Mpongwe	5	Copperbelt	4	8	19,830
1211	Chisanga	Mpongwe	6	Copperbelt	3	6	19,143
1212	Ipumbu	Mpongwe	14	Copperbelt	3	6	19,143
1213	Kasamba	Mpongwe	2	Copperbelt	3	6	18,896
1214	Kapili	Mpongwe	18	Copperbelt	2	4	18,209
1215	Mushine	Mpongwe	17	Copperbelt	2	4	17,962
1216	Chisapa	Mpongwe	19	Copperbelt	3	6	17,803
1217	Musofu	Mpongwe	20	Copperbelt	3	6	17,803
				Total	537,617	1,068,233	612,302,427