

CHAPTER 7

WATER SUPPLY MASTER PLAN

7.1 PLANNING ASSUMPTIONS

This section discusses the planning assumptions, based upon which our master plan for the water supply system in Karachi has been formulated.

7.1.1 Population and Development Patterns

In August 2007, CDGK issued the final report on Karachi Strategic Development Plan 2020 (Final Report, August 2007). This report indicated that the total population of Karachi was 15.2 million in 2005 and it would increase to 27.5 million in 2020. The report also predicted that more than 45% of the projected population increase during the 15 years from 2005 to 2020 would occur in the three towns located on the outskirts of the Karachi City, namely Keamari, Gadap and Bin Qasim whereas the other 55% would occur in the remaining 15 towns. This was based on the perception that during the next 15 years significant developments would take place on the outskirts of the city in particular in the southern part of Gadap Town. **Figure 71.1.1** shows the population projections made in the Karachi Strategic Development Plan 2020 (Final Report, August 2007). **Figure 71.1.2** illustrates the future land use envisaged by the same plan.

Karachi's total population was 15.2 million in 2005 and it would increase to 27.5 million in 2020.

We believe that the Karachi Strategic Development Plan 2020 (KSDP-2020), once it is approved and authenticated by higher authorities, will serve as a guiding principle, based on which all infrastructure development schemes for all public service sectors, such as water supply, sewerage, solid waste disposal, electricity, gas, telecommunication and roads will be developed. For this reason, we decided to develop a water supply and sewerage master plan for Karachi based on the population projection, future land use patterns and other basic data provided in the KSDP-2020 (Final Report, August 2007).

It has been predicted that 45% of the population increase during the 15 years from 2005 to 2020 would occur in the three towns located on the outskirts of the Karachi City, namely Keamari, Gadap and Bin Qasim while the other 55% would occur in the remaining 15 towns.





Figure 71.1.1 Population Projection in KSDP-2020 (Final Report - August 2007)



7.1.2 Water Sources

Despite the significant population increase envisaged by the KSDP-2020 (Final Report-August 2007), there has been no definite plan for increasing the capacity of water sources to meet the increasing water demand. In this respect, the KSDP-2020 has proposed the use of several modern technologies to increase the water supply capacity. They include the construction of sea water desalination plants, reuse of effluents from sewage treatment plants for recharging groundwater aquifers, and the development of dual water supply systems and dual sewerage systems. However, most of these technologies are not considered financially viable both at present and in the foreseeable future.

Sea water desalination will not provide a viable solution for a mega city like Karachi unless there is a remarkable technical breakthrough that substantially reduce both CAPEX and OPEX of desalination. Our review of existing studies on the development of regional groundwater resources indicated that the exploitability of groundwater in the region is very low.

In the light of the immense size of the water demand in the city, there is no doubt that the Indus River will continue to remain as the only viable water source for Karachi in the foreseeable future. This view was first indicated by the 1985 water supply master plan study for Karachi conducted by Sir M. MacDonald and Partners (principal consultant) and Associated Consulting Engineers (local associated consultant). The study made a review of all potential water sources in the Karachi region, which included the Indus River and other surface water and groundwater sources, seawater desalination, and the indirect reuse of treated sewage effluents for the recharge of aquifers and substitution of existing non-potable uses. As a result, the study indicated that the Indus River and desalination are the only two sources that could technically meet a large water demand in Karachi. The study also indicated that the cost of desalination for the foreseeable future was prohibitive and that desalination should therefore be considered as a last resort. The study then concluded that the Indus River was the only viable water source for Karachi.

This view was endorsed by a special committee formulated by GOS in 2002. The committee which was comprised of representatives from the Planning and Development Department of GOS, Irrigation and Power Department of GOS, and Karachi Water & Sewerage Board (KW&SB), prepared a report on long term water supply plan for Karachi up to the year 2025. The committee submitted the report to the Central Development Working Party (CDWP) on November 14, 2002, which was evaluating the PC-I of the scheme “Assured Water Supply for Karachi – upgrading Kinjhar Lake System” at that time. In summary, the report provided the following major findings and recommendations.

(Findings)

- The existing allocation of 1,200 cusecs from the Indus River would be fully utilized in 2005 with completion of the 100 mgd K-III project. The population of Karachi was ever growing and additional requirement up to the year 2025 was estimated to be another 1,200 cusecs thus the total requirement would be 2,400 cusecs.
- The present scheme for assuring a water supply for Karachi is considered as Phase-I. This phase is to cater for short-term assured water for Karachi up to the year 2005. Phase-II of this scheme would be required for long-term requirements of water supply in Karachi beyond 2005 and up to 2025.

(Recommendations)

- To meet the growing water demand of Karachi the water allocation for Karachi up to Vision 2025 may be increased by another 1,200 cusecs raising the total allocation to 2,400 cusecs by the Government under a national cause without affecting the water supply quota of the Thatta District for agriculture purposes. Once additional allocation was allowed then a 2-stage study programme for system expansion would have to be initiated.

- Stage-I: Study by the Irrigation and Power Department of GOS for increasing capacity in the system from the KB Feeder Upper up to the Kinjhar Lake without affecting the stability of the Kotri Barrage.
- Stage-II: Feasibility study by KW&SB in consultation with the Irrigation and Power Department for determining the most economically viable, technically feasible and secure route to bring additional 1,200 cusecs of water from the Kinjhar Lake to Karachi.

Based on the committee's recommendations, CDGK requested the GOP to grant an additional quota of 1,200 cusecs (650 mgd) from the Indus River to meet the future water demand of the Karachi City. Furthermore, KW&SB since October 2005 has been conducting the K-IV Study, the main objective of which is to recommend on the most economical and technically viable route for conveying additional 1,200 cusecs of Indus water from the Kinjhar Lake to Karachi. The study examined several alternative routes and recommended the most economical route as a result of the comparison of capital and annual operating costs to be required for each alternative. Further, the study also identified the sites for construction of three water treatment plants each having an ultimate treatment capacity of 260 mgd, 260 mgd and 130 mgd. **Figure 71.2.1** shows the locations of the raw water conveyance route and three water treatment plants proposed by the study. In January 2008, President Pervez Musharaff while presiding at the 'foundation stone unveiling ceremony' of the 'Corridor Project' at Governor's House assured the Federal Government's supports towards the implementation of the K-IV Project. A newspaper article describing this event is attached as **Appendix A71.1**.

In developing a water supply master plan for Karachi, the JICA Study assumed that Karachi would be granted an additional quota of 1,200 cusecs from the Indus River and a total of 2,400 cusecs of Indus River water would be made available at the Kinjhar Lake for extraction by KW&SB. This is based on our strong belief that if this additional quota is not granted, then there will be no such a large population increase or significant developments in Karachi as have been envisaged by the KSDP-2020 (Final Report-August 2007).

Karachi would be granted an additional quota of 1,200 cusecs from the Indus River and a total of 2,400 cusecs of Indus River water would be made available at the Kinjhar Lake for abstraction by KW&SB. If this additional quota is not granted, then there will be no such a large population increase or significant developments in Karachi as have been envisaged by the KSDP-2020 (Final Report - January 2007).

The Department of Irrigation and Power of GOS is currently responsible for the operation and maintenance of the Kotri Barrage, KB Feeder Upper and Kinjhar Lake while KW&SB's responsibility for the operation and maintenance of the bulk water supply system starts from the KG Canal that withdraws the impounded water of the Kinjhar Lake. It is likely that this demarcation of responsibilities will remain unchanged in the future, and as such, it is assumed that any infrastructure development required for enabling KW&SB to withdraw additional 1,200 cusecs from the Kinjhar Lake would be planned, designed and implemented by GOS and that GOS would also be responsible for the operation and maintenance of such additional infrastructure. Instead, it is assumed that KW&SB would pay GOS a raw water charge at the rate of Rs.0.5 per 1,000 gallons (Rs.0.11 per m³) to compensate GOS for part of the costs incurred with respect to the construction, operation and maintenance of such infrastructure.




Figure 71.2.1 K-IV Project (Source: K-IV Project Executive Summary, OSMANI May 2007)

7.2 BASIC POLICIES, GOALS AND STRATEGIES

This section discusses the following basic policies adopted for the formulation of the water supply master plan.

- Demand Management Approaches
- Separation of Bulk and Retail Supplies
- Zone-wise Management of Retail Supply
- Implementation of Distribution Network Improvement (DNI) on a Financially Sustainable Basis

Basic Policies Adopted for the Formulation of the Water Supply Master Plan

- (1) Demand Management Approaches**
- (2) Separation of Bulk and Retail Supplies**
- (3) Zone-wise Management of Retail Supply**
- (4) Implementation of DNI on a Financially Sustainable Basis**

7.2.1 Demand Management Approaches

It is estimated in **Section 6.2** that at present the volume of the actual bulk water supply to Karachi is 630 mgd, and that the current per capita bulk water supply capacity is about 40 gallons or 182 litres. Multiplying this by the total population of 15.12 million in 2005, the total volume of bulk water conveyed to Karachi through the bulk water supply system in the same year is estimated at 604.8 mgd. Assuming 10% water losses in the bulk water supply system (including evaporation in open canals and losses at water purification plants), the volume of water that was actually made available for Karachi in 2005 is estimated at 549.8 mgd ($604.8/1.1$). With the leakage in the distribution system being assumed at 35%, the volume of water actually used by customers is estimated to be 357.4 mgd (549.8×0.65). Further, if 40% of this volume is used for non-domestic purposes, water used for domestic purpose is estimated

at 214.4 mgd (357.4×0.60). Dividing this by the total served population of 13.608 million, which is 90% of the city's total population in 2005 (15.12 million) estimated by the KSDP-2020 (Final Report-August 2007), the domestic per capita consumption rate in 2005 is estimated at 15.76 gallons (71.6 litres) per day. No accurate assessment of leakage in the distribution network is possible at present. The per capita consumption rate will further reduce if the actual leakage is greater than 35%.

KSDP-2020 estimated that Karachi had a total population of 15.2 million in 2005 and also projected that the total population would increase to 27.5 million by 2020. It is envisaged from this projection that Karachi's total population could reach 32.0 million in 2025, which is almost double of the present total population. On the other hand, the possible increase in the capacity of water sources over the same period is estimated to be only 1,200 cusecs (650 mgd) as discussed in **Section 7.1**, which is less than the capacity of existing water sources i.e. 720 mgd. These observations suggest that Karachi will continuously be subjected to severe water constraints over the planning horizon of 2025.

Our observations suggest that Karachi will continuously be subjected to severe water constraints over the planning horizon of 2025.

Karachi is located in the arid region where annual precipitation is as small as 200 mm. There is no prospective surface or underground water source available within or in the vicinity which can be developed in a large scale to cater for the enormous water demand of the mega city. Karachi seems to be one of the few cities in the world, which lies in the arid region, yet accommodates as many as 16 million people.

With the exploding population and limited availability of water resources, one must choose whether (a) to provide rather abundant supplies to a limited number of people in the city or (b) to provide essential supplies to as many people in the city as possible. Given the public nature of water supply service, it is obvious that one should choose the latter option. It is therefore extremely important to ensure that this option is successfully implemented through '**Demand Management Approaches**' which provide both general public and business entities with strong incentives to voluntarily restrict their water consumption for essential purposes only. There should be a consensus reached by all stakeholders that making future water supply development plans based on unconstrained water demands is not a proper approach in the case of Karachi.

There should be a consensus reached by all stakeholders that making future water supply development plans based on unconstrained water demands is not a proper approach in the case of Karachi.

The central part of the demand management approaches will be the introduction of measured supplies with a volumetric charging system whereby all retail and bulk customers will be charged based on their actual consumption. This will be further reinforced by the introduction of a new water tariff structure which will provide both domestic and non-domestic customers with strong incentives for efficient use of water. Tariffs will be structured to differentiate essential water needs from non-essential water needs. A low tariff would be applied to essential water needs while those who consume beyond essential needs should be severely penalized. Minimizing leakage, wastage and illegal connections will also constitute the core part of the demand management approaches.

Demand Management Approaches

Goals

All consumers in the city including government and business entities are being highly conscious about water conservation and voluntarily restrict their consumption for essential purposes only.

Strategies

- ☐ **Introduction of measured supplies with a volumetric charging system whereby all retail and bulk customers will be charged based on this actual consumption**
- ☐ **Introduction of a new water tariff structure which will provide both domestic and non-domestic customers with strong incentives for efficient use of water**
- ☐ **Implementation of efficient meter reading, billing and collection**
- ☐ **Minimizing leakage, wastage and illegal connections**
- ☐ **Implementation of mass media campaigns for enhancing consumers' awareness on water conservation**
- ☐ **Mandatory use of water-saving equipment and devices in newly constructed houses and buildings such as low-volume toilets, low-flow showerheads, water faucets with flow restrictors or aerators.**
- ☐ **Subsidizing large-scale commercial and industrial users part of their investment costs for water conservation including internal recycling of used water.**

7.2.2 Separation of Bulk and Retail Supplies

KW&SB is currently supplying water to the entire Karachi District and two union councils in the Thatta District of the Sindh Province. In the near future, KW&SB is also expected to supply treated water to the Lasbela District of the Balochistan Province. This demonstrates that KW&SB is playing a role of the regional bulk water supplier.

The bulk water supply to two union councils in the Thatta District was initiated based on the notification issued by the GOS on August 23, 2004, which expanded the administrative area of KW&SB to include two union councils in the Thatta District, namely Dhabeji and Gharo. A copy of this notification is attached as **Appendix A72.1**.

The bulk water supply to the Lasbela District of the Balochistan Province was decided by the GOP during the approval process of the K-III project. The PC-1 documents of the project stipulated that out of 100 mgd of Indus water transferred from the Kinjhar Lake to Karachi under the K-III project, 95 mgd would be distributed to Karachi while the remaining 5 mgd to the Lasbela District. In accordance with this PC-1, a 27 km-long, 24-inch diameter water transmission pipeline was constructed from the Hub Filtration Plant to Lasbela as part of the K-III project. GOS and Government of Balochistan (GOB) are currently negotiating over (a) who should be responsible for the operation and maintenance of the transmission pipeline, and (b) the water tariff KW&SB will charge GOB for water it receives from KW&SB.

Under the Pakistani constitution, water is a provincial subject. However, GOP also performs a number of functions and responsibilities in the water sector, mostly relating to inter-provincial matters. The water supply to Balochistan under the K-III project is a good example of this. Because of the inclusion of the supply to Balochistan, the K-III project was given a status of an inter-provincial project and the entire project cost was subsidized by GOP. Both GOP and GOS have legitimate roles in shaping of policies and strategies for the water and sanitation

sector in the region. It is obvious that the bulk water supplies to the Thatta and Lasbela Districts are the consequence of these policies and strategies. However, it should be noted that these policies and strategies often conflict with sound business and commercial principles.

Development of a new bulk water supply scheme to bring water from the Indus River to Karachi requires a large-scale investment which would inevitably exceed the financial capability of the service provider. Thus, part of the investment cost would have to be subsidized either by GOP or GOS. The reality is that in the past the entire capital costs required for the development of the bulk water supply system were subsidized either by GOP or GOS. The cost required for operation and maintenance of the bulk water supply system is also significantly large because of the long distances covered by the system. All these considerations lead to a conclusion that managing the bulk water supply system on a full cost recovery basis would not be feasible - at least within the planning horizon of 2025. On the contrary, retail water supply in Karachi can be managed on a full cost recovery basis with sound business and commercial principles. This is why we recommend the separation of bulk and retail supplies.

Managing the bulk water supply system on a full cost recovery basis would not be feasible – at least within the planning horizon of 2025. On the contrary, retail water supply in Karachi can be managed on a full cost recovery basis with sound business and commercial principles. This is why we recommend the separation of bulk and retail supplies.

Figure 72.2.1 demonstrates the basic concept of the proposed separation. **Figure 72.2.2** illustrates the relationship between the bulk and retail suppliers after the separation. It is recommended that in the long run bulk and retail supplies should be managed and operated by different organisations.

It is recommended that in the long run bulk and retail supplies be managed and operated by different organizations.




Figure 72.2.1 Separation of Bulk and Retail Supplies




Figure 72.2.2 Bulk and Retail Suppliers after Separation

The ultimate objective of the proposed separation is to enable the retail supplier to provide customer-focused, efficient water supply and sewerage services on a financially sustainable basis. This requires the insulation of the retail supplier from external interference in the micromanagement aspects of its operation, including the employment of staff, disciplining workers for poor performance, offering rewards and promotions based on good performance, handling of payment defaulters and illegal/unauthorized connections, recovery of arrears, etc. Experience indicates that as long as retail suppliers are dependent on government subsidies they will remain vulnerable to political interference in the day-to-day management of the services and in the technical execution of projects.

The ultimate objective of the proposed separation is to enable the retail supplier to provide customer-focused, efficient water supply and sewerage services to its customers.

This requires the insulation of the retail supplier from external interference in the micromanagement aspects of its operation.

Experience indicates that as long as retail suppliers are dependent on government subsidies, they will remain vulnerable to political interference in the day-to-day management of services and in the technical execution of projects.

It is expected that the proposed separation would enhance the overall efficiency in the operation and maintenance of the water supply system. Since KW&SB in the past has been the only organization responsible for the management and operation of both bulk and retail water supply systems, there has been no absolute necessity for measuring flows at key strategic locations in the system. However, with the separation of the bulk and retail supplies, there will be an absolute necessity for accurately measuring flows at the locations where water is delivered to the retail supplier as shown in **Figure 72.2.2**.

Separation of Bulk and Retail Supplies

Goals

An institutional framework is in place whereby a competent retail supplier (or suppliers) can provide water supply and sewerage services on a full cost recovery basis with sound business and commercial principles.

Strategies

- ☐ **All stakeholders agree to the separation of the bulk and retail supplies.**
- ☐ **Conduct a separate study to identify necessary changes to existing laws, ordinances and regulations and draft detailed legal provisions to put the separation into effect.**
- ☐ **Propose such changes for approval of legislators.**

7.2.3 Zone-wise Management of Retail Supply

KW&SB has divided the entire Karachi City into five distribution zones, namely Zone I, Zone II-A, Zone II-B, Zone III-A and Zone III-B. This division was made for administrative purposes only, and from the hydraulic point of view each zone is not completely separated from others. **Figure 72.3.1** shows the locations of the existing five distribution zones. Zone I straddles the Malir River, and so do Zone II-A and Zone II-B the Lyari River. Zone III-A straddles both rivers. Retail service in each distribution zone is managed by a Zonal Chief Engineer. However, bulk customers in the zone such as cantonments, DHA, PSM, PQA and industries do not fall under his responsibility; they fall under the responsibility of the bulk transmission department. The same department is also responsible for operation and maintenance of water trunk mains that are passing through these distribution zones. **Table 72.3.1** presents the towns included in each of these five distribution zone.

KSDP-2020 (Final Report-August 2007) discussed in **Section 7.1** proposed that the water and wastewater services in Karachi should be managed and operated by each town. This however would not be a feasible option at least in the foreseeable future because of (a) the complexity of the existing water distribution system in which one water trunk main is supplying a number of towns whereas many towns are supplied by more than one water trunk main, and (b) the significant economic disparities between towns, making it difficult for some towns (such as Orangi, Baldia and Lyari) to cross-subsidize tariffs from the rich to the poor because of their weak revenue bases.

Table 72.3.1 Existing Distribution Zones

Zone	Town
Zone I	Shah Faisal
	Landhi
	Korangi
	Malir
	Bin Qasim
Zone II-A	Keamari
	Lyari
	Saddar
Zone II-B	Jamshed
	Gulshan-e-Iqbal
	Liaquatabad
Zone III-A	S.I.T.E.
	Baldia
	Orangi
Zone III-B	North Nazimabad
	New Karachi
	Gulberg
	Gadap

Instead, we propose that Karachi should be divided into three distinct hydraulic zones each separated from the others by two major rivers in Karachi i.e. Malir and Lyari Rivers. The rationale is that there is only a limited number of exiting water mains and sewer pipes that have been laid across these rivers and they can easily be located for installation of isolation valves or bulk flow meters. Further, separation of hydraulic zones by rivers would allow for more prudent approaches for planning of the sewerage system than by the administrative boundaries of the towns. **Figure 72.3.2** shows the locations of the proposed three hydraulic zones. **Table 72.3.2** presents the towns and cantonments included in each hydraulic zone. Because of its

immense size, Gadap town is separated into the three hydraulic zones with its major part being in the Zone Central. Although the main part of Keamari town is located in the Zone West, a small fraction of the town on the left bank of the Lyari River is included in the Zone Central. The other 16 towns are not divided either by the Malir or Lyari River.

Karachi should be divided into three distinct hydraulic zones by the two major rivers in Karachi i.e. Malir and Lyari Rivers.

Table 72.3.2 Proposed Hydraulic Zones

Hydraulic Zone	Town	Cantonment / DHA
Zone West	Keamari (Main)	
	S.I.T.E.	
	Baldia	
	Orangi	
	North Nazimabad	
	Gulberg	
	Liaquatabad	
	New Karachi	
Zone Central	Gadap (Fraction)	
	Lyari	Malir
	Saddar	Faisal
	Jamshed	Karachi
	Gulshan-e-Iqbal	Clifton
	Shah Faisal	Manora
	Malir	DHA
	Gadap (Main)	
Zone East	Keamari (Fraction)	
	Landhi	Korangi Creek
	Korangi	
	Bin Qasim	
	Gadap (Fraction)	

The size of the city is too large for a single retail entity to manage and operate water supply and sewerage services efficiently. It is therefore recommended that water supply and sewerage services in each hydraulic zone be managed and operated by an independent organization. Each organization will be responsible for operation and management of water supply and sewerage services within its own hydraulic zone, including the operation and maintenance of water trunk mains, leakage and NRW reduction, collection of tariffs, employment of staff and dealing with customer complaints. It will purchase treated water in bulk from the bulk supplier at the immediate downstream of filtration plants, service reservoirs, or pumping stations as the case may be, and distribute it through water trunk mains into various towns

located within its hydraulic zone. The organization will also be accountable for collection, transportation and proper treatment of sewage generated in its hydraulic zone. Its revenue base would include not only retail consumers but also bulk consumers such as cantonments, DHA, and other industrial, commercial and governmental entities within the zone. Tariffs would be different from one zone to another reflecting the actual revenue requirements of each zone, providing they obtain prior approval of an independent regulatory body.




Figure 72.3.2 Proposed Hydraulic Zones

The size of the city is too large for a single retail entity to manage and operate water supply and sewerage services efficiently. It is therefore recommended that water supply and sewerage services in each hydraulic zone should be managed and operated by an independent organization.

The advantages of having zone-wise management will be as follows:

- Each organization will be held directly accountable for the quality of the services it provides including the levels of leakage and NRW occurring in its zone
- Water supply and sewerage services can be managed and operated on a competitive basis in which each organization's performance will be evaluated on the basis of common performance indicators (PIs)
- Increase the ease with which equitable distribution can be attained
- Increase the ease with which both technical and non-technical losses can be monitored and reduced. Each zone will be further divided into a number of leakage/NRW control districts, which can be hydraulically isolated whenever necessary to monitor or control leakage and NRW.
- Increase the ease with which customer focused approaches can be implemented. For example, the time required to respond to customers' problems/complaints can be shortened.

Zone-wise Management of Retail Supply

Goals

Retail entities provide efficient water supply and sewerage services to their customers on a competitive basis and with accountability. This relates not only to the quantity and quality of water supplied but also to the improved efficiency in revenue collection, system maintenance, and response to customer problems/complaints.

Strategies

- ☐ **All stakeholders agree to the zone-wise management of water supply and sewerage services.**
- ☐ **Conduct a separate study to identify necessary changes to existing laws, ordinances and regulations and draft detailed legal provisions to put the proposed zone-wise management into effect.**
- ☐ **Propose such changes for approval of legislators.**

7.2.4 Implementation of DNI on a Financially Sustainable Basis

Assessment of the existing water supply conditions in **Section 5.1** revealed that:

- While the basic cost of piped water in Karachi may be cheap, the indirect costs associated with its use are unreasonably high;
- The overall picture is that there are many more urgent problems in the water distribution system than in the bulk water supply system;
- In the light of the poor water supply situation, many residents in Karachi have a very negative impression of KW&SB and the service it provides and are therefore reluctant to pay water charges;
- Many problems have either directly or indirectly emanated from KW&SB's financial constraints; and
- A substantial improvement to water service quality is the only way to break the 'vicious circle' as depicted in **Figure 51.2.1**.

It is the considered opinion of this JICA Study team that a substantial improvement to water service quality can be achieved by significantly reducing leakage and other water losses and introducing metered supplies with a volumetric tariff to all consumers. This view is shared by ADB in its Draft Karachi Sustainable Mega City Water & Wastewater Roadmap, May 2007.

It is only if customers are satisfied with the quality of the service they receive that they find themselves willing to pay for the service. The water awareness survey conducted as part of the JICA study indicated that many households were willing to pay higher charges for a reliable supply of good quality water. With regard to the actual supply of water, the clear targets for the improved quality of the service can be summarized as follows:

- satisfy the customers' water demands so that they no longer need to utilize secondary sources (such as shallow wells and tanker supplies)
- water should be of a potable standard (this would make filtering and boiling of water unnecessary) and be aesthetically pleasing
- water should be supplied at an adequate pressure (this would make the use of suction/booster pumps and roof-top storage tanks unnecessary)
- water should be available on a 24-hour continuous basis to keep the supply system always full of water and under pressure to avoid both contamination and excessive air entrainment (this would make the use of ground-level water reservoirs unnecessary)

These improvements can only be attained through the implementation of Distribution Network Improvements (DNI). The existing water distribution net work comprises about 4,850 km of pipelines of which about 65% is asbestos cement pipes and 26% cast iron. Much of the system is old and in very poor condition. Many pipelines in the system have already been undersized and deteriorated, and the current levels of leakage and non-revenue water are unacceptably high. DNI will embrace the rehabilitation of water trunk mains and distribution network and the refurbishment of service connections including installation of revenue meters. Where necessary, it will also include improvements to the existing sewerage system. Since DNI would require huge investments and more than 10 years of timeframe to complete it across all areas of Karachi, it can only be implemented on an area-by-area basis in a progressive way. In the short to medium term, the costs associated with DNI will have to be recovered from the tariffs charged to customers. This is necessary to implement DNI on a financially sustainable basis.

DNI can only be implemented on an area-by-area basis in a progressive way.

In the short to medium term, the costs associated with DNI will have to be recovered from the tariffs charged to customers. This is necessary to implement DNI on a financially sustainable basis.

It is therefore recommended that customers in areas where DNI has already been completed (and receiving an improved service under which they are guaranteed that water will be available for 24 hours per day on a regular basis) would pay a water charge that is some multiple of the current level of water charges, whereas customers in areas where DNI has not been completed (and continuously receiving the current level of service with intermittent supply) would continue to pay the current level of water charges. This dual pricing structure is necessary: (a) to generate the revenues in the short to medium term that will be needed to service the loans taken to finance DNI (and thereby implement DNI on a financially sustainable basis); (b) to provide a strong incentive for the efficient use of water in areas where DNI has been completed (and customers are receiving an improved service); and (c) to avoid creating an impression that an improvement in service in one neighbourhood is at the expense of the level of service in other neighbourhoods.

Customers in areas where DNI has already been completed would pay a water charge that is some multiple of the current level of water charges. On the other hand, customers in areas where DNI has not been completed would continue to pay the current level of water charges.

This dual pricing structure is necessary: (a) to generate the revenues in the short to medium term that will be needed to service the loans taken to finance DNI (and thereby implement DNI on a financially sustainable basis); (b) to provide a strong incentive for the efficient use of water in areas where DNI has been completed (and customers are receiving an improved service); and (c) to avoid creating an impression that an improvement in service in one neighbourhood is at the expense of the level of service in other neighbourhoods.

The current level of sewerage service charge is well below the level that would be necessary to ensure cost recovery in the medium and longer term, i.e. including the costs of building or extending the sewer network. With the introduction of a measured water supply, the current approach, whereby the charge for sewerage service is a proportion (25%) of the charge for clean water supply, will have the effect of linking the sewerage charge directly to the volume of clean water supplied. As such it will be in line with international practice. However, the 25% premium for sewerage service is certainly not sufficient to cover the costs of operating and maintaining the sewer network and sewage treatment plants. We suggest that this should be increased to 50% of the charge for clean water supply once the quality of sewerage service has been improved. The evidence from the water awareness survey mentioned above suggested that the priority need of the public with respect to the sewerage service is the smooth, uninterrupted removal of sullage and excreta from their home and their vicinity. For this reason, we recommend that DNI should also include improvements to the existing sewage system wherever it is found necessary. Meanwhile, customers in areas where the sewage system has already been improved through DNI would pay a sewerage service charge that is 50% of the charge for the improved service level of clean water supply which, as has been stated above, is already some multiple of the current level of water charges. In contrast, customers in areas where the sewage system has not been improved would continue to pay the current level of sewerage service charge, which is 25% of the charge for clean water supply.

DNI should include improvements to the existing sewage system wherever it is found necessary.

Meanwhile, customers in areas where the sewage system has already been improved through DNI would pay a sewerage service charge that is 50% of the charge for the improved service level of clean water supply, which is already some multiple of the current level of water charges. In contrast, customers in areas where the sewerage system has not been improved would continue to pay the current level of sewerage service charge, which is 25% of the charge for clean water supply.


The examination of the financial statements of KW&SB for recent years shows an extremely worrying trend as regards its short term financial positions. Over recent years, KW&SB has continuously been operating in deficit. The annual deficit ranges from Rs.2,000 to 2,700 million (US\$33.3 to 45.0 million) as shown in **Table 72.4.1** below. **Figure 72.4.1** illustrates these deficits as compared with annual revenues. At the end of the fiscal year 2004/05, the accumulated deficit totalled to Rs. 10,435 million (US\$173.9 million). These deficits have eventually been subsidised by GOP and GOS.

Table 72.4.1 Accumulated Deficit of KW&SB

Rs.million

Fiscal Year	2000/01	2001/02	2002/03	2003/04	2004/05
Profit/Loss of the Fiscal Year	-820.70	-2,029.65	-2,693.09	-2,536.39	-2,358.71
Accumulated Surplus/Deficit at start of Fiscal Year	3.00	-817.70	-2,847.36	-5,540.44	-8,076.83
Accumulated Surplus/Deficit at end of Fiscal Year	-817.70	-2,847.36	-5,540.44	-8,076.83	-10,435.54

Source: Profit and Loss Statements, KW&SB

**Figure 72.4.1 Revenues and Deficits of KW&SB**

This demonstrates that KW&SB is not financially capable of taking new loans for the implementation of DNI. DNI will involve not only physical improvement works; it will also include improvements to many institutional aspects, such as the introduction of a dual pricing system, elimination of illegal and unauthorised connections, and the strict enforcement of laws on payment defaulters. As such, it is very likely that the implementation of DNI would face severe political interference if it is financed by Government subsidies. It is therefore necessary to create a new institutional framework, whereby DNI can be implemented on a loan financing basis without any Government subsidies.

Implementation of DNI on a Financially Sustainable Basis

Goals

In the short to medium term, retail entities will generate the revenues sufficient to service the loans taken to finance DNI (and thereby implement DNI on a financially sustainable basis).

Strategies

- ☐ **Implement DNI on an area-by-area basis in a progressive way.**
- ☐ **Introduce a dual pricing structure in that customers in areas where DNI has already been completed (and receiving an improved level of service) would pay a water charge that is some multiple of the current level of water charges.**
- ☐ **Include improvements to the sewerage system in the scope of DNI.**
- ☐ **Increase the level of sewerage service charge to 50% of the charge for clean water supply in areas where an improvement to the sewerage system has already been made.**
- ☐ **Create a new institutional framework whereby DNI can be implemented on a loan financing basis without any Government subsidies.**

7.3 SYSTEM DEVELOPMENT PLAN

7.3.1 Expansion of Filtration Plants

As explained previously the bulk water source availability from the Indus River and Hub Dam for the Karachi Water Supply System in 2025 is 1,332 as listed below.

Future Bulk Water Availability	: 1,365 mgd
Indus River	: 1,290 mgd (2,400 cusecs: ft ³ /s)
Hub Dam	: 75 mgd
<u>Supply to Pakistan Steel Mills, Port Qasim, etc.</u>	: 33 mgd
Bulk Water Availability for Water Supply System	: 1,332 mgd

Of the bulk water of 1,332 mgd, about 630 mgd is being supplied to customers as of the end of year 2006. About 420 mgd of water is supplied after filtration and the remaining water is directly supplied without filtration.

At present two projects are being conducted for adding the filtration capacity. One is ADB Project and the other is K-IV Project. ADB Project is considering to construct two filtration plants at NEK Old (100 mgd) and COD (85 mgd). K-IV Project has proposed three filtration plants (260 mgd × 2 plants and 130 mgd × 1 plant = 650 mgd) for next 20 years. As of the end of the December 2007, PC-1 for first phase of the K-IV Project is in the process of approval. Therefore, the JICA study takes these two projects into account for preparation of water supply master plan as shown in **Table 73.1.1**. The filtration capacity of the Karachi Water Supply System is expected to be 1,270 mgd.

Table 73.1.1 Future Water Supply Capacity

Filtration Plant	Capacity	Remarks
Gharo Filtration Plant	20 mgd	existing
Pipri Filtration Plant	100 mgd	existing
NEK Old Filtration Plant	25 mgd	existing
NEK New Filtration Plant	100 mgd	existing
COD Filtration Plant	115 mgd	existing
COD Filtration Plant (expansion)	85 mgd	ADB Project
Hub Filtration Plant *	75 mgd	existing
K-III Filtration Plant at NEK Old	100 mgd	ADB Project
K-IV Filtration Plants	650 mgd	K-IV Project
Total	1,270 mgd	

source: KW&SB

* : considered to "95% level of reliability of the Hub River Yield"

Two proposed plants to be constructed at COD and NEK Old (K-III) by ADB Project are for treating water which is directly supplied to customers without filtration now and that is not to say that the supply capacity increases due to the construction of these two filtration plants. Therefore, for the planning purpose, total capacity of these two plants of 185 mgd is considered to be included in the existing capacity regardless of those completions. These plants are expected to be constructed by the year 2011.

7.3.2 Stage-wise Development Plan

(1) Construction Schedule of Bulk Water Supply Facilities proposed by K-IV Project

K-IV Project has proposed 3 filtration plants located in the western part, central part and eastern part of Gadap Town in accordance with its implementation schedule as shown in **Table 73.2.1**. Constructions of three plants are divided into 5 stages (130 mgd each). On the other hand, canals & conduits will be constructed by three stages, which capacities are 260 mgd respectively.

Table 73.2.1 Implementation Schedule of K-IV Project

Timeframe	Staging	Supply Capacity to be increased	Filtration Plant		Canal & Conduit
			Capacity	Location	
2007-2011	1 A	130 mgd	130 mgd	Central	260 mgd for Zone Central
2011-2015	1 B	130 mgd	130 mgd	Central	-
2015-2019	2 A	130 mgd	130 mgd	West	260 mgd for Zone West
2019-2023	2 B	130 mgd	130 mgd	West	-
2023-2027	3 A	130 mgd	130 mgd	East	260 mgd for Zone East

source: K-IV Project, Greater Karachi Water Supply Scheme (Executive Summary, May 2007)

The K-IV Project has recommended a construction of new filtration plant with a capacity of 130mgd at Zone Central first. **Figure 73.2.1** shows a stage-wise development plan proposed by K-IV Project against the water demand projected by JICA study mentioned in **Section 6.2 "Water Demand"**. In this case, however, Karachi City is facing a water shortage almost the every year in the future.




Figure 73.2.1 Stage-wise Development Plan proposed by K-IV Project

(2) Proposed Construction Schedule of Bulk Water Supply Facilities

As of the end of the December 2007, PC-1 for the first phase of the K-IV Project is in the process of approval. The first phase of the K-IV project includes land acquisitions for all canals and conduits to be constructed by K-IV Project, bulk water transmission facilities (260 mgd) from Kinjhar Lake and filtration plant (130 mgd). The filtration plant will be constructed at the central area of Gadap Town. The first phase project has been already ongoing and its components can not be changed by the JICA Study. Therefore, the first filtration plant with a capacity of 130 mgd will be constructed at the central.

Table 73.2.2 shows a zone-wise water balance in 2025 which is a target year of the study. As seen in **Table 73.2.2**, if the filtration plant with a capacity of 130 mgd would be constructed at the zone central, the further expansion of its capacity should not be needed anymore. Instead, it is necessary for zone west and zone east to construct a filtration plant with a capacity of 260 mgd respectively considering a balance between the water demand and the supply capacity.

Table 73.2.2 Water Balance of Each Zone in 2025

Zone	West	Central	East
Zone-wise Demand (mgd)	346	534	307
Zone-wise Supply Capacity (mgd)	75	425	120
List of the Existing Filtration Plants*	Hub: 75 mgd	NEK Old: 25 mgd NEK New: 100 mgd COD: 200 mgd K-III: 100 mgd	Pipri: 100 mgd Gharo: 20 mgd
Balance(mgd)	-271	-109	-187

*: Data from KW&SB

JICA Study proposes an alternative stage-wise development plan against the original implementation schedule of K-IV Project, as shown in **Table 73.2.3** and **Figure 73.2.2** under the following conditions.

- Completion year of the first stage, which is the year of 2011, should be kept.
- Project components of the first stage should be kept.

- Interval of each stage should be at least 4 years which is original intervals of staging proposed by K-IV Project as shown in **Table 73.2.1**.
- Canal construction for bulk water supply to filtration plant, which capacity is 260 mgd, should not be double and more at one stage.
- Water supply capacity in 2025 should exceed the demand in 2025.
- Period of water shortage (supply shortfall) should be minimised.

Table 73.2.3 Proposed Implementation Schedule

Timeframe (Construction Period)	Stage	Filtration Plant	Bulk Transmission	Remarks
2009-2011	Stage I	130 mgd × 1 plant at Zone Central	260 mgd for Zone Central	Same Plan as the K-IV Project
2014-2016	Stage II	130 mgd × 2 plants at Zones West and East	260 mgd for Zone West	Modified Plan from the K-IV Project
2019-2021	Stage III	130 mgd × 2 plants at Zones West and East	260 mgd for Zone East	




Figure 73.2.2 Recommended Stage-wise Development Plan

(3) Proposed Development Plan

To meet the increasing water demand in Karachi, the water supply capacity of the filtration plants is proposed to be expanded in three stages as shown in **Figure 73.2.2**. Target year of each stage is as follows:

Stage I (Short term)	: 2016
Stage II (Medium term)	: 2021
Stage III (Long term)	: 2025

Under Stage I the capacity will be expanded by 130 mgd to meet the water demand in year 2016. However, the increased capacity will meet only the demand of 2012 as shown in **Figure 73.2.2**. Considering the magnitude of the development scale, water right of the Indus River, future water supply situation and time frame, this is the best choice for the Karachi Water Supply System. Stage II and stage III consist of an expansion of 260 mgd respectively. The

increased capacities of those stages are to meet the water demand in 2021 and 2025 respectively. **Table 73.2.4** shows a water balance between future water demand and planned supply capacity of the proposed water supply development plan. In 2011 just before the completion of a new filtration plant of 130 mgd by K-IV Project, the system will face a water shortage of 88 mgd.

Table 73.2.4 Water Balance of the Proposed Plan

Year	2006	2011	2016	2021	2025
Total Demand (mgd) *	580	708	863	1,043	1,187
Supply Capacity (mgd)	620	620	750	1,010	1,270
Balance(mgd)	40	-88	-113	-33	83

*: including a water supply to Barochistan of 5 mgd

Table 73.2.5 shows a water balance between future water demand and planned supply capacity at each zone.

Table 73.2.5 Water Balance of Each Zone

Target Year		2006	2011	2016	2021	2025
Zone West						
Supply Capacity	mgd	75	75	75	205	335
Water Demand*	mgd	191	222	264	310	346
Balance	mgd	-116	-147	-189	-105	-11
Zone Central						
Supply Capacity	mgd	425	425	555	555	555
Water Demand	mgd	286	338	401	475	534
Balance	mgd	+139	+87	+154	+80	+21
Zone East						
Supply Capacity	mgd	120	120	120	250	380
Water Demand	mgd	104	148	198	258	307
Balance	mgd	+16	-28	-78	-8	+73

*: including a water supply to Barochistan of 5 mgd

In conclusion, the stage-wise development plan is proposed as shown in **Figure 72.2.3**.




Figure 73.2.3 Stage-wise Development Plan for the Target Year of 2025

7.3.3 Water Supply Plan

Considering the magnitude of the future Water Supply System in Karachi and topographical features of Karachi City, JICA study recommends the zone-wise management of the retail supply in where water supply area will be divided into 3 zones (Zone West, Zone Central and Zone East) by two main rivers flowing through Karachi City, namely Lyari River and Malir River. Each zone will be managed and operated by an independent organization or by a different business unit of the same organization. Zone-wise water demand is shown in **Table 73.3.1**. **Figure 73.3.1** shows the schematic water supply plan for the system in 2025.

Table 73.3.1 Zone-wise Water Demand

	2006	2011	2016	2021	2025
Total Demand	580	708	863	1,043	1,187
Zone West*	191	222	264	310	346
Zone Central	286	338	401	475	534
Zone East	104	148	198	258	307

*: including a water supply to Barochistan of 5 mgd

Water supply plan for each zone was formulated based on the following policies:

- eliminating the use of several bulk pumping stations and a large number of small size distribution pumping stations for energy cost saving,
- supplying water by gravity as much as possible, and
- keeping minimum dynamic water pressure of 10 m in distribution system.




Figure 73.3.1 Schematic Water Supply Plan for Each Zone in 2025

As a result the proposed water supply system in 2025 is shown in **Figure 73.3.2** and detailed hereinafter. The alternative studies related to water supply system are attached to **Appendixes A73.1 to A73.4**.




Figure 73.3.2 Proposed Water Supply System in 2025

For reference, definitions of water supply facilities are illustrated in **Figure 73.3.3**. Especially transmission and distribution systems are defined as follows:

Transmission System (transmission pumping station and transmission main) transfers filtered water to reservoirs by pumping or by gravity, not to supply water directly to customers. Transmission main should not have any branches for distribution or bulk supply. Flow rate of

the transmission system is equal to daily water demand.

Distribution System (distribution pumping station, trunk distribution main and distribution network main) supplies filtered water from reservoirs to customers. The design capacity of distribution system is needed to be 1.5 – 2.0 times of daily water demand considering hourly demand fluctuation. For example, during the night people use less water, but in the morning and evening people use much more water.




Figure 73.3.3 Typical Water Supply System

7.4 WATER SOURCES

Table 74.1.1 summarises planned future water sources of the KW&SB's water supply.

Table 74.1.1 Water Sources for the Target Year of 2025

Water Source	Capacity	Remarks
Kinjhar Lake (The Indus River)	645 mgd (1,200 cusecs; ft ³ /s)	Existing
Kinjhar Lake (The Indus River)	645 mgd (1,200 cusecs; ft ³ /s)	Additional planned by K-IV Project
Hub Dam	75 mgd	Existing
Dumlottee Wells	0 mgd	To be abandoned
Total	1,365 mgd	

In addition to the current bulk water of 1,200 cusecs (645 mgd) from Kinjhar Lake, another 1,200 cusecs (645 mgd) will be also taken from Kinjhar Lake for 2025 by the implementation of K-IV Project. It is estimated that 75 mgd can be taken from Hub Dam at the probability of 95% based on a hydrologic analysis, for the KW&SB's water supply including water supply to part of Barochistan District. For reference, flow data of the Indus River above the Kotri Barrage and withdrawals at the Kotri Barrage from 1976 to 1984 (Feasibility Study for future expansion of Karachi Water Supply System, December 1985) are attached to **Appendix A32.1**. On the other hand, existing Dumlottee Wells will not be suitable for the KW&SB's water source

any more, since its production has been decreasing year by year. At present it is used only in a limited period of rainy season.

CDGK have requested the Federal Government for granting an additional water right of 1,200 cusecs from Indus River for Karachi Water Supply System. As of the end of December 2007, however, an additional water right from the Indus River of 1,200 cusecs has not been approved yet. In developing a water supply system, Karachi would be granted additional 1,200 cusecs of quota from the Indus River and a total of 2,400 cusecs of the Indus River water would be made available at the Kinjhar Lake for abstraction of KW&SB. This is based on a strong belief that if this additional quota water were not granted, then there would be no such large population increase or significant developments in future as has been envisaged by KSDP – 2020 (August 2007).

7.5 BULK WATER SUPPLY SYSTEM

7.5.1 Existing Bulk Water Supply System

Present bulk water supply system for Karachi City has a capacity of 600 mgd as shown in **Table 75.1.1**. This figure does not include bulk water supply of bulk water from Gujjo Headworks to Pakistan Steel Mills and Port Qasim Authority which have their own bulk water transmission facilities (canals and pumping stations) and filtration plants. Actually as of the end of year 2006 KW&SB supplied bulk water of about 630 mgd beyond the capacity as shown in **Table 75.1.1** and detailed in **Section 3.3.1**. **Figure 75.1.1** shows a schematic diagram of the existing bulk water supply system.

Table 75.1.1 Bulk Water Supply Capacity

Bulk Water System	Capacity	Actual Supply
GK System	280 mgd	300 mgd
Haleji System	20 mgd	30 mgd
K-II System	100 mgd	120 mgd
K-III System	100 mgd	100 mgd
Dumlottee Wells	20 mgd	0 mgd
Hub System	80 mgd	80 mgd
Total	600 mgd	630 mgd

source: KW&SB




Figure 75.1.1 Existing Bulk Water Supply System

7.5.2 Proposed Bulk Water Supply System

(1) Canal and Conduit

Existing bulk water supply systems including GK, K-II and K-III bulk water supply systems will be continuously used for the future system. The existing bulk water supply system from Hub Dam to Manghopir Pumping Station (P/S) will be also used continuously. The periodical and proactive rehabilitation and repair works for the existing bulk water canals and conduits are proposed, since the existing bulk water canals and conduits are very old. It is also recommended that KW&SB should measure the actual flow rates of these canals and conduits for identifying current status of the bulk water supply system. As a result KW&SB may need to review and improve those capacities.

On the other hand, Dumlottee Conduit will be abandoned by 2025 because of the permissible yield of the Dumlottee Wells. At present K-III system transfers bulk water to Manghopir P/S through K-III Pumping Station (P/S), NEK Old Reservoir and NEK-Hub Link Main for making up for the water shortage of Hub Dam. In the proposed system, water pumped up from K-III P/S will be filtered at new F/P (K-III F/P) near NEK Old F/P and then distributed to customers. Therefore, no water goes to Manghopir P/S from the K-III system. **Figure 75.2.1** shows a proposed Greater Karachi Bulk Water Supply System from Kinjhar Lake to Karachi City considering actual bulk supply amount and on-going projects of the expansion of COD F/P and construction of K-III F/P which have been proposed by KW&SB by using ADB Loan.

In addition to the existing bulk water supply system, three canals with a total capacity of 780 mgd ($260 \text{ mgd} \times 3 \text{ canals}$) will be constructed by K-IV Project. Those canals will transfer bulk water from Kinjhar Lake to three filtration plants which will be also proposed by K-IV Project. The capacity of future bulk water supply system is summarised in **Table 75.2.1**. **Figure 75.2.2** shows a proposed arrangement between bulk water canals and filtration plants which will be constructed by K-IV project.





Figure 75.2.1 Future Greater Karachi Bulk Water Supply System

Table 75.2.1 Future Bulk Water Supply Capacity

Bulk Water System	Existing Capacity	Future Capacity	Remarks
GK System	280 mgd	305 mgd	Existing
Haleji System	20 mgd	20 mgd	Existing
K-II System	100 mgd	120 mgd	Existing
K-III System	100 mgd	100 mgd	Existing
Dumlottee Wells	20 mgd	0 mgd	to be abandoned
Hub System*	80 mgd	75 mgd	Existing
K-IV System	-	780 mgd	Proposed
Total	600 mgd	1,400 mgd	

source: KW&SB

* : considered to "95% level of reliability of the Hub River Yield"

**Figure 75.2.2 Proposed Arrangement between Canals and Filtration Plants constructed by K-IV Project**

(2) Bulk Transmission Pumping Station

The bulk transmission pumping stations for the target year of 2025 which are used mainly as intake pumping station at filtration plants except Dhabeji P/S are listed in **Table 75.2.2**. The life span of the pumping equipment is assumed to be 15 years. Therefore, the pumping equipment in all the existing pumping stations should be replaced by 2025.

Among the KW&SB's facilities, NEK Old Pumping House near NEK New F/P is well maintained and operated. Mechanical and electrical equipment at this pumping house is being kept in good condition. This is able to become a model for others to emulate for operation and maintenance of mechanical and electrical equipment not only at other P/Ss but also at F/Ps.

Table 75.2.2 Bulk Transmission Pumping Stations in 2025

Sr.No.	Name of Pumping Station	Year of Construction	Total Capacity (MGD)	Running Capacity (MGD)	Pumps & Motors					Generator Capacity (MW)
					Total No. of Pumps	No. of Stand-By Pumps	Capacity of Each Pump (MGD)	Pump Head (ft)	Electric Motor (KW)	
1	Dhabeji (Phase-I)	1959	120	48	5	3	24	210	Diesel+Gas	0.25
2	Dhabeji (Phase-II)	1971	125	100	5	1	25	210	1050	--
3	Dhabeji (Phase-III)	1978	125	100	5	1	25	210	1050	--
4	Dhabeji (Phase-IV)	1997	125	100	5	1	25	210	1050	4.52
5	K-II (Dhabeji)	1998	175	140	5	1	35	210	1635	--
6	K-III (Dhabeji)	2006	210	140	6	2	35	210	1635	--
7	Gharo (Old)	1943	37	23	3	1	5	170	Diesel	0.5
		1982			6	2	2.0	170	74.6	
		2002			2	1	5.0	170	149.1	
8	Gharo (New)	1953	40	21	2	1	10	170	Diesel	0.5
		1997			5	2	2.0	170	93.2	
		2002			2	1	5.0	170	186.4	
9	Pipri (old)	1971	75	50	6	2	12.5	100	260	1.5
10	Pipri (Phase IV)	1994	50	37.5	4	1	12.5	56	132	1.25
11	Pipri (New)	2000	60.48	51.84	14	2	4.32	100	111.9	0.6
12	Hub (New) (Manghopir)	2006	175	105	4	1	35	168	1350	-
					2	2	17.5	168	750	
13	NEK (Old)	1978	80	35	4	2	12.5	160	372.9	1.25
					6	4	5	160	111.9	
14	Low Lift (at NEK New)	1998	175	105	5	2	35	40	232.7	-
15	K-III (at NEK New)	2006	135	90	6	2	22.5	160	391.5	-

In addition to the existing bulk pumping stations, two bulk pumping stations between Kinjhar Lake and Filtration Plants are proposed for new bulk water transmission system to be constructed by K-IV Project. Details of new pumping stations are summarised in **Table 75.2.3**.

Table 75.2.3 Details of New Bulk Pumping Station

Pumping Station	Stage	Capacity	Total Dynamic Head (m)	Power Plant Required (MW)
1st Stage Pumping Station	Stage I	130 mgd	41	3.9
	Stage II	260 mgd	41	7.8
	Stage III	260 mgd	41	7.8
2nd Stage Pumping Station	Stage I	130 mgd	74	7.1
	Stage II	260 mgd	74	14.2
	Stage III	260 mgd	74	14.2

source: K-IV Project, Greater Karachi Water Supply Scheme (Executive Summary, May 2007)

On the other hand, the study proposes that the following seven existing bulk pumping stations are eliminated for future bulk water supply system for energy cost saving.

- 9th Mile Pumping Station
- Low Service Reservoir Old Pumping Station

- Low Service Reservoir New Pumping Station
- Ajmer Nagri Pumping Station
- Temple and Currie Pumping Station
- Dumlottee Pumping Station
- Board Office Pumping Station

7.6 WATER FILTRATION PLANTS

7.6.1 Proposed Filtration Plants

Table 76.1.1 shows a list of zone-wise filtration plants (F/Ps) proposed in 2025. Production of all the F/Ps is expected to keep their design capacities without overload operation.

Table 76.1.1 Filtration Plants in 2025

Filtration Plant	Zone	Capacity (mgd)	Remarks
Hub F/P	West	75	Existing
West F/P	West	260	proposed by K-IV Project
Sub-Total of Zone West		335	
NEK Old F/P	Central	25	Existing
NEK New F/P	Central	100	Existing
COD F/P	Central	115	Existing
	Central	85	expansion by ADB Project
KIII F/P	Central	100	proposed by ADB Project
Central F/P	Central	130	proposed by K-IV Project
Sub-Total of Zone Central		555	
Gharo F/P	East	20	Existing
Pipri F/P	East	100	Existing
East F/P	East	260	proposed by K-IV Project
Sub-Total of Zone East		380	
Total		1,270	

At present water for K-III F/P and COD F/P to be expanded is supplied directly to customers without filtration. It is, therefore, recommended that such water should be treated at filtration plant. Asian Development Bank proposes the construction of K-III F/P and expansion of COD F/P (Draft Karachi Sustainable Mega City Water and Wastewater Roadmap, May 2007, ADB). K-III F/P with a capacity of 100 mgd will be constructed at/near the site of NEK Old F/P and COD F/P with a capacity of 85 mgd will be expanded at the existing COD F/P. It is, however, noted that the construction of K-III F/P (100 mgd) and the expansion of COD F/P (85 mgd) are not the increase of water supply capacity because water of 100 mgd for K-III F/P and 85 mgd for COD expansion is being supplied directly to customers without filtration.

New F/Ps (260 mgd \times 2 plants at Zone West and Zone East and 130 mgd \times 1 plant at Zone Central) are proposed for future water supply system. As described in **Section 7.3 “System Development Plan”**, West F/P, Central F/P and East F/P are expected to start its production by year 2016, 2011 and 2016 respectively.

New F/Ps will consist of large capacity lagoon (520 mg) for storing 2 days bulk (raw) water and for grit chamber in case of coming turbid water from the Kinjhar Lake (K-IV Project, Greater Karachi Water Supply Scheme, Executive Summary, May 2007). As well as the existing process, the rapid sand filtration system is recommended for the proposed treatment process. The proposed treatment process consists of receiving chamber, sand filtration and chlorination and is shown in **Figure 76.1.1**. This process was designed with consideration of the bulk water quality (see **Table 76.1.2**) and the existing process. In addition the space for rapid mixing basin and flocculation/sedimentation basin should be kept for future treatment process

due to deterioration of bulk water quality. If the turbidity is found as high level continuously, it is recommended constructing rapid mixing basin and flocculation/sedimentation basin as pre-treatment to remove turbidity.




Figure 76.1.1 Proposed Water Treatment Process for New Filtration Plant

Table 76.1.2 Bulk Water Quality of KG Canal before Gujjo Headworks

Parameters	Unit	Dry Season (June 2006)	Wet Season (August 2006)
pH		8.20	8.11
Turbidity	NTU	0.19	0.55
Iron	mg/l	0.11	0.165
Manganese	µg/L	7.40	10.81
Ammonia-Nitrogen	mg/l	0.096	ND
Faecal Coliform	count/dl	43	1,100

source: Progress Report No.1, September 2006

7.6.2 Rehabilitation and Improvement of Existing Filtration Plants

The design life for the filtration plants is generally shown in **Table 76.2.1**. The design life for concrete structures is 50 years and the design life for mechanical and electrical equipment is 15 years. Once the design life is exceeded, the facilities will be abandoned and new facilities will be constructed, if necessary.

Table 76.2.1 Design Life for the Filtration Plants

Intake Facilities		Life Time (years)
	Pump House (concrete structure)	50
	Mechanical and electrical equipments	15
Filtration Plant		
	Tank and basin (concrete structures)	50
	Mechanical and electrical equipments	15

At present (as of 2007) KW&SB are proposing PC1 for the rehabilitations of the existing plants including Ghara F/P, Pipri (old 25 mgd × 2 plants) F/P, COD F/P and NEK Old F/P. The rehabilitations to the existing plants should include not only repair of the existing facilities and equipment but also some improvements based on plant safety, process control, and the need for continuous water supply. Plant safety is the most important aspect of the proposed improvements. Most filtration plants do not have safety measurement equipment for chlorine gas and some plants do not use a chlorinator for chlorination. Therefore safety and health improvements have been set as the highest priority. Process control improvements such as installing flow meters are set as the second priority. Therefore the rehabilitation and improvement of the existing filtration plants include, but are not limited to;

- Replacement of a top layer of filter media
- Rehabilitation of all valves, fittings and other accessories for filter basin
- Rehabilitation of backwashing system for filter basin
- Replacement of chlorinators and accessories and improvement of safety measurement equipment for chlorination system

- Replacement and repair of chemical dosing equipment including pipelines and other accessories
- Installation of level indicators at reservoirs
- Installation of flow meters at outlet of reservoirs
- Rehabilitation of standby generating set
- Repair of steel structure
- Repair of leakages from the water retaining structures and pipelines
- Repair and replacement of damaged flooring, walls, doors and windows where ever required.
- Arrangement of lighting system for security along the boundary line

Other F/Ps of NEK New F/P, Hub F/P and Pipri (new 50 mgd plant) are recommended to be rehabilitated at Stage III from 2019 to 2021.

7.7 WATER TRANSMISSION SYSTEM

7.7.1 General

Existing water transmission system will be improved by dividing water supply areas of Karachi into three zones of Zone-West, Zone-Central, and Zone-East. The estimated zone-wise demands in 2016, 2021, and 2025 are shown in **Tables 77.1.1** and **77.1.2**.

The future land use map in 2025 including future roads proposed in Karachi Strategic Development Plan 2020 (Final, August 2007) is shown in **Figure 77.1.1**. A contour map of Karachi is generated using GIS software from Digital Elevation Model developed based on 1:50,000 topographic maps prepared by Survey of Pakistan during 1991~1995. The created contour map is shown in **Figure 77.1.2**.

Based on these basic conditions and information, new filtered water transmission system including trunk distribution mains for the three zones is proposed as seen in **Figure 77.1.3** in consideration of;

- eliminating the use of several bulk pumping stations and a large number of small size distribution pumping stations for energy cost saving,
- supplying water by gravity as much as possible, and
- keeping minimum dynamic water pressure of 10 m in distribution system.

Flow diagram of the proposed system in 2025 is shown in **Figure 77.1.4**. Flow diagrams of the proposed systems for intermediate years of 2016 and 2021 are attached to **Appendix 77.1**. As the result of a preliminary hydraulic analysis, pumping will be required only for transferring water from filtration plants to the distribution reservoirs in order to supply water to relatively high altitude area.


The details of proposed reservoirs, filtered water transmission mains, transmission pump stations and network analysis are further explained in the following sub-sections.

Table 77.1.1 Zone-Wise Water Demand (1/2)

Zone-Wise Water Demand in 2011		
Zone-West	Zone-Central	Zone-East
Demand <u>Town</u> 1 Keamari (West) 17.64 mgd 2 SITE 34.56 mgd 3 Baldia 18.59 mgd 4 Orangi 28.00 mgd 12 North Nazimabad 26.34 mgd 13 New Karachi 26.11 mgd 14 Gulberg 23.47 mgd 15 Liaquatabad 29.43 mgd 18 Gadap (West) 12.87 mgd <u>Cantonment</u> <u>Other Authority</u> <u>Other District</u> Barochistan 5 mgd Total Demand 222.01 mgd Production <u>FP</u> Hub 80 mgd Total Production 80 mgd Remained Production -142.01 mgd	Demand <u>Town</u> 3 Keamari (Port) 10.20 mgd 5 Lyari 22.65 mgd 6 Saddar 70.72 mgd 7 Jamshed 36.86 mgd 8 Gulshan-e-Ibal 60.92 mgd 9 Shah Faisal 23.40 mgd 16 Malir 40.46 mgd 18 Gadap (Central) 22.64 mgd <u>Cantonment</u> ① Manora 0.39 mgd ② Malir 15.27 mgd ③ Karachi 1.00 mgd ④ Crifton 0.89 mgd ⑤ Faisal 6.88 mgd <u>Other Authority</u> DHA 25.88 mgd <u>Other District</u> Total Demand 338.16 mgd Production <u>FP</u> NEK Old 25 mgd NEK New 100 mgd COD 115 mgd K-III 100 mgd Total Production 340 mgd Remained Production 1.84 mgd	Demand <u>Town</u> 10 Landhi 38.56 mgd 11 Korangi 37.70 mgd 17 Bin Qasim 64.52 mgd 18 Gadap (East) 3.78 mgd <u>Cantonment</u> ⑥ Korangi 3.60 mgd <u>Other Authority</u> <u>Other District</u> Thatta (as Low Water) Total Demand 148.16 mgd Grand Total of Demand 708.33 mgd Production <u>FP</u> Gharo 20 mgd Pipri 100 mgd Total Production 120 mgd Grand Total of Production 540 mgd Remained Production -28.16 mgd
Zone-Wise Water Demand in 2016		
Zone-West	Zone-Central	Zone-East
Demand <u>Town</u> 1 Keamari (West) 32.34 mgd 2 SITE 36.36 mgd 3 Baldia 25.63 mgd 4 Orangi 31.06 mgd 12 North Nazimabad 28.71 mgd 13 New Karachi 27.88 mgd 14 Gulberg 25.83 mgd 15 Liaquatabad 29.42 mgd 18 Gadap (West) 21.76 mgd <u>Cantonment</u> <u>Other Authority</u> <u>Other District</u> Barochistan 5 mgd Total Demand 263.98 mgd Production <u>FP</u> Hub 75 mgd Total Production 75 mgd Remained Production -188.98 mgd	Demand <u>Town</u> 3 Keamari (Port) 11.83 mgd 5 Lyari 23.06 mgd 6 Saddar 71.68 mgd 7 Jamshed 43.79 mgd 8 Gulshan-e-Ibal 79.66 mgd 9 Shah Faisal 24.38 mgd 16 Malir 43.19 mgd 18 Gadap (Central) 42.95 mgd <u>Cantonment</u> ① Manora 0.47 mgd ② Malir 18.52 mgd ③ Karachi 1.21 mgd ④ Crifton 1.07 mgd ⑤ Faisal 8.34 mgd <u>Other Authority</u> DHA 30.73 mgd <u>Other District</u> Total Demand 400.88 mgd Production <u>FP</u> NEK Old 25 mgd NEK New 100 mgd COD 200 mgd K-III 100 mgd Central 130 mgd Total Production 555 mgd Remained Production 154.12 mgd	Demand <u>Town</u> 10 Landhi 45.36 mgd 11 Korangi 46.59 mgd 17 Bin Qasim 94.79 mgd 18 Gadap (East) 6.68 mgd <u>Cantonment</u> ⑥ Korangi 4.36 mgd <u>Other Authority</u> <u>Other District</u> Thatta (as Low Water) Total Demand 197.77 mgd Grand Total of Demand 862.64 mgd Production <u>FP</u> Gharo 20 mgd Pipri 100 mgd Total Production 120 mgd Grand Total of Production 750 mgd Remained Production -77.77 mgd

Table 77.1.2 Zone-Wise Water Demand (2/2)

Zone-Wise Water Demand in 2021		
Zone-West	Zone-Central	Zone-East
<u>Demand</u> <u>Town</u> 1 Keamari (West) 47.69 mgd 2 SITE 38.83 mgd 3 Baldia 31.11 mgd 4 Orangi 34.76 mgd 12 North Nazimabad 32.13 mgd 13 New Karachi 30.36 mgd 14 Gulberg 28.88 mgd 15 Liaquatabad 30.53 mgd 18 Gadap (West) 30.21 mgd <u>Cantonment</u> <u>Other Authority</u> <u>Other District</u> Barochistan 5 mgd Total Demand 309.50 mgd <u>Production</u> <u>FP</u> Hub 80 mgd West 130 mgd Total Production 210 mgd Remained Production -99.50 mgd	<u>Town</u> 3 Keamari (Port) 12.52 mgd 5 Lyari 23.87 mgd 6 Saddar 74.53 mgd 7 Jamshed 50.03 mgd 8 Gulshan-e-Ibal 103.06 mgd 9 Shah Faisal 25.79 mgd 16 Malir 48.11 mgd 18 Gadap (Central) 64.06 mgd <u>Cantonment</u> ① Manora 0.57 mgd ② Malir 22.37 mgd ③ Karachi 1.46 mgd ④ Crifton 1.30 mgd ⑤ Faisal 10.07 mgd <u>Other Authority</u> DHA 37.64 mgd <u>Other District</u> Total Demand 475.36 mgd <u>FP</u> NEK Old 25 mgd NEK New 100 mgd COD 200 mgd K-III 100 mgd Central 130 mgd Total Production 555 mgd Remained Production 79.64 mgd	<u>Town</u> 10 Landhi 54.75 mgd 11 Korangi 58.61 mgd 17 Bin Qasim 129.36 mgd 18 Gadap (East) 10.03 mgd <u>Cantonment</u> ⑥ Korangi 5.27 mgd <u>Other Authority</u> <u>Other District</u> Thatta (as Low Water) Total Demand 258.01 mgd Grand Total of Demand 1,042.87 mgd <u>FP</u> Gharo 20 mgd Pipri 100 mgd East 130 mgd Total Production 250 mgd Grand Total of Production 1,015 mgd Remained Production -8.01 mgd
Zone-Wise Water Demand in 2025		
Zone-West	Zone-Central	Zone-East
<u>Demand</u> <u>Town</u> 1 Keamari (West) 60.22 mgd 2 SITE 40.79 mgd 3 Baldia 35.63 mgd 4 Orangi 37.91 mgd 12 North Nazimabad 35.03 mgd 13 New Karachi 32.47 mgd 14 Gulberg 31.48 mgd 15 Liaquatabad 31.51 mgd 18 Gadap (West) 36.22 mgd <u>Cantonment</u> <u>Other Authority</u> <u>Other District</u> Barochistan 5 mgd Total Demand 346.27 mgd <u>Production</u> <u>F/P</u> Hub 75 mgd West 260 mgd Total Production 335 mgd Remained Production -11.27 mgd	<u>Town</u> 3 Keamari (Port) 13.09 mgd 5 Lyari 24.59 mgd 6 Saddar 76.71 mgd 7 Jamshed 55.27 mgd 8 Gulshan-e-Ibal 121.99 mgd 9 Shah Faisal 26.93 mgd 16 Malir 51.84 mgd 18 Gadap (Central) 79.84 mgd <u>Cantonment</u> ① Manora 0.65 mgd ② Malir 25.33 mgd ③ Karachi 1.66 mgd ④ Crifton 1.47 mgd ⑤ Faisal 11.41 mgd <u>Other Authority</u> DHA 43.48 mgd <u>Other District</u> Total Demand 534.25 mgd <u>F/P</u> NEK Old 25 mgd NEK New 100 mgd COD 200 mgd K-III 100 mgd Central 130 mgd Total Production 555 mgd Remained Production 20.75 mgd	<u>Town</u> 10 Landhi 62.40 mgd 11 Korangi 68.30 mgd 17 Bin Qasim 155.34 mgd 18 Gadap (East) 14.53 mgd <u>Cantonment</u> ⑥ Korangi 5.97 mgd <u>Other Authority</u> <u>Other District</u> Thatta (as Low Water) Total Demand 306.54 mgd Grand Total of Demand 1,187.05 mgd <u>F/P</u> Gharo 20 mgd Pipri 100 mgd East 260 mgd Total Production 380 mgd Grand Total of Production 1,270 mgd Remained Production 73.46 mgd



source: Karachi Strategic Development Plan 2020 (Final, August 2007)

Figure 77.1.1 Future Land Use in 2025




Figure 77.1.2 Karachi Contour Map




Figure 77.1.3 Proposed Water Supply System in 2025




Figure 77.1.4 Flow Diagram of Proposed System in 2025

7.7.2 Network Analysis

(1) Conditions of Network Analysis

1) Formula for Hydraulic Calculation: Hazen-Williams Formula

There are a number of formulae available to calculate the velocity of flow (e.g. Hazen-Williams formula, Manning's formula, Darcy-Weisbach's formula and Colebrook-White formula). The Hazen-Williams formula is the best for situations involving pressure conduits. The formula is:

$$V = 0.84935 C R^{0.63} I^{0.54}$$

For circular conduits, the formula is restated as

$$hf = 10.666 C^{-1.85} D^{-4.87} Q^{1.85} L$$

Where,

- V = Velocity (m/s)
- C = Hazen-Williams coefficient
- R = Hydraulic Radius (m)
- I = Hydraulic Gradient, hf/L
- hf = Friction Head Loss (m)
- D = Diameter of Pipe (m)
- Q = Discharge (m³/s)
- L = Pipe Length (m)

For confirmation, Darcy-Weisbach's formula with a friction factor of $e=0.45\text{mm}$ which is calculated with Colebrook-White formula was also used for checking hydraulic analysis. There was no much difference between the results. Therefore, the Hazen-Williams formula has been adopted for this study.

2) Hazen-Williams Coefficient (C Value): 110 for all materials

The Hazen-Williams coefficient (C value) for new pipes made from cast iron, ductile iron or mild steel with cement mortar lining may be between 130 and 145. However, it is generally recommended that in the absence of specific data, a C value of 110 should be adopted. Therefore, a C value of 110 was adopted when designing the transmission and distribution system, including the existing pipelines.

3) Hourly Peak Factor: 1.5

When designing the distribution system hourly demand fluctuations must be considered. For example, during the night people use less water, but in the morning and evening people use much more water. Because of absence of flow data for determining current hourly peak factor in Karachi, a peak factor of 1.5 was adopted referring to "Feasibility Study for future expansion of Karachi Water Supply System, December 1985". It is, however, difficult to review the time factor of 1.5 because water flow has not been measured properly.

4) Minimum Dynamic Water Pressure: 10 m

A minimum pressure of 10 m in the distribution system has been adopted under peak flow conditions. This will provide sufficient pressure for 2 or 3 storey house.

5) Details of the Existing Water Supply System

It should be noted that since there is no recorded data or drawings of the existing transmission and distribution systems or details of the reservoirs, the modelling for the hydraulic analysis was prepared based on interviews with the KW&SB's engineers, for the followings system components:

- routes, materials and diameters of transmission and trunk distribution mains; and
- locations, capacities and water level of reservoirs.

(2) Results of Network Analysis

Appendix A77.1 shows the results of the analysis in detail.

7.7.3 Transmission Pumping Stations

Proposed transmission pump stations will deliver filtered water to distribution reservoirs through transmission mains for supplying water mainly to new developing area of three fringe towns, Keamari, Bin Qasim and Gadap. These areas are relatively high altitude area where is higher than the filtration plant or almost the same altitude as the filtration plant. The proposed pumping stations for the target year of 2025 including two existing pumping stations (Manghopir PS and High Lift PS) are shown in **Table 77.3.1**.

Table 77.3.1 Proposed Transmission Pumping Station in 2025

Type	Zone	Name	Q (mgd)			Pump Head (m)
			2016	2021	2025	
Transmission Pumping Station	West	TPS-W-Mangopir	40.98	52.53	58.48	60
		TPS-W-West	-	6.69	22.07	50
	Central	TPS-C-COD	26.06	29.76	32.89	20
		TPS-C-NEK New	18.65	0.00	0.00	40
		TPS-C-Central	24.41	47.48	73.50	30
		TPS-C-High Lift	75.91	83.97	90.17	25
	East	TPS-E-East-01	-	28.67	36.93	40
		TPS-E-East-02	-	-	13.08	50
		TPS-E-E02	-	-	6.54	40

7.7.4 Water Transmission Mains

(1) Proposed Water Transmission Mains

The dimensions of proposed water transmission mains are listed in **Table 77.4.1**. **Figure 77.1.3** and **Figure 77.1.4** include the routes and flow diagram of the proposed filtered water transmission system respectively. Proposed filtered water transmission mains should not have any branches for distribution or bulk supply. Routes of transmission mains pass through mainly new developing area of three fringe towns, Keamari, Bin Qasim and Gadap. For future system, the existing water trunk mains except the trunk mains between NEK New F/P and University Reservoir and NEK Old and Manghopir P/S (NEK Hub Main) will not be used as the water transmission mains, but utilised for the trunk distribution mains. However, the water trunk mains between NEK New F/P and University Reservoir (about 16.7 km in total) are proposed to be rehabilitated and replaced, which are included in **Table 77.4.1**.

Table 77.4.1 Proposed Water Transmission Mains in 2025

Zone	Year	Dia. (in)	Length (m)
West	2016	72	141
		Sub-Total	141
	2021	36	20,364
		44	2,448
		Sub-Total	22,812
	2025	100	37,390
		Sub-Total	37,390
Zone-Total		60,343	
Central	2016	48	5,425
		56	11,348
		64	22,700
		88	9,275
		Sub-Total	48,748
	Zone-Total		48,748
East	2021	56	9,651
		100	20,364
		Sub-Total	30,015
	2025	24	2,078
		32	4,157
		Sub-Total	6,235
Zone-Total		36,250	
Total			145,341

(2) Water Management between Zones

Considering water demands in three zones, some water should be managed across zone boundaries as shown in **Figure 77.4.1**. Some water should be supplied from Zone Central to Zone West because Zone Central has enough supply capacity for its demand. On the other hand, there is no water exchange between Zone Central and Zone East.

Zone West	Zone Central	Zone East
Year 2016		
174 mgd	←	
Year 2021		
84 mgd	←	
Year 2025		
21 mgd	←	

Figure 77.4.1 Water Management between Zones

7.7.5 Distribution Reservoirs

(1) Proposed Distribution Reservoirs

Distribution reservoirs should have enough capacity to cope with water demand fluctuation in a day. In general peaks in water demand appear in the morning, at noon and in the evening. However, hourly demand fluctuation is difficult to accurately quantify because the metering system does not exist in the current system. Based on engineering experiences, the capacity of distribution reservoir is proposed to be eight hours of daily demand.

Distribution reservoirs should be located at suitable place to supply water with enough pressure of minimum 10 kgf/cm² at the end of distribution network. To monitor and control the flow, flow meters and flow control valves should be installed at the outlet pipes at the reservoirs. And chlorination equipment should be installed in the all distribution reservoirs to increase the safety of water supply.

Proposed reservoirs for 2025 are listed in the **Table 77.5.1** and supply areas of each reservoir are shown in **Figure.77.5.1**.

Table 77.5.1 Proposed Distribution Reservoirs in 2025

Zone	Res	HWL (+m)	LWL (+m)	H (m)	Req. Total V (mg)			Existing (mg)	Planned Total V (mg)			Planned New V (mg)		
					2016	2021	2025		2016	2021	2025	2016	2021	2025
West	Hub	+103.63	+99.36	4.27	42.0	45.9	47.9	15.0	48.0	48.0	48.0	33.0	0.0	0.0
	Orangi	+76.20	+71.32	4.88	0.0	0.0	20.1	6.0	0.0	0.0	20.0	0.0	0.0	20.0
	West*	+95.00	+90.00	5.00	0.0	51.7	65.7	0.0	0.0	50.0	70.0	0.0	50.0	20.0
	W01*	+125.00	+120.00	5.00	0.0	2.3	7.4	0.0	0.0	2.5	7.5	0.0	2.5	5.0
	Mangopir PS**	+64.00	+61.00	3.00	0.9	1.1	1.2	0.0	1.5	1.5	1.5	1.5	0.0	0.0
Centarl	COD	+45.72	+40.23	5.49	32.0	32.0	32.0	16.0	32.0	32.0	32.0	16.0	0.0	0.0
	NEK Old	+79.25	+74.37	4.88	76.5	57.1	61.5	10.0	76.5	76.5	76.5	66.5	0.0	0.0
	NEK New	+56.39	+51.51	4.88	45.6	45.6	45.6	10.0	46.0	46.0	46.0	36.0	0.0	0.0
	University	+67.06	+62.18	4.88	25.4	28.0	30.1	10.0	30.0	30.0	30.0	20.0	0.0	0.0
	High Service	+45.72	+40.84	4.88	8.7	9.9	11.0	20.0	11.0	11.0	11.0	0.0	0.0	0.0
	Central*	+95.00	+90.00	5.00	11.4	11.9	12.4	0.0	12.5	12.5	12.5	12.5	0.0	0.0
	C01*	+110.00	+105.00	5.00	8.2	15.9	24.6	0.0	10.0	15.0	25.0	10.0	5.0	10.0
East	Gharo	+47.24	+45.72	1.52	6.7	6.7	6.7	6.0	8.0	8.0	8.0	2.0	0.0	0.0
	Pipri	+76.20	+71.32	4.88	33.3	66.8	78.5	16.0	35.0	70.0	80.0	19.0	35.0	10.0
	East*	+95.00	+90.00	5.00	0.0	11.9	23.2	0.0	0.0	12.0	24.0	0.0	12.0	12.0
	E01*	+115.00	+110.00	5.00	0.0	9.6	12.4	0.0	0.0	12.5	12.5	0.0	12.5	0.0
	E02*	+125.00	+120.00	5.00	0.0	0.0	2.4	0.0	0.0	0.0	2.5	0.0	0.0	2.5
	E03*	+150.00	+145.00	5.00	0.0	0.0	2.2	0.0	0.0	0.0	2.5	0.0	0.0	2.5

*: new reservoirs

**.: suction well for PS




Figure 77.5.1 Proposed Supply Area from Each Reservoir in 2025

(2) Rehabilitation of the Existing Reservoirs

The Karachi Water Supply System has 16 existing distribution reservoirs including reservoirs at filtration plants, as listed in **Table 77.5.2**. Since the design life of the concrete structure is 50 years, this master plan proposes that 8 existing reservoirs constructed before 1975 will be rehabilitated by 2025. On the other hand, 4 reservoirs will be eliminated for future water supply system, since water from these reservoirs should be supplied by using distribution pumps. The area presently supplied from these reservoirs to be eliminated will be covered by other reservoirs by gravity. KW&SB are preparing to rehabilitate two reservoirs, High Service Reservoir and Orangi Reservoir. Especially, Orangi Reservoir is needed to be reconstruct at the existing site, since the existing reservoir has been destroyed.

Table 77.5.2 List of Existing Reservoirs

Name of Existing Reservoirs	Construction Year*	Need for Rehabilitation	Elimination by 2025	Need for Expansion
Gharo F/P (Plant-1)	1942	×	-	×
Pipri F/P (Plant-1)	1968	×	-	×
Pipri F/P (Plant-2)	1971	×	-	×
NEK Old F/P	1980	-	-	×
NEK New F/P	1998	-	-	×
COD F/P (Plant-1)	1962	×	-	×
COD F/P (Plant-2)	1971	×	-	×
Hub F/P	1982	-	-	×
University	1971	×	-	×
High Service	1945	×	-	-
Low Service	1942	-	×	-
Temple	1880	-	×	-
Currie	1896	-	×	-
Sydenham	1942	-	×	-
Orangi	1982	×	-	×
Kidney Hill	1978	-	-	-

*: information from KW&SB

7.7.6 Distribution Pumping Stations

In the areas where water can not be supplied by gravity flow, water should be supplied by pumping from distribution reservoirs. The capacity of distribution pumps is needed to be 1.5 times of daily demand considering the time factor of demand fluctuation.

Proposed distribution pumping stations will deliver water to customers who inhabit mainly at new developing area of three fringe towns, Keamari, Bin Qasim and Gadap. These areas are relatively high altitude area where is higher than the filtration plant or almost the same altitude as the filtration plant. The proposed pumping stations for the target year of 2025 are shown in **Table 77.6.1**.

Table 77.6.1 Proposed Distribution Pumping Station in 2025

Type	Zone	Name	Ave. Q (mgd)			Max. Q (mgd)			Pump Head (m)
			2016	2021	2025	2016	2021	2025	
Distribution Pumping Station	West	DPS-W-Orangi-Keamari	-	-	19.5	-	-	29.3	50
	Central	DPS-C-C01	-	-	21.76	-	-	32.6	50
	East	DPS-E-E03	-	-	5.01	-	-	7.5	90

On the other hand, a large number of the existing small size distribution pumping stations will be abandoned in the future system.

7.7.7 District Meter

In order to improve the efficiency of transmission and distribution system and to supply water equitably to the service area, it is necessary to understand how much water is flowed into which area. For that purpose, installation of flow meters (district meters) for transmission mains and trunk distribution mains is proposed mainly at the following locations. The number of flow meters required for the system in 2025 is listed in **Table 77.7.1**.

- Outlet of filtration plants, pumping stations and reservoirs
- Downstream of branch points of transmission and trunk distribution mains
- Boundary of towns

Table 77.7.1 Proposed District Flow Meters

Diameter (in)	Transmission Mains				Distribution Mains				Total
	West	Central	East	Sub-Total	West	Central	East	Sub-Total	
12				0		4	1	5	5
14				0	3	15	3	21	21
16				0	1		4	5	5
18				0	5	8	2	15	15
20				0		1		1	1
24			2	2	11	21	3	35	37
28				0	2	2		4	4
32			2	2	7	10	3	20	22
36	2			2	4	4	1	9	11
48		3		3	11	14	3	28	31
54				0	1	2		3	3
56		6	2	8	1	5	2	8	16
60				0		1		1	1
64		2		2		2		2	4
66				0	2	1		3	3
72	3			3	2	3	1	6	9
80				0		4		4	4
88		2		2	2	1	4	7	9
100	2		2	4	1	5		6	10
Total	7	13	8	28	53	103	27	183	211

7.8 DISTRUBUTION NETWORK AND SERVICE CONNECTION

7.8.1 Proposed Distribution Network and Service Connection

(1) Trunk Distribution Mains

The existing water trunk mains as listed in **Table 78.1.1** are proposed to be used as trunk distribution mains for future water supply system, except the trunk mains between NEK New F/P and University Reservoir and NEK Old and Manghopir P/S (NEK Hub Main) which will be used as the water transmission mains. At present KW&SB use these water trunk mains mainly as transmission mains from filtration plants to reservoirs or trunk distribution mains. In future proposed system these water trunk mains will be mainly used as trunk distribution mains from reservoirs, since they already have many brunch connections.

In addition some large diameter's pipelines of the existing distribution pipes shown in **Table 78.1.2** will be used as the trunk distribution mains.

Table 78.1.1 Existing Water Trunk Mains

Diameter		Length
in	mm	(m)
12	300	5,720
15	375	4,266
18	450	36,106
24	600	72,268
32	800	27
33	825	77,235
36	900	15,311
40	1,000	2,644
42	1,050	2,631
48	1,200	88,113
54	1,350	39,667
64	1,600	6,112
66	1,650	30,960
72	1,800	13,693
84	2,100	10,409
Total		405,163

*Source: KW&SB

Table 78.1.2 Existing Distribution Pipes

Diameter		Length
in	mm	(km)
3	75	1,636.2
4	100	1,531.9
5	125	60.0
6	150	609.0
8	200	199.0
9	225	34.6
10	250	130.6
12	300	317.0
15	375	107.1
16	400	20.1
18	450	96.8
21	525	1.0
24	600	58.1
27	675	5.2
30	750	2.5
33	825	25.2
36	900	6.3
48	1,200	8.9
54	1,350	3.0
60	1,500	2.0
Total		4,854.4

*Source: KW&SB

The proportions of PRCC pipes used in the existing water trunk mains are more than 80 %. Therefore the study recommend that the existing trunk mains to be used as the trunk distribution mains are replaced with steel pipes or ductile cast iron pipes for future system. Because in general steel pipes and ductile cast iron pipes are widely used for pressured and treated water pipeline of large diameters (300 mm and more) in other countries. PRCC has disadvantages of workability, difficulty of field modifications due to differing site conditions and difficulty of repairs for leakages and damages.

Total length of trunk distribution mains required for future water supply system in 2025 is about 1,600 km as listed in **Tables 78.1.3** and **78.1.4** including about 685 km of the existing water trunk mains and parts of large diameters of distribution mains.

Table 78.1.3 Proposed Trunk Distribution Mains (1/2)

Zone	Supply Area	Type	Year	Dia. (in)	Length (m)	Zone	Supply Area	Type	Year	Dia. (in)	Length (m)								
West	HUB	Replacement of Existing Pipeline	2016	14	11,321	West		Replacement of Existing Pipeline		12	5,680								
				16	9,949					14	24,735								
				18	15,563					16	14,914								
				24	20,925					18	62,353								
				32	26,626					24	58,754								
				36	4,249					32	35,527								
				48	25,265					36	4,260								
				64	10,363					48	55,348								
			Existing-Total						124,262	56	985								
			Installation of Proposed Pipeline	2016	18				2,967	64	10,363								
		24			5,078			Existing Zone-Total			272,918								
		32			2,039			Installation of Proposed Pipeline		14	227,491								
		36			4,014					16	10,121								
		48			84					18	22,322								
		Sub-Total			14,183					20	4,492								
		2021		14	74,028					24	28,091								
				16	2,908					28	15,676								
				18	6,323					32	5,379								
				24	4,558					36	26,398								
			Sub-Total							87,817	48	10,171							
		2025	14	27,673	56					7,911									
			18	559	64			34											
			28	1,407	72			2,951											
			Sub-Total					29,639		88	42,957								
			Proposed-Total					131,638		100	1,763								
		Area-Total			357,899			Proposed Zone-Total			405,760								
		Zone-Total			678,678														
		West	Installation of Proposed Pipeline	2025	14			91,484	East	Gharo	Installation of Proposed Pipeline	2016	88	25,151					
					18			784					-	-					
					24			1,585					Proposed-Total			25,151			
					36			452					Area-Total						
					48			2,318					Pipri	Replacement of Existing Pipeline	2025	12	5,769		
					56			14								14	43,610		
					72			753								18	12,410		
					88			32,547								24	13,062		
					Proposed-Total			129,937								32	26,203		
					Area-Total			129,937								48	25,283		
			W01	Installation of Proposed Pipeline	2016			14		10,091	56	18,791							
								32		3,328	64	5,988							
								Sub-Total			13,419	72				2,220			
	2021						14	11,999		Existing-Total						153,335			
							18	2,620		Installation of Proposed Pipeline	2021	14	8,312						
							20	4,492				18	1,266						
					24		5,683	24				4,373							
	28				3,294		48	2,138											
	Sub-Total				28,088		56	2,639											
	Proposed-Total				41,507		64	11,680											
	Area-Total			41,507	72		9,714												
	NEK Old	Replacement of Existing Pipeline	2016	14	11,018		88	13,859											
				16	4,965		Sub-Total					53,980							
				18	15,258		14	23,948											
				24	16,513		18	444											
				32	6,579		20	629											
				48	25,716		28	1,239											
				56	985		Sub-Total			26,259									
				Existing-Total			81,035	Proposed-Total			80,239								
				Installation of Proposed Pipeline	2016		16	442	Area-Total			80,239							
							18	2,870	East	Installation of Proposed Pipeline	2021	14	8,903						
		24	1,916				-	-											
		28	89				Proposed-Total					8,903							
		32	13				Area-Total					8,903							
		36	3,121				E01	Installation of Proposed Pipeline				2021	14	1,815					
		48	1,823										18	5,234					
		56	3,829										32	3,616					
		64	34										36	6,193					
		72	2,198										56	4,923					
		88	2,316	Proposed-Total									21,781						
		100	1,763	Area-Total					21,781										
	Proposed-Total			20,414	Area-Total				21,781										
	Area-Total			101,449	Area-Total				21,781										
	Orangi	Installation of Proposed Pipeline	2025	14	938				E02	Installation of Proposed Pipeline	2025		24	8,821					
				18	3,291		-	-											
				24	7,287		Proposed-Total					8,821							
				28	10,887		Area-Total					8,821							
				36	239		E03	Installation of Proposed Pipeline				2025	18	7,057					
				88	8,093								-	-					
			Proposed-Total								30,735		Proposed-Total			7,057			
			Area-Total								30,735		Area-Total			7,057			
			COD	Replacement of Existing Pipeline	2016		12	5,680				Replacement of Existing Pipeline		12	5,769				
							14	2,395						14	43,610				
	18	31,531					18	12,410											
	24	21,316					24	13,062											
	32	2,322					32	26,203											
	36	11					48	25,283											
	48	4,367					56	18,791											
	Existing-Total						67,622	64	5,988										
	Installation of Proposed Pipeline	2016					18	2,908	72	2,220									
							24	1,984	Existing Zone-Total					153,335					
				36	15,514		Installation of Proposed Pipeline		14	42,978									
				48	5,946				18	14,001									
				56	4,067				20	629									
				Sub-Total					30,420	24		13,194							
		2021		14	11,279				28	1,239									
				16	6,771				32	3,616									
				36	3,058				36	6,193									
				Sub-Total					21,107	48		2,138							
	Proposed-Total			51,527	56				7,561										
	Area-Total			119,149	64				11,680										
					72		9,714												
					88		39,010												
				Proposed Zone-Total			151,951												
				Zone-Total			305,286												

Table 78.1.4 Proposed Trunk Distribution Mains (2/2)

Zone	Supply Area	Type	Year	Dia. (in)	Length (m)	Zone	Supply Area	Type	Year	Dia. (in)	Length (m)			
Central	NEK Old	Replacement of Existing Pipeline	2021	14	2,116	Central	C01	Installation of Proposed Pipeline	2016	18	17,207			
				18	35,771					24	8,831			
				24	8,064					28	3,267			
				32	7,200					48	19,212			
				36	12,170					56	3,623			
				56	3,666					64	5,766			
			64	4,177	Sub-Total				57,907					
			Existing-Total						73,164			2021	14	16,490
			Installation of Proposed Pipeline	2016	18				12,457	18	4,507			
					24				3,390	20	1,104			
					32				9,033	24	3,140			
					36				1,959	28	1,293			
		48			1,747			32	8,309					
		56			1,972			44	2,728					
		72		2,193	Sub-Total			37,570						
		80		975	2025			14	18,854					
		100		17,994				36	8,619					
		Sub-Total		51,720				Sub-Total	27,473					
		2021		14				20,284	Proposed-Total		122,949			
				18				2,635	Area-Total		122,949			
			24	2,477				Replacement of Existing Pipeline	12	10,698				
			36	1,759	14				17,237					
			48	8,429	16				3,468					
			Sub-Total	35,584	18				70,066					
		2025	14	23,841	20				2,579					
			Sub-Total	23,841	24				68,337					
			Proposed-Total		111,144				28	4,423				
		Area-Total			184,309				32	27,047				
		COD	Replacement of Existing Pipeline	2021	12				9,615	36	14,287			
					14				10,029	48	20,610			
					18				21,847	56	8,473			
					20				2,579	60	1,666			
					24			42,290	64	8,839				
					28			4,423	72	1,278				
					32			12,974	Existing Zone-Total		259,008			
					36			1,915	Installation of Proposed Pipeline	14	102,147			
					48			11,496		16	10,399			
					56			4,806		18	49,751			
					60			1,666		20	1,167			
					64			4,662		24	32,490			
				72	1,278			28		10,958				
				Existing-Total				129,579			32	26,689		
				Installation of Proposed Pipeline	2016			14		1,143	36	23,439		
								16		1,750	44	2,728		
								18		3,066	48	39,983		
								24		4,970	56	15,279		
								28		1,667	64	5,766		
								36	2,082	72	7,021			
	48					8,070	80	8,858						
	56					4,912	88	8,054						
	72					4,829	100	19,034						
	80					6,840	Proposed Zone-Total		363,764					
	100		1,040			Zone-Total		622,772						
	Sub-Total					40,368			TOTAL	Replacement of Existing Pipeline	12	22,147		
	2021		14	5,065	14	85,581								
			16	2,006	16	18,383								
			18	301	18	144,828								
			24	2,277	20	2,579								
			36	3,343	24	140,154								
			Sub-Total	12,992	28	4,423								
	2025		14	1,458	32	88,776								
			Sub-Total	1,458	36	18,547								
			Proposed-Total		54,817	48	101,240							
	Area-Total			184,397			56	28,249						
	University		Replacement of Existing Pipeline	2021	16	3,468	60	1,666						
					18	5,980	64	25,190						
					24	14,326	72	3,498						
					32	6,873	Existing Total	685,261						
					36	201	14	372,616						
					48	9,114	16	20,520						
				Existing-Total			39,962			18	86,074			
				Installation of Proposed Pipeline	2016	18	3,818	20		6,288				
						24	2,580	24		73,775				
						28	713	28		27,874				
						32	5,186	32		35,684				
						36	3,928	36		56,030				
		48	2,209			44	2,728							
		56	4,773			48	52,292							
		80	1,042			56	30,751							
		88	8,054			64	17,480							
		Sub-Total	32,302		72	19,686								
		2021	14		8,310	80	8,858							
			24		1,258	88	90,021							
			28	959	100	20,798								
			36	1,749	Proposed Total	921,475								
		Sub-Total	12,276	Installation of Proposed Pipeline	12	22,147								
		2025	14		5,315	14	458,198							
			18		1,170	16	38,903							
			24		565	18	230,902							
		Sub-Total	7,050		20	8,867								
		Proposed-Total			51,628			24	213,929					
		Area-Total			91,590			28	32,297					
	HSR	Replacement of Existing Pipeline	2021		12	1,084	32	124,460						
					14	5,092	36	74,577						
					18	6,469	44	2,728						
					24	3,657	48	153,532						
			Sub-Total		16,302	56	59,000							
			Installation of Proposed Pipeline	2016	14	1,388	60	1,666						
		16			6,643	64	42,670							
		18			4,591	72	23,185							
		20			63	80	8,858							
		24			3,003	88	90,021							
		28			3,060	100	20,798							
		32			4,161	Grand Total	1,606,736							
		48			316	Sub-Total			23,225					
		Proposed-Total			23,225									
		Area-Total			39,527									

(2) Distribution Network Main and Service Connection

The required length of the new distribution network main that will be installed when the supply area expands or improves was estimated from the length of the existing distribution network main and the existing number of domestic connections, giving a unit length of about 7.3 m per connection. This means 7.3 m of distribution network main is needed to provide one additional service connection. The number of domestic service connections was based on the increase in the population served.

The proposed length of distribution network mains were calculated by multiplying the number of service connections to be installed (which reflects the increase in population served) by the unit pipeline length per connection (which is 7.3 m as mentioned above). **Table 78.1.5** shows the proposed number of service connections and length of distribution network mains.


Table 78.1.5 Proposed Number of Service Connections and Length of Distribution Network Mains (incremental basis)

Year	2008	2009	2010	2011	2012	2013	2014
Distribution Network Main (km)	372.0	372.0	372.0	465.9	465.9	465.9	465.9
Number of Service Connection	66,525 (15,729)	66,525 (15,729)	66,525 (15,729)	83,322 (19,701)	83,322 (19,701)	83,322 (19,701)	83,322 (19,701)
Year	2015	2016	2017	2018	2019	2020	2021
Distribution Network Main (km)	465.9	459.5	459.5	459.5	459.5	459.5	459.5
Number of Service Connection	83,322 (19,701)	82,179 (19,430)	82,179 (19,430)	82,179 (19,430)	82,179 (19,430)	82,179 (19,430)	82,179 (19,430)
Year	2022	2023	2024	2025	Total		
Distribution Network Main (km)	459.5	459.5	459.5	459.5	8,040.6		
Number of Service Connection	82,179 (19,430)	82,179 (19,430)	82,179 (19,430)	82,179 (19,430)	1,437,976 (339,993)		

Note: Figures in parenthesis are number of non-domestic service connections.

7.8.2 Rehabilitation of Existing Distribution Network and Service Connection

For rehabilitation of the existing distribution system, the life span of the distribution network mains is estimated at about 50 years. Considering the present water supply service and materials used for distribution network mains as shown in **Figure 78.2.1**, however, it should be necessary to improve the entire present distribution network system. Material mainly used for the existing distribution system is AC pipe (about 65%). It is, therefore, proposed that the existing distribution network mains need to be improved / replaced by a distribution network improvement (DNI) town by town. On the other hand, service connections especially water meters need to be rehabilitated / replaced after at least 10 years because of those life times. It should be noted that even if new service connection is installed, water meter is not installed at area where DNI has not been implemented.



Source: Details of Length Size & Material of Existing Water Distribution Lines, Water Distribution Wing, KW&SB

Figure 78.2.1 Proportions of Materials for Distribution Network Mains

Concept of rehabilitation and replacement of the existing distribution network main and service connection are as follows.

- The existing distribution network mains will be intensively replaced by Distribution Network Improvement (DNI).
- At the same time water meters will be installed to all the existing service connections and service pipes branched from distribution network mains to customers will be also rehabilitated or replaced if necessary.
- Before the implementation of DNI water meters will not be installed not only to the existing connection but also to new connections.
- After the implementation of DNI water meters will be installed at the same time providing new service connections.
- For new residential areas to be developed especially at Keamari, Bin Qasim and Gadap Towns, water meters will be installed at the same time providing new service connections.

And the distribution network improvement (DNI) will may include;

- replacement and rehabilitation of the existing distribution network mains,
- installation of additional distribution network mains if necessary,

- replacement and rehabilitation of service pipes branched from distribution network main to customers,
- installation of water meters,
- replacement and rehabilitation of the existing trunk distribution mains (at present used as water trunk mains) for distribution network if necessary,
- construction of distribution reservoirs if necessary,
- installation of district/sub-district meters, and
- leakage control including leakage survey.

Table 78.2.1 and **Figure 78.2.2** show an implementation schedule of DNI. DNI of towns in zone west is prioritised and proposed to be implemented at stage I from 2012 to 2016 just after the completion of construction of proposed Central F/P (130 mgd). Prioritization of DNI is based on present water supply condition, service ratio, income level of customers and magnitude of the existing distribution network mains.

Table 78.2.1 Implementation Schedule of DNI

No.	Town	Implementation Schedule of DNI													
		2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
Stage		Stage I, Phase 2			Stage I, Phase 3			Stage II, Phase 2			Stage II, Phase 3			Stage III, Phase 2	
1	Keamari														
	Zone West														
	Zone Central														
2	SITE														
3	Baldia														
4	Orangi														
5	Lyari														
6	Saddar														
7	Jamshed														
8	Gulshan-e-Iqbal														
9	Shah Faisal														
10	Landhi														
11	Korangi														
12	North Nazimabad														
13	New Karachi														
14	Gulberg														
15	Liaquatabad														
16	Malir														
17	Bin Qasim														
18	Gadap														
	Zone West														
	Zone Central														
	Zone East														




Figure 78.2.2 Implementation Schedule of DNI

Table 78.2.2 shows the number of service connections and length of distribution network mains which will be rehabilitated or replaced during DNI including installation of water meters to the existing service connections. Number of service connection includes the following two kinds of connections;

- existing connections as of 2005
- new connections from 2006 to the commencement of DNI, since before the DNI water meters will not be installed even to new connections

Table 78.2.2 Rehabilitation/Replacement of Service Connections and Distribution Network Mains by DNI (incremental basis)

Year	2008	2009	2010	2011	2012	2013	2014
Distribution Network Main (km)	-	-	-	-	273.9	547.9	570.5
Number of Service Connection	-	-	-	-	54,266 (13,060)	108,532 (26,119)	121,479 (26,705)
Year	2015	2016	2017	2018	2019	2020	2021
Distribution Network Main (km)	593.1	593.1	438.6	877.2	701.6	526.0	526.0
Number of Service Connection	134,426 (27,291)	134,426 (27,291)	115,170 (23,393)	230,340 (46,786)	179,773 (45,757)	129,206 (44,727)	129,206 (44,727)
Year	2022	2023	2024	2025	Total		
Distribution Network Main (km)	97.3	194.7	194.7	194.7	6,329.0		
Number of Service Connection	40,439 (8,164)	80,878 (16,329)	80,878 (16,329)	80,878 (16,329)	1,619,897 (383,006)		

Note: Figures in parenthesis are number of non-domestic service connections.

Table 78.2.3 shows the number of service connections which will be replaced after 10 years and length of distribution network mains which will be rehabilitated as the routine works including repairs of leakage.

Table 78.2.3 Rehabilitation/Replacement of Service Connections and Distribution Network Mains by other than DNI (incremental basis)

Year	2008	2009	2010	2011	2012	2013	2014
Distribution Network Main (km)	69.9	77.4	84.8	92.2	87.1	96.4	91.9
Number of Water meter	-	-	-	-	-	-	-
Year	2015	2016	2017	2018	2019	2020	2021
Distribution Network Main (km)	123.2	132.5	156.9	166.1	170.4	214.7	223.9
Number of Water meter	-	26,612 (6,292)	26,612 (6,292)	26,612 (6,292)	26,612 (6,292)	26,612 (6,292)	37,734 (8,922)
Year	2022	2023	2024	2025	Total		
Distribution Network Main (km)	251.9	261.1	270.3	279.5	2,850.1		
Number of Water meter	95,637 (22,841)	149,903 (35,901)	174,411 (39,220)	187,358 (39,806)	778,103 (178,150)		

Note: Figures in parenthesis are number of non-domestic service connections.

7.9 SUMMARY OF PLANNING

Tables 79.1.1 and **79.1.2** present a summary of improvement works included in the master plan for the Karachi Water Supply System which are briefly itemised below. **Table 79.1.1** shows the components for bulk water supply system by stages and **Table 79.1.2** shows the components of retail water supply system by zones.

Stage I (2009-2016):

1. Development of Bulk Water Supply System (additional capacity of 130 mgd) including;
 - a. Construction of Bulk Water Canal/Conduit (260 mgd),
 - b. Construction of 2 Bulk Pumping Stations,
 - c. Construction of 3 Filtration Plants of K-III (100 mgd), COD (85 mgd) and K-IV Central (130 mgd),
 - d. Construction of 3 Transmission Pumping Stations,
 - e. Expansion of Pump Capacity of 2 Transmission Pumping Stations,
 - f. Installation of Transmission Mains of 32 km,
 - g. Construction of 2 Distribution Reservoirs and
 - h. Expansion of 7 Distribution Reservoirs.
2. Improvement of Existing Distribution Network System of Zone West (DNI)
 - a. North Nazimabad, Gulberg, Liaquatabad (2012-2014)
 - b. Keamari, SITE, Baldia, Orangi, New Karachi, Gadap (2014-2016)
3. Development of New Distribution Network System for New Residential Areas
4. Rehabilitation and Replacement of the Existing Water Supply System

Stage II (2014-2021):

1. Development of Bulk Water Supply System (additional capacity of 260 mgd) including;
 - a. Construction of Bulk Water Canal/Conduit (260 mgd),
 - b. Construction of 2 Bulk Pumping Stations,
 - c. Construction of 2 Filtration Plants of K-IV West and K-IV East (130 mgd each),
 - d. Construction of 2 Transmission Pumping Stations,
 - e. Expansion of Pump Capacity of 4 Transmission Pumping Stations,
 - f. Installation of Transmission Mains of 53 km,
 - g. Construction of 4 Distribution Reservoirs and
 - h. Expansion of 2 Distribution Reservoirs.
2. Improvement of Existing Distribution Network System of Zone Central (DNI)
 - a. Jamshed, Gulshan-e-Iqbal, Shah Faisal, Malir, Gadap (2017-2019)
 - b. Keamari, Lyari, Saddar (2019-2021)
3. Development of New Distribution Network System for New Residential Areas
4. Rehabilitation and Replacement of the Existing Water Supply System

Stage III (2019-2025):

1. Development of Bulk Water Supply System (additional capacity of 260 mgd) including;
 - a. Construction of Bulk Water Canal/Conduit (260 mgd),
 - b. Construction of 2 Bulk Pumping Stations,
 - c. Construction of 2 Filtration Plants of K-IV West and K-IV East (130 mgd each),
 - d. Construction of 2 Transmission Pumping Stations,
 - e. Expansion of Pump Capacity of 6 Transmission Pumping Stations,
 - f. Installation of Transmission Mains of 44 km,
 - g. Construction of 2 Distribution Reservoirs,
 - h. Expansion of 6 Distribution Reservoirs and
 - i. Construction of 3 Distribution Pumping Stations.
2. Improvement of Existing Distribution Network System of Zone East (DNI)
Landhi, Korangi, Bin Qasim, Gadap (2022-2025)

3. Development of New Distribution Network System for New Residential Areas

4. Rehabilitation and Replacement of the Existing Water Supply System

Table 79.1.1 Components of Bulk Water Supply System

Facility		Proposed				Rehabilitation / Replacement of Existing Facilities	
		Stage	Stage I	Stage II	Stage III		Total
		Target Year	2016	2021	2025		
		Construction	2009-2011	2014-2016	2019-2021		
Bulk Water Canal/Conduit		260 mgd	260 mgd	260 mgd	780 mgd	620 mgd	
		K-IV	K-IV	K-IV	K-IV	GK, K-II, K-III, Hub	
Bulk Pumping Station		2 P/Ss: 3.9MW, 7.1 MW	2 P/Ss: 7.8MW, 14.2 MW	2 P/Ss: 7.8MW, 14.2 MW	6 P/Ss	15 P/Ss	
		K-IV	K-IV	K-IV	K-IV	Dhabeiji × 6, Gharo × 2, Pipri × 3, NEK New × 3, Hub × 1,	
Filtration Plant		3 F/Ps: 315 mgd	2 F/Ps: 260 mgd	2 F/Ps: 260 mgd	5 F/Ps: 835 mgd	6 F/Ps: 435 mgd	
		K-III: 100 COD: 85 K-IV(C): 130	K-IV(W): 130 K-IV(E): 130	K-IV(W): 130 K-IV(E): 130	K-III: 100 COD: 85 K-IV(W): 260 K-IV(C): 130 K-IV(E): 260	Gharo: 20 Pipri: 100 COD: 115 NEK Old: 25 NEK New: 100 Hub: 75	
Transmission Pumping Station		3 P/Ss (2 P/Ss)	2 nos. (4 P/Ss)	2 nos. (6 P/Ss)	7 P/Ss	2 P/Ss	
		Central, COD, NEK New (Manghopir, High Lift)	West, East01 (Central, COD, Manghopir, High Lift)	East02, E02 (West, Central, East01, COD, Manghopir, High Lift)	West, Central, East01, East02, COD, NEK New, E02	Manghopir, High Lift	
Transmission Main		32 km	53 km	44 km	129 km	17 km	
Distribution Reservoir		2 nos. (7 nos.)	4 nos. (2 nos.)	2 nos. (6 nos.)	8 nos.	6 nos. (8 nos.)	
		Central, C01 (Hub, COD, NEK Old, NEK New, Univ., Gharo, Pipri)	West, W01, East, E01 (C01, Pipri)	E02,E03 (Orangi, West, W01, C01, Pipri, East)	Central, C01, West, W01, East, E01, E02, E03	Gharo, Pipri, COD, Univ., High S., Orangi (Gharo, Pipri, COD, NEK Old, NEK New, Hub, Univ., Orangi)	
Distribution Pumping Station		-	-	3 P/Ss	3 P/Ss	-	

Note: Numbers in parenthesis are expansion of capacity.

Table 79.1.2 Components of Retail Water Supply System

Facility	Zone	Proposed				Rehabilitation/ Replacement			
		West	Central	East	Total	West	Central	East	Total
Trunk Distribution Main (km)		406	364	152	922	273	259	153	685
Distribution Network Main (km)		2,539	3,152	2,349	8,041	3,751	4,208	1,220	9,179
by DNI		-	-	-	-	2,578	3,069	681	6,329
by other than DNI		-	-	-	-	1,173	1,139	539	2,850
Service Connection (×1,000)		454	564	420	1,438	1,119	900	378	2,398
by DNI		-	-	-	-	553	784	283	1,620
by other than DNI		-	-	-	-	566	116	95	778