


ガーナの保護区マップ




(出所) 林業委員会 (FC) 野生生物課 (Wildlife Division) 資料

環境保全上脆弱な地域 (Environmentally Sensitive Areas)

- 1 法律により国立公園、流域保護区、野生生物保護区、および野生生物保護区（宗教的に重要な森林を含む。）として定められた地域
- 2 潜在的に観光地としての可能性を秘めた地域
- 3 絶滅の危機に瀕している固有種の野生生物（動植物）の生息・生育地
- 4 特有の歴史的、考古学的または科学的に重要な地域
- 5 固有の文化を有するコミュニティによって伝統的に所有されている地域
- 6 自然災害に侵されている地域（自然災害の頻発地、洪水、豪雨、地震、地すべり、火山活動など）
- 7 森林火災の頻発地
- 8 限界斜面を含む丘陵地帯
- 9 もともと農地として区分された地域
- 10 帯水層への水源涵養地帯
- 11 次のいずれか又は複数に該当する水域
 - a. 家庭用水として開発された水域
 - b. 管理又は保護された水域
 - c. 野生生物や漁業資源の涵養のための水域
- 12 次のいずれか又は複数に該当するマングローブ生育地
 - a. 原始の状態で群生している地域
 - b. 主要な河川の河口に隣接する地域
 - c. 伝統的な漁場の近辺または隣接地
 - d. 海岸侵食、強風または高潮に対する自然緩衝として機能している地域

(出所) ガーナ環境評価規則別表 5

環境保護庁の組織図




CCMC – Chemical Control and Management
 IEC – Information Education and Communication
 ECE – Environmental Compliance and Enforcement
 EE – Environmental Education
 EIDM – Environmental Information and Data Management
 PA – Public Affairs

EAA – Environmental Audit and Assessment
 LCE – Legal Compliance Enforcement
 EQ – Environmental Quality
 HRD – Human Resource Development
 ID – Intersectoral Division
 MI – Manufacturing Industries

出典：EPA資料

【Example of drawing(Case Study inside Techiman City (VRA Techiman Office))】

<Site 1>
 Substation : Techiman
 Feeder : 26F1B (11kV)




Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal

<Site 1>

Substation : Techiman

Feeder : 26F1B (11kV)

Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal




<Site 1>

Substation : Techiman

Feeder : 26F1B (11kV)

Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal




<Site 2>

Substation : Techiman

Feeder : 26F2B (11kV)

Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal




<Site 2>

Substation : Techiman

Feeder : 26F2B (11kV)

Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal



<Cost Estimation>

Site	Installation of Facilities	Removal of Facilities	Total Cost (US\$)
<Site 1> Substation : Techiman Feeder : 26F1B(11kV)	120mm ² AAC (without pole construction) 25.5km 50mm ² AAC (without pole construction) 0.5km $5,106.24(\text{US\$/km}) \times 25.5(\text{km})$ $+3,969.34(\text{US\$/km}) \times 0.5(\text{km})$ $=132,193.8(\text{US\$})$	50mm ² AAC (without pole construction) 25.5km 25mm ² AAC (without pole construction) 0.5km $1,075.11(\text{US\$/km}) \times 25.5(\text{km})$ $1,075.11(\text{US\$/km}) \times 0.5(\text{km})$ $=27,952.86(\text{US\$})$	160,147
<Site 2> Substation: Techiman Feeder: 26F2B(11kV)	120mm ² AAC (without pole construction) 7.2km $5,106.24(\text{US\$/km}) \times 7.2(\text{km})$ $=36,764.93(\text{US\$})$	50mm ² AAC (without pole construction) 7.2km $1,075.11(\text{US\$/km}) \times 7.2(\text{km})$ $=7,740.792(\text{US\$})$	44,506

【Example of drawing (Case Study at Accra East (Greater Accra))】

Substation : Y Baatsona
Feeder : Y11 Spintex

120 / 240 mm² Al - 3km

120 / 240 mm² Al - 6 km

120 / 240 mm² Al - 3km

Motor Way

添-96

Y Baatsona Substation



First take-off point

Ghana Cylinder Factory

Goil



double-T-off point

Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal

<Cost Estimation>

Site	Installation of Facilities	Removal of Facilities	Total Cost (US\$)
<p><Site 1> Substation : Baatsona Feeder : Y11 Spintex</p>	<p>240mm² AAC (without pole construction) 12km 7,111.92(US\$/km) x 12(km) =85343.0(US\$)</p>	<p>120mm² Cu (without pole construction) 12km 1,117.87(US\$/km) x 12(km) =13,414.4(US\$)</p>	<p>98,757</p>

【Example of drawing (Case Study at Accra East (Greater Accra))】

Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal

Substation : V Dansoman
 Feeder : V10


V Dansoman Substation



Candidate site for the new substation



A242 Distribution transformer



<Cost Estimation>


Site	Installation of Facilities	Removal of Facilities	Total Cost (US\$)
<p><Site 1> Substation : V Dansoman Feeder : V10</p>	<p>2 × 20/26MVA Substation 33/11kV (outdoor) 120mm² Cu XLPE 1km 2,500,000(US\$) x 1(place) +32,913.2(US\$/km) x 1(km) =2,532,913(US\$)</p>	<p>nothing</p>	<p>2,532,913</p>

【Example of drawing(Case Study at Konongo Area(Ashanti-East Region)】

Substation : Konongo
Feeder : Konongo(11kV)

Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal

Adumkrom (200) Name of the unelectrified village (Estimated Population)



<Cost Estimation>

Site	Installation of Facilities	Removal of Facilities	Total Cost (US\$)
Substation : Obuasi Substation Feeder : 12F4 (11kV)	<p>120mm² AAC (with pole construction) 49.2km</p> <p>50mm² AAC (with pole construction) 26.8km</p> <p>25,168.65(US\$/km) x 49.2(km) + 23,262.31(US\$/km) x 26.8(km) =1,861,727(US\$)</p>	/	1,861,727


【Example of drawing(Case Study at Nsuta&Manpong Area(Ashanti-East Region)】

<Site 1>

Substation : Agona


Feeder : Nsuta (33kV)

Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal




<Site 2>
Substation : Nsuta
Feeder : Nsuta (11kV)

Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal



<Site 3>
Substation : Nsuta
Feeder : Nsuta (11kV)



<Cost Estimation>

Site	Installation of Facilities	Removal of Facilities	Total Cost (US\$)
<Site 1> Substation : Agona Feeder : Nsuta (33kV)	35 mm ² AAC (without pole construction) 4.6km 3,969.34(US\$/km) x 4.6(km) = 18,258.96(US\$)	16 mm ² AAC (without pole construction) 4.6km 1,075.11(US\$/km) x 4.6(km) = 4,945.5(US\$)	23,204
<Site 2> Substation : Nsuta Feeder : Nsuta (11kV)	35 mm ² AAC (without pole construction) 3.6km 3,969.34(US\$/km) x 3.6(km) = 14,289.6(US\$)	16 mm ² AAC (without pole construction) 3.6km 1,075.11(US\$/km) x 3.6(km) = 3,870.4(US\$)	18,160
<Site 3> Substation : Nsuta Feeder : Nsuta (11kV)	120mm ² AAC (without pole construction) 6.3km 5,106.24(US\$/km) x 6.3(km) = 32,169.3(US\$)	16 mm ² AAC (without pole construction) 6.3km 1,075.11(US\$/km) x 6.3(km) = 6,773.2(US\$)	38,943

【Example of drawing(Case Study at Manso Nkwanta Area(Ashanti-West Region)】


Substation : MAIN B Substation

Feeder : Manso Nkwanta Feeder(33kV)


Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal

Adumkrom
 (200)

↳ Name of the unelectrified village
 (Estimated Population)



<Cost Estimation>


Site	Installation of Facilities	Removal of Facilities	Total Cost (US\$)
Substation : Obuasi Substation Feeder : 12F4 (11kV)	120mm ² AAC (with pole construction) 4.9km 25,168.65(US\$/km) x 4.9(km) =123,326.4(US\$)		123,326


【Example of drawing(Case Study at Bekwai, Obuasi Area(Ashanti-West Region)】

Substation : Bekwai Substation(from MAIN D Substation)

Feeder : KOKOFU Feeder(11kV)


Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal

Adumkrom
 (200)  Name of the unelectrified village
 (Estimated Population)



Substation : Obuasi Substation
Feeder : 12F4 (11kV)

Underground cables are along the road in direct buried type, but they will interfere with new road construction. So 11kV over-head lines will be newly constructed and the distribution line will be re-routed.




【Example of drawing(Case Study at Bolgatanga Area (VRA Bolgatanga Office))】

<Site 1>

Substation : Bolgatanga

Feeder : 29F6B (11kV)


Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal



<Site 2>

Substation : Bolgatanga


Feeder : 29F1B (11kV)



<Site 3>

Substation : Bolgatanga

Feeder : 29F4B (11kV)



Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal


<Cost Estimation>

Site	Installation of Facilities	Removal of Facilities	Total Cost (US\$)
<Site 1> Substation : Bolgatanga Feeder : 29F6B(11kV)	120mm ² AAC (without pole construction) 8.8km 5,106.24(US\$/km) x 8.8(km) =44,934.91(US\$)	50mm ² AAC (without pole construction) 8.8km 1,075.11(US\$/km) x 8.8(km) =9,460.968(US\$)	54,396
<Site 2> Substation : Bolgatanga Feeder : 29F1B(11kV)	120mm ² AAC (without pole construction) 1.6km 5,106.24(US\$/km) x 1.6(km) =8,169.984(US\$)	50mm ² AAC (without pole construction) 1.6km 1,075.11(US\$/km) x 1.6(km) =1,720.176(US\$)	9,890
<Site 3> Substation : Bolgatanga Feeder : 29F4B(11kV)	120mm ² AAC (without pole construction) 4.0km 5,106.24(US\$/km) x 4.0(km) =20,424.96(US\$)	50mm ² AAC (without pole construction) 4.0km 1,075.11(US\$/km) x 4.0(km) =4,300.44(US\$)	24,725

【Example of drawing (Case Study at Cape Coast (Central))】

Substation : Cape Coast
Feeder : Elmina (11kV)

Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal



<Cost Estimation>

Site	Installation of Facilities	Removal of Facilities	Total Cost (US\$)
<p><Site 1> Substation : Cape Coast Feeder : Elmina (11kV)</p>	<p>2 × 20/26MVA Substation 33/11kV (outdoor) 120mm² AAC (with pole construction) 0.6km 2,500,000(US\$/km) x 1 (place) +21,323.94(US\$/km) x 0.6(km) =2,512,794 (US\$)</p>	<p>nothing</p>	<p>2,512,794</p>

【Example of drawing(Case Study at Akwatia&Asamankese Area (Eastern Region)】


<Site 1>

Substation : Akwatia


Feeder : Asamankese (11kV)

Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal

<Plan 1> Reuse of the existing line as a 33kV trunk line



<Plan 2> Newly Construction of the 33kV trunk line



<Cost Estimation>

Site	Installation of Facilities	Removal of Facilities	Total Cost (US\$)
Substation : Akwatia Feeder : Asamankese (11kV)			
<p><Plan 1> The voltage of the section whose length is 34km is to be upgraded from 11kV to 33kV. And all transformers of this section are to be replaced to “33kV/0.4kV transformers”.</p>	<p>Insulators for 33kV, 34km 137,511(US\$)</p> <p>Transformer <33kV/0.4kV> 500kVA : 2 315kVA : 1 200kVA : 3 100kVA : 5 50kVA : 2 25kVA : 1 265,217(US\$)</p> <p>33kV/11kV Substation (5MVA) 1,000,000(US\$)</p> <p>120mm² AAC (with pole construction), 3.5km 25,168.65(US\$/km)x3.5(km) =88,089</p> <p>MV switchgear for 11kV 891,000</p>	<p>Transformers <11kV/0.4kV> 500kVA : 2 315kVA : 1 200kVA : 3 100kVA : 5 50kVA : 2 25kVA : 1 9,623(US\$)</p>	2,381,817
<p><Plan 2> To improve the voltage drop of existing feeder “Asamankese”, a new 33kV feeder is to be constructed from Akwatia substation to the middle point of existing 11kV Asamankese feeder. The conductor size of it is 240mm².</p> <p>The existing part of Asamankese feeder will be split on this point and be separated to 2 parts.</p> <p>The part from “Akwatia substation” to this point will be left as it is, and the other part will be a new substation that will be constructed in “the Middle part of this existing feeder” and transform 33kV from the new feeder into 11kV.</p>	<p>240 mm² AAC (with pole construction) 34km 80,500(US\$/km) x 34(km) = 2,737,000 (US\$)</p> <p>33kV/11kV Substation (5MVA) 1,000,000(US\$)</p> <p>120mm² AAC (with pole construction), 3.5km 25,168.65(US\$/km)x3.5(km) =88,089</p> <p>MV switchgear for 11kV 891,000</p>		4,716,089


【Example of drawing(Case Study at Keta(Volta Region)】

Substation : Anloga
Feeder : Keta(11kV)

Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal

New line constructed by MOE as rural electrification (Voltage drop was not considered before and after construction!)

This part passes over the pond with salt water, so the route should be changed. (Some poles are planned to be newly constructed along this road.)



<Cost Estimation>



Site	Installation of Facilities	Removal of Facilities	Total Cost (US\$)
<Site 1> Substation : Techiman Feeder : 26F1B(11kV)	120mm ² AAC (without pole construction) 20.4km 120mm ² AAC (with pole construction) 0.5km 5,106.24(US\$/km) x 20.4(km) +25,168.28(US\$/km) x 0.5(km) =104,167.3(US\$)	70mm ² Cu (without pole construction) 2.4km 35mm ² Cu (without pole construction) 14.9km 16mm ² Cu (without pole construction) 3.5km 1,117.87(US\$/km) x 2.4(km) 1,075.11(US\$/km) x 14.9(km) 1,075.11(US\$/km) x 3.5(km) =22,464.3(US\$)	116,752

【Example of drawing(Case Study at Sunyani Office Area (VRA-NED))】


Substation : Sunyani Substation
Feeder : Mim/Goaso/Hwidie (34.5kV)

<Unconnected section -1>

Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal




Coupled switchgear should be installed in this section which will be normally opened.



<Unconnected section -2>

Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal




<Cost Estimation>

Site	Installation of Facilities	Removal of Facilities	Total Cost (US\$)
Substation : Sunyani Substation Feeder : Mim/Goaso/Hwidie (34.5kV)	120mm ² AAC (with pole construction) 9.8km 25,168.65(US\$/km) x 9.8(km) =246,652.8(US\$)	/	246,653

【Example of drawing(Case Study at Sunyani)】

Substation : Sunyani
Feeder : SunyaniF8 (27F8B)

Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal




<Cost Estimation>

Site	Installation of Facilities	Removal of Facilities	Total Cost (US\$)
<p><Site 1> Substation : Main B Feeder : Circuit 5</p>	<p>100 mm² AAC (without pole construction) 18.3km</p> <p>5,106.24(US\$/km) x 18.3(km) =93,444.2(US\$)</p>	<p>35 mm² AAC (without pole construction) 4.5km</p> <p>50 mm² AAC (without pole construction) 0.3km</p> <p>70 mm² AAC (without pole construction) 13.5km</p> <p>1,075.11(US\$/km) x 4.5(km) 1,075.11(US\$/km) x 0.3(km) 1,075.11(US\$/km) x 13.5(km) =19,674.5(US\$)</p>	<p>113,119</p>

【Example of drawing(Case Study at Tamale (Northern Region))】

Substation : Tamale
Feeder : DALUN(28F1Y)




Installation of
a New Transformer
20MVA (additional)

(*) 100mm² AAC line (34.5kV) will be newly constructed from Tamale Substation to “Dalun – Airport T-off” to reinforce the capability of sending power of this feeder. As a result, this section will have 2 circuits on the same supporting structures. (New line can be constructed on existing iron towers.)

<Cost Estimation>

Site	Installation of Facilities	Removal of Facilities	Total Cost (US\$)
Substation : Tamale Feeder : DALUN (28F1Y) [34.5kV]			
<Route 1>	<p>100mm² AAC (with pole construction) 18.5km</p> <p>100mm² AAC (without pole construction) 11km</p> <p>1,000kVA Transformer (34.5kV/0.4kV) : 15 (Estimated total demand is 15MVA, so it is assumed that 15 transformers (34.5kV/0.4kV) with 1,000kVA should be installed.)</p> <p>+ Additionally, they need land leveling cost near the sugarcane.</p> <p>25,168.65(US\$/km) x 18.5(km) = 276,855(US\$) 5,106.24(US\$/km) x 11(km) = 91,912(US\$) 61,261.1(US\$/No.) x 15 = 918,917(US\$)</p>		<p>1,287,684 + Land Leveling Cost</p>
<Route 2>	<p>100mm² AAC (with pole construction) 33.3km</p> <p>100mm² AAC (without pole construction) 7.2km</p> <p>1,000kVA Transformer (34.5kV/0.4kV) : 15 (Estimated total demand is 15MVA, so it is assumed that 15 transformers (34.5kV/0.4kV) with 1,000kVA should be installed.)</p> <p>25,168.65(US\$/km) x 33.3(km) = 838,116(US\$) 5,106.24(US\$/km) x 7.2(km) = 36,765(US\$) 61,261.1(US\$/No.) x 15 = 918,917(US\$)</p>	<p>50mm² AAC (without pole construction) 7.2km</p> <p>1,075.11(US\$/km) x 7.2(km) = 7,741 (US\$)</p>	<p>1,801,538</p>

【Example of drawing (Case Study at Tema (Greater Accra)】




<Cost Estimation>

Site	Installation of Facilities	Removal of Facilities	Total Cost (US\$)
<p><Site 1> Substation : Steel Works Feeder : Steel Works (11kV)</p>	<p>1x20MVA Substation (outdoor) 120mm² AAC (with pole construction) 8.5km 2,500,000(US\$/km) x 1 (place) +21,323.94(US\$/km) x 8.5(km) =2,681,253(US\$)</p>	<p>nothing</p>	<p>2,681,253</p>

【Example of drawing(Case Study at Western Area (ECG Western Regional Office))】

<Site 1>
Substation : Main B
Feeder : Circuit 5


Black : Existing(Remain)
Red : Installation or Replacement
Blue : Removal



<Site 2>

Substation : Main C

Feeder : C08




To improve the voltage drop of existing feeder “C08”, a new 33kV feeder is to be constructed from the middle point of 33kV feeder “Circuit 5” to the city “Pretsia”. The conductor size of it is 265mm².

The existing part of “C08” will be split on “Pretsia” and be separated to 2 parts. The part from “Main C” to “Pretsia” will be left as it is, and the other part (from “Pretsia” to the end) will be connected to a new substation that will be constructed in “Pretsia” and transform 33kV from the new feeder into 11kV.

<Site 3>

Substation : Main A

Feeder : A55 (11kV)



To improve the overload current and the voltage drop of existing feeder “A55 (11kV)”, the existing cable (185mm² Al XLPE, 0.4km) should be replaced to 240mm² Cu ALPE, and the existing overhead line (150mm² AAC, 7.6km) should be replaced to 265mm² AAC. The supporting structures of the replaced section are all pylons that can endure the mechanical strengths of 265mm² AAC conductor, so it is not necessary to replace the supporting structure. Only conductors are to be replaced.

<Cost Estimation>

Site	Installation of Facilities	Removal of Facilities	Total Cost (US\$)
<Site 1> Substation : Main B Feeder : Circuit 5	<p>265 mm² AAC (with pole construction) 6.2km</p> <p>265 mm² AAC (without pole construction) 2.1km</p> <p>80,500(US\$/km) x 6.2(km) +17,500(US\$/km) x 2.1(km) = 535,850 (US\$)</p>	<p>120 mm² AAC 8.3km</p> <p>117.87(US\$/km) x 8.3(km) = 978(US\$)</p>	536,828
<Site 2> Substation : Main C Feeder : C08	<p>265 mm² AAC (with pole construction) 6.6km</p> <p>33kV/11kV Substation (5MVA)</p> <p>80,500(US\$/km) x 6.6(km) +1,000,000 = 1,531,300 (US\$)</p>	/	1,531,300
<Site 3> Substation : Main A Feeder : A55	<p>240mm² Cu Cable 0.4km</p> <p>240mm² AAC 7.6km</p> <p>64,181.33(US\$/km) x 0.4(km) +7,111.97(US\$/km) x 7.6(km) =79,724 (US\$)</p>	<p>185mm² Al XLPE Cable 0.4km</p> <p>150mm² AAC 7.6km</p> <p>5,058.02(US\$/km) x 0.4(km) +117.878(US\$/km) x 7.6(km) =2,919(US\$)</p>	82,643

