

APPENDIX—2 TECHNOLOGY TRANSFER SEMINAR

Technology Transfer Seminar

1. Selection of Technology Transfer Seminar

The technology transfer seminar will be conducted in accordance with the requests from the counterpart as follows. Contents of the seminar will be based on discussion with counterpart in the first trip finally. Technology transfer seminar was carried out at PJB Head Office in Surabaya at same period of 2nd workshop.

- 1) Design of transmission and substation including insulation, lightning and pollution for improving reliability
- 2) Method of voltage control and system protection
- 3) Advanced and efficient technologies on transmission and substation facilities including maintenance technology

2. Technology Transfer Program

Technology Transfer Program (Draft) 1st Day

Date: 27 August 2008 at 10:00 AM.
Place: PJB Head Office
Subject: Technology Transfer (Substation and Transmission)

Time	Content	Presenter
10:00 - 10:20	Coffee Time	
10:20 - 12:00	Technology Transfer "Design of Transmission and Substation"	Mr. Manabe Mr. Maruoka
12:00 - 12:30	Question and Answer	
12:30 - 13:30	Lunch	
13:30 - 15:00	Technology Transfer "Advanced and efficient technologies of Transmission and Substation equipment"	Mr. Manabe Mr. Maruoka
15:00 - 15:20	Question and Answer	
15:20 - 15:30	Questionnaire to Audience	

Technology Transfer Program (Draft) 2nd Day

Date: 28 August 2008 at 9:00 AM.
Place: PJB Head Office
Subject: Technology Transfer (System Operation)

Time	Content	Presenter
09:10 - 11:10	Technology Transfer : System Operation	Mr. Koyama
11:10 - 11:40	Question and Answer	
11:40 - 11:50	Questionnaire to Audience	
11:50 - 12:00	Closing Speech by JICA	Mr. Yamaoka
12:00 - 13:00	Lunch	

In this content, it was concrete method to measures to describe in "Clause 5.5 improvement of system operation".

The outline of technology transfer seminar is indicated as Table 1.

Table1 Contents of Technology Transfer Seminar

<p>1. Contents of Technology Transfer Seminar (Substation and Transmission)</p> <p>1.1 Insulation Design</p> <ol style="list-style-type: none">1) Classification of the over voltages and overview of design against them<ul style="list-style-type: none">• External over voltage: Lightning surge• Internal over voltage: Switching surge and sustained over voltage2) Determination of the number of insulators<ul style="list-style-type: none">• The number of insulators should be determined based on the over voltages in consideration of pollution level and horn gap.3) Protection design of lightning surge<ul style="list-style-type: none">• Reduction of shield angle of overhead ground wire• Multiple ground wire• Reduction of grounding resistance• Differential insulation4) Protection design against pollution<ul style="list-style-type: none">• Classification of pollution and salt deposit density• Flashover characteristics of polluted insulator• Countermeasures against pollution5) Insulation coordination among substation and transmission line<ul style="list-style-type: none">• Insulation level of transmission line at the first tower from substation

- 6) Insulation coordination at substations with surge arresters
 - Adequate layout of the surge arresters to protect equipment in substations

1.2 Advanced and Efficient Technologies of Transmission and Substation Equipment

- 1) Gas Insulated Switchgear (GIS)
 - Reduction of the site area for substations
 - Reduction of maintenance cost
- 2) Life assessment of substation equipment
 - Proper estimation of deterioration and time of replacement
- 3) Advanced monitoring and control system
 - Advanced monitoring and control system with LAN system
- 4) Conductor with reduced wind load and conductor with bulk capacity
 - Reduction of wind load and weight of support towers
 - Introduction of the conductor with bulk capacity
- 5) Lightning Protection Devices for Transmission Line
 - Equipments to reduce outage by lightning such as Line arresters and Active Horns

2. Contents of technical transfer seminar (System Operation)

- 1) Introduction of Past Large Scale Power Outages in KANSAI
 - Miboro Fault, Great Hanshin-Awaji Earthquake, Ohi Bulk Systems Fault
- 2) Fault Extension Protection Relays
 - Classification of typical protection relays (Fault extension protection, Fault clearance protection etc.)
 - Objectives of fault extension protection relays
- 3) Voltage Operations
 - Classification of typical voltage operations (Tapped control operation, Reactive supply equipment operation etc.)
- 4) Reactive Supply Equipment
 - Classification of typical reactive supply equipment (Static capacitor, Shunt reactor, Static Var Generator etc.)
 - Planning and operation of reactive supply equipment
- 5) DC Facilities
 - Introduction of HVDC (High Voltage Direct Current) facilities in KANSAI
- 6) Pumped-storage Power Stations
 - Roles of pumped-storage power stations in power system operation
- 7) Power System Analysis
 - Classification of typical analysis techniques
 - Analysis data management method
- 8) Optimal Hydropower Operations Considering River System
 - Hydropower operations considering river system using developed supporting systems

4. Result of the Technology Transfer Seminar

In order to confirm the "Degree of Satisfaction", "Degree of Contribution" and "Degree of Understanding", a questionnaire as shown in table-4 was handed over to each participant during the technology transfer seminar. As shown in a tabel-2, technology transfer might be assessed as successfully conducted.

Table-2 Results of questionnaire (Satisfaction and Contribution)


Topics in the seminar	Substation and Transmission (1 st day)	System Operation (2 nd day)
Degree of Satisfaction(YES)	83% (29/35)*	95% (22/23)*
Degree of Contribution(YES)	91% (31/35)*	91% (21/23)*

* (A/B): A: Number of YES, B: Number of respondents


Concerning substation and transmission (1st day), 89% of respondents could understand 50 % or more of the content. And concerning system operation (2nd day), 91% of respondents could understand 50 % or more of the content. Considering by these results, technology transfer was successfully conducted, even though the topic contains an advanced technology and performed in short period.

Table-3 Results of questionnaire (Understanding)

Topics in the Seminar	Substation and Transmission	System Operation
Date	1st day 2008/8/27	2nd day 2008/8/28
80 ~ 100 % understood	6	3
50 ~80 % understood	25	18
0~50 % understood	4	2
Number of collected questionnaires	35	23



Substation and Transmission



System Operation

■ 80 ~ 100 % understood ▨ 50 ~80 % understood ▩ 0~50 % understood

Table 2 (1/2) Result of Questionnaire for Technology Transfer Seminar(1st Day 2008.8.27)

Questionnaire Survey on Technology Transfer Seminar relating to Substation, Transmission on August 27 at PJB Head Office			
2. Technology Transfer related to Substation and Transmission			
2.1	Topics in the Seminar		
	Are you satisfied with the topics presented in the Seminar?	Yes (29)	No (6)
	If your answer is "No", what kind of topics do you expect?		
	Reactive power planning and Voltage control		
2.2	Understanding of topics		
	Do you understand the contents presented in the Seminar? Please tell us the degree of understanding.		
	80 ~ 100 % understood (6)	50 ~80 % understood (25)	0~50 % understood (4)
2.3	Contribution toward your work		
	Is this seminar useful for your work?	Yes (31)	No (3)

Table 2 (2/2) Result of Questionnaire for Technology Transfer Seminar(2nd Day 2008.8.28)

Questionnaire Survey on Technology Transfer Seminar relating to Substation, Transmission on August 28 at PJB Head Office			
2. Technology Transfer related to System Operation			
2.1	Topics in the Seminar		
	Are you satisfied with the topics presented in the Seminar?	Yes (22)	No (1)
2.2	Understanding of topics		
	Do you understand the contents presented in the Seminar? Please tell us the degree of understanding.		
	80 ~ 100 % understood (3)	50 ~80 % understood (18)	0~50 % understood (2)
2.3	Contribution toward your work		
	Is this seminar useful for your work?	Yes (21)	No (2)

5. Photo



1. PJB Head Office



2. Technology Transfer Seminar (8/27)



3. Technology Transfer Seminar (8/27)



4. Technology Transfer Seminar (8/27)



5. Technology Transfer Seminar (8/28)



6. Technology Transfer Seminar (8/28)

6. Attendance list

(a) Attendance list (8/27)

Attendant List [1 /]			
Title of Meeting: TECHNOLOGY TRANSFER SEMINAR JICA OF "THE STUDY ON OPTIMAL ELECTRIC DEVELOPMENT IN JAVA-MADURA-BALI IN THE REPUBLIC OF INDONESIA"			
Date: August.27, 2008		Place: PJB HEAD OFFICE	
Name	Position	Unit & Organization	Signature
1 T. MATSUO	JICA	JICA	<i>[Signature]</i>
2 Y. NAKAJIMA	JICA	JICA	<i>[Signature]</i>
3 Y. TANAKA	JICA	JICA	<i>[Signature]</i>
4 S. Yamazaki	Team Leader	JICA	<i>[Signature]</i>
5 H. Yamada	JICA	JICA	<i>[Signature]</i>
6 T. Kobayashi	JICA	JICA	<i>[Signature]</i>
7 K. Menabe	JICA	JICA	<i>[Signature]</i>
8 T. OHWADA	JICA	JICA	<i>[Signature]</i>
9 M. NISHIDA	JICA	JICA	<i>[Signature]</i>
10 Y. MATSUDA	JICA	JICA	<i>[Signature]</i>

Attendant List [1 /]			
Title of Meeting: TECHNOLOGY TRANSFER SEMINAR JICA OF "THE STUDY ON OPTIMAL ELECTRIC DEVELOPMENT IN JAVA-MADURA-BALI IN THE REPUBLIC OF INDONESIA"			
Date: August.27, 2008		Place: PJB HEAD OFFICE	
Name	Position	Unit & Organization	Signature
1 Y. Koyama	JICA	JICA	<i>[Signature]</i>
2 Y. Maruoka	JICA	JICA	<i>[Signature]</i>

Attendant List [3 /]			
Title of Meeting: TECHNOLOGY TRANSFER SEMINAR PLN OF "THE STUDY ON OPTIMAL ELECTRIC DEVELOPMENT IN JAVA-MADURA-BALI IN THE REPUBLIC OF INDONESIA"			
Date: August.27, 2008		Place: PJB HEAD OFFICE	
Name	Position	Unit & Organization	Signature
1 Saito	Revisi	PLN Riset	<i>[Signature]</i>
2 ERIAN MIRA	Revisi	PLN PST	<i>[Signature]</i>
3 SURJO ISNANDAR	Revisi	PST	<i>[Signature]</i>

Attendant List [1 /]			
Title of Meeting: TECHNOLOGY TRANSFER SEMINAR PJB OF "THE STUDY ON OPTIMAL ELECTRIC DEVELOPMENT IN JAVA-MADURA-BALI IN THE REPUBLIC OF INDONESIA"			
Date: August.27, 2008		Place: PJB HEAD OFFICE	
Name	Position	Unit & Organization	Signature
1 Gendawan S	AK	PJB JIB	<i>[Signature]</i>
2 AHMAD YUSUF S		PJB JIB	<i>[Signature]</i>
3 MANSUR		PJB JIB	<i>[Signature]</i>
4 Teguh Dwi		PJB JIB	<i>[Signature]</i>
5 Ari S		PJB JIB	<i>[Signature]</i>
6 SUTRISNO S		PJB JIB	<i>[Signature]</i>
7 CHIRIK ANAM		PJB JIB - KJIB	<i>[Signature]</i>
8 Suci BOSTAWATI		PJB JIB	<i>[Signature]</i>
9 Agung Welly		PJB JIB	<i>[Signature]</i>
10 Samsul		PJB JIB	<i>[Signature]</i>
11 KIRIA		PJB JIB	<i>[Signature]</i>
12 SUKHO MULYADI		PJB JIB	<i>[Signature]</i>

Attendat List [1 /]

Title of Meeting: TECHNOLOGY TRANSFER SEMINAR PJB IP			
OF "THE STUDY ON OPTIMAL ELECTRIC DEVELOPMENT IN JAVA-MADURA-BALI IN THE REPUBLIC OF INDONESIA"			
Date: August.27, 2008	Place:	PJB HEAD OFFICE	
Name	Position	Unit & Organization	Signature
1. I. E. HASARA	PT PJB UP TATON	PT PJB UP TATON	[Signature]
2. I. E. HASARA	"	"	[Signature]
3. [Signature]	PJB UP PJB	PT PJB UP PJB	[Signature]
4. [Signature]	PJB UP PJB	PT PJB UP PJB	[Signature]
5. FANDI W.F.	PT PJB UP PJB	PT PJB UP PJB	[Signature]
6. SUYANTO	PT PJB UP PJB	PT PJB UP PJB	[Signature]
7. ARIF WIRYONO	PT PJB	SD RUP	[Signature]
8. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
9. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
10. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
11. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
12. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
13. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
14. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
15. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
16. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
17. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
18. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
19. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
20. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]

Attendat List [2 /]

Title of Meeting: TECHNOLOGY TRANSFER SEMINAR PJB IP			
OF "THE STUDY ON OPTIMAL ELECTRIC DEVELOPMENT IN JAVA-MADURA-BALI IN THE REPUBLIC OF INDONESIA"			
Date: August.27, 2008	Place:	PJB HEAD OFFICE	
Name	Position	Unit & Organization	Signature
1. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
2. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
3. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
4. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
5. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
6. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
7. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
8. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
9. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
10. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
11. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
12. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
13. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
14. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
15. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
16. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]

Attendat List [1 /]

Title of Meeting: TECHNOLOGY TRANSFER SEMINAR PJB IP			
OF "THE STUDY ON OPTIMAL ELECTRIC DEVELOPMENT IN JAVA-MADURA-BALI IN THE REPUBLIC OF INDONESIA"			
Date: August.27, 2008	Place:	PJB HEAD OFFICE	
Name	Position	Unit & Organization	Signature
21. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
22. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
23. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
24. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
25. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
26. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
27. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
28. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
29. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
30. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
31. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
32. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
33. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
34. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
35. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
36. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
37. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
38. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
39. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]
40. [Signature]	PJB UP PJB	PJB UP PJB	[Signature]

(b) Attendance list (8/28)

Attendant List [1 /]			
Title of Meeting:		TECHNOLOGY TRANSFER SEMINAR OF "THE STUDY ON OPTIMAL ELECTRIC DEVELOPMENT IN JAVA-MADURA-BALI IN THE REPUBLIC OF INDONESIA"	
Date: August.28, 2008		Place: PJB HEAD OFFICE	
Name	Position	Unit & Organization	Signature
1. S. Yamacka	Team Leader	JICA	[Signature]
2. H. Yanaka	JICA	JICA	[Signature]
3. Y. NAKAJIMA	"	"	[Signature]
4. T. MATSUO	"	"	[Signature]
5. Y. Matsuda	"	"	[Signature]
6. Y. TANAKA	"	"	[Signature]
7. T. OHWADA	JICA	JICA	[Signature]
8. K. Manabe	JICA	"	[Signature]
9. Y. Maruoka	JICA	JICA	[Signature]
10. M. NISHIDA	JICA	JICA	[Signature]

Attendant List [2 /]			
Title of Meeting:		TECHNOLOGY TRANSFER SEMINAR OF "THE STUDY ON OPTIMAL ELECTRIC DEVELOPMENT IN JAVA-MADURA-BALI IN THE REPUBLIC OF INDONESIA"	
Date: August.28, 2008		Place: PJB HEAD OFFICE	
Name	Position	Unit & Organization	Signature
1. Y. Koyama	JICA	JICA	[Signature]
2. T. Kishishita	JICA	JICA	[Signature]

Attendant List [1 /]			
Title of Meeting:		TECHNOLOGY TRANSFER SEMINAR OF "THE STUDY ON OPTIMAL ELECTRIC DEVELOPMENT IN JAVA-MADURA-BALI IN THE REPUBLIC OF INDONESIA"	
Date: August.28, 2008		Place: PJB HEAD OFFICE	
Name	Position	Unit & Organization	Signature
1. Ahmad Seti		P30 JB	[Signature]
2. Ajeng Kelly			[Signature]
3. Munandar		P35 JB	[Signature]
4. Teguh Dicit		P35 JB	[Signature]
5. Chomal Anam		P35 JB	[Signature]
6. brime		P38 JB	[Signature]

Attendant List [1 /]			
Title of Meeting:		TECHNOLOGY TRANSFER SEMINAR OF "THE STUDY ON OPTIMAL ELECTRIC DEVELOPMENT IN JAVA-MADURA-BALI IN THE REPUBLIC OF INDONESIA"	
Date: August.28, 2008		Place: PJB HEAD OFFICE	
Name	Position	Unit & Organization	Signature
1. IWAN ABUNG	M.	UP BMS	[Signature]
2. RACHMAT WIDHAT	M	UP CIKATA	[Signature]
3. Adi Firmans		SINTEK	[Signature]
4. MIFTAHUL		UP MTW	[Signature]
5. Rudy F		UPHB	[Signature]
6. SUTOMO		UPHT	[Signature]
7. Redya KA		UPHT	[Signature]
8. Anik Suryana		UPHT	[Signature]
9. Irena Supangkat	VPE	UP EY	[Signature]
10. Purnima A.B	MUPGAK	PJB	[Signature]
11. Rachmanan I.	up Gant	PM	[Signature]
12. Dharma Kusana		MN KDI	[Signature]
13. Mestika R.		MT PJB	[Signature]
14. Tejo Labas	MTEK	MT PJB	[Signature]
15. A. DJATI R.	UPPTN	UP PTN	[Signature]
16. ARIF WATMAN A.	BPPOP	PJB	[Signature]
17. Wicoro Sahjono	SIB KAH	PJB	[Signature]
18. BAHYUDI	SD EOP	PJB	[Signature]
19. ADIBUS ELIANTO	SD UNAM	PJB	[Signature]
20. M. JURNI	SD UNAM	PJB	[Signature]

Attendant List [2 /]			
Title of Meeting:		TECHNOLOGY TRANSFER SEMINAR	
		PJB	
OF "THE STUDY ON OPTIMAL ELECTRIC DEVELOPMENT IN JAWA-MADURA-BALI IN THE REPUBLIC OF INDONESIA"			
Date:	August.28, 2008	Place:	PJB HEAD OFFICE
Name	Position	Unit & Organization	Signature
21	Silva	Staf	PJB
22	Pasanda Luvanto	UPB	PJB
23	Mugi Anandi	-	-
24	Elsa Wigina	SP EV	PJB
25	Soni K.	-	-
26	Wisnu Samudra	SPKON	SPKON
27	DED	SP11	SP11
28	NANUK ICB	SP KCL	-
29	Uy. Polesono	PJB	PJB
30	7377-5	SPKON	PJB
31	PUBI YUWANTORO	THE KEEPER	PJB
32	Divali	PR	-
33	Santika I	Executive	-
34	Teguh S.	SPKON	-
35	Haryo Rejoso	SPKON	PJB
36	Budi Woro	SPKON	PJB
37	Sutedo	SPKON	PJB
38	Wiberto	SPKON	PJB
39	M. Jufri A.	SPKON	PJB
40	Rahyo KA	Unit	UPIT

Attendant List [2 /]			
Title of Meeting:		TECHNOLOGY TRANSFER SEMINAR	
		PJB	
OF "THE STUDY ON OPTIMAL ELECTRIC DEVELOPMENT IN JAWA-MADURA-BALI IN THE REPUBLIC OF INDONESIA"			
Date:	August.28, 2008	Place:	PJB HEAD OFFICE
Name	Position	Unit & Organization	Signature
1	Danni Yannar	UP MKK	PJB
2	Andi Sugi	UPIT	PJB
3	Dadang W.	-	-
4	Silvandi	UPIT	PJB
5	Hedi	SPKON	-
6	Nyayu Anand	SPKON	-
7	Roni Handoyo	SPKON	-
8	Dani	ME	-
9	Manu K.	SPKON	PJB - SPKON

Attendant List [2 /]			
Title of Meeting:		TECHNOLOGY TRANSFER SEMINAR	
		PJB	
OF "THE STUDY ON OPTIMAL ELECTRIC DEVELOPMENT IN JAWA-MADURA-BALI IN THE REPUBLIC OF INDONESIA"			
Date:	August.28, 2008	Place:	PJB HEAD OFFICE
Name	Position	Unit & Organization	Signature
1	Suryanto	SPKON	PJB UP PJB
2	Andi Sugi	UPIT	PJB
3	Bambang Santoso	PT PJB	UP. Mada Tegal
4	Yan Supriyogi	PT. PJB	UP. Mada Tegal
5	Kurniawan E.W	PT. PJB	UP. Mada Tegal
6	Fandi W.	PT. PJB	UP. Mada Tegal
7	Didik M.	ENJ.	UP. CIKATA
8	Haryo Santoso	ENJ.	UP. CIKATA
9	Fandi R.	UP. PJB	-
10	I. S. Sugi	PC	UP. CIKATA
11	Mulyono R.	SPKON	PJB
12	Andi Sugi	UPIT	PJB
13	Haryo S.	UPIT	PJB
14	Alimoh Fajar R.	UPIT	PJB
15	Thammi Heger	ENJ.	UP. CIKATA
16	Haryo S.	UPIT	PJB
17	Rafsa Sangsinto A.	SPKON	PJB
18	Arifant	VPE	H.D
19	Dian A.	UPIT	PJB
20	P. Sugi	PJB	PJB

Attendant List [3 /]			
Title of Meeting:		TECHNOLOGY TRANSFER SEMINAR	
		PJB	
OF "THE STUDY ON OPTIMAL ELECTRIC DEVELOPMENT IN JAWA-MADURA-BALI IN THE REPUBLIC OF INDONESIA"			
Date:	August.28, 2008	Place:	PJB HEAD OFFICE
Name	Position	Unit & Organization	Signature
1	Haryo Sugi	Maintenance	PT. IP. UPPPT
2	Andi Sugi	UPIT	PJB
3	Co. Sugi	UPIT	PJB
4	M. MUDUDIN	OPERATION	PT. IP. UPPPT
5	ANDY CARYONO B.J	OPERATION	PT. IP. UPPPT
6	Tuhay B.	DES	PT. IP. UPPPT

Distribution material at Technology Transfer Seminar

1. Design of Transmission Line and Substation
2. Advanced and Efficient Technologies of Transmission and Substation Equipment
3. System Operation (Voltage Control and System Protection)

**APPENDIX—3 A SUMMARY OF A STUDY ON A RAILWAY
LINK PLAN FOR COAL TRANSPORTATION**

A Summary of a Study on a Railway Link Plan for Coal Transportation between Central and East Kalimantan

1. Study results of coal transportation in Kalimantan (Central – East Kalimantan)

- This study was compiled in 2005 by Nippon Koei. This study is called, Kalimantan Coal Transportation Program (KTCP). Bappenas was also involved in compiling this study.
- This study examines the economical aspect of the first stage construction priority, line section Muarathup (in Central Kalimantan) – Kalipapak (in East Kalimantan) 127 km length.
This line serves as an alternative line from the hill to the shore (line section Kalipapak – Balikpapan will be discussed later). 2 stations, 2 loading deck facilities will be built on the 127 km section.
- The calculation of the required daily train operation of the first stage is as follows :
 - The transport volume target per year is 18,5 mil ton/year
 - The operational days per year : 330 day
 - The transport volume target per day : 560,060 ton/day
 - The wagon loading capacity : 70 ton
 - Number of train wagons : 80 wagon
 - Cargo volume per train :: 5,600 ton/train
 - Number of loaded trains per day : 10 train/day
 - Train velocity : 40 km/hour
 - Travelling trip per day : 1 round trip
 - The required train : 10 train
- The rail line passes through the mining regions PKP2B and KP in Central Kalimantan and East Kalimantan until Kalipapak.
- The construction cost will reach USD 484,250,000,-. and the best funding allocation is 65,9 % by the Government and 34,1 % by the Private.
- In this study, it is recommended that the Government acts in the infrastructure development as a contribution to the Local Government whereas the Private acts as an operator in the operational stage.
- In the Nippon Koei study recommendation it is mentioned that the Local Government is expected to use this study to develop the region and to avoid the environmental impact which may arise caused by the coal transportation program. In addition to that the Government, in this case the Directorate General of Mineral, Coal and Geothermal,

should immediately inform the coal mining Contractor who is holding concession on the area in the coal transportation program in Kalimantan (KTCP), regarding the program and coordination.

2. The preliminary design study results of coal railway construction in Central Kalimantan.

- This study was compiled by Itochu Corporation – Japan in 2007
- This study examines the economical aspect of the first stage construction priority for section Pelaci (Murung Raya district – Bangkuang (South Barito district) along Barito riverbank.
- The train potential users are the existing 10 PKP2B and KP in Central Kalimantan.
- Except for coal transportation, in the future the train will be used for other commodity transportation, such as palm oil and industry commodities.
For the long term program it may be used as a public transportation in the province, cross province and cross country.
- The construction consists of 4 stages, with the following investment cost :
 - Stage I
 - Operational in 2013
 - Capacity 10 mill ton
 - Investment USD 610.2 mill
 - Stage II
 - Operational in 2015
 - Capacity 15 mill ton
 - Stage III
 - Operational in 2017
 - Capacity 20 mill ton
 - Investment USD 57.6 mill
 - Stage IV
 - Operational in 2019
 - Capacity 30 mill ton
 - Investment USD 99.5 mill

Cost sharing model as shares :

- Public USD 55 mill
- Private USD 128 mill
- Loan USD 427 mill from JBIC

REPORT
The Development Plan Progress of Coal Transportation
Infrastructure in South Sumatera

I. Preface

PT Bukit Asam Coal Mine as the Mining holder to execute the mining in Tanjung Enim region, Muara Enim District, South Sumatera Province is planning to increase the coal production from 9,6 mill T to 20 mill T.

To transport the coal from mine location to the Port in Tarahan it is required to develop the coal transportation railway to accommodate the increasing coal production capacity. The existing railway is not capable of transporting the coal with such a huge capacity.

PT Bukit Asam plans to construct the railway line from Tanjung Enim to Tarahan, which is integrated with the coal terminal and Jetty in Tarahan, Lampung province.

Currently PT Bukit Asam has performed a cooperation with China railway and PT Transpacific securindo to conduct a feasibility study on the railway line from Tanjung Enim to Tarahan as mentioned above.

The feasibility study has been compiled and is now waiting for the approval from the Transportation Department and Local Government.

II. A study on the Train Loading Station, Coal Terminal and Jetty

PT Transpacific securindo as a cooperation partner of PT Bukit Asam has been planning to lengthen the coal railway line from Tanjung Enim to Tarahan, Lampung province.

The line is expected to be operational for 20 years to transport the coal from a new reserve which amounts to 20 – 24 mill tons per year.

Construction target of the new railway line and Jetty in Tarahan

First year	:	6 million tons per year
Second year	:	10 million tons per year
Third year	:	20 million tons per year
Fourth year	:	22 million tons per year, etc.

Currently PT Bukit Asam is operating in big coal mines around Tanjung Enim.

The mine locations are connected to 2 Jettys, i.e., a small quantity Jetty in Kertapati, Palembang and a big quantity Jetty in Tarahan.

In the future the coal produced in Central Bangko mine will be transported by the train which is currently under a feasibility study. This is a matter between PT KAI and PT Bukit Asam regarding the current coal transportation capacity.

The existing mono railway line which was built during the Dutch era and was rehabilitated in 1980, has several segments with steep slope.

PT Transpacific Securindo estimated around 60 ha area in Srengsem to the North East direction of the old coal terminal will be used for constructing the new train loading facility as well as the terminal facility and shipment with a capacity of 159,000 DWT.

A summary of facilities that will be constructed

1. Train Loading Facility
 - Loading capacity : 4,400 tons per hour (for 2 times transportation with the same train)
 - Conveyor loading capacity : 2,200 tons per hour
2. Coal Terminal Facility
 - a. As the first choice related with the problem of fine and dash coal, the details of Stacking and Reclaiming System are as follows :
 - System Stacking is designed for 4,400 tons per hour and is able to receive the coal remainder from station I & II
 - Stockpile Capacity 450,000 tons – 750,000 tons
 - b. The second choice is related to the coal Blending capacity, the details of Stacking and Reclaiming System are as follows :
 - System Stacking is designed for 4,400 tons per hour and is able to receive the coal remainder from station I & II
 - Stockpile Capacity 600,000 tons, consisting of 3 stockpiles, each 200,000 tons
 - c. The ship loading system is designed for 6,000 tons per hour and is able to receive the coal from stacker/reclaimer

III.A study of Coal Railway Line

- a. Existing Railway
 - The existing railway is 411 km to Tarahan port, Lampung province
 - The management is under PT Kereta Api Indonesia
 - The tonnage of coal transported to Tarahan is 7,25 mill tons per year
 - Another railway line to Kertapati 159 km long, with the annual capacity of 1,35 mill tons per year
 - Current railway line condition is not satisfactory, and it has been renovated many times, therefore it is not suitable for coal transportation with an increasing capacity of 20 to 24 mill tons per year
- b. Construction Plan of the New Rail Line
 - This line stretches from Tanjung Enim (Central Bangko) to Tarahan (Srengsem)
 - To shorten the traveling time from Tanjung Enim to Tarahan, Tanjung Enim to Baturaja line will be built (as a shortcut)
 - The total length of a single line is 312 km with 20 stations between mine location and terminal
 - There are 24 return trips per day, 295 effective working days per year, not to mention 70 days for maintenance
 - 24 trains are required, consisting of 1 locomotive and 55 wagons. The wagon capacity is 60 tons
 - This project is a cooperation between PT Bukit Asam, China Railway and PT Transpacific Securindo
 - The capital investment cost including the land acquisition cost is USD 644,150,250, the cost for AMDAL and Basic Design is excluded
 - The total investment cost is USD 1,061,519,000
 - The project implementation schedule is as follows
 - Pre construction stage (6 months), is planned by the end of 2008

- The construction period is 36 months for a contract system with a 320 km long of railway line. It consists of 2 packages
 - : a. Srengsem - Negara Ratu
 - b. Tanjung Enim - Negara Ratu

The construction is estimated to start in mid 2009 - 2012

- Operational stage is planned to start by the end of 2012
 - Guarantee period 12 months
- The problems which are facing the railway construction are as follows
- During the construction, when the railway line crosses over the fly over between Natar and Banjar baru; which in the reality the land availability is not enough.
 - During the construction, when the railway line passes through dense housing complex such as in Kota Bumi and Martapura
 - Social issue is a dominant impact which will arise during the land acquisition process
 - Based on Lampung RUTRD, the proposed plan location of coal terminal facility is in a conservation forest, it required an intensive approach and negotiation with the Local Government.
- Regarding the above issues PT Bukit Asam has to do the following matters :
- Approach and coordination with the Lampung Province Government to find out the following information :
 1. The exact border of the conservation forest
 2. The development plan of Kota Baru Natar
 3. The highway plan between Bakauheni to Terbanggi Besar
 4. The future development plan for Srengsem region
 5. The railway line plan from Bandar Lampung to Rejosari and Bakauheni to Rejosari
 - The detailed survey involves other authorities such as : PT KAI, PT PLN, PT Telkom, PDAM to clarify the following matters :
 1. The borders of land owned by PT KAI and individuals
 2. The telecommunication, electricity and drinking water networks

APPENDIX—4 COAL SUPPLY TO PLN

KESIAPAN PASOKAN BATU BARA UNTUK PLTU



PERMASALAHAN LOGISTIK BATUBARA UNTUK PLTU

- Stock batubara di PLTU saat ini kurang dari satu bulan operasi.
- Kenaikan harga yang cepat dan hampir mencapai 100% menyulitkan untuk melakukan pengadaan jangka panjang meskipun HPS sudah disusun mengikuti harga pasar (ICI).
- Logistik yang sepenuhnya diserahkan pasar karena tidak memiliki usaha penambangan sendiri menyebabkan posisi tawar PLN dan kehandalan pasokan sangat rendah.
- Belum adanya kebijakan tentang Domestic Market Obligation (DMO) mengakibatkan PLN harus bersaing bebas dengan konsumen industri dan asing.
- Angkutan kereta api dari Tanjung Enim ke Tarahan masih single track dengan kapasitas terbatas (\pm 8,2 Juta ton).
- Jumlah perusahaan PKP2B (Perjanjian Karya Pengusahaan dan Penambangan Batubara) yang selama ini menjadi pemasok batubara ke PLTU hanya 8 dari 66 perusahaan.
- Jumlah kapal bendera Indonesia yang ada saat ini hanya 11 unit (digunakan untuk domestik dan export) sedangkan kebutuhan kapal minimal 13 unit.
- Dermaga muat yang ada lebih banyak digunakan untuk melayani export karena kebutuhan export lebih banyak dari domestik.
- Temuan BPK terhadap tingginya stock batubara menyebabkan keraguan untuk menimbun batubara dalam jumlah yang banyak.



Pengelolaan Logistik Batubara Saat Ini






No.	PLTU	KEBUTUHAN		Jangka Waktu	Volume	PASOKAN			Angkutan
		GCV	Volume			Lama Kontrak	CI/FOB		
		Kcal/Kg (ar)	per tahun	Pertahun	Tahun				
1	Suralaya	4225 - 5242	12,5 Jt	Jk. panjang Jk. menengah Jk. pendek/ spot	6,1 Jt 5 Jt 3,5 Jt	10 4 <1	CF CF CF		Kereta dan Kapal Truck, tongkang dan vessel Truck, tongkang dan vessel
2	Tanjung Jati B	5150 - 6100	4 Jt	Jk. panjang Jk. pendek	2 Jt 2 Jt	10 1	CF CF		Kapal Kapal
3	Paiton	5092 - 5242	3 Jt	Jk. menengah	2,4 Jt	4	CF		Tongkang
4	Ombilin	6585 - 6876 (adb)	631Rb	Jk. panjang Jk. menengah Spot	450 Rb 65 Rb 120 Rb	5 4 <1	CF CF CF		Truck Truck Truck
5	Bukit Asam	5178	986 Rb	Jk. Panjang	986 Rb	10	CF		Conveyor
6	Tarahan # 3 & 4	5100	706Rb	Jk. Panjang	706 Rb	25	CF		Conveyor
7	Asam-asam	3820 - 4615	650 Rb	Jk. Panjang	446 Rb	20	CF		Truck

KEBUTUHAN PEMBANGKIT & BATU BARA

No	PROYEK	TAHUN					
		2008		2009		2010	
		MW	TON	MW	TON	MW	TON
1	KEMITRAAN	-	-	1,142	4,401,725	1,142	4,401,725
2	DAERAH KRITIS	-	-	648	1,873,238	648	1,873,238
3	IPP BARU	50	192,720	250	963,600	2,620	9,720,096
4	PLN-NON PERCEPATAN	230	1,050,000	540	2,331,984	540	2,331,984
5	PLN-PERCEPATAN (JAMALI & LUAR JAMALI)	-	-	-	-	9,530	31,900,000
6	EXISTING POWER PLANT (PLN & IPP)	9,550	33,231,936	9,550	33,231,936	9,550	33,231,936
TOTAL		9,830	34,474,656	12,130	42,802,483	24,030	83,458,979

Asumsi :
 1. Perhitungan kebutuhan LRC untuk PLTU Percepatan Jawa menggunakan CF = 60% ; SFC = 0,52 Kwh/Kg dan 0,55 Kwh/Kg untuk kapasitas 300-400 MW
 2. Perhitungan kebutuhan LRC untuk PLTU Percepatan Luar Jawa menggunakan CF = 80% ; SEC heopiasi





CADANGAN BATUBARA INDONESIA

Klasifikasi Batubara	Sumber Daya Milyar ton	Cadangan Milyar ton
Kalori Rendah <5100 kcal/kg (adb)	14,95	6.962
Kalori Sedang 5100 - 6100 kcal/kg (adb)	37,65	2.443
Kalori Tinggi >6100 kcal/kg (adb)	7,97	1.229
Kalori Tinggi >7100 kcal/kg (adb)	0,672	0,124
Jumlah	61,242	6,759

Sumber data : Pusat Sumber Daya Geology th. 2005
Cadangan adalah sumberdaya yang secara teknis layak ditambang.

SPEKIFIKASI LRC

LRC UNTUK PLTU PERCEPATAN P. JAWA

Urutan	Typical	Penolakan
Gross Calorific Value kCal/kg (ar)	4200	< 4000 atau > 4500
Hardgrove Grindability Index	60	< 45 atau > 65
Total Moisture % (ar)	30	> 35
Ash Content % (ar)	5	> 6
Sodium Content % (in Ash)	1,5	> 4
Sulphur Content % (dar)	0,33	> 0,35
Nitrogen % (dar)	Max 1,2	> 1,2
Slagging dan Fouling Index	Medium	> Medium
Ukuran butiran lolos ayakan 2,38 mm	Max 20 %	> 20%
Ukuran butiran lolos ayakan 32 mm	Max 80 %	> 80%
Ukuran butiran lolos ayakan 50 mm	Min 95 %	< 95%
Ukuran butiran lolos ayakan 70 mm	100%	< 98%
Ash Fusion Temperature (DT) °C	1150	< 1100

LRC UNTUK PLTU PERCEPATAN LUAR P. JAWA

Urutan	Typical	Penolakan
Gross Calorific Value kCal/kg (ar)	4200	< 4000 atau > 4700
Hardgrove Grindability Index	60	< 50 atau > 65
Total Moisture % (ar)	30	> 40
Ash Content % (ar)	5	> 6
Sodium Content % (in Ash)	1,5	> 4
Sulphur Content % (dar)	0,33	> 0,35
Nitrogen % (dar)	Max 1,2	> 1,2
Slagging dan Fouling Index	Medium	> Medium
Ukuran butiran lolos ayakan 2,38 mm	Max 20 %	> 20%
Ukuran butiran lolos ayakan 32 mm	Max 80 %	> 80%
Ukuran butiran lolos ayakan 50 mm	Min 95 %	< 95%
Ukuran butiran lolos ayakan 70 mm	100%	< 98%
Ash Fusion Temperature (DT) °C	1150	< 1100

Keterangan :
 1) CRB Boiler, Feed Bed Boiler dan PC Boiler dengan FGD


PROGRES PENGADAAN LRC UNTUK PROYEK PLTU PERCEPATAN

- TOTAL KEBUTUHAN (35 PLTU) = 31,90 Juta Ton/tahun
- HASIL PELELANGAN = 28,49 Juta Ton/tahun
- KEKURANGAN = 3.41 Juta Ton/tahun (10,70%)

- CALON PEMASOK ADA 8 PERUSAHAAN :
 - 4 PERUSAHAAN SUDAH PRODUKSI
 - 4 PERUSAHAAN MASIH EXPLORASI
- PERIODE KONTRAK 20 THN (CIF)
- PENGIRIMAN TAHAP AWAL PADA TAHUN 2009 DENGAN HARGA DASAR, SERTA PENYESUAIAN HARGA PERUBAHAN UNTUK USD & BBI, PENYESUAIAN HARGA PERTAHUAN UNTUK INDONESIA COAL INDEX (ICI) DAN AKAN DILAKUKAN PRICE REVIEW (JIKA DIPERLUKAN).
- ASSESSMENT DUE DILIGENCE AKAN DILAKUKAN SECARA PERIODIK SETIAP 6 BULAN TERMASUK PROGRES INFRASTRUKTUR YANG AKAN DILAKUKAN OLEH PLN DENGAN KONSULTAN PT ENERGY MANAGEMENT INDONESIA (EMI) DAN POKJA BATU BARA.

PEMASOK LRC UNTUK PLTU 10.000 MW

NO	NAMA PEMASOK	STATUS	VOLUME	TAHAP PENAMBANGAN
1	PT TITAN MINING ENERGY	PKP2B	3,205,000	EXPLORASI
2	PT BARAMUTIARA PRIMA	PKP2B	2,328,000	EXPLORASI
3	KONS. PT ARUTMIN INDONESIA	KP	8,493,000	PRODUKSI
4	KONS. PT KASIH INDUSTRI	KP	3,810,000	PRODUKSI
5	PT HANSON ENERGY	KP	4,372,000	PRODUKSI
6	PT DWI GUNA LAKSANA	KP	2,945,000	PRODUKSI
7	KONS. OKTASAN BARUNA PERSADA	KP	3,056,000	PRODUKSI
8	KONS. MODAL INVESTASI MINERAL	KP	279,000	EXPLORASI
TOTAL			28,488,000	




Indonesian Coal Index Report

Weekly average ICI prices Issue 305 Friday 08 February 2008

Grade	Base	Price (USD/MT)
Indonesian 5500 Kcal	GAR	91.43
Indonesian 5800 Kcal	GAR	75.26
Indonesian 6200 Kcal	GAR	58.41

Monthly ICI averages	Nov	Dec	Jan
Indonesian 5500 Kcal	76.53	84.08	91.72
Indonesian 5800 Kcal	63.58	66.51	71.63
Indonesian 6200 Kcal	49.41	52.84	53.83



PERUSAHAAN TAMBANG PKP2B

Jumlah Perusahaan Tambang PKP2B : 66 perusahaan

dengan status :

- > 31 perusahaan sudah produksi
- > 18 perusahaan dalam tahap F/S
- > 5 perusahaan dalam tahap konstruksi
- > 12 perusahaan dalam tahap eksplorasi

Jumlah Perusahaan Tambang PKP2B yang memasok batubara ke PLN ada 8 perusahaan yaitu :


1. PT Kaltim Prima Coal
2. PT Kideco Jaya Agung
3. PT Berau Coal
4. PT Indominco Mandiri
5. PT Anugerah Bara Kaltim
6. PT Arutmin Indonesia
7. PT Adaro Indonesia
8. PT Tambang Batubara Bukit Asam

Sumber data : Indonesian Coal Book 2006/2007 dan kontrak2 PLN

Kebutuhan dan Ketersediaan Kapal dan Tongkang


Kapal

-Kebutuhan 13 unit
-Tersedia 11 unit



Tahun 2008


Kebutuhan 21 units



Tahun 2010


Tongkang

-Kebutuhan 29 unit
-Tersedia 160 unit



Tahun 2008

Kebutuhan 340 Units



Tahun 2010

Daftar Kapal Pengangkut Batubara Berbendera Indonesia

No	Nama Kapal	Ukuran	Kapasitas (ton)	Thn	Type	Pemilik
1	Dewi Umayi	Panamax	62.000	1981	Gear	Arpeni
2	Banowati	Panamax	64.000	1983	Gear	Arpeni
3	Urmilla	Panamax	63.000	1984	Gear	Arpeni
4	Suryawati	Panamax	70.000	1996	Gearless	Arpeni
5	Citrawati	Panamax	70.000	1990	Gearless	Arpeni
6	Indrani	Panamax	70.000	1986	Gearless	Arpeni
7	Mustikawati	Panamax	75.000	1981	Gearless	Arpeni
8	Victory Union	Panamax	65.000	1983	Gearless	JSK
9	Zaleha Fitrat	Handymax	43.000	1986	Gear	GLS
10	Saraswati	Handymax	24.000	1981	Gearless	Arpeni
11	Adhiguna Tarahan	Handymax	10.000	1981	Gearless	Bahtera A.

PELABUHAN MUAT BATUBARA DI INDONESIA

NO.	NAMA PELABUHAN	LOKASI	UKURAN KAPAL MAKS (DWT)	PEMAKAI
1	Tarahan	Sumatera Selatan	55,000	PT BA
2	Tanjung Bara	Kalimantan Timur	180,000	Kaltim Prima Coal
3	Samarinda / Mahakam	Kalimantan Timur	70,000	Umum
4	IBT / Pulau Laut	Kalimantan Selatan	80,000	Adaro Indonesia
5	Kota Baru / Pulau Laut	Kalimantan Selatan	150,000	Arutmin Indonesia
6	Bontang	Kalimantan Timur	90,000	Indominco Mandiri
7	Berau Offshore	Kalimantan Timur	180,000	Berau Coal
8	Benjarmasin / Taboneo	Kalimantan Selatan	170,000	Adaro dan terbuka umum
9	Baikpapan	Kalimantan Timur	80,000	Terbuka Umum
10	Adang Bay	Kalimantan Timur	120,000	Kideco Jaya Agung

- ### MONITORING TERHADAP KESIAPAN INFRASTRUKTUR
- PT BARAMUTIARA PRIMA
 - Infrastruktur belum ada
 - Pembebasan lahan sebagian kecil
 - Aliran sungai Calik terjadi sedimentasi
 - Belum ada perjanjian angkutan tongkang
 - KONS. PT ARUTMIN INDONESIA
 - Sarana Infrastruktur sudah ada & akan ditingkatkan secara bertahap
 - Angkutan batubara ke pelabuhan menggunakan konveyor
 - Saat ini pelabuhan sewa PT Cenko & PT BS, Tahun 2009 menggunakan pelabuhan sendiri
 - Crushing Plant ada 2 unit & akan ditambah 1 unit/thn
 - Kendala penambangan area di Asam-Asam tumpang tindih dengan perkebunan sawit. Area di west mulia tahun 2011 akan masuk area perkebunan sawit.
 - PT TITAN MINING ENERGY
 - Belum ada Infrastruktur yang permanen
 - Jalan angkutan menggunakan jalan profinsi
 - Belum ada perjanjian angkutan tongkang
 - KONS. PT KASIH INDUSTRI
 - Batubara akan dipasok dari KP di daerah Muba
 - Jalan angkut & pelabuhan belum ada
 - Belum ada eksplorasi detail

- ### LANGKAH-LANGKAH YANG DILAKUKAN DAN USULAN
- PLN akan segera meningkatkan stock batubara hingga posisi aman 30 hari pemakaian dan menambah porsi kontrak jangka panjang hingga 100%.
 - Perlu dukungan dari sektor yang terkait untuk mengambil kebijakan agar PKP2B ikut berpartisipasi secara penuh.
 - PLN memiliki tambang sendiri atau segera melakukan kerjasama operasi dengan pemilik tambang dan akuisisi/penyerahan modal perusahaan tambang.
 - Stock batubara di PLTU seharusnya tidak dianggap sebagai in efisiensi perusahaan karena PLTU batubara sebagai pemikul beban dasar dengan biaya bahan bakar yang murah.
 - Dibuat kebijakan tentang Domestic Market Obligation yang mengatur kewajiban pasokan, mekanisme dan insentif harga domestik. Kebutuhan dalam negeri tahun 2008 sekitar 48.47 juta ton (22.5%), tahun 2009 sekitar 58.8 juta ton (25%), tahun 2010 sekitar 107.33 juta ton (43%) harus dapat dipenuhi dengan harga yang layak untuk konsumsi domestik.
 - Pada tahun 1983-1996 Royalti batubara sebesar 13.5% dari produksi diambil pemerintah secara INKIND (dalam bentuk natura / barang). Diusulkan model seperti itu dihidupkan kembali dengan penugasan kepada anak perusahaan PLN untuk mengelola.
 - Perlu segera dibangun jalur kereta api dan coal terminal baru di Sumatera Selatan alternatif lokasi di Tanjung Api-Api (selat bangka), Kalimantan dan Jawa (diarea Suralaya dan Palton).
 - Kapal berbendera Indonesia yang ada saat ini harus didedikasikan untuk kebutuhan dalam negeri dan dalam waktu dekat harus ada tambahan 2 unit kapal Panamax.
 - Perlu sinergi atau penugasan kerjasama antar BUMN untuk angkutan batubara dan diberikan dispensasi penggunaan kapal bendera asing.

TERIMA KASIH

APPENDIX—5 OPERATION RECORD

**5.1 Operation Performance Record for
the Existing Power Plants of PJB**

**5.2 Operation Performance Record for
the Existing Power Plants of Indonesia Power**

5.1 Operation Performance Record for the Existing Power Plants of PJB

5.2 Operation Performance Record for the Existing Power Plants of Indonesia Power

Operation Performance Record for the Existing Power Plants of Indonesia Power

No.	Plant Name	Unit No.	Fuel Consumption (2007)					Heat Content of Fuel (2005)					Heat Content of Fuel (2006)					Heat Content of Fuel (2007)					Kcal Consumption (2005)				
			MFO (Ltr)	IDO (Ltr)	HSD (Ltr)	Gas (MMBTU)	Coal (Kg)	MFO (kcal/Ltr)	IDO (kcal/Ltr)	HSD (kcal/Ltr)	Gas (kcal/MMBTU)	Coal (kcal/Kg)	MFO (kcal/Ltr)	IDO (kcal/Ltr)	HSD (kcal/Ltr)	Gas (kcal/MMBTU)	Coal (kcal/Kg)	MFO (kcal/Ltr)	IDO (kcal/Ltr)	HSD (kcal/Ltr)	Gas (kcal/MMBTU)	Coal (kcal/Kg)	MFO (M.kcal)	IDO (M.kcal)	HSD (M.kcal)	Gas (M.kcal)	Coal (M.kcal)
UBP SAGULING																											
1.	SAGULING	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2.	SAGULING	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3.	SAGULING	3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4.	SAGULING	4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5.	PRK. KONDANG	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
6.	PRK. KONDANG	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
7.	PRK. KONDANG	3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
8.	PRK. KONDANG	4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
9.	BENGKOK	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
10.	BENGKOK	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
11.	BENGKOK	3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12.	BENGKOK (DAGO)	4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
13.	PLENGAN	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
14.	PLENGAN	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
15.	PLENGAN	3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
16.	PLENGAN	4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
17.	PLENGAN	5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
18.	LAMAJAN	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
19.	LAMAJAN	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20.	LAMAJAN	3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21.	CIKALONG	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
22.	CIKALONG	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
23.	CIKALONG	3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
24.	UBRUG	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
25.	UBRUG	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
26.	UBRUG	3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
27.	KRACAK	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
28.	KRACAK	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
29.	KRACAK	3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
UBP MRICA																											
29.	PB SUDIRMAN	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
30.	PB SUDIRMAN	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
31.	PB SUDIRMAN	3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
32.	KETENGER	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
33.	KETENGER	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
34.	KETENGER	3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
35.	GARUNG	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
36.	GARUNG	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
37.	WADASLINTANG	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
38.	WADASLINTANG	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
39.	JELOK	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
40.	JELOK	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
41.	JELOK	3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
42.	JELOK	4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
43.	TIM	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
44.	TIM	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
45.	TIM	3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
46.	WONOGIRI	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
47.	WONOGIRI	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
48.	KEDUNG OMO	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
49.	TAPEN	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
50.	SEMPOR	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
51.	PEJENKOLAN	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
52.	KELAMBU	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
53.	SIDOREJO	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
UBP PRIOK																											
54.	PLTU PRIOK	3	62,280,699	-	39,605	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
55.	PLTU PRIOK	4	57,675,438	-	68,640	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
56.	PLTG PRIOK	1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
57.	PLTG PRIOK	3	-	-	3,409,215	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
58.	PLTGU PRIOK	GT 11	-	-	-	9,095,668	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
59.	PLTGU PRIOK	GT 12	-	-	42,747,330	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
60.	PLTGU PRIOK	GT 13	-	-	81,888,707	5,912,169	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
61.	PLTGU PRIOK	ST 10	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
62.	PLTGU PRIOK	GT 21	-	-	54,883,198	8,460,129	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
63.	PLTGU PRIOK	GT 22	-	-	148,248,484	4,916,717	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
64.	PLTGU PRIOK	GT 23	-	-	10,354,334	4,743,562	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
65.	PLTGU PRIOK	ST 20	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
66.	PLTD KEBAYORAN	1	-	-	21,925	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
67.	PLTD KEBAYORAN	2	-	-	19,593	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
68.	PLTD KEBAYORAN	3	-	-	22,994	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
69.	PLTD KEBAYORAN	4	-	-	19,688	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
70.	PLTD KEBAYORAN	5	-	-	13,068	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
71.	PLTD KEBAYORAN	6	-	-	25,901	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
UBP SURALAYA																											
72.	PLTU SURALAYA	1	-	-	-	-	1,747,675,652	10,399	9,277	-	4,785	-	9,194	-	4,711	-	-	-	-	-	-	12,450	-	15,613	-	6,886,674	6,914,737
73.	PLTU SURALAYA	2	-	-	-	-	1,509,227,658	10,399	9,508	-	4,754	9,816	9,202	-	4,706	-	-	-	-	-	-	10,919	-	14,847	-	6,061,491	6,094,257
74.	PLTU SURALAYA	3	-	-	-	-	1,689,176,772	10,399	9,241	-	4,774	-	9,199	-	4,685	-	-	-	-	-	-	4,					

Operation Performance Record for the Existing Power Plants of Indonesia Power

No.	Plant Name	Unit No.	Av. F.O by Entity %	Av. P.O by Entity days	Prod. by Entity GWh	Av. H.R by Entity kcal/kWh	Ava.Max by Entity MW	F.C by Entity Rp/kW-m	V.C by Entity Rp/kWh	F.C by Entity \$/kW-m	V.C by Entity \$/MWh									
UBP SAGULING																				
1.	SAGULING	1	0.41	15.79	2,036	-	698.4	10,548	0.5	1.17	0.06									
2.	SAGULING	2																		
3.	SAGULING	3																		
4.	SAGULING	4																		
5.	PRK. KONDANG	1	0.22	5.68	222	-	59.4	12,773	0.3	1.42	0.03									
6.	PRK. KONDANG	2																		
7.	PRK. KONDANG	3																		
8.	PRK. KONDANG	4																		
9.	BENGKOK	1																		
10.	BENGKOK	2																		
11.	BENGKOK	3																		
12.	BENGKOK (DAGO)	4																		
13.	PLENGAN	1																		
14.	PLENGAN	2																		
15.	PLENGAN	3																		
16.	PLENGAN	4																		
17.	PLENGAN	5																		
18.	LAMAJAN	1	-	8.85	124	-	37.3	44,257	0.9	4.92	0.10									
19.	LAMAJAN	2																		
20.	LAMAJAN	3																		
21.	CIKALONG	1																		
22.	CIKALONG	2																		
23.	CIKALONG	3																		
24.	UBRUG	1																		
25.	UBRUG	2																		
26.	UBRUG	3																		
27.	KRACAK	1																		
28.	KRACAK	2																		
29.	KRACAK	3																		
UBP MRICA																				
29.	PB SUDIRMAN	1	0.01	6.49	444	-	179.4	16,189	0.5	1.80	0.06									
30.	PB SUDIRMAN	2																		
31.	PB SUDIRMAN	3																		
32.	KETENGER	1																		
33.	KETENGER	2	0.64	5.62	475	-	125.0	30,302	0.4	3.37	0.04									
34.	KETENGER	3																		
35.	GARUNG	1																		
36.	GARUNG	2																		
37.	WADASLINTANG	1																		
38.	WADASLINTANG	2																		
39.	JELOK	1																		
40.	JELOK	2																		
41.	JELOK	3																		
42.	JELOK	4																		
43.	TIM	1																		
44.	TIM	2																		
45.	TIM	3																		
46.	WONOGIRI	1																		
47.	WONOGIRI	2																		
48.	KEDUNG OMBO	1																		
49.	TAPEN	1																		
50.	SEMPOR	1																		
51.	PEJENGLAN	1																		
52.	KELAMBU	1																		
53.	SIDOREJO	1																		
UBP PRIOK																				
54.	PLTU PRIOK	3	13.48	-	-	-	45.0	1,114	-	0.12	-									
55.	PLTU PRIOK	4	47.92	27.49	6	4,498	17.0	38,629	1.2	4.29	0.13									
56.	PLTG PRIOK	1																		
57.	PLTG PRIOK	3	2.32	16.46	3,776	2,052	528.3	33,313	2.0	3.70	0.22									
58.	PLTGU PRIOK	GT 11																		
59.	PLTGU PRIOK	GT 12																		
60.	PLTGU PRIOK	GT 13																		
61.	PLTGU PRIOK	ST 10																		
62.	PLTGU PRIOK	GT 21																		
63.	PLTGU PRIOK	GT 22																		
64.	PLTGU PRIOK	GT 23																		
65.	PLTGU PRIOK	ST 20																		
66.	PLTD KEBAYORAN	1										6.12	27.34	3,281	2,046	533.5	30,403	-	3.38	-
67.	PLTD KEBAYORAN	2																		
68.	PLTD KEBAYORAN	3																		
69.	PLTD KEBAYORAN	4																		
70.	PLTD KEBAYORAN	5																		
71.	PLTD KEBAYORAN	6																		
UBP SURALAYA																				
72.	PLTU SURALAYA	1	3.49	19.70	2,907	2,450	371.5	18,219	0.7	2.02	0.08									
73.	PLTU SURALAYA	2																		
74.	PLTU SURALAYA	3																		
75.	PLTU SURALAYA	4																		
76.	PLTU SURALAYA	5	9.49	17.76	4,418	2,385	575.2	9,022	0.8	1.00	0.09									
77.	PLTU SURALAYA	6																		
78.	PLTU SURALAYA	7																		
UBP SEMARANG																				
79.	PLTU TAMBAK LOROK	1	5.83	44.08	466	2,573	89.0	15,719	0.9	1.8	0.10									
80.	PLTU TAMBAK LOROK	2																		
81.	PLTU TAMBAK LOROK	3																		
82.	PLTGU TAMBAK LOROK	GT 11																		
83.	PLTGU TAMBAK LOROK	GT 12	1.13	19.72	1,993	2,056	450.0	29,610	1.1	3.3	0.12									
84.	PLTGU TAMBAK LOROK	GT 13																		
85.	PLTGU TAMBAK LOROK	ST 10																		
86.	PLTGU TAMBAK LOROK	GT 21																		
87.	PLTGU TAMBAK LOROK	GT 22																		
88.	PLTGU TAMBAK LOROK	GT 23																		
89.	PLTGU TAMBAK LOROK	ST 20																		
90.	PLTG CILACAP	1										1.57	14.81	18	4,655	20.0	31,295	1.2	3.5	0.13
91.	PLTG CILACAP	2																		
92.	PLTG SUNYARAGI	1										3.05	12.98	37	3,527	18.0	98,922	2.7	11.0	0.30
93.	PLTG SUNYARAGI	2																		
94.	PLTG SUNYARAGI	3																		
95.	PLTG SUNYARAGI	4																		
UBP PERAK GRATI																				
95.	PLTU PERAK	3	10.91	62.84	190	2,838	40.0	122,009	0.9	13.56	0.10									
96.	PLTU PERAK	4																		
97.	PLTGU GRATI	GT 11																		
98.	PLTGU GRATI	GT 12																		
99.	PLTGU GRATI	GT 13	1.80	17.84	1,622	2,348	450.0	21,496	1.1	2.39	0.12									
100.	PLTGU GRATI	ST 10																		
101.	PLTG GRATI	2.1																		
102.	PLTG GRATI	2.2	2.12	9.79	135	3,517	100.0	3,857	1.2	0.43	0.13									
103.	PLTG GRATI	2.3																		
UBP BALI																				
104.	PLTD PESANGGARAN	2	7.64	28.36	12	2,502	5.1	80,362	1.3	8.93	0.14									
105.	PLTD PESANGGARAN	3																		
106.	PLTD PESANGGARAN	4																		
107.	PLTD PESANGGARAN	5																		
108.	PLTD PESANGGARAN	6																		
109.	PLTD PESANGGARAN	7																		
110.	PLTD PESANGGARAN	8																		
111.	PLTD PESANGGARAN	9																		
112.	PLTD PESANGGARAN	10																		
113.	PLTD PESANGGARAN	11																		
114.	PLTG PESANGGARAN	1	5.49	24.59	135	3,505	27.1	67,278	1.2	7.48	0.13									
115.	PLTG PESANGGARAN	2																		
116.	PLTG PESANGGARAN	3																		
117.	PLTG PESANGGARAN	4																		
118.	PLTG GILIMANUK	1	1.01	56.48	591	3,392	130.4	15,580	1.2	1.73	0.13									
119.	PLTG PEMARON	1	1.29	22.79	64	3,664	40.0	5,281	1.1	0.59	0.12									
120.	PLTG PEMARON	2																		
UBP KAMOJANG																				
121.	PLTP KAMOJANG	1	2.88	43.68	335	-	44.0	21,580	1.0	2.40	0.11									
122.	PLTP KAMOJANG	2																		
123.	PLTP KAMOJANG	3																		
124.	PLTP GN. SALAK	1	1.24	11.63	482	-	56.7	21,731	0.9	2.41	0.10									
125.	PLTP GN. SALAK	2																		
126.	PLTP GN. SALAK	3																		
127.	PLTP DARAJAT	1																		

APPENDIX—6 SIMULATION DATA OF WASP IV

6.1 Input Data

6.2 Output Data

6.1 Input Data

Peak Load Ratio



Period	Peak Load Ratio
--------	-----------------

Generation Energy and Peak Load

Year	Energy Sale	Station Use	T & D Loss	Generation Energy	Load Factor	Peak Load	Growth Rate of P.L.
	GWh	% of Generation Energy		GWh		MW	%
2009	109,227	4%	11.00%	127,841	75.5%	19,329	
2010	116,480	4%	10.90%	136,177	75.7%	20,535	6.2%
2011	124,169	4%	10.80%	145,003	75.9%	21,809	6.2%
2012	132,320	4%	10.70%	154,349	76.1%	23,153	6.2%
2013	140,962	4%	10.60%	164,245	76.3%	24,573	6.1%
2014	150,124	4%	10.50%	174,725	76.5%	26,073	6.1%
2015	159,838	4%	10.40%	185,824	76.7%	27,657	6.1%
2016	170,137	4%	10.30%	197,576	76.7%	29,406	6.3%
2017	181,057	4%	10.20%	210,023	76.5%	31,340	6.6%
2018	192,636	4%	10.10%	223,206	76.3%	33,395	6.6%
2019	204,913	4%	10.00%	237,168	76.1%	35,577	6.5%
2020	217,933	4%	9.90%	251,957	75.9%	37,895	6.5%
2021	231,738	4%	9.80%	267,621	75.7%	40,357	6.5%
2022	246,379	4%	9.70%	284,214	75.5%	42,973	6.5%
2023	261,905	4%	9.60%	301,790	75.3%	45,751	6.5%
2024	278,371	4%	9.50%	320,409	75.1%	48,703	6.5%
2025	295,834	4%	9.40%	340,133	74.9%	51,840	6.4%
2026	314,355	4%	9.30%	361,029	74.7%	55,172	6.4%
2027	333,999	4%	9.20%	383,167	74.5%	58,712	6.4%
2028	354,835	4%	9.10%	406,622	74.3%	62,474	6.4%

LDC for the Year 2006
(Based on P3B 2006 Data)

No.	Load	Duration	Area
1	1.0000	0.00000	
5	0.8855	0.08333	0.0186
6	0.8736	0.10417	0.0183
7	0.8632	0.12500	0.0181
8	0.8532	0.14583	0.0179
9	0.8437	0.16667	0.0177
10	0.8357	0.18750	0.0175
11	0.8275	0.20833	0.0173
12	0.8213	0.22917	0.0172
13	0.8155	0.25000	0.0170
14	0.8102	0.27083	0.0169
15	0.8060	0.29167	0.0168
16	0.8019	0.31250	0.0167
17	0.7977	0.33333	0.0167
18	0.7930	0.35417	0.0166
19	0.7889	0.37500	0.0165
20	0.7839	0.39583	0.0164
21	0.7790	0.41667	0.0163
22	0.7744	0.43750	0.0162
23	0.7697	0.45833	0.0161
24	0.7646	0.47917	0.0160
25	0.7593	0.50000	0.0159
26	0.7535	0.52083	0.0212
27	0.7479	0.54167	0.0102
28	0.7425	0.56250	0.0155
29	0.7367	0.58333	0.0154
30	0.7309	0.60417	0.0153
31	0.7255	0.62500	0.0152
32	0.7203	0.64583	0.0151
33	0.7154	0.66667	0.0150
34	0.7112	0.68522	0.0132
35	0.7058	0.70833	0.0164
36	0.7006	0.72917	0.0147
37	0.6949	0.75000	0.0145
38	0.6893	0.77083	0.0144
39	0.6830	0.79167	0.0143
40	0.6770	0.81250	0.0142
41	0.6694	0.83333	0.0140
42	0.6599	0.85417	0.0139
43	0.6499	0.87500	0.0136
44	0.6380	0.89583	0.0134
45	0.6242	0.91667	0.0132
46	0.6086	0.93750	0.0128
47	0.5932	0.95833	0.0125
48	0.5631	0.97917	0.0120
49	0.3957	1.00000	0.0100
50			
51			
52			
Area (Load Factor) =			0.7551



Addition/Retirements

No.	Name	No. of Sets	Available Capacity MW	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
-----	------	-------------	-----------------------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------

Supply Balance Information				2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
Available capacity of thermal				18,816																					
installed capacity of hydro				2,573																					
Gross available capacity				21,389	21,389	21,389	24,389	28,305	29,988	30,955	30,955	30,955	31,065	31,065	29,512	28,811	27,813	27,813	27,813	27,208	27,208	27,208	27,208	27,208	27,208
Addition/Retirement						3,000	3,916	1,683	967			110		(1,553)	(701)	(998)			(605)						
Gross available capacity(year end)				21,389	21,389	24,389	28,305	29,988	30,955	30,955	30,955	31,065	31,065	29,512	28,811	27,813	27,813	27,813	27,208	27,208	27,208	27,208	27,208	27,208	27,208
Peak Load at Power Station				-	-	19,329	20,535	21,809	23,153	24,573	26,073	27,657	29,406	31,340	33,395	35,577	37,895	40,357	42,973	45,751	48,703	51,840	55,172	58,712	62,474
Shortage/surplus of power supply				21,389	21,389	5,060	7,770	8,179	7,802	6,382	4,882	3,408	1,659	-1,828	-4,584	-7,764	-10,082	-12,544	-15,765	-18,543	-21,495	-24,632	-27,964	-31,504	-35,266
Required available capacity																									
Min. reserve margin of 10%				-	-	21,262	22,589	23,990	25,468	27,030	28,680	30,423	32,347	34,474	36,735	39,135	41,685	44,393	47,270	50,326	53,573	57,024	60,689	64,583	68,721
Max. reserve margin of 35%				-	-	26,094	27,722	29,442	31,257	33,174	35,199	37,337	39,698	42,309	45,083	48,029	51,158	54,482	58,014	61,764	65,749	69,984	74,482	79,261	84,340
Required mini. additional capacity				-	-	-	-	-	-	-	-	-	1,282	4,962	7,924	11,322	13,872	16,580	20,062	23,118	26,365	29,816	33,481	37,375	41,513

			2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
C6H	PLTU	600																						
C10H	PLTU	1000						1	1	1	1	1	5	5	8	10	12	15	17	18	21	24	27	31
LNG	PLTG	750									1	2	3	4	4	4	4	4	6	6	8	8	10	10
N10H	PLTN	1000												1	1	1	2	2	2	3	3	4	4	5
GE55	PLTP	55				6	6	6	10	12	14	16	18	20	22	24	26	28	30	32	34	36	38	
G150	PLTG	150																						
PS	Pumped S.	500									1	2	2	4	6	6	6	6	6	6	6	6	6	6
CIB3	PLTA	172														1	1	1	1	1	1	1	1	1
CPSG	PLTA	400														1	1	1	1	1	1	1	1	1
CMD3	PLTA	238														1	1	1	1	1	1	1	1	1
MANG	PLTA	360														1	1	1	1	1	1	1	1	1
PLTA	PLTA	300															3	3	6	6	6	6	7	7
Java-Sumatra I.C.		600								4	5	5	5	5	5	5	5	5	5	5	5	5	5	5

C6H	PLTU	600																						
C10H	PLTU	1000						1,000	1,000	1,000	1,000	1,000	5,000	5,000	8,000	10,000	12,000	15,000	17,000	18,000	21,000	24,000	27,000	31,000
LNG	PLTG	750									750	1,500	2,250	3,000	3,000	3,000	3,000	3,000	4,500	4,500	6,000	6,000	7,500	7,500
N10H	PLTN	1000												1,000	1,000	1,000	2,000	2,000	2,000	3,000	3,000	4,000	4,000	5,000
GE55	PLTP	55				330	330	330	550	660	770	880	990	1,100	1,210	1,320	1,430	1,540	1,650	1,760	1,870	1,980	2,090	
G150	PLTG	150																						
PS	Pumped S.	500									500	1,000	1,000	2,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000
CIB3	PLTA	172														172	172	172	172	172	172	172	172	172
CPSG	PLTA	400														400	400	400	400	400	400	400	400	400
CMD3	PLTA	238														238	238	238	238	238	238	238	238	238
MANG	PLTA	360														360	360	360	360	360	360	360	360	360
PLTA	PLTA	300															900	900	1,800	1,800	1,800	1,800	2,100	2,100
Java-Sumatera I.C.		600								2,400	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000
Total Additional Capacity						-	-	330	1,330	1,330	3,950	5,910	7,270	12,130	14,990	19,100	22,380	25,490	29,500	33,110	36,120	40,730	44,840	49,750
Total Supply Capacity at year end					24,389	28,305	30,318	32,285	32,285	34,905	36,975	38,335	41,642	43,801	46,913	50,193	53,303	56,708	60,318	63,328	67,938	72,048	76,958	82,068
Reserve Margin %					26.2%	37.8%	39.0%	39.4%	31.4%	33.9%	33.7%	30.4%	32.9%	31.2%	31.9%	32.5%	32.1%	32.0%	31.8%	30.0%	31.1%	30.6%	31.1%	31.4%

FIXSYS HYDRO

PLTA	Index	Installed Cap. [MW]	Energy Storage (GWh)	Inflow Energy				Min. Generation				Average Capacity			
				I(Wet)	II(Dry)	III	IV	I(Wet)	II(Dry)	III	IV	I(Wet)	II(Dry)	III	IV
				[GWh]	[GWh]	[GWh]	[GWh]	[GWh]	[GWh]	[GWh]	[GWh]	[MW]	[MW]	[MW]	[MW]
Jatiluhur #1-6	JTLH	180	842.6	315.8	376.9			204.3	298			180	180		
Saguling	SAGL	700.7	2,520.7	1292	680.8			999.2	400.6			701	701		
IP- Area I	IPA1	37.26	-	70.5	53.9			61.8	37.8			37	37		
IP- Area II	IPA2	59.38	-	143.1	78.9			112.3	56.7			59	59		
Sudirman	MRTC	180.9	489.8	356.9	79.7			277.3	18			181	181		
IP-Area III	APA3	125.54	-	264.1	199			235.8	166.3			126	126		
Sutami	STMI	105	451.1	263.2	155.5			164.6	127.5			105	105		
EP Non Suami	EPNS	134.5	563.5	312.3	175.8			223	115.8			135	135		
Brantas Non EP	BNEP	41.9	-	47.3	41.2			17.1	11.3			42	42		
Cirata	CRI2	1008	1,377.0	648.2	444.9			487.8	256			1008	1008		
Rajamandala	RJMD	47	90.0	82.0	61.8			70.0	52.5			47	47		
Jatigede	JTGD	110	620.0	216.8	72.3			184.3	61.4			110	110		

INPUT VARYSYS

No.	Name	No. of Sets	Min. Load MW	Capacity MW	Heat Rates		Fuel Costs		Fuel Type	Spinning Reserves	FOR	Days Scheduled Maintenance Days	Maintenance Class Size MW	O&M (FIX) \$/kWm	O&M (VAR) \$/MWh	FLD HEAT RT KCAL/KWH	UNIT GENERATION COSTS (\$/MWH)				
					Kcal/kWh		Cents/Million Kcal										BASE DOM	BASE FRGN	FLD DOM	FLD FRGN	FLD TOT
					Base Load	Average Incremental	Domestic	Foreign													
1	C6H	0	300	600	2510	2389	1509	0	0	5	7	42	600	2.61	2.00	2450	39.9	0.0	39.0	0.0	39.0
2	C10H	0	500	1000	2510	2389	1509	0	0	5	7	42	1000	2.61	2.00	2450	39.9	0.0	39.0	0.0	39.0
3	LNG	0	375	750	1911	1741	0	3968	2	7	7	42	750	1.60	1.00	1826	1.0	75.8	1.0	72.5	73.5
4	N10H	0	1000	1000	2606	2606	0	250	6	0	7	28	1000	4.66	0.41	2606	0.4	6.5	0.4	6.5	6.9
5	GE55	0	44	55	1000	1000	6430	0	5	0	7	28	55	2.50	1.00	1000	65.3	0.0	65.3	0.0	65.3
6	G150	0	75	150	3150	2625	9222	0	4	10	7	28	150	0.97	2.00	2888	292.5	0.0	268.3	0.0	268.3
7	J-SIC	5	300	600	2510	2389	1509	0	7	5	8	45	600	2.64	2.00	2450	39.9	0.0	39.0	0.0	39.0

PUMP STORAGE (Upper Cisokan)

PS1
 Installed Capacity 500 MW
 Efficiency 76 %
 O&M (Fix) 0.55 \$/kW-month
 Available Year 2015

Period	Pump Cap. MW	Gen. Cap. MW	Max. Energy GWh
1	530	500	600
2	530	500	600

PS2
 Installed Capacity 500 MW
 Efficiency 76 %
 O&M (Fix) 0.55 \$/kW-month
 Available Year 2016

Period	Pump Cap. MW	Gen. Cap. MW	Max. Energy GWh
1	530	500	600
2	530	500	600

PUMP STORAGE (Matenggeng)

PS3
 Installed Capacity 1000 MW
 Efficiency 76 %
 O&M (Fix) 0.55 \$/kW-month
 Available Year 2019

Period	Pump Cap. MW	Gen. Cap. MW	Max. Energy GWh
1	530	500	450
2	530	500	450

PUMP STORAGE (Grindulu)

PS4
 Installed Capacity 1000 MW
 Efficiency 76 %
 O&M (Fix) 0.55 \$/kW-month
 Available Year 2019

Period	Pump Cap. MW	Gen. Cap. MW	Max. Energy GWh
1	530	500	450
2	530	500	450

Hydropower Project

	MANG (Maung)	CIB3 (Cibuni-3)	CPSG (Cipasang)	CMD3(Cimandiri-3)
Construction Cost \$/kW	1872 Inc.IDC	2,865 Inc.IDC	1,636 Inc.IDC	1,998 Inc.IDC
Installed Caapcity MW	360	172	400	238
Reservoir Energy GWh	535	568	751	600
Inflow Energy wet GWh	430	450	600	480
dry GWh	160	170	230	180
Minimum Generation wet GWh	320	340	450	360
dry GWh	80	90	110	90
Average Capacity wet MW	360	172	400	238
dry MW	360	172	400	238
Construction Period year	5	5	5	5
I.D.C (%)	22.6	22.6	22.6	22.6

Source: Hydro Inventory and Pre-feasibility Studies, June 1999, Nippon Koei Co., Ltd.

Construction Cost inc. IDC

PLANT	CAPITAL COSTS (\$/kW)				PLANT LIFE YEARS	D.R.=12% I.D.C. (%)	CONSTR. TIME (YEARS)
	DEPRECIABLE PART		NON-DEPRECIABLE PART				
	DOMESTIC	FOREIGN	DOMESTIC	FOREIGN			
C6H	444	1,037	0	0	30	18.46	4
C10H	611	1,425	0	0	30	18.46	4
LNG	300	699	0	0	25	14.13	3
N10H	659	2,637	0	0	40	26.6	6
G150	82	466	0	0	20	9.6	2
PS 1&2	271	584	0	0	50	22.6	5
PS 3	252	541	0	0	50	22.6	5
PS 4	268	579	0	0	50	22.6	5
GE55	444	1,776	0	0	30	14.13	3
J-SIC	308	2,051	0	0	30	18.46	4

Java - Sumatra Interconnection (HVDC)

			Note
1. Investment Cost for HVDC			
EPC Cost	1,370	M.US\$	
Land Acquisition + ROW	160	M.US\$	
Total Investment Cost	1,530	M.US\$	
2. Construction Cost for HVDC	510	\$/kW	Divided by 3000 MW
3. Construction Cost of C6H	1,481	\$/kW	Referred to P3B Data
4. Total Investment Cost	1,991	\$/kW	


Source: Updated Feasibility Study Java - Sumatera Interconnection, Sep. 2007

WASP IV Screening Curve

Fuel Prices Scenario Index	2	Medium Scenario						
		PLTU	LNG	PLTN	PLTG	PLTU10	PLTP	Interc.
Installed Capacity	MW	600	750	1000	150	1000	55	3000
Fuel Type		coal	LNG	nuclear	HSD	coal	Geothermal	HVDC T/L
Fuel Price	\$/MMBTU	3.80	10.00	0.63	23.24	3.80	16.20	3.80
Thermal Efficiency	%	35%	47%	33%	30%	35%	86%	35%
Variabel O&M	\$/MWh	2.0	1.0	0.4	2.0	2.0	1.0	2.0
Fixed O&M	\$/KW.year	31.32	19.2	55.92	11.64	31.32	30.00	31.68
Investment Cost inc. IDC	\$/KW	1,481	999	3,296	548	2,036	2,220	2,359
Construction Period	Years	4	3	6	2	4	3	4
Book Life	Years	30	25	40	20	30	30	30
Discount Rate		12.00%	12.00%	12.00%	12.00%	12.00%	12.00%	12.00%
Capital Recovery Factor (CRF)		12.41%	12.75%	12.13%	13.39%	12.41%	12.41%	12.41%
Interest During Construction (IDC)		18.46%	14.13%	26.60%	9.60%	18.46%	14.13%	14.13%
Annual Investment cost	\$/KW.year	183.86	127.37	399.82	73.37	252.76	275.60	292.75
Annual Fixed Cost	\$/KW.year	215.18	146.57	455.74	85.01	284.08	305.60	324.43
Annual Fuel Cost	\$/KW.year	324.58	636.07	57.07	2315.88	323.65	563.14	323.65
Annual Variable O&M	\$/KW.year	17.52	8.76	3.59	17.52	17.52	8.76	17.52
Annual Variable Cost	\$/KW.year	342.10	644.83	60.66	2333.40	341.17	571.90	341.17
Annual Fixed Cost	\$/KW.year	215.18	146.57	455.74	85.01	284.08	305.60	324.43
Total	\$/KW.year	557.28	791.40	516.40	2418.41	625.25	877.50	665.60
CF	0%	215.18	146.57	455.74	85.01	284.08	305.60	324.43
	100%	557.28	791.40	516.40	2418.41	625.25	877.50	665.60

Index	Fuel Prices \$/MMBTU		
	Low	Medium	High
Coal	3.33	3.80	4.28
LNG	8.00	10.00	12.00
N.Gas	4.00	5.00	6.00
Nuclear	0.57	0.63	0.69
HSD	19.57	23.24	26.91
MFO	11.50	13.70	15.90
Geothermal	14.58	16.20	17.82

Note: \$/MMBTU is referred to "Fuel Price Sheet" except Nuclear.



INPUT REMERSIM (Fuel Consumption per GWh)

No.	Name	Type	No. of Sets	Min. Load MW	Capacity MW	Heat Rates (kcal/kWh)			Fuel Type	Heat Value kcal/kg 100kcal/MMBT U kcal/liter	Fuel Consumption (unit/GWh) at FLD			
						Base Load	Average Incremental	At FLD			1,000 ton	1,000 MMBTU	1,000 KL	Geo
1	SRL1	PLTU	4	240	381	2,622	2,452	2,559	0	5,100	0.502			
2	SRL2	PLTU	3	340	579	2,560	2,309	2,456	0	5,100	0.482			
3	MKR1	PLTU	3	44	84	3,273	3,194	3,235	3	9,598			0.337	
4	MKR2	PLTG	2	90	165	2,948	2,884	2,919	1	2,520		11.58		
5	MKR3	PLTGU	1	300	465	2,433	2,018	2,286	1	2,520		9.07		
6	MKRR	PLTGU	-	500	750	2,433	2,018	2,295	1	2,520		9.11		
7	PRK1	PLTU	2	25	48	3,229	2,957	3,099	3	9,598			0.323	
8	PRK2	PLTGU	2	315	560	2,319	1,994	2,177	4	9,095			0.239	
9	PRK3	PLTG	2	10	20	4,711	3,930	4,321	4	9,095			0.475	
10	PRKE	PLTGU	-	500	750	2,433	2,018	2,295	1	2,520		9.11		
11	MTR1	PLTGU	1	315	605	2,555	2,246	2,407	4	9,095			0.265	
12	MTR2	PLTG	2	72	138	3,376	3,204	3,294	4	9,095			0.362	
13	MTR3	PLTG	6	72	143	3,376	3,204	3,291	4	9,095			0.362	
14	MTRR	PLTGU	-	150	225	2,433	2,018	2,295	1	2,520		9.11		
15	SLK1	PLTP	3	52	52	1,000	1,000	1,000	5	7,308				-
16	SLK2	PLTP	3	52	52	1,000	1,000	1,000	5	7,308				-
17	CLND	PLTG	1	50	150	4,465	3,200	3,622	1	2,520		14.37		
18	CLGN	PLTGU	1	240	740	2,175	1,800	1,922	1	2,520		7.63		
19	SRL3	PLTU	-	340	600	2,560	2,309	2,451	0	4,200	0.584			
20	LBHN	PLTU	-	150	300	2,622	2,452	2,537	0	4,200	0.604			
21	TLNG	PLTU	-	150	300	2,622	2,452	2,537	0	4,200	0.604			
22	KMJ1	PLTP	1	26	26	1,000	1,000	1,000	5	7,308				-
23	KMJ2	PLTP	2	47	47	1,000	1,000	1,000	5	7,308				-
24	KMJ3	PLTP	1	60	60	1,000	1,000	1,000	5	7,308				-
25	DRJ1	PLTP	1	44	44	1,000	1,000	1,000	5	7,308				-
26	DRJ2	PLTP	1	70	70	1,000	1,000	1,000	5	5,300				-
27	DRJ3	PLTP	1	110	110	1,000	1,000	1,000	5	7,308				-
28	WW1	PLTP	1	110	110	1,000	1,000	1,000	5	7,308				-
29	SRG1	PLTG	2	8	18	4,700	4,084	4,358	1	2,520		17.29		
30	SRG2	PLTG	2	8	20	4,700	4,084	4,330	4	9,095			0.476	
31	PTH1	PLTP	-	60	60	1,000	1,000	1,000	5	7,308				-
32	JBSL	PLTU	-	150	300	2,590	2,115	2,353	0	4,200	0.560			
33	JBUT	PLTU	-	150	300	2,590	2,115	2,353	0	4,200	0.560			
34	CRBN	PLTU	-	360	600	2,560	2,160	2,400	0	5,300	0.453			
35	TBK1	PLTGU	2	297	496	2,632	2,015	2,384	4	9,095			0.262	
36	TBK2	PLTU	2	25	41	3,229	3,127	3,189	3	9,598			0.332	
37	TBK3	PLTU	1	125	192	3,229	3,127	3,193	3	9,598			0.333	
38	CLC1	PLTG	2	10	22	4,700	4,079	4,361	4	9,095			0.479	
39	CLC2	PLTU	2	150	300	2,772	2,285	2,529	0	5,215	0.485			
40	TJB1	PLTU	2	330	660	2,772	2,285	2,529	0	5,215	0.485			
41	TJB2	PLTU	-	360	600	2,560	2,160	2,400	0	4,500	0.533			
42	DIEN	PLTP	1	60	60	1,000	1,000	1,000	5	7,308				-
43	RMBG	PLTU	-	150	300	2,590	2,115	2,353	0	4,500	0.523			
44	PTN1	PLTU	2	225	370	2,579	2,412	2,514	0	5,100	0.493			
45	PTN2	PLTU	-	340	600	2,560	2,309	2,451	0	4,500	0.545			
46	PEC	PLTU	2	368	615	2,772	2,285	2,576	0	5,215	0.494			
47	JPOW	PLTU	2	355	610	2,700	2,310	2,537	0	5,500	0.461			
48	GSK1	PLGU	3	250	480	2,318	1,990	2,161	1	2,520		8.58		
49	GSK2	PLTG	2	5	16	4,456	4,284	4,338	1	2,520		17.21		
50	GSK3	PLTU	2	43	85	2,882	2,709	2,797	1	2,520		11.10		
51	GSK4	PLTU	2	90	175	2,826	2,601	2,717	1	2,520		10.78		
52	PRAK	PLTU	2	25	48	4,323	3,517	3,937	3	9,598			0.410	
53	GRT1	PLTGU	1	270	462	2,632	2,083	2,404	4	9,095			0.264	
54	GRT2	PLTG	3	40	100	3,376	3,310	3,336	4	9,095			0.367	
55	PMRN	PLTG	2	12	48	4,439	4,035	4,136	4	9,095			0.455	
56	GLMR	PLTG	2	5	16	4,456	4,284	4,338	4	9,095			0.477	
57	GLMK	PLTG	1	56	133	4,439	4,035	4,205	4	9,095			0.462	
58	BLI1	PLTG	4	6	20	4,700	4,131	4,302	4	9,095			0.473	
59	BLI2	PLTD	10	2	5	3,880	3,576	3,698	4	9,095			0.407	
60	BLUT	PLTU	-	65	130	2,590	2,115	2,353	0	5,300	0.444			
61	BDGL	PLTP	-	10	10	1,000	1,000	1,000	5	7,308				-
62	TJAW	PLTU	-	150	300	2,590	2,115	2,353	0	4,500	0.523			
63	JTSL	PLTU	-	150	300	2,590	2,115	2,353	0	4,500	0.523			

No.	Name	Type	No. of Sets	Min. Load MW	Capacity MW	Heat Rates (kcal/kWh)			Fuel Type	Heat Value kcal/kg 100kcal/MMBT U kcal/liter	Fuel Consumption (unit/GWh) a FLD			
						Base Load	Average Incremental	At FLD			1,000 ton	1,000 MMBTU	1,000 KL	Geo Nuclear
1	C6H	PLTU	0	300	600	2510	2389	2,450	0	4,766	0.514			
2	C10H	PLTU	0	500	1000	2510	2389	2,450	0	4,766	0.514			
3	LNG	PLTG	0	375	750	1911	1741	1,826	2	2,520		7.25		
4	N10H	PLTN	0	1000	1000	2606	2606	2,606	6	0				-
5	GE55	PLTP	0	44	55	1000	1000	1,000	5	0				-
6	G150	PLTG	0	75	150	3150	2625	2,888	4	9,095			0.318	
7	J-SIC	J-SI	5	300	600	2510	2389	2,450	7	0				-

Assumption of Fuel Prices (Medium Scenario)

Kind of Fuel	Price		Heat Content	
	USD		Cents/mKcal	
Coal	80.0	per Ton	1,509	5,300 Kcal/kg
LNG	10.0	per MMBTU	3,968	252,000 Kcal/mmbtu
Gas	5.0	per MMBTU	1,984	252,000 Kcal/mmbtu
HSD	133.0	per Barrel	9,222	9,070 Kcal/l
MFO	81.0	per Barrel	5,437	9,370 Kcal/l
Geothermal	0.0553	per kWh	6,430	
Nuclear			250	

Price Crude Oil	95	\$/barrel		
HSD	133	\$/barrel	23.24	\$/mmbtu
MFO	81	\$/barrel	13.70	\$/mmbtu
LNG+transport	10.0	\$/mmbtu		
transport	0.7	\$/mmbtu		
LNG	9.3	\$/mmbtu	9.30	\$/mmbtu
Gas	5.0	\$/mmbtu	5.00	\$/mmbtu
Coal+transport	80	\$/ton	3.80	\$/mmbtu
transport	18	\$/ton		
Coal	74	\$/ton	6,300	Kcal/kg
	62	\$/ton	5,300	Kcal/kg

Note: Coal price at P/S is CIF Price.

Heat (HSD)	19,500	btu/lb	1 kg =	2.2 lb
	10,811	Kcal/kg	berat jenis =	0.839 kg/l
	9,070	Kcal/l		
MFO	18,000	btu/lb	1 kg =	2.2 lb
	9,979	Kcal/kg	berat jenis =	0.939 kg/l
	9,370	Kcal/l		

Reference 2: Relationship between MOPS and Domestic Prices

MOPS (2008/03/31 ~ 2008/04/04)	
	\$/barrel
High Speed Diesel Oil (0.05%)	132.02
Kerosene	128.36
Crude Oil	104.30

Note: HSD and Kerosene are FOB at Singapore

MOPS means Mean of Platts Singapore

Source://www.gu-goon.com/

PERTAMINA Price		Price Index (IP)
	\$/barrel	
HSD	145.93	1.40
MFO	89.14	0.85
Crude Oil	104.30	1.00

Note : 1 barrel = 159 liter

New Fuel Prices for Industry in April 2008 released by PERTAMINA on March 31, 2008						
Fuel Type	Economical Selling Fuel Price - Non Tax (Base Price)					
	Region 1		Region 2		Region 3	
	Rp/KL	US\$/KL	Rp/KL	US\$/KL	Rp/KL	US\$/KL
Gasoline	7080.13	768.17	7352.107	797.68	7508.057	814.60
Kerosene	8532.07	925.76	8718.104	945.94	8903.029	966.01
High Speed Diesel	8458.78	917.77	8819.464	956.91	9006.539	977.20
Marine Diesel Fuel	8284.08	898.88	8464.705	918.48	8644.250	937.97
Marine Fuel Oil	5166.53	560.60	5278.949	572.80	5390.924	584.95
Pertamina DEX	8757.37	950.14	-	-	-	-

Source: www.pertamina.com/

Note : Fuel prices released by PERTAMINA depend on MOPS.

Peak Load Ratio



Period	Peak Load Ratio
--------	-----------------

Generation Energy and Peak Load

Year	Energy Sale	Station Use	T & D Loss	Generation Energy	Load Factor	Peak Load	Growth Rate of P.L.
	GWh	% of Generation Energy		GWh		MW	%
2009	109,227	4%	11.00%	127,841	75.5%	19,329	
2010	116,480	4%	10.90%	136,177	75.7%	20,535	6.2%
2011	124,169	4%	10.80%	145,003	75.9%	21,809	6.2%
2012	132,320	4%	10.70%	154,349	76.1%	23,153	6.2%
2013	140,962	4%	10.60%	164,245	76.3%	24,573	6.1%
2014	150,124	4%	10.50%	174,725	76.5%	26,073	6.1%
2015	159,838	4%	10.40%	185,824	76.7%	27,657	6.1%
2016	170,137	4%	10.30%	197,576	76.7%	29,406	6.3%
2017	181,057	4%	10.20%	210,023	76.5%	31,340	6.6%
2018	192,636	4%	10.10%	223,206	76.3%	33,395	6.6%
2019	204,913	4%	10.00%	237,168	76.1%	35,577	6.5%
2020	217,933	4%	9.90%	251,957	75.9%	37,895	6.5%
2021	231,738	4%	9.80%	267,621	75.7%	40,357	6.5%
2022	246,379	4%	9.70%	284,214	75.5%	42,973	6.5%
2023	261,905	4%	9.60%	301,790	75.3%	45,751	6.5%
2024	278,371	4%	9.50%	320,409	75.1%	48,703	6.5%
2025	295,834	4%	9.40%	340,133	74.9%	51,840	6.4%
2026	314,355	4%	9.30%	361,029	74.7%	55,172	6.4%
2027	333,999	4%	9.20%	383,167	74.5%	58,712	6.4%
2028	354,835	4%	9.10%	406,622	74.3%	62,474	6.4%

LDC for the Year 2006
(Based on P3B 2006 Data)

No.	Load	Duration	Area
1	1.0000	0.00000	
5	0.8855	0.08333	0.0186
6	0.8736	0.10417	0.0183
7	0.8632	0.12500	0.0181
8	0.8532	0.14583	0.0179
9	0.8437	0.16667	0.0177
10	0.8357	0.18750	0.0175
11	0.8275	0.20833	0.0173
12	0.8213	0.22917	0.0172
13	0.8155	0.25000	0.0170
14	0.8102	0.27083	0.0169
15	0.8060	0.29167	0.0168
16	0.8019	0.31250	0.0167
17	0.7977	0.33333	0.0167
18	0.7930	0.35417	0.0166
19	0.7889	0.37500	0.0165
20	0.7839	0.39583	0.0164
21	0.7790	0.41667	0.0163
22	0.7744	0.43750	0.0162
23	0.7697	0.45833	0.0161
24	0.7646	0.47917	0.0160
25	0.7593	0.50000	0.0159
26	0.7535	0.52083	0.0212
27	0.7479	0.54167	0.0102
28	0.7425	0.56250	0.0155
29	0.7367	0.58333	0.0154
30	0.7309	0.60417	0.0153
31	0.7255	0.62500	0.0152
32	0.7203	0.64583	0.0151
33	0.7154	0.66667	0.0150
34	0.7112	0.68522	0.0132
35	0.7058	0.70833	0.0164
36	0.7006	0.72917	0.0147
37	0.6949	0.75000	0.0145
38	0.6893	0.77083	0.0144
39	0.6830	0.79167	0.0143
40	0.6770	0.81250	0.0142
41	0.6694	0.83333	0.0140
42	0.6599	0.85417	0.0139
43	0.6499	0.87500	0.0136
44	0.6380	0.89583	0.0134
45	0.6242	0.91667	0.0132
46	0.6086	0.93750	0.0128
47	0.5932	0.95833	0.0125
48	0.5631	0.97917	0.0120
49	0.3957	1.00000	0.0100
50			
51			
52			
Area (Load Factor) =			0.7551



Addition/Retirements

No.	Name	No. of Sets	Available Capacity MW	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
-----	------	-------------	-----------------------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------

Supply Balance Information			2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	
Available capacity of thermal installed capacity of hydro			18,816 2,573																						
Gross available capacity			21,389	21,389	21,389	24,389	28,305	29,988	30,955	30,955	30,955	31,065	31,065	29,512	28,811	27,813	27,813	27,813	27,208	27,208	27,208	27,208	27,208	27,208	27,208
Addition/Retirement					3,000	3,916	1,683	967			110		(1,553)	(701)	(998)		(605)								
Gross available capacity(year end)			21,389	21,389	24,389	28,305	29,988	30,955	30,955	30,955	31,065	31,065	29,512	28,811	27,813	27,813	27,813	27,208	27,208	27,208	27,208	27,208	27,208	27,208	27,208
Peak Load at Power Station			-	-	19,329	20,535	21,809	23,153	24,573	26,073	27,657	29,406	31,340	33,395	35,577	37,895	40,357	42,973	45,751	48,703	51,840	55,172	58,712	62,474	62,474
Shortage/surplus of power supply			21,389	21,389	5,060	7,770	8,179	7,802	6,382	4,882	3,408	1,659	-1,828	-4,584	-7,764	-10,082	-12,544	-15,765	-18,543	-21,495	-24,632	-27,964	-31,504	-35,266	-35,266
Required available capacity																									
Min. reserve margin of 10%			-	-	21,262	22,589	23,990	25,468	27,030	28,680	30,423	32,347	34,474	36,735	39,135	41,685	44,393	47,270	50,326	53,573	57,024	60,689	64,583	68,721	68,721
Max. reserve margin of 35%			-	-	26,094	27,722	29,442	31,257	33,174	35,199	37,337	39,698	42,309	45,083	48,029	51,158	54,482	58,014	61,764	65,749	69,984	74,482	79,261	84,340	84,340
Required mini. additional capacity			-	-	-	-	-	-	-	-	-	1,282	4,962	7,924	11,322	13,872	16,580	20,062	23,118	26,365	29,816	33,481	37,375	41,513	41,513

			2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
C6H	PLTU	600																						
C10H	PLTU	1000						1	1	1	1	2	5	6	9	10	13	17	19	22	26	30	34	38
LNG	PLTG	750									1	2	3	4	4	4	4	5	5	5	5	5	5	5
N10H	PLTN	1000												1	1	1	2	2	2	3	3	4	4	5
GE55	PLTP	55					6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6
G150	PLTG	150																						
PS	Pumped S.	500									1	2	2	4	6	6	6	6	6	6	6	6	6	6
CIB3	PLTA	172														1	1	1	1	1	1	1	1	1
CPSG	PLTA	400														1	1	1	1	1	1	1	1	1
CMD3	PLTA	238														1	1	1	1	1	1	1	1	1
MANG	PLTA	360														1	1	1	1	1	1	1	1	1
PLTA	PLTA	300														1	1	1	1	1	1	1	1	1
Java-Sumatra I.C.		600								4	5	5	5	5	5	5	5	5	5	5	5	5	5	5

C6H	PLTU	600																						
C10H	PLTU	1000						1,000	1,000	1,000	1,000	2,000	5,000	6,000	9,000	10,000	13,000	17,000	19,000	22,000	26,000	30,000	34,000	38,000
LNG	PLTG	750									750	1,500	2,250	3,000	3,000	3,000	3,000	3,000	3,750	3,750	3,750	3,750	3,750	3,750
N10H	PLTN	1000												1,000	1,000	1,000	2,000	2,000	2,000	3,000	3,000	4,000	4,000	5,000
GE55	PLTP	55					330	330	330	330	330	330	330	330	330	330	330	330	330	330	330	330	330	330
G150	PLTG	150																						
PS	Pumped S.	500									500	1,000	1,000	2,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000
CIB3	PLTA	172														172	172	172	172	172	172	172	172	172
CPSG	PLTA	400														400	400	400	400	400	400	400	400	400
CMD3	PLTA	238														238	238	238	238	238	238	238	238	238
MANG	PLTA	360														360	360	360	360	360	360	360	360	360
PLTA	PLTA	300																						
Java-Sumatera I.C.		600								2,400	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000
Total Additional Capacity					-	-	330	1,330	1,330	3,730	5,580	7,830	11,580	15,330	19,330	21,500	25,500	29,500	32,250	36,250	40,250	45,250	49,250	54,250
Total Supply Capacity at year end					24,389	28,305	30,318	32,285	32,285	34,685	36,645	38,895	41,092	44,141	47,143	49,313	53,313	56,708	59,458	63,458	67,458	72,458	76,458	81,458
Reserve Margin %					26.2%	37.8%	39.0%	39.4%	31.4%	33.0%	32.5%	32.3%	31.1%	32.2%	32.5%	30.1%	32.1%	32.0%	30.0%	30.3%	30.1%	31.3%	30.2%	30.4%

FIXSYS HYDRO

PLTA	Index	Installed Cap. [MW]	Energy Storage (GWh)	Inflow Energy				Min. Generation				Average Capacity			
				I(Wet)	II(Dry)	III	IV	I(Wet)	II(Dry)	III	IV	I(Wet)	II(Dry)	III	IV
				[GWh]	[GWh]	[GWh]	[GWh]	[GWh]	[GWh]	[GWh]	[GWh]	[MW]	[MW]	[MW]	[MW]
Jatiluhur #1-6	JTLH	180	842.6	315.8	376.9			204.3	298			180	180		
Saguling	SAGL	700.7	2,520.7	1292	680.8			999.2	400.6			701	701		
IP- Area I	IPA1	37.26	-	70.5	53.9			61.8	37.8			37	37		
IP- Area II	IPA2	59.38	-	143.1	78.9			112.3	56.7			59	59		
Sudirman	MRTC	180.9	489.8	356.9	79.7			277.3	18			181	181		
IP-Area III	APA3	125.54	-	264.1	199			235.8	166.3			126	126		
Sutami	STMI	105	451.1	263.2	155.5			164.6	127.5			105	105		
EP Non Suami	EPNS	134.5	563.5	312.3	175.8			223	115.8			135	135		
Brantas Non EP	BNEP	41.9	-	47.3	41.2			17.1	11.3			42	42		
Cirata	CRI2	1008	1,377.0	648.2	444.9			487.8	256			1008	1008		
Rajamandala	RJMD	47	90.0	82.0	61.8			70.0	52.5			47	47		
Jatigede	JTGD	110	620.0	216.8	72.3			184.3	61.4			110	110		

INPUT VARYSYS

No.	Name	No. of Sets	Min. Load MW	Capacity MW	Heat Rates		Fuel Costs		Fuel Type	Spinning Reserves	FOR	Days Scheduled Maintenance Days	Maintenance Class Size MW	O&M (FIX) \$/kWm	O&M (VAR) \$/MWh	FLD HEAT RT KCAL/KWH	UNIT GENERATION COSTS (\$/MWH)				
					Kcal/kWh		Cents/Million Kcal										BASE DOM	BASE FRGN	FLD DOM	FLD FRGN	FLD TOT
					Base Load	Average Incremental	Domestic	Foreign													
1	C6H	0	300	600	2510	2389	1509	0	0	5	7	42	600	2.61	2.00	2450	39.9	0.0	39.0	0.0	39.0
2	C10H	0	500	1000	2510	2389	1509	0	0	5	7	42	1000	2.61	2.00	2450	39.9	0.0	39.0	0.0	39.0
3	LNG	0	375	750	1911	1741	0	3968	2	7	7	42	750	1.60	1.00	1826	1.0	75.8	1.0	72.5	73.5
4	N10H	0	1000	1000	2606	2606	0	250	6	0	7	28	1000	4.66	0.41	2606	0.4	6.5	0.4	6.5	6.9
5	GE55	0	44	55	1000	1000	6430	0	5	0	7	28	55	2.50	1.00	1000	65.3	0.0	65.3	0.0	65.3
6	G150	0	75	150	3150	2625	9222	0	4	10	7	28	150	0.97	2.00	2888	292.5	0.0	268.3	0.0	268.3
7	J-SIC	5	300	600	2510	2389	1509	0	7	5	8	45	600	2.64	2.00	2450	39.9	0.0	39.0	0.0	39.0

PUMP STORAGE (Upper Cisokan)

PS1
 Installed Capacity 500 MW
 Efficiency 76 %
 O&M (Fix) 0.55 \$/kW-month
 Available Year 2015

Period	Pump Cap. MW	Gen. Cap. MW	Max. Energy GWh
1	530	500	600
2	530	500	600

PS2
 Installed Capacity 500 MW
 Efficiency 76 %
 O&M (Fix) 0.55 \$/kW-month
 Available Year 2016

Period	Pump Cap. MW	Gen. Cap. MW	Max. Energy GWh
1	530	500	600
2	530	500	600

PUMP STORAGE (Matenggeng)

PS3
 Installed Capacity 1000 MW
 Efficiency 76 %
 O&M (Fix) 0.55 \$/kW-month
 Available Year 2019

Period	Pump Cap. MW	Gen. Cap. MW	Max. Energy GWh
1	530	500	450
2	530	500	450

PUMP STORAGE (Grindulu)

PS4
 Installed Capacity 1000 MW
 Efficiency 76 %
 O&M (Fix) 0.55 \$/kW-month
 Available Year 2019

Period	Pump Cap. MW	Gen. Cap. MW	Max. Energy GWh
1	530	500	450
2	530	500	450

Hydropower Project

	MANG (Maung)	CIB3 (Cibuni-3)	CPSG (Cipasang)	CMD3(Cimandiri-3)
Construction Cost \$/kW	1872 Inc.IDC	2,865 Inc.IDC	1,636 Inc.IDC	1,998 Inc.IDC
Installed Caapcity MW	360	172	400	238
Reservoir Energy GWh	535	568	751	600
Inflow Energy wet GWh	430	450	600	480
dry GWh	160	170	230	180
Minimum Generation wet GWh	320	340	450	360
dry GWh	80	90	110	90
Average Capacity wet MW	360	172	400	238
dry MW	360	172	400	238
Construction Period year	5	5	5	5
I.D.C (%)	22.6	22.6	22.6	22.6

Source: Hydro Inventory and Pre-feasibility Studies, June 1999, Nippon Koei Co., Ltd.

Construction Cost inc. IDC

PLANT	CAPITAL COSTS (\$/kW)				PLANT LIFE YEARS	D.R.=12% I.D.C. (%)	CONSTR. TIME (YEARS)
	DEPRECIABLE PART		NON-DEPRECIABLE PART				
	DOMESTIC	FOREIGN	DOMESTIC	FOREIGN			
C6H	444	1,037	0	0	30	18.46	4
C10H	611	1,425	0	0	30	18.46	4
LNG	300	699	0	0	25	14.13	3
N10H	659	2,637	0	0	40	26.6	6
G150	82	466	0	0	20	9.6	2
PS 1&2	271	584	0	0	50	22.6	5
PS 3	252	541	0	0	50	22.6	5
PS 4	268	579	0	0	50	22.6	5
GE55	444	1,776	0	0	30	14.13	3
J-SIC	308	2,051	0	0	30	18.46	4

Java - Sumatra Interconnection (HVDC)

			Note
1. Investment Cost for HVDC			
EPC Cost	1,370	M.US\$	
Land Acquisition + ROW	160	M.US\$	
Total Investment Cost	1,530	M.US\$	
2. Construction Cost for HVDC	510	\$/kW	Divided by 3000 MW
3. Construction Cost of C6H	1,481	\$/kW	Referred to P3B Data
4. Total Investment Cost	1,991	\$/kW	


Source: Updated Feasibility Study Java - Sumatera Interconnection, Sep. 2007

WASP IV Screening Curve

Fuel Prices Scenario Index	2	Medium Scenario							
		PLTU	LNG	PLTN	PLTG	PLTU10	PLTP	Interc.	
Installed Capacity	MW	600	750	1000	150	1000	55	3000	
Fuel Type		coal	LNG	nuclear	HSD	coal	Geothermal	HVDC T/L	
Fuel Price	\$/MMBTU	3.80	10.00	0.63	23.24	3.80	16.20	3.80	
Thermal Efficiency	%	35%	47%	33%	30%	35%	86%	35%	
Variabel O&M	\$/MWh	2.0	1.0	0.4	2.0	2.0	1.0	2.0	
Fixed O&M	\$/KW.year	31.32	19.2	55.92	11.64	31.32	30.00	31.68	
Investment Cost inc. IDC	\$/KW	1,481	999	3,296	548	2,036	2,220	2,359	
Construction Period	Years	4	3	6	2	4	3	4	
Book Life	Years	30	25	40	20	30	30	30	
Discount Rate		12.00%	12.00%	12.00%	12.00%	12.00%	12.00%	12.00%	
Capital Recovery Factor (CRF)		12.41%	12.75%	12.13%	13.39%	12.41%	12.41%	12.41%	
Interest During Construction (IDC)		18.46%	14.13%	26.60%	9.60%	18.46%	14.13%	14.13%	
Annual Investment cost	\$/KW.year	183.86	127.37	399.82	73.37	252.76	275.60	292.75	
Annual Fixed Cost	\$/KW.year	215.18	146.57	455.74	85.01	284.08	305.60	324.43	
Annual Fuel Cost	\$/KW.year	324.58	636.07	57.07	2315.88	323.65	563.14	323.65	
Annual Variable O&M	\$/KW.year	17.52	8.76	3.59	17.52	17.52	8.76	17.52	
Annual Variable Cost	\$/KW.year	342.10	644.83	60.66	2333.40	341.17	571.90	341.17	
Annual Fixed Cost	\$/KW.year	215.18	146.57	455.74	85.01	284.08	305.60	324.43	
Total	\$/KW.year	557.28	791.40	516.40	2418.41	625.25	877.50	665.60	
CF		0%	215.18	146.57	455.74	85.01	284.08	305.60	324.43
		100%	557.28	791.40	516.40	2418.41	625.25	877.50	665.60

Index	Fuel Prices \$/MMBTU		
	Low	Medium	High
Coal	3.33	3.80	4.28
LNG	8.00	10.00	12.00
N.Gas	4.00	5.00	6.00
Nuclear	0.57	0.63	0.69
HSD	19.57	23.24	26.91
MFO	11.50	13.70	15.90
Geothermal	14.58	16.20	17.82

Note: \$/MMBTU is referred to "Fuel Price Sheet" except Nuclear.



INPUT REMERSIM (Fuel Consumption per GWh)

No.	Name	Type	No. of Sets	Min. Load MW	Capacity MW	Heat Rates (kcal/kWh)			Fuel Type	Heat Value kcal/kg 100kcal/MMBT U kcal/liter	Fuel Consumption (unit/GWh) at FLD			
						Base Load	Average Incremental	At FLD			1,000 ton	1,000 MMBTU	1,000 KL	Geo
1	SRL1	PLTU	4	240	381	2,622	2,452	2,559	0	5,100	0.502			
2	SRL2	PLTU	3	340	579	2,560	2,309	2,456	0	5,100	0.482			
3	MKR1	PLTU	3	44	84	3,273	3,194	3,235	3	9,598			0.337	
4	MKR2	PLTG	2	90	165	2,948	2,884	2,919	1	2,520		11.58		
5	MKR3	PLTGU	1	300	465	2,433	2,018	2,286	1	2,520		9.07		
6	MKRR	PLTGU	-	500	750	2,433	2,018	2,295	1	2,520		9.11		
7	PRK1	PLTU	2	25	48	3,229	2,957	3,099	3	9,598			0.323	
8	PRK2	PLTGU	2	315	560	2,319	1,994	2,177	4	9,095			0.239	
9	PRK3	PLTG	2	10	20	4,711	3,930	4,321	4	9,095			0.475	
10	PRKE	PLTGU	-	500	750	2,433	2,018	2,295	1	2,520		9.11		
11	MTR1	PLTGU	1	315	605	2,555	2,246	2,407	4	9,095			0.265	
12	MTR2	PLTG	2	72	138	3,376	3,204	3,294	4	9,095			0.362	
13	MTR3	PLTG	6	72	143	3,376	3,204	3,291	4	9,095			0.362	
14	MTRR	PLTGU	-	150	225	2,433	2,018	2,295	1	2,520		9.11		
15	SLK1	PLTP	3	52	52	1,000	1,000	1,000	5	7,308				-
16	SLK2	PLTP	3	52	52	1,000	1,000	1,000	5	7,308				-
17	CLND	PLTG	1	50	150	4,465	3,200	3,622	1	2,520		14.37		
18	CLGN	PLTGU	1	240	740	2,175	1,800	1,922	1	2,520		7.63		
19	SRL3	PLTU	-	340	600	2,560	2,309	2,451	0	4,200	0.584			
20	LBHN	PLTU	-	150	300	2,622	2,452	2,537	0	4,200	0.604			
21	TLNG	PLTU	-	150	300	2,622	2,452	2,537	0	4,200	0.604			
22	KMJ1	PLTP	1	26	26	1,000	1,000	1,000	5	7,308				-
23	KMJ2	PLTP	2	47	47	1,000	1,000	1,000	5	7,308				-
24	KMJ3	PLTP	1	60	60	1,000	1,000	1,000	5	7,308				-
25	DRJ1	PLTP	1	44	44	1,000	1,000	1,000	5	7,308				-
26	DRJ2	PLTP	1	70	70	1,000	1,000	1,000	5	5,300				-
27	DRJ3	PLTP	1	110	110	1,000	1,000	1,000	5	7,308				-
28	WW1	PLTP	1	110	110	1,000	1,000	1,000	5	7,308				-
29	SRG1	PLTG	2	8	18	4,700	4,084	4,358	1	2,520		17.29		
30	SRG2	PLTG	2	8	20	4,700	4,084	4,330	4	9,095			0.476	
31	PTH1	PLTP	-	60	60	1,000	1,000	1,000	5	7,308				-
32	JBSL	PLTU	-	150	300	2,590	2,115	2,353	0	4,200	0.560			
33	JBUT	PLTU	-	150	300	2,590	2,115	2,353	0	4,200	0.560			
34	CRBN	PLTU	-	360	600	2,560	2,160	2,400	0	5,300	0.453			
35	TBK1	PLTGU	2	297	496	2,632	2,015	2,384	4	9,095			0.262	
36	TBK2	PLTU	2	25	41	3,229	3,127	3,189	3	9,598			0.332	
37	TBK3	PLTU	1	125	192	3,229	3,127	3,193	3	9,598			0.333	
38	CLC1	PLTG	2	10	22	4,700	4,079	4,361	4	9,095			0.479	
39	CLC2	PLTU	2	150	300	2,772	2,285	2,529	0	5,215	0.485			
40	TJB1	PLTU	2	330	660	2,772	2,285	2,529	0	5,215	0.485			
41	TJB2	PLTU	-	360	600	2,560	2,160	2,400	0	4,500	0.533			
42	DIEN	PLTP	1	60	60	1,000	1,000	1,000	5	7,308				-
43	RMBG	PLTU	-	150	300	2,590	2,115	2,353	0	4,500	0.523			
44	PTN1	PLTU	2	225	370	2,579	2,412	2,514	0	5,100	0.493			
45	PTN2	PLTU	-	340	600	2,560	2,309	2,451	0	4,500	0.545			
46	PEC	PLTU	2	368	615	2,772	2,285	2,576	0	5,215	0.494			
47	JPOW	PLTU	2	355	610	2,700	2,310	2,537	0	5,500	0.461			
48	GSK1	PLGU	3	250	480	2,318	1,990	2,161	1	2,520		8.58		
49	GSK2	PLTG	2	5	16	4,456	4,284	4,338	1	2,520		17.21		
50	GSK3	PLTU	2	43	85	2,882	2,709	2,797	1	2,520		11.10		
51	GSK4	PLTU	2	90	175	2,826	2,601	2,717	1	2,520		10.78		
52	PRAK	PLTU	2	25	48	4,323	3,517	3,937	3	9,598			0.410	
53	GRT1	PLTGU	1	270	462	2,632	2,083	2,404	4	9,095			0.264	
54	GRT2	PLTG	3	40	100	3,376	3,310	3,336	4	9,095			0.367	
55	PMRN	PLTG	2	12	48	4,439	4,035	4,136	4	9,095			0.455	
56	GLMR	PLTG	2	5	16	4,456	4,284	4,338	4	9,095			0.477	
57	GLMK	PLTG	1	56	133	4,439	4,035	4,205	4	9,095			0.462	
58	BLI1	PLTG	4	6	20	4,700	4,131	4,302	4	9,095			0.473	
59	BLI2	PLTD	10	2	5	3,880	3,576	3,698	4	9,095			0.407	
60	BLUT	PLTU	-	65	130	2,590	2,115	2,353	0	5,300	0.444			
61	BDGL	PLTP	-	10	10	1,000	1,000	1,000	5	7,308				-
62	TJAW	PLTU	-	150	300	2,590	2,115	2,353	0	4,500	0.523			
63	JTSL	PLTU	-	150	300	2,590	2,115	2,353	0	4,500	0.523			

No.	Name	Type	No. of Sets	Min. Load MW	Capacity MW	Heat Rates (kcal/kWh)			Fuel Type	Heat Value kcal/kg 100kcal/MMBT U kcal/liter	Fuel Consumption (unit/GWh) a FLD			
						Base Load	Average Incremental	At FLD			1,000 ton	1,000 MMBTU	1,000 KL	Geo Nuclear
1	C6H	PLTU	0	300	600	2510	2389	2,450	0	4,766	0.514			
2	C10H	PLTU	0	500	1000	2510	2389	2,450	0	4,766	0.514			
3	LNG	PLTG	0	375	750	1911	1741	1,826	2	2,520		7.25		
4	N10H	PLTN	0	1000	1000	2606	2606	2,606	6	0				-
5	GE55	PLTP	0	44	55	1000	1000	1,000	5	0				-
6	G150	PLTG	0	75	150	3150	2625	2,888	4	9,095			0.318	
7	J-SIC	J-SI	5	300	600	2510	2389	2,450	7	0				-

Assumption of Fuel Prices (Medium Scenario)

Kind of Fuel	Price		Heat Content	
	USD		Cents/mKcal	
Coal	80.0	per Ton	1,509	5,300 Kcal/kg
LNG	10.0	per MMBTU	3,968	252,000 Kcal/mmbtu
Gas	5.0	per MMBTU	1,984	252,000 Kcal/mmbtu
HSD	133.0	per Barrel	9,222	9,070 Kcal/l
MFO	81.0	per Barrel	5,437	9,370 Kcal/l
Geothermal	0.0553	per kWh	6,430	
Nuclear			250	

Price Crude Oil	95	\$/barrel		
HSD	133	\$/barrel	23.24	\$/mmbtu
MFO	81	\$/barrel	13.70	\$/mmbtu
LNG+transport	10.0	\$/mmbtu		
transport	0.7	\$/mmbtu		
LNG	9.3	\$/mmbtu	9.30	\$/mmbtu
Gas	5.0	\$/mmbtu	5.00	\$/mmbtu
Coal+transport	80	\$/ton	3.80	\$/mmbtu
transport	18	\$/ton		
Coal	74	\$/ton	6,300	Kcal/kg
	62	\$/ton	5,300	Kcal/kg

Note: Coal price at P/S is CIF Price.

Heat (HSD)	19,500	btu/lb	1 kg =	2.2 lb
	10,811	Kcal/kg	berat jenis =	0.839 kg/l
	9,070	Kcal/l		
MFO	18,000	btu/lb	1 kg =	2.2 lb
	9,979	Kcal/kg	berat jenis =	0.939 kg/l
	9,370	Kcal/l		

Reference 2: Relationship between MOPS and Domestic Prices

MOPS (2008/03/31 ~ 2008/04/04)	
	\$/barrel
High Speed Diesel Oil (0.05%)	132.02
Kerosene	128.36
Crude Oil	104.30

Note: HSD and Kerosene are FOB at Singapore

MOPS means Mean of Platts Singapore

Source://www.gu-goon.com/

PERTAMINA Price		Price Index (IP)
	\$/barrel	
HSD	145.93	1.40
MFO	89.14	0.85
Crude Oil	104.30	1.00

Note : 1 barrel = 159 liter

New Fuel Prices for Industry in April 2008 released by PERTAMINA on March 31, 2008						
Fuel Type	Economical Selling Fuel Price - Non Tax (Base Price)					
	Region 1		Region 2		Region 3	
	Rp/KL	US\$/KL	Rp/KL	US\$/KL	Rp/KL	US\$/KL
Gasoline	7080.13	768.17	7352.107	797.68	7508.057	814.60
Kerosene	8532.07	925.76	8718.104	945.94	8903.029	966.01
High Speed Diesel	8458.78	917.77	8819.464	956.91	9006.539	977.20
Marine Diesel Fuel	8284.08	898.88	8464.705	918.48	8644.250	937.97
Marine Fuel Oil	5166.53	560.60	5278.949	572.80	5390.924	584.95
Pertamina DEX	8757.37	950.14	-	-	-	-

Source: www.pertamina.com/

Note : Fuel prices released by PERTAMINA depend on MOPS.

Peak Load Ratio



Period	Peak Load Ratio
--------	-----------------

Generation Energy and Peak Load

Year	Energy Sale	Station Use	T & D Loss	Generation Energy	Less 4 % in 2008 due to PV, Wind, Bio	Generation Energy after Less	Load Factor	Peak Load	Growth Rate of P.L.
	GWh	% of Generation Energy		GWh		GWh			
2009	109,227	4%	11.00%	127,841	-	127,841	75.5%	19,329	
2010	116,480	4%	10.90%	136,177	-	136,177	75.7%	20,535	6.2%
2011	124,169	4%	10.80%	145,003	-	145,003	75.9%	21,809	6.2%
2012	132,320	4%	10.70%	154,349	-	154,349	76.1%	23,153	6.2%
2013	140,962	4%	10.60%	164,245	-	164,245	76.3%	24,573	6.1%
2014	150,124	4%	10.50%	174,725	-	174,725	76.5%	26,073	6.1%
2015	159,838	4%	10.40%	185,824	-	185,824	76.7%	27,657	6.1%
2016	170,137	4%	10.30%	197,576	-	197,576	76.7%	29,406	6.3%
2017	181,057	4%	10.20%	210,023	-	210,023	76.5%	31,340	6.6%
2018	192,636	4%	10.10%	223,206	-	223,206	76.3%	33,395	6.6%
2019	204,913	4%	10.00%	237,168	-	237,168	76.1%	35,577	6.5%
2020	217,933	4%	9.90%	251,957	-	251,957	75.9%	37,895	6.5%
2021	231,738	4%	9.80%	267,621	1%	264,945	75.7%	39,954	5.4%
2022	246,379	4%	9.70%	284,214	1%	281,372	75.5%	42,543	6.5%
2023	261,905	4%	9.60%	301,790	2%	295,754	75.3%	44,836	5.4%
2024	278,371	4%	9.50%	320,409	2%	314,001	75.1%	47,730	6.5%
2025	295,834	4%	9.40%	340,133	3%	329,929	74.9%	50,285	5.4%
2026	314,355	4%	9.30%	361,029	3%	350,198	74.7%	53,517	6.4%
2027	333,999	4%	9.20%	383,167	4%	367,840	74.5%	56,364	5.3%
2028	354,835	4%	9.10%	406,622	4%	390,357	74.3%	59,975	6.4%

LDC for the Year 2006
(Based on P3B 2006 Data)

No.	Load	Duration	Area
1	1.0000	0.00000	
5	0.8855	0.08333	0.0186
6	0.8736	0.10417	0.0183
7	0.8632	0.12500	0.0181
8	0.8532	0.14583	0.0179
9	0.8437	0.16667	0.0177
10	0.8357	0.18750	0.0175
11	0.8275	0.20833	0.0173
12	0.8213	0.22917	0.0172
13	0.8155	0.25000	0.0170
14	0.8102	0.27083	0.0169
15	0.8060	0.29167	0.0168
16	0.8019	0.31250	0.0167
17	0.7977	0.33333	0.0167
18	0.7930	0.35417	0.0166
19	0.7889	0.37500	0.0165
20	0.7839	0.39583	0.0164
21	0.7790	0.41667	0.0163
22	0.7744	0.43750	0.0162
23	0.7697	0.45833	0.0161
24	0.7646	0.47917	0.0160
25	0.7593	0.50000	0.0159
26	0.7535	0.52083	0.0212
27	0.7479	0.54167	0.0102
28	0.7425	0.56250	0.0155
29	0.7367	0.58333	0.0154
30	0.7309	0.60417	0.0153
31	0.7255	0.62500	0.0152
32	0.7203	0.64583	0.0151
33	0.7154	0.66667	0.0150
34	0.7112	0.68522	0.0132
35	0.7058	0.70833	0.0164
36	0.7006	0.72917	0.0147
37	0.6949	0.75000	0.0145
38	0.6893	0.77083	0.0144
39	0.6830	0.79167	0.0143
40	0.6770	0.81250	0.0142
41	0.6694	0.83333	0.0140
42	0.6599	0.85417	0.0139
43	0.6499	0.87500	0.0136
44	0.6380	0.89583	0.0134
45	0.6242	0.91667	0.0132
46	0.6086	0.93750	0.0128
47	0.5932	0.95833	0.0125
48	0.5631	0.97917	0.0120
49	0.3957	1.00000	0.0100
50			
51			
52			
Area (Load Factor) =			0.7551



Addition/Retirements

No.	Name	No. of Sets	Available Capacity MW	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	
Supply Balance Information				2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	
Available capacity of thermal				18,816																						
installed capacity of hydro				2,573																						
Gross available capacity				21,389	21,389	21,389	24,389	28,305	29,988	30,955	30,955	30,955	31,065	31,065	29,512	28,811	27,813	27,813	27,813	27,208	27,208	27,208	27,208	27,208	27,208	27,208
Addition/Retirement						3,000	3,916	1,683	967			110		(1,553)	(701)	(998)			(605)							
Gross available capacity(year end)				21,389	21,389	24,389	28,305	29,988	30,955	30,955	30,955	31,065	31,065	29,512	28,811	27,813	27,813	27,813	27,208	27,208	27,208	27,208	27,208	27,208	27,208	27,208
Peak Load at Power Station				-	-	19,329	20,535	21,809	23,153	24,573	26,073	27,657	29,406	31,340	33,395	35,577	37,895	39,954	42,543	44,836	47,730	50,285	53,517	56,364	59,975	
				2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	
C6H	PLTU	600																								
C10H	PLTU	1000							1	1	1	1	1	5	5	7	7	9	10	13	13	16	17	20	24	
LNG	PLTG	750										1	2	3	4	4	6	6	8	8	10	10	12	12	12	
N10H	PLTN	1000													1	1	1	2	2	3	3	4	4	5	5	
GE55	PLTP	55					6	6	6	10	12	14	16	18	20	22	24	26	28	30	32	34	36	38	38	
G150	PLTG	150													3	4	4	6	6	8	8	10	12	12	12	
PS	Pumped S.	500										1	2	2	4	6	6	6	6	6	6	6	6	6	6	
CIB3	PLTA	172															1	1	1	1	1	1	1	1	1	
CPSG	PLTA	400															1	1	1	1	1	1	1	1	1	
CMD3	PLTA	238															1	1	1	1	1	1	1	1	1	
MANG	PLTA	360															1	1	1	1	1	1	1	1	1	
PLTA	PLTA	300																1	1	1	1	1	1	1	1	
Java-Sumatra I.C.		600									4	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
C6H	PLTU	600																								
C10H	PLTU	1000							1,000	1,000	1,000	1,000	1,000	5,000	5,000	7,000	7,000	9,000	10,000	13,000	13,000	16,000	17,000	20,000	24,000	
LNG	PLTG	750										750	1,500	2,250	3,000	3,000	4,500	4,500	6,000	6,000	7,500	7,500	9,000	9,000	9,000	
N10H	PLTN	1000													1,000	1,000	1,000	2,000	2,000	2,000	3,000	3,000	4,000	4,000	5,000	
GE55	PLTP	55					330	330	330	550	660	770	880	990	1,100	1,210	1,320	1,430	1,540	1,650	1,760	1,870	1,980	2,090	2,090	
G150	PLTG	150													450	600	600	900	900	1,200	1,200	1,500	1,800	1,800	1,800	
PS	Pumped S.	500										500	1,000	1,000	2,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	
CIB3	PLTA	172															172	172	172	172	172	172	172	172	172	
CPSG	PLTA	400															400	400	400	400	400	400	400	400	400	
CMD3	PLTA	238															238	238	238	238	238	238	238	238	238	
MANG	PLTA	360															360	360	360	360	360	360	360	360	360	
PLTA	PLTA	300																900	900	1,800	1,800	1,800	2,100	2,100	2,100	
Java-Sumatera I.C.		600									2,400	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	
Total Additional Capacity							-	-	330	1,330	1,330	3,950	5,910	7,270	12,130	14,990	18,550	21,480	24,590	28,400	31,510	35,320	38,430	42,340	46,050	51,160
Total Supply Capacity at year end							24,389	28,305	30,318	32,285	32,285	34,905	36,975	38,335	41,642	43,801	46,363	49,293	52,403	55,608	58,718	62,528	65,638	69,548	73,258	78,368
Reserve Margin				%			26.2%	37.8%	39.0%	39.4%	31.4%	33.9%	33.7%	30.4%	32.9%	31.2%	30.3%	30.1%	31.2%	30.7%	31.0%	31.0%	30.5%	30.0%	30.0%	30.7%

FIXSYS HYDRO

PLTA	Index	Installed Cap. [MW]	Energy Storage (GWh)	Inflow Energy				Min. Generation				Average Capacity			
				I(Wet)	II(Dry)	III	IV	I(Wet)	II(Dry)	III	IV	I(Wet)	II(Dry)	III	IV
				[GWh]	[GWh]	[GWh]	[GWh]	[GWh]	[GWh]	[GWh]	[GWh]	[MW]	[MW]	[MW]	[MW]
Jatiluhur #1-6	JTLH	180	842.6	315.8	376.9			204.3	298			180	180		
Saguling	SAGL	700.7	2,520.7	1292	680.8			999.2	400.6			701	701		
IP- Area I	IPA1	37.26	-	70.5	53.9			61.8	37.8			37	37		
IP- Area II	IPA2	59.38	-	143.1	78.9			112.3	56.7			59	59		
Sudirman	MRTC	180.9	489.8	356.9	79.7			277.3	18			181	181		
IP-Area III	APA3	125.54	-	264.1	199			235.8	166.3			126	126		
Sutami	STMI	105	451.1	263.2	155.5			164.6	127.5			105	105		
EP Non Suami	EPNS	134.5	563.5	312.3	175.8			223	115.8			135	135		
Brantas Non EP	BNEP	41.9	-	47.3	41.2			17.1	11.3			42	42		
Cirata	CRI2	1008	1,377.0	648.2	444.9			487.8	256			1008	1008		
Rajamandala	RJMD	47	90.0	82.0	61.8			70.0	52.5			47	47		
Jatigede	JTGD	110	620.0	216.8	72.3			184.3	61.4			110	110		

INPUT VARYSYS

No.	Name	No. of Sets	Min. Load MW	Capacity MW	Heat Rates		Fuel Costs		Fuel Type	Spinning Reserves	FOR	Days Scheduled Maintenance Days	Maintenance Class Size MW	O&M (FIX) \$/kWm	O&M (VAR) \$/MWh	FLD HEAT RT KCAL/KWH	UNIT GENERATION COSTS (\$/MWH)				
					Kcal/kWh Base Load	Kcal/kWh Average Incremental	Cents/Million Kcal Domestic	Cents/Million Kcal Foreign									BASE DOM	BASE FRGN	FLD DOM	FLD FRGN	FLD TOT
1	C6H	0	300	600	2510	2389	1509	0	0	5	7	42	600	2.61	2.00	2450	39.9	0.0	39.0	0.0	39.0
2	C10H	0	500	1000	2510	2389	1509	0	0	5	7	42	1000	2.61	2.00	2450	39.9	0.0	39.0	0.0	39.0
3	LNG	0	375	750	1911	1741	0	3968	2	7	7	42	750	1.60	1.00	1826	1.0	75.8	1.0	72.5	73.5
4	N10H	0	1000	1000	2606	2606	0	250	6	0	7	28	1000	4.66	0.41	2606	0.4	6.5	0.4	6.5	6.9
5	GE55	0	44	55	1000	1000	6430	0	5	0	7	28	55	2.50	1.00	1000	65.3	0.0	65.3	0.0	65.3
6	G150	0	75	150	3150	2625	9222	0	4	10	7	28	150	0.97	2.00	2888	292.5	0.0	268.3	0.0	268.3
7	J-SIC	5	300	600	2510	2389	1509	0	7	5	8	45	600	2.64	2.00	2450	39.9	0.0	39.0	0.0	39.0

PUMP STORAGE (Upper Cisokan)

PS1
 Installed Capacity 500 MW
 Efficiency 76 %
 O&M (Fix) 0.55 \$/kW-month
 Available Year 2015

Period	Pump Cap. MW	Gen. Cap. MW	Max. Energy GWh
1	530	500	600
2	530	500	600

PS2
 Installed Capacity 500 MW
 Efficiency 76 %
 O&M (Fix) 0.55 \$/kW-month
 Available Year 2016

Period	Pump Cap. MW	Gen. Cap. MW	Max. Energy GWh
1	530	500	600
2	530	500	600

PUMP STORAGE (Matenggeng)

PS3
 Installed Capacity 1000 MW
 Efficiency 76 %
 O&M (Fix) 0.55 \$/kW-month
 Available Year 2019

Period	Pump Cap. MW	Gen. Cap. MW	Max. Energy GWh
1	530	500	450
2	530	500	450

PUMP STORAGE (Grindulu)

PS4
 Installed Capacity 1000 MW
 Efficiency 76 %
 O&M (Fix) 0.55 \$/kW-month
 Available Year 2019

Period	Pump Cap. MW	Gen. Cap. MW	Max. Energy GWh
1	530	500	450
2	530	500	450

Hydropower Project

	MANG (Maung)	CIB3 (Cibuni-3)	CPSG (Cipasang)	CMD3(Cimandiri-3)
Construction Cost \$/kW	1872 Inc.IDC	2,865 Inc.IDC	1,636 Inc.IDC	1,998 Inc.IDC
Installed Caapcity MW	360	172	400	238
Reservoir Energy GWh	535	568	751	600
Inflow Energy wet GWh	430	450	600	480
dry GWh	160	170	230	180
Minimum Generation wet GWh	320	340	450	360
dry GWh	80	90	110	90
Average Capacity wet MW	360	172	400	238
dry MW	360	172	400	238
Construction Period year	5	5	5	5
I.D.C (%)	22.6	22.6	22.6	22.6

Source: Hydro Inventory and Pre-feasibility Studies, June 1999, Nippon Koei Co., Ltd.

Construction Cost inc. IDC

PLANT	CAPITAL COSTS (\$/kW)				PLANT LIFE YEARS	D.R.=12% I.D.C. (%)	CONSTR. TIME (YEARS)
	DEPRECIABLE PART		NON-DEPRECIABLE PART				
	DOMESTIC	FOREIGN	DOMESTIC	FOREIGN			
C6H	444	1,037	0	0	30	18.46	4
C10H	611	1,425	0	0	30	18.46	4
LNG	300	699	0	0	25	14.13	3
N10H	659	2,637	0	0	40	26.6	6
G150	82	466	0	0	20	9.6	2
PS 1&2	271	584	0	0	50	22.6	5
PS 3	252	541	0	0	50	22.6	5
PS 4	268	579	0	0	50	22.6	5
GE55	444	1,776	0	0	30	14.13	3
J-SIC	308	2,051	0	0	30	18.46	4

Java - Sumatra Interconnection (HVDC)

			Note
1. Investment Cost for HVDC			
EPC Cost	1,370	M.US\$	
Land Acquisition + ROW	160	M.US\$	
Total Investment Cost	1,530	M.US\$	
2. Construction Cost for HVDC	510	\$/kW	Divided by 3000 MW
3. Construction Cost of C6H	1,481	\$/kW	Referred to P3B Data
4. Total Investment Cost	1,991	\$/kW	

Source: Updated Feasibility Study Java - Sumatera Interconnection, Sep. 2007

WASP IV Screening Curve

Fuel Prices Scenario Index	2	Medium Scenario							
		PLTU	LNG	PLTN	PLTG	PLTU10	PLTP	Interc.	
Installed Capacity	MW	600	750	1000	150	1000	55	3000	
Fuel Type		coal	LNG	nuclear	HSD	coal	Geothermal	HVDC T/L	
Fuel Price	\$/MMBTU	3.80	10.00	0.63	23.24	3.80	16.20	3.80	
Thermal Efficiency	%	35%	47%	33%	30%	35%	86%	35%	
Variabel O&M	\$/MWh	2.0	1.0	0.4	2.0	2.0	1.0	2.0	
Fixed O&M	\$/KW.year	31.32	19.2	55.92	11.64	31.32	30.00	31.68	
Investment Cost inc. IDC	\$/KW	1,481	999	3,296	548	2,036	2,220	2,359	
Construction Period	Years	4	3	6	2	4	3	4	
Book Life	Years	30	25	40	20	30	30	30	
Discount Rate		12.00%	12.00%	12.00%	12.00%	12.00%	12.00%	12.00%	
Capital Recovery Factor (CRF)		12.41%	12.75%	12.13%	13.39%	12.41%	12.41%	12.41%	
Interest During Construction (IDC)		18.46%	14.13%	26.60%	9.60%	18.46%	14.13%	14.13%	
Annual Investment cost	\$/KW.year	183.86	127.37	399.82	73.37	252.76	275.60	292.75	
Annual Fixed Cost	\$/KW.year	215.18	146.57	455.74	85.01	284.08	305.60	324.43	
Annual Fuel Cost	\$/KW.year	324.58	636.07	57.07	2315.88	323.65	563.14	323.65	
Annual Variable O&M	\$/KW.year	17.52	8.76	3.59	17.52	17.52	8.76	17.52	
Annual Variable Cost	\$/KW.year	342.10	644.83	60.66	2333.40	341.17	571.90	341.17	
Annual Fixed Cost	\$/KW.year	215.18	146.57	455.74	85.01	284.08	305.60	324.43	
Total	\$/KW.year	557.28	791.40	516.40	2418.41	625.25	877.50	665.60	
CF		0%	215.18	146.57	455.74	85.01	284.08	305.60	324.43
		100%	557.28	791.40	516.40	2418.41	625.25	877.50	665.60

Index	Fuel Prices \$/MMBTU		
	Low	Medium	High
Coal	3.33	3.80	4.28
LNG	8.00	10.00	12.00
N.Gas	4.00	5.00	6.00
Nuclear	0.57	0.63	0.69
HSD	19.57	23.24	26.91
MFO	11.50	13.70	15.90
Geothermal	14.58	16.20	17.82

Note: \$/MMBTU is referred to "Fuel Price Sheet" except Nuclear.



INPUT REMERSIM (Fuel Consumption per GWh)

No.	Name	Type	No. of Sets	Min. Load MW	Capacity MW	Heat Rates (kcal/kWh)			Fuel Type	Heat Value kcal/kg 100kcal/MMBT U kcal/liter	Fuel Consumption (unit/GWh) at FLD			
						Base Load	Average Incremental	At FLD			1,000 ton	1,000 MMBTU	1,000 KL	Geo
1	SRL1	PLTU	4	240	381	2,622	2,452	2,559	0	5,100	0.502			
2	SRL2	PLTU	3	340	579	2,560	2,309	2,456	0	5,100	0.482			
3	MKR1	PLTU	3	44	84	3,273	3,194	3,235	3	9,598			0.337	
4	MKR2	PLTG	2	90	165	2,948	2,884	2,919	1	2,520		11.58		
5	MKR3	PLTGU	1	300	465	2,433	2,018	2,286	1	2,520		9.07		
6	MKRR	PLTGU	-	500	750	2,433	2,018	2,295	1	2,520		9.11		
7	PRK1	PLTU	2	25	48	3,229	2,957	3,099	3	9,598			0.323	
8	PRK2	PLTGU	2	315	560	2,319	1,994	2,177	4	9,095			0.239	
9	PRK3	PLTG	2	10	20	4,711	3,930	4,321	4	9,095			0.475	
10	PRKE	PLTGU	-	500	750	2,433	2,018	2,295	1	2,520		9.11		
11	MTR1	PLTGU	1	315	605	2,555	2,246	2,407	4	9,095			0.265	
12	MTR2	PLTG	2	72	138	3,376	3,204	3,294	4	9,095			0.362	
13	MTR3	PLTG	6	72	143	3,376	3,204	3,291	4	9,095			0.362	
14	MTRR	PLTGU	-	150	225	2,433	2,018	2,295	1	2,520		9.11		
15	SLK1	PLTP	3	52	52	1,000	1,000	1,000	5	7,308				-
16	SLK2	PLTP	3	52	52	1,000	1,000	1,000	5	7,308				-
17	CLND	PLTG	1	50	150	4,465	3,200	3,622	1	2,520		14.37		
18	CLGN	PLTGU	1	240	740	2,175	1,800	1,922	1	2,520		7.63		
19	SRL3	PLTU	-	340	600	2,560	2,309	2,451	0	4,200	0.584			
20	LBHN	PLTU	-	150	300	2,622	2,452	2,537	0	4,200	0.604			
21	TLNG	PLTU	-	150	300	2,622	2,452	2,537	0	4,200	0.604			
22	KMJ1	PLTP	1	26	26	1,000	1,000	1,000	5	7,308				-
23	KMJ2	PLTP	2	47	47	1,000	1,000	1,000	5	7,308				-
24	KMJ3	PLTP	1	60	60	1,000	1,000	1,000	5	7,308				-
25	DRJ1	PLTP	1	44	44	1,000	1,000	1,000	5	7,308				-
26	DRJ2	PLTP	1	70	70	1,000	1,000	1,000	5	5,300				-
27	DRJ3	PLTP	1	110	110	1,000	1,000	1,000	5	7,308				-
28	WW1	PLTP	1	110	110	1,000	1,000	1,000	5	7,308				-
29	SRG1	PLTG	2	8	18	4,700	4,084	4,358	1	2,520		17.29		
30	SRG2	PLTG	2	8	20	4,700	4,084	4,330	4	9,095			0.476	
31	PTH1	PLTP	-	60	60	1,000	1,000	1,000	5	7,308				-
32	JBSL	PLTU	-	150	300	2,590	2,115	2,353	0	4,200	0.560			
33	JBUT	PLTU	-	150	300	2,590	2,115	2,353	0	4,200	0.560			
34	CRBN	PLTU	-	360	600	2,560	2,160	2,400	0	5,300	0.453			
35	TBK1	PLTGU	2	297	496	2,632	2,015	2,384	4	9,095			0.262	
36	TBK2	PLTU	2	25	41	3,229	3,127	3,189	3	9,598			0.332	
37	TBK3	PLTU	1	125	192	3,229	3,127	3,193	3	9,598			0.333	
38	CLC1	PLTG	2	10	22	4,700	4,079	4,361	4	9,095			0.479	
39	CLC2	PLTU	2	150	300	2,772	2,285	2,529	0	5,215	0.485			
40	TJB1	PLTU	2	330	660	2,772	2,285	2,529	0	5,215	0.485			
41	TJB2	PLTU	-	360	600	2,560	2,160	2,400	0	4,500	0.533			
42	DIEN	PLTP	1	60	60	1,000	1,000	1,000	5	7,308				-
43	RMBG	PLTU	-	150	300	2,590	2,115	2,353	0	4,500	0.523			
44	PTN1	PLTU	2	225	370	2,579	2,412	2,514	0	5,100	0.493			
45	PTN2	PLTU	-	340	600	2,560	2,309	2,451	0	4,500	0.545			
46	PEC	PLTU	2	368	615	2,772	2,285	2,576	0	5,215	0.494			
47	JPOW	PLTU	2	355	610	2,700	2,310	2,537	0	5,500	0.461			
48	GSK1	PLGU	3	250	480	2,318	1,990	2,161	1	2,520		8.58		
49	GSK2	PLTG	2	5	16	4,456	4,284	4,338	1	2,520		17.21		
50	GSK3	PLTU	2	43	85	2,882	2,709	2,797	1	2,520		11.10		
51	GSK4	PLTU	2	90	175	2,826	2,601	2,717	1	2,520		10.78		
52	PRAK	PLTU	2	25	48	4,323	3,517	3,937	3	9,598			0.410	
53	GRT1	PLTGU	1	270	462	2,632	2,083	2,404	4	9,095			0.264	
54	GRT2	PLTG	3	40	100	3,376	3,310	3,336	4	9,095			0.367	
55	PMRN	PLTG	2	12	48	4,439	4,035	4,136	4	9,095			0.455	
56	GLMR	PLTG	2	5	16	4,456	4,284	4,338	4	9,095			0.477	
57	GLMK	PLTG	1	56	133	4,439	4,035	4,205	4	9,095			0.462	
58	BLI1	PLTG	4	6	20	4,700	4,131	4,302	4	9,095			0.473	
59	BLI2	PLTD	10	2	5	3,880	3,576	3,698	4	9,095			0.407	
60	BLUT	PLTU	-	65	130	2,590	2,115	2,353	0	5,300	0.444			
61	BDGL	PLTP	-	10	10	1,000	1,000	1,000	5	7,308				-
62	TJAW	PLTU	-	150	300	2,590	2,115	2,353	0	4,500	0.523			
63	JTSL	PLTU	-	150	300	2,590	2,115	2,353	0	4,500	0.523			

No.	Name	Type	No. of Sets	Min. Load MW	Capacity MW	Heat Rates (kcal/kWh)			Fuel Type	Heat Value kcal/kg 100kcal/MMBT U kcal/liter	Fuel Consumption (unit/GWh) a FLD			
						Base Load	Average Incremental	At FLD			1,000 ton	1,000 MMBTU	1,000 KL	Geo Nuclear
1	C6H	PLTU	0	300	600	2510	2389	2,450	0	4,766	0.514			
2	C10H	PLTU	0	500	1000	2510	2389	2,450	0	4,766	0.514			
3	LNG	PLTG	0	375	750	1911	1741	1,826	2	2,520		7.25		
4	N10H	PLTN	0	1000	1000	2606	2606	2,606	6	0				-
5	GE55	PLTP	0	44	55	1000	1000	1,000	5	0				-
6	G150	PLTG	0	75	150	3150	2625	2,888	4	9,095			0.318	
7	J-SIC	J-SI	5	300	600	2510	2389	2,450	7	0				-

Assumption of Fuel Prices (Medium Scenario)

Kind of Fuel	Price		Heat Content	
	USD		Cents/mKcal	
Coal	80.0	per Ton	1,509	5,300 Kcal/kg
LNG	10.0	per MMBTU	3,968	252,000 Kcal/mmbtu
Gas	5.0	per MMBTU	1,984	252,000 Kcal/mmbtu
HSD	133.0	per Barrel	9,222	9,070 Kcal/l
MFO	81.0	per Barrel	5,437	9,370 Kcal/l
Geothermal	0.0553	per kWh	6,430	
Nuclear			250	

Price Crude Oil	95	\$/barrel		
HSD	133	\$/barrel	23.24	\$/mmbtu
MFO	81	\$/barrel	13.70	\$/mmbtu
LNG+transport	10.0	\$/mmbtu		
transport	0.7	\$/mmbtu		
LNG	9.3	\$/mmbtu	9.30	\$/mmbtu
Gas	5.0	\$/mmbtu	5.00	\$/mmbtu
Coal+transport	80	\$/ton	3.80	\$/mmbtu
transport	18	\$/ton		
Coal	74	\$/ton	6,300	Kcal/kg
	62	\$/ton	5,300	Kcal/kg
Note: Coal price at P/S is CIF Price.				
Heat (HSD)	19,500	btu/lb	1 kg =	2.2 lb
	10,811	Kcal/kg	berat jenis =	0.839 kg/l
	9,070	Kcal/l		
MFO	18,000	btu/lb	1 kg =	2.2 lb
	9,979	Kcal/kg	berat jenis =	0.939 kg/l
	9,370	Kcal/l		

Reference 2: Relationship between MOPS and Domestic Prices

MOPS (2008/03/31 ~ 2008/04/04)	
	\$/barrel
High Speed Diesel Oil (0.05%)	132.02
Kerosene	128.36
Crude Oil	104.30

Note: HSD and Kerosene are FOB at Singapore

MOPS means Mean of Platts Singapore

Source://www.gu-goon.com/

PERTAMINA Price		Price Index (IP)
	\$/barrel	
HSD	145.93	1.40
MFO	89.14	0.85
Crude Oil	104.30	1.00

Note : 1 barrel = 159 liter

New Fuel Prices for Industry in April 2008 released by PERTAMINA on March 31, 2008						
Fuel Type	Economical Selling Fuel Price - Non Tax (Base Price)					
	Region 1		Region 2		Region 3	
	Rp/KL	US\$/KL	Rp/KL	US\$/KL	Rp/KL	US\$/KL
Gasoline	7080.13	768.17	7352.107	797.68	7508.057	814.60
Kerosene	8532.07	925.76	8718.104	945.94	8903.029	966.01
High Speed Diesel	8458.78	917.77	8819.464	956.91	9006.539	977.20
Marine Diesel Fuel	8284.08	898.88	8464.705	918.48	8644.250	937.97
Marine Fuel Oil	5166.53	560.60	5278.949	572.80	5390.924	584.95
Pertamina DEX	8757.37	950.14	-	-	-	-

Source: www.pertamina.com/

Note : Fuel prices released by PERTAMINA depend on MOPS.

Peak Load Ratio



Period	Peak Load Ratio
--------	-----------------

Generation Energy and Peak Load

Year	Energy Sale	Station Use	T & D Loss	Generation Energy	Less 7 % in 2008 due to PV, Wind, Bio	Generation Energy after Less	Load Factor	Peak Load	Growth Rate of P.L.
	GWh	% of Generation Energy		GWh	GWh	GWh		MW	%
2009	109,227	4%	11.00%	127,841	-	127,841	75.5%	19,329	
2010	116,480	4%	10.90%	136,177	-	136,177	75.7%	20,535	6.2%
2011	124,169	4%	10.80%	145,003	-	145,003	75.9%	21,809	6.2%
2012	132,320	4%	10.70%	154,349	-	154,349	76.1%	23,153	6.2%
2013	140,962	4%	10.60%	164,245	-	164,245	76.3%	24,573	6.1%
2014	150,124	4%	10.50%	174,725	-	174,725	76.5%	26,073	6.1%
2015	159,838	4%	10.40%	185,824	-	185,824	76.7%	27,657	6.1%
2016	170,137	4%	10.30%	197,576	-	197,576	76.7%	29,406	6.3%
2017	181,057	4%	10.20%	210,023	-	210,023	76.5%	31,340	6.6%
2018	192,636	4%	10.10%	223,206	-	223,206	76.3%	33,395	6.6%
2019	204,913	4%	10.00%	237,168	-	237,168	76.1%	35,577	6.5%
2020	217,933	4%	9.90%	251,957	-	251,957	75.9%	37,895	6.5%
2021	231,738	4%	9.80%	267,621	1%	264,945	75.7%	39,954	5.4%
2022	246,379	4%	9.70%	284,214	1%	281,372	75.5%	42,543	6.5%
2023	261,905	4%	9.60%	301,790	3%	292,736	75.3%	44,379	4.3%
2024	278,371	4%	9.50%	320,409	3%	310,797	75.1%	47,242	6.5%
2025	295,834	4%	9.40%	340,133	5%	323,126	74.9%	49,248	4.2%
2026	314,355	4%	9.30%	361,029	5%	342,978	74.7%	52,413	6.4%
2027	333,999	4%	9.20%	383,167	7%	356,345	74.5%	54,602	4.2%
2028	354,835	4%	9.10%	406,622	7%	378,158	74.3%	58,101	6.4%

LDC for the Year 2006
(Based on P3B 2006 Data)

No.	Load	Duration	Area
1	1.0000	0.00000	
5	0.8855	0.08333	0.0186
6	0.8736	0.10417	0.0183
7	0.8632	0.12500	0.0181
8	0.8532	0.14583	0.0179
9	0.8437	0.16667	0.0177
10	0.8357	0.18750	0.0175
11	0.8275	0.20833	0.0173
12	0.8213	0.22917	0.0172
13	0.8155	0.25000	0.0170
14	0.8102	0.27083	0.0169
15	0.8060	0.29167	0.0168
16	0.8019	0.31250	0.0167
17	0.7977	0.33333	0.0167
18	0.7930	0.35417	0.0166
19	0.7889	0.37500	0.0165
20	0.7839	0.39583	0.0164
21	0.7790	0.41667	0.0163
22	0.7744	0.43750	0.0162
23	0.7697	0.45833	0.0161
24	0.7646	0.47917	0.0160
25	0.7593	0.50000	0.0159
26	0.7535	0.52083	0.0212
27	0.7479	0.54167	0.0102
28	0.7425	0.56250	0.0155
29	0.7367	0.58333	0.0154
30	0.7309	0.60417	0.0153
31	0.7255	0.62500	0.0152
32	0.7203	0.64583	0.0151
33	0.7154	0.66667	0.0150
34	0.7112	0.68750	0.0132
35	0.7058	0.70833	0.0164
36	0.7006	0.72917	0.0147
37	0.6949	0.75000	0.0145
38	0.6893	0.77083	0.0144
39	0.6830	0.79167	0.0143
40	0.6770	0.81250	0.0142
41	0.6694	0.83333	0.0140
42	0.6599	0.85417	0.0139
43	0.6499	0.87500	0.0136
44	0.6380	0.89583	0.0134
45	0.6242	0.91667	0.0132
46	0.6086	0.93750	0.0128
47	0.5932	0.95833	0.0125
48	0.5631	0.97917	0.0120
49	0.3957	1.00000	0.0100
50			
51			
52			
Area (Load Factor) =			0.7551



Addition/Retirements

No.	Name	No. of Sets	Available Capacity MW	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028
-----	------	-------------	-----------------------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------

Supply Balance Information				2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	
Available capacity of thermal				18,816																						
installed capacity of hydro				2,573																						
Gross available capacity				21,389	21,389	21,389	24,389	28,305	29,988	30,955	30,955	30,955	31,065	31,065	29,512	28,811	27,813	27,813	27,813	27,208	27,208	27,208	27,208	27,208	27,208	27,208
Addition/Retirement						3,000	3,916	1,683	967			110		(1,553)	(701)	(998)			(605)							
Gross available capacity (year end)				21,389	21,389	24,389	28,305	29,988	30,955	30,955	30,955	31,065	31,065	29,512	28,811	27,813	27,813	27,813	27,208	27,208	27,208	27,208	27,208	27,208	27,208	27,208
Peak Load at Power Station				-	-	19,329	20,535	21,809	23,153	24,573	26,073	27,657	29,406	31,340	33,395	35,577	37,895	39,954	42,543	44,379	47,242	49,248	52,413	54,602	58,101	

			2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	
C6H	PLTU	600																							
C10H	PLTU	1000						1	1	1	1	1	5	5	7	7	9	10	12	12	15	16	18	21	
LNG	PLTG	750									1	2	3	4	4	6	6	8	8	10	10	12	12	12	
N10H	PLTN	1000												1	1	1	2	2	2	3	3	4	4	5	
GE55	PLTP	55					6	6	6	10	12	14	16	18	20	22	24	26	28	30	32	34	36	38	
G150	PLTG	150													3	4	4	6	6	8	8	10	12	12	
PS	Pumped S.	500										1	2	2	4	6	6	6	6	6	6	6	6	6	
CIB3	PLTA	172														1	1	1	1	1	1	1	1	1	
CPSG	PLTA	400														1	1	1	1	1	1	1	1	1	
CMD3	PLTA	238														1	1	1	1	1	1	1	1	1	
MANG	PLTA	360														1	1	1	1	1	1	1	1	1	
PLTA	PLTA	300															3	3	6	6	6	6	8	8	
Java-Sumatra I.C.		600								4	5	5	5	5	5	5	5	5	5	5	5	5	5	5	

C6H	PLTU	600																							
C10H	PLTU	1000						1,000	1,000	1,000	1,000	1,000	5,000	5,000	7,000	7,000	9,000	10,000	12,000	12,000	15,000	16,000	18,000	21,000	
LNG	PLTG	750									750	1,500	2,250	3,000	3,000	4,500	4,500	6,000	6,000	7,500	7,500	9,000	9,000	9,000	
N10H	PLTN	1000												1,000	1,000	1,000	2,000	2,000	3,000	3,000	4,000	4,000	5,000	5,000	
GE55	PLTP	55					330	330	330	550	660	770	880	990	1,100	1,210	1,320	1,430	1,540	1,650	1,760	1,870	1,980	2,090	
G150	PLTG	150													450	600	600	900	900	1,200	1,200	1,500	1,800	1,800	
PS	Pumped S.	500									500	1,000	1,000	2,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	
CIB3	PLTA	172														172	172	172	172	172	172	172	172	172	
CPSG	PLTA	400														400	400	400	400	400	400	400	400	400	
CMD3	PLTA	238														238	238	238	238	238	238	238	238	238	
MANG	PLTA	360														360	360	360	360	360	360	360	360	360	
PLTA	PLTA	300															900	900	1,800	1,800	1,800	2,400	2,400	2,400	
Java-Sumatera I.C.		600								2,400	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	3,000	
Total Additional Capacity						-	-	330	1,330	1,330	3,950	5,910	7,270	12,130	14,990	18,550	21,480	24,590	28,400	30,510	34,320	37,430	41,340	44,350	48,460
Total Supply Capacity at year end						24,389	28,305	30,318	32,285	32,285	34,905	36,975	38,335	41,642	43,801	46,363	49,293	52,403	55,608	57,718	61,528	64,638	68,548	71,558	75,668
Reserve Margin						26.2%	37.8%	39.0%	39.4%	31.4%	33.9%	33.7%	30.4%	32.9%	31.2%	30.3%	30.1%	31.2%	30.7%	30.1%	30.2%	31.3%	30.8%	31.1%	30.2%

FIXSYS HYDRO

PLTA	Index	Installed Cap. [MW]	Energy Storage (GWh)	Inflow Energy				Min. Generation				Average Capacity			
				I(Wet)	II(Dry)	III	IV	I(Wet)	II(Dry)	III	IV	I(Wet)	II(Dry)	III	IV
				[GWh]	[GWh]	[GWh]	[GWh]	[GWh]	[GWh]	[GWh]	[GWh]	[MW]	[MW]	[MW]	[MW]
Jatiluhur #1-6	JTLH	180	842.6	315.8	376.9			204.3	298			180	180		
Saguling	SAGL	700.7	2,520.7	1292	680.8			999.2	400.6			701	701		
IP- Area I	IPA1	37.26	-	70.5	53.9			61.8	37.8			37	37		
IP- Area II	IPA2	59.38	-	143.1	78.9			112.3	56.7			59	59		
Sudirman	MRTC	180.9	489.8	356.9	79.7			277.3	18			181	181		
IP-Area III	APA3	125.54	-	264.1	199			235.8	166.3			126	126		
Sutami	STMI	105	451.1	263.2	155.5			164.6	127.5			105	105		
EP Non Suami	EPNS	134.5	563.5	312.3	175.8			223	115.8			135	135		
Brantas Non EP	BNEP	41.9	-	47.3	41.2			17.1	11.3			42	42		
Cirata	CRI2	1008	1,377.0	648.2	444.9			487.8	256			1008	1008		
Rajamandala	RJMD	47	90.0	82.0	61.8			70.0	52.5			47	47		
Jatigede	JTGD	110	620.0	216.8	72.3			184.3	61.4			110	110		

INPUT VARYSYS

No.	Name	No. of Sets	Min. Load MW	Capacity MW	Heat Rates		Fuel Costs		Fuel Type	Spinning Reserves	FOR	Days Scheduled Maintenance Days	Maintenance Class Size MW	O&M (FIX) \$/kWm	O&M (VAR) \$/MWh	FLD HEAT RT KCAL/KWH	UNIT GENERATION COSTS (\$/MWH)				
					Kcal/kWh		Cents/Million Kcal										BASE DOM	BASE FRGN	FLD DOM	FLD FRGN	FLD TOT
					Base Load	Average Incremental	Domestic	Foreign													
1	C6H	0	300	600	2510	2389	1509	0	0	5	7	42	600	2.61	2.00	2450	39.9	0.0	39.0	0.0	39.0
2	C10H	0	500	1000	2510	2389	1509	0	0	5	7	42	1000	2.61	2.00	2450	39.9	0.0	39.0	0.0	39.0
3	LNG	0	375	750	1911	1741	0	3968	2	7	7	42	750	1.60	1.00	1826	1.0	75.8	1.0	72.5	73.5
4	N10H	0	1000	1000	2606	2606	0	250	6	0	7	28	1000	4.66	0.41	2606	0.4	6.5	0.4	6.5	6.9
5	GE55	0	44	55	1000	1000	6430	0	5	0	7	28	55	2.50	1.00	1000	65.3	0.0	65.3	0.0	65.3
6	G150	0	75	150	3150	2625	9222	0	4	10	7	28	150	0.97	2.00	2888	292.5	0.0	268.3	0.0	268.3
7	J-SIC	5	300	600	2510	2389	1509	0	7	5	8	45	600	2.64	2.00	2450	39.9	0.0	39.0	0.0	39.0

PUMP STORAGE (Upper Cisokan)

PS1
 Installed Capacity 500 MW
 Efficiency 76 %
 O&M (Fix) 0.55 \$/kW-month
 Available Year 2015

Period	Pump Cap. MW	Gen. Cap. MW	Max. Energy GWh
1	530	500	600
2	530	500	600

PS2
 Installed Capacity 500 MW
 Efficiency 76 %
 O&M (Fix) 0.55 \$/kW-month
 Available Year 2016

Period	Pump Cap. MW	Gen. Cap. MW	Max. Energy GWh
1	530	500	600
2	530	500	600

PUMP STORAGE (Matenggeng)

PS3
 Installed Capacity 1000 MW
 Efficiency 76 %
 O&M (Fix) 0.55 \$/kW-month
 Available Year 2019

Period	Pump Cap. MW	Gen. Cap. MW	Max. Energy GWh
1	530	500	450
2	530	500	450

PUMP STORAGE (Grindulu)

PS4
 Installed Capacity 1000 MW
 Efficiency 76 %
 O&M (Fix) 0.55 \$/kW-month
 Available Year 2019

Period	Pump Cap. MW	Gen. Cap. MW	Max. Energy GWh
1	530	500	450
2	530	500	450

Hydropower Project

	MANG (Maung)	CIB3 (Cibuni-3)	CPSG (Cipasang)	CMD3(Cimandiri-3)
Construction Cost \$/kW	1872 Inc.IDC	2,865 Inc.IDC	1,636 Inc.IDC	1,998 Inc.IDC
Installed Caapcity MW	360	172	400	238
Reservoir Energy GWh	535	568	751	600
Inflow Energy wet GWh	430	450	600	480
dry GWh	160	170	230	180
Minimum Generation wet GWh	320	340	450	360
dry GWh	80	90	110	90
Average Capacity wet MW	360	172	400	238
dry MW	360	172	400	238
Construction Period year	5	5	5	5
I.D.C (%)	22.6	22.6	22.6	22.6

Source: Hydro Inventory and Pre-feasibility Studies, June 1999, Nippon Koei Co., Ltd.

Construction Cost inc. IDC

PLANT	CAPITAL COSTS (\$/kW)				PLANT LIFE YEARS	D.R.=12% I.D.C. (%)	CONSTR. TIME (YEARS)
	DEPRECIABLE PART		NON-DEPRECIABLE PART				
	DOMESTIC	FOREIGN	DOMESTIC	FOREIGN			
C6H	444	1,037	0	0	30	18.46	4
C10H	611	1,425	0	0	30	18.46	4
LNG	300	699	0	0	25	14.13	3
N10H	659	2,637	0	0	40	26.6	6
G150	82	466	0	0	20	9.6	2
PS 1&2	271	584	0	0	50	22.6	5
PS 3	252	541	0	0	50	22.6	5
PS 4	268	579	0	0	50	22.6	5
GE55	444	1,776	0	0	30	14.13	3
J-SIC	308	2,051	0	0	30	18.46	4

Java - Sumatra Interconnection (HVDC)

			Note
1. Investment Cost for HVDC			
EPC Cost	1,370	M.US\$	
Land Acquisition + ROW	160	M.US\$	
Total Investment Cost	1,530	M.US\$	
2. Construction Cost for HVDC	510	\$/kW	Divided by 3000 MW
3. Construction Cost of C6H	1,481	\$/kW	Referred to P3B Data
4. Total Investment Cost	1,991	\$/kW	


Source: Updated Feasibility Study Java - Sumatera Interconnection, Sep. 2007

WASP IV Screening Curve

Fuel Prices Scenario Index	2	Medium Scenario							
		PLTU	LNG	PLTN	PLTG	PLTU10	PLTP	Interc.	
Installed Capacity	MW	600	750	1000	150	1000	55	3000	
Fuel Type		coal	LNG	nuclear	HSD	coal	Geothermal	HVDC T/L	
Fuel Price	\$/MMBTU	3.80	10.00	0.63	23.24	3.80	16.20	3.80	
Thermal Efficiency	%	35%	47%	33%	30%	35%	86%	35%	
Variabel O&M	\$/MWh	2.0	1.0	0.4	2.0	2.0	1.0	2.0	
Fixed O&M	\$/KW.year	31.32	19.2	55.92	11.64	31.32	30.00	31.68	
Investment Cost inc. IDC	\$/KW	1,481	999	3,296	548	2,036	2,220	2,359	
Construction Period	Years	4	3	6	2	4	3	4	
Book Life	Years	30	25	40	20	30	30	30	
Discount Rate		12.00%	12.00%	12.00%	12.00%	12.00%	12.00%	12.00%	
Capital Recovery Factor (CRF)		12.41%	12.75%	12.13%	13.39%	12.41%	12.41%	12.41%	
Interest During Construction (IDC)		18.46%	14.13%	26.60%	9.60%	18.46%	14.13%	14.13%	
Annual Investment cost	\$/KW.year	183.86	127.37	399.82	73.37	252.76	275.60	292.75	
Annual Fixed Cost	\$/KW.year	215.18	146.57	455.74	85.01	284.08	305.60	324.43	
Annual Fuel Cost	\$/KW.year	324.58	636.07	57.07	2315.88	323.65	563.14	323.65	
Annual Variable O&M	\$/KW.year	17.52	8.76	3.59	17.52	17.52	8.76	17.52	
Annual Variable Cost	\$/KW.year	342.10	644.83	60.66	2333.40	341.17	571.90	341.17	
Annual Fixed Cost	\$/KW.year	215.18	146.57	455.74	85.01	284.08	305.60	324.43	
Total	\$/KW.year	557.28	791.40	516.40	2418.41	625.25	877.50	665.60	
CF		0%	215.18	146.57	455.74	85.01	284.08	305.60	324.43
		100%	557.28	791.40	516.40	2418.41	625.25	877.50	665.60

Index	Fuel Prices \$/MMBTU		
	Low	Medium	High
Coal	3.33	3.80	4.28
LNG	8.00	10.00	12.00
N.Gas	4.00	5.00	6.00
Nuclear	0.57	0.63	0.69
HSD	19.57	23.24	26.91
MFO	11.50	13.70	15.90
Geothermal	14.58	16.20	17.82

Note: \$/MMBTU is referred to "Fuel Price Sheet" except Nuclear.



INPUT REMERSIM (Fuel Consumption per GWh)

No.	Name	Type	No. of Sets	Min. Load MW	Capacity MW	Heat Rates (kcal/kWh)			Fuel Type	Heat Value kcal/kg 100kcal/MMBT U kcal/liter	Fuel Consumption (unit/GWh) at FLD			
						Base Load	Average Incremental	At FLD			1,000 ton	1,000 MMBTU	1,000 KL	Geo
1	SRL1	PLTU	4	240	381	2,622	2,452	2,559	0	5,100	0.502			
2	SRL2	PLTU	3	340	579	2,560	2,309	2,456	0	5,100	0.482			
3	MKR1	PLTU	3	44	84	3,273	3,194	3,235	3	9,598			0.337	
4	MKR2	PLTG	2	90	165	2,948	2,884	2,919	1	2,520		11.58		
5	MKR3	PLTGU	1	300	465	2,433	2,018	2,286	1	2,520		9.07		
6	MKRR	PLTGU	-	500	750	2,433	2,018	2,295	1	2,520		9.11		
7	PRK1	PLTU	2	25	48	3,229	2,957	3,099	3	9,598			0.323	
8	PRK2	PLTGU	2	315	560	2,319	1,994	2,177	4	9,095			0.239	
9	PRK3	PLTG	2	10	20	4,711	3,930	4,321	4	9,095			0.475	
10	PRKE	PLTGU	-	500	750	2,433	2,018	2,295	1	2,520		9.11		
11	MTR1	PLTGU	1	315	605	2,555	2,246	2,407	4	9,095			0.265	
12	MTR2	PLTG	2	72	138	3,376	3,204	3,294	4	9,095			0.362	
13	MTR3	PLTG	6	72	143	3,376	3,204	3,291	4	9,095			0.362	
14	MTRR	PLTGU	-	150	225	2,433	2,018	2,295	1	2,520		9.11		
15	SLK1	PLTP	3	52	52	1,000	1,000	1,000	5	7,308				-
16	SLK2	PLTP	3	52	52	1,000	1,000	1,000	5	7,308				-
17	CLND	PLTG	1	50	150	4,465	3,200	3,622	1	2,520		14.37		
18	CLGN	PLTGU	1	240	740	2,175	1,800	1,922	1	2,520		7.63		
19	SRL3	PLTU	-	340	600	2,560	2,309	2,451	0	4,200	0.584			
20	LBHN	PLTU	-	150	300	2,622	2,452	2,537	0	4,200	0.604			
21	TLNG	PLTU	-	150	300	2,622	2,452	2,537	0	4,200	0.604			
22	KMJ1	PLTP	1	26	26	1,000	1,000	1,000	5	7,308				-
23	KMJ2	PLTP	2	47	47	1,000	1,000	1,000	5	7,308				-
24	KMJ3	PLTP	1	60	60	1,000	1,000	1,000	5	7,308				-
25	DRJ1	PLTP	1	44	44	1,000	1,000	1,000	5	7,308				-
26	DRJ2	PLTP	1	70	70	1,000	1,000	1,000	5	5,300				-
27	DRJ3	PLTP	1	110	110	1,000	1,000	1,000	5	7,308				-
28	WW1	PLTP	1	110	110	1,000	1,000	1,000	5	7,308				-
29	SRG1	PLTG	2	8	18	4,700	4,084	4,358	1	2,520		17.29		
30	SRG2	PLTG	2	8	20	4,700	4,084	4,330	4	9,095			0.476	
31	PTH1	PLTP	-	60	60	1,000	1,000	1,000	5	7,308				-
32	JBSL	PLTU	-	150	300	2,590	2,115	2,353	0	4,200	0.560			
33	JBUT	PLTU	-	150	300	2,590	2,115	2,353	0	4,200	0.560			
34	CRBN	PLTU	-	360	600	2,560	2,160	2,400	0	5,300	0.453			
35	TBK1	PLTGU	2	297	496	2,632	2,015	2,384	4	9,095			0.262	
36	TBK2	PLTU	2	25	41	3,229	3,127	3,189	3	9,598			0.332	
37	TBK3	PLTU	1	125	192	3,229	3,127	3,193	3	9,598			0.333	
38	CLC1	PLTG	2	10	22	4,700	4,079	4,361	4	9,095			0.479	
39	CLC2	PLTU	2	150	300	2,772	2,285	2,529	0	5,215	0.485			
40	TJB1	PLTU	2	330	660	2,772	2,285	2,529	0	5,215	0.485			
41	TJB2	PLTU	-	360	600	2,560	2,160	2,400	0	4,500	0.533			
42	DIEN	PLTP	1	60	60	1,000	1,000	1,000	5	7,308				-
43	RMBG	PLTU	-	150	300	2,590	2,115	2,353	0	4,500	0.523			
44	PTN1	PLTU	2	225	370	2,579	2,412	2,514	0	5,100	0.493			
45	PTN2	PLTU	-	340	600	2,560	2,309	2,451	0	4,500	0.545			
46	PEC	PLTU	2	368	615	2,772	2,285	2,576	0	5,215	0.494			
47	JPOW	PLTU	2	355	610	2,700	2,310	2,537	0	5,500	0.461			
48	GSK1	PLGU	3	250	480	2,318	1,990	2,161	1	2,520		8.58		
49	GSK2	PLTG	2	5	16	4,456	4,284	4,338	1	2,520		17.21		
50	GSK3	PLTU	2	43	85	2,882	2,709	2,797	1	2,520		11.10		
51	GSK4	PLTU	2	90	175	2,826	2,601	2,717	1	2,520		10.78		
52	PRAK	PLTU	2	25	48	4,323	3,517	3,937	3	9,598			0.410	
53	GRT1	PLTGU	1	270	462	2,632	2,083	2,404	4	9,095			0.264	
54	GRT2	PLTG	3	40	100	3,376	3,310	3,336	4	9,095			0.367	
55	PMRN	PLTG	2	12	48	4,439	4,035	4,136	4	9,095			0.455	
56	GLMR	PLTG	2	5	16	4,456	4,284	4,338	4	9,095			0.477	
57	GLMK	PLTG	1	56	133	4,439	4,035	4,205	4	9,095			0.462	
58	BLI1	PLTG	4	6	20	4,700	4,131	4,302	4	9,095			0.473	
59	BLI2	PLTD	10	2	5	3,880	3,576	3,698	4	9,095			0.407	
60	BLUT	PLTU	-	65	130	2,590	2,115	2,353	0	5,300	0.444			
61	BDGL	PLTP	-	10	10	1,000	1,000	1,000	5	7,308				-
62	TJAW	PLTU	-	150	300	2,590	2,115	2,353	0	4,500	0.523			
63	JTSL	PLTU	-	150	300	2,590	2,115	2,353	0	4,500	0.523			

No.	Name	Type	No. of Sets	Min. Load MW	Capacity MW	Heat Rates (kcal/kWh)			Fuel Type	Heat Value kcal/kg 100kcal/MMBT U kcal/liter	Fuel Consumption (unit/GWh) a FLD			
						Base Load	Average Incremental	At FLD			1,000 ton	1,000 MMBTU	1,000 KL	Geo Nuclear
1	C6H	PLTU	0	300	600	2510	2389	2,450	0	4,766	0.514			
2	C10H	PLTU	0	500	1000	2510	2389	2,450	0	4,766	0.514			
3	LNG	PLTG	0	375	750	1911	1741	1,826	2	2,520		7.25		
4	N10H	PLTN	0	1000	1000	2606	2606	2,606	6	0				-
5	GE55	PLTP	0	44	55	1000	1000	1,000	5	0				-
6	G150	PLTG	0	75	150	3150	2625	2,888	4	9,095			0.318	
7	J-SIC	J-SI	5	300	600	2510	2389	2,450	7	0				-

Assumption of Fuel Prices (Medium Scenario)

Kind of Fuel	Price		Heat Content	
	USD		Cents/mKcal	
Coal	80.0	per Ton	1,509	5,300 Kcal/kg
LNG	10.0	per MMBTU	3,968	252,000 Kcal/mmbtu
Gas	5.0	per MMBTU	1,984	252,000 Kcal/mmbtu
HSD	133.0	per Barrel	9,222	9,070 Kcal/l
MFO	81.0	per Barrel	5,437	9,370 Kcal/l
Geothermal	0.0553	per kWh	6,430	
Nuclear			250	

Price Crude Oil	95	\$/barrel		
HSD	133	\$/barrel	23.24	\$/mmbtu
MFO	81	\$/barrel	13.70	\$/mmbtu
LNG+transport	10.0	\$/mmbtu		
transport	0.7	\$/mmbtu		
LNG	9.3	\$/mmbtu	9.30	\$/mmbtu
Gas	5.0	\$/mmbtu	5.00	\$/mmbtu
Coal+transport	80	\$/ton	3.80	\$/mmbtu
transport	18	\$/ton		
Coal	74	\$/ton	6,300	Kcal/kg
	62	\$/ton	5,300	Kcal/kg

Note: Coal price at P/S is CIF Price.

Heat (HSD)	19,500	btu/lb	1 kg =	2.2 lb
	10,811	Kcal/kg	berat jenis =	0.839 kg/l
	9,070	Kcal/l		
MFO	18,000	btu/lb	1 kg =	2.2 lb
	9,979	Kcal/kg	berat jenis =	0.939 kg/l
	9,370	Kcal/l		

Reference 2: Relationship between MOPS and Domestic Prices

MOPS (2008/03/31 ~ 2008/04/04)	
	\$/barrel
High Speed Diesel Oil (0.05%)	132.02
Kerosene	128.36
Crude Oil	104.30

Note: HSD and Kerosene are FOB at Singapore

MOPS means Mean of Platts Singapore

Source://www.gu-goon.com/

PERTAMINA Price		Price Index (IP)
	\$/barrel	
HSD	145.93	1.40
MFO	89.14	0.85
Crude Oil	104.30	1.00

Note : 1 barrel = 159 liter

New Fuel Prices for Industry in April 2008 released by PERTAMINA on March 31, 2008						
Fuel Type	Economical Selling Fuel Price - Non Tax (Base Price)					
	Region 1		Region 2		Region 3	
	Rp/KL	US\$/KL	Rp/KL	US\$/KL	Rp/KL	US\$/KL
Gasoline	7080.13	768.17	7352.107	797.68	7508.057	814.60
Kerosene	8532.07	925.76	8718.104	945.94	8903.029	966.01
High Speed Diesel	8458.78	917.77	8819.464	956.91	9006.539	977.20
Marine Diesel Fuel	8284.08	898.88	8464.705	918.48	8644.250	937.97
Marine Fuel Oil	5166.53	560.60	5278.949	572.80	5390.924	584.95
Pertamina DEX	8757.37	950.14	-	-	-	-

Source: www.pertamina.com/

Note : Fuel prices released by PERTAMINA depend on MOPS.

6.2 Output Data

Base Scenario (Policy Oriented)

YEAR	PRESENT WORTH COST OF THE YEAR (K\$)					OBJ.FUN. (CUMM.)	LOLP %	LNG	N10H	GE55	G150	C10H	J-SI	Hydro	PUMP
	CONCST	SALVAL	OPCOST	OP-Coal	TOTAL										
2009	-	-	6,019,205	-	6,019,205	6,019,205	0.029	-	-	-	-	-	-	-	-
2010	-	-	4,899,357	-	4,899,357	10,918,562	0.027	-	-	-	-	-	-	-	-
2011	584,024	58,402	4,655,034	-	5,180,656	16,099,218	0.028	-	-	6	-	-	-	-	-
2012	1,449,185	168,314	4,456,589	-	5,737,460	21,836,678	0.028	-	-	6	-	1	-	-	-
2013	-	-	4,266,500	(1,364)	4,265,136	26,101,814	0.029	-	-	6	-	1	-	-	-
2014	3,489,675	539,066	4,148,529	(19,034)	7,080,104	33,181,918	0.027	-	-	10	-	1	4	-	-
2015	1,436,983	251,476	4,013,061	(52,615)	5,145,953	38,327,871	0.027	1	-	12	-	1	5	-	1
2016	642,766	127,520	3,937,326	(82,181)	4,370,391	42,698,262	0.030	2	-	14	-	1	5	-	2
2017	3,690,462	846,235	3,878,421	(179,366)	6,543,282	49,241,544	0.029	3	-	16	-	5	5	-	2
2018	1,832,782	502,776	3,801,422	(181,411)	4,950,017	54,191,561	0.030	4	1	18	-	5	5	-	3
2019	2,317,949	697,791	3,727,594	(262,416)	5,085,336	59,276,897	0.029	4	1	20	-	8	5	-	4
2020	1,917,688	662,641	3,625,065	(307,148)	4,572,964	63,849,861	0.029	4	1	22	-	10	5	4	4
2021	1,953,862	760,847	3,427,301	(325,347)	4,294,969	68,144,830	0.029	4	2	24	-	12	5	4	4
2022	1,937,782	848,107	3,298,525	(376,012)	4,012,188	72,157,018	0.029	4	2	26	-	15	5	7	4
2023	1,189,803	578,293	3,225,698	(404,629)	3,432,579	75,589,597	0.029	6	2	28	-	17	5	7	4
2024	1,403,016	786,478	3,039,239	(398,816)	3,256,960	78,846,557	0.029	6	3	30	-	18	5	10	4
2025	1,280,619	975,249	2,960,542	(420,187)	3,025,725	81,872,282	0.029	8	3	32	-	21	5	10	4
2026	1,405,205	989,483	2,808,038	(425,804)	2,797,956	84,670,238	0.029	8	4	34	-	24	5	10	4
2027	1,112,072	878,219	2,723,275	(435,811)	2,521,317	87,191,555	0.029	10	4	36	-	27	5	11	4
2028	1,356,615	1,207,217	2,584,914	(439,529)	2,294,783	89,486,338	0.029	10	5	38	-	31	5	11	4

Base Scenario (Policy Oriented)

YEAR	Peak Load (MW)	Supply Cap. (MW)	LNG	N10H	GE55	G150	C10H	J-SI	Hydro	PUMP	RENEW Wind+Bio	RES. %
2009	19,329	24,390	-	-	-	-	-	-	-	-	-	26.2%
2010	20,535	28,306	-	-	-	-	-	-	-	-	-	37.8%
2011	21,809	30,319	-	-	330	-	-	-	-	-	-	39.0%
2012	23,153	32,286	-	-	-	-	1,000	-	-	-	-	39.4%
2013	24,573	32,286	-	-	-	-	-	-	-	-	-	31.4%
2014	26,073	34,906	-	-	220	-	-	2,400	-	-	-	33.9%
2015	27,657	36,976	750	-	110	-	-	600	-	-	-	33.7%
2016	29,406	38,336	750	-	110	-	-	-	-	500	-	30.4%
2017	31,340	41,643	750	-	110	-	-	4,000	-	-	-	32.9%
2018	33,395	43,802	750	1,000	110	-	-	-	-	500	-	31.2%
2019	35,577	46,914	-	-	110	-	-	3,000	-	-	500	31.9%
2020	37,895	50,194	-	-	110	-	-	2,000	-	1,170	-	32.5%
2021	40,357	53,304	-	1,000	110	-	-	2,000	-	-	-	32.1%
2022	42,973	56,709	-	-	110	-	-	3,000	-	900	-	32.0%
2023	45,751	60,319	1,500	-	110	-	-	2,000	-	-	-	31.8%
2024	48,703	63,329	-	1,000	110	-	-	1,000	-	900	-	30.0%
2025	51,840	67,939	1,500	-	110	-	-	3,000	-	-	-	31.1%
2026	55,172	72,499	-	1,000	110	-	-	3,000	-	-	-	30.6%
2027	58,712	76,959	1,500	-	110	-	-	3,000	-	300	-	31.1%
2028	62,474	82,069	-	1,000	110	-	-	4,000	-	-	-	31.4%
TOTAL			7,500	5,000	2,090	-	31,000	3,000	3,270	2,000	-	

Base Scenario (Policy Oriented)

YEAR	f-0.5	NPV Conv.	C10H Generation (1000 GWh)				JS-1 Generation (1000 GWh)				T. Generation (1000 GWh)		OP Cost K\$	OP Cost (NPV) K\$	
			12.0%	P-1 Base	P-1 Peak	P-2 Base	P-2 Peak	P-1 Base	P-1 Peak	P-2 Base	P-2 Peak	BASE			PEAK
2009	-0.5	0.94491	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0	0
2010	-1.5	0.84367	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0	0
2011	-2.5	0.75328	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0	0
2012	-3.5	0.67257	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0	0
2013	-4.5	0.60051	0.02	0.00	0.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-2,272	-1,364
2014	-5.5	0.53617	0.40	0.00	0.33	0.00	0.15	0.00	0.37	0.00	1.25	0.00	0.00	-35,500	-19,034
2015	-6.5	0.47872	0.76	0.00	0.60	0.00	0.12	0.00	1.39	0.00	3.87	0.00	0.00	-109,908	-52,615
2016	-7.5	0.42743	1.12	0.00	0.91	0.00	0.28	0.00	2.28	0.00	6.77	0.00	0.00	-192,268	-82,181
2017	-8.5	0.38163	1.62	0.02	1.12	0.01	0.21	0.00	2.49	0.00	16.52	0.03	0.00	-469,999	-179,366
2018	-9.5	0.34074	2.12	0.03	1.55	0.11	0.29	0.00	3.05	0.00	18.61	0.14	0.00	-532,402	-181,411
2019	-10.5	0.30424	2.68	0.07	2.03	0.19	0.39	0.00	3.22	0.00	28.82	0.19	0.00	-602,531	-262,416
2020	-11.5	0.27164	3.15	0.10	2.49	0.27	0.51	0.00	3.55	0.00	37.20	0.26	0.00	-677,148	-307,448
2021	-12.5	0.24254	3.59	0.13	2.93	0.36	0.64	0.00	3.99	0.00	43.79	0.33	0.00	-752,347	-325,347
2022	-13.5	0.21655	25.21	2.55	22.90	3.54	3.40	0.00	3.69	0.00	55.20	6.09	0.00	-827,011	-376,012
2023	-14.5	0.19335	29.84	4.04	27.06	4.97	3.86	0.01	4.13	0.00	64.89	9.02	0.00	-902,148	-404,629
2024	-15.5	0.17263	31.51	5.37	29.46	6.93	4.10	0.01	4.26	0.01	69.33	12.32	0.00	-977,282	-420,187
2025	-16.5	0.15414	37.09	6.54	35.27	8.60	4.27	0.01	4.57	0.01	81.20	15.16	0.00	-1,052,944	-452,816
2026	-17.5	0.13762	43.01	8.02	39.89	9.40	4.40	0.01	4.46	0.01	91.76	17.62	0.00	-1,128,000	-475,804
2027	-18.5	0.12288	49.50	10.77	44.82	11.75	4.55	0.01	4.71	0.01	103.58	21.84	0.00	-1,203,511	-498,811
2028	-19.5	0.10971	56.05	11.55	52.31	12.52	4.56	0.01	4.65	0.01	117.57	24.09	0.00	-1,278,022	-521,818
TOTAL															

Scenario 1 (Coal Power Acceleration)

YEAR	PRESENT WORTH COST OF THE YEAR (K\$)					OBJ.FUN. (CUMM.)	LOLP %	LNG	N10H	GE55	G150	C10H	J-SI	Hydro	PUMP
	CONCST	SALVAL	OPCOST	OP-Coal	TOTAL										
2009	-	-	6,019,205	-	6,019,205	6,019,205	0.029	-	-	-	-	-	-	-	-
2010	-	-	4,899,357	-	4,899,357	10,918,562	0.027	-	-	-	-	-	-	-	-
2011	584,024	58,402	4,655,034	-	5,180,656	16,099,218	0.028	-	-	6	-	-	-	-	-
2012	1,449,185	168,314	4,456,589	-	5,737,460	21,836,678	0.028	-	-	6	-	1	-	-	-
2013	-	-	4,266,500	(1,364)	4,265,136	26,101,814	0.029	-	-	6	-	1	-	-	-
2014	3,212,544	496,255	4,147,409	(23,907)	6,839,791	32,941,605	0.028	-	-	6	-	1	4	-	-
2015	1,313,264	229,556	4,013,965	(60,501)	5,037,171	37,978,776	0.028	1	-	6	-	1	5	-	1
2016	1,453,285	291,695	3,938,238	(105,974)	4,993,854	42,972,630	0.029	2	-	6	-	2	5	-	2
2017	2,769,528	633,492	3,908,800	(201,899)	5,842,937	48,815,567	0.030	3	-	6	-	5	5	-	2
2018	2,478,923	672,626	3,816,995	(213,425)	5,409,867	54,225,434	0.029	4	1	6	-	6	5	-	3
2019	2,239,324	674,316	3,742,177	(299,293)	5,007,891	59,233,325	0.029	4	1	6	-	9	5	-	4
2020	1,262,186	440,731	3,661,677	(338,139)	4,144,993	63,378,318	0.029	4	1	6	-	10	5	4	4
2021	2,413,772	937,132	3,446,940	(363,982)	4,559,598	67,937,916	0.029	4	2	6	-	13	5	4	4
2022	1,866,394	808,966	3,337,636	(430,453)	3,964,611	71,902,527	0.029	4	2	6	-	17	5	4	4
2023	986,523	480,879	3,266,052	(464,021)	3,307,875	75,210,202	0.028	5	2	6	-	19	5	4	4
2024	1,718,075	955,387	3,090,336	(471,186)	3,381,838	78,592,040	0.028	5	3	6	-	22	5	4	4
2025	1,328,463	827,539	3,006,373	(504,961)	3,002,335	81,594,375	0.028	5	3	6	-	26	5	4	4
2026	1,666,171	1,172,638	2,847,643	(507,067)	2,834,109	84,428,484	0.028	5	4	6	-	30	5	4	4
2027	1,059,042	836,849	2,763,199	(528,500)	2,456,892	86,885,376	0.027	5	4	6	-	34	5	4	4
2028	1,328,261	1,182,002	2,621,172	(524,173)	2,243,259	89,128,635	0.027	5	5	6	-	38	5	4	4

Scenario 1 (

PRODUCTION MIX (1000 GWh)
Base Scenario (Policy Oriented)

YEAR	FUEL TYPE										TOTAL
	COAL	GAS	LNG	MFO	HSD	GEO	NUC	J-SI	PUMP	HYD	
2009	87.34	24.29	-	1.41	2.86	4.17	-	-	-	6.00	126.07
2010	#####	13.06	-	-	0.02	0.15	-	-	-	6.00	133.93
2011	#####	15.02	-	-	0.02	0.05	-	-	-	6.00	142.23
2012	#####	21.34	-	-	0.02	0.31	-	-	-	6.14	151.01
2013	#####	27.47	-	0.01	0.06	2.15	-	-	-	6.14	160.25
2014	#####	32.38	-	0.02	0.09	5.20	-	0.52	-	6.14	170.04
2015	#####	36.58	0.07	0.02	0.13	8.12	-	2.51	0.70	6.43	181.28
2016	#####	39.35	1.65	0.11	0.38	12.10	-	4.74	1.73	6.43	194.06
2017	#####	38.70	2.32	-	0.38	14.81	-	4.58	1.38	6.43	206.19
2018	#####	37.57	4.03	-	2.70	15.23	7.52	5.64	0.38	6.43	218.29
2019	#####	37.92	4.55	-	2.59	16.98	7.52	6.02	0.30	6.43	232.41
2020	#####	38.04	5.34	-	3.32	18.25	7.52	6.68	0.24	9.13	247.43
2021	#####	38.05	5.42	-	3.46	19.10	15.05	6.68	0.23	9.13	263.47
2022	#####	38.10	5.97	-	3.02	20.17	15.05	7.09	0.15	10.99	280.45
2023	#####	38.13	10.13	-	3.39	21.06	15.05	8.00	0.04	10.99	298.41
2024	#####	38.15	10.94	-	3.79	21.97	22.57	8.38	0.03	12.85	317.65
2025	#####	38.23	15.48	-	3.99	22.88	22.57	8.87	0.02	12.85	338.09
2026	#####	38.23	15.70	-	4.11	23.74	30.09	8.88	0.02	12.85	359.83
2027	#####	38.25	20.86	-	4.37	24.71	30.09	9.29	0.02	13.47	382.91
2028	#####	38.25	20.79	-	4.40	25.52	37.62	9.23	0.02	13.47	407.45

PRODUCTION MIX (1000 GWh)
Scenario 1 (Coal Power Acceleration)

YEAR	FUEL TYPE										TOTAL
	COAL	GAS	LNG	MFO	HSD	GEO	NUC	J-SI	PUMP	HYD	
2009	87.34	24.29	-	1.41	2.86	4.17	-	-	-	6.00	126.07
2010	#####	13.06	-	-	0.02	0.15	-	-	-	6.00	133.93
2011	#####	15.02	-	-	0.02	0.05	-	-	-	6.00	142.23
2012	#####	21.34	-	-	0.02	0.31	-	-	-	6.14	151.01
2013	#####	27.47	-	-	0.06	2.15	-	-	-	6.14	160.24
2014	#####	32.38	-	0.02	0.11	4.87	-	0.75	-	6.14	170.04
2015	#####	36.77	0.14	0.03	0.17	7.27	-	2.97	0.81	6.43	181.44
2016	#####	39.34	1.58	0.09	0.28	10.27	-	4.56	1.59	6.43	193.86
2017	#####	38.72	2.73	-	0.78	12.03	-	5.13	1.80	6.43	206.74
2018	#####	37.57	4.06	-	2.80	11.77	7.52	5.69	0.39	6.43	218.28
2019	#####	37.92	4.67	-	2.70	12.47	7.52	6.16	0.30	6.43	232.40
2020	#####	38.07	6.05	-	3.99	12.84	7.52	7.33	0.24	9.13	247.50
2021	#####	38.06	5.72	-	3.72	12.90	15.05	6.96	0.23	9.13	263.47
2022	#####	38.10	6.04	-	3.07	13.01	15.05	7.16	0.14	9.13	280.43
2023	#####	38.14	8.80	-	3.67	13.08	15.05	8.15	0.02	9.13	298.42
2024	#####	38.14	8.80	-	3.72	13.10	22.57	8.07	0.10	9.13	317.72
2025	#####	38.21	9.39	-	4.06	13.20	22.57	8.40	0.01	9.13	338.09
2026	#####	38.21	9.22	-	4.02	13.23	30.09	8.22	0.01	9.13	359.82
2027	#####	38.23	9.94	-	4.43	13.29	30.09	8.64	0.01	9.13	382.89
2028	#####	38.23	10.00	-	4.49	13.30	37.62	8.64	0.01	9.13	407.43

PRODUCTION MIX (1000 GWh)
Scenario 2 (Power Source Diversification)

YEAR	FUEL TYPE											TOTAL
	COAL	GAS	LNG	MFO	HSD	GEO	NUC	J-SI	PUMP	HYD	RENEW	
2009	87.34	24.29	-	1.41	2.86	4.17	-	-	-	6.00	-	126.07
2010	#####	13.06	-	-	0.02	0.15	-	-	-	6.00	-	133.93
2011	#####	15.02	-	-	0.02	0.05	-	-	-	6.00	-	142.23
2012	#####	21.34	-	-	0.02	0.31	-	-	-	6.14	-	151.01
2013	#####	27.49	-	-	0.06	2.15	-	-	-	6.14	-	160.23
2014	#####	32.47	-	0.02	0.09	5.20	-	0.48	-	6.14	-	170.05
2015	#####	37.00	1.02	0.02	0.13	8.12	-	1.41	0.90	6.43	-	181.55
2016	#####	39.44	2.94	0.11	0.38	12.10	-	3.71	1.73	6.43	-	194.06
2017	#####	38.89	6.09	-	0.38	14.81	-	3.20	1.38	6.43	-	206.19
2018	#####	37.77	8.33	-	2.70	15.23	7.52	3.91	0.37	6.43	-	218.27
2019	#####	38.27	11.13	-	3.41	17.02	7.52	4.93	0.30	6.43	-	232.42
2020	#####	38.45	18.11	-	4.40	18.32	7.52	5.93	0.24	9.13	-	247.43
2021	#####	38.44	18.20	-	4.48	19.06	15.05	5.66	0.24	9.13	2.68	263.55
2022	#####	38.56	26.12	-	4.86	20.17	15.05	6.34	0.17	10.99	2.84	280.51
2023	#####	38.61	27.89	-	5.25	21.04	15.05	6.67	0.09	10.99	6.04	298.55
2024	#####	38.64	35.00	-	6.22	21.86	22.57	7.00	0.07	12.85	6.41	317.76
2025	#####	38.71	37.01	-	6.74	22.78	22.57	7.40	0.03	12.85	10.20	338.17
2026	#####	38.74	44.61	-	7.70	23.63	30.09	7.62	0.02	12.85	10.83	359.86
2027	#####	38.78	46.36	-	8.98	24.60	30.09	8.02	0.02	13.47	15.33	382.91
2028	#####	38.79	46.79	-	8.96	25.41	37.62	7.95	0.02	13.47	16.27	407.42

PRODUCTION MIX (1000 GWh)
Scenario 3 (CO2 Emission Reduction)

YEAR	FUEL TYPE											TOTAL
	COAL	GAS	LNG	MFO	HSD	GEO	NUC	J-SI	PUMP	HYD	RENEW	
2009	87.34	24.29	-	1.41	2.86	4.17	-	-	-	6.00	-	126.07
2010	#####	13.06	-	-	0.02	0.15	-	-	-	6.00	-	133.93
2011	#####	15.02	-	-	0.02	0.05	-	-	-	6.00	-	142.23
2012	#####	21.34	-	-	0.02	0.31	-	-	-	6.14	-	151.01
2013	#####	27.49	-	-	0.06	2.15	-	-	-	6.14	-	160.23
2014	#####	32.47	-	0.02	0.09	5.20	-	0.48	-	6.14	-	170.05
2015	#####	37.00	1.02	0.02	0.13	8.12	-	1.41	0.90	6.43	-	181.55
2016	#####	39.44	2.94	0.11	0.38	12.10	-	3.71	1.73	6.43	-	194.06
2017	#####	38.89	6.09	-	0.38	14.81	-	3.20	1.38	6.43	-	206.19
2018	#####	37.77	8.33	-	2.70	15.23	7.52	3.91	0.37	6.43	-	218.27
2019	#####	38.27	11.13	-	3.41	17.02	7.52	4.93	0.30	6.43	-	232.42
2020	#####	38.45	18.11	-	4.40	18.32	7.52	5.93	0.24	9.13	-	247.43
2021	#####	38.44	18.20	-	4.48	19.06	15.05	5.66	0.24	9.13	2.68	263.55
2022	#####	38.56	26.12	-	4.86	20.17	15.05	6.34	0.17	10.99	2.84	280.51
2023	#####	38.61	27.90	-	5.31	21.05	15.05	6.67	0.09	10.99	6.04	298.55
2024	#####	38.64	34.94	-	6.27	21.87	22.57	7.06	0.09	12.85	9.61	317.81
2025	#####	38.67	36.06	-	6.42	22.68	22.57	7.15	0.04	12.85	17.01	338.23
2026	#####	38.70	43.43	-	7.34	23.50	30.09	7.35	0.03	12.85	18.05	359.89
2027	#####	38.75	44.90	-	8.53	24.42	30.09	7.73	0.02	14.09	26.82	382.92
2028	#####	38.77	46.19	-	8.84	25.31	37.62	7.89	0.02	14.09	28.46	407.38

PRODUCTION MIX (%)
Base Scenario (Policy Oriented)

YEAR	FUEL TYPE										TOTAL
	COAL	GAS	LNG	MFO	HSD	GEO	NUC	J-SI	PUMP	HYD	
2009	69.3	19.3	-	1.1	2.3	3.3	-	-	-	4.8	100.0
2010	85.6	9.8	-	-	0.0	0.1	-	-	-	4.5	100.0
2011	85.2	10.6	-	-	0.0	0.0	-	-	-	4.2	100.0
2012	81.6	14.1	-	-	0.0	0.2	-	-	-	4.1	100.0
2013	77.6	17.1	-	0.0	0.0	1.3	-	-	-	3.8	100.0
2014	73.9	19.0	-	0.0	0.1	3.1	-	0.3	-	3.6	100.0
2015	69.9	20.2	0.0	0.0	0.1	4.5	-	1.4	0.4	3.5	100.0
2016	65.7	20.3	0.9	0.1	0.2	6.2	-	2.4	0.9	3.3	100.0
2017	66.7	18.8	1.1	-	0.2	7.2	-	2.2	0.7	3.1	100.0
2018	63.6	17.2	1.8	-	1.2	7.0	3.4	2.6	0.2	2.9	100.0
2019	64.6	16.3	2.0	-	1.1	7.3	3.2	2.6	0.1	2.8	100.0
2020	64.2	15.4	2.2	-	1.3	7.4	3.0	2.7	0.1	3.7	100.0
2021	63.1	14.4	2.1	-	1.3	7.2	5.7	2.5	0.1	3.5	100.0
2022	64.2	13.6	2.1	-	1.1	7.2	5.4	2.5	0.1	3.9	100.0
2023	64.2	12.8	3.4	-	1.1	7.1	5.0	2.7	0.0	3.7	100.0
2024	62.6	12.0	3.4	-	1.2	6.9	7.1	2.6	0.0	4.0	100.0
2025	63.1	11.3	4.6	-	1.2	6.8	6.7	2.6	0.0	3.8	100.0
2026	62.9	10.6	4.4	-	1.1	6.6	8.4	2.5	0.0	3.6	100.0
2027	63.2	10.0	5.4	-	1.1	6.5	7.9	2.4	0.0	3.5	100.0
2028	63.4	9.4	5.1	-	1.1	6.3	9.2	2.3	0.0	3.3	100.0

PRODUCTION MIX (%)
Scenario 1 (Coal Power Acceleration)

YEAR	FUEL TYPE										TOTAL
	COAL	GAS	LNG	MFO	HSD	GEO	NUC	J-SI	PUMP	HYD	
2009	69.3	19.3	-	1.1	2.3	3.3	-	-	-	4.8	100.0
2010	85.6	9.8	-	-	0.0	0.1	-	-	-	4.5	100.0
2011	85.2	10.6	-	-	0.0	0.0	-	-	-	4.2	100.0
2012	81.6	14.1	-	-	0.0	0.2	-	-	-	4.1	100.0

FUEL CONSUMPTION

TYPE OF PLANT	COAL		GAS		LNG		MFO		HSD	
	Million Tones	Million Tones	Million MMBTU	Million MMBTU	Million MMBTU	Million KL	Million KL	Million KL	Million KL	Million KL
YEAR	Coal	J-SI	Sub total							
2009	44.1	-	44.1	221.1	-	-	0.5	0.7		
2010	59.4	-	59.4	111.8	-	-	-	-		
2011	62.4	-	62.4	128.0	-	-	-	-		
2012	63.4	-	63.4	185.9	-	-	-	-		
2013	64.0	-	64.0	244.1	-	-	-	-		
2014	64.6	0.3	64.9	290.9	-	-	-	-		
2015	65.1	1.3	66.4	331.1	0.5	-	-	-		
2016	65.5	2.4	67.9	359.6	1.1	-	-	-		
2017	70.1	2.4	72.5	351.1	1.6	-	-	-		
2018	70.6	2.9	73.5	337.8	2.9	-	-	-		
2019	75.7	3.1	78.8	341.3	3.0	-	-	-		
2020	79.7	3.5	83.2	342.7	36.7	-	-	-		
2021	85.0	3.5	88.5	342.8	39.3	-	-	-		
2022	89.1	3.7	92.8	343.3	43.3	-	-	-		
2023	94.4	4.2	98.6	343.8	73.4	-	-	-		
2024	97.7	4.4	102.1	344.1	79.3	-	-	-		
2025	104.2	4.6	108.8	344.9	112.3	-	-	-		
2026	110.0	4.6	114.6	345.0	113.8	-	-	-		
2027	117.0	4.9	121.9	345.3	151.2	-	-	-		
2028	124.4	4.8	129.2	346.3	150.7	-	-	-		
TOTAL	1,604.4	50.6	1,655.0	5,999.9	893.4	0.5	15.2			

CO2 Emission

YEAR	Coal+JSI		Gas	LNG	MFO	HSD	Total CO2 Emission
	CO2/GWh	CO2/GWh					
2009	887	443	443	704	704	704	91,237
2010	77,471	10,760	0	993	2,013	2,013	107,539
2011	101,739	5,786	0	0	14	14	114,119
2012	107,451	6,654	0	0	14	14	118,746
2013	109,278	9,454	0	0	14	14	122,572
2014	110,334	12,178	0	7	42	42	126,358
2015	111,877	14,384	0	14	63	63	130,423
2016	113,472	16,391	0	14	92	92	135,245
2017	114,119	17,104	0	14	130,423	130,423	142,786
2018	114,119	17,104	0	14	130,423	130,423	142,786
2019	114,119	17,104	0	14	130,423	130,423	142,786
2020	114,119	17,104	0	14	130,423	130,423	142,786
2021	114,119	17,104	0	14	130,423	130,423	142,786
2022	114,119	17,104	0	14	130,423	130,423	142,786
2023	114,119	17,104	0	14	130,423	130,423	142,786
2024	114,119	17,104	0	14	130,423	130,423	142,786
2025	114,119	17,104	0	14	130,423	130,423	142,786
2026	114,119	17,104	0	14	130,423	130,423	142,786
2027	114,119	17,104	0	14	130,423	130,423	142,786
2028	114,119	17,104	0	14	130,423	130,423	142,786
TOTAL	2,638,967	297,975	144,135	1,098	47,041	3,119,236	

SOx and NOx Emission

YEAR	Coal+JSI		Gas	LNG	MFO+HSD	Total
	SOx Emission	NOx Emission				
2009	175	384	0	107	0	184
2010	229	505	0	57	0	229
2011	242	533	0	66	0	242
2012	246	542	0	94	0	246
2013	249	547	0	121	0	249
2014	252	555	0	142	0	252
2015	258	569	0	163	0	258
2016	265	582	0	173	0	265
2017	284	626	0	170	0	284
2018	289	635	0	165	0	289
2019	312	687	0	167	0	312
2020	331	729	0	167	0	331
2021	346	761	0	167	0	346
2022	374	823	0	168	0	374
2023	399	878	0	168	0	399
2024	415	912	0	168	0	415
2025	444	977	0	168	0	444
2026	470	1,034	0	168	0	470
2027	502	1,105	0	168	0	502
2028	535	1,176	0	168	0	535
TOTAL	6,617	14,560	0	2,933	0	6,617

FUEL CONSUMPTION

TYPE OF PLANT	COAL		GAS		LNG		MFO		HSD	
	Million Tones	Million Tones	Million MMBTU	Million MMBTU	Million MMBTU	Million KL	Million KL	Million KL	Million KL	Million KL
YEAR	Coal	J-SI	Sub total							
2009	44.1	-	44.1	221.1	-	-	0.5	0.7		
2010	59.4	-	59.4	111.8	-	-	-	-		
2011	62.4	-	62.4	128.0	-	-	-	-		
2012	63.4	-	63.4	185.9	-	-	-	-		
2013	64.0	-	64.0	244.1	-	-	-	-		
2014	64.6	0.4	65.0	290.9	-	-	-	-		
2015	65.2	1.6	66.8	333.3	1.0	-	-	-		
2016	65.5	2.4	67.9	359.6	1.1	-	-	-		
2017	70.1	2.7	72.8	351.4	1.9	-	-	-		
2018	70.6	3.0	73.6	337.8	2.9	-	-	-		
2019	75.7	3.2	78.9	341.3	3.0	-	-	-		
2020	81.2	3.8	85.0	343.0	43.9	-	-	-		
2021	85.4	3.6	89.0	342.9	41.5	-	-	-		
2022	93.1	3.7	96.8	343.3	43.8	-	-	-		
2023	99.3	4.3	103.6	343.7	63.8	-	-	-		
2024	104.6	4.2	108.8	343.9	63.8	-	-	-		
2025	113.1	4.4	117.5	344.6	68.0	-	-	-		
2026	119.7	4.3	124.0	344.6	66.8	-	-	-		
2027	129.4	4.5	133.9	344.9	72.1	-	-	-		
2028	137.0	4.5	141.5	344.9	72.5	-	-	-		
TOTAL	1,672.9	50.6	1,723.5	6,001.1	631.7	0.5	15.1			

CO2 Emission

YEAR	Coal+JSI		Gas	LNG	MFO	HSD	Total CO2 Emission
	CO2/GWh	CO2/GWh					
2009	887	443	443	704	704	704	91,237
2010	77,471	10,760	0	993	2,013	2,013	107,539
2011	101,739	5,786	0	0	14	14	114,119
2012	107,451	6,654	0	0	14	14	118,746
2013	109,278	9,454	0	0	14	14	122,572
2014	110,334	12,178	0	7	42	42	126,358
2015	111,877	14,384	0	14	63	63	130,423
2016	113,472	16,391	0	14	92	92	135,245
2017	114,119	17,104	0	14	130,423	130,423	142,786
2018	114,119	17,104	0	14	130,423	130,423	142,786
2019	114,119	17,104	0	14	130,423	130,423	142,786
2020	114,119	17,104	0	14	130,423	130,423	142,786
2021	114,119	17,104	0	14	130,423	130,423	142,786
2022	114,119	17,104	0	14	130,423	130,423	142,786
2023	114,119	17,104	0	14	130,423	130,423	142,786
2024	114,119	17,104	0	14	130,423	130,423	142,786
2025	114,119	17,104	0	14	130,423	130,423	142,786
2026	114,119	17,104	0	14	130,423	130,423	142,786
2027	114,119	17,104	0	14	130,423	130,423	142,786
2028	114,119	17,104	0	14	130,423	130,423	142,786
TOTAL	2,638,967	297,975	144,135	1,098	47,041	3,119,236	

SOx and NOx Emission

YEAR	Coal+JSI		Gas	LNG	MFO+HSD	Total
	SOx Emission	NOx Emission				
2009	175	384	0	107	0	184
2010	229	505	0	57	0	229
2011	242	533	0	66	0	242
2012	246	542	0	94	0	246
2013	249	547	0	121	0	249
2014	252	555	0	142	0	252
2015	258	569	0	163	0	258
2016	265	582	0	173	0	265
2017	284	626	0	170	0	284
2018	289	635	0	165	0	289
2019	312	687	0	167	0	312
2020	331	729	0	167	0	331
2021	346	761	0	167	0	346
2022	374	823	0	168	0	374
2023	399	878	0	168	0	399
2024	415	912	0	168	0	415
2025	444	977	0	168	0	444
2026	470	1,034	0	168	0	470
2027	502	1,105	0	168	0	502
2028	535	1,176	0	168	0	535
TOTAL	6,921	15,227	0	2,935	0	6,921

FUEL CONSUMPTION

TYPE OF PLANT	COAL		GAS		LNG		MFO		HSD	
	Million Tones									

**SUMMARY OF
FIXED SYSTEM
(NOMINAL CAPACITY (MW))**

YEAR	FUEL TYPE										TOTAL
	COAL	GAS	LNG	MFO	HSD	GEO	NUC	J-SI	PUMP	HYD	
2009	11,371	3,713	-	718	5,128	886	-	-	-	2,574	24,390
2010	15,531	3,713	-	274	5,078	1,136	-	-	-	2,574	28,306
2011	16,261	4,688	-	192	5,078	1,526	-	-	-	2,574	30,319
2012	17,261	5,438	-	192	5,078	1,696	-	-	-	2,621	32,286
2013	17,261	5,438	-	192	5,078	1,696	-	-	-	2,621	32,286
2014	17,261	5,438	-	192	5,078	1,916	-	2,400	-	2,621	34,906
2015	17,261	5,438	750	192	5,078	2,026	-	3,000	500	2,731	36,976
2016	17,261	5,438	1,500	192	5,078	2,136	-	3,000	1,000	2,731	38,336
2017	21,261	5,237	2,250	-	3,918	2,246	-	3,000	1,000	2,731	41,643
2018	21,261	5,072	3,000	-	3,382	2,356	1,000	3,000	2,000	2,731	43,802
2019	24,261	5,072	3,000	-	2,384	2,466	1,000	3,000	3,000	2,731	46,914
2020	26,261	5,072	3,000	-	2,384	2,576	1,000	3,000	3,000	3,901	50,194
2021	28,261	5,072	3,000	-	2,384	2,686	2,000	3,000	3,000	3,901	53,314
2022	31,261	5,072	3,000	-	1,779	2,796	2,000	3,000	3,000	4,801	56,709
2023	33,261	5,072	4,500	-	1,779	2,906	2,000	3,000	3,000	4,801	59,459
2024	34,261	5,072	4,500	-	1,779	3,016	3,000	3,000	3,000	5,701	63,329
2025	37,261	5,072	6,000	-	1,779	3,126	3,000	3,000	3,000	5,701	67,939
2026	40,261	5,072	6,000	-	1,779	3,236	4,000	3,000	3,000	5,701	72,049
2027	43,261	5,072	7,500	-	1,779	3,346	4,000	3,000	3,000	6,001	76,959
2028	47,261	5,072	7,500	-	1,779	3,456	5,000	3,000	3,000	6,001	82,069

**SUMMARY OF
FIXED SYSTEM
(NOMINAL CAPACITY (MW))**

YEAR	FUEL TYPE										TOTAL
	COAL	GAS	LNG	MFO	HSD	GEO	NUC	J-SI	PUMP	HYD	
2009	11,371	3,713	-	718	5,128	886	-	-	-	2,574	24,390
2010	15,531	3,713	-	274	5,078	1,136	-	-	-	2,574	28,306
2011	16,261	4,688	-	192	5,078	1,526	-	-	-	2,574	30,319
2012	17,261	5,438	-	192	5,078	1,696	-	-	-	2,621	32,286
2013	17,261	5,438	-	192	5,078	1,696	-	-	-	2,621	32,286
2014	17,261	5,438	-	192	5,078	1,696	-	2,400	-	2,621	34,686
2015	17,261	5,438	750	192	5,078	1,696	-	3,000	500	2,731	36,646
2016	18,261	5,438	1,500	192	5,078	1,696	-	3,000	1,000	2,731	38,896
2017	21,261	5,237	2,250	-	3,918	1,696	-	3,000	1,000	2,731	41,093
2018	22,261	5,072	3,000	-	3,382	1,696	1,000	3,000	2,000	2,731	44,142
2019	25,261	5,072	3,000	-	2,384	1,696	1,000	3,000	3,000	2,731	47,144
2020	26,261	5,072	3,000	-	2,384	1,696	1,000	3,000	3,000	3,901	49,314
2021	29,261	5,072	3,000	-	2,384	1,696	2,000	3,000	3,000	3,901	53,314
2022	33,261	5,072	3,000	-	1,779	1,696	2,000	3,000	3,000	3,901	56,709
2023	35,261	5,072	3,750	-	1,779	1,696	2,000	3,000	3,000	3,901	59,459
2024	38,261	5,072	3,750	-	1,779	1,696	3,000	3,000	3,000	3,901	63,459
2025	42,261	5,072	3,750	-	1,779	1,696	3,000	3,000	3,000	3,901	67,459
2026	46,261	5,072	3,750	-	1,779	1,696	4,000	3,000	3,000	3,901	72,459
2027	50,261	5,072	3,750	-	1,779	1,696	4,000	3,000	3,000	3,901	76,459
2028	54,261	5,072	3,750	-	1,779	1,696	5,000	3,000	3,000	3,901	81,459

**SUMMARY OF
FIXED SYSTEM
(NOMINAL CAPACITY (MW))**

YEAR	FUEL TYPE											TOTAL
	COAL	GAS	LNG	MFO	HSD	GEO	NUC	J-SI	PUMP	HYD	RENEW	
2009	11,371	3,713	-	718	5,128	886	-	-	-	2,574	-	24,390
2010	15,531	3,713	-	274	5,078	1,136	-	-	-	2,574	-	28,306
2011	16,261	4,688	-	192	5,078	1,526	-	-	-	2,574	-	30,319
2012	17,261	5,438	-	192	5,078	1,696	-	-	-	2,621	-	32,286
2013	17,261	5,438	-	192	5,078	1,696	-	-	-	2,621	-	32,286
2014	17,261	5,438	-	192	5,078	1,916	-	2,400	-	2,621	-	34,906
2015	17,261	5,438	750	192	5,078	2,026	-	3,000	500	2,731	-	36,976
2016	17,261	5,438	1,500	192	5,078	2,136	-	3,000	1,000	2,731	-	38,336
2017	21,261	5,237	2,250	-	3,918	2,246	-	3,000	1,000	2,731	-	41,643
2018	21,261	5,072	3,000	-	3,382	2,356	1,000	3,000	2,000	2,731	-	43,802
2019	23,261	5,072	3,000	-	2,834	2,466	1,000	3,000	3,000	2,731	-	46,364
2020	23,261	5,072	4,500	-	2,984	2,576	1,000	3,000	3,000	3,901	-	49,294
2021	25,261	5,072	4,500	-	2,984	2,686	2,000	3,000	3,000	3,901	535	52,939
2022	26,261	5,072	6,000	-	2,679	2,796	2,000	3,000	3,000	4,801	567	56,176
2023	29,261	5,072	6,000	-	2,679	2,906	2,000	3,000	3,000	4,801	1,207	59,926
2024	29,261	5,072	7,500	-	2,979	3,016	3,000	3,000	3,000	5,701	1,281	63,810
2025	32,261	5,072	7,500	-	2,979	3,126	3,000	3,000	3,000	5,701	2,038	67,677
2026	32,261	5,072	9,000	-	3,279	3,236	4,000	3,000	3,000	5,701	2,164	70,713
2027	36,261	5,072	9,000	-	3,579	3,346	4,000	3,000	3,000	6,001	3,063	76,322
2028	40,261	5,072	9,000	-	3,579	3,456	5,000	3,000	3,000	6,001	3,250	81,619

Note: Capacity Factor of Renewable is assumed 20 %.

**SUMMARY OF
FIXED SYSTEM
(%)**

YEAR	FUEL TYPE											TOTAL
	COAL	GAS	LNG	MFO	HSD	GEO	NUC	J-SI	PUMP	HYD	RENEW	
2009	46.6	15.2	-	2.9	21.0	3.6	-	-	-	10.6	-	100.0
2010	54.9	13.1	-	1.0	17.9	4.0	-	-	-	9.1	-	100.0
2011	53.6	15.5	-	0.6	16.7	5.0	-	-	-	8.5	-	100.0
2012	53.5	16.8	-	0.6	15.7	5.3	-	-	-	8.1	-	100.0
2013	53.5	16.8	-	0.6	15.7	5.3	-	-	-	8.1	-	100.0
2014	49.4	15.6	-	0.6	14.5	5.5	-	6.9	-	7.5	-	100.0
2015	46.7	14.7	2.0	0.5	13.7	5.5	-	8.1	1.4	7.4	-	100.0
2016	45.0	14.2	3.9	0.5	13.2	5.6	-	7.8	2.6	7.1	-	100.0
2017	51.1	12.6	5.4	-	9.4	5.4	-	7.2	2.4	6.6	-	100.0
2018	48.5	11.6	6.8	-	7.7	5.4	2.3	6.8	4.6	6.2	-	100.0
2019	50.2	10.9	6.5	-	6.1	5.3	2.2	6.5	6.5	5.9	-	100.0
2020	47.2	10.3	9.1	-	6.1	5.2	2.0	6.1	6.1	7.9	-	100.0
2021	47.7	9.6	8.5	-	5.6	5.1	3.8	5.7	5.7	7.4	1.0	100.0
2022	46.7	9.0	10.7	-	4.8	5.0	3.6	5.3	5.3	8.5	1.0	100.0
2023	48.8	8.5	10.0	-	4.5	4.8	3.3	5.0	5.0	8.0	2.0	100.0
2024	45.9	7.9	11.8	-	4.7	4.7	4.7	4.7	4.7	8.9	2.0	100.0
2025	47.7	7.5	11.1	-	4.4	4.6	4.4	4.4	4.4	8.4	3.0	100.0
2026	45.6	7.2	12.7	-	4.6	4.6	5.7	4.2	4.2	8.1	3.1	100.0
2027	47.5	6.6	11.8	-	4.7	4.4	5.2	3.9	3.9	7.9	4.0	100.0
2028	49.3	6.2	11.0	-	4.4	4.2	6.1	3.7	3.7	7.4	4.0	100.0

Breakdown of Renewable Energy

Energy Share (%)	in 2028 (MW)	
	Sc 2	Sc 3
PV	65.0%	6,036
Wind	34.4%	3,194
Biomass	0.6%	56

**SUMMARY OF
FIXED SYSTEM
(NOMINAL CAPACITY (MW))**

YEAR	FUEL TYPE										TOTAL	
	COAL	GAS	LNG	MFO	HSD	GEO	NUC	J-SI	PUMP	HYD		
2009	11,371	3,713	-	718	5,128	886	-	-	-	2,574	-	24,390
2010	15,531	3,713	-	274	5,078	1,136	-	-	-	2,574	-	28,306
2011	16,261	4,688	-	192	5,078	1,526	-	-	-	2,574	-	30,319
2012	17,261	5,438	-	192	5,078	1,696	-	-	-	2,621	-	32,286
2013	17,261	5,438	-	192	5,078	1,696	-	-	-	2,621	-	32,286
2014	17,261	5,438	-	192	5,078	1,916	-	2,400	-	2,621	-	34,906
2015	17,261	5,438	750	192	5,078	2,026	-	3,000	500	2,731	-	36,976
2016	17,261	5,438	1,500	192	5,078	2,136	-	3,000	1,000	2,731	-	38,336
2017	21,261	5,237	2,250	-	3,918	2,246	-	3,000	1,000	2,731	-	41,643
2018	21,261	5,072	3,000	-	3,382	2,356	1,000	3,000	2,000	2,731	-	43,802
2019	23,261	5,072	3,000	-	2,834	2,466	1,000	3,000	3,000	2,731	-	46,364
2020	23,261	5,072	4,500	-	2,984	2,576	1,000	3,000	3,000	3,901	-	49,294
2021	25,261	5,072	4,500	-	2,984	2,686	2,000	3,000	3,000	3,901	535	52,939
2022	26,261	5,072	6,000	-	2,679	2,796	2,000	3,000	3,000	4,801	567	56,176
2023	28,261	5,072	6,									