

No.

**The STUDY on  
BHERAMARA  
COMBINED CYCLE POWER STATION  
in BANGLADESH**

**Final Report  
(Main Report)**

**February, 2009**

**Japan International Cooperation Agency (JICA)**

**Tokyo Electric Power Services Co., LTD  
Tokyo Electric Power Co., LTD**

|        |
|--------|
| IDD    |
| JR     |
| 08-076 |

## **Preface**

In response to a request from the Government of People's Republic of Bangladesh, the Government of Japan decided to conduct the Feasibility Study on Bheramara Combined Cycle Power Station in Bangladesh, and entrusted the study to Japan International Cooperation Agency (JICA).

JICA sent to Bangladesh the Study Team headed by Mr. Hideyuki OKANO, Tokyo Electric Power Services Co., Ltd. and organized by Joint Venture of Tokyo Electric Power Services Co., Ltd. and Tokyo Electric Power Company. four times from February 2008 to December 2008.

The team held discussions with the officials concerned of the Government of People's Republic of Bangladesh and conducted a series of on-site surveys. After its return to Japan, the team conducted further studies and compiled the results in this report.

I hope this report will be utilized for contributing to stable power supply and environmental improvement in the People's Republic of Bangladesh as well as further evolution of friendship relations between both nations.

I wish to express my sincere appreciation to all those who participated in this study project for their close cooperation with the team.

February 2009

Seiichi NAGATSUKA  
Vice-President  
Japan International Cooperation Agency

February 2009

Mr. Seiichi NAGATSUKA  
Vice-President  
Japan International Cooperation Agency  
Tokyo, Japan

## **Letter of Transmittal**

We are pleased to submit to you the final reports of “ The STUDY on BHERAMARA COMBINED CYCLE POWER STATION in BANGLADESH.” The report is to propose the construction of high efficient and large capacity gas turbine based Combined Cycle Power Station at Bheramara in western Bangladesh and to recommend and propose appropriate management and organization of North-West Power Generation Company (hereinafter refer as “NWPGL”) and new Bheramara power station for smooth and efficient implementation of corporatization from BPDB.

We assure that the construction of the Plant will be contributive to the stabilization of power supply, the improvement of environment and the development of related areas, and that the application of the recommendations of this report to the power development plan of the People’s Republic of Bangladesh will contribute to not only the promotion of the republic welfare, but also the industrial development in the country.

Finally, we would like to express our gratitude to your agency, the Ministry of Power, Energy and Mineral Resources, Bangladesh Power Development Board, North-West Power Generation Company, Power Grid Company of Bangladesh Ltd and Department of Environment and Local Consultants for well suited advice and support.

Very truly yours,

Hideyuki OKANO  
Team Leader,  
The Study on Bheramara Combined Cycle  
Power Station  
in Bangladesh

## Table of Contents

### Overall Evaluation and Proposal

#### Part I Feasibility of Bheramara Combined Cycle Power Station Construction Plan

##### Chapter 1 Preface

|       |  |       |
|-------|--|-------|
| 1.1   | Background of the study .....                        | I-1-1 |
| 1.2   | Objectives of the Study and scope of the Study ..... | I-1-1 |
| 1.2.1 | Objectives of the Study .....                        | I-1-1 |
| 1.2.2 | Scope of the Study .....                             | I-1-2 |
| 1.2.3 | Duration of the Study .....                          | I-1-3 |
| 1.3   | Assignment of the Study Team .....                   | I-1-5 |
| 1.4   | Work Shop.....                                       | I-1-5 |
| 1.5   | Stake Holder Meeting .....                           | I-1-5 |

##### Chapter 2 Social / Economic State of Conditions in Bangladesh

|       |                                 |        |
|-------|---------------------------------|--------|
| 2.1   | Overview.....                   | I-2-1  |
| 2.2   | Population and Labor Force..... | I-2-2  |
| 2.2.1 | Population Census .....         | I-2-2  |
| 2.2.2 | Labor Force Survey .....        | I-2-3  |
| 2.3   | Macro Economy.....              | I-2-5  |
| 2.3.1 | Economic Growth.....            | I-2-5  |
| 2.3.2 | Inflation .....                 | I-2-7  |
| 2.3.3 | Fiscal Balance.....             | I-2-7  |
| 2.3.4 | Monetary Policy .....           | I-2-8  |
| 2.3.5 | Balance of Payments .....       | I-2-8  |
| 2.3.6 | Foreign Exchange Rate .....     | I-2-9  |
| 2.3.7 | Government Budget .....         | I-2-10 |
| 2.4   | Industrial Structure.....       | I-2-11 |
| 2.5   | Household Economy .....         | I-2-13 |
| 2.6   | Inflation and Prices .....      | I-2-15 |

##### Chapter 3 Power Sector in Bangladesh

|     |  |       |
|-----|--|-------|
| 3.1 | Brief of Power Sector in Bangladesh..... | I-3-1 |
|-----|--|-------|

|       |  |        |
|-------|--|--------|
| 3.2   | Organization of Power Sector in Bangladesh .....                 | I-3-11 |
| 3.3   | Financial Standing of Bangladesh Power Development Board .....   | I-3-14 |
| 3.3.1 | Business Performance .....                                       | I-3-16 |
| 3.3.2 | Equity Capital Account .....                                     | I-3-19 |
| 3.3.3 | Asset Accounts .....   | I-3-19 |
| 3.3.4 | Liability Accounts .....   | I-3-21 |
| 3.3.5 | Ratio Analysis.....  | I-3-21 |
| 3.4   | Electricity Tariff.....  | I-3-22 |
| 3.4.1 | International Comparison of Electricity Tariff .....             | I-3-22 |
| 3.4.2 | Electricity Tariff .....   | I-3-23 |
| 3.4.3 | Tariff Policy at Bangladesh Energy Regulatory Commission .....   | I-3-25 |
| 3.4.4 | The Electricity Tariff of Independent Power Producer (IPP) ..... | I-3-27 |

## Chapter 4 Technical Feasibility of the Project

|       |  |        |
|-------|--|--------|
| 4.1   | Power Demand Forecast .....                                | I-4-1  |
| 4.1.1 | The Way of Thinking of the Power Demand Forecast .....     | I-4-1  |
| 4.1.2 | Justification of Power Demand Forecast in PSMP 2006.....   | I-4-1  |
| 4.2   | Benefits .....   | I-4-3  |
| 4.2.1 | Electrification rate .....                                 | I-4-3  |
| 4.2.2 | Benefits to Accrue in the Industrial Sector.....           | I-4-5  |
| 4.3   | Power Generation Development Planning .....                | I-4-6  |
| 4.3.1 | Existing power generation facilities .....                 | I-4-6  |
| 4.3.2 | Current Situation of Demand – Supply Balance .....         | I-4-8  |
| 4.3.3 | Power Generation Development Planning .....                | I-4-9  |
| 4.4   | Power System Planning .....                                | I-4-12 |
| 4.4.1 | Transmission and substation facilities owned by PGCB ..... | I-4-12 |
| 4.4.2 | Transmission facilities related to this project .....      | I-4-17 |
| 4.4.3 | System analysis .....                                      | I-4-18 |
| 4.5   | Fuel Supply Planning.....                                  | I-4-19 |
| 4.5.1 | Gas production volume and forecast of gas reserve.....     | I-4-19 |
| 4.5.2 | Forecast of gas supply volume and gas demand .....         | I-4-19 |
| 4.5.3 | Gas pipeline construction project.....                     | I-4-22 |
| 4.5.4 | Possibility of gas supply to the Bheramara CCPP.....       | I-4-25 |
| 4.5.5 | Supply of fuel oil to Bheramara CCPP.....                  | I-4-25 |
| 4.6   | Site conditions.....                                       | I-4-26 |
| 4.6.1 | General .....  | I-4-26 |
| 4.6.2 | Site Location .....  | I-4-26 |
| 4.6.3 | Site Planning .....  | I-4-27 |
| 4.6.4 | Topography and Soil Conditions .....                       | I-4-30 |

|        |   |         |
|--------|---|---------|
| 4.6.5  | Water Source .....  | I-4-45  |
| 4.6.6  | Site Environment.....   | I-4-67  |
| 4.7    | Study on Selection of Combined Cycle Power Plant.....           | I-4-68  |
| 4.7.1  | Fuel Flexibility of Combined Cycle Power Plant.....             | I-4-68  |
| 4.7.2  | Selection of Combined Cycle Power Plant Technology .....        | I-4-75  |
| 4.7.3  | Study on Shaft Configuration.....                               | I-4-82  |
| 4.7.4  | Selection of Cooling System .....                               | I-4-104 |
| 4.8    | Equipments and materials transportation.....                    | I-4-129 |
| 4.8.1  | Procurement of equipments and materials .....                   | I-4-130 |
| 4.8.2  | Heavy weight equipments transportation .....                    | I-4-130 |
| 4.8.3  | Transportation limit .....                                      | I-4-131 |
| 4.8.4  | Survey and study policy .....                                   | I-4-133 |
| 4.8.5  | Selection of candidate transportaion routes.....                | I-4-133 |
| 4.8.6  | Survey of candidate transportaion routes .....                  | I-4-135 |
| 4.8.7  | Recommended transportation route.....                           | I-4-145 |
| 4.8.8  | Heavy weight cargoes transportation method for maintenance..... | I-4-147 |
| 4.9    | Project Implementation Schedule .....                           | I-4-147 |
| 4.9.1  | General .....   | I-4-147 |
| 4.9.2  | Project Implementation Schedule.....                            | I-4-147 |
| 4.10   | Outline of Long Term Service Agreement for Gas Turbine.....     | I-4-149 |
| 4.11   | Project Implementation Organization .....                       | I-4-151 |
| 4.11.1 | General .....   | I-4-151 |
| 4.11.2 | Organization of NWPGL.....                                      | I-4-152 |
| 4.12   | Conclusion .....  | I-4-155 |
| 4.12.1 | Evaluation.....   | I-4-155 |
| 4.12.2 | Confirmation of Technical Feasibility.....                      | I-4-155 |

## Chapter 5 Basic Design

|       |   |        |
|-------|---|--------|
| 5.1   | Outline of the Project .....                                      | I-5-1  |
| 5.2   | Operational Requirements.....                                     | I-5-1  |
| 5.2.1 | General .....   | I-5-1  |
| 5.2.2 | Plant Duty.....   | I-5-1  |
| 5.2.3 | Control and Operation Philosophy .....                            | I-5-2  |
| 5.3   | Study on Basic Technical Issues .....                             | I-5-4  |
| 5.3.1 | Expected Performance of Bherarma Combined Cycle Power Plants..... | I-5-4  |
| 5.3.2 | Bottoming Cycle Optimization .....                                | I-5-21 |
| 5.3.3 | Exhaust Gas Bypass System.....                                    | I-5-23 |
| 5.3.4 | Auxiliary Boiler.....   | I-5-26 |

|        |   |        |
|--------|---|--------|
| 5.4    | Scope of Works .....                                  | I-5-26 |
| 5.4.1  | Procurement and/or Manufacture .....                  | I-5-26 |
| 5.4.2  | Works and Services to be provided by Contractor ..... | I-5-27 |
| 5.4.3  | Works and Services to be provided by Employer.....    | I-5-30 |
| 5.4.4  | Terminal Points.....                                  | I-5-30 |
| 5.5    | Plant Design Considerations .....                     | I-5-31 |
| 5.5.1  | Design Conditions .....                               | I-5-31 |
| 5.5.2  | Codes and Standards.....                              | I-5-32 |
| 5.5.3  | Site Layout .....                                     | I-5-32 |
| 5.5.4  | Environmental Requirements .....                      | I-5-33 |
| 5.5.5  | Gas Turbine .....                                     | I-5-36 |
| 5.5.6  | Heat Recovery Steam Generator .....                   | I-5-37 |
| 5.5.7  | Steam Turbine.....                                    | I-5-39 |
| 5.5.8  | Fuel Supply System.....                               | I-5-40 |
| 5.5.9  | Water Treatment System.....                           | I-5-42 |
| 5.5.10 | Wastewater System.....                                | I-5-44 |
| 5.5.11 | Fire Fighting System .....                            | I-5-44 |
| 5.5.12 | Electrical Equipment .....                            | I-5-45 |
| 5.5.13 | Protection and Control System.....                    | I-5-51 |
| 5.5.14 | Civil and Building Works .....                        | I-5-53 |
| 5.5.15 | Substation .....                                      | I-5-57 |
| 5.5.16 | Transmission Line .....                               | I-5-67 |

## Chapter 6 Study of Construction Plant

|     |   |       |
|-----|---|-------|
| 6.1 | Connection with Gas Pipeline.....       | I-6-1 |
| 6.2 | Connection with Transmission Line ..... | I-6-3 |
| 6.3 | Facilities for Construction .....       | I-6-7 |
| 6.4 | Temporary Utility Supply .....          | I-6-9 |

## Chapter 7 Environmental and Social Consideration

|       |  |        |
|-------|--|--------|
| 7.1   | Outline of the proposed site .....       | I-7-1  |
| 7.1.1 | Location of the proposed site .....      | I-7-1  |
| 7.1.2 | Outline of the natural environment ..... | I-7-1  |
| 7.1.3 | Outline of the social environment .....  | I-7-18 |
| 7.2   | EIA related Laws and Regulations.....    | I-7-34 |
| 7.2.1 | EIA Regulations and procedures .....     | I-7-35 |

|       |   |        |
|-------|---|--------|
| 7.2.2 | EIA related organizations .....   | I-7-38 |
| 7.2.3 | Relation with the project .....   | I-7-43 |
| 7.2.4 | EIA Schedule .....  | I-7-43 |
| 7.3   | Environment impact assessment and measures for avoiding or mitigating the impact .<br>..... | I-7-44 |
| 7.3.1 | Environment impact assessment for selected method .....                                     | I-7-44 |
| 7.3.2 | Impact assessment and measures for avoiding or mitigating the impact .....                  | I-7-48 |
| 7.4   | Environmental Management Plan and Monitoring Plan .....                                     | I-7-81 |
| 7.4.1 | The objective of the environmental management plan.....                                     | I-7-81 |
| 7.4.2 | Work Plans and Schedules .....  | I-7-86 |
| 7.4.3 | Environmental Implementation and Training .....   | I-7-91 |
| 7.4.4 | Environmental Monitoring Plan .....   | I-7-91 |
| 7.5   | Stakeholder consultation (explanation to local residents) .....                             | I-7-93 |
| 7.5.1 | Purposes .....  | I-7-93 |
| 7.5.2 | Implementation .....  | I-7-93 |
| 7.5.3 | Result of the consultations .....   | I-7-94 |
| 7.5.4 | The Focus Group Discussions .....   | I-7-97 |
| 7.5.5 | Opinions from the local residents at social environmental survey .....                      | I-7-98 |

## Chapter 8 Project Cost and Economic and Financial Analysis

|       |  |        |
|-------|--|--------|
| 8.1   | Operational Condition of the Bheramara CCPP .....    | I-8-1  |
| 8.2   | Project Cost.....                                    | I-8-2  |
| 8.2.1 | Trend of FOB price for F-class CCPP.....             | I-8-2  |
| 8.2.2 | Contract Records of F-class CCPP.....                | I-8-3  |
| 8.2.3 | Estimation of Project Cost.....                      | I-8-5  |
| 8.2.4 | Justification of the Project Cost Estimation .....   | I-8-7  |
| 8.3   | The Basis of Economic and Financial Analyses .....   | I-8-9  |
| 8.4   | Financial Evaluation .....                           | I-8-13 |
| 8.4.1 | Method of Evaluation and the Basic Parameters.....   | I-8-13 |
| 8.4.2 | Financial Cost.....                                  | I-8-14 |
| 8.4.3 | Financial Benefit .....                              | I-8-19 |
| 8.4.4 | Financial Analysis .....                             | I-8-20 |
| 8.4.5 | Sensitivity Test .....                               | I-8-24 |
| 8.5   | Economic Evaluation .....                            | I-8-26 |
| 8.5.1 | Methodology of Evaluation and Basic Assumptions..... | I-8-26 |
| 8.5.2 | Economic Cost .....                                  | I-8-26 |
| 8.5.3 | Economic Benefit.....                                | I-8-29 |
| 8.5.4 | Economic Evaluation .....                            | I-8-36 |
| 8.5.5 | Sensitivity Test .....                               | I-8-37 |



|     |                                 |        |
|-----|---------------------------------|--------|
| 8.6 | Key Performance Indicators..... | I-8-39 |
|-----|---------------------------------|--------|

## Part II Proposal for Corporation Plan and Organization of NWPGL and Bheramara Combined Cycle Power Station

### Chapter 1 Introduction

|     |                               |        |
|-----|-------------------------------|--------|
| 1.1 | Objectives.....               | II-1-1 |
| 1.2 | Terms of Reference (TOR)..... | II-1-1 |
| 1.3 | Composition of Experts.....   | II-1-2 |
| 1.4 | Field Survey Schedule.....    | II-1-2 |

### Chapter 2 NWPGL Corporate Directivity

|       |  |        |
|-------|--|--------|
| 2.1   | Phase-wise Roadmap.....                                      | II-2-1 |
| 2.2   | Phase-wise Ideal Figures of NWPGL.....                       | II-2-2 |
| 2.3   | Factor Analysis of Power Crisis .....                        | II-2-3 |
| 2.4   | Corporate Visions .....                                      | II-2-5 |
| 2.4.1 | Inter Linkage with Power Sector Roadmap & NWPGL Vision ..... | II-2-5 |
| 2.4.2 | Vision Statements for NWPGL.....                             | II-2-5 |

### Chapter 3 Corporate Governance

|       |  |         |
|-------|--|---------|
| 3.1   | Approaches to Realizing the Corporate Visions.....                         | II-3-1  |
| 3.2   | Fundamental Frame in Corporate Governance .....                            | II-3-1  |
| 3.2.1 | Outline.....   | II-3-1  |
| 3.3   | Applicable Laws and Regulations in Bangladesh .....                        | II-3-2  |
| 3.3.1 | Corporate Governance Code 2004 .....                                       | II-3-2  |
| 3.3.2 | Bangladesh Companies Act 1994.....   | II-3-4  |
| 3.3.3 | Three (3)-Year Road Map For Power Sector Reform (2008 - 2010).....         | II-3-5  |
| 3.4   | Key Findings from Corporatization Review Phase.....                        | II-3-5  |
| 3.4.1 | Board Composition .....  | II-3-6  |
| 3.4.2 | Governance Framework .....   | II-3-6  |
| 3.4.3 | Segregation of Ownership & Management .....                                | II-3-6  |
| 3.4.4 | Board Committees.....  | II-3-6  |
| 3.5   | Establishment of Fundamental Framework in Corporate Governance System..... | II-3-10 |
| 3.5.1 | Board Composition and Governance Framework .....                           | II-3-10 |

|  |         |
|--|---------|
| 3.5.2 Principle of Segregating Execution and Supervisory Functions of Management ..... | II-3-11 |
| 3.5.3 Reorganization to Clarify Management Responsibilities .....                      | II-3-15 |
| 3.5.4 Reinforcement of Audit Function .....  | II-3-16 |
| 3.5.5 Visualization of Management and Operation System .....                           | II-3-23 |
| 3.5.6 Transfer of the project .....  | II-3-24 |
| 3.5.7 Transfer of the existing BPDB P/S .....  | II-3-24 |

## Chapter 4 Human Capital Management

|  |         |
|--|---------|
| 4.1 Approaches to Realizing the Corporate Visions .....                                | II-4-1  |
| 4.2 Directivity of Human Capital Management .....                                      | II-4-1  |
| 4.2.1 Basic Concept of Human Capital Management .....                                  | II-4-1  |
| 4.2.2 Direction in Human Capital Management which should be Aimed for by NWPGL ..      | II-4-2  |
| 4.2.3 The Job Description concerning the Career Development Program of the Head Office | II-4-3  |
| and Power Station.....   | II-4-3  |
| 4.3 Organizational Management System.....  | II-4-4  |
| 4.3.1 General Concept of Organization Structure .....                                  | II-4-4  |
| 4.3.2 Corporate Level Structure .....  | II-4-4  |
| 4.3.3 Recommendation of Corporate Level Structure.....                                 | II-4-5  |
| 4.3.4 Plant Level Structure.....   | II-4-7  |
| 4.3.5 Recommendation for Plant-level Structure .....                                   | II-4-9  |
| 4.4 Recruitment and Relocation Management .....  | II-4-12 |
| 4.4.1 Positions .....  | II-4-12 |
| 4.4.2 Selection Procedure.....   | II-4-13 |
| 4.4.3 Tenure and Conditions of Appointment .....                                       | II-4-14 |
| 4.4.4 Selection Committee .....  | II-4-15 |
| 4.4.5 Key Learnings from the Previous Experience.....                                  | II-4-15 |
| 4.4.6 Recommendation of NWPGL Recruitment and Relocation Management .....              | II-4-18 |
| 4.5 Performance Evaluation System and Promotion System of Individuals.....             | II-4-21 |
| 4.5.1 As-is Analysis on Previous Cases.....  | II-4-22 |
| 4.5.2 Key Learnings from the Previous Cases .....                                      | II-4-25 |
| 4.5.3 Recommendation of NWPGL Performance Evaluation System .....                      | II-4-26 |
| 4.6 Compensation and Incentive System .....  | II-4-28 |
| 4.6.1 Basic Pay .....  | II-4-28 |
| 4.6.2 Incentive and Benefit .....  | II-4-30 |
| 4.6.3 Recommendations for Compensation Incentive and Benefits System.....              | II-4-34 |
| 4.7 Career Development.....  | II-4-37 |

|   |         |
|---|---------|
| 4.7.1 Approach to Career Development .....  | II-4-37 |
| 4.7.2 As- is Analysis.....  | II-4-37 |
| 4.7.3 Gap Analysis: Career Development and Training .....                           | II-4-38 |
| 4.7.4 Recommendations for Career Development and Training .....                     | II-4-40 |
| 4.8 Acceptance of Existing Power Stations and Simulation of Manpower Planning ..... | II-4-41 |
| 4.8.1 Simulation of Manpower Planning.....  | II-4-41 |
| 4.8.2 Considerations on the Acceptance of Existing Power Stations .....             | II-4-44 |

## Chapter 5 Accounting and Financial Management

|   |         |
|---|---------|
| 5.1 Approach for Achieving the Corporate Vision .....                               | II-5-1  |
| 5.2 Accounting and Accounting Policies.....   | II-5-1  |
| 5.2.1 Accounting System at BPDB .....   | II-5-1  |
| 5.2.2 Organizational Structure of Finance and Accounts Department .....             | II-5-2  |
| 5.2.3 Chart of Accounts.....  | II-5-3  |
| 5.2.4 Accounts Processing.....  | II-5-3  |
| 5.2.5 Accounting System and Practice at Preceding Corporatized Power Entities ..... | II-5-4  |
| 5.2.6 Recommendation for Accounting System and Processing at NWPGL .....            | II-5-7  |
| 5.2.7 Recommendation for Establishing the Integrated Accounting Package.....        | II-5-13 |
| 5.3 Accounting Policies.....  | II-5-22 |
| 5.3.1 Accounting Policies.....  | II-5-22 |
| 5.3.2 Recommendation for Establishing the Accounting Policies .....                 | II-5-22 |
| 5.3.3 Framework of Significant Accounting Policies.....                             | II-5-23 |
| 5.4 Financial Policy and Management .....   | II-5-29 |
| 5.4.1 Financial Restructuring of Power Sector Entities .....                        | II-5-29 |
| 5.4.2 Financial Management .....  | II-5-31 |
| 5.4.3 Delegation of Power and Internal Control .....                                | II-5-32 |
| 5.4.4 Establishment of Financial Policy .....                                       | II-5-34 |
| 5.4.5 Risks and Preventive Measures .....   | II-5-34 |
| 5.5 Budget .....  | II-5-39 |
| 5.5.1 Budget System at BPDB .....   | II-5-39 |
| 5.5.2 Recommendation for Establishing Budget System .....                           | II-5-43 |
| 5.6 Management Accounting.....  | II-5-46 |
| 5.6.1 Roles and Functions of Management Accounting.....                             | II-5-46 |
| 5.6.2 Recommendation for Establishing the Management Accounting System.....         | II-5-48 |
| 5.7 Financial Simulation .....  | II-5-50 |
| 5.7.1 Financial Model.....  | II-5-50 |
| 5.7.2 Assumptions .....   | II-5-50 |
| 5.7.3 Simulation .....  | II-5-51 |

|   |         |
|---|---------|
| 5.7.4 Sensitivity Test .....              | II-5-52 |
| 5.7.5 Input and Output of the Model ..... | II-5-53 |

## Chapter 6 Operation and Maintenance Management

|   |         |
|---|---------|
| 6.1 Approach for Achieving the Corporate Vision .....   | II-6-1  |
| 6.2 Strengthening of Organization Management (Construction of O&M Management System based on PDCA)..... | II-6-1  |
| 6.2.1 Segregation of Duties between Head Office and P/S.....  | II-6-1  |
| 6.3 Strengthening of Cause Analysis Ability.....  | II-6-2  |
| 6.3.1 Selection of Maintenance Management Method.....   | II-6-2  |
| 6.3.2 Proposal of Concrete Management Method.....   | II-6-6  |
| 6.4 O&M Implementation System .....   | II-6-11 |
| 6.5 Long-term Human Capital Development.....  | II-6-14 |
| 6.5.1 Development of Staffs during the Construction Period.....   | II-6-14 |
| 6.5.2 Training System.....  | II-6-15 |
| 6.6 Support for the Implementation of Environment Management Planning and Monitoring ...                |         |
| .....   | II-6-15 |
| 6.6.1 Corporate Level.....  | II-6-15 |
| 6.6.2 Management Level.....   | II-6-16 |
| 6.6.3 Plant Level .....   | II-6-17 |
| 6.6.4 Public Level .....  | II-6-19 |

## Chapter 7 Safety Management

|   |         |
|---|---------|
| 7.1 Approach for Achieving the Corporate Vision .....                         | II-7-1  |
| 7.2 Clarification of Definition .....   | II-7-1  |
| 7.3 Current Analysis.....   | II-7-1  |
| 7.3.1 Understanding of Current Situation .....                                | II-7-1  |
| 7.3.2 Gap Analysis .....  | II-7-2  |
| 7.4 Recommendation.....   | II-7-4  |
| 7.4.1 Approach for Achieving Reduction of Risk .....                          | II-7-4  |
| 7.4.2 Organizational and Institutional Aspects.....                           | II-7-5  |
| 7.4.3 Management Methodology .....  | II-7-7  |
| 7.4.4 Ex-ante Activity (Preventive Activities).....                           | II-7-7  |
| 7.4.5 Ex-post Activity.....   | II-7-9  |
| 7.4.6 Safety Equipment .....  | II-7-10 |
| 7.4.7 Strengthening Safety Management System during Construction Period ..... | II-7-10 |

## Chapter 8 Information Management System (IMS)

|  |         |
|--|---------|
| 8.1 Approach for Achieving the Corporate Vision .....                      | II-8-1  |
| 8.2 The Necessity of Establishing an Information Management Strategy ..... | II-8-1  |
| 8.3 Concrete Strategy .....  | II-8-2  |
| 8.3.1 Total System .....   | II-8-2  |
| 8.3.2 External Information Transmission .....                              | II-8-4  |
| 8.3.3 Internal information transmission .....                              | II-8-4  |
| 8.3.4 Application in O & M.....  | II-8-5  |
| 8.4 PI System .....  | II-8-6  |
| 8.4.1 PI System in Information Management.....                             | II-8-6  |
| 8.4.2 Hardware, Software List and Budgetary Quotation .....                | II-8-10 |

## Chapter 9 Risk Management

|  |         |
|--|---------|
| 9.1 Relevant Contract.....   | II-9-1  |
| 9.1.1 Subsidiary Loan Agreement .....  | II-9-1  |
| 9.1.2 Employment Contract .....  | II-9-2  |
| 9.1.3 Power Purchase Agreement (PPA) .....   | II-9-4  |
| 9.1.4 Gas Sales Agreement (GSA) .....  | II-9-5  |
| 9.1.5 Maintenance Management Contract.....   | II-9-6  |
| 9.2 Preparation/ during construction stage (Phase 1) .....                         | II-9-7  |
| 9.2.1 Risks which the Construction is not as Planned.....                          | II-9-7  |
| 9.2.2 Risks which incur at the Time of Transfer of Existing Power Station(s) ..... | II-9-8  |
| 9.3 Immediate Operation Stage (Phase 2: Up to 3 Years from Commissioning) .....    | II-9-9  |
| 9.3.1 Forced Outage/Accidents due to Initial Troubles.....                         | II-9-9  |
| 9.3.2 Gas Depletion.....   | II-9-9  |
| 9.4 Stable Operation Stage(Phase 3 : 3-10 Years form Commissioning) .....          | II-9-16 |
| 9.4.1 Risks of not being able to carry out Periodic Inspections on Schedule.....   | II-9-16 |
| 9.4.2 Risks regarding Deterioration of Management Environment .....                | II-9-17 |
| 9.4.3 Risks of Decline in Capacity Factor.....                                     | II-9-19 |

## Chapter 10 Management Plan

|   |         |
|---|---------|
| 10.1 Policy Management.....                         | II-10-1 |
| 10.1.1 Significance of Policy Management.....       | II-10-1 |
| 10.1.2 Flow of Policy Management Activity .....     | II-10-1 |
| 10.1.3 Activity Schedule of Target Management ..... | II-10-2 |
| 10.1.4 Target Management Items .....                | II-10-3 |

|   |          |
|---|----------|
| 10.1.5 Issues for Promoting Target Management Activity .....                              | II-10-4  |
| 10.1.6 Assigned Role in the Policy Management.....  | II-10-5  |
| 10.1.7 Relation between Management Plan and other Plans.....                              | II-10-6  |
| 10.2 Relation between NWPGL and Each Power Station .....                                  | II-10-6  |
| 10.2.1 Structure of Performance Evaluation .....  | II-10-6  |
| 10.2.2 Delegation of Authority to the Director of Power Plant and Evaluation Method ..... | II-10-10 |
| 10.2.3 Line of Business Contents Required from NWPGL.....                                 | II-10-11 |
| 10.3 Proto Type of Mid-term Management Plan.....  | II-10-11 |
| 10.3.1 Proto Type of Mid-term Management Plan for NWPGL .....                             | II-10-11 |
| 10.3.2 Proto Type of Mid-term Management Plan for Bheramara Power Station .....           | II-10-12 |
| 10.4 Promotion of TQM.....  | II-10-12 |
| 10.4.1 Organizational Structure for TQM Promotion .....                                   | II-10-12 |
| 10.4.2 Function of TQM Promotion Office.....  | II-10-14 |

## Chapter 11 Roadmap for Corporatization

|  |         |
|--|---------|
| 11.1 Short-term Roadmap .....  | II-11-1 |
| 11.2 Mid-term Roadmap .....  | II-11-3 |
| 11.3 Long-term Roadmap.....  | II-11-6 |
| 11.4 Fields which need to be strengthened.....   | II-11-7 |
| 11.4.1 Improvement of management capability by introducing TQM activities.....                                 | II-11-7 |
| 11.4.2 Improvement of operation management capability by introducing operating simulator.....                  | II-11-8 |
| 11.4.3 Improvement of maintenance management capability by introducing non-destructive inspection method ..... | II-11-9 |

## Abbreviations

|        |  |
|--------|--|
| A&G    | Administrative and General   |
| AASHTO | American Association of State Highway and Transportation Officials |
| AC     | Alternating Current  |
| ACCPAC | ACCPAC (Name of Software)  |
| ACE    | Advanced Computing Engine  |
| ACI    | American Concrete Institute  |
| ADB    | Asian Development Bank   |
| ADP    | Annual Development Programme                                       |
| AE     | Assistant engineer   |
| AEO    | Annual Energy Outlook  |
| AES    | American Energy Services Inc. (AES, Inc.)                          |
| AIS    | Air Insulated Switchgear   |
| AISC   | American Institute of Steel Construction                           |
| AISI   | American Iron and Steel Institute                                  |
| AM     | Assistant Manager  |
| ANSI   | American National Standards Institute                              |
| APC    | Auxiliary Power Consumption  |
| APR    | Annual Performance Report  |
| APSCL  | Ashuganj Power Station Company Limited                             |
| ASCE   | American Society of Civil Engineering                              |
| ASME   | American Society of Mechanical Engineers                           |
| ASTM   | American Society for Testing and Materials                         |
| AVR    | Automatic Voltage Regulator system                                 |
| AWS    | American Welding Society   |
| AWWA   | American Water Works Association                                   |
| B/S    | Balance Sheet  |
| BADC   | Bangladesh Agriculture Development Corporation                     |
| BAPEX  | Bangladesh Petroleum Exploration Company Ltd                       |
| BAS    | Bangladesh Accounting Standard                                     |
| BB     | Bangladesh Bank  |
| BDM    | Break Down Maintenance   |
| BEI    | Bangladesh Enterprise Institute                                    |
| BERC   | Bangladesh Energy Regulatory Commission                            |
| BIWTA  | Bangladesh Inland Water Transport Authority                        |
| BNBC   | Bangladesh National Building Code                                  |
| BPC    | Bangladesh Petroleum Corporation                                   |
| BPDB   | Bangladesh Power Development Board                                 |

|       |   |
|-------|---|
| BPHE  | Bangladesh Public Health Engineer                   |
| BUET  | Bangladesh University of Engineering and Technology |
| BWDB  | Bangladesh Water Development Board                  |
| C/P   | Counterpart   |
| CB    | Cash and Bank Management                            |
| CBM   | Condition Based Maintenance                         |
| CCDB  | Christian Commission for Development in Bangladesh  |
| CCGT  | Combined Cycle Gas Turbine                          |
| CCPP  | Combined Cycle Power Plant                          |
| CCR   | Central Control Room                                |
| CD    | Custom Duty   |
| CE    | Chief Engineer                                      |
| CEMS  | Continuous Emission Monitoring System               |
| CEO   | Chief Executive Officer                             |
| CFO   | Chief Financial Officer                             |
| CGS   | City Gate Station                                   |
| CHCO  | Chief Human Capital Officer                         |
| CHRO  | Chief Human Resource Officer                        |
| CIO   | Chief Information Officer                           |
| CMD   | Chairman and Managing Director                      |
| CNG   | Compressed Natural Gas                              |
| COD   | Commissioning Date                                  |
| COO   | Chief Operating Officer                             |
| CPA   | Certified Public Accountant                         |
| CPDO  | Chief Planning & Development Officer                |
| CPF   | Contributory Provident Fund                         |
| CPI   | Consumer Price Index                                |
| CRO   | Chief Risk Officer                                  |
| CSR   | Corporate Social Responsibility                     |
| CV    | Calorific Value                                     |
| CWIP  | Capital Work In Progress                            |
| CZPDC | Central Zone Power Distribution Company             |
| DC    | Direct Current                                      |
| DCCI  | Dhaka Chamber of Commerce & Industry                |
| DCS   | Distributed Control System                          |
| DESA  | Dhaka Electricity Supply Authority                  |
| DESCO | Dhaka Electricity Supply Company                    |
| DG    | Director General                                    |
| DGM   | Deputy General Manager                              |
| DM    | Deputy Manager                                      |



|       |  |
|-------|--|
| DO    | Diesel Oil   |
| DOE   | Department of Environment                                  |
| DPA   | Direct Project Aid   |
| DPP   | Development Project Proforma                               |
| DR    | Discount Rate  |
| DSCR  | Debt Service Coverage Ratio                                |
| Dy    | Deputy   |
| E&Y   | Ernst & Young  |
| EBIT  | Earnings Before Interest and Tax                           |
| EBITD | Earnings Before Interest, Tax and Depreciation             |
| ECNEC | Executive Committee of National Economic Council           |
| ED    | Executive Director   |
| EE    | Executive Engineer   |
| EGCB  | Electricity Generation Company of Bangladesh Ltd.          |
| EIA   | Environmental Impact Assessment                            |
| EIRR  | Economic Internal Rate of Return                           |
| EOH   | Equivalent Operation Hour                                  |
| EPC   | Engineering, Procurement and Construction Contract         |
| ERC   | Energy Regulatory Commission                               |
| ERD   | Economic Relations Division                                |
| ERP   | Enterprise Resource Planning                               |
| ES    | Escalation rate of power Sales tariff                      |
| F(&)A | Finance & Accounting                                       |
| F.eX  | Foreign Exchange   |
| FBCC  | Federation of Bangladesh Chambers of Commerce and Industry |
| FD    | Fixed Deposit  |
| FE    | Foreign Exchange   |
| FIFO  | First In and First Out                                     |
| FIRR  | Financial Internal Rate of Return                          |
| FOB   | Free on Board  |
| FRRP  | Power Sector Financial Restructuring and Recovery Plan     |
| FSA   | Fuel Supply Agreement                                      |
| FY    | Fiscal Year  |
| GCB   | Gas Circuit Breaker  |
| GCC   | Gas Combined Cycle   |
| GCV   | Gross Calorific Value                                      |
| GFA   | Gross Fixed Assets   |
| GIS   | Gas Insulated Switchgear                                   |
| GJ    | Giga Joules  |
| GL    | General Ledger   |

|       |  |
|-------|--|
| GM    | General Manager  |
| GNI   | Gross National Income                                      |
| GOB   | Government of Bangladesh                                   |
| GOJ   | Government of Japan  |
| GSA   | Gas Sales Agreement  |
| GT    | Gas Turbine  |
| GTCL  | Gas Transmission Company Limited                           |
| GTG   | Gas Turbine Generator                                      |
| HMS   | Human Machine System                                       |
| HO    | Heavy Oil  |
| HR    | Human Resource   |
| HRA   | House Rent Allowance                                       |
| HRD   | Human Resource Development                                 |
| HRSG  | Heat Recovery Steam Boiler                                 |
| HSD   | High Speed Diesel  |
| HSE   | Health Safety & Environment                                |
| HSEQ  | Health Safety, Environment & Quality                       |
| HT    | High Tension   |
| I&C   | Instrumentation and Control                                |
| IAS   | International Accounting Standards                         |
| IASB  | International Accounting Standard Board                    |
| Ic/R  | Inception Report   |
| ICAB  | Institute of Chartered Accountants of Bangladesh           |
| ICMAB | Institute of Cost and Management Accountants of Bangladesh |
| IDA   | International Development Agency                           |
| IDB   | Islamic Development Bank                                   |
| IDC   | Interest During Construction                               |
| IEB   | Institute of Engineers of Bangladesh                       |
| IEE   | Initial Environmental impact Examination                   |
| IFRS  | International Financial Reporting Standards                |
| IMED  | Implementation, Monitoring and Evaluation Division         |
| IMS   | Information Management System                              |
| INA   | Information Not Available                                  |
| IOC   | International Oil Company                                  |
| IPB   | Isolated Phase Bus   |
| IPCC  | Intergovernmental Panel on Climate Change                  |
| IPP   | Independent Power Producer                                 |
| ISA   | Instrumentation, System, and Automation Society            |
| ISO   | International Standard Organization                        |
| IT    | Information Technology                                     |

|                 |  |
|-----------------|--|
| JAM             | Junior Assistant Manager                                 |
| JBIC            | Japan Bank for International Cooperation                 |
| JICA            | Japan International Cooperation Agency                   |
| KEM             | Key Executive Manager                                    |
| KLHEP           | Kargi Langpi Hydro Electric Project                      |
| KPI             | Key Performance Indicator                                |
| KSAO            | Knowledge, Skills, Abilities and Other traits or factors |
| KYT             | Kiken Yochi Training                                     |
| L/A             | Loan Agreement   |
| L/T             | Long Term  |
| LA              | Lightening Arrester                                      |
| LCD             | Liquid Crystal Display                                   |
| LDC             | Load Dispatch Center                                     |
| LTPM            | Long Term Parts Management                               |
| LTSA            | Long Term Service Agreement                              |
| MBO             | Management by Objective                                  |
| MD              | Managing Director  |
| MES             | Manufacturing Execution System                           |
| MIS             | Management Information System                            |
| MLA             | Multilateral Lending Agency                              |
| mmscfd          | Million standard cubic feet per day                      |
| MOH             | Major Overhaul   |
| MOL             | Ministry of Land   |
| MOM             | Minutes of Meeting                                       |
| MoPEMR          | Ministry of Power, Energy & Mineral Resources            |
| MP              | Master Plan  |
| MS              | Multi-shaft  |
| MSCF            | Mil (Thousand) Standard Cubic Feet                       |
| MTMF            | Medium Term Macroeconomic Framework                      |
| MU              | Million Unit   |
| MW              | Mega Watt  |
| NFPA            | National Fire Protection Association                     |
| NLDC            | National Load Dispatch Center                            |
| NO <sub>x</sub> | Nitrogen oxide   |
| NRV             | Net Realizable Value                                     |
| NTPC            | National Thermal Power Corporation Ltd                   |
| NWPGCL          | North-West Power Generation Company Ltd.                 |
| O&M             | Operation and Maintenance                                |
| OA              | Office Automation  |
| OCB             | Oil Circuit Breaker                                      |

|       |   |
|-------|---|
| OCGT  | Open Cycle Gas Turbine                                |
| OECD  | Organization for Economic Cooperation and Development |
| OEM   | Original Equipment Manufacturer                       |
| OH    | Overhaul  |
| OJT   | On the Job Training                                   |
| OMCO  | Operation & Maintenance Chief Officer                 |
| OPGW  | Optical Ground Wire                                   |
| P/S   | Power Station   |
| PAT   | Profit After Tax                                      |
| PBITD | Profits Before Interest, Tax and Depreciation         |
| PBS   | Palli Bidyut Samities                                 |
| PC    | Personal Computer                                     |
| PC    | Power Cell  |
| PCS   | Process Control System                                |
| PDA   | Personal Digital Assistant                            |
| PDCA  | Plan Do Check Action                                  |
| PDPAT | Power Development Planning Assist Tool                |
| PGCB  | Power Grid Company of Bangladesh                      |
| PI    | Plant Information                                     |
| PIMS  | Plant Information Management System                   |
| PIU   | Project Implementation Unit                           |
| PLC   | Programmable Logoc Controller                         |
| PM    | Plant Manager   |
| PMB   | Plant Management Board                                |
| PMC   | Plant Management Committee                            |
| POAE  | Plant Operating Availability on an Energy basis       |
| POAH  | Plant Operating Availability                          |
| PP    | Power Purchased                                       |
| PP    | Project Proforma                                      |
| PPA   | Power Purchase Agreement                              |
| PPE   | Personal Protective Equipments                        |
| PSMP  | Power System Master Plan                              |
| PSP   | Power Sales Tariff                                    |
| PTW   | Permit to Work  |
| PwC   | Pricewaterhouse Coopers Pvt. Ltd.                     |
| QC    | Quality Control                                       |
| R&M   | Repair and Maintenance                                |
| RAO   | Regional Administration Office                        |
| RDPP  | Revised Development Project Proforma                  |
| REB   | Rural Electrification Board                           |

|        |  |
|--------|--|
| RMS    | Regulative Metering Station                          |
| ROA    | Return on Asset                                      |
| RPA    | Residual Project Aid                                 |
| S/S    | Substation   |
| SBU    | Strategic Business Unit                              |
| SCADA  | Supervisory Control And Data Acquisition             |
| SCGT   | Simple Cycle Gas Turbine                             |
| SCI    | Statement of Corporate Intent                        |
| SDE    | Sub Divisional Engineer                              |
| SE     | Superintending Engineer                              |
| SGV    | SyCip Gorres Velayo & Co,                            |
| SHR    | Sensible Heat Ratio                                  |
| SL     | Subordinated Ledger                                  |
| SL     | Transmission and Distribution System Loss            |
| SLDC   | State Load Dispatch Center                           |
| SOP    | Sale of Power  |
| SPP    | Small Power Producer                                 |
| SS     | Single-shaft   |
| ST     | Steam Turbine  |
| STG    | Steam Turbine Generator                              |
| SUS    | Stainless Used Steel                                 |
| SZPDC  | South Zone Power Distribution Company                |
| TBM    | Time Based Maintenance                               |
| TBM    | Tool Box Meeting                                     |
| TFD    | Time of Flight Diffraction                           |
| TGTDCL | Titas Gas Transmission and Distribution Company Ltd. |
| Tk     | Bangladesh Taka                                      |
| TL     | Transmission Line                                    |
| TMT    | Top Management Team                                  |
| TNA    | Training Needs Assessments                           |
| TOR    | Terms of Reference                                   |
| TQM    | Total Quality Management                             |
| UEEP   | Used Energy End Point                                |
| USD    | United States Dollar                                 |
| UT     | Ultrasonic Testing                                   |
| VAT    | Value Added Tax                                      |
| VC     | Variable Cost  |
| VCT    | Voltage Circuit Transformer                          |
| W/S    | Work Shop  |
| WACC   | Weighted Average of the Capital Cost                 |

|         |  |
|---------|--|
| WASP    | Wien Automatic System Planning Package                     |
| WB      | World Bank   |
| WBSEDCL | West Bengal State Electricity Distribution Company Limited |
| WPI     | Wholesale Price Index                                      |
| WTP     | Willingness to Pay   |
| WZPDCL  | West Zone Power Distribution Company Ltd.                  |
| XEN     | Executing Engineer   |

## UNITS

### Prefixes

|       |   |                    |
|-------|---|--------------------|
| $\mu$ | : | micro- = $10^{-6}$ |
| m     | : | milli- = $10^{-3}$ |
| c     | : | centi- = $10^{-2}$ |
| d     | : | deci- = $10^{-1}$  |
| da    | : | deca- = 10         |
| h     | : | hecto- = $10^2$    |
| k     | : | kilo- = $10^3$     |
| M     | : | mega- = $10^6$     |
| G     | : | giga- = $10^9$     |

### Units of Length

|    |   |            |
|----|---|------------|
| m  | : | meter      |
| mm | : | millimeter |
| cm | : | centimeter |
| km | : | kilometer  |
| in | : | inch       |
| ft | : | feet       |
| yd | : | yard       |

### Units of Area

|               |   |                    |
|---------------|---|--------------------|
| $\text{cm}^2$ | : | square centimeter  |
| $\text{m}^2$  | : | square meter       |
| $\text{km}^2$ | : | square kilometer   |
| $\text{ft}^2$ | : | square feet (foot) |
| $\text{yd}^2$ | : | square yard        |
| ha            | : | hectare            |

### Units of Volume

|              |   |             |
|--------------|---|-------------|
| $\text{m}^3$ | : | cubic meter |
| l            | : | liter       |
| kl           | : | kiloliter   |

### Units of Mass

|    |   |              |
|----|---|--------------|
| g  | : | gram         |
| kg | : | kilogram     |
| t  | : | ton (metric) |
| lb | : | pound        |

### Units of Density

|                        |   |                          |
|------------------------|---|--------------------------|
| $\text{kg}/\text{m}^3$ | : | kilogram per cubic meter |
| $\text{t}/\text{m}^3$  | : | ton per cubic meter      |

|                     |   |                                    |
|---------------------|---|------------------------------------|
| mg/m <sup>3</sup> N | : | milligram per normal cubic meter   |
| g/m <sup>3</sup> N  | : | gram per normal cubic meter        |
| ppm                 | : | parts per million                  |
| μg/scm              | : | microgram per standard cubic meter |

#### Units of Pressure

|                          |   |  |
|--------------------------|---|--|
| kg/cm <sup>2</sup>       | : | kilogram per square centimeter (gauge) |
| lb/in <sup>2</sup>       | : | pound per square inch                  |
| mmHg                     | : | millimeter of mercury                  |
| mmHg abs                 | : | millimeter of mercury absolute         |
| mAq                      | : | meter of aqueous                       |
| lb/in <sup>2</sup> , psi | : | pounds per square inches               |
| atm                      | : | atmosphere                             |
| Pa                       | : | Pascal                                 |
| bara                     | : | bar absolute                           |

#### Units of Energy

|      |   |                      |
|------|---|----------------------|
| kcal | : | kilocalorie          |
| Mcal | : | megacalorie          |
| MJ   | : | mega joule           |
| TJ   | : | tera joule           |
| kWh  | : | kilowatt-hour        |
| MWh  | : | megawatt-hour        |
| GWh  | : | gigawatt-hour        |
| Btu  | : | British thermal unit |

#### Units of Heating Value

|         |   |                                |
|---------|---|--------------------------------|
| kcal/kg | : | kilocalorie per kilogram       |
| kJ/kg   | : | kilojoule per kilogram         |
| Btu/lb  | : | British thermal unit per pound |

#### Units of Heat Flux

|                       |   |   |
|-----------------------|---|---|
| kcal/m <sup>2</sup> h | : | kilocalorie per square meter hour         |
| Btu/ft <sup>2</sup> H | : | British thermal unit per square feet hour |

#### Units of Temperature

|     |   |                              |
|-----|---|------------------------------|
| deg | : | degree                       |
| °   | : | degree                       |
| C   | : | Celsius or Centigrade        |
| °C  | : | degree Celsius or Centigrade |
| F   | : | Fahrenheit                   |
| °F  | : | degree Fahrenheit            |



### Units of Electricity

|      |   |                                     |
|------|---|-------------------------------------|
| W    | : | watt                                |
| kW   | : | kilowatt                            |
| A    | : | ampere                              |
| kA   | : | kiloampere                          |
| V    | : | volt                                |
| kV   | : | kilovolt                            |
| kVA  | : | kilovolt ampere                     |
| MVA  | : | megavolt ampere                     |
| Mvar | : | megavar (mega volt-ampere-reactive) |
| kHz  | : | kilohertz                           |

### Units of Time

|     |   |        |
|-----|---|--------|
| s   | : | second |
| min | : | minute |
| h   | : | hour   |
| d   | : | day    |
| y   | : | year   |

### Units of Flow Rate

|                     |   |  |
|---------------------|---|--|
| t/h                 | : | ton per hour                               |
| t/d                 | : | ton per day                                |
| t/y                 | : | ton per year                               |
| m <sup>3</sup> /s   | : | cubic meter per second                     |
| m <sup>3</sup> /min | : | cubic meter per minute                     |
| m <sup>3</sup> /h   | : | cubic meter per hour                       |
| m <sup>3</sup> /d   | : | cubic meter per day                        |
| lb/h                | : | pound per hour                             |
| m <sup>3</sup> N/s  | : | cubic meter per second at normal condition |
| m <sup>3</sup> N/h  | : | cubic meter per hour at normal condition   |

### Units of Conductivity

|       |   |                             |
|-------|---|-----------------------------|
| μS/cm | : | microSiemens per centimeter |
|-------|---|-----------------------------|

### Units of Sound Power Level

|    |   |           |
|----|---|-----------|
| dB | : | deci-bell |
|----|---|-----------|

### Units of Currency

|      |   |                |
|------|---|----------------|
| Sum  | : | Uzbekistan Sum |
| US\$ | : | US Dollar      |
| ¥    | : | Japanese Yen   |

**Exchange Rate : US\$ 1 = 68 taka**

## LIST OF TABLES

| No.   | Title of Tables   |
|---|---|
| <b>Part I Feasibility of Bheramara Combined Cycle Power Station Construction Plan</b> |   |
| Table I-1-3-1   | Formation of the Team   |
| Table I-2-1-1   | Comparison of Socio-Economic Indicators among South Asian Countries                                       |
| Table I-2-2-1   | Administrative Units, Population and Households (2001 Census)   |
| Table I-2-2-2   | Status of Jobs (%)  |
| Table I-2-3-1   | Macro Economic Indicators   |
| Table I-2-3-2   | Remittances from Oversea Workers  |
| Table I-2-3-3   | Outline of Budget for 2009  |
| Table I-2-4-1   | Composition of GDP at Market Price  |
| Table I-2-4-2   | Exports of Sectors  |
| Table I-2-5-1   | Household Income and Expenditure Survey   |
| Table I-2-6-1   | Inflation   |
| Table I-3-1-1   | Power Generating Facilities using Fuel  |
| Table I-3-1-2   | Power Generating Facilities using a Generation Method   |
| Table I-3-1-3   | Generated Power (GWH)   |
| Table I-3-1-4   | Maximum Power Demand  |
| Table I-3-1-5   | Generated Power by Fuel   |
| Table I-3-1-6   | List of Power-Generating Facilities   |
| Table I-3-1-7   | Facility Capacities, Available Power, Demand Estimates, and Scheduled Outages                             |
| Table I-3-3-1   | Financial statements of BPDB since 2000 till 2006   |
| Table I-3-4-1   | Electricity Tariff  |
| Table I-3-4-2   | Electricity Tariff of IPPs  |
| Table I-4-1-1   | Comparison of Power Demand Forecast   |
| Table I-4-2-1   | Annual power consumption per household in Bangladesh  |
| Table I-4-2-2   | Annual power consumption by households from the Bheramara CCPP in the western zone of Bangladesh          |
| Table I-4-2-3   | Estimated number of electrified households and the electrification rate in the western zone of Bangladesh |
| Table I-4-2-4   | Electricity Generated and Load Shedding   |
| Table I-4-3-1   | List of existing power generation facilities (as of July 2008)  |

|                |   |
|----------------|---|
| Table I-4-3-2  | Load shedding as of July 26, 2008   |
| Table I-4-3-3  | List of power generation development projects (as of August 2008)               |
| Table I-4-3-4  | List of the retirement plan for the existing thermal power plant                |
| Table I-4-3-5  | Balance of power demand and supply  |
| Table I-4-4-1  | Transmission facilities owned by PGCB   |
| Table I-4-4-2  | Substation facilities owned by PGCB   |
| Table I-4-4-3  | Investment plan of PGCB   |
| Table I-4-5-1  | Gas production volume and forecast of gas reserve (unit: Bcf)                   |
| Table I-4-5-2  | Forecast of gas supply volume (Daily maximum supply volume, unit: mmcfd)        |
| Table I-4-5-3  | Forecast of gas demand volume (Daily maximum demand volume, unit: mmcfd)        |
| Table I-4-5-4  | Period of gas supply for new gas thermal power Plant                            |
| Table I-4-6-1  | Comparison of 2 sites   |
| Table I-4-6-2  | Information of hydrostratigraphic units   |
| Table I-4-6-3  | Aquifer properties (Theis method)   |
| Table I-4-6-4  | Aquifer properties (Neumann method)   |
| Table I-4-6-5  | Result of existing tubewell survey  |
| Table I-4-7-1  | Unit price of fuel as of Summer 2007  |
| Table I-4-7-2  | Typical contract record of a heavy oil-fired gas turbine                        |
| Table I-4-7-3  | Plant performance of heavy oil-fired CCPP                                       |
| Table I-4-7-4  | Basic conditions for fuel cost evaluation                                       |
| Table I-4-7-5  | Result of tentative calculation of the fuel cost in power generation facilities |
| Table I-4-7-6  | Performance of Diesel oil-fired CCPP (F class)                                  |
| Table I-4-7-7  | Estimated investment cost related to diesel oil firing system                   |
| Table I-4-7-8  | ISO Performance of the assumed E-class CCPP                                     |
| Table I-4-7-9  | ISO Performance of the assumed F-class CCPP                                     |
| Table I-4-7-10 | Assumed price of E-class CCPP (as of June 2008)                                 |
| Table I-4-7-11 | Assumed price of F-class CCPP (as of June 2008)                                 |
| Table I-4-7-12 | Technical assumption for economic comparison between E class and F class CCPP   |
| Table I-4-7-13 | Economical comparison between E- and F-class CCPP                               |
| Table I-4-7-14 | Technical assumptions for estimation of carbon dioxide emissions                |
| Table I-4-7-15 | List of IPCC coefficients   |
| Table I-4-7-16 | Effects of reducing greenhouse gas emissions                                    |
| Table I-4-7-17 | Summary of comparison of E class CCPP and F class CCPP                          |
| Table I-4-7-18 | Single-shaft Combined Cycle Power Plant (above 100 MW)                          |

|                |   |
|----------------|---|
|                | Experience  |
| Table I-4-7-19 | 3,000 rpm Multi-shaft Combined Cycle Power Experience                                       |
| Table I-4-7-20 | Application Experience with SSS Clutch over 100 MW for CCPPs                                |
| Table I-4-7-21 | Computer Estimated Construction Costs for Multi-shaft CCPP                                  |
| Table I-4-7-22 | Computer Estimated Construction Costs for Single-shaft CCPPs                                |
| Table I-4-7-23 | Sample of Application Experiences with Air Cooled Condenser for Steam Turbines above 150 MW |
| Table I-4-7-24 | Hydrogeological parameter settings for the model  |
| Table I-4-7-25 | Projected abstraction of groundwater for irrigation, domestic and municipal purposes        |
| Table I-4-7-26 | Impact on the existing tubewells  |
| Table I-4-8-1  | Packing list (gas turbine)  |
| Table I-4-8-2  | Packing list (steam turbine)  |
| Table I-4-8-3  | Packing list (HRSG)   |
| Table I-4-8-4  | Packing list (generator)  |
| Table I-4-8-5  | Port facilities in Mongla port  |
| Table I-4-8-6  | Summary of channel width and depth from Mongla to Bheramara                                 |
| Table I-4-8-7  | Channel transportation by barges and tugboats from Mongla port to Bheramara site            |
| Table I-4-8-8  | Data of channel width and depth from Daulatdia to Sirajganj                                 |
| Table I-4-8-9  | Comparison of Transportation Cost   |
| Table I-4-9-1  | Required Months from Selection of Consultant to the Completion of CCPP                      |
| Table I-4-10-1 | An Example of Inspection Interval   |
| Table I-4-10-2 | Characteristic of LTSA  |
| Table I-5-3-1  | Comparison of Computer Estimated Construction Cost  |
| Table I-5-5-1  | Design Conditions   |
| Table I-5-5-2  | Calculation result for Diesel Oil Tank  |
| Table I-5-5-3  | Emission Limit of Pollutant   |
| Table I-5-5-4  | Noise Standards   |
| Table I-5-5-5  | Effluent Standards  |
| Table I-5-5-6  | HRSG Circulation Comparison   |
| Table I-5-5-7  | Gas Flow Orientation Comparisons  |
| Table I-5-5-8  | Specifications of Gas   |
| Table I-5-5-9  | Specifications of HSD   |
| Table I-5-5-10 | List of protected areas and fire fighting and detection systems types                       |
| Table I-5-5-11 | Overview Specifications of the Generators   |

|                   |  |
|-------------------|--|
| Table I-5-5-12    | Comparison of cooling system   |
| Table I-5-5-13    | Overview Specifications of the Transformers  |
| Table I-5-5-14    | Three Phase Transformer and Single Phase Transformer                               |
| Table I-5-5-15    | Generator Main Circuit Protection  |
| Table I-5-5-16    | Overview Specifications of the 230kV Substation                                    |
| Table I-5-5-17    | Overview Specifications of the 132kV Substation                                    |
| Table I-5-5-18    | Overview specifications of the 230/132kV Bus-tie Transformers                      |
| Table I-5-5-19    | In Feed Capacity of feeders at 230kV substation                                    |
| Table I-5-5-20    | Load Capacity of feeders at 230kV substation                                       |
| Table I-5-5-21    | In Feed Capacity of feeders at 132kV substation                                    |
| Table I-5-5-22    | Load Capacity of feeders at 132kV substation                                       |
| Table I-5-5-23    | Technical characteristics of conductor, ground wire and OPGW                       |
| Table I-5-5-24    | Load condition on conductor and ground wire  |
| Table I-5-5-25    | Characteristics of insulator   |
| Table I-5-5-26    | Designation and use of towers  |
| Table I-5-5-27    | Leg extensions   |
| Table I-5-5-28    | Span length for tower design at intact conditions                                  |
| Table I-5-5-29    | Span length for tower design at broken wire conditions                             |
| Table I-5-5-30    | Minimum clearance  |
| Table I-5-5-31    | Minimum clearance at crossing point  |
| Table I-5-5-32    | Coordinate data  |
| Table I-5-5-33    | Construction cost for transmission facilities (Case 1)                             |
| Table I-5-5-34    | Construction cost for transmission facilities (Case 2)                             |
|                   |  |
| Table I-7-1-1     | Monthly average precipitation  |
| Table I-7-1-2     | Monthly average wind velocity and prevailing wind direction                        |
| Table I-7-1-3     | Present condition of the air quality (dry season: 2008 June 8-11 )                 |
| Table I-7-1-4     | Present condition of the air quality (rainy season: 2008 Sep.3-6)                  |
| Table I-7-1-5     | Present condition of the noise levels  |
| Table I-7-1-6 (1) | Present situation of the water quality (dry season: 2008, June 8th)                |
| Table I-7-1-6 (2) | Present situation of the water quality (rainy season: 2008, Sep. 8th)              |
| Table I-7-1-7     | List of plants confirmed in the site   |
| Table I-7-1-8     | List of animals found 1 km around the site   |
| Table I-7-1-9     | List of fish inhabiting the Padma River  |
| Table I-7-1-10    | Overview of the socio-economic environment of Bheramara                            |
| Table I-7-1-11    | Population of each village of Bahirhar Union                                       |
| Table I-7-1-12    | Workforce in each age category in Bheramara Union                                  |
| Table I-7-1-13    | Cultivation and crop production for main agricultural products in Kushtia District |

|                   |  |
|-------------------|--|
| Table I-7-1-14    | Conditions of arsenic contamination of tube wells in Bheramara Upazila   |
| Table I-7-1-15    | Underground water Test Reports for areas around Power Station  |
| Table I-7-1-16    | Users of electricity in Bheramara Upazila  |
| Table I-7-1-17    | Rate of school attendance in Bheramara area  |
| Table I-7-1-18    | Result of existing tube well survey  |
| Table I-7-1-19    | Households interviewed in the survey, according to age bracket   |
| Table I-7-1-20    | Education background of the heads of households  |
| Table I-7-1-21    | Employment of the heads of households  |
| Table I-7-1-22    | Monthly income and expenses of each household  |
| Table I-7-1-23    | Main Furniture and durable owned by the households   |
| Table I-7-1-24    | Type of toilet facilities used in each household   |
| Table I-7-1-25    | Medical institutions to be used  |
| Table I-7-1-26    | Electrification rate of the households   |
| Table I-7-1-27    | House building materials for each households   |
| Table I-7-1-28    | Fuel used for cooking  |
| Table I-7-2-1     | Numbers of affected households and Acquired area   |
| Table I-7-3-1 (1) | Overview of the selected assessment items (Construction period)  |
| Table I-7-3-1 (2) | Overview of the selected assessment items (Operation period)   |
| Table I-7-3-2     | Noise level of major construction machinery  |
| Table I-7-3-3     | Result of simulating the diffusion of noise produced from the machines used in construction work                       |
| Table I-7-3-4     | NOx emission concentration   |
| Table I-7-3-5     | Emission specifications  |
| Table I-7-3-6     | Setting conditions for stability and wind speed  |
| Table I-7-3-7     | Setting conditions for stability and wind speed  |
| Table I-7-3-8     | Estimation result of the maximum future concentration under normal conditions using a new facility (24-hour value)     |
| Table I-7-3-9     | Estimation result of the maximum future concentration by new installation under special conditions                     |
| Table I-7-3-10    | Estimation result of the maximum future concentration under normal conditions including new facilities (24-hour value) |
| Table I-7-3-11    | The predicted blow wastewater quality  |
| Table I-7-3-12    | Noise level of power generation facility   |
| Table I-7-3-13    | Result of diffusion simulation of the noise generated from the power generation facility                               |
| Table I-7-4-1     | Ambient Air quality standard   |
| Table I-7-4-2     | Gas emission standard for industrial facilities  |
| Table I-7-4-3     | Ambient water quality standard (inland surface water)  |
| Table I-7-4-4     | Environmental water quality standard (drinking water)  |

|                |  |
|----------------|--|
| Table I-7-4-5  | Waste water discharge standards  |
| Table I-7-4-6  | Noise standard   |
| Table I-7-4-7  | Major environmental impacts and mitigation measures using the construction phase |
| Table I-7-4-8  | Major environmental impacts and mitigation measures during the operation phase   |
| Table I-7-4-9  | Monitoring schedule during the construction phase                                |
| Table I-7-4-10 | Monitoring schedule during the operation phase                                   |
| Table I-7-5-1  | Contents of the stakeholder consultations  |
| Table I-7-5-2  | Contents of the Focus Group Discussions  |
| Table I-7-5-3  | Opinions from local residents at the social environmental survey                 |
|                |  |
| Table I-8-1-1  | Technical Assumption of Bheramara CCPP   |
| Table I-8-2-1  | Contract records of F-class CCPP for 2007-2008                                   |
| Table I-8-2-2  | Estimated Project Cost for Bheramara CCPP (as of June 2008)                      |
| Table I-8-2-3  | Comparison with other project cost   |
| Table I-8-3-1  | Inflation Rates  |
| Table I-8-3-2  | Foreign Exchange Rates   |
| Table I-8-3-3  | Terms and Conditions of Loans  |
| Table I-8-4-1  | Project Cost for Economic and Financial Analyses (2014 constant price)           |
| Table I-8-4-2  | Domestic Gas Price   |
| Table I-8-4-3  | Maintenance Cost (2014 constant price)   |
| Table I-8-4-4  | Fiscal Levies  |
| Table I-8-4-5  | Yields of the Treasury Bills in 2008   |
| Table I-8-4-6  | Electricity Selling Price and Supply Cost  |
| Table I-8-4-7  | Financial Internal Rate of Return (FIRR)   |
| Table I-8-4-8  | Sensitivity Test of FIRR   |
| Table I-8-5-1  | Estimate of International Gas Price  |
| Table I-8-5-2  | Comparison of the Methodologies for Economic Analysis                            |
| Table I-8-5-3  | Calculation of WTP Minimum   |
| Table I-8-5-4  | The Highest Tariff for Category of Consumers                                     |
| Table I-8-5-5  | Diesel Generation Cost at Bhola Power Station of BPDB                            |
| Table I-8-5-6  | Calculation of WTP Maximum   |
| Table I-8-5-7  | Economic Internal Rate of Return EIRR) < Base Case >                             |
| Table I-8-5-8  | Sensitivity Test of EIRR   |
| Table I-8-6-1  | Operational and Effect Indicators  |

## **Part II Proposal for Corporation Plan and Organization of NWPGL and Bheramara Combined Cycle Power Station**

|               |   |
|---------------|---|
| Table II-2-1  | Time Schedule for Corporatization of NWPGL                                  |
| Table II-2-2  | Case of power sector corporatization in Bangladesh until now                |
| Table II-3-1  | Bangladesh Corporate Governance Code 2004 Key Highlights                    |
| Table II-3-2  | Comparative Chart on Bangladesh Utilities Corporate Governance Practices    |
| Table II-3-3  | Comparisons of board composition at company in Bangladesh                   |
| Table II-4-1  | Concept of human management (stage-wise)                                    |
| Table II-4-2  | Transition of relationship between human resource and company               |
| Table II-4-3  | Comparative Matrix of Corporate Organization Structure                      |
| Table II-4-4  | Workforce for NWPGL HQ  |
| Table II-4-5  | Segregation of duties for NWPGL Headquarters                                |
| Table II-4-6  | Comparative Matrix of Plant Organization Structure of Bangladesh Utilities  |
| Table II-4-7  | Comparison of P/S personnel   |
| Table II-4-8  | Segregation of duties at power station                                      |
| Table II-4-9  | EGCB Written Test Format  |
| Table II-4-10 | Selection Interview Aspects   |
| Table II-4-11 | Composition of Selection Committee in some Bangladesh Power Sector entities |
| Table II-4-12 | Comparison of Recruitment Process of Bangladesh Utilities                   |
| Table II-4-13 | Recruitment examination (EGCB case)   |
| Table II-4-14 | Career path conference  |
| Table II-4-15 | Career path planning report   |
| Table II-4-16 | Key Elements of Performance Evaluation Systems                              |
| Table II-4-17 | Skill Set Evaluation Table  |
| Table II-4-18 | Written Test Evaluation Basis EGCB  |
| Table II-4-19 | Promotion Interview Assessment Basis  |
| Table II-4-20 | Performance evaluation Comparative Matrix for Bangladesh Utilities          |
| Table II-4-21 | Basic Pay Structure of APSC   |
| Table II-4-22 | BPDB Pay Scales   |
| Table II-4-23 | EGCB Basic Pay Scales   |
| Table II-4-24 | Comparison Matrix of Basic Pay of Bangladesh Utilities                      |
| Table II-4-25 | HRA Comparative Matrix for Bangladesh Utilities                             |
| Table II-4-26 | Medical Allowance Comparative Matrix  |



|               |  |
|---------------|--|
| Table II-4-27 | Training Comparative Matrix for Bangladesh Utilities   |
| Table II-4-28 | Current number of personnel working at each power station and future target                    |
| Table II-4-29 | Transfer period of existing power stations and running-in period of newly-built power stations |
| Table II-4-30 | Proposed personnel transfer process at existing power stations                                 |
| Table II-5-1  | Chart of Accounts of BPDB  |
| Table II-5-2  | Project Payment Mechanism (a sample case from India)   |
| Table II-5-3  | Comparison of Budget and Actual  |
| Table II-5-4  | Budget Time Table  |
| Table II-5-5  | Assumptions for Financial Simulation   |
| Table II-5-6  | Ratio Analysis   |
| Table II-5-7  | Sensitivity Tests (Average during 2011-26)   |
| Table II-5-8  | Assumptions  |
| Table II-5-9  | Capital Cost   |
| Table II-5-10 | Profit & Loss Statement of Bheramara Power Station (360MW)                                     |
| Table II-5-11 | Profit & Loss Statement of NWPGL (660MW)   |
| Table II-5-12 | Balance Sheet of NWPGL (3 Plants: 660MW)   |
| Table II-6-1  | Functions between HQ and P/S   |
| Table II-6-2  | Datasheet for analyzing unscheduled outages  |
| Table II-6-3  | Analysis sheet of unplanned stop trouble: Preventive measure of reoccurrence                   |
| Table II-6-4  | Specific Environmental Preservation Measures   |
| Table II-7-1  | Gap Analysis   |
| Table II-7-2  | TBM-KY Board   |
| Table II-7-3  | How to implement KY4 rand method   |
| Table II-7-4  | Touch and Call   |
| Table II-7-5  | Safety equipment   |
| Table II-8-1  | Sample of reporting items  |
| Table II-8-2  | Function of operation data processing computer   |
| Table II-8-3  | Maintenance planning & Management system   |
| Table II-8-4  | Hardware lists   |
| Table II-8-5  | software list  |
| Table II-9-1  | Characteristics of LTSA  |
| Table II-9-2  | Total Power Supply Scenario for All Sectors  |

|               |  |
|---------------|--|
| Table II-9-3  | Supply Scenario for Power Sector   |
| Table II-9-4  | Category wise Gas Demand and Supply Scenario (2008)                        |
| Table II-9-5  | Revised power development plan (October 2008)                              |
| Table II-9-6  | Estimated gas consumption (FY2006-2007)                                    |
| Table II-9-7  | Simulation of gas shortage   |
| Table II-9-8  | kWh Balance Comparison   |
| Table II-9-9  | Comparison of fuel consumption/thermal efficiency                          |
| Table II-9-10 | Comparison of economic efficiency  |
| Table II-9-11 | Operation results and Retirement plan of the existing power stations       |
|               |  |
| Table II-10-1 | Activity schedule of target management                                     |
| Table II-10-2 | The performance evaluation system at the Baghabari power station           |
| Table II-10-3 | The bonus rank by comprehensive score                                      |
| Table II-10-4 | Score calculation based on performance data 2003-2004 at the Baghabari P/S |
| Table II-10-5 | The performance evaluation method of each plant in NWPGL (proposal)        |
| Table II-10-6 | Roles and Members of TQM Steering Committee                                |
| Table II-10-7 | Roles and Members of TQM Promotion Office                                  |
|               |  |
| Table II-11-1 | Short-term Roadmap   |
| Table II-11-2 | Mid-term Roadmap (first half)  |
| Table II-11-3 | Mid-term Roadmap (latter half)   |

## LIST OF FIGURES

| No.   | Title of Figures  |
|---|---|
| <b>Part I Feasibility of Bheramara Combined Cycle Power Station Construction Plan</b> |   |
| Figure I-2-3-1  | Trade Deficit and Overseas Remittances  |
| Figure I-2-3-2  | Trend of Foreign Exchange Rate  |
| Figure I-3-1-1  | Generated Power of BPDB   |
| Figure I-3-1-2  | Generated Power of BPDB and IPP   |
| Figure I-3-1-3  | Maximum Power Demand  |
| Figure I-3-1-4  | Generated Power by Fuel   |
| Figure I-3-1-5  | Facility Capacities, Available Power, Demand Estimates, and Scheduled Outages |
| Figure I-3-1-6  | Daily Power Consumption Patterns  |
| Figure I-3-1-7  | Locations of Existing Power Stations  |
| Figure I-3-2-1  | Electrical Power Sector in Bangladesh   |
| Figure I-3-3-1  | Business Performance of BPDB  |
| Figure I-3-3-2  | Average Supply Cost and Average Billing Rate                                  |
| Figure I-3-3-3  | Power Generated at BPDB and Volume Purchased from IPP                         |
| Figure I-3-3-4  | System Loss of Electricity  |
| Figure I-3-3-5  | Balances of Accounts Receivable   |
| Figure I-3-3-6  | Trends of the Fixed Assets and Capital Work in Progress                       |
| Figure I-3-4-1  | Average Power Tariff in Asian Countries                                       |
| Figure I-4-1-1  | Comparison of Power Demand Forecast   |
| Figure I-4-3-1  | Percentage of the amount of power generation by energy type for FY2006        |
| Figure I-4-3-2  | Load curve as of July 26, 2008  |
| Figure I-4-4-1  | Grid map  |
| Figure I-4-4-2  | Example of power flow analysis  |
| Figure I-4-4-3  | Overview of transmission system around Bheramara substation                   |
| Figure I-4-4-4  | Situation around Bheramara substation   |
| Figure I-4-5-1  | Forecast of gas demand and supply   |
| Figure I-4-5-2  | Gas Transmission Network in Bangladesh  |
| Figure I-4-6-1  | Project Site Location   |
| Figure I-4-6-2  | Site Boundary   |
| Figure I-4-6-3  | Borehole location map   |
| Figure I-4-6-4  | Bheramara site and Padma River  |

|                 |   |
|-----------------|---|
| Figure I-4-6-5  | Water level at Hardinge Bridge  |
| Figure I-4-6-6  | Monthly variation of minimum discharge at Hardinge Bridge               |
| Figure I-4-6-7  | Monthly variation of minimum discharge at Hardinge Bridge in dry season |
| Figure I-4-6-8  | Velocity at Hardinge Bridge   |
| Figure I-4-6-9  | Bed elevation of Padma River at cross section RMG-13                    |
| Figure I-4-6-10 | Pump/Observation wells layout   |
| Figure I-4-6-11 | Longitudinal cross section (S-N)  |
| Figure I-4-6-12 | Longitudinal cross section (W-E)  |
| Figure I-4-6-13 | Pump well design  |
| Figure I-4-6-14 | Pumping test result   |
| Figure I-4-6-15 | Confined aquifer  |
| Figure I-4-6-16 | Unconfined aquifer  |
| Figure I-4-6-17 | Groundwater table of Well No. KTA-7 and Padma River water level         |
| Figure I-4-6-18 | Groundwater table contour map of minimum elevation (dry season)         |
| Figure I-4-6-19 | Groundwater table contour map of maximum elevation (wet season)         |
| Figure I-4-6-20 | Tubewell survey map   |
| Figure I-4-6-21 | Modeled dry season (May) water table contour map                        |
| Figure I-4-6-22 | Modeled wet season (September) water table contour map                  |
| Figure I-4-7-1  | An example of ash deposited on the 1st stage nozzle of a turbine        |
| Figure I-4-7-2  | Marginal fuel oil usage in CCPP   |
| Figure I-4-7-3  | Typical Layout of Single-shaft Arrangement Combined Cycle Power Plant   |
| Figure I-4-7-4  | Typical Layout of Multi-shaft Combined Cycle Power Plant                |
| Figure I-4-7-5  | Open Cut  |
| Figure I-4-7-6  | Intake Tower  |
| Figure I-4-7-7  | Floating Pump   |
| Figure I-4-7-8  | Deep Well   |
| Figure I-4-7-9  | Deep well layout  |
| Figure I-4-7-10 | Model grid  |
| Figure I-4-7-11 | 3D view of the study area   |
| Figure I-4-7-12 | Matching of observed and calculated hydrographs of KTA-7                |
| Figure I-4-7-13 | Modeled dry season (May) water table contour map                        |
| Figure I-4-7-14 | Modeled wet season (September) water table contour map                  |
| Figure I-4-7-15 | Zoomed in modeled dry season (May) water table contour map              |
| Figure I-4-7-16 | Tubewells survey map with impacted area in dry season                   |
| Figure I-4-8-1  | Candidate transportation routes   |

|                 |   |
|-----------------|---|
| Figure I-4-8-2  | The River water level data for past 30 years at 1 km down river of Harding bridge         |
| Figure I-4-8-3  | Candidate jetty positions in Sirajganj site   |
| Figure I-4-9-1  | Project Schedule  |
| Figure I-5-5-1  | General Arrangement of Main Equipments  |
| Figure I-5-5-2  | Water Mass Balance Diagram  |
| Figure I-5-5-3  | The scheme of power station and 230 / 132kV substation                                    |
| Figure I-5-5-4  | VCT and LA of 132kV substation after replacement  |
| Figure I-5-5-5  | 132kV substation GCB (1979)   |
| Figure I-5-5-6  | 132kV substation OCB (1982)   |
| Figure I-5-5-7  | The scheme of 230kV substation  |
| Figure I-5-5-8  | The scheme of existing power station 132kV substation                                     |
| Figure I-5-5-9  | The Scheme of Replaced 132kV Substation   |
| Figure I-5-5-10 | Power Flow at 230kV Substation (Normal)   |
| Figure I-5-5-11 | Power Flow at 230kV Substation (Tripping at 230kV Bheramara-Jhenaidah One circuit)        |
| Figure I-5-5-12 | Power Flow at Existing 132kV Substation (Max Demand 4,130MW on 17 <sup>th</sup> Sep 2007) |
| Figure I-5-5-13 | Power Flow at 132kV Substation (Normal)   |
| Figure I-5-5-14 | Power Flow at 132kV Substation (Tripping at 230kV Bheramara-Jhenaidah One Circuit)        |
| Figure I-5-5-15 | Transmission system around Bheramara power station  |
| Figure I-5-5-16 | Overview using special gantry   |
| Figure I-5-5-17 | Profile of existing 132kV line  |
| Figure I-5-5-18 | Profile of 230kV line at crossing point of existing 132kV line                            |
| Figure I-5-5-19 | Overview by reduction of conductor height of existing 132kV line                          |
| Figure I-5-5-20 | Profile of 132kV line after the adoption of height reduction                              |
| Figure I-5-5-21 | Profile of 230kV line at the crossing point of 132kV line                                 |
| Figure I-6-1-1  | Gas pipeline from CGS to Bheramara CCPP   |
| Figure I-6-2-1  | Configuration of tower  |
| Figure I-6-3-1  | Layout plan of jetty, storage yard and access road  |
| Figure I-7-1-1  | Monthly average temperature   |
| Figure I-7-1-2  | Monthly average humidity  |
| Figure I-7-1-3  | Monthly average sunshine hours  |
| Figure I-7-1-4  | Topographical features of Bangladesh  |
| Figure I-7-1-5  | Area affected from massive flood damage in 1998   |

|                    |  |
|--------------------|--|
| Figure I-7-1-6     | Location points of measuring air quality   |
| Figure I-7-1-7     | Location points of measuring Noise level   |
| Figure I-7-1-8     | Location points of measuring Water quality in river  |
| Figure I-7-1-9     | Location of interview survey   |
| Figure I-7-1-10    | Land utilization around the project site   |
| Figure I-7-1-11    | Tube well survey map   |
| Figure I-7-2-1     | Flow chart for EIA implementation process  |
| Figure I-7-2-2     | Flow chart for procedures on each category   |
| Figure I-7-2-3     | Flow chart approved by EIA on the project  |
| Figure I-7-3-1     | Construction machinery noise level   |
| Figure I-7-3-2     | Result of simulating the diffusion of noise produced from the machines used in construction work   |
| Figure I-7-3-3     | Estimation result of the maximum ground-level concentration of NO <sub>x</sub> under normal conditions, using a new facility (24-hour value)             |
| Figure I-7-3-4     | Estimation result of the maximum future ground-level concentration of NO <sub>x</sub> under special conditions using a new facility (24-hour value)      |
| Figure I-7-3-5 (1) | Estimation result of the maximum future ground-level concentration of NO <sub>x</sub> including existing facilities (24-hour value with stability B)     |
| Figure I-7-3-5 (2) | Estimation result of the maximum concentration of NO <sub>x</sub> for future including existing facilities (24-hour value with stability B)              |
| Figure I-7-3-5 (3) | Estimation result of the maximum ground-level concentration of NO <sub>x</sub> for future including existing facilities (24-hour value with stability D) |
| Figure I-7-3-6     | Result of diffusion simulation of the noise generated from the power generation facility   |
| Figure I-8-2-1     | Trend of FOB price of the F class 1 on 1 CCPP  |
| Figure I-8-3-1     | Exchange Rates and Trend Lines   |
| Figure I-8-4-1     | Historical Trend of Gas Prices   |
| Figure I-8-4-2     | Domestic and International Prices of Diesel Oil  |
| Figure I-8-4-3     | Sensitivity Test of FIRR   |
| Figure I-8-5-1     | Willingness to Pay   |
| Figure I-8-5-2     | Sensitivity Test of EIRR   |

## **Part II Proposal for Corporation Plan and Organization of NWPGL and Bheramara Combined Cycle Power Station**

|                |  |
|----------------|--|
| Figure II-2-1  | Directivity of NWPGL   |
| Figure II-2-2  | Frequency distribution of days when load shedding was conducted in 2007  |
| Figure II-2-3  | Factor analysis of power crisis  |
| Figure II-2-4  | Three pillars of corporate vision  |
| Figure II-3-1  | Fundamental structure of corporate governance system   |
| Figure II-3-2  | Recommendation of corporate governance system based on the Principle of Separating the Execution and Supervisory Functions of Management |
| Figure II-3-3  | Management Resources   |
| Figure II-4-1  | Functions between HQ and P/S for HCM   |
| Figure II-4-2  | Organogram for NWPGL Headquarters  |
| Figure II-4-3  | Organogram for Bheramara Power Station   |
| Figure II-4-4  | Performance Evaluation Systems   |
| Figure II-4-5  | Performance Evaluation based on the PDCA Cycle   |
| Figure II-4-6  | Performance Evaluation System  |
| Figure II-4-7  | Other components of the pay structure of APSC  |
| Figure II-4-8  | Other components of the pay structure of BPDB  |
| Figure II-4-9  | Other components of the pay structure of PGCB  |
| Figure II-4-10 | Compensation system linked to personal performance   |
| Figure II-4-11 | Component of Total Compensation  |
| Figure II-4-12 | Human Capital Portfolio  |
| Figure II-4-13 | Number of workers at the existing Bheramara power station due to retire by year  |
| Figure II-4-14 | Result of simulation of manpower forecast (base case)  |
| Figure II-4-15 | Case in which the existing Khulna power station is also transferred to NWPGL   |
| Figure II-4-16 | Proposed personnel transfer process at existing power stations   |
| Figure II-5-1  | Organizational Structure of Finance and Accounts at BPDB   |
| Figure II-5-2  | Organizational Structure of Finance and Accounting Division of EGCB  |
| Figure II-5-3  | Framework of Internal Control System   |
| Figure II-5-4  | Project Payment Mechanism  |
| Figure II-5-5  | Approach for IT implementation   |

|                |   |
|----------------|---|
| Figure II-5-6  | Integrated Accounting Package                                     |
| Figure II-5-7  | Cash & Bank Account Control Module                                |
| Figure II-5-8  | Bank Account Reconciliation Module                                |
| Figure II-5-9  | Stores Accounting Module  |
| Figure II-5-10 | Fixed Assets Control Module                                       |
| Figure II-5-11 | Account Payable Control Module                                    |
| Figure II-5-12 | Steps for Developing the Integrated Accounting Package            |
| Figure II-5-13 | External Advisory Institutions                                    |
| Figure II-5-14 | Steps for Preparation of Capital Budget                           |
| Figure II-5-15 | Flow of Preparation of Recurrent Budget                           |
| Figure II-5-16 | Role of Management Accounting                                     |
| Figure II-5-17 | Figure II-5-17 Impact of the Accumulation of Account Receivable   |
|                |   |
| Figure II-6-1  | Organizational-wise O&M management flow                           |
| Figure II-6-2  | Conceptual figure of maintenance management (level-wise)          |
| Figure II-6-3  | Necessity of Trend analysis                                       |
| Figure II-6-4  | Negative spiral of shortage of supply capability                  |
| Figure II-6-5  | Standard management flow based on PDCA                            |
| Figure II-6-6  | Hein Richs Principle Disaster Occurrence Pyramid                  |
| Figure II-6-7  | Environmental Management System (Corporate Level)                 |
| Figure II-6-8  | Environmental Management System (Management Level)                |
| Figure II-6-9  | Environmental Management Systems (Plant Level)                    |
| Figure II-6-10 | Environmental Management System (Public Level)                    |
|                |   |
| Figure II-7-1  | General industrial case (or IPP)                                  |
| Figure II-7-2  | Power sector case (BPDB)  |
| Figure II-7-3  | Human Machine System (HMS) and Disaster Occurring Mechanism       |
| Figure II-7-4  | Concept of Reducing the Number of Disasters                       |
| Figure II-7-5  | Safety and Health Management Structure                            |
| Figure II-7-6  | Safety Management Manual System                                   |
| Figure II-7-7  | Management Flow Based on PDCA Cycle                               |
|                |   |
| Figure II-8-1  | Process data acquisition and distribution for the decision making |
| Figure II-8-2  | The framework of plant information management strategy            |
| Figure II-8-3  | Information integration in power plants                           |
| Figure II-8-4  | System hierarchy for manufacturing industry                       |
| Figure II-8-5  | PI system configurations  |
| Figure II-8-6  | PI Process Flow diagram in Process Book                           |



|                |   |
|----------------|---|
| Figure II-8-7  | Report with PI Data Link  |
| Figure II-8-8  | Data analyzing with PI Data Link/Excel  |
| Figure II-8-9  | Applications of PI system   |
| Figure II-9-1  | Simulation of balance between demand for and supply of gas  |
| Figure II-9-2  | Estimated daily load curve at maximum power generation (2015)<br>[Case 0 Rate of gas supply development 80%, Bheramara power station operated by gas] |
| Figure II-9-3  | Daily load curve at maximum power generation (2015)   |
| Figure II-9-4  | Estimated monthly maximum power demand in 2007  |
| Figure II-10-1 | Flow of Policy Management Activity  |
| Figure II-10-2 | Target Management Items   |
| Figure II-10-3 | Relation between Top management and General employee  |
| Figure II-10-4 | Relation between management plan and other plans  |
| Figure II-11-1 | Introduction of simulator at P/S (Yokogawa Electric Corporation, Eraring 660MW, Australia)  |

## **Overall Evaluation and Recommendation**

### **Introduction**

Consultants have taken 6 months in surveying and studying the feasibility on the construction of the Bheramara Combined Cycle Power Plant (hereinafter referred to as "Bheramara CCPP"). This report is to describe the results of survey and study on the "Bheramara Combined Cycle Power Station in Bangladesh" under a commission from the Japan International Cooperation Agency (hereinafter referred to as "JICA"), an independent administrative agency of Japan. The objective of the Study is to evaluate the technical feasibility, environmental and social considerations, and economic feasibility of the construction program and to propose a corporate plan on the autonomous and efficient management of the North-West Power Generation Company (NWPGL) and Bheramara CCPP, based on the trend of the BPDB spin-off program and the preceding cases of other companies. The following describes the overall evaluation on the aforementioned survey work.

### **I. Overall Evaluation**

As a result of evaluating the technical feasibility, environmental and social considerations, and economic feasibility of the construction program in this survey, the feasibility of the Bheramara CCPP construction has been generally verified, although with certain qualifications. Further, a corporate plan has been proposed on the autonomous and efficient management of the North-West Power Generation Company (NWPGL) and Bheramara CCPP, and the groundwork is considered to have been laid for the organization, system, and business operation procedures for implementation of this project and operation of the power generation company.

#### **1. Technical Feasibility**

##### **1.1 Justification of the construction program**

The study has verified the adequacy of the power demand forecast described in the Power System Master Plan update 2006 (hereinafter referred to as "PSMP2006"), acquisition of sufficient beneficial effects such as an increase in the electrification rate due to the implementation of this project and improvement in the practical side of life due to an increase in employment opportunity, adequacy of the electric power development program based on the power demand forecast, and adequacy of the power generation facility arrangement and output of the Bheramara CCPP through system analysis. Verification of the aforementioned adequacies leads to the conclusion that the construction program of this project is suitable.

## **1.2 Diversification of fuels and selection of the gas turbine type**

The study on fuel diversification in the CCPP using gas as a major fuel has demonstrated that use of heavy oil and light oil as an alternative fuel is not a proper selection from the viewpoint of technology, economy, and environment. Preferential supply of gas is essential for the implementation of this project. Our recommendation for fuel diversification is a gas-fired CCPP provided with a light oil backup facility. Further, when consideration is given to the output level programmed in the Bheramara CCPP, possible candidates include the CCPP using two E-type gas turbines (hereinafter referred to as "E-type CCPP), or CCPP using one F-type gas turbine (hereinafter referred to as "F-type CCPP). The E-type CCPP has an advantage in that the output of 450 MW or more (under the site conditions) can be ensured, depending on the manufacturers to be selected by international bid. However, when this type is subjected to an overall evaluation from the technical, economical and environmental point of view, we would like to recommend the F-type CCPP which is characterized by high efficiency and a small environmental load for this project.

## **1.3 Natural gas supply**

The Bheramara CCPP is planned to be fired by natural gas in normal operation, and the reliable supply of natural gas to the Bheramara CCPP determines the success or failure of this project. When this survey started, it was learnt that natural gas would be supplied to the Bheramara CCPP in 2012. However, due to a delay in the development of a new gas field, MoPEMR announced in August 2008 that the supply of natural gas to the Bheramara CCPP might be achieved around 2016. In the meantime, for the earliest possible solution to the current power shortage problem, it is absolutely essential to commence the commercial operation of the Bheramara CCPP in 2014. This makes it necessary for the Government of Bangladesh to set up a definite policy for the preferential supply of natural gas to the Bheramara CCPP by promoting the development of a new gas field and suspension of the existing low efficiency gas-fired power plant.

## **1.4 Condenser cooling system and use of a groundwater**

For the condenser cooling system, a study has been made for a once-through type cooling system, cooling tower system, and air-cooled condenser system from the viewpoint of technology, environment, and economy. Adoption of a cooling tower system has been determined as a result of this study. In the cooling tower system, groundwater is used as the make-up water. As a result of surveying and analyzing the impact of the use of the groundwater on the wells around the new power plant, it has been verified that there is no impact during dry or rainy seasons and in long-term use. However, to verify the impact after

commencement of commercial operation, monitoring of the surrounding wells is essential.

### **1.5 Transportation of heavy equipment**

In the construction of a large gas-fired power plant, a serious impact may occur to the construction process is given by the method adopted for transporting such heavy objects as gas turbine, steam turbine, generator stator, and transformer, and the level of difficulty in their transportation. In this project, heavy objects will be carried mainly through river from the port of Mongla in the southwestern part of Bangladesh to the Bheramara site. In the meantime, river transportation is restricted to the period from July to September by the depth of water in the Padma River in the vicinity near the Bheramara site. Accordingly, a detailed heavy object transportation program must be worked out by the contractor in consultation with the river administrator and transportation company. Further, the material and equipment of 40 tons or less in weight will be carried by land from the port of Mongla to the project site. However, when the heavy objects weighing 40 tons or more are to be carried, the risk of river transportation must be minimized by using land transportation instead of river transportation, for example, by optimizing the individual package weight and dimensions, along with consideration given to the mode of land transportation such as separate transportation.

### **1.6 Project schedule**

The river transportation of heavy objects is restricted to the three-month period from July to September affecting the project schedule. Due to the globally tight conditions of the production line, the required delivery time of an F-type gas turbine will be about 25 months from the design phase to the time of delivery on an F.O.B. basis. Thus, about 64 months will be required from the conclusion of LA to the completion of the power plant construction. Further, there are signs of a global economic recession resulting from the impact of the financial crisis triggered by the United States and the subsequent trend of gas turbine production must be closely watched.

## **2. Environmental and Social Consideration**

The construction site of the Bheramara CCPP is located at the site adjacent to the existing Bheramara power plant in the northeast, and the surrounding land is also owned by BWDB or BPDB. So there is no need for large-scale land acquisition. Natural forests, habitats of precious plants and animals or ancient remains have not been discovered within the project site. This site has no problems with natural environment. Further, there are no particular problems with the social environment, because almost all the inhabitants around the existing power plant and project site are engaged in farming, and their relocation is not required by this

project. With the construction of the Bheramara CCPP, there are concerns about the possibility of noise, vibration, water pollution and air pollution being caused during the construction period, and noise, vibration, air pollution, and water pollution being caused after commencement of commercial operation. However, impact on the surrounding environment and inhabitants can be removed by taking adequate environmental measures based on the simulation analysis results.

In addition, during construction and after commissioning, comprehensive contribution to local economy and industry can be achieved through the employment of the local people who will participate in the training program, procuring the local products from the hometown cooperation and upbringing of new local industry in cooperation with a local self-governing body. And the maintenance of the organization system should be planned in order to grasp the opinion of inhabitants enough and address them.

Based upon the foregoing, it is judged that this Project will not have adverse impact on neighboring environment and the inhabitants. Rather it will be able to contribute to activation of the local economy.

### **3. Economic Feasibility**

There has been a steep rise in the prices of the gas turbine, steam turbine, and generator constituting the CCPP due to the recent rising prices of the materials and overheating of the power generation facility market. With consideration given to market trends and based on the recent conclusion of contracts, the project cost has been calculated as amounting to a total of about 84.5 billion yen (of which the power generation facility cost amounts to about 43.2 billion yen). As a result of economic and financial analyses, the EIRR has been calculated as 20.64% by the method of quantifying the Willingness-to-Pay and FIRR has been calculated as 5.88% on a tentative basis. Thus, the EIRR having been calculated exceeds the opportunity cost of the capital in Bangladesh and the FIRR exceeds the weighted average cost of the invested capital, whereby this project has been verified to be economically feasible.

### **4. Strengthening the functions of a power generation company and supporting the improvement of basic conditions in a power plant**

Based on the study of a preceding company having been spun off in conformity to the Bangladesh policy on the improvement of the electric power sector, analysis of the present situation in Bheramara CCPP was conducted according to the case research from the viewpoint of business administration, risk management, organization management, labor and personnel management, financial and accounting management, O & M management, information management, and environmental management.

The following problems have been detected:

- Stable business administration of the BPDB has not been achieved for a long period of time under the protection of the regulations led by the Government, without sufficient autonomous and efficient management being promoted.

- The business administration vision is not sufficiently captured by the personnel, and there is no clear definition of a grand design on which the organization should be based.

- Since the principle of separating the business administration implementation function from the supervising function is not established, independence of business administration is not ensured, and decision making in business administration is slow.

- There is no incentive/punishment system or employment system that can provide logical and effective functions, as can be observed in the guarantee of lifetime employment and the fixed salary system are not interlinked with individual business performances.

- BPDB is a seller of electricity as well as a purchaser of electricity as a single buyer. Accordingly, this organization has no concept of practical cash flow, which is essential to autonomous management.

- In many of the power plants in Bangladesh, there is a widespread compulsion of breakdown maintenance where "the facility should be operated until it is broken". Proactive maintenance activities can not be conducted at all. As a result, there is rapid dilapidation of the equipment and facilities, hence a perfect "negative spiral" of occurrences in serious accidents and troubles, resulting in occurrence of massive repair costs, failure to repair due to financing difficulties and reduction in supply.

- In Bangladesh, there are many power plants which were constructed and operated before the EIA scheme was improved. Thus, a management scheme based on the environmental management program has not worked out in many cases. The Bheramara power plant will be operated after the environmental management program has been approved. It is very important to strengthen the organization management scheme on environmental management including monitoring.

## II. Recommendation

Based on the results of this survey, we would like to submit the following proposals:

1. The construction of this project is planned based on the assumed power demand calculated in the PSMP2006 and electric power development program. The power demand prediction is closely related to the GDP growth rate. The GDP growth rate up to 2025 can be represented by a curve exhibiting an upward slope to the right. Accordingly, the power demand is anticipated to register a favorable increase. As discussed above, due to the global economic recession triggered by the United States, the GDP growth rate is expected to slow down in Bangladesh as well as in other parts of the world. In this situation, it will be necessary to review the power demand prediction based on the real economy.

2. An earlier start of the study is desired in order to work out specific measures on how to implement the preferential supply of gas to the Bheramara CCPP in and after 2014. As most realistic measure, taking into consideration of the efficient utilization of natural gas produced in Bangladesh and balanced business operation of electric power company, natural gas should be re-allocated to the Bheramara CCPP, rather than to aged and low efficient existing gas thermal power plants.

3. A cooling tower system has been adopted as the cooling system and groundwater will be used as the make-up water of this system. Based on the results of the pumping test conducted in September this year, it has been found out from the analysis results that there is a sufficient reserve of groundwater around the site planned for the power plant construction, and there is almost no impact on the existing wells in the surrounding area when a large volume of groundwater is drawn off. However, to verify the impact subsequent to commencement of the commercial operation, we would like to propose continuous monitoring of the wells now running as well as to be implemented in the surrounding area.

4. Transportation of heavy objects is planned mainly based on river transportation, and river transportation is possible only during the period from July to September due to the low water level in the Padma River. In this survey, however, due to the limited time, we measured the water depth of a navigation route from the port of Mongla to the Bheramara site during the period of July. Accordingly, to verify the reliability of the period of river transportation, we would like to recommend measurement of the water depth of the navigation route from the port

of Mongla to the Bheramara site during the period of June through October, starting a year before the river transportation begins.

5. The period of river transportation of heavy objects and the delivery time of the gas turbine are critical points in the project schedule, as discussed above. In the meantime, due to the recent global economic recession, there is a possibility of the combined cycle power generation project being delayed or cancelled. The current tight conditions of the gas turbine production line may be loosened in the future, and the delivery time of the gas turbine may be shortened. These possibilities must be carefully watched.

6. There is a possibility of a slowdown in the steep rise of the project cost resulting from a substantial rise in material costs and overheating of the power generation facility market for the last several years. The trend of the power generation facility market must be carefully watched.

7. We would like to propose the most important six key messages for ensuring that autonomous and efficient management will be carried out by the NWPGL and Bheramara power plant.

#### Key Message 1: Working out a business administration vision

To ensure continued development of a company, it is important to implement an efficient management and in-house human resources development program. The target of the NWPGL is the continued development of the organization, which can be achieved by both autonomous management and human resources development. The three major points of "autonomy of business administration", "highly reliable power supply", and "continued development" are the NWPGL's business administration vision. Balanced achievement of these major points is the key to success.

#### Key Message 2: Principle of separating the business administration implementation function from the supervising function

To ensure continued development of a company, it is essential to establish a corporate governance scheme and to work out a framework to direct and unify the company. The major points are:

<1> Separating the business administration implementation function from the supervising function

<2> Implementation and operation of internal regulations



<3> Supervision from outside the company

In particular, it is important to separate the business administration implementation function from the supervising function in order to enhance the independence of the business administration, and to increase the speed of decision making in business administration and job implementation.

Key Message 3: Working out an employment system based on the principle of competition and rating by performance

We would like to propose the introduction of an employment system based on the principle of competition and rating by performance for the purpose of ensuring autonomy and efficient management under the umbrella of NWPGL. It is important to introduce a framework of a one-year trial period, followed by the conclusion of a three-year employment contract as a regular employee, and then by updating the contract period in conformity to individual performances. Further, roles and responsibilities should be defined through the improvement of the regulations on official authority and others, and adequate evaluation of performances should be carried out according to a multifaceted evaluation procedure, whereby adequate pay (remuneration) is provided. It is necessary to introduce such a framework where incentives effectively come into play.

Key Message 4: Ensuring cash flow

All the electric power generated by NWPGL will be purchased by the BPDB as a single buyer. Payment will be made to NWPGL by BPDB according to the PPA agreement to be concluded between BPDB and NWPGL. This means that the PPA agreement is crucial. In APSCL, the accounts receivable are equivalent to the sales of about one year. Although the balance is kept in the black in terms of the statement of profit and loss, sufficient equipment and materials cannot be procured due to the lack of cash flow, and the operation of the power plant may be adversely affected. Thus, when a PPA agreement is concluded, it is necessary to take into account the management of accounts receivable, for example, through pledging a letter of credit or revolving credit, opening an escrow account, or diversification of electricity buyers.

Key Message 5: Working out the O & M management scheme based on proactive maintenance activities

In many of the power plants in Bangladesh, maintenance is compelled to be carried out on "Level 1: breakdown maintenance (BDM)" where the facility is operated until it is broken down", on a continuous basis. In Japan, the periodic legal inspection is stipulated by regulation authorities and the maintenance is carried out mainly on "Level 2: time based

maintenance (TBM)". As a result of the maintenance activities by the electric utilities and active study of the essential requirements for inspection by regulation authorities, the level is shifting toward "Level 3: condition based maintenance (CBM)" where the periodic inspection interval is prolonged while the current level of safety is kept. Thus, Bangladesh is expected to acquire the skill capable of accurate identification of situations so as to adopt the flexible maintenance management based on the TBM/CBM combination which is similar to that of Japan, and to improve the level of organization and technology, whereby the reliability and safety of the facilities are ensured.

**Key Message 6: Working out the management scheme in conformity with the environmental management program**

In the Bheramara power plant this time, licensing of power generation depends on the approval of EIA and environmental management programs. Thus, it is strongly desired that effective implementation of environmental management will be accomplished by working out an organization administration scheme related to environmental management in each of the corporate, management, plant and public levels, as well as by working out program, maintenance measures, monitoring and record management programs, whereby adverse impact on the environment subsequent to commencement of commercial operation will be minimized.

**Part I**

**Feasibility  
of  
Bheramara Combined Cycle Power  
Station Construction Plan**

## **Chapter 1 Preface**

### **1.1 Background of the study**

Bangladesh is aiming for supplying electric power to all the citizens by 2020. However electrification rate is still 42% in 2007. In comparison to 5,100 MW as the peak power demand, the maximum power generating capacity is approximately 3,800 MW. They cause planned power cut because of power supply shortage. On the other hand, power demand growth is forecasted as 8% a year from now on and it is necessary to build approximately 5,500 MW of new power supply for next five years to satisfy power demand growth.

Also natural gas field as the significant natural resource in Bangladesh is unevenly distributed at eastern area in Bangladesh. It leads to build power stations in eastern area not in western area. This unevenly gas distribution situation causes power supply shortage in western area, transmission loss from eastern power to western area and drop in voltage. Generally western area is slow in development and it is a matter of great urgency to aim to raise their living standard in western area.

Now natural gas pipeline is under construction with the support from ADB and Bangladesh is planning to build a large scale gas power plant in western area.

Meanwhile Bangladesh has been reforming the electric power sector in order to improve administrative management and power supply since 1994. So far, BPDB has been divided into APSCL, EGCB and PGCB. Bheramara CCPP is supposed to belong to NWPGL and company plan is also the subject matter of this study.

In August 2007, Bangladesh requested Japan Government for a feasibility study of Bheramara combined cycle power plant in western Bangladesh. ODA task force in Bangladesh is examining possibility of providing ODA loan from JBIC concerning The Plant construction.

In order to decide the scope of F/S, study the power sector and creation of the company, JICA executed on-site study of The Plant in October, 2007 and recorded M/M concerning the future cooperation plan to confirm the necessary condition of the Plant through discussion with local party and study of the candidate site for The Plant. Based on the draft which was prepared during the last on-site study, JICA agreed with local party concerning contents of S/W afterward.

### **1.2 Objectives of the Study and Scope of the Study**

#### **1.2.1 Objectives of the Study**

Objectives of the study are as follows.

- (1) To execute the Feasibility Study concerning Bheramara CCPP Construction in The People's Republic of Bangladesh and necessary technology transfer to the staff concerned of local C/P for The Study term.
- (2) To support NWPGL, which will manage The Plant, concerning administrative system and management plan.

Concerned departments in Bangladesh are as follows.

- Ministry of Power Energy and Mineral Resources: MoPEMR
- Bangladesh Power Development Board: BPDB
- NWPGL
- APSCL
- EGCB

- PGCB
- Petrobangla
- Economic Relations Division : ERD
- Planning Commission
- MOE
- Bangladesh Water Development Board: BWDB

The areas to be studied are as follows.

- (1) The areas to be studied are Bheramara and its surrounding places.
- (2) The areas to be executed to support management of NWPGL are Bheramara and its surrounding areas and Dhaka and its surrounding areas.

### **1.2.2 Scope of the Study**


Based on the Minute of Meeting and Scope of Works which were signed in December, 2007 between the Preliminary Study Team of JICA and Bangladesh, the following components of the Study will be carried out:

- (1) Collection and confirm of Basic information and plan
  - Power demand forecast
  - Profitable effect
  - Fuel supply system
  - Power system plan to connect 230kV power line
  - Practicable system
  - Adequacy for the site selection
- (2) Study for construction site
  - Topography survey and study of structures
  - Soil quality study
  - Study for the cooling system and river conditions
- (3) Study for engineering
  - Designing for power plant and determination of necessary specification
  - Determination of Project cost and financial plan
  - Estimation of necessary procurement and delivery schedule
  - Basic design
  - Construction schedule
- (4) Suggestion for administrative system of The Plant
- (5) Study of financial analysis and management effect index
- (6) Environment and social concern
  - Study of the environment
  - Study of the social concern
  - Study of pollution countermeasure
  - Study of reduction plan of environmental impact
  - Study of environmental management and monitoring
  - Study of resettlement
  - Support for stakeholder committee
- (7) Support of administrative plan about the power company and administrative system
  - Support to NWPGL to establish its organization
  - Support for business plan of The Plant
- (8) Technology transfer for whole study -term

(9) Work Shop (hereinafter called as “W/S” )

### **1.2.3 Duration of the Study**

Schedule of the Study is shown in the next page.



### 1.3 Assignment of the Study Team

Table I-1-3-1 shows the assignment for each expert of the Team.

Table I-1-3-1 Formation of the Team

| Name                                 | Assignment                         |
|--------------------------------------|------------------------------------|
| Hideyuki OKANO                       | Project Manager                    |
| Shinji OUCHI                         | Power Plant System Planning Expert |
| Hiroshi SHINOHARA                    | Fuel Supply Planning Expert        |
| Ichiro KATAGIRI                      | Civil Expert                       |
| Hajime SAIT                          | Mechanical Expert A                |
| Kenji MIKATA                         | Mechanical Expert B                |
| Masamichi SHOJI                      | Electrical Expert                  |
| Kenichi KITAMURA                     | Transmission Expert                |
| Noboru SEKI                          | Business Management Expert         |
| Kiyoshi KATAOKA                      | O&M Management Expert              |
| Toshiyuki KOBAYASHI                  | Organizational Structure Expert    |
| Yasuhisa KURODA                      | Financial and Accounting Expert    |
| Norihiko FUKAZAWA/<br>Mitsutake KUDO | Environmental Expert A             |
| Tadashi NAKAMURA                     | Environmental Expert B             |
| Nobunao TAKAHASHI                    | Coordinator                        |

### 1.4 Work Shop

Three Work Shops were held on the following dates. Details of each work shop are described in Technology Transfer Report.

- 1st Work Shop : June 4, 2008
- 2nd Work Shop : September 10 and 18, 2008
- 3rd Work Shop : November 20 and 24, 2008

### 1.5 Stake Holder Meeting

Stake holder meeting were held three times on the following dates. Details of each stake holder meeting are described in Chapter 7 of Main Report.

- 1st Stake Holder Meeting : June 16 and 17, 2008
- 2nd Stake Holder Meeting : September 21 and 22, 2008
- 3rd Stake Holder Meeting : November 30 and December 1, 2008



## Chapter 2 Social / Economic State of Conditions in Bangladesh

### 2.1 Overview

Bangladesh has been exerting incessant efforts to improve the socio-economic conditions of the country since its independence in 1971 while being continuously assisted by the domestic and external organizations. Notwithstanding those domestic and external efforts, the Gross National Income (GNI) per capita in the country remains at the level of US\$ 450 (2006 constant price) and is classified as one of the Least Developed Countries as defined by United Nation<sup>1</sup>. The level of GNI per capita is below the level of US\$ 900 which is defined as the threshold for graduating from the category of the Least Developed Countries. The fundamental indicators of the socio-economic conditions of Bangladesh compares with those of other neighboring South Asian countries as follows;

Table I-2-1-1 Comparison of Socio-Economic Indicators among South Asian Countries

| Country         | GNI/capita<br>(US\$) | GDP<br>Growth<br>Rate<br>(%) | Average<br>Rate of<br>Inflation<br>(%) | Fiscal<br>Balance<br>(% of<br>GDP) | Poverty<br>Headcount<br>Rate<br>*1<br>(%) | Enrollment<br>for<br>Primary<br>Education<br>(%) | Average<br>Life<br>Expectancy<br>at Birth<br>(years) | Electricity<br>Consumption<br>(kWh/capita) |
|-----------------|----------------------|------------------------------|--|------------------------------------|---|--|--|--|
| Year of<br>Data | 2006                 | 2000-2006                    | 2000-2006                              | 2006                               | 2004                                      | 2006   | 2006   | 2005                                       |
| Bangladesh      | 450                  | 5.6                          | 5.9                                    | -3.2 *1                            | 36.3                                      | 103  | 64   | 136  |
| India           | 820                  | 7.4                          | 4.2                                    | -2.8                               | 35.3                                      | 115  | 64   | 480  |
| Nepal           | 320                  | 3.3                          | 5.2                                    | -1.6                               | 30.9                                      | 126  | 63   | 70   |
| Pakistan        | 800                  | 5.5                          | 5.6                                    | -4.2                               | 17.0                                      | 84   | 65   | 456  |
| Sri Lanka       | 1,310                | 4.8                          | 9.7                                    | -7.2                               | 5.6                                       | 105  | 75   | 378  |

(note) \*1: Poverty Headcount Rate is taken from World Bank, "Bangladesh: Country Assistance Strategy 2006-2009"

\*2: Fiscal Balance of Bangladesh is taken from IMF, "Bangladesh: Statistical Appendix" June, 2007

(source) World Bank, "World Development Indicators 2008", 2008

World Bank, "Bangladesh: Country Assistance Strategy 2006-2009", undated

The above table confirms GNI per capita of Bangladesh being at US\$ 450 which ranks second to Nepal from the bottom among the neighboring countries. On the other hand, the growth rate of GDP is second highest after India while the rate of inflation is acknowledged to be high. The country ranks in the middle in its fiscal balance but its poverty headcount rate is the highest in the region. The average consumption of electricity per capita is very low in comparison with the countries of India, Pakistan and Sri Lanka, at less than 30% of India and Pakistan.

Taking a closer look at recent years of economic performance, GDP grew in 2005/06 by 6.7% from the preceding year. Despite suffering from the flood damages in the early part of the fiscal year, the economy has been boosted by the constant inflow of remittances from the workers abroad together with the increase of private investment which grew by 8% for the year. The

<sup>1</sup> United Nations Conference for Trade and Development (UNCTAD) initiated classification of countries by GNI per capita in 1971. The list of the countries is periodically reviewed and updated. The criteria used at present are; for a new country to be listed is the three year average of GNI per capita staying below US\$ 750 and for a country to graduate from the list, the GNI per capita must exceed US\$ 900. In addition to the criteria by income, other criteria are used by UN to review the classification; the level of human assets as measured through Human Assets Index and economic vulnerability measured through Economic Vulnerability Index.

stagnant inflation has kept the prices high against which the government has taken measures by liberalizing the imports into the country. The fiscal management has followed conservative operation but the fiscal deficit is in the increasing trend recording the deficit of 3.9% of GDP in the fiscal year of 2006. The outstanding balances of domestic and external debts of the government stand at 47% of GDP in the domestic debt and 30% in external debt both of which, are judged being at stable levels. While the economy is treading a healthy growth pattern, the needs are pointed out for the country to curb the inflation and to improve the tax collection in the fiscal front. While the fiscal position of the government is burdened with the continuous deficits, the tasks of the government is frequently pointed out that it improves the efficiency of tax collection so that it can mobilize more of the domestic resource into the development of the socio-economic condition of the country.

Given the current status as such, World Bank recognizes the progress of the socio-economic conditions of Bangladesh as follows<sup>2</sup>;

- Bangladesh is the 10<sup>th</sup> most rapidly growing economy among 31 large developing countries with populations above 20 million and with GDP growth averaging 5% since 1990s;
- Income poverty in Bangladesh declined by 1 %age point per year since 1990 - faster than almost all other developing countries;
- Primary school enrollment is almost 100% - one of the highest in the developing world. The ratio of girls to boys in primary school is higher than most developing countries;
- Bangladesh is the only country to have eradicated polio in South Asia. 77% of all children are immunized before age 2, a national coverage rate far exceeding that of India and Pakistan;
- Bangladesh has consistently allocated its budget in a pro-poor way, injecting substantial public resources into education and health. Bangladesh's military expenditures are the lowest by far of any country in the region, as a %age of GDP;
- While infant and child mortality remains high, Bangladesh has reduced this scourge faster than any other developing country; and
- Despite progress, governance and corruption remains a major concern in Bangladesh. Bangladesh performs poorly relative to other low income countries in political stability, regulatory quality and control of corruption.

Based on the perception of the country as above, World Bank is summarizing its long term outlook on the strategy for economic development of Bangladesh which spells out that, the country has the necessary assets; much-improved economic fundamentals; success in implementing many first-generation reforms; a young, rapidly growing labor force; and an established entrepreneurial culture and the country could join the ranks of middle-income countries within a decade (by 2016) or some time after<sup>3</sup>.

## **2.2 Population and Labor Force**

### **2.2.1 Population Census**

In Bangladesh, Bangladesh Bureau of Statistics is conducting the national census once every 10 years. The latest survey was conducted in July 2001 which determined the total population as

---

<sup>2</sup> World Bank, "Bangladesh Fact Sheet 2005-6", 2008

<sup>3</sup> World Bank, "Bangladesh: Strategy for Sustained Growth", July, 2007

124.35 million out of which 23.5% resided in the urban area and 76.5 in the rural area. The annual growth rate of population after the census is recognized as 1.58% which will lead to the forecast of population in 2011 as 145.5 million. The government is vigorously pursuing the family planning campaign and the growth of population is expected to slow down gradually. The total population is comprised of; Muslims 89.6%; Hindus 9.3%; Buddhists 0.6%; and Christians 0.3%. Due to the population increase, the population density increased from 720/km<sup>2</sup> in 1991 to 843/km<sup>2</sup> in 2001. The gender is composed of 106 males versus 100 females. The literacy rate found in 2001 census as 46.2% among those whose ages are 7 years and older. The total number of households was found to be 25.5 million<sup>4</sup>. The populations in major cities were; 5.3 million in Dhaka (metropolitan area); 2.0 million in Chittagong; 0.8 million in Khulna; and 0.4 million in Rajshahi. Cities and township other than those mentioned are; Barisal; Sylhet; Mymensingh; Comilla; etc. Administratively, the country is comprised of 6 Divisions under the State and each Division is divided into Zilas (Districts) which is sub-divided into Upazilas (Sub-districts). The area, population, number of households and administrative units are enumerated in the following table;

Table I-2-2-1 Administrative Units, Population and Households (2001 Census)

| Division   | Area (km <sup>2</sup> ) | Population (thousand) | Households (thousand) | No of Zila | No. of Upazila (Thana) | No. of Union | No. of Village | No. of City Corporation |
|------------|-------------------------|-----------------------|-----------------------|------------|------------------------|--------------|----------------|-------------------------|
| Barisal    | 13,644                  | 8,174                 | 1,648                 | 6          | 39                     | 334          | 4,273          | 22                      |
| Chittagong | 33,771                  | 24,290                | 4,472                 | 11         | 102                    | 914          | 15,060         | 38                      |
| Sylhet     | 12,596                  | 7,939                 | 1,388                 | 4          | 35                     | 322          | 10,101         | 14                      |
| Dhaka      | 30,985                  | 39,045                | 8,236                 | 17         | 141                    | 1,236        | 25,283         | 64                      |
| Khulna     | 22,285                  | 14,705                | 3,119                 | 10         | 64                     | 565          | 9,284          | 28                      |
| Rajshahi   | 34,495                  | 30,202                | 6,627                 | 16         | 127                    | 1,094        | 23,361         | 57                      |
| Total      | 147,570                 | 124,355               | 25,491                | 64         | 508                    | 4,466        | 87,320         | 223                     |

(source) Bangladesh Bureau of Statistics, "Statistical Yearbook of Bangladesh 2006"

## 2.2.2 Labor Force Survey

### (1) Employed Labor

With respect to the labor force, Bangladesh Bureau of Statistics is conducting the Labor Force Survey. The total population of Bangladesh is known to have increased approximately three times from 52 million in 1960 to 140 million as of today. Female population has grown faster than male population reflecting the underlying improvements in gender parity with the share of female population increasing from 47% in 1960 to 49% in 2005 is slightly higher than in India and Pakistan.

Recent trend shows that the growth of the working-age population outpaced that of the population as a whole. While the total population has increased by about 70 % between 1980 – 2005, working-age population (those in 15 – 64 age group) practically doubled – increasing from 44 million in 1980 to 86 million in 2005. Demographic factors such as increased life expectancy and markedly lower infant mortality have offset the slowdown in population growth (from 2.5 % in 1980s to about 1.5 %), resulting in working-age population growth remaining largely unchanged at about 3 % per annum. Under-5 mortality rates fell from 205 per 1,000 live births in 1980 to 77 in 2004; one of the fastest rates of decline in the

<sup>4</sup> Bangladesh Bureau of Statistics, "Statistical Yearbook of Bangladesh 2006"

developing world. Life expectancy at birth increased from 49 years to 64 years over the same period. The growth rate of working-age population is expected to slow down to 2 % a year in the coming years. Still more than one-third of the population is currently under the working-age, a sizable pool to be fed by the robust labor supply growth.

In Bangladesh, the predominant majority of the population lives in the rural areas and so is the labor force with 76% residing in the rural areas. According to the 2003 Labor Force Survey, total labor force was counted as 46.3 million, out of which male were 36.0 million and female 10.3 million. The Survey conducted 3 years later in 2006 found the total labor force as 49.5 million out of which male were 37.4 million and female 12.1 million. The female labor force grew at the surprising annual rate. During 1996 – 2003, the number of female labor force has doubled and reached 10 million while male labor force increased by 17% during the same period. There exists the trend of urbanization in the labor market, too, as the share of the urban labor force among the total increased from 23% in 1996 to 24.5% in 2003.

## (2) Employment

Taking a look at the employment opportunity, Bangladesh economy is observed to have created 5.3 million new jobs during 2000 – 2003. This is a sizable increase but it still falls short of the 5.6 million new entrants to the labor force by 0.3 million. New jobs for females kept pace with the increase in female entrants while the shortage of job opportunities was all among the male entrants. With respect to the urban – rural breakdown, 2 million new jobs were created in urban areas where the labor force increased by 2.1 million. In rural areas, 3.3 million new jobs were created whereas the labor force increased by 3.5 million.

In 2003, despite accounting for just 21% of GDP, agriculture sector accounted for 52% of the labor force, up from 49% in 1996. During the same period, the share of agriculture among GDP decreased from 25% to 21%. Industry- wise, almost 90% of male workers are engaged in agriculture (50%) or in services (38%), while only about 10% are engaged in the manufacturing and construction industries which jointly comprise about a quarter of GDP. Among the female jobs, share of agriculture rose from 28% in 1996 to 59% in 2003 and this increase of female labor pushed up the total labor force in agriculture.

One cannot understand fully the job opportunity in Bangladesh without going into the status of the jobs and employment. The status of the jobs are enumerated in the following table;

Table I-2-2-2 Status of Jobs (%)

| Status of Employment | Bangladesh |        |       | Urban |        |       | Rural |        |       |
|----------------------|------------|--------|-------|-------|--------|-------|-------|--------|-------|
|                      | Male       | Female | Total | Male  | Female | Total | Male  | Female | Total |
| Employee             | 13.8       | 13.4   | 13.7  | 24.4  | 21.6   | 23.7  | 10.5  | 10.5   | 10.5  |
| Employer             | 0.4        | 0.2    | 0.4   | 0.7   | 0.3    | 0.6   | 0.4   | 0.1    | 0.3   |
| Self-Employed        | 50.6       | 24.5   | 44.8  | 47.1  | 21.6   | 41.2  | 51.6  | 25.5   | 45.9  |
| Day Labor            | 22.9       | 9.6    | 20.0  | 17.3  | 10.1   | 15.6  | 24.7  | 9.5    | 21.4  |
| Unpaid Family Work   | 9.9        | 48.0   | 18.4  | 7.6   | 39.3   | 15.0  | 10.6  | 51.0   | 19.4  |
| Domestic Worker      | 0.1        | 2.5    | 0.6   | 0.1   | 4.3    | 1.1   | 0.1   | 1.8    | 0.5   |
| Apprentice           | 1.0        | 0.6    | 0.9   | 1.3   | 1.2    | 1.3   | 0.9   | 0.4    | 0.8   |
| Others               | 1.2        | 1.2    | 1.2   | 1.4   | 1.6    | 1.4   | 1.1   | 1.1    | 1.1   |
| Total                | 100.0      | 100.0  | 100.0 | 100.0 | 100.0  | 100.0 | 100.0 | 100.0  | 100.0 |

(source) Bangladesh Labor Force Survey 2003 (World Bank, “Bangladesh: Strategy for Sustained Growth”, July 2007)

Among the labor force that has responded as having jobs, 45% of the total are self-employed

which is close to half of the labor force. The self-employed constitute 41% of the urban labor force and 46% of the rural labor force. Next to be noted is the unpaid family work in which 18% of the total labor force, (15% of the urban and 19% of rural labor force) are engaged. The self-employed and the unpaid family work being combined, 63% of the total labor force, (56% of urban and 65% of rural labor force) are found to be engaged. Those employment status are closely related to the low level of personal income of the country. Gender-wise, 51% of male are self-employed as against 25% of female. In addition 10% of male workers are engaged in the unpaid family work while 48% of female workers are in the same category. The level of female workers in the category is astounding and further broken down into the 39% in urban against 51% in rural female workers.

### (3) Unemployment

In Bangladesh, the statistics of unemployment reports consistently low percentage levels as is usual in most of the developing countries. The definition of unemployment in Bangladesh is any person of age 15 years or above if he or she did not work at all during the preceding week of the survey and was actively looking for work<sup>5</sup>. According to the definition, the unemployment rate in 2003 is recorded as 4.3% or in the absolute number of 2 million. The unemployment rate increases with the education levels of the labor force. The more educated workers have higher reservation wages and are less willing to compromise on the quality of job they accept. In furtherance, those who go for higher level of education often come from more well-off family and can afford to stay away from working for a longer period.

Should we consider monthly income of Taka 2,000 which is equivalent to one dollar a day, definition set up by UN for absolute poverty, about half of the self-employed fell below the poverty level in 2003<sup>6</sup>. About 35% of the urban self-employed and 40% of the rural self-employed belonged to the category in 2003, which compares with the 40% and 43% respectively in 2000. Rural workers are recognized to be in harder conditions through those statistics.

## 2.3 Macro Economy

### 2.3.1 Economic Growth

The macro economy of Bangladesh is represented by the following indicators;

Table I-2-3-1 Macro Economic Indicators

| Fiscal Year                                       | 2002/03   | 2003/04 | 2004/05 | 2005/06 | 2006/07 |
|---|---|---------|---------|---------|---------|
| National Accounts                                 | <b>(Annual percentage change, unless otherwise specified)</b> |         |         |         |         |
| GDP (nominal: Taka billion) *1                    | 3,005   | 3,330   | 3,707   | 4,157   | 4,675   |
| Real GDP *1                                       | 5.26  | 6.27    | 5.96    | 6.63    | 6.51    |
| CPI Inflation (average) *1                        | 4.38  | 5.83    | 6.48    | 7.16    | 7.20    |
| CPI Inflation (end-of-period) *1                  | 5.03  | 5.64    | 7.35    | 7.54    | 9.20    |
| WPI Inflation (average) *1                        | 3.07  | 3.72    | 13.82   |         |         |
| Unemployment (%) *2                               | 3.2   | 3.2     | 4.3     |         |         |
| No. of Employed<br>(end-of-period: in million) *3 | 46.3  |         | 49.5    |         |         |
| Poverty Headcount Index (%)<br>of population)     |   | 36.3    |         |         |         |

<sup>5</sup> World Bank, "Bangladesh: Strategy for Sustainable Growth", June 2007

<sup>6</sup> ditto

| Fiscal Year                          | 2002/03                  | 2003/04 | 2004/05 | 2005/06 | 2006/07   |
|--------------------------------------|--------------------------|---------|---------|---------|-----------|
| <b>Investment &amp; Saving</b>       | <b>(in % of GDP)</b>     |         |         |         |           |
| Gross National Saving *1             | 24.45                    | 25.44   | 25.84   | 27.67   | 29.15     |
| Investment *1                        | 23.41                    | 24.02   | 24.53   | 24.65   | 24.33     |
| Saving/Investment Balance *7         | 1.04                     | 1.42    | 1.31    | 3.02    | 4.82      |
| <b>Government Finance</b>            | <b>(in Taka Billion)</b> |         |         |         |           |
| Revenue *4                           | 309.7                    | 339.0   | 389.2   | 443.7   |           |
| Expenditure *4                       | 411.4                    | 441.6   | 513.3   | 578.2   |           |
| Out of which Subsidy *4              | 70.2                     | 78.9    | 103.2   | 108.6   |           |
| Balance *4                           | -101.7                   | -102.6  | -124.0  | -134.5  |           |
| Overall Fiscal Deficit (% of GDP) *6 |                          | -2.4    | -2.6    | -2.7    | -3.9      |
| Net Public Debt *5                   | 488.7                    | 547.2   | 607.3   | 691.6   | 784.2     |
| <b>Monetary Sector</b>               | <b>(in Taka Billion)</b> |         |         |         |           |
| Money Supply (M2) *1                 | 1,140                    | 1,297   | 1,516   | 1,812   | 2,120     |
| Credit to Private Sector *1          | 829                      | 946     | 1,107   | 1,310   | 1,508     |
| <b>External Sector</b>               | <b>(in US\$ Million)</b> |         |         |         |           |
| Exports of Goods *4                  | 6,492                    | 7,521   | 8,573   | 10,422  | 12,093 *7 |
| Imports of Goods *4                  | 8,707                    | 9,840   | 11,870  | 13,301  | 15,581 *7 |
| Trade Balance *4                     | -2,215                   | -2,319  | -3,297  | -2,879  | -3,488 *7 |
| Current Account Balance *4           | 176                      | 176     | -557    | 572     | 951 *7    |
| In % of GDP *4                       | 0.3                      | 0.3     | -0.9    | 0.9     | 1.4 *7    |
| Capital Account Balance *4           | 841                      | 165     | 947     | 218     | -278 *7   |
| Overall Balance *4                   | 815                      | 171     | 67      | 365     | 1,493 *5  |
| External Debt *4                     | 16,455                   | 16,761  | 19,286  | 19,420  |           |
| In % of GDP *4                       | 32.8                     | 30.4    | 29.3    | 28.6    | 28.3*6    |
| Debt Service *4                      | 926                      | 1,043   | 1,139   | 1,458   |           |
| Debt Service Ratio (%) *1            |                          | 7.0     | 6.7     | 5.8     | 5.3       |
| Gross Official Reserve *4            | 2,471                    | 2,714   | 2,930   | 3,471   | 5,077 *1  |
| In months of Imports *4              | 2.9                      | 2.8     | 2.5     | 2.7     | 3.9 *7    |
| <b>Memorandum Item</b>               |                          |         |         |         |           |
| Exchange Rate (Taka/US\$: average)*1 | 57.90                    | 60.43   | 63.75   | 69.67   | 68.80     |

(source) Data taken from the following sources and processed by the author;

\*1: Bangladesh Bank, "Monthly Economic Trends" September 2008

\*2: World Bank, "World Development Indicators" Various Years

\*3: Bangladesh Bureau of Statistics, "Statistical Yearbook of Bangladesh: 2006", 2006

\*4: IMF, "Bangladesh: Statistical Appendix", June 2007

\*5: Bangladesh Bank, "Major Economic Indicators: Monthly Update", February 2008

\*6: ADB, "Bangladesh: Quarterly Economic Update", June 2008

\*7: processed by the author

During the 5 years covered by the above table, the macro economy performed comfortably well. GDP has been on the growth orbit by growing at average annual rate of 6.13%. For the fiscal year 2008, the economy appears to have achieved 6.2% which is slightly lower than 6.5% in 2007<sup>7</sup>. The good performance has been supported primarily by the domestic consumption and the remittance from overseas workers. In 2008/09, the economy has started showing its vulnerability to the international aggravation of the financial sector triggered by the problem of

<sup>7</sup> ADB, "Bangladesh: Quarterly Economic Update", June 2008

sub-prime lending in U.S.A. World Bank is lowering its estimate of the economic growth of the country from the previous estimate of 6.5% to 4% in its worst case of the scenarios<sup>8</sup> stemming from the slowdown in export and workers oversea remittance.

In the investment front, the domestic investment took a minor setback to 24.2% of GDP. Meanwhile, it has been continuously pointed out that the economy is in critical shortage of the infrastructure. The shortage of electricity and the bottlenecks in the transport sector are major hindrances halting the international trades with neighboring countries. While the investment is showing sluggishness, the national saving is on the increasing trend. The national saving, being the aggregate of the domestic saving plus the fund transfer from oversea countries (net), has achieved a steady increase owing to the increasing amount of the remittances by the workers overseas. This has widened the gap between the national saving and investment.

What has been behind such scene is that the economic environment has not been sufficiently developed to the extent that entices the private investor to make investment decisions or that due to the inadequate functioning of the financial institutions to intervene the financial market and the money flow so that the national saving is effectively directed to the private sector for investment. There remains the task for the country to develop the environment for investment and enable the national economy to mobilize the robust saving and facilitate the investment.

While the weakness and the task being identified, Bangladesh is assessed by international institutions that it embraces a potential capability to attain GDP growth at an average of 7%. As one of such assessments of the country, PricewaterhouseCoopers reportedly evaluates Bangladesh as one of the 13 countries that have potentialities of achieving the GDP growth which is higher than the average of the member countries of OECD. Countries classified there are; Bangladesh; Argentina; Egypt; Iran; Malaysia; Nigeria; Pakistan; Philippines; Poland; Saudi Arabia; South Africa; Thailand; and Vietnam<sup>9</sup>.

### **2.3.2 Inflation**

Inflation is to be dealt with later in section 2.6.

### **2.3.3 Fiscal Balance**

In the fiscal year of 2004, the revenue grew 9.5% from the preceding year which was short of meeting the growth of nominal GDP but attained the growth of 14.8% in 2005 and 14.0% in 2006 in line with the growth of nominal GDP. Similar to the revenue, the expenditure is also on an increasing trend. Approximately 20% of the expenditure are routed to the subsidies which include fuel, fertilizer, food, etc. The expansion of expenditure caused the fiscal deficit to inflate and that is causing the public debt balance to expand.

The fiscal deficit has been seen at 3.2% of GDP in 2007 which will further be deteriorated in 2008 as the international prices of commodities and resources climbed after Bangladesh fiscal year 2007 has been over. The deficit for 2008 is reported to have been 4.8% of GDP<sup>10</sup>. The world has seen the crude oil price soaring toward the end of Bangladesh fiscal year of 2008 (June), the government has made a belated step on September 1, 2008 to revise the prices of petroleum products such as kerosene, diesel oil, etc. whose prices have been withheld since April 2007. The government has revised the gas tariff in part while the one for power sector has been kept unchanged since November 2005. The application submitted by PETROBANGLA for

---

<sup>8</sup> "The Daily Star" dated November 27, 2008

<sup>9</sup> PricewaterhouseCoopers, "The World in 2050: Beyond the BRICS: A broader Look at Emerging Market Growth Prospects", 2008

<sup>10</sup> ADB, "Bangladesh: Quarterly Economic Update", March 2008

the revision of the tariff is under appraisal now by BERC.

The subsidies granted by the government in 2008 are as follows: (a) Bangladesh Petroleum Corporation for the petroleum products for 6.2% of total fiscal outlay; (b) PETROBANGLA for the gas for fertilizer production and electricity generation at 4.2%; and (c) the food sector received 0.9% of the outlay. The government is reported to have spent in total 14.1% of the total expenditure as subsidies<sup>11</sup>.

### **2.3.4 Monetary Policy**

Monetary policy is in purview of the Central Bank, Bangladesh Bank. Bangladesh Bank exercises the monetary policy through the control of money supply. The past record of the money supply shows the increase of money supply by 13.8% in 2004; 16.9% in 2005; 19.5% in 2006; and 17.0% in 2007. The money supplied for each year has kept pace with the nominal growth of GDP and to be understood being sufficient enough to endorse the economic growth.

The official discount rate has been fixed and maintained at 5.0% as a result of lowering in 2004. The weighted average of interest rates at commercial banks has been fluctuating within the ranges of 5.6-6.9% for deposits and 10.9-12.9% for lending during such period. The spread between the two rates is seen to be as large as 5-6%. The magnitude of the spread margin indicates the inefficiency of financial intervention function. In addition, the level of non-performing loans at the commercial banks staying at about 12% is pushing up the financial intervention cost of the banks. Both the deposit rate and the lending rate of interest used to be at the lower end of the range stated above during 2004 and 2005 but shifted upward within the range lately.

### **2.3.5 Balance of Payments**

The exports of Bangladesh are predominantly, approximately two thirds, are occupied by the readymade garments. The export of readymade garments took a setback and recorded negative growth from the preceding year in 2002 due to the lifting of quota by U.S.A. but regained its momentum in 2004 and has been growing steadily ever since. The growth rates recorded were 27.3% in 2005; 21.6% in 2006; 28.0% in 2007; and 16.2% in 2008<sup>12</sup> and are higher than the growth of exports as a whole. With exception of the readymade garments, exports are composed of the commodities such as fish & shrimp; raw jute and jute products; leather; others (items processed at export processing zones) but none of such items occupy a substantial share among the country's total.

On the other hand, the growth of imports used to be lower than that of exports up till 2006, but in 2007 and later the imports of food stuff sharply increased by 26% in 2008<sup>13</sup> from the preceding year. On top of this, the skyrocketing prices of international commodities caused the imports of petroleum products and industrial intermediary goods to soar to a significant extent. The sharp increase of imports caused the deficit in the trade balance to inflate. The remittances from the overseas workers amounting as much as 50% of the total exports on constant basis has contributed the current account to be in surplus. The amount of remittances are recorded as; Taka 322.7 billion (US\$ 4,801 million) in 2006; Taka 412.9 billion (US\$ 7,978 million) in 2007; Taka 544.5 billion (US\$ 7,915 million) in 2008<sup>14</sup>.

---

<sup>11</sup> ADB, "Bangladesh: Quarterly Economic Update", June 2008

<sup>12</sup> Bangladesh Bank, "Major Economic Indicators: Monthly Update" September 2008

<sup>13</sup> ditto

<sup>14</sup> ditto



Table I-2-3-2 Remittances from Oversea Workers

(Unit : Taka billion)

| Fiscal Year                  | 1999   | 2000   | 2001   | 2002   | 2003   | 2004   | 2005   | 2006   | 2007   | 2008     |
|------------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|----------|
| Total Remittances            | 82.0   | 98.1   | 101.7  | 143.8  | 177.3  | 198.7  | 236.5  | 322.7  | 412.9  | 544.5*1  |
| % change from preceding year | 18.2%  | 19.6%  | 3.7%   | 41.4%  | 23.3%  | 12.1%  | 19.0%  | 36.5%  | 27.9%  | 31.9%    |
| Trade Balance                | -176.3 | -172.1 | -179.5 | -181.2 | -226.8 | -236.8 | -300.6 | -365.2 | -395.6 | -376.8*1 |
| Current Account Balance      | -18.9  | -0.1   | -43.3  | 14.0   | 11.4   | 30.1   | -23.6  | 47.9   | 65.4   | 59.3*1   |

(note) \*1 : Figures denominated in US\$ (US\$7,914.78 million) was converted by the average exchange rate in 2008.  
 (source) Bangladesh Bank, “Major Economic Indicators: Monthly Update” September 2008

The continuous and increasing trade deficit and the trend of overseas remittances are illustrated to be offsetting each other in the following figure;





Figure I-2-3-1 Trade Deficit and Overseas Remittances

The current account balance recorded a deficit in 2005. Fiscal years other than 2005 is maintaining the surplus and the surpluses contributed the foreign exchange reserves to accumulate from US\$ 2,471 million in 2003 to US\$ 5,077 million in 2007 and US\$ 6,149 million at the end of fiscal year 2008<sup>15</sup>.

### 2.3.6 Foreign Exchange Rate

Foreign exchange is also under the purview of Bangladesh Bank. The exchange rates for the past decade between 1999 and 2008 are traced in the following figure;

<sup>15</sup> ditto



(source) Bangladesh Bank, "Monthly Economic Trends", April 2008

Figure I-2-3-2 Trend of Foreign Exchange Rate

Against the US Dollar, Taka had been depreciating consistently up till March 2006 when Taka recorded US\$ 1 = Taka 68.0. Since then, till now the currency has somewhat stabilized. Having the ample and accumulating foreign exchange reserves, the Central Bank has been providing the foreign currency sufficient enough to meet the demand in the market with the aim to keep the market stabilized. The stabilized exchange rate is helping to curb the increase of import price which should have taken place if the exchange rate deteriorated. The stabilization of the exchange rates is contributing to prevent aggravation of the inflationary pressure.

### 2.3.7 Government Budget

In June 2008, the national budget for the fiscal year of 2009 has been compiled. The budget reflects the Medium Term Macroeconomic Framework (MTMF) of the government and incorporates the growth target of GDP at 6.5%; the inflation at 9%; the growth of exports at 16.5% and imports at 21%. The total expenditure budgeted for 2009 is Taka 1 trillion, which includes Annual Development Programme (ADP) of Taka 256 billion (16% of GDP) and recurrent expenditure of Taka 744 billion. The fund raising for the budget is planned to be from fiscal revenue of Taka 694 billion (11.1% of GDP), domestic borrowing of 2.7% and external borrowing of 2.2%. The fiscal budget for 2009 is outlined in the following table;

Table I-2-3-3 Outline of Budget for 2009

(Unit : Taka Billion)

|                               | Budget for FY<br>2009 (A) | FY 2008 Budget<br>Revised (B) | % Change<br>(A over B) | (A) in % of GDP |
|-------------------------------|---------------------------|-------------------------------|------------------------|-----------------|
| Total Revenue                 | 693.8                     | 605.4                         | 14.6                   | 11.1            |
| Tax Revenue                   | 567.9                     | 480.1                         | 18.3                   | 9.1             |
| Non-tax Revenue               | 125.9                     | 125.3                         | 0.5                    | 2.0             |
| Total Expenditure             | 999.6                     | 860.9                         | 16.1                   | 16.0            |
| Current Expenditure           | 619.5                     | 536.2                         | 15.5                   | 9.9             |
| ADP                           | 256.0                     | 225.0                         | 13.8                   | 4.1             |
| Other Development Expenditure | 124.1                     | 99.7                          | 24.5                   | 2.0             |
| Fiscal Deficit                | 305.8                     | 255.5                         | 19.7                   | 4.9             |
| Financing of Deficit          |                           |                               |                        |                 |
| External Resources (net)      | 135.8                     | 131.5                         | 3.3                    | 2.2             |
| Foreign Grant                 | 63.4                      | 43.9                          | 44.5                   | 1.0             |
| Foreign Loans                 | 72.4                      | 87.5                          | -17.4                  | 1.2             |
| Domestic Resources            | 170.0                     | 124.0                         | 37.1                   | 2.7             |
| Domestic Bank Borrowing       | 135.0                     | 104.0                         | 29.8                   | 2.2             |
| Domestic Non-bank Borrowing   | 35.0                      | 20.0                          | 74.8                   | 0.6             |

(source) ADB, "Bangladesh: Quarterly Economic Update", June 2008

## 2.4 Industrial Structure

Bangladesh has long been dependent on agriculture. However, the country's dependence on agriculture is gradually decreasing and a variety of new industries are burgeoning. The industrial structure is seen in the following table in which one can notice the manufacturing sector exceeding agriculture in its output.

Table I-2-4-1 Composition of GDP at Market Price

(Unit : Taka Billion)

| Fiscal Year                       | 1994-95 |      | 1999-00 |      | 2006-07 |      |
|-----------------------------------|---------|------|---------|------|---------|------|
|                                   | Amount  | (%)  | Amount  | (%)  | Amount  | (%)  |
| Agriculture & Forestry            | 310     | 20.3 | 447     | 18.9 | 678     | 14.5 |
| Fishing                           | 76      | 5.0  | 137     | 5.8  | 173     | 3.7  |
| Mining & Quarrying                | 15      | 1.0  | 23      | 1.0  | 53      | 1.1  |
| Manufacturing                     | 225     | 14.7 | 348     | 14.7 | 810     | 17.3 |
| Electricity, Gas & Water          | 23      | 1.5  | 31      | 1.3  | 58      | 1.2  |
| Construction                      | 97      | 6.4  | 176     | 7.4  | 368     | 7.9  |
| Wholesale & Retail Trade          | 189     | 12.4 | 292     | 12.3 | 657     | 14.1 |
| Hotel & restaurant                | 9       | 0.6  | 15      | 0.6  | 33      | 0.7  |
| Transport & Communication         | 135     | 8.9  | 197     | 8.3  | 484     | 10.3 |
| Financial Intermediations         | 22      | 1.5  | 36      | 1.5  | 74      | 1.6  |
| Real Estate & Business Activities | 131     | 8.6  | 211     | 8.9  | 349     | 7.5  |

| Fiscal Year                           | 1994-95 |       | 1999-00 |       | 2006-07 |       |
|---------------------------------------|---------|-------|---------|-------|---------|-------|
|                                       | Amount  | (%)   | Amount  | (%)   | Amount  | (%)   |
| Public Administration & Defense       | 37      | 2.4   | 62      | 2.6   | 127     | 2.7   |
| Education                             | 31      | 2.0   | 54      | 2.3   | 114     | 2.4   |
| Health & Social Works                 | 34      | 2.2   | 54      | 2.3   | 100     | 2.1   |
| Community, Social & Personal Services | 131     | 8.6   | 204     | 8.6   | 435     | 9.3   |
| Custom Excises & Duties               | 61      | 4.0   | 83      | 3.5   | 161     | 3.5   |
| Total                                 | 1,525   | 100.0 | 2,371   | 100.0 | 4,675   | 100.0 |

(source) Bangladesh Bank, "Monthly Economic Trends", April 2008

In 2007, the industry that appeared on top of the industry-wise GDP output list was manufacturing with its contribution of 17.3%, followed by agriculture of 14.5% and wholesale and retail trades of 14.1%. Agriculture used to lead the list by occupying the shares of 20.3% in 1995 and 18.9% in 2000, but has retreated since then. The manufacturing has taken over the leading position and occupies the share of 17.3% in 2007. The industries that have expanded their shares between 1995 and 2007 include; manufacturing by 2.6%; wholesale and retail trades by 1.7%; construction by 1.5%; and transportation and communication by 1.4%. The industries that have decreased their shares include; agriculture by 5.8% which is particularly noteworthy; fishing and shrimp by 1.3%; and real estate by 1.1%.

The prime feature of the manufacturing industry in Bangladesh is broadly defined as the one utilizing and processing the indigenous and/or imported materials. Typical examples of such are found in; readymade garments; cotton products; pharmaceuticals; fertilizers; wooden products; iron and steels; ceramics; cements; plastic products, chemicals; etc. There exist other industrial sectors such as; engineering; shipbuilding; oil refineries; paints; dyeing and tanning materials; electric wires; lighting apparatuses; florescent lamps; other electrical appliances; cigarettes; matches; etc. In addition, handicrafts sector includes; handlooms; carpets weaving; shoes; bamboos and canes; porcelain; brass products; decorations; etc. While manufacturing industry comprises 17% of GDP, the overwhelming majority is shared by the readymade garments in which Bangladesh stands at the 5th among the ranking of the exporting countries to EU and is counted among the top 10 apparel exporting countries to U.S.A.

As there is no existence of statistics in respect of the sector-wise value additions, we are finding it hard to check and confirm the ups and downs of different sectors of the manufacturing industry in such respect. Instead, we hereby resort to the statistics of exports as a proxy to the measure of the rises and falls of the sectors. The statistics of sectoral composition of exports are captured as in the following table;

Table I-2-4-2 Exports of Sectors

(Unit : Taka Billion)

| Fiscal Year            | 1994-95 |       | 1999-00 |       | 2006-07 |       |
|------------------------|---------|-------|---------|-------|---------|-------|
|                        | Amount  | (%)   | Amount  | (%)   | Amount  | (%)   |
| Jute                   | 2.6     | 2.0   | 3.7     | 1.5   | 9.8     | 1.2   |
| Jute Product           | 13.7    | 10.4  | 11.3    | 4.5   | 26.0    | 3.3   |
| Tea                    | 1.3     | 0.9   | 0.9     | 0.4   | 0.4     | 0.1   |
| Leather                | 8.8     | 6.7   | 7.6     | 3.0   | 22.9    | 2.9   |
| Fishing and Shrimp     | 13.2    | 10.0  | 18.1    | 7.3   | 37.0    | 4.7   |
| Readymade Garments     | 74.4    | 56.7  | 157.2   | 63.1  | 518.9   | 65.8  |
| Petroleum Products     | 0.5     | 0.4   | 0.6     | 0.2   | 3.3     | 0.4   |
| Fertilizer             | 3.1     | 2.4   | -       | 0.0   | 2.7     | 0.3   |
| Others (including EPZ) | 13.8    | 10.5  | 49.8    | 20.0  | 168.4   | 21.3  |
| Total                  | 131.3   | 100.0 | 249.2   | 100.0 | 789.2   | 100.0 |

(source) Bangladesh Bank, "Monthly Economic Trends", April 2008

The above table confirms that the overwhelming majority of exports are occupied by the readymade garments. The share of the sector that had been 56.7% in 1995 has kept increasing to 63.1% in 2000 and 65.8% in 2007. To the contrary of the readymade garments, the jute and jute products which has been counted as one of the traditional industries have nosedived from 12.4% in 2007 to 4.5% in 2007. Similar trends are observed for fish and shrimp which has seen its share halved from 10.0% to 4.7% during the same period and this is also true for leather industry. Meanwhile, the one classified under "others (including EPZ)" are doubling its share from 10.5% in 1995 to 21.3% in 2007 demonstrating the upsurge of new industries and the demise of the old ones.

## 2.5 Household Economy

Bangladesh Bureau of Statistics is conducting another periodical survey, Household Income and Expenditure Survey" once in every 5 years, the latest one of which has been done in 2005. The output of the survey is summarizing the size of households, income, expenditures, etc. as in the following table;

Table I-2-5-1 Household Income and Expenditure Survey

|                                       | 2000 Survey |       |       | 2005 Survey |          |        |          |        |          |  |
|---------------------------------------|-------------|-------|-------|-------------|----------|--------|----------|--------|----------|--|
|                                       | Urban       | Rural | Total | Urban       |          | Rural  |          | Total  |          |  |
|                                       |             |       |       | Actual      | % Change | Actual | % Change | Actual | % Change |  |
| Number of Samples                     | 2,400       | 5,040 | 7,440 | 3,680       |          | 6,400  |          | 10,080 |          |  |
| Population (million)                  | 25.3        | 100.8 | 126.1 | 34.3        | 35.6%    | 104.5  | 3.7%     | 138.8  | 10.1%    |  |
| No. of Households (million)           | 4.9         | 19.4  | 24.4  | 7.3         | 49.0%    | 21.4   | 10.3%    | 28.6   | 17.2%    |  |
| Average Household Size (person)       | 5.13        | 5.19  | 5.18  | 4.72        | -8.0%    | 4.89   | -5.8%    | 4.85   | -6.4%    |  |
| Average Earner per Household (person) | 1.54        | 1.43  | 1.45  | 1.50        |          | 1.37   |          | 1.40   |          |  |
| Income (Taka/month)                   |             |       |       |             |          |        |          |        |          |  |
| Income per Household                  | 9,878       | 4,816 | 5,842 | 10,463      | 5.9%     | 6,095  | 26.6%    | 7,203  | 23.3%    |  |
| Income per Capita                     | 1,926       | 928   | 1,128 | 2,217       | 15.1%    | 1,246  | 34.3%    | 1,485  | 31.6%    |  |
| Expenditure (Taka/month)              |             |       |       |             |          |        |          |        |          |  |
| Expenditure per Household             | 7,337       | 4,257 | 4,881 | 8,533       | 16.3%    | 5,319  | 24.9%    | 6,134  | 25.6%    |  |
| Consumption Expenditure per Household | 7,125       | 3,879 | 4,537 | 8,315       | 16.7%    | 5,165  | 33.2%    | 5,964  | 31.4%    |  |
| Food Expenditure per Household        | 3,175       | 2,300 | 2,477 | 3,756       | 18.3%    | 3,023  | 31.4%    | 3,175  | 28.2%    |  |
| Share of Food Expenditure on (%)      |             |       |       |             |          |        |          |        |          |  |
| Total Expenditure                     | 43.3        | 54.0  | 50.7  | 44.0        |          | 56.8   |          | 52.3   |          |  |
| Consumption Expenditure               | 44.6        | 59.3  | 54.6  | 45.2        |          | 58.5   |          | 53.8   |          |  |
| Calorie Intake (K. cal/capita/day)    | 2,150       | 2,263 | 2,240 | 2,194       | 2.0%     | 2,253  | -0.4%    | 2,239  | 2.1%     |  |
| Source of Drinking Water (%)          | 32.1        | 0.4   | 6.8   | 28.5        |          | 0.5    |          | 7.6    |          |  |
| Access to Electricity (%)             | 80.4        | 18.7  | 31.2  | 82.6        |          | 31.2   |          | 44.2   |          |  |

(source) Bangladesh Bureau of Statistics, "Household Income and Expenditure Survey 2005"

The above table lists those of the important data compiled during the Household Income and Expenditure Survey which indicates various facts concerning the household and living of Bangladesh population. The population data indicates the progress of urbanization by showing its increase in the urban areas by 36% between 2000 and 2005 whereas that in rural areas by 10%. The number of households is witnessed to be increasing at higher rate than the total population while the average size of the households has reduced from 5.18 in 2000 to 4.85 in 2005. The average earner per household became smaller but its extent of reduction is in line with the reduction of the average number of persons per household and deemed unchanged against the size of household.

The income per household has increased by 23%, being constituted by the increase of 6% in urban areas and 25% in rural areas. The increase in rural areas has outpaced the one in urban areas. The average monthly income per capita is recognized as Taka 1,485 (equivalent to US\$ 24), of which the urban is Taka 2,217 (US\$ 36) and the rural is Taka 1,246 (US\$ 20). The line of absolute poverty is defined by the United Nations as one dollar per capita per day which

is converted to Taka 1,860 per month by using the exchange rate then prevailing. The average income in the urban areas is exceeding the poverty line by about 20%, whereas that of rural areas is undermining the line by about 40% and so is the national total by about 20%. From such data, one can surmise that more than half of the population belongs to the absolute poverty level. The average expenditure per household is recognized as Taka 6,134 per month out of which the consumption expenditure occupies Taka 5,964 per month. The propensity to consume stands at 83% for the national total; 79% in the urban areas; and 85% in rural areas. The share of the food among the total consumption expenditure, Engel's co-efficient, is noticed to be as high as 54% for the national total; 45% in the urban areas; and 58% in rural areas. The low level of income and high Engel's co-efficient are co-habiting ubiquitously throughout the country.

Finally, the list provides the source of drinking water and the access to the electricity grid. The source of drinking water data appears noteworthy in such respect that the percentage taking water from the water supply systems in the urban areas has retreated from 32% in 2000 to 28% in 2005. This may be the reflection of the inability of the public infrastructure to keep up with the urbanization. To the contrary of drinking water, the electricity data indicates that 83% of the urban areas are connected to the grid whereas the rate of access to the grid in the rural areas grew from 19% in 2000 to 31%. The national average rate of access to the grid has increased from 31% in 2000 to 44% in 2005.

## 2.6 Inflation and Prices

In Bangladesh like other countries, there exist two kinds of price indices, the consumer price index (CPI) and wholesale price index (WPI). Those indices are captured and released by Bangladesh Bureau of Statistics. While CPI is followed month by month and is released in one or two months after the date of the statistics, WPI is officially followed annually and is released at later date of over one year. As WPI comes at such later date and is not of use for timely analysis, the inflation of the country is predominantly discussed by using CPI. The following table shows the CPI during past 10 years;

Table I-2-6-1 Inflation

| Fiscal Year   | 1999 | 2000 | 2001 | 2002 | 2003 | 2004 | 2005 | 2006 | 2007 | 2008  | Average |
|---|------|------|------|------|------|------|------|------|------|-------|---------|
| CPI: Average Annual Rate of Increase (%)            | 7.06 | 2.79 | 1.94 | 2.79 | 4.38 | 5.83 | 6.49 | 7.16 | 7.20 | 9.94  | 4.63    |
| CPI: Point to Point Increase at Year End (%)        |      |      | 1.66 | 3.58 | 5.03 | 5.64 | 7.35 | 7.54 | 9.20 | 10.04 |         |
| CPI (Food): Average Annual Increase (%)             | 9.30 | 2.68 | 1.39 | 1.63 | 3.46 | 6.92 | 7.91 | 7.76 | 8.11 | 12.28 | 6.14    |
| CPI (Food): Point to Point Increase at Year End (%) |      |      | 0.87 | 1.94 | 5.22 | 6.64 | 8.73 | 8.81 | 9.82 | 14.10 |         |

(source) Bangladesh Bureau of Statistics

The annual increase of CPI has hit the bottom at 1.9% in 2001 and has been on the continuous increase for 7 years since then. The indices were; 2.79% in 2002; 4.38% in 2003; jumped to 6.49% in 2005; and climbed high closer to 10% in 2008.

The average taken for the past 10 years stands at 4.63% which is far beyond the levels of the targets established at many of the developed countries but remains within a complacent level considering the stable growth rates of GDP. The average is the outcome of the low inflation recorded in 2000 – 2002 that has been offset by the high rates during later years. Curbing of inflation remains to be one of the important tasks of the government in its economic policy.

With respect to the basket comprising the CPI, the largest among the components is food which occupies 58.8% of total CPI. The inflation appears to be a lot severe in the food category. CPI (food) that used to be stagnant in 2001 and 2002 has moved to the higher layer in 2004 and it has eventually hit the annual average of 12.28% in 2008, or 14.10% in the point-to-point at the year end of 2008, due primarily to the increase of food prices in the international market. Some of the examples are found in rice whose price rose by 61% during the twelve months since April 2007 to April 2008. The price of wheat also rose 56% during the same period.

In order to curb the price hike of foods, the government took the measures of reducing the custom duties levied on food imports, increasing the imports of foods by the government sector, providing subsidies to the marketing of foods, etc. Financial institutions joined such move by softening the terms and conditions for financing the imports of foods aiming at contributing to mitigate the inflationary pressure in its eventuality<sup>16</sup>.

---

<sup>16</sup> ditto



## Chapter 3 Power Sector in Bangladesh

### 3.1 Brief of Power Sector in Bangladesh

#### (1) Power generation facilities

In fiscal year 2007 the total installed capacity was 5,202 MW, which comprised a thermal power capacity of 4,972 MW (95.6%), and a hydroelectric power capacity of 230 MW (4.4%). In terms of fuels, natural gas-fired power stations represent 81.3% of the total capacity. In terms of the installed capacity of different electric power utility companies, as of March 2004 the installed capacity of the BPDB (Bangladesh Power Development Board) was 3,429 MW while that of the IPPs (independent power producers) was 1,260 MW. However, the percentage of power generating facilities that were inoperable due to aging was high, between 30% and 40%.

Although natural gas is the central pillar of domestic energy production in Bangladesh, because the gas fields are unevenly distributed, located primarily in the east of the country, the fuels used and the types of generating facilities differ between the eastern and western regions. In the east, all thermal power stations use natural gas as fuel, but in the west the main fuel is oil.

Because there is a chronic supply shortage in Bangladesh, electric power utility companies cannot afford to stop power stations for inspection and maintenance, and because periodic inspections are also not being sufficiently performed, the generating capacity of most thermal power stations is substantially less than the rated power.

Table I-3-1-1 Power Generating Facilities using Fuel

| Fuel                | MW    | %     |
|---------------------|-------|-------|
| Natural Gas         | 4,228 | 81.28 |
| Heavy Oil           | 280   | 5.38  |
| Diesel              | 214   | 4.11  |
| Hydroelectric Power | 230   | 4.42  |
| Coal                | 250   | 4.81  |
| Total               | 5,202 | 100.0 |

(source) BPDB Annual Report 2006/2007

Table I-3-1-2 Power Generating Facilities using a Generation Method

| Fuel                | MW    | %     |
|---------------------|-------|-------|
| Hydroelectric Power | 230   | 4.42  |
| Steam Turbine       | 2,638 | 50.71 |
| Gas Turbine         | 1,106 | 21.26 |
| Combined Cycle      | 990   | 19.03 |
| Diesel              | 238   | 4.58  |
| Total               | 5,202 | 100.0 |

(source) BPDB Annual Report 2006/2007

#### (2) Power transmission facilities

In fiscal year 2006, transmission facilities comprised 230 kV lines and complementary 132 kV lines. The combined length of the lines was 3,796.5 km. The 230 kV bulk transmission lines all comprise of two transmission lines and form a loop together with the 132 kV lines in the area around the capital. The 230 kV systems link the main substations around the capital and interconnect the eastern and western regions.

Details of transmission facilities in Bangladesh are described in 4.4.1

(3) Power distribution facilities

As the high-voltage distribution lines, 33 kV and 11 kV lines are used, and 400V and 230V lines are used as the low-voltage distribution lines. Power is distributed by means of three-phase, four-wire systems and single-phase systems. The single-phase systems are primarily used in rural areas for the purpose of rural electrification. The combined length of the distribution lines is 47,646 km.

(4) Generated power and peak load

The generated power of the BPDB in Bangladesh and the rate of increase in generated power are shown in Table I-3-1-1 and Figures I-3-1-1 and I-3-1-2. Maximum demand and its rate of increase are shown in Table I-3-1-2 and Figure I-3-1-3.

The generated power increased by more than 10% over the decade of the 1980s, which corresponds to a period of rapid economic growth. Since then, generated power has continued to grow in response to economic growth.

The significant reduction in the rates of increase in generated power for 2006/2007 was due to serious gas supply shortage.

The average rate of increase in generated power over the past 27 years has been 8.95%.

The peak load has increased in the same way as generated power, with the exception of 1996, at an average rate of 7.1% for the past 20 years.

As the above shows, the demand for electrical power in Bangladesh is rising rapidly. Normally, this rise in demand would be accompanied by gas field development and increased gas production, but in recent years gas production has leveled off, making it impossible to increase power generation.

(5) Breakdown of generated power

The breakdown of generated power by fuel is shown in Table I-3-1-3 and Figure I-3-1-4. As the table clearly shows, thermal power generation is dominant and hydroelectric power generation is supplemental in Bangladesh, and thermal power stations are largely dependent on natural gas as fuel.

(6) Supply and demand conditions

As shown in Table I-3-1-5, the available power in Bangladesh is less than the estimated demand, making regular scheduled outages necessary.


Especially since 2005, the amount of scheduled outages has been increasing, due in large part to gas supply shortages.

Also, as noted above, because of the chronic power shortage in Bangladesh, power-generating facilities cannot be stopped, and thus appropriate maintenance cannot be performed. As a result, facilities are often happened trouble due to insufficient maintenance and many are unable to generate their rated power. Unoperable thermal power plants cause to be one of the chronic power shortage.

Table I-3-1-3 Generated Power (GWH)


| Year      | Gross Energy Generation of BPDB |           |           | Total Private Generation (Net) | Total Generation PDB (Gross)+IPP (Net) | % Increase over the Preceding Year | Energy Transfer through East-West Interconnector |              |
|-----------|---------------------------------|-----------|-----------|--------------------------------|--|------------------------------------|--|--------------|
|           | East Zone                       | West Zone | Total     |                                |  |                                    | East to West                                     | West to East |
| 1980-81   | 1,978.27                        | 683.54    | 2,661.81  | 0                              | 2,661.81                               | 11.31                              | 0  | 0            |
| 1981-82   | 2,292.02                        | 744.42    | 3,036.44  | 0                              | 3,036.44                               | 14.07                              | 0  | 0            |
| 1982-83   | 2,845.68                        | 586.99    | 3,432.67  | 0                              | 3,432.67                               | 13.05                              | 341.32   | 0.24         |
| 1983-84   | 3,398.19                        | 568.00    | 3,966.19  | 0                              | 3,966.19                               | 15.54                              | 519.04   | 1.44         |
| 1984-85   | 3,655.89                        | 872.55    | 4,528.44  | 0                              | 4,528.44                               | 14.18                              | 477.41   | 20.63        |
| 1985-86   | 3,487.90                        | 1,312.36  | 4,800.26  | 0                              | 4,800.26                               | 6.00                               | 222.40   | 106.43       |
| 1986-87   | 4,749.10                        | 837.85    | 5,586.95  | 0                              | 5,586.95                               | 16.39                              | 797.84   | 10.91        |
| 1987-88   | 5,752.54                        | 788.86    | 6,541.40  | 0                              | 6,541.40                               | 17.08                              | 1,179.54   | 0.02         |
| 1988-89   | 6,533.94                        | 580.91    | 7,114.85  | 0                              | 7,114.85                               | 8.77                               | 1,550.00   | 0            |
| 1989-90   | 7,400.98                        | 330.96    | 7,731.94  | 0                              | 7,731.94                               | 8.67                               | 1,956.78   | 0            |
| 1990-91   | 8,125.80                        | 144.40    | 8,270.20  | 0                              | 8,270.20                               | 6.96                               | 2,314.07   | 0            |
| 1991-92   | 8,499.90                        | 394.35    | 8,894.25  | 0                              | 8,894.25                               | 7.55                               | 2,213.00   | 0            |
| 1992-93   | 8,582.69                        | 623.75    | 9,206.44  | 0                              | 9,206.44                               | 3.51                               | 1,919.89   | 0            |
| 1993-94   | 9,129.04                        | 655.31    | 9,784.35  | 0                              | 9,784.35                               | 6.28                               | 1,980.76   | 0            |
| 1994-95   | 9,885.28                        | 921.15    | 10,806.43 | 0                              | 10,806.43                              | 10.45                              | 1,954.62   | 0            |
| 1995-96   | 10,734.62                       | 739.59    | 11,474.21 | 0                              | 11,474.21                              | 6.18                               | 2,215.02   | 0            |
| 1996-97   | 10,804.70                       | 1,052.89  | 11,857.59 | 0                              | 11,857.59                              | 3.34                               | 1,924.17   | 0            |
| 1997-98   | 11,789.06                       | 1,093.34  | 12,882.40 | 0                              | 12,882.40                              | 8.64                               | 1,997.00   | 0            |
| 1998-99   | 13,126.07                       | 746.13    | 13,872.20 | 578.22                         | 14,450.42                              | 12.17                              | 2,186.00   | 0            |
| 1999-00   | 13,634.19                       | 684.23    | 14,318.42 | 1,244.29                       | 15,562.71                              | 7.70                               | 2,482.45   | 0            |
| 2000-2001 | 13,717.26                       | 1,110.92  | 14,828.18 | 2,192.68                       | 17,020.86                              | 9.37                               | 1,979.40   | 0            |
| 2001-2002 | 13,266.78                       | 1,182.78  | 14,449.56 | 3,771.19                       | 18,220.75                              | 7.05                               | 2,249.16   | 0            |
| 2002-2003 | 11,370.99                       | 1,509.79  | 12,880.78 | 6,298.81                       | 19,179.59                              | 5.26                               | 2,170.40   | 0            |
| 2003-2004 | 11,302.91                       | 2,039.17  | 13,342.08 | 7,478.18                       | 20,820.26                              | 8.55                               | 2,135.55   | 0            |
| 2004-2005 | 11,909.63                       | 2,157.37  | 14,067.00 | 7,939.19                       | 22,006.19                              | 5.70                               | 2,146.20   | 0            |
| 2005-2006 | 13,177.27                       | 2,239.68  | 15,416.95 | 8,286.07                       | 23,703.02                              | 7.71                               | 2,344.72   | 0            |
| 2006-2007 | 12,963.82                       | 2,530.88  | 15,494.70 | 8,244.54                       | 23,739.24                              | 0.15                               | 1,950.25   | 0            |

(source) BPDB Annual Report 2006/2007



(source) BPDB Annual Report 2006/2007

Figure I-3-1-1 Generated Power of BPDB




(source) BPDB Annual Report 2006/2007

Figure I-3-1-2 Generated Power of BPDB and IPP

Table I-3-1-4 Maximum Power Demand

| Year      | Maximum Demand Served in MW |           |          | % Increase over the preceding year |
|-----------|-----------------------------|-----------|----------|------------------------------------|
|           | East Zone                   | West Zone | Total    |                                    |
| 1990-91   | 1,141.00                    | 499.00    | 1,640.00 |                                    |
| 1991-92   | 1,160.00                    | 512.00    | 1,672.00 | 1.951                              |
| 1992-93   | 1,293.30                    | 530.00    | 1,823.30 | 9.049                              |
| 1993-94   | 1,355.00                    | 520.00    | 1,875.00 | 2.836                              |
| 1994-95   | 1,472.00                    | 498.00    | 1,970.00 | 5.067                              |
| 1995-96   | 1,497.00                    | 590.40    | 2,087.40 | 5.959                              |
| 1996-97   | 1,594.30                    | 520.10    | 2,114.40 | 1.293                              |
| 1997-98   | 1,559.60                    | 576.50    | 2,136.10 | 1.026                              |
| 1998-99   | 1,828.00                    | 620.50    | 2,448.50 | 14.625                             |
| 1999-2000 | 1,878.00                    | 787.00    | 2,665.00 | 8.842                              |
| 2000-2001 | 2,175.00                    | 858.20    | 3,033.20 | 13.816                             |
| 2001-2002 | 2,447.00                    | 770.50    | 3,217.50 | 6.076                              |
| 2002-2003 | 2,511.50                    | 916.50    | 3,428.00 | 6.542                              |
| 2003-2004 | 2,646.00                    | 946.10    | 3,592.10 | 4.787                              |
| 2004-2005 | 2,749.50                    | 971.30    | 3,720.80 | 3.583                              |
| 2005-2006 | 2,809.00                    | 973.10    | 3,782.10 | 1.647                              |
| 2006-2007 | 2,725.00                    | 992.80    | 3,717.80 | -1.700                             |

(source) BPDB Annual Report 2006/2007



(source) BPDB Annual Report 2006/2007


Figure I-3-1-3 Maximum Power Demand

Table I-3-1-5 Generated Power by Fuel

Unit:GWh

| Year | Thermal Power |           |            |          | Hydraulic Power | Total     |
|------|---------------|-----------|------------|----------|-----------------|-----------|
|      | Natural Gas   | Heavy Oil | Deisel Oil | Coal     |                 |           |
| 2007 | 19,832.46     | 1,023.37  | 279.51     | 1,081.44 | 566.31          | 22,783.09 |

(source) BPDB Annual Report 2006/2007



(source) BPDB Annual Report 2006/2007

Figure I-3-1-4 Generated Power by Fuel

Table I-3-1-6 List of Power-Generating Facilities

| SL No. | Name of Power Plant                          | Type of fuel | Installed Capacity (As of June) (MW) | Gross Energy Generation (GWh) | Annual Plant factor (%) | Efficiency (%) (Net) | Overall Thermal Efficiency (%) (Net) |
|--------|--|--------------|--------------------------------------|-------------------------------|-------------------------|----------------------|--------------------------------------|
| 1      | Karnafuli Hydro (2x40 MW-3x50 MW)            | Hydro        | 230                                  | 569.06                        | 28.24                   |                      | 32.34                                |
| 2      | Chittagong Thermal Power Plant Unit 1        | Gas          | 210                                  | 997.21                        | 54.21                   | 28.66                |                                      |
|        | Chittagong Thermal Power Plant Unit 2        | Gas          | 210                                  | 1,026.28                      | 55.79                   | 31.30                |                                      |
| 3      | Sikalbana 60MW Steam Turbine                 | Gas          | 60                                   | 122.67                        | 23.34                   | 24.42                |                                      |
|        | Sikalbana 2x28 MW Barge Mounting GT          | Gas          | 28                                   | 8.52                          | 3.47                    | 20.82                |                                      |
| 4      | Ashuganji 2x64 MW Steam Turbine              | Gas          | 128                                  | 899.30                        | 80.20                   | 30.27                |                                      |
|        | Ashuganji 3x150 MW Steam Turbine             | Gas          | 450                                  | 2,012.01                      | 51.04                   | 31.92                |                                      |
|        | Ashuganji GT 1                               | Gas          | 56                                   | 238.0                         | 48.52                   | 19.00                |                                      |
|        | Ashuganji ST                                 | Gas          | 34                                   | 80.76                         | 36.55                   | 25.86                |                                      |
|        | Ashuganji GT 2"                              | Gas          | 56                                   | 207.39                        | 42.28                   | 19.01                |                                      |
| 5      | Ghorasal 2x55 MW Steam Turbine (1+2nd Unit)  | Gas          | 110                                  | 185.45                        | 19.25                   | 21.60                |                                      |
|        | Ghorasal 3x150MW Steam Turbine (3+4th Unit)  | Gas          | 420                                  | 1,894.61                      | 51.50                   | 31.11                |                                      |
|        | Ghorasal 2x210MW S/T (5+6th Unit)            | Gas          | 420                                  | 2,490.36                      | 67.69                   | 32.88                |                                      |
| 6      | Siddhirganj 50 MW Steam Turbine**            | Gas          | 0                                    | 169.51                        | 38.70                   | 26.61                |                                      |
|        | Siddhirganj 210 MW Steam Turbine             | Gas          | 210                                  | 1,074.70                      | 58.43                   | 33.96                |                                      |
| 7      | Haripur 3x33 MW Gas Turbine                  | Gas          | 99                                   | 29.24                         | 38.70                   | 26.61                |                                      |
|        | Tongi 100 MW Gas Turbine                     | Gas          | 109                                  | 181.58                        | 58.43                   | 33.96                |                                      |
| 8      | Shahjibazar Gas Turbine (7 units)            | Gas          | 57                                   | 81.43                         | 16.31                   | 15.04                |                                      |
|        | Shahjibazar 60 MW Gas Turbine                | Gas          | 70                                   | 25.61                         | 4.18                    | 21.71                |                                      |
| 9      | Sylhet 1x20 MW Gas Turbine                   | Gas          | 20                                   | 139.00                        | 79.30                   | 24.64                |                                      |
| 10     | Fenchuganji C.C.                             | Gas          | 90                                   | 529.06                        | 67.11                   | 35.73                |                                      |
| 11     | Khulna 1x110 MW Steam Turbine                | F. oil       | 110                                  | 301.55                        | 31.29                   | 22.24                |                                      |
|        | Khulna 1x60 MW Steam Turbine                 | F. oil       | 60                                   | 4.69                          | 0.89                    | 23.57                |                                      |
|        | Khulna 2x28 MW BMPP                          | SKD          | 56                                   | 43.95                         | 8.96                    | 22.75                |                                      |
| 12     | Barisal 2x20 MW Gas Turbine                  | HSD          | 40                                   | 57.99                         | 16.55                   | 15.04                |                                      |
|        | Barisal Diesel (9 units)                     | HSD          | 7                                    | 3.73                          | 6.08                    | 21.72                |                                      |
| 13     | Bhola Diesel                                 | HSD          | 3                                    | 2.56                          | 24.79                   | 25.94                |                                      |
|        | Bhola Old                                    | FO           |                                      | 3.96                          |                         |                      |                                      |
|        | Bhola New                                    | HSD          | 2                                    | 0.26                          | 1.63                    | 19.18                |                                      |
|        |  | HSD          | 2                                    | 1.55                          | 8.83                    | 18.62                |                                      |
| 14     | Bheramara 3x20 MW Gas Turbine                | HSD          | 60                                   | 106.77                        | 20.31                   | 24.2                 |                                      |
| 15     | Baghabari 71 MW Gas Turbine                  | Gas          | 71                                   | 0                             | 0                       | 0                    |                                      |
|        | Baghabari 100 MW Gas Turbine                 | Gas          | 100                                  | 738.94                        | 84.35                   | 29.30                |                                      |
| 16     | Ranppur 20 MW Gas Turbine                    | HSD          | 20                                   | 25.47                         | 14.54                   | 21.79                |                                      |
| 17     | Saidpur 20 MW Gas Turbine                    | HSD          | 20                                   | 35.73                         | 20.39                   | 22.29                |                                      |
| 18     | Barapuluria 2x125 MW ST (COAL)               | COAL         | 250                                  | 1,201.26                      | 54.85                   | 29.89                |                                      |
| 19     | Thakurgaon 3x1.5 MW Diesel                   | LDO          | 5                                    | 1.69                          | 4.28                    | 27.28                |                                      |
|        | Total (Grid)                                 |              | <b>3872</b>                          | <b>15,491.94</b>              | <b>45.67</b>            |                      |                                      |
| 20     | Isolated East                                | HSD          |                                      | 1.97                          |                         |                      |                                      |
|        | Isolated West                                | HSD          |                                      | 0.79                          |                         |                      |                                      |
|        | <b>Total BPDB</b>                            |              | <b>3872</b>                          | <b>15,494.70</b>              | <b>45.68</b>            |                      |                                      |
| 1      | KPCL (Khulna BMPP)                           | FO           | 110                                  | 746.58                        |                         |                      |                                      |
| 2      | WEST MONT (Baghabari, BMPP)                  | Gas          | 90                                   | 491.9                         |                         |                      |                                      |
| 3      | NEPC (Haripur, BMPP)                         | Gas          | 110                                  | 655.56                        |                         |                      |                                      |
| 4      | RPC (Mymensingh)                             | Gas          | 210                                  | 930.92                        |                         |                      |                                      |
| 5      | AES Haripur                                  | Gas          | 360                                  | 2,538.47                      |                         |                      |                                      |
| 6      | AES Meghnaghat                               | Gas          | 450                                  | 2,883.10                      |                         |                      |                                      |
|        | <b>Total Private (Net Generation)</b>        |              | <b>1330</b>                          | <b>8,244.54</b>               |                         |                      |                                      |
|        | BPDB Net Generation                          |              |                                      | 14,538.55                     |                         |                      |                                      |
|        | IPP Net Generation                           |              |                                      | 8,244.54                      |                         |                      |                                      |
|        | <b>Total Net Generation (BPDB+IPP)</b>       |              |                                      | <b>22,783.09</b>              |                         |                      |                                      |
|        | <b>Total Generation (BPDB Gross+IPP Net)</b> |              |                                      | <b>23,739.24</b>              |                         |                      |                                      |

\*\*Siddhirganj 50 MW has been dismantled in June '2007. So its installed capacity is shown 0 MW.

(source) BPDB Annual Report 2006/2007

Table I-3-1-7 Facility Capacities, Available Power, Demand Estimates, and Scheduled Outages


| Year      | Installed Capacity (MW)<1 | Generation capability (MW)<2 | Demand Forecast (MW)<3 | Demand served (MW)<4 | Load Shedding (MW)<5 |
|-----------|---------------------------|------------------------------|------------------------|----------------------|----------------------|
| 1990-91   | 2,350.00                  | 1,719.00                     | -                      | 1,640.00             | 340-15               |
| 1991-92   | 2,398.00                  | 1,724.00                     | -                      | 1,672.00             | 550-25               |
| 1992-93   | 2,608.00                  | 1,918.00                     | -                      | 1,823.00             | 480-20               |
| 1993-94   | 2,608.00                  | 1,881.00                     | -                      | 1,875.00             | 540-23               |
| 1994-95   | 2,908.00                  | 2,133.00                     | 2,038.00               | 1,970.00             | 537-10               |
| 1995-96   | 2,908.00                  | 2,105.00                     | 2,220.00               | 2,087.00             | 545-10               |
| 1996-97   | 2,908.00                  | 2,148.00                     | 2,419.00               | 2,114.00             | 674-20               |
| 1997-98   | 3,091.00                  | 2,320.00                     | 2,638.00               | 2,136.00             | 711-32               |
| 1998-99   | 3,603.00                  | 2,850.00                     | 2,881.00               | 2,449.00             | 774-16               |
| 1999-2000 | 3,711.00                  | 2,665.00                     | 3,149.00               | 2,665.00             | 536-10               |
| 2000-2001 | 4,005.00                  | 3,033.00                     | 3,394.00               | 3,033.00             | 663-15               |
| 2001-2002 | 4,230.00                  | 3,217.50                     | 3,659.00               | 3,217.50             | 367-5                |
| 2002-2003 | 4,680.00                  | 3,428.00                     | 3,947.00               | 3,428.00             | 468-5                |
| 2003-2004 | 4,680.00                  | 3,592.10                     | 4,259.00               | 3,592.10             | 694-2                |
| 2004-2005 | 4,995.00                  | 3,720.80                     | 4,597.00               | 3,720.80             | 770-7                |
| 2005-2006 | 5,245.00                  | 3,782.10                     | 4,693.00               | 3,782.10             | 1312-15              |
| 2006-2007 | 5,202.00                  | 3,717.80                     | 5,112.00               | 3,717.80             | 1345-40              |

**Note :**

- <1 Installed capacity as of June of the year
- <2 Generation capability is the Maximum available generation capacity after maintenance outage in the year
- <3 Demand forecast is the Base Forecast of PSMP 2005
- <4 The dates of maximum demand served and maximum available generation capacity may not be the same.
- <5 Load shedding is the range of maximum and minimum throughout the year


(source) BPDB Annual Report 2006/2007






(source) BPDB Annual Report 2006/2007

Figure I-3-1-5 Facility Capacities, Available Power, Demand Estimates, and Scheduled Outages



(source) BPDB Annual Report 2006/2007

Figure I-3-1-6 Daily Power Consumption Patterns



(source) BPDB Annual Report 2006/2007

Figure I-3-1-7 Locations of Existing Power Stations

### 3.2 Organization of Power Sector in Bangladesh

The long-term vision of the government of Bangladesh is to supply electricity to all citizens by 2020. The government has announced a reform of the power sector so as to achieve a reliable, high quality supply of power at appropriate charges. The BPDB is acting in line with this government strategy.

#### (1) Company form

In Bangladesh, the Ministry of Power, Energy, and Mineral Resources (MoPEMR) manages the power industry. Under the management of MoPEMR, power is generated by the Bangladesh Power Development Board (BPDB), independent power producers (IPP) that were created as spin-offs or subsidiaries of the BPDB, and investor-owned utilities. Power is supplied to consumers via BPDB transmission facilities by the BPDB for provincial cities, by the Dhaka Electricity Supply Authority (DESA) and the Dhaka Electricity Supply Company (DESCO) in Dhaka, and by rural electrification cooperatives called Palli Bidyut Samities (PBS) in rural areas. Figure I-3-2-1 shows the organization of the power sector in Bangladesh.

#### 1) Ministry of Power, Energy, and Mineral Resources (MoPEMR) and Power Cell (PC)

The MoPEMR is responsible for controlling the formulation of plans for electricity providers and making investment decisions. Power Cell was established in 1995 within the Power Division of the MoPEMR for the purpose of carrying forward of the power sector reform activities of the Government of Bangladesh. The primary objectives of the reform program are stated as; to develop an implementation plan of reform program; to implement programs to achieve performance improvements, customer satisfaction; to help facilitate the development of the sector with optimum utilization of resources; to develop strategy for corporatization of different entities; to structure financial and business plan of the entities; to develop the strategy for distribution area demarcation and rationalization of utilities; to develop the human resource development plan; to develop the power sector master plan; etc<sup>1</sup>.

#### 2) Bangladesh Power Development Board (BPDB)

The BPDB was established in 1972, the year after Bangladesh gained independence, and is engaged in the development of power supplies, the formulation and implementation of generating plans, managing the power from the IPPs, and generating, transmitting, and supplying power. In addition to using its own transmission and distribution equipment to supply power to divisional cities, it sells electricity wholesale to the Dhaka Electricity Supply Authority (DESA), which transmits and distributes power in the region of the capital, and the Rural Electrification Board (REB), which is responsible for rural electrification. BPDB handles about 40% of the wholesale electric power supply in the country. The number of power consumers is about 1.6 million.

#### 3) Power Grid Company of Bangladesh (PGCB)

In 1996 the power transmission division of the BPDB was spun off and the PGCB was established under the 1994 Company's Act as the organization for planning and operating the national grid system. The PGCB is (owned 75%) subsidiary of the BPDB. The transfer

---

<sup>1</sup> The website of Power Cell, "About Us"

of authority over all the transmission system facilities from the BPDB and the DESA was completed by December 2002.

4) Dhaka Electricity Supply Authority (DESA)

The DESA was established in 1990 to separate the transmission and distribution of the capital region (districts) from the BPDB. The DESA purchases power from the BPDB via 132 kV transmission lines for retail supply to its consumers and wholesale supply to the REB. The number of consumers is roughly 600,000.

As per Government decision, Dhaka Power Distribution Company (DPDC) has taken over DESA activities from 1<sup>st</sup> July 2008.

5) Dhaka Electric Supply Company Ltd. (DESCO)

The Dhaka Electric Supply Company Ltd. (DESCO) was established under the Company's Act in 1996 as a private power distribution company by the government of Bangladesh, with assistance from the Asian Development Bank, in an effort to improve the efficiency of the power distribution business that had previously been a state-run monopoly. In particular, DESCO aims to resolve the problems of uncollected charges and stealing electricity. In addition to power distribution in the Mirpur area, DESCO took over the power distribution for the Gulshan area from DESA on April 10, 2003. Furthermore, DESCO executes distribution business in Ultra Tongi area. The number of consumers is about 347,000. The performance of DESCO is better than that of DESA in terms of its systems and electricity charge collection.

6) Rural Electrification Board (REB) and Palli Bidyut Samities (PBS)


Since its establishment in 1977, the REB has been engaged in constructing substation and distribution facilities to allow the provision of electrical power from the existing transmission system to the regions away from the capital. In addition, in regions where there is no transmission system in place, the REB is pursuing rural electrification by setting up small-scale generation and transmission facilities using power sources such as diesel fuel and solar power. In April 1998, the Small Power Generation Policy was enacted to promote rural electrification by setting up power stations of 10 MW or less in rural areas.

The completed power facilities are transferred to the rural electrification cooperatives (PBS) in the various regions, which manage the facilities. From the outset, the rural electrification of Bangladesh has been supported by the United States Agency for International Development (USAID). The PBSs were established on the model of the American rural electrification cooperatives, and in organization and operation they are a form of direct democracy in which the residents, who are the beneficiaries, can participate. As of 2003, the REB had established PBSs in seventy (70) locations, which supply power to approximately 3 million households. The performance of the REB/PBSs (distribution loss rate: about 15% and electricity charge collection rate: about 95%) compares favorably with that of the BPDB (distribution loss rate: about 30%, electricity charge collection rate: about 80%) and the DESA (distribution loss rate: about 25%, electricity charge collection rate: about 60%).

The REB purchases power from the BPDB and the DESA via 33 kV transmission lines, which comprises 24% of power supplied on a retail basis. The number of consumers is about 4.529 million.

7) Bangladesh Energy Regulatory Commission (BERC)

BERC was established in 2003 by the virtue of Act No. 13 of 2003<sup>2</sup>. The objectives of the organization are specified by the law as; to create an atmosphere conducive to private investment in the generation and transmission in power sector, transportation and marketing of gas resources and petroleum products; to ensure transparency in the management, operation and tariff determination in these sectors; to protect consumers' interest and promote the creation of a competitive market. The law also specifies the functions and power of BERC as; to enhance the efficiency of the use of energy; to ensure efficient use, quality service, determine tariff of electricity for generation, transmission; to issue, cancel and determine conditions of licences; to approve schemes on the basis of overall program of licencees; to collect the statistics of energy; to resolve disputes; etc. The law specifically states the relationship between the Government and BERC in its Chapter 5 wherein it is specified that the government shall have the power of giving policy directives for the development and overall planning of the energy sector and shall issue any policy directive in consultation with BERC. The tariff setting policy of BERC is discribed in the item 3.4.3 Tarrif Policy of Energy Regulatory Commission.



Remark: —> Flow of Electricity ⇌ Capital  
 (source) Japan Electric Power Information Center, Inc.

Figure I-3-2-1 Electrical Power Sector in Bangladesh

(2) Reforms in the power sector and the current organization

The Ministry of Power, Energy, and Mineral Resources (MoPEMR) embarked in 1994 on a reform of the power sector that is ongoing and includes the participation of IPPs and the break-up and privatization of the BPDB. In 1994, the Power Sector Development & Reform

<sup>2</sup> Bangladesh Gazette, S.R.O. No. 228/Law/2003, Act No. 13 of 2003 to make Provisions for the Establishment of an Independent and Impartial Regulatory Commission for the Energy Sector

Program was implemented, and in 1996 the Power Sector Power Generation Policy was enacted to open up the power generation sector to private interests. In 2000, a Vision Statement/Policy Statement announced the goal of supplying inexpensive and reliable electrical power to all citizens by 2020 and set the direction for power sector reforms. In 2003, the Energy Regulatory Commission Act was enacted in preparation for the establishment of an independent and fair Energy Regulatory Commission (ERC) for the energy sector.

Regarding the power generation division of the BPDB, the Haripur power station became a division based on the Vision Statement/Policy Statement of January 2001. The Ashganj power station became a spin off. With the Energy Regulatory Commission Act of May 2003, the Baghabari power station became a division.

Similarly, in the distribution division of the BPDB, the West Zone Power Distribution Co. Ltd. (WZPDCL), which distributes power to the Khulna and Barisal divisions, was spun off from the Energy Regulatory Commission Act.

### **3.3 Financial Standing of Bangladesh Power Development Board**

Bangladesh Power Development Board (BPDB) is the nodal institution in the power sector under the jurisdiction of the Ministry of Power, Energy and Mineral Resources (MoPEMR) assigned with the functional responsibilities of generation, transmission and distribution of electricity. The Government of Bangladesh and MoPEMR has been vigorously pursuing the structural and institutional reform of the power sector which envisages the unbundling and corporatizing the power entities functioning under its jurisdiction aiming at the ultimate target of fully commercialized and self sufficient entities. The financial statements of BPDB since 2000 till 2006 are summarized and shown below, based on which we will review and delve into the issues and constraints BPDB is faced in its financial performance.

Table I-3-3-1 Financial statements of BPDB since 2000 till 2006


|  | 2000-01        | 2001-02        | 2002/03        | 2003-04        | 2004-05        | 2005-06        | 2006-07        |
|--|----------------|----------------|----------------|----------------|----------------|----------------|----------------|
| (in Taka Million)                                  |                |                |                |                |                |                |                |
| <b>INCOME STATEMENT</b>                            |                |                |                |                |                |                |                |
| <b>Operating Revenue</b>                           |                |                |                |                |                |                |                |
| Energy Sales                                       | 31,483         | 35,248         | 40,040         | 43,432         | 43,581         | 45,859         | 47,986         |
| Other Operating Income                             | 753            | 762            | 2,804          | 1,194          | 1,124          | 710            | 1,598          |
| <b>Total Operating Revenue</b>                     | <b>32,235</b>  | <b>36,010</b>  | <b>42,843</b>  | <b>44,626</b>  | <b>44,705</b>  | <b>46,568</b>  | <b>49,583</b>  |
| <b>Operating Expenses</b>                          |                |                |                |                |                |                |                |
| Generation Expenses                                | 18,034         | 17,451         | 17,652         | 15,939         | 18,568         | 21,362         | 24,400         |
| Electricity Purchase from IPP                      | 7,882          | 10,865         | 13,338         | 20,233         | 22,490         | 25,382         | 25,166         |
| Transmission Expense                               | 1,742          | 2,056          | 2,336          | 1,243          | 1,369          | 1,162          | 1,216          |
| Distribution Expense                               | 3,694          | 3,919          | 3,887          | 4,392          | 4,380          | 4,495          | 4,351          |
| Customer Accounts Expenses                         | 375            | 374            | 406            | 425            | 448            | 299            | 270            |
| General & Administrative Expenses                  | 375            | 463            | 468            | 531            | 484            | 817            | 964            |
| <b>Total Operating Expenses</b>                    | <b>32,103</b>  | <b>35,128</b>  | <b>38,086</b>  | <b>42,765</b>  | <b>47,738</b>  | <b>53,517</b>  | <b>56,366</b>  |
| <b>Operating Income</b>                            | <b>132</b>     | <b>882</b>     | <b>4,757</b>   | <b>1,861</b>   | <b>-3,033</b>  | <b>-6,948</b>  | <b>-6,783</b>  |
| Provision for Assets Insurance Fund (PAIF)         | 15             | 15             | 15             | 15             | 15             | 15             | 15             |
| Financing & Other Charges                          | 2,891          | 2,555          | 2,205          | 1,562          | 1,728          | 1,355          | 2,150          |
| Net Loss before Charging Exchange Rate Fluctuation | -2,773         | -1,688         | 2,537          | 285            | -4,777         | -8,319         | -8,948         |
| Loss due to Exchange Rate Fluctuation              | -976           | -2,063         | 872            | -1,418         | -1,309         | -1,062         | -93            |
| <b>(Net Loss) for the Year</b>                     | <b>-858</b>    | <b>-3,751</b>  | <b>1,664</b>   | <b>-1,133</b>  | <b>-6,086</b>  | <b>-9,381</b>  | <b>-9,040</b>  |
| <b>Retained Earnings</b>                           |                |                |                |                |                |                |                |
| Balance Brought Forward from Previou Year          | -36,596        | -41,669        | -44,982        | -45,688        | -47,094        | -53,577        | -63,234        |
| Previous Year's Adjustment                         | -1,324         | 438            | -2,370         | -273           | -397           | -277           | 11,558         |
| Net Income/(Loss) for the Year                     | -3,749         | -3,751         | 1,664          | -1,133         | -6,086         | -9,381         | -9,041         |
| Balance Carried Forward to Succeeding Year         | -41,669        | -44,982        | -45,688        | -47,094        | -53,577        | -63,234        | -83,833        |
| <b>BALANCE SHEET</b>                               |                |                |                |                |                |                |                |
| <b>Fixed Assets</b>                                |                |                |                |                |                |                |                |
| Utility Plants in Service                          | 230,840        | 230,268        | 170,848        | 177,308        | 172,956        | 200,570        | 293,023        |
| Less Accumulated Depreciation                      | 114,096        | 121,277        | 94,428         | 99,213         | 101,392        | 106,547        | 124,702        |
| <b>Written Down Value</b>                          | <b>116,744</b> | <b>108,991</b> | <b>76,421</b>  | <b>78,095</b>  | <b>71,564</b>  | <b>94,023</b>  | <b>168,321</b> |
| Project in Progress                                | 21,777         | 27,355         | 28,830         | 36,653         | 48,365         | 39,450         | 18,367         |
| <b>Total Fixed Assets</b>                          | <b>138,521</b> | <b>136,345</b> | <b>105,251</b> | <b>114,748</b> | <b>119,930</b> | <b>133,473</b> | <b>186,688</b> |
| <b>Investment</b>                                  |                |                |                |                |                |                |                |
| Investment   | 2,276          | 2,683          | 5,430          |                |                |                | 14,502         |
| Investment Share from PGCB                         | 2,071          | 3,343          | 3,816          |                |                |                |                |
| <b>Total Investments</b>                           | <b>4,347</b>   | <b>6,026</b>   | <b>6,617</b>   | <b>15,643</b>  | <b>15,216</b>  | <b>15,366</b>  | <b>14,502</b>  |
| <b>Current Assets</b>                              |                |                |                |                |                |                |                |
| Cash in Hand & at Bank                             | 12,286         | 10,809         | 7,360          | 9,989          | 14,821         | 14,023         | 16,567         |
| Accounts Receivable - Trade                        | 32,657         | 40,780         | 44,639         | 47,469         | 50,198         | 51,232         | 45,714         |
| Accounts Receivable - others                       | 3,586          | 2,829          | 3,215          | 4,643          | 4,535          | 5,140          | 5,728          |
| Receivable to REB                                  |                | 2,077          | 3,723          | 1,645          | 1,645          | 1,645          | 1,645          |
| Provision for Bad & Doubtful Debts                 | -639           | -680           | -703           | -725           | -795           | -823           | -532           |
| Advance to Contractors & Suppliers                 | 3,133          | 1,592          | 436            | 799            | 780            | 953            | 1,036          |
| Advance to Employees                               | 613            | 771            | 985            | 1,094          | 1,136          | 1,132          | 1,133          |
| Stock & Stores                                     | 6,738          | 7,067          | 7,303          | 7,748          | 7,331          | 7,338          | 7,977          |
| Deposits & Prepaid Expenses                        | 1,205          | 1,232          | 138            | 131            | 84             | 110            | 225            |
| <b>Total Current Assets</b>                        | <b>59,579</b>  | <b>66,476</b>  | <b>67,096</b>  | <b>72,794</b>  | <b>79,735</b>  | <b>80,751</b>  | <b>79,495</b>  |
| <b>Total Property &amp; Assets</b>                 | <b>202,446</b> | <b>208,849</b> | <b>188,210</b> | <b>203,185</b> | <b>214,881</b> | <b>229,590</b> | <b>280,685</b> |
| <b>Capital &amp; Liabilities</b>                   |                |                |                |                |                |                |                |
| <b>Capital &amp; Reserve</b>                       |                |                |                |                |                |                |                |
| Paid up Capital                                    | 60,833         | 64,077         | 67,992         | 73,526         | 78,156         | 84,647         | 89,323         |
| Net Surplus/(Deficit)                              | -41,669        | -44,982        | -45,688        | -47,094        | -53,577        | -63,234        | -83,833        |
| Appraisal Surplus                                  | 55,748         | 55,748         | 55,748         | 55,748         | 55,748         | 55,748         | 117,058        |
| Grants   | 3,966          | 3,980          | 4,015          | 4,050          | 4,120          | 4,221          | 4,548          |
| Deposit Work Fund                                  | 734            | 796            | 829            | 871            | 934            | 992            | 1,102          |
| Liquidity Damage Reserve                           | 116            | 116            | 72             | 72             | 72             | 72             | 72             |
| <b>Total Capital &amp; Reserve</b>                 | <b>79,729</b>  | <b>79,735</b>  | <b>82,969</b>  | <b>87,174</b>  | <b>85,455</b>  | <b>82,447</b>  | <b>128,270</b> |
| <b>Long Term Liabilities</b>                       |                |                |                |                |                |                |                |
| Government Loan                                    | 15,594         | 16,382         | 16,981         | 20,503         | 23,569         | 27,842         | 33,322         |
| Foreign Loan                                       | 37,317         | 32,196         | 19,721         | 21,159         | 21,902         | 26,914         | 23,589         |
| <b>Total Long Term Liabilities</b>                 | <b>52,911</b>  | <b>48,578</b>  | <b>36,702</b>  | <b>41,662</b>  | <b>45,471</b>  | <b>54,756</b>  | <b>56,911</b>  |
| <b>Medium Term Liabilities</b>                     |                |                |                |                |                |                |                |
| Security Deposit (Consumers)                       | 1,463          | 1,600          | 1,729          | 1,869          | 2,022          | 2,172          | 2,325          |

|  | (in Taka Million) |         |         |         |         |         |           |
|--|-------------------|---------|---------|---------|---------|---------|-----------|
|  | 2000-01           | 2001-02 | 2002/03 | 2003-04 | 2004-05 | 2005-06 | 2006-07   |
| <b>CASH FLOW STATEMENT</b>   |                   |         |         |         |         |         |           |
| <b>Cash Flow from Operating Activities</b>   |                   |         | 2,212   | 2,727   | 1,085   | -4,317  | -811      |
| Total Receipts   |                   |         | 38,621  | 42,467  | 41,782  | 44,957  | 54,222    |
| Total Payment for Operating Expenses   |                   |         | -35,161 | -38,052 | -39,879 | -47,768 | 52,572    |
| Debt Service Liabilities-Interest Payment  |                   |         | -1,248  | -1,688  | -818    | -1,506  | 2,454     |
| <b>Cash Flow from Investing Activities</b>   |                   |         |         |         |         |         |           |
| Net Cash Flow from Investing Activities  |                   |         | -10,043 | -8,175  | -9,241  | -16,230 | -8,238    |
| <b>Cash Flow from Financing Activities</b>   |                   |         |         |         |         |         |           |
| Net Cash Flow from Financing Activities  |                   |         | 4,382   | 8,076   | 12,988  | 19,750  | 11,593    |
| <b>Net Cash Flow</b>   |                   |         | -3,449  | 2,629   | 4,832   | -798    | -2,544    |
| <b>KEY INDICATORS</b>  |                   |         |         |         |         |         |           |
| <b>Total Volume of Sales (GWh)</b>   | 14,003            | 15,243  | 16,332  | 18,023  | 19,196  | 20,954  | 21,181    |
| <b>System Loss</b>   |                   |         |         |         |         |         |           |
| T&D Loss (% of Generation)   | 13.85%            | 12.62%  | 11.35%  | 10.16%  | 9.29%   | 7.86%   | 7.03%     |
| Distribution Loss (% of Import)  |                   |         |         |         |         |         |           |
| Including REB  | 18.77%            | 17.20%  | 14.81%  | 10.90%  | 9.41%   | 8.21%   | 7.20%     |
| Excluding REB  | 26.11%            | 24.50%  | 22.35%  | 21.33%  | 20.00%  | 19.06%  | 16.58%    |
| T&D Loss (net for whole system in % of generation)                                     | 30.02%            | 27.65%  | 24.48%  | 19.95%  | 17.83%  | 15.42%  | 13.72%    |
| <b>Unit Supply Cost (Tk/kWh)</b>   | 2.50              | 2.47    | 2.47    | 2.54    | 2.62    | 2.70    | 2.77      |
| <b>Average Billing Rate (Tk/kWh)</b>   | 2.25              | 2.31    | 2.45    | 2.41    | 2.27    | 2.19    | 2.26      |
| <b>Total Number of Employees</b>   |                   | 28,027  | 25,691  | 21,272  | 21,230  | 21,254  | 20,494    |
| <b>Personnel Expenses</b>  | 2,322             | 2,479   | 2,528   | 2,971   | 2,374   | 2,766   | 3,263     |
| <b>Depreciation</b>  | 6,933             | 7,181   | 6,618   | 4,785   | 4,901   | 5,156   | 6,677     |
| <b>Net Cash Flow from Operating Activities</b>   | 4,751             | 6,423   | 2,212   | 2,727   | 1,084   | -4,317  | -811      |
| <b>Debt Service</b>  |                   |         |         |         |         |         |           |
| <b>Payment of Interest</b>   | 2,891             | 2,555   | 2,205   | 1,562   | 1,728   | 1,355   | 2,150     |
| <b>Repayment of Loan</b>   |                   |         |         |         |         |         |           |
| Foreign Loan   | 4,854             | 8,243   | 1,781   | 1,988   | 1,921   | 3,290   | 4,540     |
| Government Loan  | 629               | 778     | 750     | 1,100   | 900     | 300     | 409       |
| <b>Total Repayment</b>   | 5,483             | 9,021   | 2,531   | 3,088   | 2,821   | 3,590   | 4,949     |
| <b>Capital Expenditure</b>   |                   |         |         |         |         |         |           |
| <b>UPIS</b>  |                   |         | 625     | 757     | 663     | 964     | 655       |
| <b>PIP</b>   |                   |         | 6,948   | 7,752   | 12,407  | 15,639  | 8,845     |
| <b>Total Capital Expenditure</b>   | 7,573             | 7,948   | 7,573   | 8,509   | 13,070  | 16,603  | 9,500     |
| <b>Key Performance Indicators</b>  |                   |         |         |         |         |         |           |
| Debt Service Coverage Ratio (net ope revenue before debt service/debt service) (times) | 1.07              | 0.52    | 2.21    | 1.12    | 0.12    | -0.58   | -0.03     |
| Self-financing ratio (funds from internal source/ave of capex) (%)                     | 62.74%            | 80.81%  | 29.21%  | 32.05%  | 8.29%   | -26.00% | -8.54%    |
| Return on Equity (net income/equity) (%)   | -1.08%            | -4.70%  | 2.01%   | -1.30%  | -7.12%  | -11.38% | -7.05%    |
| Return on Net Fixed Assets (net income/net fixed assets)                               | -0.73%            | -3.44%  | 2.18%   | -1.45%  | -8.50%  | -9.98%  | -5.37%    |
| Debt Equity Ratio (Debt/(Debt + Equity)) (%)   | 60.62%            | 61.82%  | 55.92%  | 57.10%  | 60.23%  | 64.09%  | 54.30%    |
| Current Ratio (current assets/current liabilities) (%)                                 | 94.04%            | 95.13%  | 111.96% | 110.43% | 105.35% | 95.40%  | 91.20%    |
| Operating Ratio (operating cost/total revenue) (%)                                     | 1.00              | 0.98    | 0.89    | 0.96    | 1.07    | 1.15    | 1.14      |
| Construction Work in Progress/Total Fixed Assers (%)                                   | 15.72%            | 20.06%  | 27.39%  | 31.94%  | 40.33%  | 29.56%  | 9.84%     |
| Stock & Stores/Total Fixed Assets (%)  | 5.77%             | 6.48%   | 9.56%   | 9.92%   | 10.24%  | 7.80%   | 4.74%     |
| Account Receivable Turnover (months)   | 12.45             | 13.88   | 13.38   | 13.12   | 13.82   | 13.41   | 11.43     |
| Sales per Employee (kWh/employee)  |                   | 543,868 | 635,709 | 847,264 | 904,192 | 985,885 | 1,033,522 |
| Employment Cost/Total Revenue (%)  | 7.20%             | 6.88%   | 5.90%   | 6.66%   | 5.31%   | 5.94%   | 6.58%     |

### 3.3.1 Business Performance

The business performance of BPDB has been in the chronic slump for a long time till today, with the accumulation of the insurmountable losses which amounts to Taka 83.8 billion. The paid up capital of BPDB has been deeply encroached to virtually zero level by the accumulated losses.






(source) BPDB, "Annual Reports 2001/02 - 2006/07"

Figure I-3-3-1 Business Performance of BPDB


To be specifically noteworthy, BPDB has undergone the deficits at the level of gross margin subtracting the operational expense from the operational revenue during the three years succeeding the fiscal year of 2004/05, which obviously has fallen short of appropriating the financial expenses. In 2006/07, the accumulated deficits went up to Taka 83.8 billion which is the level equal to 1.7 times of annual revenue and is beyond the capability of BPDB to restore the financial health. The prime most reason causing the slump in the business performance of BPDB rests with the low electricity tariff that can not cover the electricity supply cost.



(source) BPDB, "Annual Reports 2001/02 - 2006/07"

Figure I-3-3-2 Average Supply Cost and Average Billing Rate


Among the total volume that BPDB supplies, the proportion of the IPP generated electricity is on the steady increase. In general, IPP generates and sells electricity based on the generation cost while adding a certain margin which tends to be higher than the cost of the power generated by BPDB and its affiliated entities. In 2004/05, the volume of the energy purchased from IPP constituted 35% of the total energy BPDB sold and the amount spent for the purchase of IPP energy occupied 47% of the total expenditure of BPDB. Abiding by the contract, BPDB is not able to contain the increase of the electricity cost while IPPs are engaged in the generation activities in accordance with the power purchase agreement signed between BPDB and IPPs.



(source) BPDB, "Annual Reports 2001/02 - 2006/07"

Figure I-3-3-3 Power Generated at BPDB and Volume Purchased from IPP

Remaining concomitantly responsible for generation, transmission and distribution, BPDB has been faced with the serious problem of power loss incurred in its supply system. The following figure illustrates the power losses BPDB has been suffering both for the power coming from its own generation and the one purchased from IPPs, including the auxiliary consumption, transmission and distribution losses. Although the steady trend of decrease is in place during recent years, the amount of the auxiliary consumption stays as high as 7% while BPDB is suffering from the aggregate system loss of 16.6% if it includes the generation, transmission and distribution. The high percentage of system loss indicates the urgent necessity BPDB is confronted with in reducing the loss of the precious energy reaching to the end beneficiaries.



(source) BPDB, "Annual Reports 2001/02 - 2006/07"

Figure I-3-3-4 System Loss of Electricity

The nation-wide system loss in the power sector is followed by Power Cell of the Ministry of Power, Energy and Mineral Resources which indicates the astonishing level of losses; the auxiliary consumption at 6.0%; transmission loss at 5.63%; distribution loss at 20.97%; making the total losses at 32.60%<sup>3</sup>. The statistics implies that out of the total volume generated, one third is lost before it reaches to the end-users.

<sup>3</sup> Power Cell, MoPEMR, "Bangladesh Power Sector Databook", June 2006

### 3.3.2 Equity Capital Account


BPDB practiced the revaluation of assets twice in recent history, once in the fiscal year 2000 and the second time in 2007 which generated the revalued surplus of Taka 117.0 billion into the capital accounts with the effect of saving the capital account going into negative balance. In addition to the two-time revaluations, the government has periodically converted BPDB's debt to the equity so that the capital account of BPDB has been kept from plunging into the deficit ridden position. While the revaluation had the effects of saving BPDB's capital account from falling to the negative balance, it has failed to generate fresh money which BPDB has freedom to spend for its own use. The practice caused the balance sheet to superficially improve but has realized no addition of fresh money. In order for the practice of revaluation to bear fruits, the higher value of the fixed assets will have to be depreciated properly and entail the increase of the tariff so that it will assure BPDB to recover the full cost of the fixed assets. Though BPDB revalued its fixed assets in the fiscal year of 2000, no change took place in the depreciation since the time of revaluation till the fiscal year of 2006. The revaluation done has been no more than a make-up in its appearance. In the balance sheet of 2006/07, the total fixed assets increased by Taka 92 billion in whose opposite the accumulated depreciation increased by Taka 18 billion, the capital project in progress decreased by Taka 21 billion and the surplus from asset valuation increased by Taka 61 billion. It is to be noted that a significant amount was transferred from the capital projects in progress to the fixed assets that has increased the total assets as of the fiscal year.

### 3.3.3 Asset Accounts

The power sector business is the one of highly capital intensive nature with a large amount of long term investment in its operational assets. The weight of the current asset tends to become smaller as the entity succeeds in improving its efficiency. In BPDB, the current assets are swollen to be of significant existence constituting a large position due to the increase of the accounts receivable. In the fiscal year of 2006/07, the percentage of the current assets among the total assets stood at 28%. At Japanese power companies which have achieved the high operational efficiency, the weight of the current assets is seen to be as low as 5%<sup>4</sup> on an average of the 10 power specialized companies in the fiscal year of 2006. There appears a notable difference between Bangladesh and Japan. With respect to the accounts receivable, the turnover of BPDB's account receivable stands at about 360 days though the indicator showed the sign of downtrend during the past two years. The electricity is billed and paid once a month regularly, and the turnover should not be longer than 30 days, should there be no arrear in collecting them. The number stands at 21 days in Japan that exactly meets the above contention. The long period of the turnover at BPDB stems nothing but from the vicious cycle of non-payment of bills at all levels of power generation till consumption. It is imperative to scrutinize the causes of slow and/or non-payment and exert efforts to assess the outstanding account receivable collectible from the non-collectible. What is suggested is that BPDB exerts its efforts in collecting the good receivable while writing off the non-collectible ones.

---

<sup>4</sup> The Federation of Electric Power Companies of Japan: <http://3.fepc.or.jp/tok-bin/kensaku.cgi>




(source) BPDB, "Annual Reports 2001/02 - 2006/07"

Figure I-3-3-5 Balances of Accounts Receivable

With respect to the turnover of the fixed assets against the total revenue which checks how many times the fixed assets roll over through the amount of total revenue. It is learnt that the fixed assets turned over 0.25 times in BPDB. The total assets of BPDB are swollen due to the revaluation and such fact causes the turnover at lower rate which should be much higher as the power sector of the country is suffering from the acute shortage of power due to the insufficient investment. The number stood at 0.16 times in Japan where the capital investment into fixed assets is considered at the saturated level.

The insufficiency of investment drives the power entity to make aggressive investment while such is evidenced by the capital work in progress and its relative weight against the total fixed assets. In the fiscal year of 2004/05, the ratio of the capital work in progress against the total fixed assets recorded 40.3% but is on a continuous declining trend ever since. In particular, the value of fixed assets inflated in 2006/07 due to the second revaluation and caused the ratio to decline sharply.



(source) BPDB, "Annual Reports 2001/02 - 2006/07"

Figure I-3-3-6 Trends of the Fixed Assets and Capital Work in Progress

The capital work in progress represents the construction work that is going on prior to the commissioning of the asset. The fact that the ratio stands high indicates the capital investment is going on at a high rate but it should be noted that those assets are yet to be commissioned and to be engaged in the productive activities. The balance in the account delivers a negative impact upon the total operational efficiency. It is imperative to plan the capital investment in such a

manner that will maintain the balance in execution of investment to meet with the increase of demand for power. The ratio is observed to be as low as 5.2% among the Japanese companies in the power sector.

An attention is invited to the next important point among the asset accounts which is concerned with the depreciation. BPDB has seen its assets expanded due to the revaluation carried out in the fiscal year of 2000. From the very moment of the revaluation done, the depreciation should have been done based on the increased value of the properties. In reality, no such change has taken place in the practice of BPDB during the period of fiscal year of 2000/01 through 2005/06. The change of depreciation has been instituted only in the fiscal year of 2006/07 and the delay in the implementation of the change caused BPDB to lose the opportunity to recover the capital invested.

### **3.3.4 Liability Accounts**

There exists an account which should never be overlooked, i.e. Debt Service Liabilities. The account represents the liabilities that had been owed but had not been met by BPDB on the due dates of both principal and interest payments. Those are the arrears accumulated with the debt service of BPDB owed to the government who borrowed the funds from the donor institutions and on-lent to BPDB. The government has been serving the original debts due to the donors; but could not realise its claim from BPDB. The fundamental structure of BPDB's debt service is that BPDB collects the electricity bill which includes but not limited to the depreciation. BPDB should have made payments of the principal and interest of debts out of the proceeds collected through the electricity bills. Should the tariff be set at the level that covers the cost incurred for the supply, the amounts collected through the billing should be sufficient to pay the expenses of fuel and others and also make payment of principal and interest of the loans taken? The funds collected in reality were insufficient to honor those debts due to the simple reason that the average billing rate obviously undermined the average cost of supply. The government and the power sector have an obvious task to rectify such disorder of the electricity tariff as their first priority issue.

In respect of the employees' retirement benefit account there is a need for the management to seriously consider the future implication of the current system with a view to their sustainability of the systems in the long term. At present, BPDB maintains three kinds of the employees' retirement benefit plans, i.e. the Retiree Pension Plan, the Contributory Provident Fund and the Gratuity Fund. While the Pension Plan is a defined benefit plan providing pension payments to the retirees after the eligibility age, the other two are the plans providing one-time lump sum payment. The defined benefit plan requires the sponsor to contribute the funds necessary to cover the pension liability which is calculated through the actuarial valuation of the age structure of beneficiaries. Apparently, no efforts are being made by BPDB for conducting and assessing the actuarial valuation and determining the pension liabilities. A significant risk lies in the fact that when the life expectancy becomes longer this will undoubtedly increase the potential future payments to the retirees. The management is urged to delve into the nature of the matter and cause the appropriate measures to be taken or introduced.

### **3.3.5 Ratio Analysis**

One can assess the solvency of a business entity by calculating the ratio of the current assets and the current liabilities. The ratio checks whether the entity maintains sufficient liquid assets that should be appropriated to pay the liquid liabilities. The general rule of thumb for the solvency is often quoted to be 150%. BPDB used to maintain momentarily the ratios above 100% during the fiscal years 2003 through 2005 but submerged below 100% in the fiscal year of 2006. The ratio for the fiscal year of 2006/07 was 91.2%. There is a serious problem that is inherent to the


figure of the current assets before arguing the current ratio. The current assets that are divided by the current liabilities include the gigantic sum of the account receivable the major part of which are deemed irrecoverable. The ratio calculated, thus, needs to be discounted by a considerable margin. The ratio cannot be quoted healthy by any means.

Another point of concern surfaces at the calculation of debt service coverage ratio (DSCR). The ratio is calculated by dividing the net operating income before debt service by the sum of loan repayment and interest paid. The prevailing standard for the ratio is 1.3 in general. BPDB recorded DSCR of 1.1 and 0.5 in 2000/01 and 2001/02 before hitting 2.2 in 2002/03. The ratio took a sharp decline starting from 2003/04 at the level of 1.1 to 0.1 in 2004/05 and went deep into the minus territory by aggravating the ratio to -0.6 in 2005/06. The major cause of the negative ratio is due to the poor performance that has ended in the continuous deficits. The ratio also contains a hidden danger that cannot be identified from the outcome. The deflator of the equation needs to cover all the sums of payment of principal and interest that falls due in any particular year. It appears that BPDB relocated and hid the sums that cannot be paid for the debt services into the debt service liability account and therefore excluded them from the deflator. The ratios calculated apparently took only the amount BPDB actually paid which may or may not include any amount included in the debt service liability account during the period. What is indicated here is the fact that the actual financial condition of the entity is undoubtedly serious and needs immediate actions to cope with.

### 3.4 Electricity Tariff

#### 3.4.1 International Comparison of Electricity Tariff

Bangladesh has the universal tariff which covers the entire country under one tariff system. The following figure compares the electricity tariffs imposed in some of the neighboring countries in Asia.



(source) Bangladesh: Annual Report of DESCO. Pakistan: WAPDA Others: Japan Electric Power Information Center, Inc., “Kaigai Shokoku no Denki Jigyo”, 2006

Figure I-3-4-1 Average Power Tariff in Asian Countries

As is shown in the above figure, the power tariff prevailing in the Asian countries as of 2004 are; Bangladesh: US ¢ 5.56/kWh<sup>5</sup>; Pakistan: US ¢ 6.98/kWh<sup>6</sup>; Indonesia: US ¢ 6.51/kWh; Malaysia: US ¢ 6.18/kWh; Philippines: US ¢ 11.10/kWh; Thailand: US ¢ 6.34/kWh; Vietnam:

<sup>5</sup> DESCO, “Annual Report 2007”, 2008

<sup>6</sup> Water and Power Development Authority of Pakistan

US ¢ 5.07/kWh and India: US ¢ 6.10/kWh<sup>7</sup>. Philippines is way out high in comparison with the other countries while Vietnam is the lowest trailing the others. The average tariff in Bangladesh is recognized as US ¢ 5.56/kWh which more than in Vietnam but is lower than in the countries of India, Pakistan, Thailand, Malaysia and Indonesia as the second lowest among the compared countries.

### 3.4.2 Electricity Tariff

In Bangladesh, entities engaged in the power sector undertakings are regulated to obtain the approval of Bangladesh Energy Regulatory Commission (BERC) for the tariff, fixing the price of electricity they supply based on the actual cost of their operation. The prevailing tariff was updated as of January 1, 2007 and has been in force ever since. The tariff is given in the following table;

Table I-3-4-1 Electricity Tariff

| Consumer Category                             | Range  | Rate/kWh   | Charges            |  |  |
|---|--|--|--------------------|--|--|
|   |  |  | Demand             | Service  | Minimum  |
| Domestic Category-A                           | • 000-100kWh<br>• 101-400kWh<br>• 401kWh 超                   | • Tk 2.50<br>• Tk 3.15<br>• Tk 5.25              | Tk 10.00/kW/month  | Single Phase:<br>Tk 5.00/month<br>3-phase:<br>Tk 25.00/month | Tk 100.00/month  |
| Agricultural Pumping Category-B               | • Flat   | • Tk 1.93  | Tk 35.00 /kW/month | 1-phase:<br>Tk 5.00/momth<br>3-phase<br>Tk 25.00/month       | Tk 125.00/H.P./month                                   |
| Small Industry Category=C                     | • Flat<br>• Peak<br>• Off peak                               | • Tk 4.02<br>• Tk 5.62<br>• Tk 3.20              | Tk 35.00 /kW/month | Tk 60.00/month   | Not applicable   |
| Non-Residential Category-D                    |  | • Tk 3.35  | Tk 10.00/kW/month  | 1-phase<br>Tk 5.00/month<br>3-phase<br>Tk 25.00/month        | Tk 100.00/month  |
| Commercial Category-E                         | • Flat<br>• Peak<br>• Off peak                               | • Tk 5.30<br>• Tk 8.20<br>• Tk 3.80              | Tk 20.00 /kW/month | 1-phase:<br>Tk 5.00/month<br>3-phase:<br>Tk 25.00/month      | Tk 125.00 /kW/month                                    |
| Medium Voltage 11kV General Category-F        | • Flat<br>• Peak<br>• Off peak                               | • Tk 3.80<br>• Tk 6.73<br>• Tk 3.14              | Tk 40.00 /kW/month | Tk 350.00/month  | Tk 80.00 /kW/month but not less than Tk 8,000.00/month |
| Extra High Voltage Category-G-1               | • DESA-132kV<br>• DESA-33kV                                  | • Tk 2.34<br>• Tk 2.39                           | Tk 35.00/kW/month  | Not applicable   | Tk 80.00/kW/month                                      |
| Extra High Voltage 132kV General Category G-2 | • Flat<br>• 2300-0600hrs<br>• 0600-1300hrs<br>• 1300-1700hrs | • Tk 2.82<br>• Tk 1.49<br>• Tk 2.48<br>• Tk 1.66 | Tk 35.00/kW/month  | Tk 80.00/kW/month  | Tk 60.00/kW/month                                      |

<sup>7</sup> Japan Electric Power Information Center, Inc., "Kaigai Shokoku no Denki Jigyo", 2006

| Consumer Category                           | Range   | Rate/kWh   | Charges              |                 |                      |
|---|---|--|----------------------|-----------------|----------------------|
|   |   |  | Demand               | Service         | Minimum              |
|   | • 1700-2300hrs  | • Tk 5.52  |                      |                 |                      |
| High Voltage<br>33 kV General<br>Category-H | • Flat<br>• Peak<br>• Off peak  | • Tk 3.58<br>• Tk 6.45<br>• Tk 3.03                  | Tk<br>35.00/kW/month | Tk 400.00/month | Tk<br>80.00/kW/month |
| Category I-1                                | REB<br>1) 132kV<br>2) 33kV<br>• Economically insolvent<br>• Economically marginal<br>• Economically solvent | • Tk 2.34<br><br>• Tk 2.05<br>• Tk 2.05<br>• Tk 2.39 | Not applicable       | Tk 400.00/month | Not applicable       |
| Category I-2                                | DESCO<br>• 132kV<br>• 33kV  | • Tk 2.34<br>• Tk 2.39                               | Not applicable       | Tk 400.00/month | Not applicable       |
| Category I-3                                | WZPDCL<br>• 132kV<br>• 33kV   | • Tk 2.34<br>• Tk 2.39                               | Not applicable       | Tk 400.00/month | Not applicable       |
| Category I-4                                | Distribution of<br>BPDB<br>• 132kV<br>• 33kV  | • Tk 2.34<br>• Tk 2.39                               | Not applicable       | Tk 400.00/month | Not applicable       |
| Category I-5                                | Distribution<br>Company in Future<br>• 132kV<br>• 33kV  | • Tk 2.34<br>• Tk 2.39                               | Not applicable       | Tk 400.00/month | Not applicable       |
| Street Lights &<br>Pump Category-J          |   | • Tk 3.86  | Tk<br>35/kW/month    | Tk 200.00/month | Not applicable       |

(note) As of December 2008, the exchange rate stands at US\$1=Taka 67.59 and Taka 1=US\$0.0148 in the monthly average. (source: eXchangeRate.com)

(source) MoPEMR

The prevailing tariff establishes rates applicable to categorized consumers of households, agricultural pumping, small industry, commercial, bulk for wholesale; street lights and pumping. Different rates are set for the volume of consumption, size of contract (demand) and differentiated time zones.

The following are the points to be noted;

- 1) The tariff is suppressed at a low level in general. At BPDB, the average billing rates are undermining the average supply costs.
- 2) In particular, the tariffs are notably lower for agriculture, bulk for wholesale and a part of the households and existence of such low rates are triggering the cross subsidy from the other categories of users.
- 3) The tariff for REB among the bulk wholesale is allowed to be charged with the lower and benevolent rate for the economically insolvent class.

BPDB submitted an application for the revision of its tariff for the increase of an average of 41% in June 2008 which was officially received by BERC on July 3, 2008. In accordance with the prevailing regulation for setting the electricity tariff, BERC took the steps of appraising and approving the application through conducting the public hearing on August 20, 2008. The



Commission made its official announcement on the revision of tariff on September 29, 2008. During the course of the appraisal, BERC and BPDB agreed to separate the application of revising the retail tariff from the wholesale tariff and concentrate the initial round of the appraisal into the wholesale tariff. The rationale behind this separation was such that the retail tariffs are dependant on the revision of the wholesale tariff and the distribution companies may reasonably apply for its revision after the whole sale tariff will be notified. BPDB, in regard to the retail tariff, should be placed in the same position with other distribution companies. The appraisal was been conducted based on the audited financial performance for 2006/07 and 2007/08. BERC made its decision to approve the increase of such tariff by 16% from the weighted average whoklesale tariff of Taka 2.04/kWh before the application to be immediately effective. BERC was reportedly conservative in making the appraisal as it was the first instance of handling the tariff application and such posture of BERC led the appraisal to totally deny the return on equity applied by BPDB for the percentage of 3%. The tariff approved by BERC is barely equal to the cost of purchase of the power by BPDB from IPPs. For this, BPDB has not been allowed any cost of service at all. The outcome of the application implies that the business environment for BPDB's operation shall continue to be tough and severe in terms of attaining profitable operation.

The revision of the wholesale tariff is understood to invoke the revision of the retail tariff at distribution companies. As of November 2008, the distribution companies are reported to have filed or are under preparation of their applications for increase of their tariffs. Depending upon the ultimate decision to be reached by BERC, the universal tariff might cease to exist. A new tariff regime might be created, should BERC pursue the principle of "actual cost plus reasonable margin". As of present, BERC is stating that its policy has not been established on the issue<sup>8</sup>.

In addition to the tariff of electricity, BERC has also received an application for the revision of the gas tariff from Petrobangla and is in the stage of appraisal. The decision is mentioned to be announced on November 30, 2008. Unlike for the power tariff, BERC reveals that the reasonable rate of return will be allowed for the gas tariff. The difference of treatment between the two sector is explained to be due to the facts that; 1) BPDB, the applicant of the bulk tariff revision is 100% owned by the government while the companies in gas sector are partially invested by the private capital; 2) gas sector has long contributed to the fiscal budget position whereas the power sector has long been consuming the fiscal expenditure. The revision of the gas tariff will trigger another revision of the power tariff. Under the regulation for setting the electricity tariff, power sector entities are permitted to apply twice a year for the revision of the tariff.

In a separate motion, the government announced to revise the tariff of petroleum products by an average rate of 35% on September 1, 2008. On October 27, the tariff was reversed downward by approximately 16%. Through such changes, the price of high speed diesel oil was brought up from Taka 40.00/liter to Taka 55.00/liter on September 1 and to Taka 46.61/liter on October 27. Due to the recent international trend of crude oil and petroleum products, the price is expected to be reduced once again in late 2008 or early 2009. Such changes of the price have not been reflected in the revision of power tariff of September 2008, the power tariff might undergo another round of adjustment.

### **3.4.3 Tariff Policy at Bangladesh Energy Regulatory Commission**

Bangladesh Energy Regulatory Commission (BERC) has been established in 2004. The tariffs at which power companies and entities sell electricity irrespective of wholesale or retail have to be approved by BERC before they become effective. In reality, BERC has been and still is in the

---

<sup>8</sup> Interview at BERC on November 26, 2008.

process of hiring the staff and organizing the institution. It barely started its oversight activities but yet to wait for December of 2008 before it will be operating in a full fledged manner. MoPEMR solicited BERC to approve the tariff revision that took place in March 2007, though BERC itself was then in the midst of aligning the organization. In addition, the government is reported to have approached BERC for another increase of tariff by additional 10% during the year of 2007. The application has not been processed as requested partly due to the fact that BERC was yet to strengthen its institutional capacity before making the drastic decision.

The fundamental rules and regulations that are providing BERC with the authority to regulate and rule the power sector are; 1) Bangladesh Energy Regulatory Commission Act 2003 (Act No. 13 of 2003), 2) Licensing Regulation, 3) Electric Generation Tariff Regulation 2008. The rules and regulations for establishing the electricity tariff are being prepared by BERC which includes the regulations such as; 1) Electric Generation Tariff Regulation 2008, 2) (draft) Electricity Transmission Tariff Regulation 2008, 3) (draft) Electricity Distribution Tariff Regulation 2008. Out of these three tariff regulations, the generation tariff regulation has been approved and become effective in 2008 while the other two are in the stage of draft and are yet to be approved. The generation tariff regulation prescribes that BERC shall, within 60 days of official acceptance of the application, hold a public hearing and that BERC shall make its final decision and notification within 90 days after its official receipt of the application.

The Generation Tariff Regulation sets forth the following principles in setting up the electricity tariff<sup>9</sup>. The power tariff is composed of “fuel charge” and “service rate charge”. The fuel charge describes that the licensed power companies will earn no profit or return on the cost and the rates for fuel recovery will change on a semi-annual basis. The service tariff rate is intended to establish the tariff rates which provide the least cost to consumers while providing the opportunity for licensed power companies to earn sufficient revenues to cover all of their operating expense and providing for the continued improvement of their operating system and attract capital for investment. The amount that the licensed companies are allowed to recover through billing is demonstrated by the following equation;

$$\text{Revenue Requirement} = \text{Operating Expenses} + \text{Taxes} + \text{Annual Depreciation Expense} \\ + \text{Overall Rate of Return} \times (\text{Gross Investment} - \text{Accumulated Depreciation})$$

The power company, filing an application to BERC for approval of the tariff, has to establish a test period in which the applicant compiles his data on the basis of operation. BERC’s analysis and decision is made based on the data produced for the test year. A generating entity, who has no operating history, which will make the best estimate for a fiscal year, outcome of which will be considered by BERC. For the purpose of the regulation, the capital work in progress is allowed to be included in the total rate base for calculating the return on assets. Likewise, the regulation also allows inclusion of the regulatory working capital into the rate base. The amount of working capital allowed are: the amount equivalent to the two months of operation and maintenance expenses; two months of fuel inventory, if the plant operates on liquid fuel or coal but not for gas nor hydro power; one month of materials and supplies inventory and one month of pre-payments. For the return on capital, the applicant shall apply to BERC with the expected returns on investment accompanied by adequate support to justify such return. It is understood that BERC prefers to consider the cost of equity as the sum of a risk-free rate of return plus a return to compensate the investor for the market risk.

---

<sup>9</sup> Bangladesh Energy Regulatory Commission, “Bangladesh Energy Regulatory Commission Electric Generation Tariff Regulation 2008”

### 3.4.4 The Electricity Tariff of Independent Power Producer (IPP)

The IPPs are operating based on the long term power purchase contracts signed with BPDB prior to the commencement of the projects, which governs the methodology of pricing and actual prices of power to be sold. Those contracts and the prices have been approved by the government before starting productive operation of their plants. The following table lists up outline profiles of IPPs with the average tariff approved;

Table I-3-4-2 Electricity Tariff of IPPs

| Company                                    | Fuel      | Rated Capacity (MW) | Date of Commissioning     | Average Tariff (US Cents/kWh)     | Plant Factor |
|--|-----------|---------------------|---------------------------|-----------------------------------|--------------|
| Khulna Power Co., Ltd.(KPCL)               | Heavy Oil | 110                 | 1998.10                   | Heavy Oil: 5.83<br>Gas: 4.40      | 80%          |
| Baghabari, WESTMONT                        | Gas       | 90                  | 1999.6                    | 4.30                              | 80%          |
| NEPC, Haripur                              | Gas       | 110                 | 1999.6                    | 4.41                              | 80%          |
| Rural Power Co., Ltd. (RPCL)               | Gas       | 140                 | 2001.4                    | 4.30                              | 80%          |
| AES Haripur(*1)                            | Gas       | 360                 | SC: 2001.6<br>CC: 2001.12 | 2.73( *2)                         | 85%          |
| AES Meghnaghat(*1)                         | Gas       | 450                 | 2002.11                   | 2.79(*2)                          | 85%          |
| Summit Power Co., Ltd.                     | Gas       | 30                  | 2003.10                   | Tk 1.69 /kWh                      | 75%          |
| Baghabari 2 <sup>nd</sup> , WESTMONT       | Gas       | 40                  | 2006.8                    | 2.79                              | 80%          |
| Rural Power Co., Ltd (RPCL)                | Gas       | 70                  | 2006.9                    | 4.30                              | 80%          |
| Meghanaghat 2 <sup>nd</sup> BON Consortium | Gas       | 450                 | 2008 (scheduled)          | 2.7865                            | 75%          |
| Summit Power Co., Ltd (Narsingi PBS-1)     | Gas       | 24                  | 2006 (scheduled)          | Less than 3 Paisa from BST of PBS |              |
| Summit Power Co., Ltd. (Comilla PBS-1)     | Gas       | 13                  | 2006 (scheduled)          | Less than 3 Paisa from BST of PBS |              |
| Summit Power Co., Ltd. (Dhaka PBS-1)       | Gas       | 25                  | 2007 (scheduled)          | Less than 3 Paisa from BST of PBS |              |

(note) (\*1) : The owner of the project was changed due to the sale of the project to Pendekar Energy, current owner.

(\*2) : The price of gas was set at US\$ 2.40/GJ for the tariff. The gas is supplied at US\$ 1.20/GJ at present.

(source) Power Cell, MoPEMR, "Bangladesh Power Sector Data Book", June 2006

All the electricity generated by IPPs is sold to the single buyer, BPDB. The average billing rate of BPDB is Tk 2.26/kWh for the fiscal year of 2006/07. Five plants out of the above listed IPPs are exceeding the average billing rate of BPDB. In general, IPPs are approved with higher tariffs and higher plant factors. Based on those terms of the contract, they operate as the base load supplier while they are required to maintain their plants operative without any breaks at all times with the exception of the scheduled and agreed maintenance periods. The management of IPPs is carried out in confrontation with those pressures for constant operation.

## **Chapter 4 Technical Feasibility of the Project**

### **4.1 Power Demand Forecast**

#### **4.1.1 The Way of Thinking of the Power Demand Forecast**

According to Power System Master Plan Update 2006 (PSMP) prepared by Power Cell with support from the ADB, the power demand forecast follows the growth rate of the GDP (the gross national product) closely and as a technique of the electricity demand prediction in PSMP, the growth rate of the GDP in the future is predicted and then power demand is forecast based on these.

#### **4.1.2 Justification of Power Demand Forecast in PSMP 2006**


Table I-4-1-1 and Figure I-4-1-1 show approximation curves which display power demand forecasts made in the Power System Master Plan in 1995, the ADB Gas Development Project, 2005 Gas Sector Master Plan and PSMP 2006, and those curves show approximately same trend. Therefore, the power demand forecast in PSMP 2006 is proper and justified.

Table I-4-1-1 Comparison of Power Demand Forecast

(Unit: GWh)

| Fiscal Year | Base Case<br>(PSMP 2006) | 1995 Power<br>Sector Master<br>Plan | ADB Gas<br>Development.<br>Projec | 2005 Gas<br>Sector Master<br>Plan | Demand<br>Forecast by<br>Company |
|-------------|--------------------------|-------------------------------------|-----------------------------------|-----------------------------------|----------------------------------|
| 2005        | 21,964                   | 22,823                              | 24,161                            | 21,989                            | 21,964                           |
| 2006        | 23,945                   | 24,662                              | 26,108                            | 23,361                            | 23,945                           |
| 2007        | 26,106                   | 26,651                              | 28,214                            | 24,818                            | 26,106                           |
| 2008        | 28,461                   | 28,804                              | 30,492                            | 26,366                            | 28,461                           |
| 2009        | 31,028                   | 31,133                              | 32,959                            | 28,581                            | 31,028                           |
| 2010        | 33,828                   | 33,654                              | 35,628                            | 30,982                            | 33,828                           |
| 2011        | 36,622                   | 36,300                              | 38,428                            | 33,584                            | 36,622                           |
| 2012        | 39,647                   | 39,157                              | 41,452                            | 36,406                            | 39,647                           |
| 2013        | 42,922                   | 42,243                              | 44,720                            | 39,464                            | 42,922                           |
| 2014        | 46,467                   | 45,578                              | 48,250                            | 42,780                            | 46,467                           |
| 2015        | 50,306                   | 49,180                              | 52,064                            | 46,374                            | 50,306                           |
| 2016        | 54,079                   |                                     | 56,229                            | 50,269                            | 54,079                           |
| 2017        | 58,135                   |                                     | 60,727                            | 54,493                            | 58,135                           |
| 2018        | 62,496                   |                                     | 65,586                            | 59,070                            | 62,496                           |
| 2019        | 67,183                   |                                     | 70,832                            | 64,033                            | 67,183                           |
| 2020        | 72,222                   |                                     | 76,499                            | 69,412                            | 72,222                           |
| 2021        | 77,092                   |                                     | 80,324                            | 75,029                            | 77,092                           |
| 2022        | 82,290                   |                                     | 84,340                            | 81,100                            | 82,290                           |
| 2023        | 87,839                   |                                     | 88,557                            | 87,662                            | 87,839                           |
| 2024        | 93,761                   |                                     | 92,985                            | 92,985                            | 93,761                           |
| 2025        | 100,083                  |                                     | 97,634                            | 102,422                           | 100,083                          |

(source) PSMP 2006



(source) PSMP 2006

Figure I-4-1-1 Comparison of Power Demand Forecast

## 4.2 Benefits

### 4.2.1 Electrification rate

Construction of the Bheramara Combined Cycle Power Plant (hereinafter referred to as “Bheramara CCPP”) will contribute to stable power supply in the western zone (Khulna, Rajshai and Barisal Division) currently suffering from a power supply shortage.

It will also improve the electrification rate in the western zone.

It is estimated (see the Table I-4-2-1~3) that construction of the Bheramara CCPP is expected to achieve electrification of about 1,900,000 general households in the western zone. Calculation is as follows.

$$g (359.88\text{MW}) \times h (70\%) \times 365\text{day} \times 24\text{hour} \times b (42.71\%) / e (497 \text{ kWh}) \doteq n (1,900,000)$$

Electrification rate of households in the western zone after operation of Bheramara Power Station shall increase from 21.93% to 39.50% (Table I-4-2-3).

Table I-4-2-1 Annual power consumption per household in Bangladesh

|   | Item   | Unit   | Calculation formula | Value |
|---|--|--------|---------------------|-------|
| a | Annual power consumption per household in Bangladesh         | GWh    | —                   | 6,457 |
| b | Percentage of power consumption of general households in "a" | %      | —                   | 42.71 |
| c | Power consumption of general households                      | GWh    | a x b               | 2,758 |
| d | Number of electrified households in Bangladesh               | 10,000 | —                   | 555   |
| e | Annual power consumption per household                       | kWh    | c / d               | 497   |

(source) Annual Power Consumption: FY 04-05 June MIS Rpt.  
Consumer Connections: Cumulative thru Dec '05 MIS Rpt.

Table I-4-2-2 Annual power consumption by households from the Bheramara CCPP in the western zone of Bangladesh

|   | Item   | Unit | Calculation formula               | Value   |
|---|--|------|-----------------------------------|---------|
| f | Output of Bheramara CCPP   | MW   | —                                 | 360.00  |
| g | Power consumption in the western zone in "a"                       | MW   | —                                 | 359.88  |
| h | Capacity factor of Bheramara CCPP                                  | %    | —                                 | 70      |
| i | Annual power consumption in the western zone                       | GWh  | $g \times 24 \times 365 \times h$ | 2,206.8 |
| j | Annual power consumption by general households in the western zone | GWh  | i x b                             | 942     |

(source) Power Grid Company of Bangladesh Load Flow Study 2008

Table I-4-2-3 Estimated number of electrified households and the electrification rate in the western zone of Bangladesh

|   | Item  | Unit   | Calculation formula | Value |
|---|---|--------|---------------------|-------|
| k | number of households in the western zone  | 10,000 |                     | 1,080 |
| l | electrification rate of households  | %      |                     | 21.93 |
| m | number of electrified households in the western zone  | 10,000 | k x l               | 237   |
| n | Estimated increasing number of electrified households in the western zone by operation of Bheramara P.S   | 10,000 | j / e               | 190   |
| o | Estimated total number of electrified households in the western zone after operation of Bheramara P.S     | 10,000 | m + n               | 427   |
| p | Estimated electrification rate of households in the western zone after operation of Bheramara P.S         | %      | o / k               | 39.50 |
| q | Estimated increasing electrification rate of households in the western zone by operation of Bheramara P.S | %      | p - l               | 17.57 |

(source) Bangladesh Bureau of Statistics Bangladesh 2006

#### 4.2.2 Benefits to Accrue in the Industrial Sector

Bangladesh is plagued with the acute power shortage which causes the load shedding both scheduled and unscheduled. In addition, the fluctuation of voltage is rampant and volatile from which the industrial sector is suffering a significant negative impact. The Power Sector Master Plan Update conducted in 2006 reveals that the power demand was recorded as 3,925MW in the fiscal year of 2004 whereas 461MW of electricity was shed representing 12% of the maximum demand<sup>1</sup> and the total volume of energy lost from the opportunity was 221GWh, being equivalent to 11% of the total volume of electricity generated. The project we are working on is of the rated capacity of 360MW which is anticipated to generate 2,200 GWh annually at the plant factor of 70%. Once completed, this project is to cover approximately 90% of the shortage at the peak hours and more than sufficient to cover fully the shortage of annual energy that was recorded to experience of 2004. In the fiscal year of 2006, the increase of electricity demand caused the aggravation of the power shortage which was recorded as 1,312MW. The extent this project could cover will be approximately 1/4 of the shortage of the year.

Table I-4-2-4 Electricity Generated and Load Shedding

| FY   | Actual Net Peak Load (MW) | Estimated Load Shedding (MW) | Estimated Net Peak Load (MW) | Net Energy Generation (GWh) | Estimated Load Shedding (GWh) | Estimated Net Energy Generation (GWh) |
|------|---------------------------|------------------------------|------------------------------|-----------------------------|-------------------------------|---------------------------------------|
| 2000 | 2,538                     | 462                          | 3,000                        | 14,739                      | 182                           | 14,921                                |
| 2001 | 2,904                     | 280                          | 3,184                        | 16,254                      | 178                           | 16,432                                |
| 2002 | 3,110                     | 289                          | 3,399                        | 17,445                      | 105                           | 17,549                                |
| 2003 | 3,333                     | 330                          | 3,663                        | 18,422                      | 104                           | 18,526                                |
| 2004 | 3,491                     | 461                          | 3,952                        | 20,062                      | 221                           | 20,283                                |
| 2005 | 3,721                     | 771                          | 4,597                        |                             |                               |                                       |
| 2006 | 3,782                     | 1,312                        | 4,693                        |                             |                               |                                       |

(source) For FY 2000-2004: Power Cell, "Power System Master Plan Update", June 2006  
For FY 2005 and 2006: BPDB, "Annual Report FY 2006"

The volume of 221GWh energy lost due to load shedding in the fiscal year 2004 can be valued at Tk 716 million at the rate of Tk 3.24/kWh which used to be the average selling price of power by DESCO<sup>2</sup>, the representative power distributor for the year of 2004. While the GDP used to stand at Tk 3,329.7 billion for the year of 2004, the energy lost is calculated to be equivalent of 0.2% of the country's GDP.

Going further back to 1990s, there exists a study titled "South Asia Growth and Regional Integration" conducted by World Bank on the power supply condition in Bangladesh<sup>3</sup>. The study describes the power supply condition of Bangladesh in 1998 that the number of days that BPDB operated with no power cut are counted as 49 days only out of the whole year making the load shedding as the frequent routine events. Out of the total demand, approximately 25% were not met and the power shortage caused the situation in which the industrial production contributing 15% of GDP was not able to produce about 10% of the sector's output. What is suggested here is that approximately Tk 30 billion, 1.5% of GDP, had been lost in its production opportunity.

<sup>1</sup> Power Cell, "Power System Master Plan Update", June 2006

<sup>2</sup> DESCO, "Annual Report" 2007

<sup>3</sup> World Bank, "South Asia Growth and Regional Integration: Chapter 6, Power Sector Reform, Private Investment and Regional Cooperation", 2000



The gloomy state of condition lingered in the country ever since. In 2005, Energy Information Agency of U.S.A. reported that every year in Bangladesh, the load shedding and the fluctuating voltage of power were causing the loss of industrial production for the value of US\$ 1.0 billion. More recently, Transparency International Bangladesh has made a sampling survey<sup>4</sup> covering 1,027 consumers (corporate and individuals) over the impact of the power shortage and the quality of power. From the survey of the industrial sector, it has been learnt that out of the sample beneficiary industries, 39% has responded that they have suffered from the inferior quality of power in such manner that the fluctuating voltage has caused damages to the productive equipment. In the ready made garment industry, it has been reported that 90% of the industrial concerns were to suffer from the disruption of the operation for producing the export products due to the power failures. It has been also reported that they should have been able to produce approximately 5% more than what has been actually produced, should there have been no load shedding. The value of the loss of production has been estimated to be approximately Tk 18.2 billion and the damages caused to the machinery has been approximately US\$ 1.7 billion.

The Bheramara CCPP Project is planned to operate as the base load supplier, a significant portion of the power shortage mentioned above will be covered by the project and the economic loss caused by the load shedding should be mitigated by a considerable extent.

### **4.3 Power Generation Development Planning**

#### **4.3.1 Existing power generation facilities**

Table I-4-3-1 shows a list of power generation facilities in Bangladesh as of July 26, 2008, and the maximum power output on the same date. The derated generation capacity is 4830 MW including the IPPs. All power output is provided by thermal power plants, except for 230 MW Karnafuli hydro power plants.

---

<sup>4</sup> Transparency International Bangladesh, “The State of the Governance in the Power Sector of Bangladesh”, November, 2007

Table I-4-3-1 List of existing power generation facilities (as of July 2008)

|    |   | Derated<br>Generation<br>Capacity<br>/MW | Generation<br>at the time<br>of max.<br>demand<br>/ MW | Remarks                                   | Generation<br>Reduced<br>/ MW |
|----|---|--|--|---|-------------------------------|
| 1  | Karnafuly Hydro Power Station (2x40, 3x50M) | 230                                      | 113  | No.3 overhauling                          | 50                            |
| 2  | Chittagong (Raojan) (2x210MW)               | 360                                      | 90   | Generation reduce due to gas shortage     | 270                           |
| 3  | (a) Sikalbaha Steam (1x60MW)                | 40                                       | 0  | Generation closed due to gas shortage     | 40                            |
|    | (b) Sikalbaha BMPP (1x28MW)                 | 10                                       | 0  | Generation closed due to gas shortage     | 10                            |
| 4  | (a) Ghorasal Steam (2 x 55MW)               | 85                                       | 30   | No.1 under maintenance                    | 55                            |
|    | (b) Ghorasal Steam (4x210MW)                | 750                                      | 560  | No.4 under maintenance                    | 190                           |
| 5  | Tongi GT (1x80MW)                           | 80                                       | 70   |   |                               |
| 6  | Sylhet GT (1x20MW)                          | 20                                       | 19   |   |                               |
| 7  | (a) Shahjibazar GT (1x12, 3x15MW)           | 38                                       | 20   |   |                               |
|    | (b) Shahjibazar GT (1x12, 3x16MW)           | 60                                       | 63   |   |                               |
| 8  | (a) Fenchuganj GT(2x30MW)                   | 60                                       | 30   | No.1 under maintenance                    | 30                            |
|    | (b) Fenchuganj Steam (1x30MW)               | 28                                       | 14   |   |                               |
| 9  | (a) Khulna Steam (1x110MW)                  | 60                                       | 0  | Under maintenance                         | 60                            |
|    | (b) Khulna Steam (1x60MW)                   | 35                                       | 0  |   | 35                            |
| 10 | (a) Barisal GT (2x20MW)                     | 35                                       | 30   |   |                               |
|    | (b) Barisal Diesel (1x1.5MW)                | 2.5                                      | 1.3  |   |                               |
| 11 | Bhola Diesel (2x1.5MW)                      | 2.5                                      | 2.4  |   |                               |
| 12 | Bheramara GT (3x20MW)                       | 54                                       | 42   |   |                               |
| 13 | Rangur GT (1x20MW)                          | 18                                       | 20   |   |                               |
| 14 | Saidpur GT (1x20MW)                         | 18                                       | 19   |   |                               |
| 15 | Bhoro Pukuria Coal (2x125MW)                | 220                                      | 200  |   |                               |
| 16 | Thakurgaon Diesel (1x3MW)                   | 3  | 2  |   |                               |
| 17 | Haripur GT (3x33MW)                         | 96                                       | 0  | Generation closed due to gas shortage     | 96                            |
| 18 | (a) Baghabari GT (1x71MW)                   | 71                                       | 0  | Generation closed due to gas shortage     | 71                            |
|    | (b) Baghabari GT (1x100MW)                  | 100                                      | 100  |   |                               |
| 19 | Siddhirganj Steam (1x210MW)                 | 190                                      | 100  | Generation reduce due to gas shortage     | 90                            |
| 20 | (a) Ashuganji Steam (2x64MW)                | 128                                      | 124  |   |                               |
|    | (b) Ashuganji Steam (3x150MW)               | 440                                      | 275  | No.3 under maintenance                    | 150                           |
|    | (c) Ashuganji GT (2x56MW)                   | 60                                       | 70   |   |                               |
|    | (d) Ashuganji CCPP (1x34MW)                 | 18                                       | 0  | Under maintenance                         | 18                            |
| 21 | Meghnaghat IPP (2x150+150MW)                | 450                                      | 442  | Generation reduce due to gas shortage     | 8                             |
| 22 | Haripur IPP (1x240+120MW)                   | 360                                      | 348  | Generation reduce due to gas shortage     | 12                            |
| 23 | Mymensingh IPP (4x35+70MW)                  | 210                                      | 143  | Generation reduce due to gas shortage     | 67                            |
| 24 | Haripur NEPC IPP (8x15MW)                   | 110                                      | 89   | Under maintenance                         | 15                            |
| 25 | KPCL IPP (19x6.5MW)                         | 110                                      | 90   |   |                               |
| 26 | Westmont IPP (2x45MW)                       | 70                                       | 68   |   |                               |
| 27 | Sylhet Rental (1x50MW)                      | 48                                       | 45   |   |                               |
| 28 | Khulna Rental (1x40MW)                      | 40                                       | 39   |   |                               |
| 29 | Bogra Rental (1x20MW)                       | 20                                       | 18   | Synchronized at 33kV                      |                               |
| 30 | Sumit Power (1x100MW)                       | 100                                      | 99   | Synchronized at 33kV                      |                               |
|    | Total                                       | 4830                                     | 3376   | Total Generation reduce due to gas shorta | 664                           |
|    |   |  |  | Maintenance / rehabilitation              | 603                           |

(source) BPDB Homepage

Further, percentage of the amount of power generation by type of energy is shown in Figure I-4-3-1. As illustrated, almost 90 percent of power is generated by locally produced natural gas.





Figure I-4-3-1 Percentage of the amount of power generation by energy type for FY2006

#### 4.3.2 Current Situation of Demand – Supply Balance

As shown in Table I-4-3-1, as of July 26, 2008, the generation at the time of maximum demand is only 3376 MW although derated generation capacity is 4830 MW. On examination of the reason, it reveals that the shutdown of the power plant resulting from maintenance or trouble corresponds to 603 MW; on the other hand, the shortage of gas supply corresponds to 664 MW. This suggests that a shortage of gas supply in Bangladesh is very serious.

Figure I-4-3-2 shows the load curve of the same date. It shows that a shortage of power supply occurs at all times. Especially as shown in Table I-4-3-2, load shedding of 825 MW occurred at the time of maximum demand at 20:00. Should the aforementioned gas supply shortage problem be solved, there is still a shortage of electric power generating capacity of 161 MW. This requires quick action to be taken to launch a new power generation development project.

Further, 80 percent of the power plants in Bangladesh are concentrated in the eastern zone close to the natural gas field. This requires power transmission of about 200 to 300 MW from east to west. Thus, from the viewpoint of system operation, power generation development in the western zone is an urgent necessity.



(source) BPDB homepage

Figure I-4-3-2 Load curve as of July 26, 2008

Table I-4-3-2 Load shedding as of July 26, 2008

| Zone           | Area      | Actual Shedding/MW |
|----------------|-----------|--------------------|
| East           | Dhaka     | 224                |
|                | Cittagong | 120                |
|                | Comilla   | 27                 |
|                | Mymensing | 59                 |
|                | Sylhet    | 40                 |
| East Sub-Total |           | 470                |
| West           | Khulna    | 162                |
|                | Rajshahi  | 100                |
|                | Barisal   | 24                 |
|                | Rangpur   | 69                 |
| West Sub-Total |           | 355                |
| Total          |           | 825                |

(source) BPDB homepage

### 4.3.3 Power Generation Development Planning

BPDB is working out power generation development planning according to the demand assumption of the basic case carried out in PSMP 2006. In this assumption, in the meantime, as discussed in Section 4.5, outlook of gas supply for the future power plant is unclear due to a delay in gas development. The Government of Bangladesh has worked out a policy for screening of a gas-fired thermal power plant construction plan and for cancellation of construction of a gas-fired thermal power plant after Bheramara CCPP. Table I-4-3-3 shows the list of power generation development projects which was revised in August 2008 as a result of this coordination (hereinafter referred to as “the Projects List”). In this list the commercial operation date of the Bheramara CCPP is amended as September 2014 according to the result in

Sub-section 4.9.

Table I-4-3-4 shows the list of the retirement plan for the existing thermal power plant stated in PSMP2006. Most of these plants have operated 20 – 30 years and most of those thermal efficiencies are within the range of 20 - 25%. This value is quite lower comparing average thermal efficiency of thermal power plant of a Japanese electric power company who introduces high efficient power plants is recorded around 46% and BPDB's one is reported as 32.34%. The thermal efficiency of Bheramara CCPP is planned around 54%. For balanced business operation of electric power company, balanced replacement of power plant and cost down of generation cost is necessary, therefore aged power plant should be retired and be built new high efficiency power plants as planned. However those plants can not retire due to delay of construction of new power plants described below.

Table I-4-3-5 shows the balance of power demand and supply up to 2014. The retirement plan listed in Table I-4-3-4 is not reflected in the estimated power supply. Considering the expected maximum power demand of 4700MW in 2008, the power demand expectation in PSMP2006 might be higher than actual demand. However even in 2014 when the Bheramara CCPP commences commercial operation, the power supply would be short by 650MW compared to power demand.

The following describes the progress of other subjects to be developed by BPDB. In the first place,

Japanese ODA Loan Agreement was signed for the Haripur 360 MW CCPP on December 12, 2007, and bids will be invited for the power generation facilities in the beginning of the next year. However the commercial operation is expected to start in 2014 due to the delay of fuel gas supply. Almost other projects will be delayed for about 2 years due to the delay of fuel gas supply. As for the Khulna 210 MW thermal power plant, there was a re-bidding in March 2008, but the result was not successful. Thus, the project was excluded from the Project List.

The following describes the IPP project in Bangladesh. For the Bibiyana 450 MW CCPP requested by the Power Cell, the bid was closed on July 24, 2008. Although only one Consortium of Powertek Malaysia, KEPCO Korea and Siemens offered the bid and it was canceled at last governmental approval process. In this situation the commercial operation in 2012 will be unrealistic. The bid of Sirajiganji 450 MW CCPP is conducted a few months behind that of the Bibiyana CCPP and the commercial operation will start in 2013 due to delay of gas supply. Further, the Meghnaghat 450 MW CCPP Unit 2 and 3 were excluded from the Projects List. Re-bidding was planned for the Unit-2 after 2006; however it seems to be cancelled. Thus, the IPP projects in Bangladesh seem to be not going smoothly.

As described above, Bangladesh is facing retirement of some plants and cancellation or delays of the major power plant construction project. If the Bheramra CCPP Project is financed by Japanese ODA Loan and the commercial operation date will start as planned, the Project will make a significant contribution to secure generation capacity in Bangladesh.

Table I-4-3-3 List of power generation development projects (as of August 2008)

| Generating Station  | Type of Fuel | Capacity    | Expected Commissioning date | Source of Fund    |
|---|--------------|-------------|-----------------------------|-------------------|
| <b>Under-construction</b>                                   |              |             |                             |                   |
| Sikalbaha 150 peaking Power Plant                           | Gas          | 150         | FY 2009                     | GOB               |
| Sylhet (Fenchuganj) 90 MW CCPP                              | Gas          | 90          | FY 2008                     | GOB               |
| Siddhirganj 2x120 MW peaking power Plant                    | Gas          | 240         | FY 2009 (Dec/08)            | ADB               |
| <b>Small IPP</b>  |              |             |                             |                   |
| <b>BPDB</b>   |              |             |                             |                   |
| 1. Feni   | Gas          | 22          | January /2009               |                   |
| 2. Tangail  | Gas          | 22          | January /2009               |                   |
| 3. Barabkundu   | Gas          | 22          | January /2009               |                   |
| 4. Jangalia   | Gas          | 33          | January /2009               |                   |
| <b>REB</b>  |              |             |                             |                   |
|   | Gas          | 121         |                             |                   |
| <b>Sub-Total</b>  |              | <b>700</b>  |                             |                   |
| <b>Under Process</b>  |              |             |                             |                   |
| Khulna 150 MW Peaking PP                                    | Gas/Oil      | 150         | December 2010 *1            | ADB               |
| Sirajganj 150 MW Peaking Power Plant                        | Gas          | 150         | June 2013                   | ADB               |
| Chandpur 150 MW CCPP  | Gas          | 150         | June 2012                   | GOB               |
| Sylhet 150 MW CCPP  | Gas          | 150         | June 2010                   | GOB               |
| Horipur 360 MW CCPP   | Gas          | 360         | June 2014                   | JBIC              |
| Siddhirganj 2x150 MW peaking power Plant                    | Gas          | 300         | June 2014                   | WB                |
| Bheramara 360 MW CCPP                                       | Gas          | 360         | September 2014 *2           | JBIC              |
| Bhola 150 MW CCPP   | Gas          | 150         | June 2012                   | IDB               |
| Bibiana 450 MW CC PP IPP                                    | Gas          | 450         | December 2011               | WB                |
| Sirajganj 450 MW Combined Cycle IPP                         | Gas          | 450         | June 2013                   |                   |
| <b>Sub-Total</b>  |              | <b>2670</b> |                             |                   |
| <b>New Addition</b>   |              |             |                             |                   |
| Barapukuria 125 MW ( 3rd Unit ) Coal fired TPS              | Coal         | 125         | FY 2012                     | Supplier's Credit |
| Kaptai Hydro Power Plant extension 2x50 MW (6th & 7th unit) | Hydro        | 100         | FY 2012 (As per DPP)        | (Not yet funded)  |
| <b>Sub-Total</b>  |              | <b>225</b>  |                             |                   |
| <b>Total</b>  |              | <b>3595</b> |                             |                   |

(source) The Study Team made it from the documents of MoPEMR and BPDB.

(Note) \*1: The plant will be operated by diesel oil until June 2013 when the supply of fuel gas is started.

\*2: The expected commissioning date is amended as September 2014 according to the result in Sub-section 4.9.

Table I-4-3-4 List of the retirement plan for the existing thermal power plant

| Retirement Year               | Plant Name        | Output / MW | Efficiency / % | Gas Demand / mmcf/d | Commercial Operation Year |
|-------------------------------|-------------------|-------------|----------------|---------------------|---------------------------|
| Gas fired Thermal Power Plant |                   |             |                |                     |                           |
| 2006                          | Mymensingh IPP    | 140         | -              | 38                  |                           |
| 2007                          | Shahjibazar       | 30          | 20.82          | 10                  | 1968-69                   |
| 2008                          | Ashuganji (ST)    | 120         | 31.92          | 36                  | 1970                      |
|                               | Sylhet            | 19          | 24.64          | 6                   | 1986                      |
| 2010                          | Ashuganji (CC+GT) | 140         | -              | 13                  | 1982-86                   |
|                               | Haripur           | 90          | 23.55          | 18                  | 1987                      |
| 2012                          | Ghorasal          | 37          | 21.60          | 12                  | 1974-76                   |
| 2013                          | Baghabari         | 70          | 29.30          | 17                  | 1991                      |
|                               | Sub-total         | 646         | -              | 150                 |                           |
| Oil fired Thermal Power Plant |                   |             |                |                     |                           |
| 2008                          | Bheramara         | 54          | 24.20          | N/A                 | 1976-80                   |
|                               | Khulna(GT)        | 32          | 22.75          | N/A                 | 1980                      |
| 2009                          | Khulna(ST)        | 47          | 23.57          | N/A                 | 1973                      |
|                               | Sub-total         | 133         | -              | N/A                 |                           |
|                               | Total             | 779         | -              | 150                 |                           |

(source) Study Team makes from Power System Master Plan Update 2006 and the documents provided by BPDB such as Annual Report 2006-2007.

Table I-4-3-5 Balance of power demand and supply

|   | 2008 | 2009 | 2010 | 2011 | 2012  | 2013  | 2014 |
|---|------|------|------|------|-------|-------|------|
| Power Peak Demand (PSMP Base Case) / MW | 5569 | 6066 | 6608 | 7148 | 7732  | 8364  | 9047 |
| Planned Generation Capacity / MW        | 4830 | 5409 | 5709 | 6159 | 6684  | 7284  | 8394 |
| Capacity Shortage / MW                  | -739 | -657 | -899 | -989 | -1048 | -1080 | -653 |

(source) Study Team makes from Power System Master Plan Update 2006 and Table I-4-3-1, Table I-4-3-3.

#### 4.4 Power System Planning

##### 4.4.1 Transmission and substation facilities owned by PGCB

Power Grid Company of Bangladesh Ltd. (PGCB) is in charge of grid planning, construction, operation and maintenance in Bangladesh. Voltage of transmission system is 230kV, 132kV and 66kV at present, and the voltage of Meghnahat – Aminbazar transmission line, which will be constructed in the future, is planned to be 400kV. Table I-4-4-1 and Table I-4-4-2 shows the breakdown of transmission and substation facilities owned by PGCB as of June 2007

respectively.

Table I-4-4-1 Transmission facilities owned by PGCB

|         |                |                |            |
|---------|----------------|----------------|------------|
| Voltage | 230kV          | 132kV          | 66kV       |
| Length  | 1,466.5 ckt km | 5,577.6 ckt km | 167 ckt km |

Table I-4-4-2 Substation facilities owned by PGCB

|          |           |           |            |
|----------|-----------|-----------|------------|
| Voltage  | 230/132kV | 132/66kV  | 66/33/11kV |
| Unit     | 10        | 70        | 2          |
| Capacity | 5,175 MVA | 7,219 MVA | 25.6 MVA   |

In addition, Figure I-4-4-1 shows the grid map of PGCB.

Electric power flows from eastern zone to western zone at present, because almost all power stations are located in the eastern zone of Bangladesh. Example of the result of power flow analysis is shown in Figure I-4-4-2. This figure is the result of power flow analysis of 230kV transmission lines in the last year at peak power generation.





Figure I-4-4-1 Grid map




Figure I-4-4-2 Example of power flow analysis

Table I-4-4-3 shows the investment plan of transmission and substation facilities up to 2012. Following projects are also considered in this study.

Table I-4-4-3 Investment plan of PGCB

|    | Name of the Project  | Estimated cost (MUS\$) |       |        | Expected Completion Year |
|----|--|------------------------|-------|--------|--------------------------|
|    |  | Foreign                | Local | Total  |                          |
| 1  | Shunt Compensation at Grid Substations by Capacitor Banks (Phase -1)   | 11.76                  | 6.53  | 18.29  | 2007-08                  |
| 2  | Ishurdi – Baghabari – Sirajganj - Bogra 230 kV Transmission Line   | 42.28                  | 26.59 | 68.87  | 2008-09                  |
| 3  | National Load Dispatch Centre  | 54.35                  | 37.89 | 92.24  | 2008-09                  |
| 4  | Construction & Extension of Grid Substations including transmission line facilities (Phase-1)  | 57.29                  | 36.37 | 93.66  | 2008-09                  |
| 5  | Naogaon - Niamatpur 132 kV Transmission Line   | -                      | 13.25 | 13.25  | 2008-09                  |
| 6  | Aminbazar - Savar 132 kV Transmission Line   | 7                      | 5     | 12     | 2008-09                  |
| 7  | Ashuganj - Shahjibazar 132 kV single circuit line  | -                      | 2.5   | 2.5    | 2008-09                  |
| 8  | Three Transmission Lines Project.  | 31.94                  | 24.39 | 56.33  | 2009-10                  |
|    | i. Thakurgaon - Panchgar 45 km 132kV Line  |                        |       |        |                          |
|    | ii. Naoga - Joypurhat 40 km 132kV Line   |                        |       |        |                          |
|    | iii. Cuadanga – Jhenaidha - Magura 73 km 132kV Line  |                        |       |        |                          |
| 9  | Meghnaghat - Aminbazar 400 kV Transmission Line  | 22.86                  | 17.39 | 40.25  | 2009-10                  |
| 10 | Aminbazar - Old Airport 230 kV Transmission Line and Associated Substations  | 53.22                  | 40.03 | 93.25  | 2009-10                  |
| 11 | Transmission Efficiency Improvement through Reactive Power Compensation at Grid Substations and Reinforcement of Goalpara Substation | 20.45                  | 13.11 | 33.56  | 2009-10                  |
| 12 | Bhola - Barisal 132 kV Transmission Line   | 18.57                  | 21.43 | 40.00  | 2009-10                  |
| 13 | Chandraghona – Rangamati – Khagrachari 132 kV Transmission Line  | 13.2                   | 10    | 23.2   | 2009-10                  |
| 14 | Sylhet – Shahjibazar - Brahmanbaria 230 kV transmission Line with associated substations   | 71.20                  | 51.32 | 122.52 | 2010-11                  |
| 15 | Ishurdi - Rajshahi 230 kV Transmission Line  | 30                     | 10    | 40     | 2010-11                  |
| 16 | Construction of 230/132 kV Substations at Shyampur, Jhenaidah (or Jessore), Bheramara and Sripur                                     | 50                     | 32    | 82     | 2010-11                  |
| 17 | Raojan – Madunaghat - Sikalbaha 230 kV Transmission Line   | 38                     | 30    | 68     | 2010-11                  |

|    | Name of the Project  | Estimated cost (MUS\$) |       |        | Expected Completion Year |
|----|--|------------------------|-------|--------|--------------------------|
|    |  | Foreign                | Local | Total  |                          |
| 18 | Eight new 132/33 kV S/Ss with Interconnecting 132 kV line (2008-09 to 2010-2011) | 53.383                 | 31.04 | 84.423 | 2010-11                  |
| 19 | Haripur 360 MW Power Plant and Associated Substation Construction Project        | -                      | -     | -      | 2011-12                  |
| 20 | Enhancement of Capacity of Grid Substations and Transmission Line (Phase-I)      | 90                     | 65    | 155    | 2011-12                  |

**4.4.2 Transmission facilities related to this project**

The survey and study of the items related to 230kV line near this project site, new 230kV Bheramara substation and existing 132kV Bheramara substation were carried out.

(1) Present situation of construction of transmission line

Figure I-4-4-3 shows the plan of connection of new Bheramara substation with 230kV transmission line.




Figure I-4-4-3 Overview of transmission system around Bheramara substation

As for the construction of 230kV transmission line, gap conductor stringing at Hardinge Bridge, a part of stringing, etc are already completed.



Figure I-4-4-4 Situation around Bheramara substation

#### 4.4.3 System analysis

The results of system analysis at the operation year of Bheramara power station were confirmed. PGCB uses the software prepared by CYME INTERNATIONAL for the power system.

##### (1) Power flow and voltage analysis

230kV line, which is under construction at present, is connected with new power plant (substation). Following table shows the case of one line fault (N-1) in order to confirm the transmission capacity. Because the thermal capacity of new power station is not determined, expected maximum thermal capacity (575MW), which is severe for transmission capacity, is applied for this study.

| Case | Fault location                            |
|------|---|
| 1    | 230kV Bheramara S/S - 230kV Jhndh S/S     |
| 2    | 230kV Bheramara S/S - 230kV Ishudri S/S   |
| 3    | 230kV Bheramara S/S - 132kV Bheramara S/S |
| 4    | 230kV Bheramara S/S - Bheramara CCPP      |
| 5    | 230kV Ishudri S/S - 230kV Baghabari S/S   |
| 6    | 230kV Ishudri S/S - 230kV Ghorasal S/S    |

As a result, it was confirmed that the fault location between 230kV Bheramara S/S and 230kV Ishudri S/S was most severe case, and that the power flow was 184MW. This amount is less than 60% of transmission capacity (322MW), and it is confirmed that the transmission capacity is enough for power flow.

In addition, it was confirmed that voltage was satisfied with the criteria (between -10% and +10%).

##### (2) Fault current analysis

It was confirmed that maximum fault current at each substation was less than maximum allowable current of circuit breaker.

##### (3) Dynamic stability analysis

Dynamic simulation was carried out in order to confirm the effect of the accident of Bheramara power station. It was confirmed that the result was the same as the effect occurred

by the accident of other power station.

## 4.5 Fuel Supply Planning

### 4.5.1 Gas production volume and forecast of gas reserve

Table I-4-5-1 shows the gas production volume in Bangladesh as of June 2008, gas production volume during the period from 2008 through 2020, and the forecast of gas reserve by fiscal year 2020.

Table I-4-5-1 Gas production volume and forecast of gas reserve (unit: Bcf)

| Company     |              | Recoverable<br>(P1+P2) | Cumulative Production<br>(June 2008) | Remaining Reserve<br>(P1+P2) | Production<br>(2008 - 2020) | Remaining Reserve<br>(P1+P2) (2020) |
|-------------|--------------|------------------------|--------------------------------------|------------------------------|-----------------------------|-------------------------------------|
| Petrobangla | BGFCL        | 10,876.0               | 5,374.1                              | 5,501.9                      | 4,726.0                     | 775.9                               |
|             | SGFL         | 3,476.0                | 914.8                                | 2,561.2                      | 1,799.0                     | 762.2                               |
|             | BAPEX        | 1,015.0                | 105.3                                | 909.7                        | 1,220.0                     | -310.3                              |
| IOC-1       | CHEVRON      | 3,687.0                | 732.9                                | 2,954.1                      | 2,966.0                     | -11.9                               |
|             | CAIRN        | 500.0                  | 439.7                                | 60.3                         | 40.0                        | 20.3                                |
|             | TULLOW       | 305.0                  | 47.3                                 | 257.8                        | 274.0                       | -16.2                               |
|             | NIKO         | 603.0                  | 86.6                                 | 516.4                        | 75.0                        | 441.4                               |
| IOC-2       | Block-5,7,10 | 0                      | 0                                    | 0                            | 621.0                       | 0                                   |
|             | Block-16     | 0                      | 0                                    | 0                            | 329.0                       | 0                                   |
|             | Block-17,18  | 0                      | 0                                    | 0                            | 274.0                       | 0                                   |
| IOC-3       |              | 0                      | 0                                    | 0                            | 949.0                       | 0                                   |
| Total       |              | 20,462.0               | 7,700.7                              | 12,761.4                     | 13,273.0                    | 1,661.4                             |

(source) Petrobangla (July, 2008)

BGFCL, SGFL, and BAPEX as gas producing companies described in Table I-4-5-1 are subsidiaries of Petrobangla, and are financed by the Government of Bangladesh. CHEVRON, CAIRN, TULLOW, and NIKO are the international petroleum and gas companies which are called the International Oil Company (IOC).

The IOC-1 shows the supply plan of private mining companies already under contract. The supply plan is based on P1 (supply probability: 90%) and P2 (supply probability: 50%). And the IOC-1 concluded production sharing agreements with Petrobangla, and the produced gas is sold to Petrobangla.

The IOC-2 shows the individual site (block), year of drilling, and supply volume. The gas reserve has not yet been verified by Petrobangla.

The IOC-3 assumes an offshore supply. The bidding was termed only in May 2008. Similarly to the case of the IOC-2, the year of drilling and supply volume are shown. The gas reserve has not been verified by Petrobangla.

The remaining reserve (P1+P2) of IOC-2 and IOC-3 is not verified by Petrobangla. Thus, total of gas reserve in Bangladesh in fiscal year 2020 is total of Petrobangla and IOC-1.

### 4.5.2 Forecast of gas supply volume and gas demand

Table I-4-5-2 shows the forecast of gas supply volume during the period from 2008 through 2020 in Bangladesh. According to the gas supply volume forecast by Petrobangla for the IOC-2 and IOC-3 where the individual site (Block) and the year of drilling have not yet been verified, gas supply can be started in 2011 for the IOC-2 and in 2014 for the IOC-3.

Table I-4-5-2 Forecast of gas supply volume (Daily maximum supply volume, unit: mmcf/d)

| Company     | 2008-09      | 2009-10 | 2010-11 | 2011-12 | 2012-13 | 2013-14 | 2014-15 | 2015-16 | 2016-17 | 2017-18 | 2018-19 | 2019-20 |       |
|-------------|--------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|-------|
| Petrobangla | BGFCL        | 782     | 817     | 907     | 976     | 1,090   | 1,079   | 1,091   | 1,100   | 1,100   | 1,095   | 1,095   | 1,095 |
|             | SGFL         | 180     | 190     | 222     | 280     | 320     | 350     | 430     | 480     | 540     | 590     | 590     | 590   |
|             | BAPEX        | 53      | 112     | 185     | 230     | 260     | 328     | 348     | 345     | 365     | 364     | 363     | 363   |
| IOC-1       | CHEVRON      | 830     | 760     | 740     | 710     | 680     | 650     | 620     | 590     | 540     | 480     | 420     | 370   |
|             | CAIRN        | 50      | 0       | 0       | 0       | 0       | 0       | 0       | 0       | 0       | 0       | 0       | 0     |
|             | TULLOW       | 100     | 100     | 60      | 60      | 60      | 60      | 60      | 60      | 60      | 60      | 0       | 0     |
|             | NIKO         | 45      | 45      | 55      | 55      | 75      | 75      | 50      | 50      | 50      | 50      | 50      | 50    |
| IOC-2       | Block-5,7,10 | 0       | 0       | 0       | 100     | 200     | 200     | 200     | 200     | 200     | 200     | 200     | 200   |
|             | Block-16     | 0       | 0       | 0       | 100     | 100     | 100     | 100     | 100     | 100     | 100     | 100     | 100   |
|             | Block-17,18  | 0       | 0       | 0       | 0       | 50      | 100     | 100     | 100     | 100     | 100     | 100     | 100   |
| IOC-3       | 0            | 0       | 0       | 0       | 0       | 0       | 300     | 300     | 500     | 500     | 500     | 500     |       |
| Total       | 2,040        | 2,024   | 2,169   | 2,511   | 2,835   | 2,942   | 3,299   | 3,325   | 3,555   | 3,539   | 3,418   | 3,368   |       |

(source) Petrobangla (July, 2008)

Table I-4-5-3 shows the gas demand forecast in Bangladesh during the period from 2008 through 2020.

According to the gas demand forecast by Petrobangla, during the period from 2008 through 2020, the demand in each field is represented as about 52 % for electric power, about 10 % for household consumption, and about 9 % for fertilizer.

The average annual growth rate in each field is shown as 7.82 % for electric power, 0.08 % for household consumption, and 0.02 % for fertilizer during the period from 2008 through 2020.

Table I-4-5-3 Forecast of gas demand volume (Daily maximum demand volume, unit: mmcf/d)

| Company             | Category      | 2008-09       | 2009-10       | 2010-11       | 2011-12       | 2012-13       | 2013-14       | 2014-15       | 2015-16       | 2016-17       | 2017-18       | 2018-19       | 2019-20 |
|---------------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------|
| BGSL                | Power         | 138.3         | 148.3         | 183.3         | 218.3         | 218.3         | 218.3         | 218.3         | 218.3         | 218.3         | 218.3         | 218.3         | 218.3   |
|                     | Captive       | 29.6          | 32.0          | 34.5          | 37.3          | 40.3          | 43.5          | 47.0          | 50.7          | 54.8          | 59.2          | 63.9          | 69.0    |
|                     | Fertilizer    | 120.0         | 120.0         | 120.0         | 120.0         | 120.0         | 120.0         | 120.0         | 120.0         | 120.0         | 120.0         | 120.0         | 120.0   |
|                     | Non-Bulk      | 122.7         | 132.5         | 143.1         | 154.6         | 166.9         | 180.3         | 194.7         | 210.3         | 227.1         | 245.3         | 264.9         | 286.1   |
|                     | Sub-total     | 410.6         | 432.8         | 480.9         | 530.2         | 545.5         | 562.1         | 580.0         | 599.3         | 620.2         | 642.8         | 667.1         | 693.4   |
| JGTDSL              | Power         | 136.7         | 166.7         | 241.7         | 205.7         | 205.7         | 205.7         | 205.7         | 205.7         | 205.7         | 205.7         | 205.7         | 205.7   |
|                     | Captive       | 5.8           | 6.2           | 6.7           | 6.9           | 7.0           | 7.2           | 7.4           | 7.6           | 7.8           | 8.0           | 8.3           | 8.5     |
|                     | Fertilizer    | 15.0          | 15.0          | 25.0          | 25.0          | 25.0          | 25.0          | 25.0          | 25.0          | 25.0          | 25.0          | 25.0          | 25.0    |
|                     | Non-Bulk      | 33.5          | 36.2          | 39.1          | 42.2          | 45.6          | 49.2          | 53.2          | 57.4          | 62.0          | 67.0          | 72.3          | 78.1    |
|                     | Sub-total     | 191.0         | 224.1         | 312.5         | 279.8         | 283.3         | 287.1         | 291.3         | 295.7         | 300.5         | 305.7         | 311.3         | 317.3   |
| PGCL                | Power         | 85.0          | 85.0          | 200.0         | 200.0         | 200.0         | 200.0         | 200.0         | 200.0         | 200.0         | 200.0         | 200.0         | 200.0   |
|                     | Captive       | 4.0           | 4.8           | 5.8           | 6.9           | 8.3           | 10.0          | 11.9          | 14.3          | 17.2          | 20.6          | 24.8          | 29.7    |
|                     | Fertilizer    | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0     |
|                     | Non-Bulk      | 11.0          | 13.2          | 15.8          | 19.0          | 22.8          | 27.4          | 32.9          | 39.4          | 47.3          | 56.8          | 68.1          | 81.7    |
|                     | Sub-total     | 100.0         | 103.0         | 221.6         | 225.9         | 231.1         | 237.4         | 244.8         | 252.7         | 262.2         | 272.6         | 284.9         | 311.4   |
| TGTDCI              | Power         | 75.0          | 86.0          | 98.0          | 114.0         | 116.0         | 117.0         | 120.0         | 128.0         | 133.0         | 135.0         | 143.0         | 152.0   |
|                     | Captive       | 198.1         | 213.9         | 231.0         | 249.5         | 269.5         | 291.0         | 314.3         | 339.5         | 366.6         | 395.9         | 427.6         | 461.8   |
|                     | Fertilizer    | 155.0         | 155.0         | 155.0         | 155.0         | 155.0         | 155.0         | 155.0         | 155.0         | 155.0         | 155.0         | 155.0         | 155.0   |
|                     | Non-Bulk      | 551.4         | 595.6         | 643.2         | 694.7         | 750.2         | 810.3         | 875.1         | 945.1         | 1020.7        | 1102.3        | 1190.5        | 1285.8  |
|                     | Sub-total     | 1661.5        | 1827.5        | 2011.2        | 2246.2        | 2336.7        | 2435.3        | 2614.4        | 2727.6        | 2873.3        | 3009.2        | 3266.1        | 3425.6  |
| SGCL                | Power         | 0.0           | 0.0           | 135.0         | 135.0         | 298.0         | 298.0         | 298.0         | 298.0         | 298.0         | 298.0         | 298.0         | 298.0   |
|                     | Captive       | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0     |
|                     | Fertilizer    | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0           | 0.0     |
|                     | Non-Bulk      | 0.0           | 0.0           | 14.0          | 15.1          | 16.3          | 17.6          | 19.1          | 20.6          | 22.2          | 24.0          | 25.9          | 28.0    |
|                     | Sub-total     | 0.0           | 0.0           | 149.0         | 150.1         | 314.3         | 315.6         | 317.1         | 318.6         | 320.2         | 322.0         | 323.9         | 326.0   |
| <b>Total Demand</b> | <b>2363.1</b> | <b>2587.4</b> | <b>3175.2</b> | <b>3432.2</b> | <b>3710.9</b> | <b>3837.5</b> | <b>4047.6</b> | <b>4264.9</b> | <b>4448.7</b> | <b>4627.1</b> | <b>4931.3</b> | <b>5143.7</b> |         |

(source) Petrobangla (July, 2008)

Lastly, Figure I-4-5-1 shows a summary of the gas supply and demand forecast.


In the Petrobangla project on July 2008 (line: total demand), the forecast of gas demand is much higher than the forecast of gas supply even when all the supply plans of Petrobangla, IOC-1, IOC-2 and IOC-3 have been completed.

Meanwhile, MoPEMR readjusted that postpone of gas supply for new gas thermal power plant as shown on Table I-4-5-4. The forecast of gas demand for electric power (line: total demand (adjusted by Study Team)) according to this readjustment, the forecast of gas supply is slightly lower than the forecast of gas demand when Bheramara CCPP will commence commercial operation in the vicinity of 2014 if all the supply plans of Petrobangla, IOC-1, IOC-2, and IOC-3 have been achieved. This forecast of gas demand indicates maximum gas demand. Thus, it is hard to say that there is shortage of gas supply at any time and if the gas could be supplied to efficient thermal power plants when peak of gas demand, the Study Team deems that it is

possible to supply gas for Bheramara CCPP.

After fiscal year in 2017, if there is gas supply plan just indicated on Table I-4-5-2, the gas supply volume will be decreasing. Thus, the Study Team deems that it is necessary to ensure exploration and development of new gas fields should be accelerated except for planning.

In addition, the result of economic evaluation for prioritizing gas supply to Bheramara CCPP by management team is described on Volume II 9.3.2 Gas Shortage.



(source) Petrobangla (July, 2008)

(Total Demand (Adjusted by Study Team) was made by the Study Team)

Figure I-4-5-1 Forecast of gas demand and supply



Table I-4-5-4 Period of gas supply for new gas thermal power Plant

| No. | Generating Station                       | Type of Fuel | Expected Commissioning date by BPDB | Revised Commissioning date by MoPEMR | Gas Demand (mmcf/d) |
|-----|--|--------------|-------------------------------------|--------------------------------------|---------------------|
| 1   | Sikalbaha 150 peaking Power Plant        | Gas          | FY 2009                             | FY 2012                              | 35                  |
| 2   | Siddhirganj 2x120 MW peaking power Plant | Gas          | FY 2008                             | FY 2008                              | 65                  |
| 3   | Khulna 150 MW Peaking PP                 | Gas/Oil      | FY 2010                             | FY 2013                              | 35                  |
| 4   | Sirajganj 150 MW Peaking Power Plant     | Gas          | FY 2010                             | FY 2013                              | 35                  |
| 5   | Chandpur 150 MW CCPP                     | Gas          | FY 2010                             | FY 2012                              | 30                  |
| 6   | Sylhet 150 MW CCPP                       | Gas          | FY 2010                             | FY 2010                              | 30                  |
| 7   | Haripur 360 MW CCPP                      | Gas          | FY 2012                             | FY 2014                              | 55                  |
| 8   | Siddhirganj 2x150 MW peaking power Plant | Gas          | FY 2010                             | FY 2014                              | 70                  |
| 9   | 210 MW Khulna Thermal Power Station      | Gas/Oil      | FY 2011                             | Cancel                               |                     |
| 10  | Bheramara 360 CCPP                       | Gas          | FY 2012                             | FY 2016                              | 55                  |
| 11  | Bhola 150 MW CCPP                        | Gas          | FY 2011                             | FY 2012                              | 30                  |
| 12  | Bibiana 450 MW CCPP IPP                  | Gas          | FY 2010                             | FY 2011                              | 75                  |
| 13  | Sirajganj 450 MW Combined Cycle IPP      | Gas          | FY 2010                             | FY 2013                              | 75                  |
|     | Total                                    |              |                                     |                                      | 590                 |

(source) MoPEMR (August, 2008)

#### 4.5.3 Gas pipeline construction project

Figure I-4-5-2 shows the gas pipeline route under construction financed by ADB. Much of the gas being produced in Bangladesh is located in the northeastern region. Thus, when the ADB financed gas pipeline is used to transport the gas produced in the northeastern region to the western or southwestern region where Bheramara CCPP is located, gas pressure may be reduced because of the pressure loss of the gas pipe line, and gas may not be easily supplied to the gas consumers including the Bheramara CCPP.

To solve this problem, the ADB loan includes the plan for the construction of gas compressors in Ashuganj and Elenga so as to solve the problem of insufficient gas supply pressure.


It has been confirmed that construction of the gas pipe line (up to Khulna) and gas compressors will be completed by 2011.

Gas is supplied to the Bheramara CCPP through a gas pipeline which is branched off from some midpoint (between Ishwardi and Kushtia) of a 240 km, 30 inch gas pipeline which is laid between Hatikumrul and Khulna.

The new gas thermal power plants, Bheramara CCPP, Khulna 150 MW Peaking PP, Sirajganj 150 MW Peaking Plant and Sirajganj 450 MW Combined Cycle IPP will be constructed down the stream of Elenga, and the total gas demand of these new thermal power plants included Bheramra CCPP will be 200 mmcf/d.

Khulna 150 MW Peaking PP is dual firing thermal power plant. Thus, in case of Khulna 150 MW Peaking PP is operated by oil, total gas demand is 170 mmcf/d.

The maximum gas supply capacity of the 30 inch gas pipeline is about 350 mmcf/d. Thus, if Khulna 150 MW Peaking PP is operated by oil and there are affect the supply of gas to household consumptions, it seems to be possible to supply of gas to the Bheramara CCPP that requires 55 mmcf/d.



(source) Petrobangla

Figure I-4-5-2 Gas Transmission Network in Bangladesh

#### 4.5.4 Possibility of gas supply to the Bheramara CCPP

As indicated in section 4.5.2, since there is concern about insufficient gas supply in Bangladesh, the Study Team make a judgment that it is necessary to ensure stable gas supply to the Bheramara CCPP which is planned to commence commercial operation in 2014, the Government of Bangladesh should set up a policy as followings.

- Exploration and development of new gas fields should be accelerated.
- Gas should be supplied to efficient thermal power plants, especially CCPP with priority.
- Old and low efficient gas thermal power plants should be stopped, if required after the high efficient thermal power plants such as Haripur and Bheramara CCPPs will be put into operation.
- A long term agreement stipulated minimum gas supply should be signed.

List of old and low efficient gas thermal power plants should be stopped to supply gas to high efficient thermal power plants such as Bheramara CCPP with priority is described in section 4.3.3.

The Study Team make a judgment that it is necessary to be stopped the existing gas thermal power plants considering following items.

- Management policy of power plants
- Construction plan of new gas thermal power plants
- Efficiency of thermal power plants
- System stability
- Balance of gas supply and gas demand

#### 4.5.5 Supply of fuel oil to Bheramara CCPP

The Study Team has concern about insufficient gas supply for Bheramara CCPP, we survey and study the possibility of supplying fuel oil to Bheramara CCPP.

All the fuel oil used in Bangladesh is imported from abroad. The HSD to be used in the Bheramara CCPP is imported from the Middle East. The major storage tanks are located in Chittagong, Bagabari, and Khulna. The recent demand for fuel oil remains flat.

The fuel oil rate is determined by the Government of Bangladesh. The heavy oil rate in Bangladesh is less than 50 % of the market price, and the light oil rate is about 50 % of the market price.

At present, the Bheramara CCPP is provided with HSD tanks (3,000 KL x 2 tanks) to supply fuel to the existing power plant. HSD is transported from the Khulna to these tanks by railway (maximum carrying capacity: 50 m<sup>3</sup> (42.5 KL) @0.85kg/m<sup>3</sup>).

The Bheramra CCPP will use HSD for emergency and not in a continuous basis from technical and economical points of view as followings and described on section 4.7.1;

- Bangladesh Petroleum Corporation (BPC) should import more HSD from abroad. (2,000 KL/day x 365 days = 730,000 KL/year)
- BPC should prepare tanker for importing HSD.
- BPC should construct HSD storage tank in Khulna.
- The railway company should upgrade (40 kL x 25 vehicles x 2 trains = 2,000 kL) the existing railway for transportation of HSD from Khulna to Bheramara CCPP.
- Two (2) Large HSD storage tanks having a capacity of 50,000 kL and HSD unloading facilities should be constructed at Bheramara CCPP.
- It is necessary to huge investment for above-mentioned.