

**THE STUDY FOR  
SUSTAINABLE RURAL WATER SUPPLY SYSTEM  
IN THE SOUTHERN KHATLON OBLAST  
IN  
THE REPUBLIC OF TAJIKISTAN**

**FINAL REPORT**

**SUPPORTING REPORT**

**APRIL 2009**

**JAPAN INTERNATIONAL COOPERATION AGENCY**

**EARTH SYSTEM SCIENCE CO., LTD.**

**JAPAN TECHNO CO., LTD.**

**THE STUDY FOR  
SUSTAINABLE RURAL WATER SUPPLY SYSTEM  
IN THE SOUTHERN KHATLON OBLAST  
IN  
THE REPUBLIC OF TAJIKISTAN**

**FINAL REPORT**

**SUPPORTING REPORT**

**APRIL 2009**

**JAPAN INTERNATIONAL COOPERATION AGENCY**

**EARTH SYSTEM SCIENCE CO., LTD.**

**JAPAN TECHNO CO., LTD.**

**TABLE OF CONTENTS – FINAL REPORT**  
**- SUPPORTING REPORT -**

- 1      CHAPTER 3      CURRENT SITUATION AND DEVELOPMENT ISSUES ON  
THE VAKHSH CONDUITS**
- Attached Tables
- 2      CHAPTER 4      EXISTING CONDITION AND DEVELOPMENT ISSUES OF  
RURAL WATER SUPPLY SYSTEM**
- Appendix-1      Inventory Survey Sheet  
Appendix-2      Rural Water Supply System Survey Sheet  
Appendix-3      Data Base of Rural Water Supply System  
Attached Tables  
Attached Figures
- 3      CHAPTER 8      REHABILITATION AND EXPANSION PLAN OF THE  
VAKHSH CONDUITS**
- Appendix      Rehabilitation and Expansion Plan of the Vakhsh Conduits  
Attached Tables  
Attached Figures
- 4      CHAPTER 9      REHABILITATION AND EXPANSION PLAN OF RURAL  
WATER SUPPLY SYSTEM**
- Attached Figures  
(1) Results of Pumping Test  
(2) Rehabilitation and Extension Plan  
(3) Design of Facility Structure
- 5      MANUAL FOR OPERATION AND MAINTENANCE OF RURAL WATER  
SUPPLY SYSTEMS**

## LIST OF TABLES – FINAL REPORT

### **1      CHAPTER 3      CURRENT SITUATION AND DEVELOPMENT ISSUES ON THE VAKHSH CONDUITS**

Attached Table 3.1	Pressure and Head of Junctions in the Hydraulic Model -----	3 - 1
Attached Table 3.2	Pipe Inner Flow of Vakhsh Conduits Hydraulic Model on the Condition that the Inflow to Tanks is not Regulated -----	3 - 5
Attached Table 3.3	Base Demands in 2027 on the Vakhsh Conduits Hydraulic Model and Output of the Analysis -----	3 - 9

### **2      CHAPTER 4      EXISTING CONDITION AND DEVELOPMENT ISSUES OF RURAL WATER SUPPLY SYSTEM**

Attached Table 4.1	Rural Water Supply System Survey Sheet (K1 Lenin, Dushra, Azizov Sino)	4 - 10
Attached Table 4.2	Rural Water Supply System Survey Sheet (K2 Yangi Yul) -----	4 - 11
Attached Table 4.3	Rural Water Supply System Survey Sheet (K4 Khaeti Nav) -----	4 - 12
Attached Table 4.4	Rural Water Supply System Survey Sheet (K5 Navruz) -----	4 - 13
Attached Table 4.5	Rural Water Supply System Survey Sheet (K7 Jarkurgan) -----	4 - 14
Attached Table 4.6	Rural Water Supply System Survey Sheet (K9 Uchi Kabda) -----	4 - 15
Attached Table 4.7	Rural Water Supply System Survey Sheet (K10 Kalinin) -----	4 - 16
Attached Table 4.8	Rural Water Supply System Survey Sheet (K11 Borshevik) -----	4 - 17
Attached Table 4.9	Rural Water Supply System Survey Sheet (K12 Tsorbogy Ziraki) -----	4 - 18
Attached Table 4.10	Rural Water Supply System Survey Sheet (K13 Kalinin) -----	4 - 19
Attached Table 4.11	Rural Water Supply System Survey Sheet (S2 Rudaki) -----	4 - 20
Attached Table 4.12	Rural Water Supply System Survey Sheet (S4 Batan) -----	4 - 21
Attached Table 4.13	Rural Water Supply System Survey Sheet (S5 Sultanobod) -----	4 - 22
Attached Table 4.14	Rural Water Supply System Survey Sheet (S9 Binokor) -----	4 - 23
Attached Table 4.15	Rural Water Supply System Survey Sheet (N1 44-Chashma 01tinsoy) -----	4 - 24
Attached Table 4.16	Rural Water Supply System Survey Sheet (N2 Alfa Ferma) -----	4 - 25
Attached Table 4.17	Rural Water Supply System Survey Sheet (P1 Utsastok Tugul) -----	4 - 26
Attached Table 4.18	Rural Water Supply System Survey Sheet (P5 Komsomol) -----	4 - 27
Attached Table 4.19	Rural Water Supply System Survey Sheet (P6 Utsastok Pekhtakor) -----	4 - 28
Attached Table 4.20	Rural Water Supply System Survey Sheet (P9 Utsastok Zarbdor) -----	4 - 29
Attached Table 4.21	Rural Water Supply System Survey Sheet (P11 Utsastok Shakardasht) ----	4 - 30
Attached Table 4.22	Rural Water Supply System Survey Sheet (P12 Utsastok Shakardasht) ----	4 - 31
Attached Table 4.23	Rural Water Supply System Survey Sheet (P13 Sarmantoi) -----	4 - 32
Attached Table 4.24	Rural Water Supply System Survey Sheet (P14 Utsastok M. Gorikiy) ----	4 - 33
Attached Table 4.25	Rural Water Supply System Survey Sheet (P15 Utsastok Burka)-----	4 - 34



Attached Table 8.31	Valves List for Water Pipe Bridges of Vakhsh Conduit -----	8 - 69
Attached Table 8.32	Basic Specification of Stopping and Control Valves -----	8 - 30
Attached Table 8.33	Projected Distribution Pipe Length of the WSSs in the Vakhsh Rayon -----	8 - 72
Attached Table 8.34	Projected Distribution Pipe Length of the WSSs in the Kolkhozobo Rayon -----	8 - 74
Attached Table 8.35	Projected Distribution Pipe Length of the WSSs in the Dzhilikul Rayon -----	8 - 83
Attached Table 8.36	Projected Distribution Pipe Length of the WSSs in the Kumsangir Rayon -----	8 - 86
Attached Table 8.37	Required Dimensions of Facilities and Land -----	8 - 37
Attached Table 8.38	Typical Sedimentation Basin -----	8 - 37
Attached Table 8.39	Typical Filtration Basin (Filtration Speed Max.150m/day: Except 1 Standby Basin and Other 10% of Standby Capacity) -----	8 - 38
Attached Table 8.40	Distribution Reservoir -----	8 - 38
Attached Table 8.41	Other facilities: Sand Settlement Basin -----	8 - 38
Attached Table 8.42	Other facilities: Receiving Basin (Retention time 1.5min) -----	8 - 39

## LIST OF FIGURES – SUPPORTING REPORT

### **2      CHAPTER 4      EXISTING CONDITION AND DEVELOPMENT ISSUES OF RURAL WATER SUPPLY SYSTEM**

Figure 4.1	Structure of Database System -----	4 - 38
Attached Figure 4.2	Start Format -----	4 - 41
Attached Figure 4.3	Facility Data Sheet 1 -----	4 - 42
Attached Figure 4.4	Facility Data Sheet 2 -----	4 - 43
Attached Figure 4.5	Facility Data Sheet 3.1 -----	4 - 44
Attached Figure 4.6	Facility Data Sheet 3.2 -----	4 - 45
Attached Figure 4.7	Facility Data Sheet 4 -----	4 - 46
Attached Figure 4.8	Facility Data Sheet 5 -----	4 - 47

### **3      CHAPTER 8      REHABILITATION AND EXPANSION PLAN OF THE VAKHSH CONDUITS**

Attached Figure 8.1.4	Valves Location of Junction Points on the Vakhsh Conduits -----	8 - 31
Attached Figure 8.1.5	General Structure of Water Pipe Bridge -----	8 - 32
Attached Figure 8.1.6	Single Diagram of Water Treatment Plant of TV15 -----	8 - 88
Attached Figure 8.1.7	Concept Design of Control Flow of Water Treatment Plant -----	8 - 89
Attached Figure 8.1.8	Site Plan (Facility Arrangement Plan) Type A/B -----	8 - 90
Attached Figure 8.1.9	Site Plan (Facility Arrangement Plan) Type C/D -----	8 - 91
Attached Figure 8.1.10	Coagulation and Sedimentation Type A/B/C -----	8 - 92
Attached Figure 8.1.11	Rapid Filtration Basin Type A and B -----	8 - 93
Attached Figure 8.1.12	Rapid Filtration Basin Type C -----	8 - 94
Attached Figure 8.1.13	Rapid Filtration Basin Type D -----	8 - 95
Attached Figure 8.1.14	Distribution Reservoir Type A/B and C -----	8 - 96

### **4      CHAPTER 9      REHABILITATION AND EXPANSION PLAN OF RURAL WATER SUPPLY SYSTEM**

Attached Figure 9.1	Result of the Pumping Test (K-2 Yangi Yul) -----	9 - 1
Attached Figure 9.2	Result of the Pumping Test (K-5 Navrus) -----	9 - 2
Attached Figure 9.3	Result of the Pumping Test (K-3 Kabla) -----	9 - 3
Attached Figure 9.4	Result of the Pumping Test (K-11 Bolshevik) -----	9 - 4
Attached Figure 9.5	Result of the Pumping Test (N-1 44-Chashma) -----	9 - 5
Attached Figure 9.6	Result of the Pumping Test (S-4 Vatan) -----	9 - 6
Attached Figure 9.7	Result of the Pumping Test (S-5 Sultanobod) -----	9 - 7

Attached Figure 9.8	Result of the Pumping Test (S-9 Binokor)	9 - 8
Attached Figure 9.9	Result of the Pumping Test (P-13 Sarmantoy)	9 - 9
Attached Figure 9.10	Rehabilitation and Extension Plan (K-2 Yangi Yul)	9 - 10
Attached Figure 9.11	Rehabilitation and Extension Plan (K-5 Navrus)	9 - 11
Attached Figure 9.12	Rehabilitation and Extension Plan (K-7 Jarkurgan)	9 - 12
Attached Figure 9.13	Rehabilitation and Extension Plan (K-9 (1/2) Kabla)	9 - 13
Attached Figure 9.13	Rehabilitation and Extension Plan (K-9 (2/2) Boshkala)	9 - 14
Attached Figure 9.14	Rehabilitation and Extension Plan (K-11 Bolshevik)	9 - 15
Attached Figure 9.15	Rehabilitation and Extension Plan (N-1(1/4) Oltinsoy)	9 - 16
Attached Figure 9.15	Rehabilitation and Extension Plan (N-1(2/4) Olzu)	9 - 17
Attached Figure 9.15	Rehabilitation and Extension Plan (N-1(3/4) Bahor)	9 - 18
Attached Figure 9.15	Rehabilitation and Extension Plan (N-1(4/4) Traganov)	9 - 19
Attached Figure 9.16	Rehabilitation and Extension Plan (S-4 Vatan)	9 - 20
Attached Figure 9.17	Rehabilitation and Extension Plan (S-5(1/2) Sultanabod)	9 - 21
Attached Figure 9.17	Rehabilitation and Extension Plan (S-5 (2/2) Yangabod)	9 - 22
Attached Figure 9-18	Rehabilitation and Extension Plan (S-9 Binokor)	9 - 23
Attached Figure 9-19	Rehabilitation and Extension Plan (P-13(1/2) Sarmantoy-1)	9 - 24
Attached Figure 9-19	Rehabilitation and Extension Plan (P-13(2/2) Sarmantoy-2)	9 - 25
Attached Figure 9-20	Design of Borehole	9 - 26
Attached Figure 9-21	Design of Control House	9 - 27
Attached Figure 9-22	Design of Elevated Water Tank (H=10m)	9 - 28
Attached Figure 9-23	Design of Semi-Underground Water Tank (60m <sup>3</sup> )	9 - 29
Attached Figure 9-24	Design of Public Water Tap	9 - 30

**1 CHAPTER 3 CURRENT SITUATION AND  
DEVELOPMENT ISSUES ON  
THE VAKHSH CONDUITS**

***Attached Tables***

Attached Table 3.1 Pressure and Head of Junctions in the Hydraulic Model

continued(1/4)

Junction ID	Elevation	Actual Demand	Head	Pressure	Remark
	m	LPS	m	m	
A01	439	0.00	443.07	4.07	
A02	429	0.00	439.45	10.45	
A03	426	0.00	436.50	10.50	
A04(valve)	424	0.00	434.64	10.64	
AB04	423	0.66	435.15	12.15	
B01	417	0.00	433.79	16.79	
B02	417	0.00	433.75	16.75	
B03	414	0.00	433.63	19.63	
B04	410	0.00	433.32	23.32	
B05	402	0.00	430.05	28.05	
B06	403	0.00	430.03	27.03	
B07	401	0.00	429.45	28.45	
B08	408	0.00	427.64	19.64	
B09	402	0.00	427.61	25.61	
B10	406	0.00	427.54	21.54	
B11	397	0.00	427.25	30.25	
B12	400	0.00	424.24	24.24	
B13	394	0.00	423.57	29.57	
B14	392	0.00	419.41	27.41	
B15	390	0.00	415.72	25.72	
B16	381	0.00	411.83	30.83	
B18	387	0.00	403.38	16.38	
B19	384	0.00	403.10	19.10	
B20	391	0.00	403.03	12.03	
B21	389	0.00	402.99	13.99	
B22	386	0.00	402.57	16.57	
B24	364	0.00	383.32	19.32	
B25	364	0.00	382.19	18.19	
B26	364	0.00	382.04	18.04	
B27	364	0.00	382.03	18.03	
B28V	366	0.00	381.99	15.99	
BB01	386	0.00	411.83	25.83	
BB06	384	0.03	408.07	24.07	
BB10	404	1.17	429.38	25.38	
BB11	397	0.69	427.18	30.18	
BB12	390	1.62	419.33	29.33	
BB13	402	0.93	427.12	25.12	
BB14	395	2.32	423.84	28.84	
BB19	400	1.22	427.38	27.38	
BB20	389	0.00	393.00	4.00	
BB21	388	0.36	403.38	15.38	
BB22	382	0.08	411.83	29.83	
BR02	369	2.00	382.96	13.96	
BR03	367	2.77	383.26	16.26	
BR12	372	2.00	382.79	10.79	
BR13	369	0.00	383.32	14.32	
BR14	369	0.00	383.32	14.32	
BR23	363	0.00	383.32	20.32	
BR25	369	2.45	383.12	14.12	
BR28	370	7.17	383.01	13.01	
BR35	367	2.82	383.31	16.31	
BR36	367	5.23	378.16	11.16	
BR39	367	0.00	383.32	16.32	
BV11	410	1.09	433.05	23.05	
BV12	394	0.36	423.24	29.24	
BV14	390	0.00	415.72	25.72	
C01	421	0.00	433.56	12.56	
C02	427	0.00	433.51	6.51	

Attached Table 3.1 Pressure and Head of Junctions in the Hydraulic Model

continued(2/4)

Junction ID	Elevation	Actual Demand	Head	Pressure	Remark
	m	LPS	m	m	
C03	414	0.00	433.07	19.07	
C04	421	0.00	431.48	10.48	
C05	417	0.00	430.99	13.99	
C06	425	0.00	430.37	5.37	
C07	420	0.00	428.24	8.24	
C08	419	0.00	426.12	7.12	
C09	416	0.00	425.75	9.75	
C10	413	0.00	425.56	12.56	
C11	410	0.00	424.34	14.34	
C12	415	0.00	424.20	9.20	
C13(valve)	420	0.00	424.00	4.00	
C14	418	0.00	424.00	6.00	
C15	417	0.00	424.00	7.00	
C17	406	0.00	424.00	18.00	
C18	415	0.00	424.00	9.00	
CB02	415	0.57	423.99	8.99	
CB03	414	0.09	432.64	18.64	
CB05	422	0.69	425.40	3.40	
CB07	420	0.00	420.00	0.00	
CB08	415	0.87	426.02	11.02	
CB09	409	0.91	424.15	15.15	
CB15	410	0.06	423.78	13.78	
CB16	410	0.03	424.32	14.32	
CB17	417	0.03	430.98	13.98	
CB18	418	0.69	427.48	9.48	
CB23	411	0.51	425.45	14.45	
CB24	413	0.00	424.00	11.00	
CB25	425	0.00	429.00	4.00	
CV13	421	0.18	430.53	9.53	
CV15	422	0.00	433.51	11.51	
D01(valve)	359	0.00	374.55	15.55	
D02	366	0.00	372.82	6.82	
D03	362	0.00	366.79	4.79	
D04	363	0.00	366.79	3.79	
D05	356	0.00	364.28	8.28	
D06	355	0.00	357.41	2.41	
D07	355	0.00	357.26	2.26	
D08	355	0.00	355.01	0.01	
D09	353	0.00	354.53	1.53	
D10	350	0.00	353.54	3.54	
D11	341	0.00	351.84	10.84	
DJ01	355	0.88	357.26	2.26	
DJ02	355	0.00	355.01	0.01	
DJ03	362	0.44	366.79	4.79	
DJ04	363	0.52	366.78	3.78	
DJ05	350	1.43	353.53	3.53	
DJ06	355	0.52	357.40	2.40	
DJ07	353	0.00	354.53	1.53	
DJ09	341	0.00	351.84	10.84	
DJ11	355	0.00	357.41	2.41	
DR24	366	2.00	372.70	6.70	
E01	373	0.00	379.88	6.88	
E02	375	0.00	379.39	4.39	

Attached Table 3.1 Pressure and Head of Junctions in the Hydraulic Model

continued(3/4)

Junction ID	Elevation	Actual Demand	Head	Pressure	Remark
	m	LPS	m	m	
E03	375	0.00	378.95	3.95	
E04	378	0.00	378.84	0.84	
E05	378	0.00	378.84	0.84	
E06	372	0.00	378.83	6.83	
E07	369	0.00	378.82	9.82	
E08	368	0.00	378.82	10.82	
E09	384	0.00	378.82	-5.18	
E10	381	0.00	378.81	-2.19	
E11(valve)	381	0.00	378.81	-2.19	
E12	378	0.00	378.81	0.81	
E13	379	0.00	378.81	-0.19	
ER01	384	0.00	378.82	-	out of operation
ER04	375	2.16	378.66	3.66	
ER05	386	0.00	378.81	-	There's no flow.
ER06	370	0.00	378.81	8.81	
ER10	372	1.86	378.95	6.95	
ER11	367	5.81	377.17	10.17	
ER16	369	0.46	378.82	9.82	
ER18	368	2.58	378.78	10.78	
ER27	369	0.00	372.50	3.50	
ER29	369	6.85	378.72	9.72	
ER30	370	0.00	378.81	8.81	
ER32	372	1.39	378.66	6.66	
ER33	371	1.19	376.36	5.36	
<b>ER37</b>	378	0.00	378.81	0.81	There's no flow.
<b>ER38</b>	378	0.00	378.81	0.81	There's no flow.
F01	376	0.00	-	-	There's no flow.
F02	377	0.00	-	-	There's no flow.
F03	377	0.00	-	-	There's no flow.
F04	385	0.00	-	-	There's no flow.
F05P	382	0.00	-	-	There's no flow.
FR07	385	0.00	-	-	There's no flow.
FR15	387	0.00	-	-	There's no flow.
FR19	377	0.00	-	-	There's no flow.
FR26	385	0.00	-	-	There's no flow.
FR34	375	0.00	-	-	There's no flow.
G01	383	0.00	-	-	There's no flow.
G02	390	0.00	-	-	There's no flow.
G03	388	0.00	-	-	There's no flow.
G04	389	0.00	-	-	There's no flow.
G05	390	0.00	-	-	There's no flow.
G06	384	0.00	-	-	There's no flow.
G07	390	0.00	-	-	There's no flow.
GQ01	390	0.00	-	-	There's no flow.
GQ02	390	0.00	-	-	There's no flow.
GQ03	384	0.00	-	-	There's no flow.
GQ04	390	0.00	-	-	There's no flow.
GQ05	371	0.00	-	-	There's no flow.
GQ06	383	0.00	-	-	There's no flow.
GQ07	390	0.00	-	-	There's no flow.
GR09	383	0.00	-	-	There's no flow.
H01	348	0.00	362.79	14.79	
H02	360	0.00	361.60	1.60	

Attached Table 3.1 Pressure and Head of Junctions in the Hydraulic Model

continued(4/4)

Junction ID	Elevation	Actual Demand	Head	Pressure	Remark
	m	LPS	m	m	
HJ08	348	0.00	362.79	14.79	
HJ10	348	0.00	362.79	14.79	
HJ12	360	0.00	361.60	1.60	
HJ13	358	0.00	361.00	3.00	
I01	371	0.00	-	-	There's no flow.
I02	373	0.00	-	-	There's no flow.
I03	386.3	0.00	-	-	There's no flow.
SB (Reservoir)	443.5	-609.51	443.50	0.00	outflow
TB07 (Tank)	415	159.72	419.00	4.00	
TB20 (Tank)	389	154.91	393.00	4.00	
TB25 (Tank)	425	37.51	429.00	4.00	
TJ07 (Tank)	353	0.00	356.00	3.00	out of operation
TJ09 (Tank)	341	90.32	345.00	4.00	
TJ12 (Tank)	360	0.00	363.00	3.00	out of operation
TJ13 (Tank)	358	9.71	361.00	3.00	
<b>TQ01 (Tank)</b>	390	0.00	394.00	4.00	There is no flow
TQ04 (Tank)	390	0.00	394.00	4.00	out of operation
TQ05 (Tank)	371	0.00	374.00	3.00	out of operation
<b>TR05 (Tank)</b>	386	0.00	389.00	3.00	There is no flow
TR06 (Tank)	370	0.00	372.00	2.00	out of operation
TR08 (Tank)	382	0.00	385.00	3.00	There is no flow
TR19 (Tank)	377	0.00	380.00	3.00	out of operation
TR26 (Tank)	385	0.00	388.00	3.00	out of operation
TR27 (Tank)	369	89.64	372.50	3.50	
TR31 (Tank)	364	0.00	368.00	4.00	out of operation
TV15 (Tank)	422	0.00	426.00	4.00	out of operation

Note: Base demand is the hourly peak demand of WSS

Source: own study

Supporting Report 1  
Chapter 3 Current Situation and Development Issues on The Vakhsh Conduits

Attached Table 3.2 Pipe Inner Flow of Vakhsh Conduits Hydraulic Model on the Condition that the Inflow to Tanks is not Regulated

continued (1/4)

Link	Start Nodes	End Nodes	Length (m)	Inside Diameter (m)	Roughness	Flow	Unit Headloss
						(liter/second)	(m/km)
ASBA1	SB	A01	1229	1200	100	609.51	0.35
A12	A01	A02	5223	1192	70	609.51	0.69
A23	A02	A03	1776	996	70	609.51	1.66
A34	A03	A04(valve)	1116	996	70	608.85	1.66
A3B04	A03	AB04	514	68	69	0.66	2.62
B1011	B10	B11	225	900	70	403.50	1.27
B10B19	B10	BB19	157	105	69	1.22	0.99
B1112	B11	B12	2388	900	70	401.88	1.26
B11B11	B11	BB11	1171	150	69	0.69	0.06
B11B13	B11	BB13	1249	150	69	0.93	0.11
B1213	B12	B13	540	900	70	399.56	1.25
B12B14	B12	BB14	704	150	69	2.32	0.57
B12main	B01	B02	32	900	70	406.98	1.29
B1314	B13	B14	905	700	67	399.20	4.59
B13V12	B13	BV12	49	40.8	87	0.36	6.70
B1415	B14	B15	810	700	67	397.58	4.56
B14B12	B14	BB12	420	150	87	1.62	0.19
B1516	B15	B16	852	700	67	397.58	4.56
B15V14	B15	BV14	1859	105	55	0.00	0.00
B16B01	B16	BB01	213	81	69	0.00	0.00
B16B06	B16	BB06	825	700	67	397.50	4.56
B16B22	B16	BB22	85	100	55	0.08	0.01
B1819	B18	B19	156	700	67	242.20	1.82
B18B20	B18	<b>BB20</b>	70	198.2	110	<b>154.91</b>	148.32
B18B21	B18	BB21	299	313	69	0.36	0.00
B1920	B19	B20	36	700	67	242.20	1.82
B2021	B20	B21	22	700	67	242.20	1.82
B2122	B21	B22	230	700	67	242.20	1.82
B2224	B22	B24	10574	700	67	242.20	1.82
B23main	B02	B03	94	900	70	406.98	1.29
B2425	B24	B25	758	700	67	217.76	1.49
B24R02	B24	BR02	217	124	55	2.00	1.67
B24R03	B24	BR03	217	200	55	2.77	0.30
B24R12	B24	BR12	217	105	69	2.00	2.46
B24R13	B24	BR13	217	105	37	0.00	0.00
B24R14	B24	BR14	217	105	44	0.00	0.00
B24R23	B24	BR23	217	96.8	110	0.00	0.00
B24R25	B24	BR25	217	150	55	2.45	0.96
B24R28	B24	BR28	223	208	55	7.17	1.43
B24R35	B24	BR35	217	198.2	110	2.82	0.09
B24R36	B24	BR36	217	95	69	5.23	23.80
B24R39	B24	BR39	218	200	69	0.00	0.00
B2526	B25	B26P	102	700	67	217.76	1.49
B2627	B26P	B27	8	700	67	217.76	1.50
B2728	B27	B28(valve)	22	700	67	217.76	1.50
B34	B03	B04	238	900	70	405.89	1.28
B3V11	B03	BV11	568	100	69	1.09	1.02
B45	B04	B05	2545	900	70	405.89	1.28
B56	B05	B06	14	900	70	405.89	1.28
B67	B06	B07	455	900	70	405.89	1.28
B78	B07	B08	1417	900	70	404.72	1.28
B7B10	B07	BB10	442	132	98	1.17	0.16
B89	B08	B09	28	900	70	404.72	1.28
B910	B09	B10	54	900	70	404.72	1.28
BA4B1	A04(valve)	B01	1083	996	70	406.98	0.79
BB0618	BB06	B18	1030	700	67	397.47	4.56
C1011	C10	C11	765	614	67	160.38	1.61
C10B23	C10	CB23	159	81	69	0.51	0.69

Attached Table 3.2 Pipe Inner Flow of Vakhsh Conduits Hydraulic Model on the Condition that the Inflow to Tanks is not Regulated

continued (2/4)

Link	Start Nodes	End Nodes	Length	Inside Diameter	Roughness	Flow	Unit Headloss
			(m)	(m)		(liter/second)	(m/km)
C1112	C11	C12	86	614	67	160.35	1.61
C11B16	C11	CB16	23	24.1	87	0.03	0.87
C12	C01	C02	21	614	67	201.87	2.46
C1213	C12	C13(valve)	120	614	67	160.29	1.60
C12B15	C12	CB15	108	22.1	98	0.06	3.85
C1314	C13(valve)	C14	584	614	67	0.00	0.00
C13B02	C13(valve)	CB02	98	105	87	0.57	0.16
C13B07	C13(valve)	<b>CB07</b>	153	313	87	<b>159.72</b>	26.17
C1415	C14	C15	384	600	67	0.00	0.00
C15CB24	C15	CB24	40	600	67	0.00	0.00
C1718	C17	C18	1044	600	67	0.00	0.00
C23	C02	C03	180	614	67	201.87	2.46
C2V15	C02	<b>CV15</b>	57	234	55	<b>0.00</b>	0.00
C34	C03	C04	646	614	67	201.78	2.46
C3B03	C03	CB03	84	27.9	69	0.09	5.03
C45	C04	C05	198	614	67	201.60	2.45
C4V13	C04	CV13	442	36.2	110	0.18	2.15
C56	C05	C06	254	614	67	201.57	2.45
C5B17	C05	CB17	71	36.7	87	0.03	0.11
C67	C06	C07	1269	614	67	164.05	1.68
C6B25	C06	<b>CB25</b>	68	208	69	<b>37.51</b>	20.12
C78	C07	C08	1291	614	67	162.49	1.65
C7B08	C07	CB08	1189	81	69	0.87	1.87
C7B18	C07	CB18	626	81	69	0.69	1.22
C89	C08	C09	224	614	67	161.58	1.63
C8B09	C08	CB09	968	81	69	0.91	2.03
C910	C09	C10	116	614	67	160.89	1.62
C9B05	C09	CB05	1034	105	69	0.69	0.34
CA5C1	A04(valve)	C01	440	614	67	201.87	2.46
CB2417	CB24	C17	6058	600	67	0.00	0.00
D1011	D10	D11	1293	514	67	90.32	1.32
D10J05	D10	DJ05	68	150	69	1.43	0.23
D11J09	D11	<b>DJ09</b>	1	514	67	<b>90.32</b>	1.34
D12	D01(valve)	D02	978	514	67	105.82	1.77
D23	D02	D03	3528	514	67	103.82	1.71
D2R24	D02	DR24	49	105	69	2.00	2.46
D34	D03	D04	3	514	67	103.38	1.69
D3J03	D03	DJ03	143	156	69	0.44	0.02
D45	D04	D05	1493	514	67	102.86	1.68
D4J04	D04	DJ04	131	150	69	0.52	0.04
D56	D05	D06	4926	514	67	93.15	1.40
D67	D06	D07	87	514	60	92.63	1.70
D6J02	D08	DJ02	59	105	69	0.00	0.00
D6J06	D06	DJ06	28	105	55	0.52	0.31
D6J11	D06	DJ11	28	156	69	0.00	0.00
D78	D07	D08	1655	514	67	91.75	1.36
D7J01	D07	DJ01	51	147.6	110	0.88	0.04
D89	D08	D09	355	514	67	91.75	1.36
D910	D09	D10	728	514	67	91.75	1.36
D9J07	D09	<b>DJ07</b>	171	208	69	<b>0.00</b>	0.00
DB28V3	B28(valve)	D01(valve)	4212	514	67	105.82	1.77
E1011	E10	E11(valve)	5	514	67	3.55	0.01

Attached Table 3.2 Pipe Inner Flow of Vakhsh Conduits Hydraulic Model on the Condition that the Inflow to Tanks is not Regulated

continued (3/4)

Link	Start Nodes	End Nodes	Length	Inside Diameter	Roughness	Flow	Unit Headloss
			(m)	(m)		(liter/second)	(m/km)
E1112	E11(valve)	E12	882	514	67	3.55	0.00
E12	E01	E02	274	514	67	106.13	1.78
E1213	E12	E13	167	514	67	0.00	0.00
E12R04	E12	ER04	223	154	55	2.16	0.67
E12R32	E12	ER32	223	100	110	1.39	0.67
E12R37	E12	ER37	223	154	55	0.00	0.00
E12R38	E12	ER38	223	68	55	0.00	0.00
E13R05	E13	<b>ER05</b>	2237	514	67	<b>0.00</b>	0.00
E13R06	E13	<b>ER06</b>	91	131	55	<b>0.00</b>	0.00
E13R30	E13	ER30	91	105	69	0.00	0.00
E1R11	E01	ER11	690	156	55	5.81	3.93
E23	E02	E03	246	514	67	106.13	1.78
E34	E03	E04	2393	514	67	14.63	0.05
E3R10	E03	ER10	13	147.6	110	1.86	0.17
E3R27	E03	<b>ER27</b>	13	150	69	<b>89.64</b>	496.34
E45	E04	E05	23	514	67	14.63	0.05
E56	E05	E06	382	514	67	14.63	0.05
E67	E06	E07	180	514	67	13.44	0.04
E6R33	E06	ER33	2618	105	69	1.19	0.94
E78	E07	E08	16	514	67	6.59	0.01
E7R29	E07	ER29	29	156	69	6.85	3.50
E89	E08	E09	945	514	67	3.55	0.00
E8R16	E08	ER16	7	105	55	0.46	0.25
E8R18	E08	ER18	6	105	55	2.58	6.02
E910	E09	E10	403	514	67	3.55	0.00
E9R01	E09	ER01	589	208	69	0.00	0.00
EB281	B28(valve)	E01	1079	514	67	111.94	1.96
F12	F01	F02	1792	514	67	0.00	0.00
F23	F02	F03	191	514	67	0.00	0.00
F2R19	F02	<b>FR19</b>	264	208	69	<b>0.00</b>	0.00
F34	F03	F04	6448	514	67	0.00	0.00
F3R15	F03	FR15	409	156	69	0.00	0.00
F45	F04	F05P	2755	514	67	0.00	0.00
F4R07	F04	FR07	4	105	55	0.00	0.00
F4R26	F04	<b>FR26</b>	4	105	69	<b>0.00</b>	0.00
FD11	D01(valve)	F01	7740	514	67	0.00	0.00
FR19R34	FR19	FR34	947	100	69	0.00	0.00
G01	F05	G01	543	500	67	0.00	0.00
G12	G01	G02	2660	500	67	0.00	0.00
G1Q06	G01	GQ06	123	100	69	0.00	0.00
G1R09	G01	GR09	123	96.8	110	0.00	0.00
G23	G02	G03	5781	500	67	0.00	0.00
G2Q02	G02	GQ02	8	101.6	110	0.00	0.00
G2Q07	G02	GQ07	8	96.8	110	0.00	0.00
G34	G03	G04	3000	514	67	0.00	0.00
G3Q05	G03	<b>GQ05</b>	3722	208	69	<b>0.00</b>	0.00
G45	G04	G05	3215	414	67	0.00	0.00
G56	G05	G06	188	313	55	0.00	0.00
G5Q01	G05	<b>GQ01RC</b>	50	262	44	<b>0.00</b>	0.00
G67	G06	G07	1113	313	55	0.00	0.00
G6Q03	G06	GQ03	35	96.8	110	0.00	0.00
G7Q04	G07	<b>GQ04</b>	50	207.8	110	<b>0.00</b>	0.00

Attached Table 3.2 Pipe Inner Flow of Vakhsh Conduits Hydraulic Model on the Condition that the Inflow to Tanks is not Regulated

continued (4/4)

Link	Start Nodes	End Nodes	Length	Inside Diameter	Roughness	Flow	Unit Headloss
			(m)	(m)		(liter/second)	(m/km)
H12	H01	H02	3492	313	55	9.71	0.34
H1J08	H01	HJ08	289	208	69	0.00	0.00
H1J10	H01	HJ10	289	105	44	0.00	0.00
H2J12	H02	<b>HJ12</b>	1257	208	69	<b>0.00</b>	0.00
H2J13	H02	<b>HJ13</b>	1747	313	55	<b>9.71</b>	0.34
HD121	D05	H01	4348	313	55	9.71	0.34
I12	I01	I02	299	313	76	0.00	0.00
I23	I02	I03	2626	313	69	0.00	0.00
I3F5	I03	F05	2193	313	76	0.00	0.00
ID111	D11	I01	3514	313	76	0.00	0.00

Uzun (R31) & Kalinin (R08) Pumping Stations are not considered in this modeling because they are currently not supplied with water from the Vakhsh Conduits

Supporting Report 1  
Chapter 3 Current Situation and Development Issues on The Vakhsh Conduits

Attached Table 3.3. Base Demands in 2027 on the Vakhsh Conduits Hydraulic Model and Output of the Analysis

ID	Elevation	Base Demand	Possible Flow Rate	Head	Pressure	ID	Elevation	Base Demand	Possible Flow Rate	Head	Pressure
	m	LPS	LPS	m	m		m	LPS	LPS	m	m
SB	443.5		-272.18	443.50	0.00	R01	385	2.15	3.76	402.14	17.14
B04	386	0.07	0.12	434.66	48.66	R04	383	1.92	3.36	400.71	17.71
B01	415	0.22	0.39	440.98	25.98	R05	372	0.81	1.42	416.96	44.96
B06	414	0.03	0.05	441.22	27.22	R06	367	2.77	4.85	415.27	48.27
B10	423	0.25	0.44	441.30	18.30	R09	372	0.87	1.52	418.35	46.35
B11	422	0.27	0.47	440.88	18.88	R10	369	0.47	0.82	418.35	49.35
B12	384	0.01	0.02	433.55	49.55	R11	369	1.53	2.68	416.56	47.56
B13	415	11.4	19.96	440.91	25.91	R16	387	1.68	2.94	404.2	17.2
B14	415	0.34	0.6	440.06	25.06	R18	369	0.39	0.68	415.66	46.66
B19	409	0.39	0.68	439.92	30.92	R27	368	1.12	1.96	415.64	47.64
B20	404	0.51	0.89	439.89	35.89	R29	377	2.35	4.11	404.39	27.39
B21	397	0.27	0.47	439.24	42.24	R30	363	0.57	1	418.58	55.58
B22	390	0.71	1.24	436.87	46.87	R32	366	0.87	1.52	408.72	42.72
R02	402	0.41	0.72	439.19	37.19	R33	369	1.06	1.86	418.55	49.55
R03	395	1.01	1.77	438.12	43.12	R37	385	2.11	3.69	402.15	17.15
R12	410	0.02	0.04	440.85	30.85	R38	369	0.81	1.42	416.96	47.96
R13	410	0.01	0.02	441.00	31.00	R07	370	3.41	5.97	418.45	48.45
R14	417	0.01	0.02	441.27	24.27	R15	369	3.26	5.71	415.6	46.6
R23	418	0.27	0.47	440.78	22.78	R19	370	0.74	1.3	414.94	44.94
R25	400	0.53	0.93	439.26	39.26	R26	372	1.2	2.1	414.74	42.74
R28	389	6.01	10.52	432.09	43.09	R34	371	0.74	1.3	412.86	41.86
R35	388	0.14	0.25	432.16	44.16	Q01	375	1.12	1.96	401.54	26.54
R36	382	0.06	0.11	434.67	52.67	Q02	367	1.23	2.15	418.66	51.66
R39	411	0.2	0.35	440.99	29.99	Q03	367	2.49	4.36	414.99	47.99
V11	413	3.75	6.57	440.99	27.99	Q04	378	1.88	3.29	414.73	36.73
V12	425	5.69	9.96	441.13	16.13	Q05	378	1.88	3.29	397.59	19.59
V14	355	0.76	1.33	404.75	49.75	Q06	367	0.5	0.88	418.67	51.67
B02	355	0.3	0.53	404.44	49.44	Q07	410	0.47	0.82	440.86	30.86
B03	362	0.38	0.67	406.74	44.74	J08	394	0.14	0.25	438	44
B05	363	0.45	0.79	406.74	43.74	J10	421	0.07	0.12	440.83	19.83
B07	350	1.24	2.17	404.24	54.24	J12	390	0.17	0.3	435.62	45.62
B08	355	0.45	0.79	404.76	49.76	J13	422	10.38	18.18	441.14	19.14
B09	353	1.27	2.22	404.37	51.37						
B15	348	2.82	4.94	399.54	51.54						
B16	341	8.09	14.17	404.10	63.10						
B17	348	0.58	1.02	399.21	51.21						
B18	355	1.15	2.01	404.77	49.77						
B23	360	2.55	4.47	396.48	36.48						
B24	358	6.08	10.65	396.26	38.26						
B25	390	10.24	17.93	395.60	5.60						
V13	390	0.74	1.3	400.13	10.13						
V15	384	0.84	1.47	395.64	11.64						
J01	390	7.05	12.34	395.02	5.02						
J02	371	5.27	9.23	392.54	21.54						
J03	383	1.03	1.8	400.89	17.89						
J04	390	1.17	2.05	400.12	10.12						
J05	384	1.68	2.94	415.28	31.28						
J06	369	0.87	1.52	418.46	49.46						
J07	367	1.2	2.1	418.64	51.64						
J09	375	1.88	3.29	414.73	39.73						
J11	386	12.41	21.73	414.83	28.83						
R24	370	1.2	2.1	414.91	44.91						

## **2 CHAPTER4 EXISTING CONDITION AND DEVELOPMENT ISSUES OF RURAL WATER SUPPLY SYSTEM**

- Appendix-1 Inventory Survey Sheet**
- Appendix-2 Rural Water Supply System Survey Sheet**
- Appendix-3 Data Base of Rural Water Supply System**
  - (1) Attached Tables**
  - (2) Attached Figures**

**2 CHAPTER4 EXISTING CONDITION  
AND DEVELOPMENT ISSUES  
OF RURAL WATER SUPPLY SYSTEM**

**Appendix-1 Inventory Survey Sheet**

Sheet No. 1

A. Water Supply System

Date:

A-1 Name of Ryon	
A-2 Name of Jamoat	
A-3 Name of Village	
Name of Responder	
Coordinates (center of village)	N, E, EL. m
A-4 Name of Water Supply System	
A-5 Year of construction	
A-6 Owner of water supply system	
A-7 Name of operator	
A-8 Water source	1-Vakhsh Conduit, 2-Groundwater, 3-Irrigation canal 4-Other (specify: )
A-9 Operating condition	1-Working, 2-Out of working
A-9-1 If working	1-1 Throughout the year 1-2 Seasonal (from to , months) If seasonal, what is the reason?
A-9-1-1 Average water supply	1-1 Average water supply m <sup>3</sup> /day 1-2 Maximum daily water supply m <sup>3</sup> /day 1-3 Maximum hourly water supply m <sup>3</sup> /hour
A-9-1-2 Service hours	From to , from to . ( hours/day)
A-9-1-3 Service area and Service Population (name of village or Sokhfoz/ Kolvoz, and population served)	Total population served: _____ Breakdown: Village: _____ : _____ persons Village: _____ : _____ persons
A-9-2 If out of working	
A-9-2 -1 Reason of out of working	
A-9-2 -2 Date (Month/Year) of stopping	

A-10 History of rehabilitation or repairing of facilities	Year and contents of rehabilitation of repairing 1-  2-  3-
---	--

**Sheet No. 2 B. Water Source (Vakhsh Conduits Groundwater Irrigation canal)**

B-1 Number of well(s)	Well(s)		
B-2 Coordinates of well(s)	N,	E,	EL. m
	N,	E,	EL. m
	N,	E,	EL. m
B-3 Depth of well			
B-4 Capacity (Yield) of well*	m <sup>3</sup> /hour or	m <sup>3</sup> /day	
B-5 Maximum yield of well*	m <sup>3</sup> /hour or	m <sup>3</sup> /day	
B-6 Water Level	Static	m BGL,	Dynamic m BGL
B-7 Casing/Screen pipe			
B-7-1 Diameter	mm or inches		
B-7-2 Material	1-Steel, 2-Stainless steel, 3-PVC, 4-Other (specify )		
B-7-3 Position of screen	From	m to	m BGL
B-8 Pump			
B-8-1 Type	1-Submersible, 2- Vertical Turbine, 3-Other (specify )		
B-8-2 Position	m BGL		
B-8-3 Rated motor output			
B-8-4 Pump head	m		
B-8-5 Discharge of pump	m <sup>3</sup> /min or		m <sup>3</sup> /hour
B-8-6 Diameter and material of riser pipe	Diameter	, Material	
B-8-7 Starting up method of pump	1-Direct on line, 2-Star delta		
B-8-8 Location of control panel	1-Indoor, 2-Outdoor (3- splash-proof, 4-Not splash-proof)		
Others (mark, if installed)	Low water level warning, emergency stop for idle running, installation of air valve, check valve, sluice valve and compound gauge (in case of submersible pumps)		
B-9 Water Quality (to be measured by test paper and water quality tester)			
pH		Fe	
Temperature		F	
EC		As	
TDS		Cl	
Total Coli.		NO <sub>3</sub>	
E. Coli			
B-10 Availability of alternative water source, if operation of water supply service is seasonal or service is stopping.	Type of water source 1-Vakhsh Conduit, 2-Groundwater, 3-Irrigation canal 4-Other (specify: ) Fetching time per day: hours/day Times of fetching: times/day		

BGL: below ground level

\*: result of pumping test

**Sheet No. 3-1 Aqueduct, Transmission, Tank, Distribution, etc.**

<b>C Aqueduct (conduit from water source to a reservoir or distribution tank)</b>	
C-1 Diameter of pipe	mm
C-2 Material of pipe	
C-3 Length of conduit	km
C-4 Condition of pipe	1- No problem 2- Deteriorated (1- totally 2- partially: specify ) 3- Urgent rehabilitation is required 4- What is problems, please describe.
C-5 Valve	Type and number of valve Sluice valve <sub>2</sub> _____ locations Check valve <sub>2</sub> _____ locations Air valve <sub>2</sub> _____ locations Other _____, _____ locations
<b>D Reservoir</b>	
Coordinates	N, E, EL. m
D-1 Capacity	m <sup>3</sup>
D-2 Material of reservoir	1- concrete, 2- steel, 3- other (specify, )
D-3 Water level	1- High water level: m 2- Low water level: m
D-4 Condition of reservoir	1- No problem 2- Deteriorated (1- totally 2- partially: specify ) 3- Urgent rehabilitation is required 4- What is problems, please describe.

**Sheet No. 3-2 Aqueduct, Transmission, Tank, Distribution, etc.**

<b>E Chlorination system</b>	
E-1 Facility	1- installed, 2- not installed
E-2 Agent used for chlorination	
<b>F Transmission line (water line from reservoir to distribution tank)</b>	
F-1 Diameter of pipe	mm
F-2 Material of pipe	
F-3 Distance of water line	Km
F-4 Condition of pipe	1- No problem 2- Deteriorated (1- totally 2- partially: specify ) 3- Urgent rehabilitation is required 4- What is problems, please describe.
F-5 Valve	Type and number of valve Sluice valve <sub>2</sub> _____ locations Air valve <sub>2</sub> _____ locations Other _____, _____ locations
<b>G Distribution Tank</b>	
Coordinates	N, E, EL. m
G-1 Type	1- Elevated, 2-Ground, 3- Other (specify, )
G-2 Capacity	m <sup>3</sup>
G-3 Material of tank	1- concrete, 2- steel, 3- other (specify, )
G-4 Condition of reservoir	1- No problem 2- Deteriorated (1- totally 2- partially: specify ) 3- Urgent rehabilitation is required 4- What is problems, please describe.

**Sheet No. 3-3 Aqueduct, Transmission, Tank, Distribution, etc.**


<b>H Distribution Main</b>	
H-1 Diameter of pipe	mm
H-2 Material of pipe	
H-3 Total length of main	km
H-4 Condition of pipe	1- No problem 2- Deteriorated (1- totally 2- partially: specify ) 3- Urgent rehabilitation is required 4- What is problems, please describe.
H-5 Valve	Type and number of valve Air valve <sub>2</sub> _____ locations Sluice valve <sub>2</sub> _____ locations Other valve _____, _____ locations
<b>I Public tap</b>	<b>taps</b>
I-1 Diameter of pipe	mm
I-2 Material of pipe	
I-3 Mean length of service line	km



**Sheet No. 6 Name and Quantity of Facilities to be rehabilitated or replaced**

Name of Facility	Specification and quantity

**Sheet No. 7 Schematic layout of water supply system**



Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.1 Rural Water Supply System Survey Sheet (K1 Lenin, Dushra, Azizov Sino)

Sites name: K1 Lenin, Dushra, Azizov Sino      O (rehabilitation only one system without Vodokanal) Visit day, time: 11/30 10:30~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Conntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	re-use	fonction				<p>φ 150 to village φ 110 to the reservoir in borehole φ 140 to village</p>
2	casing	re-use	fonction				
3	quality water						
4	submersible pump	installation	-				The pump was stolen, that's specs is 65m <sup>3</sup> /h-110mH.
5	riser pipe	installation	-				
6	dicharge rate						
7	pressure gage	installation	-				
8	air relief valve	installation	-				
9	gate valve	re-use	?				
10	check valve	re-use	?				Half water is distributed by water tank trucks, another half of water is distributed by pipes. Three pump stacions was connected by pipes and only one station works. This working pump station owned by Vodakanal supply water in the three systems. That means these systems was operated by Vodakanal.
Reservoir							<input type="checkbox"/> picture
11	structure	repaire	fonction				<p>There are 3 reservoirs. The first one in the pump station is 25m<sup>3</sup>-3mH for distribution by water tank trucks. The second one reservoirs is in the site of school that is now constructing. The third one (20m<sup>3</sup>-14mH) is also at the another place in this area that isn't connected to another pipes.</p>
12	pipes	installation	?				
13	water level gage	installation	-				
14	lignting rod	no-need					
Control room, power line							<input type="checkbox"/> picture : There isn't control room.
15	pipes	installation	-				
16	flowmeter	no need	-				
17	pressure gage	installation	-				
18	safty relief valve	installation	-				
19	gate valve	installation	-				
20	check valve	installation	-				
21	water meter	installation	-				
22	transformer with fuse-breaker	replace	?				63kVA, 3phases, 6,000V/400V, there's no fences.
23	incoming panel (with watt-hour meter)	installation	-				
24	control panel of submersible pump	replace	breakdown				
25	electric wire or cable	replace	?				
26	fence	re-use					
Equipments of distribution							
27	pipes	repaire					
28	valves box	?					

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.2 Rural Water Supply System Survey Sheet (K2 Yangi Yul)

Sites name: K2 Yangi Yul

○

Visit day, time: 11/29 15:05~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Conntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	installation	breakdown				
2	casing	installation	fonction				
3	quality water						
4	submersible pump	replace	breakdown				The submersible pump was burned after drawing the sand from water. This pump was inside of borehole. 5.3m <sup>3</sup> /h-110mH, 5kW
5	riser pipe	replace	?				Steel φ100, inside of borehole 76mm
6	dicharge rate						
7	pressure gage	installation	-				
8	air relief valve	installation	-				
9	gate valve	installation	-				
10	check valve	installation	-				
Reservoir							<input type="checkbox"/> picture
11	structure	repaire	fonction				25m <sup>3</sup> -16mH, made of steel
12	pipes	repaire	fonction				distribution main : steel, diameter 110mm
13	water level gage	installation	-				
14	ligtning rod	installation	-				
Control room, power line							<input type="checkbox"/> picture
15	pipes	installation	-				
16	flowmeter	no need	-				
17	pressure gage	installation	-				
18	safty relief valve	installation	-				
19	gate valve	installation	-				
20	check valve	installation	-				
21	water meter	installation	-				
22	transformer with fuse-breaker	no need	-				Receiving power line with 400V 3phases-4lines
23	incoming panel (with watt-hour meter)	installation	-				
24	control panel of submersible pump	replace	?				400V, 69A, 50Hz. Ammeter 80-100A max made in USSR
25	electric wire or cable	replace	?				
26	fence	re-use					
Equipments of distribution							
27	pipes	repaire					They replaced the distribution pipes length 1-2km. Total length is 4.5km. There is reakage of water from distribution pipes of another
28	valves box	?					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	?					<input type="checkbox"/> picture
32	water meter	installation					
33	gate valve	installation					
Others							

**2 CHAPTER4 EXISTING CONDITION  
AND DEVELOPMENT ISSUES  
OF RURAL WATER SUPPLY SYSTEM**

**Appendix-2 Rural Water Supply System Survey Sheet**

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.3 Rural Water Supply System Survey Sheet (K4 Khaeti Nav)

Sites name: K4 Khaeti Nav

○

Visit day, time: 11/29 14:30~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Conntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	re-use	?				This borehole was cleaned by UNDP. They paid monthly 17-20 somoni for the electricity.
2	casing	re-use	?				
3	quality water						
4	submersible pump	replace	breakdown				The submersible pump was burned, was taken away from the borehole. 25m <sup>3</sup> /h-110mH.
5	riser pipe	replace	?				Steel pipes φ110
6	dicharge rate						
7	pressure gage	installation	-				
8	air relief valve	installation	-				
9	gate valve	installation	-				
10	check valve	installation	-				
Reservoir							<input type="checkbox"/> picture
11	structure	repaire	fonction				25m <sup>3</sup> -8mH made of steel
12	pipes	repaire	fonction				Distribution pipes are made of steel, diameter 85mm and 100mm.
13	water level gage	installation	-				
14	lignting rod	installation	-				
Control room, power line							<input type="checkbox"/> picture : There isn't control room.
15	pipes	installation	-				
16	flowmeter	no need	-				
17	pressure gage	installation	-				
18	safty relief valve	installation	-				
19	gate valve	installation	-				
20	check valve	installation	-				
21	water meter	installation	-				
22	transformer with fuse-breaker	no need	-				Receiving power line is 400V 3phases-4lines.
23	incoming panel (with watt-hour meter)	installation	-				
24	control panel of submersible pump	replace	fonction				This control panel probably works.
25	electric wire or cable	replace	?				
26	fence	re-use					
Equipments of distribution							
27	pipes	repaire					
28	valves box	?					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	?					<input type="checkbox"/> picture
32	water meter	installation					
33	gate valve	installation					
Others							

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.4 Rural Water Supply System Survey Sheet (K5 Navruz)

Sites name: K5 Navruz

x

Visit day, time: 11/27 11:30~

No.	Equipments	Replace or re-use	Fonction or breakdown	Builder (country)	Manufacturing date	Contents of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	Screen	re-use	operation				Submersible pump stopped operation. due to burning of transformere one month ago.
2	Casing	re-use	operation				 reservoir
3	Water Quality						
4	Submersible Pump	?	?				10m3/h-110mH, 5.5kW
5	Riser Pipe	re-use	operation				steel, $\phi$ 76, 22m
6	Yield						
7	Pressure gauge	installatio n					
8	air relief valve	installatio n					$\phi$ 25*1
9	gate valve	installatio n	-				$\phi$ 150*4
10	check valve	installatio n	-				$\phi$ 150*2
Tank							<input type="checkbox"/> picture
11	Structure	repair	機能				Steel made levated tank (Q=15m3, 12mH) was constructed by RWSA in 2001. Another steel made ground tank (25m3) is beside the elevated tank.. Water leakage was observed on the elevated tank.
12	Pipe	repair	operation				transmission line: steel $\phi$ 150 2.5km
13	Water Level Gauge	installatio n	-				
14	lightning rod	installatio n	-				
Control room, power line							<input type="checkbox"/> picture
15	Structure	repair	-				Control room only, no equipment
16	pipes	installatio n	-				
17	flowmeter	not required	-				
18	pressure gage	installatio n	-				
19	safty relief valve	installatio n	-				
20	gate valve	installatio n	-				
21	check valve	installatio n	-				
22	water meter	installatio n	-				
23	transformer with fuse-breaker	re-use	breakdown				
24	incoming panel (with watt-hour meter)	installatio n	-				
25	control panel of submersible pump	re-use	?				
26	electric wire or cable	re-use	?				
27	fence	repair	breakdown				
Equipments of distribution							
28	pipes	repair					steel $\phi$ 150- 1.5km steel $\phi$ 20- 0.4km
29	valves box	?					$\phi$ 150*4
30	air relief valve	?					$\phi$ 25*1
31	sand ejection valve	?					
32	public taps	?					<input type="checkbox"/> picture, 20 taps
33	water meter	installatio n					
34	gate valve	installatio n					
Others							

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.5 Rural Water Supply System Survey Sheet (K7 Jarkurgan)

Sites name: K7 Jarkurgan

○

Visit day, time: 11/29 12:15~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Conntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	installation	breakdown				This borehole isn't used from 2006. This screen is holes type diameter 3-5mm.
2	casing	installation	fonction				
3	quality water						
4	submersible pump	replace	breakdown				Submersible pump's capacity 6.3m <sup>3</sup> /h, it started drawing the sable, because of screen.
5	riser pipe	replace	?				φ110mm
6	dicharge rate						
7	pressure gage	installation	-				
8	air relief valve	installation	-				
9	gate valve	re-use	?				φ100mm
10	check valve	installation	-				
Reservoir							<input type="checkbox"/> picture
11	structure	repaire	fonction				25m <sup>3</sup> -16m <sup>3</sup> , it's compairately new. There's a hole outside of discharge pipe to the bottom of the reservoir, but they said this reservoir has two panel of bottom. There was no reakage from the reservoir. Water is coming from diefferent submersible pump, but there isn't enough water height. Diameter of distribution pipes are 110mm and 100mm.
12	pipes	repaire	fonction				
13	water level gage	installation	-				
14	ligtning rod	installation	-				
Control room, power line							<input type="checkbox"/> picture: There isn't control room.
15	pipes	installation	-				
16	flowmeter	no need	-				
17	pressure gage	installation	-				
18	safty relief valve	installation	-				
19	gate valve	installation	-				
20	check valve	installation	-				
21	water meter	installation	-				
22	transformer with fuse-breaker	no need	-				Receiving power is 400v 3phases-4line.
23	incoming panel (with watt-hour meter)	installation	-				
24	control panel of submersible pump	replace	fonction				Maximam valeur of ammeter is 20 - 30A. It probably work.
25	electric wire or cable	replace					
26	fence	re-use					
Equipments of distribution							
27	pipes	repaire					
28	valves box	?					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	?					<input type="checkbox"/> picture
32	water meter	installation					
33	gate valve	installation					
Others							
32	Submersible pump of another system	replace	fonction				We visited the borehole that supply water to this system, the submeresible pump works. But control panel is too old. Village people changed this pump for ten times. Now capacity of pump ; 6.3m <sup>3</sup> /h-80m <sup>3</sup> .

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.6 Rural Water Supply System Survey Sheet (K9 Uchi Kabda)

Sites name: K9 Uchi Kabda

○

Visit day, time: 11/30 14:05~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Conntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	re-use	?				
2	casing	re-use	?				
3	quality water						
4	submersible pump	replace	breakdown				The submersible pump was burned, now it's still in the borehole. 65m3-120mH
5	riser pipe	replace	?				Steel φ110
6	dicharge rate						
7	pressure gage	replace	?				
8	air relief valve	installation	-				
9	gate valve	installation	-				
10	check valve	installation	-				
Reservoir							<input type="checkbox"/> picture
11	structure	repaire	fonction				25m3-8mH made of steel
12	pipes	repaire	fonction				Diameter of distribution and discharge pipes is 110mm.
13	water level gage	installation	-				
14	ligtning rod	installation	-				
Control room, power line							<input type="checkbox"/> picture
15	pipes	installation	-				
16	flowmeter	no need	-				
17	pressure gage	installation	-				
18	safty relief valve	installation	-				
19	gate valve	installation	-				
20	check valve	installation	-				
21	water meter	installation	-				
22	transformer with fuse-breaker	replace	fonction	(It's too old)			Capacity isn't confirmed from panel, but it's uesd also for the houses near hear.
23	incoming panel (with watt-hour meter)	installation	-				In the switching panel, a watt-hour meter is installed and was stopped at the valeur 21,659 kWh. In the control panel there's a ammeter max.150A and NFB 63A, ammeter max. 100A.
24	control panel of submersible pump	replace	?				
25	electric wire or cable	replace	?				
26	fence	re-use					
Equipments of distribution							
27	pipes	repaire					
28	valves box	?					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	?					<input type="checkbox"/> picture
32	water meter	installation					
33	gate valve	installation					
Others							Electricity rate is 2.2 diram per kWh in this area for house.

Supporting Report 2  
 Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.7 Rural Water Supply System Survey Sheet (K10 Kalinin)

Sites name: K10 Kalinin

Visit day, time: 11/30 15:00~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Conntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen						
2	casing						
3	quality water		It's necessary to study again in this site.				
4	submersible pump						
5	riser pipe						
6	dicharge rate						
7	pressure gage						
8	air relief valve						
9	gate valve						
10	check valve						
Reservoir							<input type="checkbox"/> picture
11	structure						
12	pipes						
13	water level gage						
14	lightning rod						
Control room, power line							<input type="checkbox"/> picture
15	pipes						
16	flowmeter						
17	pressure gage						
18	safty relief valve						
19	gate valve						
20	check valve						
21	water meter						
22	transformer with fuse-breaker						
23	incoming panel (with watt-hour meter)						
24	control panel of submersible pump						
25	electric wire or cable						
26	fence						
Equipments of distribution							
27	pipes						
28	valves box						
29	air relief valve						
30	sand ejection valve						
31	public taps						<input type="checkbox"/> picture
32	water meter						
33	gate valve						
Others							

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.8 Rural Water Supply System Survey Sheet (K11 Borshevik)

Sites name: K11 Borshevik

△

Visit day, time: 11/29 13:50~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Conntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	?	?				
2	casing	?	?				
3	quality water						
4	submersible pump	replace	breakdown				There isn't a submersible pump in the borehole. 63m3/h-65mH.
5	riser pipe	replace	?				φ110
6	discharge rate						
7	pressure gage	installation	-				
8	air relief valve	installation	-				
9	gate valve	installation	-				
10	check valve	installation	-				
Reservoir							<input type="checkbox"/> picture
11	structure	installation	-				There is no reservoir for this system, water is supplied directly from the pressure of submersible pump.
12	pipes	installation	-				
13	water level gage	installation	-				
14	lightning rod	installation	-				
Control room, power line							<input type="checkbox"/> picture
15	pipes	installation	-				
16	flowmeter	no need	-				
17	pressure gage	installation	-				
18	safty relief valve	installation	-				
19	gate valve	installation	-				
20	check valve	installation	-				
21	water meter	installation	-				
22	transformer with fuse-breaker	no need	-				Receiving the power line with 400V 3phases-4lines
23	incoming panel (with watt-hour meter)	installation	-				
24	control panel of submersible pump	replace	breakdown				
25	electric wire or cable	replace	?				
26	fence	repaire					
Equipments of distribution							
27	pipes	repaire					Total length is 8 km. After rehabilitation of UNDP, there was about 30 points of reakages of water from pipes.
28	valves box	?					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	?					<input type="checkbox"/> picture
32	water meter	installation					
33	gate valve	installation					
Others							

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.9 Rural Water Supply System Survey Sheet (K12 Tsorbogoy Ziraki)

Sites name: K12 Tsorbogoy Ziraki

O(Tsorbogoy)

Visit day, time: 11/30 13:35~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Conntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	re-use	?				There are 2 stations, one is at Tsorbogoy, another is at Ziraki. Borehole depth at Tsorbogoy 80 meters. Borehole at Ziraki is plugged with sand or
2	casing	re-use	?				
3	quality water						
4	submersible pump	replace	breakdown				The submersible pump at Tsorbogoy was burned, it was 65m <sup>3</sup> /h-120mH.
5	riser pipe	replace	?				Steel φ110
6	dicharge rate						
7	pressure gage	installation	-				
8	air relief valve	installation	-				
9	gate valve	installation	-				
10	check valve	installation	-				
Reservoir							<input type="checkbox"/> picture
11	structure	repaire	fonction				Reservoir at Tsorbogoy 25m <sup>3</sup> -16mH made of steel.
12	pipes	repaire	fonction				Distribution and discharge pipes: diameter 110mm, steel
13	water level gage	installation	-				
14	lignting rod	installation	-				
Control room, power line							<input type="checkbox"/> picture There isn't control room at Tsorbogoy.
15	pipes	installation	-				
16	flowmeter	no need	-				
17	pressure gage	installation	-				
18	safty relief valve	installation	-				
19	gate valve	installation	-				
20	check valve	installation	-				
21	water meter	installation	-				
22	transformer with fuse-breaker	replace	fonction				For the Tsorbogoy station : 100kVA, 3phases, 6,000V/400V, made in 1984
23	incoming panel (with watt-hour meter)	installation					
24	control panel of submersible pump	replace	?				Control panel of Tsorbogoy ; 400V, 30A
25	electric wire or cable	replace	?				
26	fence	re-use					
Equipments of distribution							
27	pipes	repaire					3km Length of distribution pipes out of 8km were repaired.
28	valves box	?					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	?					<input type="checkbox"/> picture
32	water meter	installation					
33	gate valve	installation					
Others							

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.10 Rural Water Supply System Survey Sheet (K13 Kalinin)

Sites name: K13 Kalinin

△

Visit day, time: 11/29 13:20~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Conntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	installation	breakdown				There is the sand from borehole, they couldn't pump up water. The submersible pump isn't taken away. They installed again some screens inside the borehole.
2	casing	installation	fonction				
3	quality water						
4	submersible pump	replace	breakdown				Pump of 6.5m <sup>3</sup> /h-125mH is taken on the ground just beside of borehole. They said that the capacity is 4 kW.
5	riser pipe	replace	-				
6	dicharge rate						
7	pressure gage	installation	-				
8	air relief valve	installation	-				
9	gate valve	installation	-				
10	check valve	installation	-				
Reservoir							<input type="checkbox"/> picture
11	structure	installation	?	(It's too old)			25m <sup>3</sup> -16mH, made of steel
12	pipes	installation	?				
13	water level gage	installation	-				
14	ligntning rod	installation	-				
Control room, power line							<input type="checkbox"/> picture : There isn't control room.
15	pipes	installation	-				
16	flowmeter	no need	-				
17	pressure gage	installation	-				
18	safty relief valve	installation	-				
19	gate valve	installation	-				
20	check valve	installation	-				
21	water meter	installation	-				
22	transformer with fuse-break	replace	fonction	(It's too old)			25kVA, 3phases, 10,000V/400V
23	incoming panel (with watt-hour meter)	installation					
24	control panel of submersible pump	replace	?				
25	electric wire or cable	replace	?				
26	fence						
Equipments of distribution							
27	pipes	repaire					
28	valves box	?					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	?					<input type="checkbox"/> picture
32	water meter	installation					
33	gate valve	installation					
Others							


Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.11 Rural Water Supply System Survey Sheet (S2 Rudaki)

Sites name: S2 Rudaki

©

Visit day, time: 11/28 11:40~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Conntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	?	?				This system is 2 reservoirs, one submersible pump and one booster pump (spiral pump) installed on the ground.  Submersible pump (22kW) was burned. Booster pump (spiral pump, 220-340m <sup>3</sup> /h/32-25mH) was taken away, but control panel (400V) exist. φ110  
2	casing	?	?				
3	quality water						
4	submersible pump	replace	breakdown				
5	riser pipe	replace	?				
6	dicharge rate						
7	pressure gage	installation	-				
8	air relief valve	installation	-				
9	gate valve	replace	?				
10	check valve	replace	?				
Reservoir							<input type="checkbox"/> picture
11	structure	repaire	fonction				Outside is made of concrent inside is made of steel, about 18m <sup>3</sup> -3mH. Reservoir for booster pump is made of steel, about 35m <sup>3</sup> .
12	pipes	repaire	fonction				
13	water level gage	installation	-				
14	ligtning rod	installation	-				
Control room, power line							<input type="checkbox"/> picture
15	pipes	installation	-				Electricity was provided by 400V 3phases-4lines for the control room. That power line is just near the site. Transformer is 400kVA, 10,000V/400V, made in 1990. This transformer provide electricity for the houses.  380V, NFB100A, ammeter 150-max 200A
16	flowmeter	no need	-				
17	pressure gage	installation	-				
18	safty relief valve	installation	-				
19	gate valve	installation	-				
20	check valve	installation	-				
21	water meter	installation	-				
22	transformer with fuse-brea	repaire	fonction				
23	incoming panel (with watt-hour meter)	installation					
24	control panel of submersible pump	replace	?				
25	electric wire or cable	replace					
26	fence	re-use					
Equipments of distribution							
27	pipes	repaire					<input type="checkbox"/> picture
28	valves box	?					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	?					
32	water meter	installation					
33	gate valve	installation					
Others							

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.12 Rural Water Supply System Survey Sheet (S4 Batan)

Sites name: S4 Batan

©

Visit day, time: 11/28 12:40~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Conntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	?	?				
2	casing	?	?				
3	quality water						
4	submersible pump	replace	breakdown				The guide of RWSA said "The voltage fluctuation made the moter of the pump to be burned". 40m3-60mH
5	riser pipe	replace	?				Steelφ110, afterφ150
6	dicharge rate						
7	pressure gage	installation	-				
8	air relief valve	installation	-				
9	gate valve	re-use	?				
10	check valve	re-use	?				
Reservoir							<input type="checkbox"/> picture
11	structure	repaire	fonction				made of steel, 20mH There wasn't reakage of water.
12	pipes	repaire	fonction				
13	water level gage	installation	-				
14	lignting rod	installation	-				
Control room, power line							<input type="checkbox"/> picture
15	pipes	installation	-				
16	flowmeter	no need	-				
17	pressure gage	installation	-				
18	safty relief valve	installation	-				
19	gate valve	installation	-				
20	check valve	installation	-				
21	water meter	installation	-				
22	transformer with fuse-brea	replace	not fonction				Electrical power from commercial power line, transformer is : 160kVA, 3phases, 10,000V/400V, made in USSR in 1983
23	incoming panel (with watt-hour meter)	installation					
24	control panel of submersible pump	replace	?				
25	electric wire or cable	replace					
26	fence	re-use					
Equipments of distribution							
27	pipes	repaire					
28	valves box	?					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	?					<input type="checkbox"/> picture
32	water meter	installation					
33	gate valve	installation					
Others							

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.13 Rural Water Supply System Survey Sheet (S5 Sultanabod)

Sites name: S5 Sultanabod x (system works)

Visit day, time: 11/28 15:30~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Connntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	re-use	fonction				The facilities are rehabilitated 6 months ago, now work.
2	casing	re-use	fonction				
3	quality water						
4	submersible pump	re-use	fonction				The submersible pump and distribution pipes are repaired. 60m <sup>3</sup> /h, original capacity 45kW, but now 32kW of pump is installed.
5	riser pipe	re-use	fonction				steel φ150
6	dicharge rate						<p>The diagram illustrates the components of a borehole system. It shows a 'borehole house' connected to a 'gate' and a 'check valve'. A 'control panel' is connected to the system. A 'pressure gage' is also shown. The system leads to a 'borehole' and finally 'to discharge'.</p>
7	pressure gage	re-use	fonction				
8	air relief valve	installati n	-				
9	gate valve	re-use	fonction				
10	check valve	re-use	fonction				φ200
							φ200
Reservoir							<input type="checkbox"/> picture
11	structure	repaire	fonction and breakdown				There're 2 reservoir of 25m <sup>3</sup> outside of the pumping station, one works but another is out of order.
12	pipes	repaire	fonction				
13	water level gage	installati n	-				
14	liignting rod	no-need	-				
Control room, power line							<input type="checkbox"/> picture
15	pipes	installati n	-				In the room of borehole, there is control panel of submersible pump.
16	flowmeter	no need	-				
17	pressure gage	installati n	-				
18	safty relief valve	installati n	-				
19	gate valve	installati n	-				
20	check valve	installati n	-				
21	water meter	installati n	-				
22	transformer with fuse-brea	re-use	fonction				
23	incoming panel (with watt-hour meter)	installati n					
24	control panel of submersible pump	replace	fonction				400V, NFB 100A, ammeter max 150A
25	electric wire or cable	replace					
26	fence	re-use					
Equipments of distribution							
27	pipes	repaire					
28	valves box	?					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	?					<input type="checkbox"/> picture
32	water meter	installati n					
33	gate valve	installati n					
Others							

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.14 Rural Water Supply System Survey Sheet (S9 Binokor)

Sites name: S9 Binokor

△ (system not small)

Visit day, time: 11/28 10:45~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Conntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	?	One is works but the others don't work.			Operation and maintenance by Vodakanal, owed by Jamoat. There're 3 boreholes, but only one works now. Facilities were rehabilitated in 2005.	
2	casing	?	One is works but the others don't work.				
3	quality water						
4	submersible pump	replace	fonction and breakdown			Installed depth is 35 meters. This pump fill up the reservoir for less than 1 hour	
5	riser pipe	replace	?			Steel, φ120	
6	dicharge rate						
7	pressure gage	installation	-				
8	air relief valve	installation	-				
9	gate valve	re-use					
10	check valve	installation	-				
Reservoir							<input type="checkbox"/> picture
11	structure	repaire	fonction			130m3-20mH, made of steel	
12	pipes	repaire	fonction				
13	water level gage	installation	-				
14	ligntning rod	installation	-				
Control room, power line							<input type="checkbox"/> picture
15	pipes	installation	-				
16	flowmeter	no need	-				
17	pressure gage	installation	-				
18	safty relief valve	installation	-				
19	gate valve	installation	-				
20	check valve	installation	-				
21	water meter	installation	-				
22	transformer with fuse-breake	replace	fonction			400kVA, 3phases, 10,000V/400V	
23	incoming panel (with watt-hour meter)	installation	breakdown			There are 7 panels for feeder and control of pumps, but almost of panels don't work.	
24	control panel of submersible pump	installation and replace	fonction and breakdown			made in 1975, 380V 69A	
25	electric wire or cable	installation and replace	?				
26	fence	re-use					
Equipments of distribution							
27	pipes	repaire					
28	valves box	?					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	?				<input type="checkbox"/> picture	
32	water meter	installation					
33	gate valve	installation					
Others							

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.15 Rural Water Supply System Survey Sheet (N1 44-Chashuma 01 tinsoy)

Sites name: N1 44-Chashuma 01 tinsoy × (No people)

Visit day, time: 11/29 10:30~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Conntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture:
1	screen	?	function and breakdown				there are three boreholes. Two of them are functioning. The other is breakdown.
2	casing	?	function and breakdown				
3	quality water						
4	submersible pump	installation and	function and breakdown				There are three submersible pumps. One pump is working. One is malfunction and another is removed. Spec. is 120m <sup>3</sup> /h-80mH 32kW.
5	riser pipe	installation and	function and breakdown				steel, φ 114, 30m
6	dicharge rate						
7	pressure gage	installation	function				
8	air relief valve	?	?				φ 32*3, φ 32*3(transmission line)
9	gate valve	installation and					φ 150*9, 3pits*d=1.5m, φ 250*4(transmission line)
10	check valve	installation and					φ 150*3
Reservoir							Two 250 m <sup>3</sup> of concrete ground tanks are in the main pumping station. Bahor and Taraganov have two 100m <sup>3</sup> of tanks and one 500m <sup>3</sup> of tank. Oltinsoy and Orzuhave 25m <sup>3</sup> of ground tank..
11	structure	installation	function	(It's too old)			
12	pipes	?	?				Transmission line: φ 273, steel, 0.7km
13	water level gage	not require	-				
14	ligtning rod	installation	-				
							Reconstruction of pump house of main pumping stationis required. Because it vibrates during operation.
Control room, power line							<input type="checkbox"/> Pictute
15	Structure	replace	function				Reconstruction of pump house of main pumping stationis required. Because it vibrates during operation.
16	pipes	re-use	function				There're three booster pumps for distribution, one works, but the others don't work. There's problem on the pump, and cables. 75kW 3,000rpm
17	flowmeter	installation	-				There are 3 booster pumps, but only one pump is working. Two pumps are not working due to problem of cable. Capacity of pumps is 75kw
18	pressure gage	installation	-				
19	safty relief valve	installation	-				
20	gate valve	re-use	function				
21	check valve	re-use	function				
22	water meter	installation	-				
23	transformer with fuse-breaker	installation and	fonction				
24	incoming panel (with watt-hour meter)	replace	?				4 incoming panels and power boards for high voltage. 4 inercepters for low voltage.
25	control panel of submersible pump	replace	function and breakdown				
26	electric wire or cable	replace	function and breakdown				1 motor is malfunctioned due to operation furing lost phase. It was caused too narrow spacing of cables and cables touched each other during typhoon. Reputting work of electric wire is required.
27	fence	re-use					
Equipments of distribution							
27	pipes	repair					Iron ductile and steel, φ 273-114, 35km. Leakage was observed from 10km of pipeline. Distribution pipeline welded spirally is installed on the φ 200x9 φ 200x4 18 pits with diameter of 1.5m
28	valves box	?					
29	air relief valve	?					φ 32*12
30	sand ejection valve	?					
31	public taps	?					<input type="checkbox"/> Picture, 65taps
32	water meter	installation					
33	gate valve	installation					
Others							There are booster pumping station s in Bahor and Traganov. Pumping station in Bahor has two pumps (55kW, 2,940rpm), but only one pump is working. Pumping station in Traganov has also two pumps. Three 50m <sup>3</sup> of tanks exist in Bahor. One 75m <sup>3</sup> of tanks exist in Traganov.

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.16 Rural Water Supply System Survey Sheet (N2 Alfa Ferma)

Sites name: N2 Alfa Ferma

x (No people)

Visit day, time: 11/29 10:30~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Conntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture: There aren't any houses in this area, but they said "in the future the people will come".
1	screen	installatio n	breakdown				There are 2 well, into the one well (depth 23m), a hund pump is installed, another is about 300 m from this hund pump.
2	casing	installatio n	breakdown				
3	quality water						
4	submersible pump	installatio n	-				
5	riser pipe	installatio n	-				
6	dicharge rate						
7	pressure gage	installatio n	-				
8	air relief valve	installatio n	-				
9	gate valve	installatio n	-				
10	check valve	installatio n	-				
Reservoir							<input type="checkbox"/> picture
11	structure	installatio n	?	(It's too old)			made of steel,
12	pipes	repaire	?				
13	water level gage	installatio n	-				
14	lignting rod	installatio n	-				
Control room, power line							<input type="checkbox"/> picture There isn't control room.
15	pipes	installatio n	-				
16	flowmeter	no need	-				
17	pressure gage	installatio n	-				
18	safty relief valve	installatio n	-				
19	gate valve	installatio n	-				
20	check valve	installatio n	-				
21	water meter	installatio n	-				
22	transformer with fuse-breaker	replace	fonction				250kVA, 3phases, 10,000V/400V
23	incoming panel (with watt-hour meter)	installatio n					
24	control panel of submersible pump	installatio n	-				
25	electric wire or cable	installatio n					
26	fence	installatio n					
Equipments of distribution							
27	pipes	installatio n	?				
28	valves box	installatio n					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	installatio n					<input type="checkbox"/> picture
32	water meter	installatio n					
33	gate valve	installatio n					
Others							

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.17 Rural Water Supply System Survey Sheet (P1 Utsastok Tugul)

Sites name: P1 Utsastok Tugul

Visit day, time: 11/27 11:30~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Conntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	?	?				Borehole is beside of junior high school, it didn't work after civil war.
2	casing	?	?				<p>The diagram shows a schoolhouse (rectangle) and a playground (square) in the center. Three reservoirs (circles) are located around the site. A legend at the bottom identifies symbols for 'reservoir', 'hundpum', and 'borehole'.</p>
3	quality water						
4	submersible pump	installatio	-				
5	riser pipe	installatio	-				
6	discharge rate						
7	pressure gage	installatio	-				
8	air relief valve	installatio	-				
9	gate valve	installatio	-				
10	check valve	installatio	-				
Reservoir							
11	structure	installatio	?	(It's too old)			Made of steel, 25m3-16mH
12	pipes	repaire	fonction				
13	water level gage	installatio	-				
14	ligtning rod	installatio	-				
Control room, power line							<input type="checkbox"/> picture
15	pipes	installatio	-				
16	flowmeter	no need	-				
17	pressure gage	installatio	-				
18	safty relief valve	installatio	-				
19	gate valve	installatio	-				
20	check valve	installatio	-				
21	water meter	installatio	-				
22	transformer with fuse-break	?	?				
23	incoming panel (with watt-hour meter)	installatio	-				
24	control panel of submersible pump	installatio	-				
25	electric wire or cable	installatio	-				
26	fence	installatio	-				
Equipments of distribution							
27	pipes	repaire	?				
28	valves box	?					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	?					<input type="checkbox"/> picture
32	water meter	installatio	-				
33	gate valve	installatio	-				
Others							

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.18 Rural Water Supply System Survey Sheet (P5 Komsomol)

Sites name: P5 Komsomol

x

Visit day, time: 11/26 17:00~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Conntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	installation	breakdown				There's some stones inside of the borehole. Depth is 36 meters.
2	casing	installation	breakdown				This system worked 5 or 6 years ago.
3	quality water						
4	submersible pump	installation	-				A submersible pump have been installed, but now there isn't. There was a power line of three phases.
5	riser pipe	installation	-				
6	discharge rate						
7	pressure gage	installation	-				
8	air relief valve	installation	-				
9	gate valve	installation	-				
10	check valve	installation	-				
Reservoir							<input type="checkbox"/> picture
11	structure	installation	?	(It's too old)			Hight is about 15meters until bottom of the reservoir, made of steel.
12	pipes	repaire	?				
13	water level gage	installation	-				
14	ligtning rod	installation	-				
Control room, power line							<input type="checkbox"/> picture
15	pipes	installation	-				
16	flowmeter	no need	-				
17	pressure gage	installation	-				
18	safty relief valve	installation	-				
19	gate valve	installation	-				
20	check valve	installation	-				
21	water meter	installation	-				
22	transformer with fuse-break	no need	-				There is a power line of 400V three phases and 4 line to the control room.
23	incoming panel (with watt-hour meter)	installation	-				
24	control panel of submersible pump	replace	breakdown				
25	electric wire or cable	replace					
26	fence	installation	-				
Equipments of distribution							
27	pipes	repaire					
28	valves box	?					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	?					<input type="checkbox"/> picture
32	water meter	installation					
33	gate valve	installation					
Others							

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.19 Rural Water Supply System Survey Sheet (P6 Utsastok Pekhtakor)

Sites name: P6 Utsastok Pekhtakor

Visit day, time: 11/27 14:50~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Connntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	re-use	fonction				2 boreholes and each inside of borehole there is submersible pump. Rehabilitated in 2004 by UNDP, one pump was out of order in 2006. 2 pumps worked alternately.
2	casing	re-use	fonction				Village people don't know the reason that pumps didn't work. But there is many reakage from distribution pipes and there're also operating problems.
3	quality water						
4	submersible pump	replace	fonction and breakdown				
5	riser pipe	re-use	?				φ110 and φ130
6	discharge rate						
7	pressure gage	installation	-				
8	air relief valve	installation	-				
9	gate valve	installation	-				
10	check valve	installation	-				
Reservoir							<input type="checkbox"/> picture
11	structure	repaire	fonction				
12	pipes	repaire	fonction				
13	water level gage	installation	-				
14	ligntning rod	installation	-				
Control room, power line							<input type="checkbox"/> picture : There isn't control room.
15	pipes	installation	-				
16	flowmeter	no need	-				
17	pressure gage	installation	-				
18	safty relief valve	installation	-				
19	gate valve	installation	-				
20	check valve	installation	-				
21	water meter	installation	-				
22	transformer with fuse-brea	repaire	fonction				250kVA 10,000V/400V 3phases-4lines made in USSR in 1979, 1.3tons. This transformer also provides for houses. Condition is comparatively
23	incoming panel (with watt-hour meter)	installation					
24	control panel of submersible pump	installation	-				
25	electric wire or cable	installation	-				
26	fence	repaire	particiel				
Equipments of distribution							
27	pipes	repaire					
28	valves box	?					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	?					<input type="checkbox"/> picture
32	water meter	installation					
33	gate valve	installation					
Others							

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.20 Rural Water Supply System Survey Sheet (P9 Utsastok Zarbdor)

Sites name: P9 Utsastok Zarbdor

○

Visit day, time: 11/27 15:25~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Connntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	?	?				Rehabilitated by Against Hunger
2	casing	?	?				
3	quality water	?					Because of quality of water, village people refused to pay for water.
4	submersible pump	replace	breakdown				Pump was burned one year ago.
5	riser pipe	replace	?			(because of quality of water)	φ85mm
6	dicharge rate						
7	pressure gage	installatio n	-				
8	air relief valve	installatio n	-				
9	gate valve	installatio n	-				
10	check valve	installatio n	-				
Reservoir							<input type="checkbox"/> picture
11	structure	repaire	fonction			(One will be repaired, another will be examinated)	There are 2 units, one is 25m3-10mH, another is 6mH.
12	pipes	repaire	fonction				
13	water level gage	installatio n	-				
14	ligtning rod	installatio n	-				
Control room, power line							<input type="checkbox"/> picture
15	pipes	installatio n	-				
16	flowmeter	no need	-				
17	pressure gage	installatio n	-				
18	safty relief valve	installatio n	-				
19	gate valve	installatio n	-				
20	check valve	installatio n	-				
21	water meter	installatio n	-				
22	transformer with fuse-breaker	no need	-				Electricity was provided by 400V 3phases-4lines for the control room. That power line is near the control room.
23	incoming panel (with watt-hour meter)	installatio n	-				
24	control panel of submersible pump	installatio n	-				Someone took away for his house.
25	electric wire or cable	installatio n	-				
26	fence	re-use					
Equipments of distribution							
27	pipes	repaire					
28	valves box	?					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	?					<input type="checkbox"/> picture
32	water meter	installatio n					
33	gate valve	installatio n					
Others							

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.21 Rural Water Supply System Survey Sheet (P11 Utsastok Shakardasht)

Sites name: P11 Utsastok Shakardasht × Visit day, time: 11/27 9:20~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Conntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	installation	breakdown				Borehole is plugged with sand in 1992. There are 15~20 hand pumps made by themselves in this area. Depth of well is 9~12 meters.
2	casing	installation	breakdown				
3	quality water						
4	submersible pump	installation	-				A submersible pump of 40m3/125mH was installed.
5	riser pipe	installation	-				
6	dicharge rate						
7	pressure gage	installation	-				
8	air relief valve	installation	-				
9	gate valve	installation	-				
10	check valve	installation	-				
Reservoir							<input type="checkbox"/> picture
11	structure	installation	breakdown	(It's too old)			25m3-16mH, made of steel, constructed in 1965.
12	pipes	installation	breakdown				Pipe is broken.
13	water level gage	installation	-				
14	ligtning rod	installation	-				
Control room, power line							<input type="checkbox"/> picture : There isn't control room.
15	pipes	installation	-				
16	flowmeter	no need	-				
17	pressure gage	installation	-				
18	safty relief valve	installation	-				
19	gate valve	installation	-				
20	check valve	installation	-				
21	water meter	installation	-				
22	transformer with fuse-breaker	replace	fonction	(It' too old)			100kVA, 3phases-4lines, 10,000V/400V, 50Hz, made in 1969
23	incoming panel (with watt-hour meter)	installation					
24	control panel of submersible pump	installation	-				
25	electric wire or cable	installation	-				
26	fence	installation	-				
Equipments of distribution							
27	pipes	repaire					
28	valves box	?					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	?					<input type="checkbox"/> picture
32	water meter	installation					
33	gate valve	installation					
Others							

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.22 Rural Water Supply System Survey Sheet (P12 Utsastok Shakardasht)

Sites name: P12 Utsastok Shakardasht x Visit day, time: 11/27 10:05~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Contnenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	installatio n	breakdow n				This facility stopped in 1994. This borehole is plugged with sand and stones.
2	casing	installatio n	breakdow n				
3	quality water						
4	submersible pump	installatio n	-				
5	riser pipe	installatio n	-				
6	dicharge rate						
7	pressure gage	installatio n	-				
8	air relief valve	installatio n	-				
9	gate valve	installatio n	-				
10	check valve	installatio n	-				
Reservoir							<input type="checkbox"/> picture
11	structure	installatio n	breakdow n	(It's too old)			This reservoir is made of steel, 25m3-15or16mH. This structure is little inclined.
12	pipes	installatio n	breakdow n				Diameter of distribution and also discharge pipes are $\phi$ 100 made of steel.
13	water level gage	installatio n	-				
14	lightning rod	installatio n	-				
Control room, power line							<input type="checkbox"/> picture: There isn't control room.
15	pipes	installatio n	-				
16	flowmeter	no need	-				
17	pressure gage	installatio n	-				
18	safty relief valve	installatio n	-				
19	gate valve	installatio n	-				
20	check valve	installatio n	-				
21	water meter	installatio n	-				
22	transformer with fuse-breaker	no need	-				Commercial power line of 400V 3phases and 4 lines is near the reservoir (100-200m).
23	incoming panel (with watt-hour meter)	installatio n	-				
24	control panel of submersible pump	installatio n	-				
25	electric wire or cable	installatio n	-				
26	fence	installatio n	-				
Equipments of distribution							
27	pipes	repaire	?				
28	valves box	?					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	?					<input type="checkbox"/> picture
32	water meter	installatio n					
33	gate valve	installatio n					
Others							
							Price of cotton is 10 diram per kilogram.

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.23 Rural Water Supply System Survey Sheet (P13 Sarmantoi)

Sites name: P13 Sarmantoi

○

Visit day, time: 11/26 14:20~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Conntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	?	?				2 boreholes, one is submersible pump, another is spiral and centrifugal pump based on the ground level.
2	casing	?	?				
3	quality water						
4	submersible pump	replace	breakdown				Because of sand in the groundwater, submersible pump was broken. Depth installed is more than 40m.
5	riser pipe	replace	?				φ110 (diametre outside)
6	dicharge rate						
7	pressure gage	replace	?				
8	air relief valve	installation	-				
9	gate valve	re-use					
10	check valve	installation	-				
Reservoir							<input type="checkbox"/> picture
11	structure	repaire	fonction				Hight is about 15meters until bottom of the reservoir. 25m3*2 unite. Frame and posts are made of steel, tank are made of concret.
12	pipes	repaire	fonction				There are some small holes on the one tank. But another is no hole. French NGO named ACTED repaired these facilities.
13	water level gage	installation	-				
14	ligtning rod	installation	-				
Control room, power line		repaire					<input type="checkbox"/> picture
15	pipes	installation	-				
16	flowmeter	no need	-				
17	pressure gage	installation	-				
18	safty relief valve	installation	-				
19	gate valve	installation	-				
20	check valve	installation	-				
21	water meter	installation	-				
22	transformer with fuse-breaker	replace	fonction				160kVA, 3phases, 10,000V/400V, made in USSR
23	incoming panel (with watt-hour meter)	installation	?				
24	control panel of submersible pump	replace	breakdown				
25	electric wire or cable	replace					
26	fence	re-use					
Equipments of distribution							
27	pipes	repaire					
28	valves box	?					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	?					<input type="checkbox"/> picture
32	water meter	installation					
33	gate valve	installation					
Others							

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.24 Rural Water Supply System Survey Sheet (P14 Utsastok M. Gorikiy)

Sites name: P14 Utsastok M. Gorikiy

◎

Visit day, time: 11/27 11:05~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Connntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	re-use	?				In 2003 the rehabilitation of facilities was implemented by UNDP-ECHO
2	casing	re-use	?				Surface of site about 20m x 50m
3	quality water						
4	submersible pump	installatio n	breakdow n				The moter of submersiblepump : diameter 180mm, length 70cm
5	riser pipe	installatio n	-				
6	dicharge rate						
7	pressure gage	installatio n	-				
8	air relief valve	installatio n	-				
9	gate valve	installatio n	-				
10	check valve	installatio n	-				
Reservoir							<input type="checkbox"/> picture
11	structure	repaire	fonction				Made of steel, 26m3-10mH
12	pipes	repaire	fonction				discharge and distribution main $\phi$ 100, steel pipes
13	water level gage	installatio n	-				
14	lightning rod	installatio n	-				
Control room, power line							<input type="checkbox"/> picture
15	pipes	repaire	fonction				Condition of control room isn't so bad.
16	flowmeter	no need	-				
17	pressure gage	installatio n	-				
18	safty relief valve	installatio n	-				
19	gate valve	installatio n	-				
20	check valve	installatio n	-				
21	water meter	installatio n	-				
22	transformer with fuse-breaker	replace	fonction				160kVA, 3phases, 10,000V/400V, it's old.
23	incoming panel (with watt-hour meter)	installatio n					
24	control panel of submersible pump	replace	breakdow n				normal current written on the panel 69A
25	electric wire or cable	installatio n					
26	fence	re-use					
Equipments of distribution							
27	pipes	repaire	60% fonction				There are pipes made of PVC and steel, said 60% is useful.
28	valves box	?					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	?					<input type="checkbox"/> picture
32	water meter	installatio n					
33	gate valve	installatio n					
Others							

Supporting Report 2  
Chapter 4 Existing Condition and Development Issues of Rural Water Supply System

Attached Table 4.25 Rural Water Supply System Survey Sheet (P15 Utsastok Burka)

Sites name: P15 Utsastok Burka

△

Visit day, time: 11/26 15:30~

No.	Equipments	Replace or re-use	Fonction or breakdown	Bilder (country)	Manufacturing date	Conntenu of problems, expected cause of breakdown	Specifications
Borehole							<input type="checkbox"/> picture
1	screen	?	?				
2	casing	?	?				
3	quality water						Arsenic is less than 0.2 mg/l.
4	submersible pump	installatio n	-				A hand pump is installed.
5	riser pipe	installatio n	-				
6	dicharge rate						
7	pressure gage	installatio n	-				
8	air relief valve	installatio n	-				
9	gate valve	installatio n	-				
10	check valve	installatio n	-				
Reservoir							<input type="checkbox"/> picture
11	structure	installatio n	?	(It's too old)			Hight is about 15meters until bottom of the reservoir. Tank is made of steel. There is no reakage from tank.
12	pipes	installatio n	?				It's necessary to change the pipes.
13	water level gage	installatio n	-				
14	lignting rod	installatio n	-				
Control room, power line							<input type="checkbox"/> picture
15	pipes	installatio n	-				Control room is destroyed.
16	flowmeter	no need	-				
17	pressure gage	installatio n	-				
18	safty relief valve	installatio n	-				
19	gate valve	installatio n	-				
20	check valve	installatio n	-				
21	water meter	installatio n	-				
22	transformer with fuse-breaker	no need	-				There isn't a transformer and incoming panel, but near the hund pump there is a power line of 220V sigle phase, 380V three phases and 4
23	incoming panel (with watt-hour meter)	installatio n	-				
24	control panel of submersible pump	installatio n	-				
25	electric wire or cable	installatio n	-				
26	fence	installatio n	-				
Equipments of distribution							
27	pipes	repaire	?				
28	valves box	?					
29	air relief valve	?					
30	sand ejection valve	?					
31	public taps	?					<input type="checkbox"/> picture: There are taps in each houses about 70% of household. Total 560 houses in three villages.
32	water meter	installatio n					
33	gate valve	installatio n					
Others							

**2 CHAPTER4 EXISTING CONDITION  
AND DEVELOPMENT ISSUES  
OF RURAL WATER SUPPLY SYSTEM**

**Appendix-3 Data Base of Rural Water Supply System**

- (1) Attached Figures**
- (2) Attached Tables**

## 2. CHAPTER 4 EXISTING CONDITION AND DEVELOPMENT ISSUES OF RURAL WATER SUPPLY SYSTEM

### 4.1 INTRODUCTION

In order to formulate the water supply improvement plan for the existing water supply system, detailed information of each water supply system located in the targeted area is essential.

However, due to an inexistence of a database of the water supply system in the target area, the inventory survey has been carried out in this Study, as mentioned in Chapter 4. And all information collected by this inventory survey was compiled in a database created in this Study.

In addition, the Geographical Information System (hereinafter referred to as GIS) was introduced to the study. The GIS technology is possible to do the spatial analysis by using various data, which is one of the advantages of utilizing GIS.

In this chapter, the design of database created considering the actual utilization of the databases and the outputs created by GIS are described.

### 4.2 DATABASE SYSTEM CREATED IN THE STUDY

#### 4.2.1 DESIGN OF THE DATABASE SYSTEM

The results of the inventory survey were compiled by MS-Excel and then those data were divided in to 7 tables, in accordance with their characteristics listed in the *Table 4.1* and *Table 4.2*, that compose the “Khatlon\_WSS.mdb”, a database created by MS-Access.

It will point out simply the method of viewing the database as follows. Opening the file of “Khatlon\_WSS.mdb” to view the database, “Start” form pops up to choose each facility. To select the name of the facility, records, being compiled six sheets, are opened up. Each sheet shows the data of the inventory survey. It is a set of view form in the Attached Figure 4.3 - 4.8.

**Table 4.1 List of Information in the Database (1)**

Database table	Items	Remarks	
A_Water_Supply	<ul style="list-style-type: none"> <li>-Date inventoried</li> <li>-Name of Rayon,</li> <li>-Name of Jamoat</li> <li>-Name of Village</li> <li>-Coordinates</li> <li>-Name of the WSS</li> <li>-Year of Construction</li> <li>-Owner of the WSS</li> <li>-Operator of the WSS</li> <li>-Type of source of water</li> <li>-Source of water</li> </ul>	<ul style="list-style-type: none"> <li>-Operating condition</li> <li>-Average quantity of water supplied</li> <li>-Maximum quantity of water supplied</li> <li>-Service hours</li> <li>-Reason of stopping the operation</li> <li>-Date of stopping the operation</li> <li>-History of rehabilitation made in the system</li> </ul>	Basic information about the water supply system (English and Russian).
B_Water_Source	<ul style="list-style-type: none"> <li>-Quantity of well</li> <li>-Depth of well</li> <li>-Capacity (yield) of well</li> <li>-Static and dynamic water level of the well</li> <li>-Casing diameter</li> <li>-Casing material</li> <li>-Screen position</li> <li>-Pump model and type</li> <li>-Pump setting position</li> </ul>	<ul style="list-style-type: none"> <li>-Pump motor output</li> <li>-Pump head</li> <li>-Pump discharge capacity</li> <li>-Diameter of the riser pipe</li> <li>-Material of the riser pipe</li> <li>-Pump starting up method</li> <li>-Location of control panel</li> <li>-Alternative water source</li> <li>-Distance to fetching water</li> <li>-Fetching times per day</li> </ul>	Information about the source of water for the water supply system (English and Russian).

**Table 4.2 List of Information in the Database (2)**


Database table	Items	Remarks
C_Network	<ul style="list-style-type: none"> <li>-Diameter and material of the aqueduct</li> <li>-Total length of the aqueduct</li> <li>-Condition and problems of the aqueduct</li> <li>-Quantity of valves in the aqueduct</li> <li>-Coordinates of the reservoir</li> <li>-Capacity and material of the reservoir</li> <li>-High and low water level of the reservoir</li> <li>-Condition and problems of the reservoir</li> <li>-Existence of chlorination facility and the agent utilized</li> <li>-Diameter and material of the transmission line</li> <li>-Length of the transmission line</li> <li>-Condition and problems of the transmission line</li> <li>-Quantity of valves in the transmission line</li> <li>-Coordinates of the Distribution tank</li> <li>-Type and capacity of the distribution tank</li> <li>-Material of the distribution tank</li> <li>-Condition and problems of the distribution tank</li> <li>-Diameter and material of the distribution main</li> <li>-Length of the distribution main</li> <li>-Condition and problems of the distribution main</li> <li>-Quantity of valves in the distribution main</li> <li>-Quantity of public taps</li> <li>-Diameter and material of the public tap</li> <li>-Total length of the service line</li> </ul>	Information about the water supply system network (English and Russian)
E_Rehabilitation	-Name and quantity of facilities to be rehabilitated or replaced	(English and Russian)
F_Figure	Schematic layout of the water supply system	(English and Russian)
Pop_Serv	<ul style="list-style-type: none"> <li>-Villages served by the water supply system</li> <li>-Population served by the water supply system</li> </ul>	(English and Russian)
WaterQuality	-Results of the water quality analysis	(English and Russian)
Well	-Coordinates of each well existent as a water source	(English and Russian)

The structure of the Khatlon\_WSS Database is shown in *Figure 4.1*. Two sub folders are created under Khatlon\_WSS folder; “Db” folder and “GIS” folder. In the “Db” data folder, “Khatlon\_WSS.mdb”, a MS-Access database file and two subfolders “Tables (excel)” and “Figures” are filed. “Khatlon\_WSS.mdb” file is composed of seven (7) tables where the results of the inventory survey are organized. The “Tables (excel)” folder contains MS-Excel files where the results of the inventory survey are organized and in the “Figures” folder, the schematic layout of all water supply system inventoried is filed as a raster data.

In the “GIS” data folder, the data files for creating maps and results of analysis such as table, polygon, polyline and point data are filed as a shape file and a dbf file. Under “GIS” folder, four (4) sub folders were created (“01\_MapFileGIS”, “Raster”, “Study\_Area” and “Figures”). First of all, in the “01\_MapFilesGIS” the outputs of GIS analysis such as distribution of water supply

system, operational condition of the water supply system, population served, etc are filed as a map file (“mxd” format which can be opened by Arc GIS).

Second, in the “Raster” folder, 28 maps which cover the whole Khatlon Oblast are filed as a raster data. Those maps were utilized as a background of the map files. Third, in the “Study\_Area” folder, shapefile of the administrative boundaries of the Study Area are filed and two subfolders were also created (“Inventory” and “Priority System”). Those subfolders contain the shapefiles and dbf files of the analyzed by GIS. Finally, in the “Figure” folder, the outputs of the analysis by GIS are filed as a raster data.



**FIGURE 4.1 STRUCTURE OF DATABASE SYSTEM**

**THE STUDY FOR SUSTAINABLE RURAL WATER SUPPLY SYSTEM IN THE  
 SOUTHERN KHATLON OBLAST IN THE REPUBLIC OF TAJIKISTAN**

**JICA**

### 4.3 DATABASE SYSTEM CREATED WITH GEOGRAPHIC INFORMATION SYSTEM (GIS)

#### 4.3.1 GENERAL

In order to realize effective advantage of the GIS, it should be mentioned that accurate data input and proper technical consideration to the results obtained by GIS analysis are required to prevent the misunderstanding of the results. Considering the characteristics of the advantages of GIS technology, the preparation of maps and analysis were carried out as long as the study uses the developed GIS.

#### 4.3.2 MAPS CREATED BY GEOGRAPHIC INFORMATION SYSTEM (GIS)

##### (1) Base Map

Administrative boundaries such as Oblast boundary and Rayon boundary are fundamental information; however, the digital format of those boundaries data was not available before starting the Study. Therefore, the Study Team prepared and created the digital format of the boundaries through three (3) steps, which are

1) The collection of the boundary data on the prints, 2) the scanning of collected maps and 3) the digitizing of the scanned maps.

The base maps provided in the Study are listed in the *Table 4.3*.

**Table 4.3 List of Base Maps Created**

	Data	Source	Format
1	Study area boundary	Existing Topographic map	Shape
2	Rayon boundary	Existing Topographic map	Shape
3	Oblast boundary	Existing Topographic map	Shape

##### (2) Analysis Map

In order to understand the actual situation of the water supply system of the Study Area, analysis maps of the actual situation of the water supply system was created in the Study. An inventory survey was accomplished due to an inexistence of any information about the water supply system of the covered target area in neither digital nor even paper base document.

The development of a location map of water supply systems, in digital format, is one of the important results achieved by the Study.

Analysis maps were created by overlaying the information of the inventory survey such as operation condition, served population, etc to the correspondent water supply system. *Table 4.4* show the list of maps created in this Study.

**Table 4.4 List of Maps Created**

	Maps
1	Distribution map of the water supply system
2	Distribution map of the water supply facility by operating condition
3	Distribution map of the water supply system by number of population served
4	Distribution map of the water supply system by type of water source
5	Distribution map of the priority facilities

#### **4.4 RECOMMENDATIONS**

The database system is created as the results of the analysis and of the field investigations performed by the Study Team, i.e. the inventory survey for the water supply system and site survey. In order to facilitate continued effective utilization of the database, the following items are absolutely recommended.

##### **(1) Improvement of the Accuracy of Locality Information**

For the effective application of the database, the locality information is the fundamental matter, especially for the analysis by the GIS. Therefore, it is strongly recommended to determine the coordinate by the Global Positioning System (GPS) when any new data is added to the database. Besides, it is desirable to determine the coordinates even for the existing data.


##### **(2) Periodical Update of the Database**

In order to reflect the latest conditions on the water supply system, it is recommended to do the periodical update of the database.

**2 CHAPTER4 EXISTING CONDITION  
AND DEVELOPMENT ISSUES  
OF RURAL WATER SUPPLY SYSTEM**

**Appendix-3 Data Base of Rural Water Supply System**

**(1) Attached Figures**



**ATTACHED FIGURE 4.2 START FORMAT**

**THE STUDY FOR SUSTAINABLE RURAL WATER SUPPLY SYSTEM IN THE  
 SOUTHERN KHATLON OBLAST IN THE REPUBLIC OF TAJIKISTAN**

**JICA**

**Исследование Плана Устойчивого Снабжения Питательной Водой Южных Районов Хатлонской Области Республики Таджикистан**

**The Study for Sustainable Rural Water Supply System in the Southern Khatlon Oblast in the Republic of Tajikistan**

**Исследование Объектов Существующих Систем Сельхозводоснабжения**  
**Inventory of Existing Rural Water Supply Systems**

---

Оборудование код:       Дата обследования:       Название интервьюер:    
 Facility Code:      Date of Survey:      Name of Interviewer:

Название Района:       Название Джамоата:    
 Name of Rayon:      Name of Jamoat:

Название Кишлака:    
 Name of Village:

Координаты (центр кишлака):  C N       B E      Высота:  м      UTM:  C (N)   
 Coordinates (center of village):      Altitude:       B (E)

Оборудование код:    
 Facility Code:

**A. Система водоснабжения / A. Water Supply System**

Название системы водоснабжения:       Год строительства:    
 Name of Water Supply System:      Year of Construction:

Владелец системы водоснабжения:    
 Owner of Water Supply System:

Организация несущая ответственность за систему:       Рабочее состояние:    
 Name of Operator of Water Supply System:      Operating condition:

Источник воды:      Water Source:      Замечание:      Remarks:   
 1.                      
 2.                      
 3.                  

**Если работаем / If Working**

Оборудование код:    
 Facility Code:

Рабочий период:  (Круглый год / По сезону)      Район обслуживания и населения:  (Throughout the year / Seasonal)   
 Working period:      Service area and service population

Если по сезону / If seasonal		населения	
Период: <input type="text"/>	Причина: <input type="text"/>	Кишлака:	Population:
Period:	Reason:	Бустон	1135
		Пешкадам	1550
		Обслуживаемое население, в общем: <b>2685</b>	
		Total population served:	

Средняя подача воды:  м<sup>3</sup>/день      m<sup>3</sup>/day   
 Average water supply:   
 Максимальная подача воды:  м<sup>3</sup>/день      m<sup>3</sup>/day   
 Maximum daily water supply:   
 Максимальная часовая подача воды:  м<sup>3</sup>/час      m<sup>3</sup>/hour   
 Maximum hourly water supply:   
 Служба времени:    
 Service time:   
 Служба часов:  час/день      hours/day   
 Service hours:

**Если не работаем / If Out of Working**

Оборудование код:    
 Facility Code:

Число выхода из строя:    
 Date of stopping:   
 Указать причину:      Reason of out of working:   
 Частично трубопровод негоден.      Incomplete facility

Информация о реабилитации или ремонта оборудования:	
1- Не проводилось	not conducted
<input type="text"/>	<input type="text"/>
2- <input type="text"/>	<input type="text"/>
3- <input type="text"/>	<input type="text"/>

ATTACHED FIGURE 4.3 FACILITY DATA SHEET 1

THE STUDY FOR SUSTAINABLE RURAL WATER SUPPLY SYSTEM IN THE SOUTHERN KHATLON OBLAST IN THE REPUBLIC OF TAJIKISTAN

JICA

**Б. Источник воды / B. Water Source**

Оборудование код: V-01  
Facility Code:

Число скважин:   
Number of Well(s):

Глубина скважин:  м  
Depth:

Координаты скважин:   
Coordinates of well(s):

Мощность (подача) скважины:  м<sup>3</sup>/час (m<sup>3</sup>/hour)  
Capacity (Yield) of well:

Максимальная подача скважины:  м<sup>3</sup>/час (m<sup>3</sup>/hour)  
Maximum yield of well:

Уровень воды:  
Water Level:

Неподвижный:  
Static Water Level:  м BGL  
 m BGL

Динамичный:  
Dynamic Water Level:  м BGL  
 m BGL

BGL: Ниже грунтового уровня /  
Below ground level

Оборудование код: V-01  
Facility Code:

---

**Обсадные трубы / фильтр (Casing / Screen pipe)**

Диаметр:  мм  
Diameter:

Позиция фильтра:  м BGL  
Position of screen:

Материал:  (Стальной, Нержавеющая сталь, Виниловая, Другой)  
Material: (Steel, Stainless steel, PVC, Other)

Другой:

**Насос (Pump)**

Насос:   
Pump:

Вид (тип):  (Подводная, Вертикальная турбина, Другой)  
Type: (Submersible, Vertical turbine, Other)

Другой:

Позиция:  м BGL  
Position:

Расчетная производительность двигателя:  кВт  
Rated motor output:

Голова насоса (напор):  м  
Pump head:

Подача насоса:  м<sup>3</sup>/мин (m<sup>3</sup>/min)  
Discharge of pump:

Диаметр водоподъемника:  мм  
Diameter of riser pipe:

Материал водоподъемника:   
Material of riser pipe:

Метод включения насоса:   
Starting up method of pump:

Расположение контрольной панели:   
Location of control panel:

**Качество воды / Water Quality**

Оборудование код: V-01  
Facility Code:

---

**Доступность альтернативного источника воды, если снабжение воды сезонное или приостановлено.**  
*Availability of alternative water source, if operation of water supply service is seasonal or service is stopping.*

Вид источника воды:  (Вахшский трубопровод, Подземная вода, Ирригационный канал, Другой /  
Type of water source: Irrigation canal, Vakhsh Conduit, Groundwater, Irrigation Canal, Other)

Другой:  (Указать Вахшской межхоза)  
Other: Vahshskoe between econo

Расстояние до ближайшего источника воды:  км  
Distance from the nearest water source:

Сколько раз набирается вода:  число/день  
Times of fetching water:  times/day

Оборудование код: V-01  
Facility Code:

**ATTACHED FIGURE 4.4 FACILITY DATA SHEET 2**

**THE STUDY FOR SUSTAINABLE RURAL WATER SUPPLY SYSTEM IN THE SOUTHERN KHATLON OBLAST IN THE REPUBLIC OF TAJIKISTAN**

JICA

<b><u>В. Труба (Акведук) / C. Aqueduct</u></b>		Оборудование код: Facility Code: V-01
Диаметр трубы : Diameter of pipe:	<input type="text"/> мм <input type="text"/> mm	Материал трубы : Material of pipe: <input type="text"/>
		Длина трубы : Length of conduit: <input type="text"/> км <input type="text"/> km
Состояние трубы: 1	<input type="text"/>	Опишите проблему: <input type="text"/>
2	<input type="text"/>	
Condition of pipe: 1	<input type="text"/>	Describe the problems: <input type="text"/>
2	<input type="text"/>	
Вид и число задвижек: Type and number of valves:	Задвижка: Sluice valve: <input type="text"/>	Контрольный клапан: Check valve: <input type="text"/>
		Вантуз: Air valve: <input type="text"/>
		Другой: Others: <input type="text"/>
<b><u>Д. Резервуар / D. Reservoir</u></b>		Оборудование код: Facility Code: V-01
Координаты: Coordinates:	<input type="text"/> С <input type="text"/> N	<input type="text"/> В <input type="text"/> E
	Высота: Altitude: <input type="text"/> км <input type="text"/> km	UTM: <input type="text"/> С (N) <input type="text"/> В (E)
Мощность: Capacity: <input type="text"/> м3 <input type="text"/> m3	Материал резервуара: Material of reservoir: <input type="text"/> (бетонный, стальной, другой) (Concrete, steel, other)	Другой: Other: <input type="text"/>
Уровень воды: Water Level:	Высокий уровень воды: High water level: <input type="text"/> м <input type="text"/> m	Низкий уровень воды: Low water level: <input type="text"/> м <input type="text"/> m
Состояние резервуара: 1	<input type="text"/>	Опишите проблему: <input type="text"/>
2	<input type="text"/>	
Condition of reservoir: 1	<input type="text"/>	Describe the problems: <input type="text"/>
2	<input type="text"/>	
<b><u>Е. Система хлоринации / E. Chlorination system</u></b>		
Оборудование: Facility:	<input type="text"/> Не установлено <input type="text"/> Not installed	Вещество, используемое для обеззараживания : Agent used for chlorination: <input type="text"/>
<b><u>Ж. Водовод (линия воды от резервуара до распределительного бака) / F. Transmission line (water line from reservoir to distribution tank)</u></b>		Оборудование код: Facility Code: V-01
Диаметр трубы : Diameter of pipe:	<input type="text"/> мм <input type="text"/> mm	Материал трубы : Material of pipe: <input type="text"/>
		Длина трубы : Distance of water line: <input type="text"/> км <input type="text"/> km
Состояние трубы: 1	<input type="text"/>	Опишите проблему: <input type="text"/>
2	<input type="text"/>	
Condition of pipe: 1	<input type="text"/>	Describe the problems: <input type="text"/>
2	<input type="text"/>	
Вид и число задвижек: Type and number of valves:	Задвижка: Sluice valve: <input type="text"/>	Вантуз: Air valve: <input type="text"/>
		Другой: Others: <input type="text"/>

ATTACHED FIGURE 4.5 FACILITY DATA SHEET 3.1

THE STUDY FOR SUSTAINABLE RURAL WATER SUPPLY SYSTEM IN THE  
SOUTHERN KHATLON OBLAST IN THE REPUBLIC OF TAJIKISTAN

JICA

<b>3. Водонапорная башня / G. Distribution Tank</b>				Оборудование код: Facility Code: V-01
Координаты: Coordinates:	C N	B E	Высота: Altitude:	UTM: C (N) B (E)
Вид: Type:	(Высотный, Грунтовый, Другой) (Elevated, Ground, Other)	Другой: Other:	Мощность: Capacity:	m <sup>3</sup> m <sup>3</sup>
Материал: Material of tank:	(Бетонный, Стальной, Другой) (Concrete, Steel, Other)	Другой: Other:		
Состояние резервуара: Condition of reservoir:	1 2	Опишите проблему: Describe the problems:		
<b>И. Главный распределитель / H. Distribution Main</b>				
Диаметр трубы: Diameter of pipe:	160 мм mm	Материал трубы: Material of pipe:	Дюралюминиевое, пластмас Cast iron and layer color	Общая длина магистрали: Total length of main: 2.5 км km
Состояние трубы: Condition of pipe:	1 Повреждена (частично) 2 Необходимы срочные реабилитации 1 Deteriorated (partially) 2 Urgent rehabilitation is required	Опишите проблему: Describe the problems:	В связи агрессивных грунта земли пришлось в негодные e-900м Corroded conduit	
Вид и число задвижек: Type and number of valves:	Вантуз: 1шт-д32мм Air valve: 1p-d 32mm	Задвижка: Sluice valve: 2шт-д150мм 2p-d 150mm	Другой: Others:	
<b>Л. Общественный водопровод / I. Public Tap</b>				
Число водопроводной воды: Quantity of public taps:	32	Диаметр трубы: Diameter of pipe:	15 мм mm	Оборудование код: Facility Code: V-01
Материал трубы: Material of pipe:	Стальной Steel	Средняя длина линии обслуживания: Total length of service line:	20 км km	

ATTACHED FIGURE 4.6 FACILITY DATA SHEET 3.2

THE STUDY FOR SUSTAINABLE RURAL WATER SUPPLY SYSTEM IN THE  
SOUTHERN KHATLON OBLAST IN THE REPUBLIC OF TAJIKISTAN

JICA

<b>M. Система эксплуатации и содержания / J. Operation and Maintenance System</b>		Оборудование код: Facility Code:	V-01
Организация, несущая ответственность за эксплуатацию и содержания:	Джамоат	(Таджиксельхозводопроводстрой, Ассоциация водопользователей, Джамоат, Кишлак, Колхоз, Совхоз, Другой)	
Type of organization in charge for Operation and Maintenance:	Jamoat	(RWSA, Water User Association, Jamoat, Village, Kolkhoz, Sovkhoz, Other)	
Другой:			
Other:			
Компонент организации:	Государственное		
Component of organization:	State system		
Система оплаты воды:	Потребительские расходы по водомеру	Водный тариф:	0.0251 сомони/м3
Water tariff system:	Commodity Charge	Water tariff:	0.0251 Somoni/m3
Система сбора денег:	Контролёр	(Контролёр, Перевод, Бесплатный, Другой)	
Water tariff collection system:	Collector	(Collector, Transferring, Free of charge, Other)	
Роль организации в ремонте и замены оборудования (включая распределение расхода):	Таджиксельхозводопроводстрой:		
Ответственная организация:			
Role of organization for repairing and replacement of facilities (including expense distribution):	RWSA:		
Operator:			
<b>K. Другие / K. Others</b>		Оборудование код: Facility Code:	V-01
Приоритет для улучшения условия жизни в кишлаке/общине	Priorities for improvement of living conditions of village / community		
1-ый Приоритет:	В связи с нехваткой питьевой воды последние годы увеличила инфекционные заболевания среди население	1st priority:	The water shortage in recent years, has increased the incidence of infectious diseases
2-ой Приоритет:	В случае обеспечение питьевой воды уменьшится разные инфекционные заболевания особенно среди и детей подростков	2nd priority:	Providing drinking water, the number of diseases will decrease, specially among childrens
Какие химические удобрения используются на этой территории:	Не используется		
Names of agricultural chemicals used in the area:	Not used		

ATTACHED FIGURE 4.7 FACILITY DATA SHEET 4

THE STUDY FOR SUSTAINABLE RURAL WATER SUPPLY SYSTEM IN THE SOUTHERN KHATLON OBLAST IN THE REPUBLIC OF TAJIKISTAN

JICA

Оборудование код: V-01  
 Facility Code:

Название и количество оборудования, которые подлежат ремонту или замены.

1. Труба ст. д160мм (900 м).
2. Труба ст. Д200мм (200 м).
3. Труба ст. Д100мм (1,1 км).
4. Водомером д20мм (32 шт).
5. Задвижка д150мм (4 шт).
6. Задвижка д100мм (6 шт).

Name and quantity of facilities to be rehabilitated or replaced.

1. Steel pipe d 160mm (900m).
2. Steel pipe d 200 mm (200m).
3. Steel pipe d 100 mm (1.1km).
4. Water meter d 20 mm (32pcs).
5. Sluice valve d 150 mm (4pcs).
6. Sluice valve d 100 mm (6pcs).

**Схематическое Расположение Система Снабжения Воды / Schematic Layout of Water Supply Facility**

Оборудование код: V-01  
 Facility Code:

WSSID	Расположение код Layout Code	Схематическое Расположение	Schematic Layout
V-01	V001	Расположение 1	Layout 1

**ATTACHED FIGURE 4.8 FACILITY DATA SHEET 5**

**THE STUDY FOR SUSTAINABLE RURAL WATER SUPPLY SYSTEM IN THE  
 SOUTHERN KHATLON OBLAST IN THE REPUBLIC OF TAJIKISTAN**

JICA

**2 CHAPTER4 EXISTING CONDITION  
AND DEVELOPMENT ISSUES  
OF RURAL WATER SUPPLY SYSTEM**

**Appendix-3 Data Base of Rural Water Supply System**

**(2) Attached Tables**

Water Supply System Data Base

Serial No.	File No.	WSS ID	Date	A-1 Name of Rayon	A-2 Name of Jamoat	A-3 Name of Intervener	A-3 Coordinates (Center of Village)		A-4 Name of Water Supply System	A-5 Year of Construction	A-6 Owner of Water Supply System	A-7 Name of Operator	A-8 Water Source	A-9 Operating Condition	A-9 Remarks	A-9-1 In Working	
							Latitude N	Longitude E								Altitude (m)	Working Period
1	1	K-10	11/11/2007	Kabodiyon	Yangi Yul	Kalinin	37° 19.518	68°11.176	371	1972	Jamoat Yangi Yul	Jamoat Yangi Yul	2: Groundwater	2: Out of working			
2	2	K-08	10/11/2007	Kabodiyon	S. Khudokulov	Chkalov	37° 24.252	68°10.882	392	1974	Jamoat Chkalov	Jamoat Chkalov	2: Groundwater	1: Working		1: Throughout the year	
3	3	K-03	08/11/2007	Kabodiyon	S. Khudokulov	Kizil-Ibiloq	37° 24.652	68°10.882	390	1978	Jamoat Qizil-Ibiloq	Jamoat Qizil-Ibiloq	2: Groundwater	1: Working		1: Throughout the year	
4	4	K-09	13/11/2007	Kabodiyon	U. Nazarov	Kabla	37° 28.088	68°08.878	401	1968	U. Nazarov Jamoat	U. Nazarov Jamoat	2: Groundwater	2: Out of working			
5	5	K-12	13/11/2007	Kabodiyon	I. Niyozov	Chorbeg, Zirali	37° 28.457	68°11.341	403	1985	Jamoat Niyozov	Jamoat Niyozov	2: Groundwater	2: Out of working			
6	6	K-02	07/11/2007	Kabodiyon	S. Khudokulov	Yangi Yul	37° 13.004	68°11.791	383	1985	Jamoat S. Khudokulov	Jamoat S. Khudokulov	2: Groundwater	2: Out of working			
7	7	K-05	11/11/2007	Kabodiyon	Narobod	Naruz	37° 04.718	68°08.223	339	2001	RWSA	RWSA	2: Groundwater	2: Out of working		1: Throughout the year	

Water Supply System Data Base

Serial No.	File No.	WSS ID	Date	A-1 Name of Rayon	A-2 Name of Jamoat	A-3 Name of Village	A-3 Name of Interviewer	A-3 Coordinates (Center of Village)			A-4 Name of Water Supply System	A-5 Year of Construction	A-6 Owner of Water Supply System	A-7 Name of Operator	A-8 Water Source	A-9 Operating Condition	A-9 Remarks	A-9-1 If Working	
								Latitude N	Longitude E	Altitude (m)								Working Period	If seasonal, what is the reason?
8	K-01	13/11/2007	Kabodiyon	Nowiti Khazarav	Lepin, Jara, Azbov, Shno, Tursunzoda	Saidov R.	37° 23.947	68°08.901	360	Water Supply Jamoat Noziti Khazarav	1971	GUP "KHMK" Kabodiyon region	KOFO Kabodiyon	2: Groundwater	1: Working	partially (30%)	1: Throughout the year		
9	K-14	12/11/2007	Kabodiyon	Yangi Yul	Kuzil-Kuch	Saidov R.	37° 19.618	68°11.176	371	Water Supply Kuzil-Kuch	1970	OVP "Kafolat"	OVP "Kafolat"	2: Groundwater	2: Out of working				
10	K-06	07/11/2007	Kabodiyon	Kabodiyon	Chungly	Qurbanov S.	37° 20.300	68°01.003	385	Water Supply Chungly	1967	Jamoat Kabodiyon	Jamoat Kabodiyon	2: Groundwater	1: Working		1: Throughout the year		
11	K-04	10/11/2007	Kabodiyon	S. Khudokulov	Khatayil Nev	Ruziev R.	37° 11.344	68°11.176	349	Water Supply Haydy nav	1978	Jamoat S. Khudokulov	Jamoat S. Khudokulov	2: Groundwater	2: Out of working				
12	K-13	09/11/2007	Kabodiyon	S. Khudokulov	Kalihin	Ruziev R.	37° 11.474	68°13.003	360	Water Supply Kalihin	1976	Jamoat S. Khudokulov	Jamoat S. Khudokulov	2: Groundwater	2: Out of working				
13	K-11	09/11/2007	Kabodiyon	S. Khudokulov	Boishetik	Ruziev R.	37° 09.705	68°13.278	355	Water Supply Boishetik Jamoat S. Khudokulov	1970	Jamoat S. Khudokulov	Jamoat S. Khudokulov	2: Groundwater	2: Out of working				
14	K-07	09/11/2007	Kabodiyon	S. Khudokulov	Jarkurgan	Saidov R.	37° 12.172	68°12.706	370	Water Supply Jarkurgan	1970	Jamoat S. Khudokulov	Jamoat S. Khudokulov	2: Groundwater	2: Out of working				
15	R-37	24/09/2007	Ko'hitxonobod	S. Isaev	Mira	Ruziev R.	37° 36.027	68°39.367	378	Water Supply Mira	1974	Vodkharal	Vodkharal	1: Yakshik Conduit	1: Working	partially	1: Throughout the year		

Water Supply System Data Base

Serial No.	File No.	MS ID	Date	A-2			A-3			A-4	A-5	A-6	A-7	A-8		A-9	A-9-1		
				Name of Rayon	Name of Jamoat	Name of Village	Name of Interviewer	Latitude N	Longitude E					Altitude (m)	Name of Water Supply System		Year of Construction	Owner of Water Supply System	Name of Operator
16	2	R-06	27/09/2007	Koikhabod	S. Iseev	Central district hospital	Ruziev R.	37° 35.648	068°59.227	370	Water Supply Central district hospital	1978	Central district hospital of Jamoat S. Isaeva	Central district hospital of Jamoat S. Isaeva	1: Vakhsh Conduit	1: Working	1: Throughout the year		
17	3	R-04	24/08/2007	Koikhabod	S. Iseev	Kazaliks	Ruziev R.	37° 36.027	068°59.367	375	Water Supply Kazaliks Village	1974	GUP "KGMK"	Vodokanal GUP "KGMK"	1: Vakhsh Conduit	1: Working	1: Throughout the year	partially (50%)	
18	4	R-05	25/09/2007	Koikhabod	PGT Iseev	Lenin	Ruziev R.	37° 36.027	068°59.367	367	Water Supply Vodokanal PGT Isaeva	1974	GUP "KGMK"	GUP "KGMK"	1: Vakhsh Conduit	1: Working	1: Throughout the year	partially (50%)	
19	5	R-38	27/09/2007	Koikhabod	S. Iseev	Sovet	Ruziev R.	37° 36.027	068°59.367	378	Water Supply Sovet PGT Isaeva	1974	Vodokanal GUP "KGMK" (State Unitary Enterprise)	Vodokanal GUP "KGMK"	1: Vakhsh Conduit	1: Working	1: Throughout the year	partially	
20	6	R-32	25/09/2007	Koikhabod	PGT Iseev	Khlypzevod-Phyzvod	Ruziev R.	37° 36.027	068°59.367	372	Water Supply Khlypzevod-Phyzvod of PGT Isaeva	1973	Vodokanal GUP "KGMK"	Vodokanal GUP "KGMK"	1: Vakhsh Conduit	1: Working	1: Throughout the year	partially (50%)	
21	7	R-07	25/09/2007	Koikhabod	Kollin	40 year Okhyabr	Ruziev R.	37° 30.001	068°59.654	385	Water Supply 40 year Okhyabr	1974	Koikhoz 40 year Okhyabr	Koikhoz 40 year Okhyabr	1: Vakhsh Conduit	2: Out of working			

Water Supply System Data Base

Serial No.	File No.	WSS ID	Date	A-1		A-2		A-3			A-4		A-5	A-6	A-7	A-8		A-9	A-9-1	
				Name of Rayon	Name of Jamoat	Name of Village	Name of Interviewer	Latitude N	Longitude E	Altitude (m)	Name of Water Supply System	Year of Construction				Owner of Water Supply System	Name of Operator		Water Source	Operating Condition
22	8	R-08	28/09/2007	Kolikhazobod	Kalini	Kalini	Maliyev A.	37° 28.631	068°37.895	382	Pump station Kalini	1984	RWSA and KHREY Qumsangir	RWSA and KHREY Qumsangir	1: Vakhsh Conduit	3: Irrigation canal	1: Working	partially (30%)	1: Throughout the year	
23	9	R-09	15/10/2007	Kolikhazobod	Kalini	Lzbekobod	Ruziev R.	37° 28.636	068°38.182	383	Water Supply Lzbekobod	1984	Qumsangir KHREY	Qumsangir KHREY	1: Vakhsh Conduit		2: Out of working			
24	10	R-27	27/09/2007	Kolikhazobod	Madaniyat	Esaingulov	Ruziev R.	37° 38.323	068°37.381	385	Water Supply Kolhoz Esaingulov	1985	Esaingulov Kolhoz	Esaingulov Kolhoz	1: Vakhsh Conduit		1: Working		1: Throughout the year	
25	11	R-10	23/09/2007	Kolikhazobod	Madaniyat	Kizi Baurak	Ruziev R.	37° 38.323	068°37.381	372	Water Supply Kizi-Baurak Kolhoz T. Esaingulov	1985	Kolhoz T. Esaingulov	Kolhoz T. Esaingulov	1: Vakhsh Conduit		1: Working		1: Throughout the year	
26	12	R-11	26/09/2007	Kolikhazobod	Madaniyat	JD Station	Ruziev R.	37° 38.323	068°36.848	387	Water Supply Kolhoz T. Esaingulov	1976	Kolhoz T. Esaingulov	Kolhoz T. Esaingulov	1: Vakhsh Conduit		1: Working	partially	1: Throughout the year	
27	13	R-13	23/09/2007	Kolikhazobod	Navobod	Kizi Namuna	Ruziev R.	37° 39.502	068°36.848	389	Water Supply Kizi Namuna Gram N. Begova	1992	Jamoat Navobod	Jamoat Navobod	1: Vakhsh Conduit		2: Out of working			
28	14	R-14	27/09/2007	Kolikhazobod	Navobod	Andreva	Safarov S.	37° 38.502	068°36.848	369	Water Supply Andrew Kolhoz N. Begova	1994	Jamoat Navobod	Jamoat Navobod	1: Vakhsh Conduit		2: Out of working			

Water Supply System Data Base

Serial No.	File No.	WSS ID	Date	A-1		A-2		A-3			A-4	A-5	A-6	A-7	A-8		A-9	A-9-1	
				Name of Rayon	Name of Jamest	Name of Village	Name of Interviewer	Latitude N	Longitude E	Altitude (m)					Name of Water Supply System	Year of Construction		Owner of Water Supply System	Name of Operator
29	15	R-28	23/09/2007	Kolkhozobod	Nerobod	Chapeev	Ruziev R.	37° 39.508	068°38.648	370	Water Supply Chapeev	1980	Jamest Nerobod	Jamest Nerobod	1: Vakhsh Conduit	1: Working			
30	16	R-12	26/09/2007	Kolkhozobod	Nerobod	Urtaabuz	Ruziev R.	37° 39.502	068°38.648	372	Water Supply Urtaabuz	1987	Kokhoz S. Jamaev	Kokhoz S. Jamaev	1: Vakhsh Conduit	1: Working	partially	1: Throughout the year	
31	17	R-29	20/09/2007	Kolkhozobod	Tugalan	Communist	Ruziev R.	37° 36.914	068°38.324	369	Water Supply Communist, Jamest Tugalan	1987	Jamest Tugalan	Jamest Tugalan	1: Vakhsh Conduit	1: Working	by gravity	1: Throughout the year	
32	18	R-15	01/10/2007	Kolkhozobod	Tugalan	Engels	Ruziev R.	37° 33.369	068°38.777	387	Water Supply Engels of Jamest Tugalan	1987	Jamest Tugalan	Jamest Tugalan	1: Vakhsh Conduit	2: Out of working			
33	19	R-30	28/09/2007	Kolkhozobod	Tugalan	Galaba	Ruziev R.	37° 35.646	068°38.277	370	Water Supply Galaba, Jamest Tugalan	1987	Jamest Tugalan	Jamest Tugalan	1: Vakhsh Conduit	2: Out of working			
34	20	R-33	27/09/2007	Kolkhozobod	Tugalan	Isoev	Ruziev R.	37° 37.806	068°38.729	371	Water Supply Isoev	1987	Vodkhanai	Vodkhanai	1: Vakhsh Conduit	1: Working	partially (50%)	1: Throughout the year	
35	21	R-01	28/09/2007	Kolkhozobod	Tugalan	Jomi	Ruziev R.	37° 36.314	068°38.394	394	Water Supply Jomi, Jamest Tugalan	1987	Jamest Tugalan	Jamest Tugalan	1: Vakhsh Conduit	2: Out of working			
36	22	R-16	01/10/2007	Kolkhozobod	Tugalan	Khopkorob	Ruziev R.	37° 36.914	068°38.342	369	Water Supply Khopkorob	1978	Jamest Tugalan	Jamest Tugalan	1: Vakhsh Conduit	1: Working	partially (50%)	1: Throughout the year	

Water Supply System Data Base

Serial No.	File No.	WBS ID	Date	A-1		A-2		A-3				A-4		A-5		A-6		A-7		A-8		A-9		A-9.1			
				Name of Rayon	Name of Jamoat	Name of Village	Name of Intervener	Latitude N	Longitude E	Altitude (m)	Name of Water Supply System	Year of Construction	Owner of Water Supply System	Name of Operator	Water Source	Operating Condition	Remarks	Working Period	If Seasonal (period and months)	If seasonal, what is the reason?							
37	R-17	28/09/2007	Koikhozobod	Tugalan	Kirov	Ruziev R.	37° 36.910	068°37.241	374	Water Supply Kirov from the bore hole 5 to Main pipe line	1978	MM and VR TR	KUMCO	2: Groundwater	1: Working												
38	R-18	28/09/2007	Koikhozobod	Tugalan	Lenin	Ruziev R.	37° 36.914	068°38.343	368	Water Supply Lenin, Jamoat Tugalan	1978	Jamoat Tugalan	Jamoat Tugalan	1: Vakhsh Conduit	1: Working										1: Throughout the year		
39	R-19	28/09/2007	Koikhozobod	Tugalan	Leningrad	Ruziev R.	37° 33.927	068°39.276	375	Water Supply Leningrad Jamoat Tugalan	1987	Jamoat Tugalan	Jamoat Tugalan	1: Vakhsh Conduit 3: Irrigation canal	2: Out of working												
40	R-20	22/09/2007	Koikhozobod	Tugalan	Pyatletka	Ruziev R.	37° 36.295	068°38.669	370	Water Supply Pyatletka of Jamoat Tugalan	1987	Jamoat Tugalan	Jamoat Tugalan	3: Irrigation canal	2: Out of working												
41	R-34	01/10/2007	Koikhozobod	Tugalan	Shaakhtyor	Ruziev R.	37° 33.365	068°38.715	375	Water Supply Shaakhtyor of Jamoat Tugalan	1987	Jamoat Tugalan	Jamoat Tugalan	1: Vakhsh Conduit 3: Irrigation canal	2: Out of working												
42	R-21	28/09/2007	Koikhozobod	Tugalan	Yosh-Lentichl	Ruziev R.	37° 36.295	068°38.690	365	Water Supply Yosh-Lentichl (From bore hole 4 to main pipe-line)	1978	KOREY	KOREY	2: Groundwater	1: Working											1: Throughout the year	

Water Supply System Data Base

Serial No.	File No.	WSS ID	Date	A-1		A-2		A-3			A-4	A-5	A-6	A-7	A-8		A-9		
				Name of Region	Name of Jamoat	Name of Village	Name of Interviewer	Latitude N	Longitude E	Altitude (m)					Name of Water Supply System	Year of Construction	Owner of Water Supply System	Name of Operator	Water Source
43	R-02	01/10/2007	Koikhozobod	Uzun	Ittiqoq-1	Ruziev R.	37° 39.502	068°26.848	369	Water Supply Ittiqoq-1	1974	Koikhoz S. Jumaev	Koikhoz S. Jumaev	Koikhoz S. Jumaev	1: Vekshah Conduit	1: Working		1: Throughout the year	
44	R-23	01/10/2007	Koikhozobod	Uzun	Ittiqoq-2	Ruziev R.	37° 39.502	068°26.848	363	Water Supply Ittiqoq Koikhoz Jumaev	2001	Koikhoz S. Jumaev	Koikhoz S. Jumaev	1: Vekshah Conduit	2: Cd of working				
45	R-22	02/10/2007	Koikhozobod	Uzun	Ittiqoq-3	Salarov S.	37° 39.502	068°26.848	360	Water Intake Installation Uzun 1	1962	RWSA	RWSA		1: Working	partially (50%)	1: Throughout the year		
46	R-24	02/10/2007	Koikhozobod	Uzun	K. Mar'ks	Ruziev R.	37° 38.450	068°35.400	368	Water Supply K. Mar'ks	1987	Jamoat Uzun	Jamoat Uzun		1: Working	partially	1: Throughout the year		
47	R-39	02/10/2007	Koikhozobod	Uzun	Mehnatobod	Salarov S.	37° 39.503	068°26.848	387	Water Supply Mehnatobod Jamoat Uzun from Koikhoz S. Jumaev	1988	Koikhoz S. Jumaev	Koikhoz S. Jumaev	1: Vekshah Conduit	1: Working	partially	1: Throughout the year		
48	R-03	24/09/2007	Koikhozobod	Uzun	Pakhtasari	Ruziev R.	37° 39.502	068°26.848	387	Water Supply Pakhtasari	1978	Koikhoz S. Jumaev	Koikhoz S. Jumaev	1: Vekshah Conduit	1: Working	partially	1: Throughout the year		

Water Supply System Data Base

Serial No.	File No.	WSSM ID	Date	A-1		A-2		A-3			A-4	A-5	A-6	A-7	A-8		A-9		A-10	
				Name of Rayon	Name of Jamoat	Name of Village	Name of Interviewer	Latitude N	Longitude E	Altitude (m)					Name of Water Supply System	Year of Construction	Owner of Water Supply System	Name of Operator	Water Source	Operating Condition
49	R-36	02/10/2007	Ko'khazobod	Uzun	Pakhaabod	Ruziev R.	37° 39.502	068°28.648	367	Water Supply Pakhaabod Jamoat Uzun	1988	Jamoat Uzun ko'khaz Jumaev	Jamoat Uzun ko'khaz Jumaev	1: Vakhsh Conduit	1: Working	partially	1: Throughout the year			
50	R-25	03/10/2007	Ko'khazobod	Uzun	Pranda	Ruziev R.	37° 38.502	068°28.648	669	Water Supply Pranda Ko'khaz S. Jumaev	1978	Ko'khaz S. Jumaev	Ko'khaz S. Jumaev	1: Vakhsh Conduit	1: Working	partially	1: Throughout the year			
51	R-35	03/10/2007	Ko'khazobod	Uzun	Sanoat	Ruziev R.	37° 38.502	068°28.648	697	Water Supply Sanoat	1988	Ko'khaz S. Jumaev	Ko'khaz S. Jumaev	1: Vakhsh Conduit	1: Working	partially	1: Throughout the year			
52	R-31	03/10/2007	Ko'khazobod	Uzun	Uzun	Safarov S.	37° 38.502	068°28.648	365	Water Supply constructions Uzun 2	1974	RSWA	RSWA	1: Vakhsh Conduit	1: Working	partially (50%)	1: Throughout the year			

Water Supply System Data Base

Serial No.	File No.	WSS ID	Date	A.1 Name of Rayon	A.2 Name of Jameat	A.3 Name of Village	A.3 Name of Interviewer	A.3 Coordinates (Center of Village)			A.4 Name of Water Supply System	A.5 Year of Construction	A.6 Owner of Water Supply System	A.7 Name of Operator	A.8 Water Source	A.9 Operating Condition	Remarks	A.9-1 If Working	
								Latitude N	Longitude E	Altitude (m)								Working Period	If Seasonal (period and months)
53	39	R-26	20/09/2007	Kolkhozobod	Kalinin	Zonalnaya, Kalerina	Ruziev R.	37° 30.001	069°30.634	385	Water Supply the construction village Kalanina	1988	Kolkhoz 40 year Otkyabr	Kolkhoz 40 year Otkyabr	1: Vakhsh Conduit	2: Out of working			
54	1	J-02	11/10/2007	Dzhilikul	Dzhilikul	Badakhsion	Ruziev R.	37° 30.686	069°32.235	365	Vodkanal	1986	Vodkanal	Vodkanal	1: Vakhsh Conduit	2: Out of working			
55	2	J-01	07/10/2007	Dzhilikul	Dehkonobod	Agroonomy	Ruziev R.	37° 31.506	069°32.690	355	Water Supply Agroonomy village of Jameat Dehkanabad	1990	Kolkhoz Fayzaly Said	Kolkhoz Fayzaly Said	1: Vakhsh Conduit	1: Working	partially (50%)	1: Throughout the year	
56	3	J-03	09/10/2007	Dzhilikul	Dehkonobod	Kirov	Ruziev R.	37° 34.651	069°34.608	362	Water Supply Kirov village of Jameat Dehkanabad	1990	Moskva Sovkhoz, Dehkanabad Jameat	Moskva Sovkhoz, Dehkanabad Jameat	1: Vakhsh Conduit	1: Working	partially (50%)	1: Throughout the year	
57	4	J-04	09/10/2007	Dzhilikul	Dehkonobod	Moskva	Ruziev R.	37° 34.651	069°34.600	363	Water Supply of Moskva village of Dehkanabad Jameat	1991	Moskva Sovkhoz of Dehkanabad Jameat	Moskva Sovkhoz of Dehkanabad Jameat	1: Vakhsh Conduit	1: Working	partially (50%)	1: Throughout the year	
58	5	J-05	09/10/2007	Dzhilikul	Dehkonobod	Kuybeshov	Ruziev R.	37° 30.089	069°32.130	350	Water Supply of Kuybeshov village, Jameat Dehkanabad	1990	Fayzaly Said kolkhoz	Fayzaly Said kolkhoz	1: Vakhsh Conduit	1: Working	partially (50%)	1: Throughout the year	

Water Supply System Data Base

Serial No.	File No.	WSS ID	Date	A-1			A-2			A-3			A-4	A-5	A-6	A-7	A-8	A-9	A-10	
				Name of Rayon	Name of Jamoat	Name of Village	Name of Interviewer	Latitude N	Longitude E	Altitude (m)	Name of Water Supply System	Year of Construction							Owner of Water Supply System	Name of Operator
59	J-06	06/10/2007	Dzhiblikul	Dekkonobod	Ruboz Sufi	Abdulhasov Kh.	37° 31.560	068°32.690	355	Water Supply of Sufi Ribhoz village	1976	Community of Dekkonobod Jamoat	Community of Dekkonobod Jamoat	1: Vaikshah Conduit	1: Working	partially (50%)	1: Throughout the year			
60	J-07	10/10/2007	Dzhiblikul	Dekkonobod	Mirovoy	Ruziev R.	37° 30.086	068°32.248	355	Water Supply of Mirovoy village	1983	Fayzaly Said kolkhoz	Fayzaly Said kolkhoz	1: Vaikshah Conduit	2: Out of working					
61	J-09	12/10/2007	Dzhiblikul	Dzhiblikul	Dzhiblikul	Kilichev M.	37° 30.089	068°32.130	345	Vodokanal	1988	Vodokanal	Vodokanal	1: Vaikshah Conduit	1: Working	partially (50%)	1: Throughout the year			
62	J-10	12/10/2007	Dzhiblikul	Dzhiblikul	Galaba village of Kolkhoz Sultorov	Ruziev R.	37° 33.220	068°31.400	348	Water Supply of Galaba village of Jamoat Dzhiblikul	1984	Vodokanal	Vodokanal	1: Vaikshah Conduit	2: Out of working					
63	J-08	12/10/2007	Dzhiblikul	Kabodiyon	Kabodiyon	Ruziev R.	37° 33.220	068°31.400	348	Water Supply village Kabodiyon	1989	Jamoat Kabodiyon Dzhiblikul district	Jamoat Kabodiyon Dzhiblikul district	1: Vaikshah Conduit	2: Out of working					
64	J-11	11/10/2007	Dzhiblikul	Dzhiblikul	Lentibod	Ruziev R.	37° 31.560	068°32.690	355	Water Supply Leninobod	1998	Vodokanal	Vodokanal	1: Vaikshah Conduit	2: Out of working					
65	J-12	06/10/2007	Dzhiblikul	Nuri Vaikshah	Eshbek Sattorov	Ruziev R.	37° 32.006	068°28.455	360	Water Supply Kolkhoz Eshbek Sattorov	1997	Kolkhoz Eshbek Sattorov	Kolkhoz Eshbek Sattorov	1: Vaikshah Conduit	2: Out of working					

Water Supply System Data Base

Settle No.	File No.	WSS ID	Date	A-1 Name of Rayon	A-2 Name of Jameat	A-2 Name of Village	A-3 Name of Interviewer	A-3 Coordinates (Center of Village)		A-4 Name of Water Supply System	A-5 Year of Construction	A-5 Owner of Water Supply System	A-7 Name of Operator	A-3 Water Source	A-9 Operating Condition	A-9 Remarks	A-B-1 If Working	
								Latitude N	Longitude E								Altitude (m)	Working Period
66	13	J-13	06/10/2007	Dzhilkul	Nuri Valohsh	42 Moskva 42 E. Saitorov	Ruziev R.	37° 32.000	68°28.455 360	Water Supply of 42 Moskva of 42 E. Saitorov	1987	RWISA	RWISA	1. Vakhsh Conduit	1: Working	partially (50%)	1: Throughout the year	
67	14	J-14	20/02/2008	Dzhilkul	Dzhilkul	Komitem	Rahmatov I.	37° 28.824	68°23.024 350	Public water to users village Komitem	1988	Public water to users village Komitem	Public water to users village Komitem	1. Vakhsh Conduit 2. Groundwater	1: Working 2: Out of working			
68	2	N-03	16/11/2007	Nosir-Khatay	Firuz	Navuz of Sovhoz No.5	Qurbonov S.	37° 17.302	68°02.660 397	Water Supply Navuz and Jamoat Mubammadiev	1974	RWISA	RWISA	2. Groundwater	1: Working		1: Throughout the year	
69	2	N-01	16/11/2007	Nosir-Khatay	Isildoi	44-Chashma "Oltinoy"	Qurbonov S.	37° 17.295	68°02.660 395	Water Supply Nosir-Khatay	1972	RWISA	RWISA	2. Groundwater	1: Working	partially (50%)	1: Throughout the year	
70	3	N-02	16/11/2007	Nosir-Khatay	Komsomol	Alla Ferma	Qurbonov S.	37° 18.370	68°03.705 375	Water Supply Alla Ferma	1985	RWISA	RWISA	2. Groundwater	2: Out of working			

Water Supply System Data Base

Serial No.	File No.	WSS ID	Date	A-1		A-2		A-3			A-4	A-5	A-5	A-5	A-7	A-3	A-9	A-9-1	
				Name of Rayan	Name of Jamoat	Name of Village	Name of Interviewer	Latitude N	Longitude E	Altitude (m)								Name of Water Supply System	Year of Construction
71	1	P-15	30/10/2007	Pyandzh	Arab	Burka	Ruziev R	37° 13.680	069°08.001	363	Water Supply Burka	1965	Jamoat Arab	Jamoat Arab	2: Groundwater	2: Out of working			
72	2	P-05	28/10/2007	Pyandzh	Arab	Komsomol	Ruziev R	37° 12.321	069°07.818	361	Water Supply Komsomol Koldoz Pleva	1972	Jamoat Arab	Jamoat Arab	2: Groundwater	2: Out of working			
73	3	P-02	30/10/2007	Pyandzh	Arab	Ojoniqize	Ruziev R	37° 12.673	069°10.775	372	Water Supply Ojoniqize	1965	Jamoat Arab	Jamoat Arab	2: Groundwater	2: Out of working			
74	4	P-06	01/11/2007	Pyandzh	Kuldimen	Pahtakor	Abbasaitinov A	37° 17.320	069°03.723	344	Water Supply Pahtakor	1965	Jamoat Kuldeman	Jamoat Kuldeman	2: Groundwater	2: Out of working			
75	5	P-06	02/11/2007	Pyandzh	Namuna	Uchasok-A, Zaubdor, Kuduly	Ruziev R	37° 18.756	069°03.332	338	Emomali Rahmonov	1973	E. Rahmonov of Jamoat Namuna		2: Groundwater	2: Out of working			
76	6	P-03	02/11/2007	Pyandzh	Namuna	Peshqadam 1 and 2	Ruziev R	37° 18.913	069°02.312	345	Water Supply Jamoat Namuna	1965	Jamoat Namuna	Jamoat Namuna	2: Groundwater	1: Working	1: Throughout the year		

Water Supply System Data Base

Serial No.	File No.	WSS ID	Date	A-1		A-2		A-3			A-4	A-5	A-6	A-7	A-8		A-9	A-9-1	
				Name of Rayon	Name of Jamoat	Name of Village	Name of Interviewer	Latitude N	Longitude E	Altitude (m)					Name of Water Supply System	Year of Construction		Owner of Water Supply System	Name of Operator
77	7	P-04	01/11/2007	Pyandzh	city Pyandzh	Pyandzh	Ruziev R.	37°13.557	069°08.265	357	Water Supply PCT Pyandzh	1958	Water-supply Pyanjikogo region	Water-supply Pyanjikogo region	1: Throughout the year				
78	8	P-07	03/11/2007	Pyandzh	Tugul	Territory School No.5	Ruziev R.	37°10.720	069°10.732	371	Water Supply Jamoat Tugul and School No.5	1965	Jamoat Tugul	Jamoat Tugul	1: Working				
79	9	P-08	05/11/2007	Pyandzh	Samarzoiy	Dzeifjinsky-1	Ruziev R.	37°18.009	069°08.194	354	Water Supply population Dzeifjinsky-1	1993	RWSA	RWSA	1: Working	partially (30%)			
80	10	P-10	05/11/2007	Pyandzh	Samarzoiy	Dzeifjinsky-2	Ruziev R.	37°16.009	069°08.194	354	Water Supply population Dzeifjinsky-2	1993	RWSA	RWSA	1: Working	partially (50%)			
81	11	P-13	03/11/2007	Pyandzh	Samarzoiy	Samarzoiy	Abdullhaev A.	37°16.013	069°07.140	347	Water Supply Samarzoiy	1973	Jamoat Samarzoiy	Jamoat Samarzoiy	2: Out of working				

Water Supply System Data Base

Serial No.	File No.	WSS ID	Date	A-1		A-2		A-3			A-4	A-5	A-6	A-7	A-8	A-9	A-10		
				Name of Rayon	Name of Jamoat	Name of Village	Name of Interviewer	Latitude N	Longitude E	Altitude (m)							Year of Construction	Owner of Water Supply System	Name of Operator
82	12	P-18	06/11/2007	Pyandzh	Sarmanloy	Kubashev	Ruziev R.	37° 13.230	069°07.123	344	Water Supply Kubashev	1965	Jamoat Sarmanloy	Jamoat Sarmanloy	2. Groundwater	2. Out of working			
83	13	P-11	06/11/2007	Pyandzh	Tugul	Gulliston	Ruziev R.	37° 11.246	069°11.604	366	Water Supply Gulliston	1965	Jamoat Tugul	Jamoat Tugul	2. Groundwater	2. Out of working			
84	14	P-01	26/10/2007	Pyandzh	Tugul	Area Tugul	Ruziev R.	37° 10.699	069°10.284	373	Water Supply Jamoat Tugul area Gubbod	1965	Jamoat Tugul	Jamoat Tugul	2. Groundwater	2. Out of working			
85	15	P-14	06/11/2007	Pyandzh	Tugul	M. Gorfy	Ruziev R.	37° 09.603	069°11.433	379	Water Supply M. Gorfy	1964	Jamoat Tugul	Jamoat Tugul	2. Groundwater	2. Out of working			
86	16	P-12	06/11/2007	Pyandzh	Tugul	Shakandast	Ruziev R.	37° 10.411	069°11.599	383	Water Supply Shakandast	1965	Jamoat Tugul	Jamoat Tugul	2. Groundwater	2. Out of working			
87	1	Q-01	11/10/2007	Kumsangir	Dusti	1-Aves	Hasanov T.	37° 21.435	069°48.577	382	Vodokanal Dusti	1973	GLP HMK Vodokanal Dusti	Vodokanal Dusti	1. Yalbish Conduit 3. Irrigation canal	1. Working	partially (40%)	1: Throughout the year	
88	2	Q-02	09/10/2007	Kumsangir	Kupaky	50 let		37° 27.204	069°28.422	390	Water Supply 50 let	1985	Kumsangir «RWWS»	Kumsangir «RWWS»	1. Yalbish Conduit	2. Out of working			

Water Supply System Data Base

Serial No.	File No.	WSS ID	Date	A-1		A-2		A-3			A-4	A-5	A-5	A-7	A-5		A-9	A-9-1	
				Name of Rayon	Name of Jamoat	Name of Village	Name of Interviewer	Latitude N	Longitude E	Altitude (m)					Name of Water Supply System	Year of Construction		Owner of Water Supply System	Name of Operator
89	3	Q-06	18/10/2007	Kumsangir	Krupsky	Udamik	Malaev A.	37° 28.538	068°38.162	383	Water Supply Udamik	1987	Kumsangir «RWWS»	Kumsangir «RWWS»	1: Vakhsh Conduit	2: Out of working			
90	4	Q-03	08/10/2007	Kumsangir	Krupsky	Kazi-Nishon	Malaev A.	37° 21.278	068°41.448	384	Water Supply Kazi-Nishon	1986	Kumsangir «RWWS»	Kumsangir «RWWS»	1: Vakhsh Conduit	2: Out of working			
91	5	Q-07	10/10/2007	Kumsangir	Krupsky	Matsaniyat	Malaev A.	37° 27.204	068°38.422	390	Water Supply System Matsaniyat	1985	Kumsangir «RWWS»	Kumsangir «RWWS»	1: Vakhsh Conduit	2: Out of working			
92	6	Q-08	10/10/2007	Kumsangir	[Pyen]	8 village, 5 village	Ruziev R.	37° 17.995	068°44.280	370	Water Supply 5 village	1972	Kumsangir Vodbekanal	Kumsangir Vodbekanal	3: Irrigation canal	2: Out of working			
93	7	Q-04	11/10/2007	Kumsangir	[Pyen]	Koikhoz Lenin	Ruziev R.	37° 20.831	068°42.208	380	Water Supply Koikhoz Lenin Kumsangir Ryan	1987	Koikhoz Lenin	Koikhoz Lenin	1: Vakhsh Conduit	2: Out of working			

Water Supply System Data Base

Serial No.	File No.	WSS ID	Date	A-1			A-2				A-3			A-4	A-5	A-5	A-7	A-3	A-9	A-6-1								
				Name of Rayon	Name of Jameat	Name of Village	Name of Interviewer	Latitude N	Longitude E	Altitude (m)	Name of Water Supply System	Year of Construction	Owner of Water Supply System							Name of Operator	Water Source	Operating Condition	Remarks	Working Period	If Seasonal (period and months)	If seasonal, what is the reason?		
94	6	Q-05	10/10/2007	Kumsangir	Telisan	7th Village	Ruziev R.	37° 24.838	068°08.820	378	Water Supply 7th village of Jameat Telisan	1988	Kumsangir «RWWS»	Kumsangir «RWWS»														
95	1	S-03	13/11/2007	Shakhratus	Jura Nazarov	Ahoj	Ruziev R.	38° 58.834	068°01.855	313	Water Supply Ahoj	1977	Jameat Jura Nazarov	Jameat Jura Nazarov								1: Throughout the year						
96	2	S-07	14/11/2007	Shakhratus	Obshoron and Khobmatov	Stratoley	Qurbonov S.	37° 15.914	068°08.945	359	Water Supply Stratoley	1961	UVK Shakhratus	UVK Shakhratus								1: Working	partially (30%)	1: Throughout the year				
97	3	S-02	16/11/2007	Shakhratus	Obshoron	Rudaki	Qurbonov S.	37° 15.100	068°08.105	353	Water Supply Rudaki	1988	Jameat Obshoron	Jameat Obshoron														
98	4	S-04	16/11/2007	Shakhratus	Obshoron	Valan	Valiev M.	37° 14.100	068°08.120	354	Water Supply Kolkhoz Valan	1983	Jameat Obshoron	Jameat Obshoron														
99	5	S-09	13/11/2007	Shakhratus	Obshoron	Binkor	Qurbonov S.	37° 19.280	068°08.945	383	Water Supply Binkor	1988	Jameat Obshoron	Jameat Obshoron														
100	8	S-05	15/11/2007	Shakhratus	Pakhtabod	Sultanalob	Qurbonov S.	37° 23.235	068°08.235	349	Water Supply Sultanalob	1974	Jameat Pakhtabod	Jameat Pakhtabod														
101	7	S-08	15/11/2007	Shakhratus	Sayod	Kdzi Askar	Qurbonov S.	37° 12.823	068°08.409	339	Water Supply Kdzi Askar	1985	Jameat Sayod	Jameat Sayod														

Water Supply System Data Base

Serial No	File No	WSS ID	Date	A-1 Name of Rayon	A-2 Name of Jamoat	A-3 Name of Village	A-3 Name of Interviewer	A-3 Coordinates (Center of Village)		A-4 Name of Water Supply System	A-5 Year of Construction	A-5 Owner of Water Supply System	A-7 Name of Operator	A-8 Water Source	A-9 Operating Condition	A-9-1 If Working	
								Latitude N	Longitude E							Altitude (m)	Working Period
102	8	S-10	17/11/2007	Shakhritus	Sayod	Sayod	Shodimurod	37° 12.596	68°08.264 339	Water Supply Sayod	1985	Jamoat Sayod	Jamoat Sayod	2: Groundwater	1: Working	1: Throughout the year	
103	8	S-01	13/11/2007	Shakhritus	Shakhritus	Kari Marks	Ruziev R	37° 15.882	68°08.307 356	Water Supply Kari Marks	1974	Jamoat Shakhritus	Jamoat Shakhritus	2: Groundwater	1: Working	1: Throughout the year	
104	10	S-06	15/11/2007	Shakhritus	Shakhritus	PGT Shakhritus	Qurbonov S.	37° 15.882	68°08.307 356	Water Supply Shakhritus	1960	UVK	GUP "KIMIK"	2: Groundwater	1: Working	1: Throughout the year	partially (50%)
105	1	V-01	22/10/2007	Vakhsh	Ok Goza	Peshladam, Buston	Ruziev R	37° 40.009	68°49.756 416	Vakhshose between economic planning Jamoat OK Goza	1988	Jamoat Ok Goza	Jamoat Ok Goza	3: Irrigation canal	2: Out of working		
106	2	V-05	28/10/2007	Vakhsh	Kirov	Ok-Goza, Yangi-Ah, Kazi-Soy, Yangi-Hayot, Yangi-Yor, Shikshona	Qurbonov S.	37° 48.317	68°52.894 434	Water Supply Sovkhoz Turdiev the 3rd Branches	1981	Jamoat Kirov and RWSA	Jamoat Kirov and RWSA	3: Irrigation canal	1: Working	1: Throughout the year	
107	3	V-02	22/10/2007	Vakhsh	Kirov	Haslabod, Navabod, Botrobod	Qurbonov S.	37° 48.317	68°52.894 434	Water Supply Jamoat Kirov	1987	Jamoat Kirov	Sovkhoz S. Turdiev	3: Irrigation canal	2: Out of working		
108	4	V-03	23/10/2007	Vakhsh	Kirov	Kirov-1, B.Mart, Shurappa	Qurbonov S.	37° 48.317	68°52.894 434	Water Supply Jamoat Kirov 1-branch	1987	Jamoat Kirov	Sovkhoz S. Turdiev	3: Irrigation canal	2: Out of working		
109	5	V-04	25/10/2007	Vakhsh	Kirov	Lenin, Ruzobod, Mandoboy	Qurbonov S.	37° 48.655	68°50.116 411	Water Supply Jamoat Kirov vilajasi Lenin, Ruzobod and Mandoboy	1991	RWSA	RWSA	3: Irrigation canal	2: Out of working		
110	6	V-06	23/10/2007	Vakhsh	Ok Goza	Angurbog, 50 years, Komsonel	Qurbonov S.	37° 40.099	68°49.765 416	Water Supply Jamoat Ok Goza	1986	Jamoat Ogoza	Jamoat Ogoza	3: Irrigation canal	2: Out of working		
111	7	V-07	24/10/2007	Vakhsh	Ok Goza	Sovetobod, International, Chiklov, Palhtakor	Qurbonov S.	37° 40.099	68°49.765 416	Water Supply Jamoat Ok Goza	1986	RWSA	RWSA	3: Irrigation canal	2: Out of working		
112	8	V-08	25/10/2007	Vakhsh	Rohi Lenin	Dusti, Rudebi, Chapsev	Qurbonov S.	37° 45.553	68°52.144 447	Water Supply Jamoat Rohi Lenin	1986	RWSA	RWSA	3: Irrigation canal	2: Out of working		
113	9	V-09	27/10/2007	Vakhsh	Vakhsh	PGT Vakhsh	Qurbonov S.	37° 42.855	68°51.132 436	Water Supply PGT Vakhsh	1978	RWSA	RWSA	1: Vakhsh Conduit	2: Out of working		

Water Supply System Data Base

Serial No	File No	WSS ID	Date	A-1		A-2		A-3			A-4		A-5		A-6		A-7		A-8		A-9		A-10		
				Name of Rayon	Name of Jamoat	Name of Village	Name of Infiltrator	Latitude N	Longitude E	Altitude (m)	Name of Water Supply System	Year of Construction	Owner of Water Supply System	Name of Operator	Water Source	Operating Condition	Remarks	Working Period	If Seasonal (period and months)	If seasonal, what is the reason?					
114	10	V-10	28/10/2007	Vakhsh	Yangiobod	Soroboz Vakhsh	Gurbonov S.	37° 41.154	068°52.152	412	Water Supply Soroboz Vakhsh	1988	RWSA	RWSA											
115	11	V-12	16/02/2008	Vakhsh	Tojikobod	MCSS (Military base of Ministry on exceeding amount)	Abdurahimov A.	37° 48.185	068°43.032	394	Water Supply Military base of Ministry on exceeding amount	2000	Ministry on exceeding event	Ministry on exceeding event											
116	12	V-14	14/02/2008	Vakhsh	Tojikobod	Navobod	Zorov J.	37° 44.960	068°43.505	390	Water Supply Navobod	1980	Jamoat Tojikobod	Jamoat Tojikobod											
117	13	V-13	13/02/2008	Vakhsh	Tojikobod	Pakhtakor	Abdurahimov A.	37° 48.501	068°47.613	421	Water Supply Pakhtakor	1987	Jamoat Tojikobod	Jamoat Tojikobod											
118	14	V-11	12/02/2008	Vakhsh	Tojikobod	Zarkhez	Zorov J.	37° 48.659	068°46.644	410	Water Supply Zarkhez	1987	Jamoat Tojikobod	Jamoat Tojikobod											
119	15	V-15	15/02/2008	Vakhsh	Tojikobod	Soltmon	Abdurahimov A.	37° 48.183	068°45.552	413	Water Supply of S. Jumayev	1980	Jamoat Tojikobod	Jamoat Tojikobod											

Water Supply System Data Base

Serial No.	File No.	WSS ID	Average Water Supply		Service Hours		Total Population Served		(1)		(2)		(3)		(4)		(5)		(6)		(7)		(8)			
			Average water supply (m <sup>3</sup> /day)	Maximum daily water supply (m <sup>3</sup> /day)	Maximum hourly water supply (m <sup>3</sup> /hour)	Time	hours/day	hours/day	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population
			(name of village or Sokhkor Kohoz, and population served)																							
1	1	K-10	400	600	40	6:00 - 11:00 17:00 - 22:00	10	20738	2274	Teiman	2490	Frunze	2330	Paikhtakor	2470	Lenin	1400	Beshkemir	3755	Sangoba	2500	Obunoboev	1070			
2	2	K-08	400	600	40	6:00 - 11:00 17:00 - 22:00	10	2844	2844	Chakor																
3	3	K-03	400	600	25	6:00 - 11:00 17:00 - 22:00	10	3229	3229	Kozil-Isfiroq																
4	4	K-09						17564	6180	Kabile	Bonhata	6674	Chapary 1	3200	Chapary 2	1310										
5	5	K-12						11202	4413	Zinak	Chorbog	6789														
6	6	K-02						3618	3618	Yangi-Yul																
7	7	K-05	100	200	10	6:00 - 11:00 17:00 - 22:00	10	620	620	Naruz																







Water Supply System Data Base

Serial No.	Fl No.	WS No.	A. Water Supply System										A.3-1.2						A.3-1.1								
			Average Water Supply			Service Hours			Total Population Served			(1)		(2)		(3)		(4)		(5)		(6)		(7)		(8)	
			Average water supply (m <sup>3</sup> /day)	Maximum daily water supply (m <sup>3</sup> /day)	Maximum hourly water supply (m <sup>3</sup> /hour)	Time	hours/day	hours/day	Total Population Served	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population
28	15	R-28	240	300	12.5	all day long	24	5510	Chapaev	2153	Communism	1705	Komsomol	1837													
30	16	R-12	40	100	8	10:00-22:00	12	1300	Urtabuz	1300																	
31	17	R-29	50	80	6.6	10:00-22:00	12	4862	Communist	1520	Madim Gorky	3342															
32	18	R-15						2500	Engels	2500																	
33	19	R-30						1100	Galaba	1100																	
34	20	R-33	150	300	25	10:00-22:00	12	1100	Iseev	1100																	
35	21	R-01						2487	Jemli	2487																	
36	22	R-15	50	100	4.18	10:00-22:00	12	590	Khopkorob	590																	

Water Supply System Data Base

Serial No.	File No.	WSS ID	A.9-1.1			A.9-1.2		A.9-1.3 (Name of village or Sothhoz Kohvoz, and population served)																
			Average Water Supply		Service Hours		Total Population Served		(1)		(2)		(3)		(4)		(5)		(6)		(7)		(8)	
			Average water supply (m <sup>3</sup> /day)	Maximum daily water supply (m <sup>3</sup> /day)	Maximum hourly water supply (m <sup>3</sup> /hour)	Time	Secondary	Total Population Served	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population
37	R-17		1200	2400	120	10:00-22:00	12	5000	Kirev	1500	PGT Ishev	3500												
38	R-18		80	120	12	8:00-18:00	12	1670	Lenin	1670														
39	R-19							3493	Leningrad	3493														
40	R-20							2791	Pyallietka	2791														
41	R-34							1673	Shabhyor	1673														
42	R-21		1200	2400	120	8:00-11:00, 17:00-22:00	10	5000	Yosh-Limnesh	1600	PGT Ishev	3200												

Water Supply System Data Base

Serial No.	Fill No.	WSS ID	A.3-1-1				A.3-1.2				A.3-1.3															
			Average Water Supply		Maximum hourly water supply (m <sup>3</sup> /hour)	Service Hours	Time	hours/day	Total Population Served	(1)		(2)		(3)		(4)		(5)		(6)		(7)		(8)		
			Average water supply (m <sup>3</sup> /day)	Maximum daily water supply (m <sup>3</sup> /day)						Village	Population	Village														
43	29	R-02	80	150	0.25	all day long		1300	Ittiloq-1	1300																
44	30	R-23					950	Ittiloq-2	950																	
45	31	R-22	1200	2400	240	8:00-18:00	10	3998	Ittiloq-3	1117	2003	Teiman	906													
46	32	R-24	50	100	4.1	10:00-22:00	12	1300	K. Marik	1300																
47	33	R-29	150	300	30	8:00-16:00	10	748	Mehnatobod	748																
48	34	R-03	80	120	10	10:00-22:00	12	1800	Pakhtaaraal	1800																





Water Supply System Data Base

Serial No.	File No.	WSS ID	A. Water Supply System													
			A-A-1.1					A-A-1.2								
			Average water supply (m <sup>3</sup> /day)	Maximum daily water supply (m <sup>3</sup> /day)	Maximum hourly water supply (m <sup>3</sup> /hour)	Time	Service Hours	Total Population Served	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
						Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	
59	6	J-06	50	100	8.3	10:00-22:00	12	870	Surh	870						
60	7	J-07						1887	Mirevoy	1887						
61	8	J-08	1200	2400	100	6:00-11:00; 18:00-21:00	6	4820	Dzhalil	4820						
62	9	J-10						860	Galaba	860						
63	10	J-05						4200	Kabodiyon	4200						
64	11	J-11						1700	Lemabod	1700						
65	12	J-12						3800	Eshbek Baitonov	3800						





Water Supply System Data Base

Sheet No.	File No.	WSS ID	A. Water Supply System																				
			A-1-1		A-1-2		(1)		(2)		(3)		(4)		(5)		(6)		(7)		(8)		
			Average water supply (m <sup>3</sup> /day)	Maximum daily water supply (m <sup>3</sup> /day)	Maximum hourly water supply (m <sup>3</sup> /hour)	Service Hours	Time	Total Population Served	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	
77	7	P-04	4800	9600		5	8:00-12:00	8860	Lenin	2150	Karl Marks	1020	Lehudi	756	50 years Pognantschuk	854	50 years Okyabi 540	Sadovaya	910	Ayni	1350	Shvendzova	480
78	8	P-07	400	800	40	10	6:00-11:00, 17:00-22:00	2700	Tugat	1000	School No. 5	1700											
79	9	P-08	400	800	35	12	7:00-18:00	4500	Dzerjinskiy-1	3500	Kalinchack	1000											
80	10	P-10	150	320	13.3	12	7:00-18:00	4500	Dzerjinskiy-2	4500													
81	11	P-13						5900	Sarmanloy 1	2500	Sarmanloy 2	3400											



Water Supply System Data Base

Serial No.	File No.	WSS ID	A-B-1-1		A-B-1-2		(name of village or Sobhizai Kolvoz, and population served)															
			Average Water Supply		Service Hours		(1)		(2)		(3)		(4)		(5)		(6)		(7)		(8)	
			Average water supply (m <sup>3</sup> /day)	Maximum daily water supply (m <sup>3</sup> /day)	Maximum hourly water supply (m <sup>3</sup> /hour)	Total Population Served	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population
89	3	Q-06				1534	Udemik	1534														
90	4	Q-03				1255	Kizi-Nishon	1255														
91	5	Q-07				1749	Madaniyat	1749														
92	6	Q-08				6800	3 village	1715	5 village	1235	6 village	1450	9 village	2200								
93	7	Q-04				11978	1 village	2570	2 village	2452	4 village	2650	6 village	4107								

Water Supply System Data Base

Serial No.	File No.	WSS ID	A.3-1-1		A.3-1-2		A.3-1-3								(8)					
			Average Water Supply		Service Hours	Total Population Served	(1)		(2)		(3)		(4)				(5)		(6)	
			Average water supply (m <sup>3</sup> /day)	Maximum daily water supply (m <sup>3</sup> /day)			Maximum hourly water supply (m <sup>3</sup> /hour)	Time	hours/day	Village	Population	Village	Population	Village			Population	Village	Population	Village
94	8	Q-05	240	400	40	8	6498	3425	Kulshan	2714	Mahyamyli	2357								
95	1	S-03	400	400	40	8	5395	5395	Alvoj											
96	2	S-07	400	800	40	10	12520	2642	Shitaley	2280	Sventlov	1955	Camuna	1525	Leinobod	3104	Kabramon	1594		
97	3	S-02					1200		Rusaki											
98	4	S-04	400	800	40	10	5300	5300	Velan											
99	5	S-09	250	500	25	10	4962	2642	Binokor	2260	Gidrostroilely									
100	6	S-05					6865		Sultanalod	2315	Yangabod									
101	7	S-08	150	200	25	10	1125	1125	Kuzi Ashar											

Water Supply System Data Base

File No.	WSS ID	A.8-1.1 Average Water Supply				A.8-1.2 Service Hours		(name of Village or Sakhiqz Kohoz, and population served)																		
		Average water supply (m <sup>3</sup> /day)	Maximum daily water supply (m <sup>3</sup> /day)	Maximum hourly water supply (m <sup>3</sup> /hour)	Total Population Served	Time (hours/day)	Village	Population	(1)		(2)		(3)		(4)		(5)		(6)		(7)		(8)			
									Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population	Village	Population
102	S-10	250	500	25	2500	not determined	Sayod	2500																		
103	S-01	250	500	25	3000	6:00-11:00, 17:00-22:00	Karl Marks	3000																		
104	S-06	1200	2400	120	12000	6:00-11:00, 17:00-22:00	PGT Shantuz	12000																		
105	V-01				2685		Buston	1135	Preshadam	1550																
106	V-05	400	800	40	6907	6:00-11:00, 17:00-22:00	Ok-Gozu	2901	Yangi-Ahlg	1507	Koil-Soy	1088	Yangi-Hayot	1346	Yangi-Yor	685	Shar-Shara	1470								
107	V-02				7705		Healobod	3446	Narobod	2470	Babobod	1789														
108	V-03				6723		Krov-1	4304	B-Mart	1000	Shurlepqa	1419														
109	V-04				3644		Lenin	1619	Ruzobod	1058	Mardoboy	1087														
110	V-06				3317		Agarbobog	1680	50 years Commem	1337																
111	V-07				12085		Sovetobod	2856	Internatsional	3600	Chalovnek	3158	Pakhtakor	2471												
112	V-08				17400		Durbil	8500	Rudaki	5400	Chappaev	3500														
113	V-09				4200		PGT Vaksah	4200																		



Water Supply System Data Base

Serial No	File No	WSS ID	(9)		(10)		A-9-2		A-10		B-1				B-2				B-3				B-4	
			Village	Population	Village	Population	Reason of out of working	A-9-2-1 Date (Month/Year) of Stoppage	History of rehabilitation or repairing of facilities	Number of well(s)	Coordinates of well (1)		Coordinates of well (2)		Coordinates of well (3)		Coordinates of well (4)		Coordinates of well (5)		Depth of well (m)	Capacity (Yield) of well		
											Latitude N	Longitude E		Latitude N	Longitude E	Altitude (m)								
1	1	K-10	Kash-Kuch	1450			2004	Decrept facility	2001-partially	2	37°19.518	068°11.178	371	37°18.724	068°11.320	370					110	70	700	
2	2	K-08							2001-partially	1	37°24.252	068°10.900	390								92	40	400	
3	3	K-03								1	37°24.252	068°10.992	390								110	40	480	
4	4	K-09					2006	Decrept facility	2004-partially	2	37°25.720	068°08.635	387	37°25.882	068°09.700	390					70	120	1200	
5	5	K-12					April-1999	Broken-down		1	37°25.457	068°11.341	404								70	120	1200	
6	6	K-02					2005	No operator	2004-partially	1	37°13.010	068°11.791	364								110	40	400	
7	7	K-05							2008-partially	1	37°04.554	068°07.098	330								40	10	100	

Water Supply System Data Base

Serial No	File No	ID WSS	(9)		(10)		A-9-2		A-10		B-1			B-2						B-3		B-4							
			Village	Population	Village	Population	If out of working	A-9-2-1 Reason of out of working	A-9-2-3 Date (Month/Year) of Start-up	History of rehabilitation or repairing of facilities	Number of wells	Coordinates of well (1)			Coordinates of well (2)			Coordinates of well (3)			Coordinates of well (4)			Depth of well (m)	Capacity (Yield) of well				
												Latitude N	Longitude E	Altitude (m)		Latitude N	Longitude E	Altitude (m)	m <sup>3</sup> /hour	m <sup>3</sup> /day									
8	8	K-01						Deceit facility	1993	2003		3723.998	068°09.886	385	3723.878	068°09.881	386	3723.801	068°09.719	385								65	650
9	9	K-14								2005-partially by ECHO	1	3720.101	068°12.001	379														40	400
10	10	K-06								2002-partially	1	3720.300	068°01.003	390														10	100
11	11	K-04						Deceit facility	2004	2000-partially	1	37°11.344	068°11.176	349														40	400
12	12	K-13						Deceit facility	2004	2000	1	37°11.474	068°03.063	360														40	344
13	13	K-11						Deceit facility	2001	not conducted	1	37°09.705	068°13.278	355														40	400
14	14	K-07						Deceit facility	2005	2001-partially	2	37°12.172	068°12.700	370	37°11.860	068°12.836	369										16	160	
15	15	R-37						Lack of water		not conducted																			



Water Supply System Data Base

Serial No.	File No.	WSS ID	(P)			A-9-2		A-10	B-1			B-2						B-3		B-4										
			Village	Population	Village	Population	(10)		If out of working	A-9-2-2 Date (Month/Year) of Stoppage	History of rehabilitation or repairing of facilities	Latitude N	Longitude E	Altitude (m)	Capacity (Yield) of well m3/day	Capacity (Yield) of well m3/hour														
22	6	R-08						Lack of water in the Vakhsh conduit	1998	2004																				
23	9	R-09						Lack of water in the Vakhsh conduit	1998	not conducted																				
24	10	R-27						Lack of water pressure in the Vakhsh conduit	1998	not conducted																				
25	11	R-10						Lack of water in the Vakhsh conduit	1993	not conducted																				
26	12	R-11						Decrepit facility	1993	not conducted																				
27	13	R-13						Decrepit facility Problem of conduit network	1992	not conducted																				
28	14	R-14						Problem of conduit network	1998	not conducted																				





Water Supply System Data Base

Well No.	Site No.	(9)		(10)		A-9-2		A-10	B-1	B-2						B-3		B-4							
		Village	Population	Village	Population	A-9-2-1	A-9-2-2			Number of well (1)	Coordinates of well (1)		Coordinates of well (2)		Coordinates of well (3)		Coordinates of well (4)		Depth of well (m)	Capacity (Yield) of well m <sup>3</sup> /hour	Capacity (Yield) of well m <sup>3</sup> /day				
				Reason of out of working	Year (Month/Year) of Shutdown	History of rehabilitation or repairing of facilities				Latitude N	Longitude E	Altitude (m)	Latitude N	Longitude E	Altitude (m)	Latitude N	Longitude E	Altitude (m)	Latitude N	Longitude E	Altitude (m)				
43	29					not conducted																			
44	30			Corroded conduit	2005	not conducted																			
45	31			Collapsed in the No.1 and No.2 boreholes	2002	2001			4	37°30.502	068°38.846	383	37°30.532	068°38.884	383	37°30.602	068°38.928	384	37°30.622	068°38.331	384	50	120	1200	
46	32					not conducted																			
47	33			Lack of water pressure in the 7th main conduit	1999	not conducted																			
48	34			Lack of water pressure	1995	not conducted																			





Water Supply System Data Base

Serial No.	File No.	WSS ID	(8)			A-B-2		A-10	B-1	B-2						B-3	B-4									
			Village	Population	Village	Population	A-B-2.1			A-B-2.2	Coordinates of well (1)		Coordinates of well (2)		Coordinates of well (3)		Coordinates of well (4)		Coordinates of well (5)		Depth of well (m)	Capacity (Yield) of well m3/day				
										Latitude N	Longitude E	Altitude (m)	Latitude N	Longitude E	Altitude (m)	Latitude N	Longitude E	Altitude (m)	Latitude N	Longitude E	Altitude (m)	Latitude N	Longitude E	Altitude (m)		
59	6	J-06					Lack of water in the Vaibish conduit	1999	not conducted																	
60	7	J-07					Lack of water in the Vaibish conduit	1994	not conducted																	
61	8	J-08					Lack of water in the Vaibish conduit	1993	2000-partially																	
62	9	J-10					Corroded conduit	1997	not repaired																	
63	10	J-08					Lack of water from Vaibish conduit	1992	not conducted																	
64	11	J-11					Broken-down	2006	not conducted																	
65	12	J-12					Decrepit facility	1992	not conducted																	

Water Supply System Data Base

Serial No.	Fib No.	WSS ID	A-3-2				A-10	B-1	B-2						B-3				B-4							
			(9)		(10)				If out of working		Coordinates of well (1)		Coordinates of well (2)		Coordinates of well (3)		Coordinates of well (4)		Coordinates of well (5)		Depth of well		Capacity (Yield) of well			
			Village	Population	Village	Population			A-3-2-1	A-3-2-2	Latitude N	Longitude E	Altitude (m)	Altitude (m)	Altitude (m)	Altitude (m)	Altitude (m)	Altitude (m)								
66	13	J-13																								
67	14	J-14																								
68	1	N-03																								
69	2	N-01																								
70	3	N-02																								



Water Supply System Data Base

Serial No.	File No.	WSS ID	(9)			A.9.2		A.10	B-1	B-2						B-3		B-4							
			Village	Population	Village	Population	A.9.2-1 Reason of out of working			A.9.2-2 Data (Month/year) of Stoppage	History of rehabilitation or repairing of facilities	Number of well(s)	Coordinates of well (1)		Coordinates of well (2)		Coordinates of well (3)		Coordinates of well (4)		Coordinates of well (5)		Depth of well (m)	Capacity (Yield) of well m <sup>3</sup> /hour m <sup>3</sup> /day	
77	7	P-04							6	37°13.590	069°06.306	359	37°13.912	069°06.347	359								70-80	720	17290
78	8	P-07						2003-partially	1	37°10.720	069°10.732	371											60-70	40	400
79	9	P-08						2003																	
80	10	P-10						1984																	
81	11	P-13						2004	2	37°16.103	069°17.140	347	37°16.790	069°17.201	344								70	40	400

Water Supply System Data Base

Serial No.	File No.	WSS ID	(8)			A-4-2		A-10	B-1	B-2						B-3		B-4										
			Village	Population	Village	Population	A-4-2-1			A-4-2-2	Number of wells	Coordinates of well (1)		Coordinates of well (2)		Coordinates of well (3)		Coordinates of well (4)		Coordinates of well (5)		Depth of well	Capacity (Yield) of well					
									Latitude N	Longitude E	Altitude (m)	Latitude N	Longitude E	Altitude (m)	Latitude N	Longitude E	Altitude (m)	Latitude N	Longitude E	Altitude (m)	Latitude N	Longitude E	Altitude (m)	Latitude N	Longitude E	Altitude (m)	m <sup>3</sup> /hour	m <sup>3</sup> /day
82	12	P-16					2004	2001	37°13.230	069°07.133	344															40	400	
83	13	P-11					1990	not conducted	37°11.240	069°11.804	366															40	400	
84	14	P-01					1992	not repaired from 1990	37°10.699	069°10.264	373				37°10.599	069°10.224	375									40	400	
85	15	P-14					2006	2003	37°09.603	069°11.433	379															40	400	
86	16	P-12					2003	not conducted	37°10.441	069°11.589	383															40	400	
87	1	Q-01					1995	not conducted																				
88	2	Q-02					1995	not conducted																				



Water Supply System Data Base

Serial No.	File No.	WSID	A-1			A-2			A-3			A-4			B-1			B-2						B-3		B-4					
			Village	Population	Village	Population	Population	(10)	If out of working	A-2-1 Reason of out of working	A-2-2 Date (Month/Year) of Stoppage	A-3-1 History of rehabilitation or repairing of facilities	Number of well(s)	Latitude N	Longitude E	Altitude (m)	Latitude N	Longitude E	Altitude (m)	Latitude N	Longitude E	Altitude (m)	Latitude N	Longitude E	Altitude (m)	Latitude N	Longitude E	Altitude (m)	Depth of well (m)	Capacity (Yield) of well m <sup>3</sup> /hour	m <sup>3</sup> /day
94	Q-05							Incomplete facility Lack of water in the Vakhsh conduit	1992	2005-partially	1	30°58.834	068°01.855	313																	
95	S-03									2005-partially	1	30°58.834	068°01.855	313													65	40	240		
96	S-07							Decrease facility (30% rate of operation)	1998	2002-partially	3	37°15.914	068°08.945	359	37°15.815	068°08.960	360	37°15.765	068°08.975	359							70	40	400		
97	S-02							Decrease facility	2008	2001-partially	1	37°15.101	068°08.105	353													65	40	400		
98	S-04									not conducted	1	37°14.159	068°05.004	352													65	40	400		
99	S-09							Decrease facility	2008	2001-partially	2	37°15.414	068°06.445	359	37°15.519	068°08.589	360										80-90	25	250		
100	S-05							No operator	2005	2002-reconstructed	2	37°23.102	068°08.125	365	37°23.213	068°08.302	366										65	63	630		
101	S-08									2004-partially	1	37°12.102	068°08.202	340													65	25	150		

Water Supply System Data Base

Well No	Site No	CI SSM	(8)		(10)		A-4-2		A-10	B-1	B-2						B-3		B-4			
			Village	Population	Village	Population	Reason of out of working	A-4-2-1 (Month/year)			A-4-2-2 (Month/year)	Coordinates of well (1)		Coordinates of well (2)		Coordinates of well (3)		Coordinates of well (4)		Depth of well (m)	Capacity (m <sup>3</sup> /hour)	Capacity (Yield) of well m <sup>3</sup> /day
												Latitude N	Longitude E									
102	8	S-10							2000-partially	1	37°12.823	068°08.409	339								25	150
103	9	S-01							2002-partially	1	37°16.864	068°08.908	359								25	250
104	10	S-06							1987-partially	3	37°16.864	068°08.908	359	37°16.710	068°08.812	359	37°16.910	068°08.888	360		120	1200
105	1	V-01							not conducted													
106	2	V-05							2000-partially													
107	3	V-02							not conducted													
108	4	V-03							not conducted													
109	5	V-04							not conducted													
110	6	V-06							not conducted													
111	7	V-07							2001-rehabilitation of station 1													
112	8	V-08							2003-partially													
113	9	V-09							not conducted													



Water Supply System Data Base

Serial No.	File No.	WSS ID	B. Water Source (Wahat Conditia Groundwater Irrigation canal)																					
			B-5		B-6 Water level			B-7 Casing / Screen Pipe			B-8 Pump				B-9-8									
			Maximum yield of well	Static Water Level (m BGL)	Dynamic Water Level (m BGL)	B-7-1 Diameter (mm)	B-7-2 Material	B-7-2 Specify for Other	B-7-3 Position of Screen (m BGL)	Pump	Type	Specify for Other	B-8-2 Position (m BGL)	B-8-3 Rated motor output (hp)		B-8-4 Pump head (m)	B-8-5 Discharge of pump	Diameter of Riser Pipe (mm)	B-8-6 Material of riser pipe	B-9-7 Starting up method of pump	Location of control panel	Others (mark, if installed)		
1	1	K-10	70	1300	4	425	1: Steel				70-90	ECV 10-120-60	1: Submersible		42	32	60	2	120	100	Steel	2: Star delta	1: Indoor	Installed
2	2	K-08	40	600	6	325	1: Steel				65-80	ECV 8-40-125	1: Submersible		38	22	125	0.7	40	50	Steel	2: Star delta	1: Indoor	Installed
3	3	K-03	40	600	5	325	1: Steel				80-90	ECV 8-40-125	1: Submersible		42	22	125	0.7	40	80	Steel	2: Star delta	1: Indoor	
4	4	K-09	120	2400	6	425	1: Steel				45-60	ECV 10-120-60	1: Submersible		35	32	60	2	120	100	Steel	2: Star delta	1: Indoor	Installed
5	5	K-12	120	2400	10	325	1: Steel				45-60	ECV 10-120-60	1: Submersible		38	32	60	2	120	120	Steel	2: Star delta	2: Outdoor	Not Installed
6	6	K-02	40	600	4	325	1: Steel				70-90	ESV16-16-125	1: Submersible		38	11	125	0.7	40	76	Steel	2: Star delta	1: Indoor	
7	7	K-05	10	200	4	325	1: Steel				25-35	ECV 8-10-110	1: Submersible		22	5.5	110	0.16	10	76	Steel	2: Star delta	1: Indoor	Installed

Water Supply System Data Base

Serial No.	File No.	WSS ID	B-5		B-6		B-7			B-8				B-9				B-10				
			Maximum yield of well	m <sup>3</sup> /hour	m <sup>3</sup> /day	Satatic Water Level (m BGL)	Dynamic Water Level (m BGL)	B-7-1 Diameter (mm)	B-7-2 Material	B-7-2 Specify for Other	B-7-3 Position (m BGL)	B-8-1 Type	B-8-1 Specify for Other	B-8-2 Position (m BGL)	B-8-3 Rated motor output (kw)	B-8-4 Pump head (m)	B-8-5 Discharge of pump	m <sup>3</sup> /min	m <sup>3</sup> /hour	Diameter of Riser Pipe (mm)	B-8-6 Material of riser pipe	B-8-7 Starting up method of pump
8	K-01	85	1300	0	425	1: Steel			45-60	1: Submersible		36	32	120	1	65	150	Steel		2: Star delta	1: Indoor	Installed
9	K-14	40	800	5	276	1: Steel			45-60	1: Submersible		28	22	125	0.7	40	89	Steel		2: Star delta	1: Indoor	
10	K-06	10	200	4	219	1: Steel			45-55	1: Submersible		40	6.5	110	0.16	10	76	Steel		2: Star delta	2: Outdoor	Installed
11	K-04	40	800	5	325	1: Steel			55-70	1: Submersible		30	22	125	0.7	40	100	Steel		2: Star delta	2: Outdoor	Installed
12	K-13	40	600	5	425	1: Steel			55-70	1: Submersible		32	22	125	0.7	40	100	Steel		2: Star delta	1: Indoor	Not Installed
13	K-11	40	600	5	225	1: Steel			70-90	1: Submersible		45	22	125	0.7	40	100	Steel		2: Star delta	1: Indoor	Installed
14	K-07	16	320	6	325	1: Steel			80-100	1: Submersible		38	11	125	0.3	16	100	Steel		2: Star delta	1: Indoor	
15	1	R-37																				

Water Supply System Data Base

Well No.	File No.	WSS ID	B-5		B-6 Water level		B-7 Casing / Screen Pipe			B-8 Pump												
			Maximum yield of well	m <sup>3</sup> /day	Static Water Level (m BGL)	Dynamic Water Level (m BGL)	B-7-1 Diameter (mm)	B-7-2 Material	B-7-3 Position of Screen	B-8-1		B-8-2	B-8-3	B-8-4	B-8-5 Discharge of pump		B-8-6	B-8-7	B-8-8			
			m <sup>3</sup> /hour				Specify for Other	Type	Pump						m <sup>3</sup> /min	m <sup>3</sup> /hour	Diameter of Riser Pipe (mm)	Material of riser pipe	Standing up method of pump	Location of control panel	Others (mark, if installed)	
16	2	R-06																				
17	3	R-04																				
18	4	R-05																				
19	5	R-38																				
20	6	R-32																				
21	7	R-07																				



Water Supply System Data Base

Serial No.	File No.	WSS ID	B. Water Source (Vakhat Conduits Groundwater Irrigation canal)																						
			B-5		B-6			B-7			B-8		B-9												
			Maximum yield of well	m <sup>3</sup> /day	Satatic Water Level (m BGL)	Dynamic Water Level (m BGL)	B-7-1 Diameter (mm)	B-7-2 Material	B-7-2 Specify for Other	B-7-3 Position (m BGL)	Pump	Type	Specify for Other	B-8-2 Position (m BGL)	B-8-3 Rated motor output (kw)	B-8-4 Pump head (m)	B-8-5 Discharge of pump	B-8-5 m <sup>3</sup> /min	B-8-5 m <sup>3</sup> /hour	Diameter of Riser Pipe (mm)	B-8-6 Material of riser pipe	B-8-7 Starting up method of pump	B-8-8 Location of control panel	Others (mark, if installed)	
29	15	R-28																							
30	16	R-12																							
31	17	R-28																							
32	18	R-15																							
33	19	R-30																							
34	20	R-33																							
35	21	R-01																							
36	22	R-16																							

Water Supply System Data Base

Serial No.	File No.	WSS ID	B-5		B-6		B-7			B-8		B-9		B-10		Others (mark, if installed)									
			m <sup>3</sup> /hour	m <sup>3</sup> /day	Static Water Level (m BGL)	Dynamic Water Level (m BGL)	B-7-1 Diameter (mm)	B-7-2 Material	B-7-2 Specify for Other	B-7-3 Position of Screen (m BGL)	Pump	Type	Specify for Other	B-9-2 Position (m BGL)	B-9-3 Rated motor output (hp)		B-9-4 Pump head (m)	B-9-5 Discharge of pump							
																		m <sup>3</sup> /min	m <sup>3</sup> /hour						
37	23	R-17	120	2400		5	425	1: Steel		38-50	ECV 10-120-60	1: Submersible		28	320x / 2900rpm	60	2	120	150	Steel	2: Star delta	2: Outdoor			
38	24	R-18																							
39	25	R-19																							
40	26	R-20																							
41	27	R-24																							
42	28	R-21	120	2400		4	425	1: Steel		30-40	ECV 10-120-60	1: Submersible		24	320x / 2900rpm	60	2	120	150 mm x4	Steel	2: Star delta	2: Outdoor			

Water Supply System Data Base

Serial No.	File No.	WSS ID	B. Water Source (Valkhah Conduits Groundwater Irrigation canal)																	
			B-5		B-6			B-7				B-8			B-8-8					
			Maximum yield of well		Water level		Casing / Screen Pipe			B-8 Pump										
m <sup>3</sup> /hour	m <sup>3</sup> /day	Satatic Water Level (m BGL)	Dynamic Water Level (m BGL)	B-7-1 Diameter (mm)	B-7-2 Material	B-7-2 Specify for Other	B-7-3 Position (m BGL)	Pump	Type	Specify for Other	B-8-2 Position (m BGL)	B-8-3 Rated motor output (kw)	B-8-4 Pump head (m)	B-8-5 Discharge of pump	B-8-6 Diameter of Riser Pipe (mm)	B-8-6 Material of riser pipe	B-8-7 Starting up method of pump	Others (mark, if installed)		
43	29	R-02																		
44	30	R-23																		
45	31	R-22	120	2400	2	426	1: Steel	40-55	ECV 10-120-60	1: Submersible	24-28	32	125	2	120	100	Steel	2: Star delta	1: Indoor	Installed
46	32	R-24																		
47	33	R-39																		
48	34	R-03																		

Water Supply System Data Base

Serial No.	File No.	WSS ID	B. Water Source (Walkiash Conduits Groundwater Irrigation canal)																
			B-5		B-6			B-7			B-8 Pump								
			Maximum yield of well	Static Water Level (m BGL)	Dynamic Water Level (m BGL)	B-7.1 Diameter (mm)	B-7.2 Material	B-7.2 Specify for Other	B-7.3 Position of Screen (m BGL)	B-8.1	B-8.2	B-8.3	B-8.4	B-8.5 Discharge of pump	B-8.6				
m <sup>3</sup> /hour	m <sup>3</sup> /day						Type	Position (m BGL)	Rated motor output (kw)	Pump head (m)	m <sup>3</sup> /min	m <sup>3</sup> /hour	Diameter of Riser Pipe (mm)	Material of riser pipe	Stacking up method of pump	Location of control panel	Others (mark, if installed)		
49	35	R-36																	
50	36	R-25																	
51	37	R-35																	
52	38	R-31																	

Water Supply System Data Base

Well No.	File No.	WSS ID	B-5		B-6			B-7			B-8 Pump				B-6-8 Others (mark, if installed)				
			Maximum yield of well m <sup>3</sup> /hour	m <sup>3</sup> /day	Static Water Level (m BGL)	Dynamic Water Level (m BGL)	B-7-1 Diameter (mm)	B-7-2		B-8-1 Type	B-8-2 Position (m BGL)	B-8-3 Rated motor output (kW)	B-8-4 Pump head (m)	B-8-5 Discharge of pump		B-8-6 Material of riser pipe	B-8-7 Starting up method of pump	B-6-8 Location of control panel	
								B-7-1 Material	B-7-2 Specify for Other					B-7-3 Position (m BGL)					m <sup>3</sup> /min
53	39	R-26																	
54	1	J-02																	
55	2	J-01																	
56	3	J-03																	
57	4	J-04																	
58	5	J-05																	

Water Supply System Data Base

Well No	File No	WSS ID	B-5		B-6		B-7			B-8-1		B-8-5 Discharge of pump				B-8-6		B-8-7	B-8-8
			Maximum yield of well	m <sup>3</sup> /day	Static Water Level (m BGL)	Dynamic Water Level (m BGL)	B-7-1 Diameter (mm)	B-7-2 Material	B-7-2 Specify for Other	B-7-3 Position of Screen (m BGL)	Pump	Type	Specify for Other	B-8-2 Position (m BGL)	B-8-3 Rated motor output (kw)	B-8-4 Pump head (m)	m <sup>3</sup> /min		
59	6	J-06																	
60	7	J-07																	
61	8	J-09																	
62	9	J-10																	
63	10	J-08																	
64	11	J-11																	
65	12	J-12																	

Water Supply System Data Base

Gate No.	File No.	WSS ID	B-5		B-6 Water level		B-7 Casing / Screen Pipe			B-8 Pump						B-9-6									
			Maximum yield of well m <sup>3</sup> /hour	m <sup>3</sup> /day	Static Water Level (m BGL)	Dynamic Water Level (m BGL)	B-7-1 Diameter (mm)	B-7-2 Material	B-7-2 Specify for Other	B-7-3 Position of Screen (m BGL)	B-8-1 Type	Specify for Other	B-8-2 Position (m BGL)	B-8-3 Rated motor output (kw)	B-8-4 Pump head (m)	m <sup>3</sup> /min	m <sup>3</sup> /hour	Discharge of pump	Diameter of riser Pipe (mm)	B-8-6 Material of riser pipe	B-8-7 Starting up method of pump	Location of control panel	Others (mark, if installed)		
																								Pump	B-8-1 Type
66	13	J-13																							
67	14	J-14	40	800	4	4	425	1: Steel	30-35	ESV 8-40-125	1: Submersible	25	22	125	0.7	40	40	100	Steel		2: Star delta	2: Outdoor			
68	1	N-03	40	800	6	6	425	1: Steel	95-110	ECV 8-40-125	1: Submersible	45	22	125	0.7	40	76	Steel			2: Star delta	1: Indoor	Installed		
69	2	N-01	120	2400	6	6	425	1: Steel	45-55	ECV 10-120-80	1: Submersible	30	32 kw 2900 turn/minute	80	2	120	114	Steel			2: Star delta	1: Indoor	Installed		
70	3	N-02	25	400	4	4	219	1: Steel	85-80	ECV 5-25-110	1: Submersible	40	22	110	0.4	25	89	Steel			2: Star delta	1: Indoor			

Water Supply System Data Base

Serial No.	File No.	WSS ID	B-5		B-6		B-7		B-8		B-9		B-10		B-11		B-12		B-13		B-14		B-15		B-16		B-17		B-18		B-19		B-20		B-21		B-22		B-23		B-24		B-25		B-26		B-27		B-28		B-29		B-30		B-31		B-32		B-33		B-34		B-35		B-36		B-37		B-38		B-39		B-40		B-41		B-42		B-43		B-44		B-45		B-46		B-47		B-48		B-49		B-50		B-51		B-52		B-53		B-54		B-55		B-56		B-57		B-58		B-59		B-60		B-61		B-62		B-63		B-64		B-65		B-66		B-67		B-68		B-69		B-70		B-71		B-72		B-73		B-74		B-75		B-76		B-77		B-78		B-79		B-80		B-81		B-82		B-83		B-84		B-85		B-86		B-87		B-88		B-89		B-90		B-91		B-92		B-93		B-94		B-95		B-96		B-97		B-98		B-99		B-100	
			Maximum yield of well m <sup>3</sup> /hour	Maximum yield of well m <sup>3</sup> /day	Static Water Level (m BSL)	Dynamic Water Level (m BSL)	B-7-1 Diameter (mm)	B-7-2 Material	B-7-2 Specify for Other	B-7-3 Position (m BSL)	Pump	Type	Specify for Other	B-8-2 Position (m BSL)	Rated motor output (kw)	B-8-4 Pump head (m)	m <sup>3</sup> /min	m <sup>3</sup> /hour	Diameter of Riser Pipe (mm)	Material of riser pipe	Stacking up method of pump	Location of control panel	Others (mark, if installed)																																																																																																																																																																											
71	1	P-15	120	2400	6	428	1: Steel	65-70	ECV 10-120-60	1: Submersible	60	32	60	2	120	100	Steel	2: Star delta	1: Indoor																																																																																																																																																																															
72	2	P-05	40	800	4	273	1: Steel	55-70	ECV 8-40-125	1: Submersible	38	22	125	0.7	40	78	Steel	2: Star delta	2: Outdoor																																																																																																																																																																															
73	3	P-02	40	800	6	273	1: Steel	45-60	ECV 8-40-125	1: Submersible	40	22	125	0.7	40	88	Steel	2: Star delta	1: Indoor	installed																																																																																																																																																																														
74	4	P-06	120	2400	8	325	1: Steel	70-90	ECV 10-120-60	1: Submersible	48	32	60	2	120	100	Steel	2: Star delta	1: Indoor	installed																																																																																																																																																																														
75	5	P-09	40	800	15	325	1: Steel	45-55	ECV 8-40-110	1: Submersible	32	22	110	0.7	40	78	Steel	2: Star delta	1: Indoor																																																																																																																																																																															
76	6	P-03	40	800	6	325	1: Steel	55-70	ECV 8-40-125	1: Submersible	32	22	125	0.7	40	88	Steel	2: Star delta	1: Indoor	installed																																																																																																																																																																														

### Water Supply System Data Base

Serial No.	File No.	B. Water Sources (Kakhatan Conduits Groundwater Irrigation canal)																			
		B-5		B-6			B-7 Casing / Screen Pipe				B-8 Pump										
ID	WSID	Maximum yield of well		Static Water Level (m BGL)	Dynamic Water Level (m BGL)	B-7-1 Diameter (mm)	B-7-2 Material	B-7-2 Specify for Other	B-7-3 Positive Head of Screen (m BGL)	B-8-1		B-8-2 Position (m BGL)	B-8-3 Rated motor output (kw)	B-8-4 Pump head (m)	B-8-5 Discharge of pump	B-8-6 Diameter of Riser Pipe (mm)	B-8-6 Material of riser pipe	B-8-7 Starting up method of pump	B-8-8 Location of control panel	Others (mark, if installed)	
		m <sup>3</sup> /hour	m <sup>3</sup> /day							Pump	Type										Specify for Other
77	7	P-04	360	3600	6	325-426	1: Steel		55-65	ECV 10-120-60	1: Submersible	36	32	60	2	120	150	Steel	2: Star delta	1: Indoor	Installed
78	8	P-07	40	600	5	273	1: Steel		45-60	ECV 8-40-125	1: Submersible	32	22	125	0.7	40	114	Steel	2: Star delta	1: Indoor	
79	9	P-08																			
80	10	P-10																			
81	11	P-13	55	700	4	325	1: Steel		4-6	ECV 8-40-125	1: Submersible	35	22	125		114	Steel	2: Star delta	1: Indoor		

Water Supply System Data Base

Serial No.	Fig No.	WSS ID	B. Water Source (Vakshah Conduits Groundwater Irrigation canal)																			
			B-5		B-6		B-7			B-8				B-9			B-10					
			Maximum yield of well	Static Water Level (m BGL)	Dynamic Water Level (m BGL)	B-7-1 Diameter (mm)	B-7-2 Material	B-7-2 Specify for Other	B-7-3 Position (m BGL)	Pump	Type	Specify for Other	B-8-2 Position (m BGL)	Rated motor output (kw)	B-8-4 Pump head (m)	m <sup>3</sup> /min	m <sup>3</sup> /hour	Diameter of Riser Pipe (mm)	Material of riser pipe	Starting up method of pump	Location of control panel	Others (mark, if installed)
82	12 P-16	40	800		6	325	1: Steel		45-55	ECV 8-40-125	1: Submersible		33	22	125	0.7	40	80	Steel	2: Star delta	1: Indoor	
83	13 P-11	40	800		5	273	1: Steel		45-55	ECV 8-40-125	1: Submersible		35	22	125	0.7	40	75	Steel	2: Star delta	1: Indoor	
84	14 P-01	40	800		4	273	1: Steel		55-60	ECV 8-40-125	1: Submersible		37	22	125	0.7	40	100	Steel	2: Star delta	1: Indoor	
85	15 P-14	40	700		8	325	1: Steel		55-60	ECV 8-40-125	1: Submersible		42	22	110	0.7	40	100	Steel	2: Star delta	1: Indoor	Installed
86	16 P-12	40	800		4	428	1: Steel		50-60	ECV 8-40-125	1: Submersible		35	32	125	0.7	40	114	Steel	2: Star delta	1: Indoor	
87	1 Q-01																					
88	2 Q-02																					

Water Supply System Data Base

Serial No.	File No.	WSS ID	B-5 Maximum yield of well		B-6 Water level			B-7 Casing / Screen Pipe			B-8 Pump					B-9-8				
			m3/hour	m3/day	Static Water Level (m BGL)	Dynamic Water Level (m BGL)	B-7-1 Diameter (mm)	B-7-2 Material	B-7-2 Specify for Other	B-7-3 Position of Screen (m BGL)	B-8-1 Type	B-8-2 Position (m BGL)	B-8-3 Rated motor output (kw)	B-8-4 Pump head (m)	B-8-5 Discharge of pump m <sup>3</sup> /min	m <sup>3</sup> /hour	Diameter of Riser Pipe (mm)	B-8-6 Material of riser pipe	B-8-7 Staging up method of pump	Location of control panel
89	3	Q-06																		
90	4	Q-03																		
91	5	Q-07																		
92	6	Q-08																		
93	7	Q-04																		



### Water Supply System Data Base

Serial No.	PFA No.	WSS ID	B. Water Source (Kalkaah Conduits Groundwater Irrigation canal)																			
			B-5		B-6			B-7			B-8		B-9									
			Maximum yield of well	Static Water Level (m BGL)	Dynamic Water Level (m BGL)	B-7-1 Diameter (mm)	B-7-2 Material	B-7-2 Specify for Other	B-7-3 Position (m BGL)	Pump	Type	Specify for Other	B-8-2 Position (m BGL)	Rated motor output (kw)	B-8-4 Pump head (m)	B-8-5 Discharge of pump	B-8-6 Diameter of Riser Pipe (mm)	B-8-6 Material of riser pipe	B-8-7 Starting up method of pump	B-8-8 Location of control panel	B-8-8 Others (mark, if installed)	
102	8	S-10	25	180	5	325	1: Steel		45-55	ESV 8-40-110	1: Submersible		32	11	110	0.4	25	80	Steel	2: Star delta	1: Indoor	Installed
103	9	S-01	25	500	6	325	1: Steel		45-55	ECV 8-25-110	1: Submersible		38	22	110	0.4	25	100	Steel	2: Star delta	1: Indoor	
104	10	S-08	120	2400	6	325-426	1: Steel		45-60	ECV 8-120-60	1: Submersible		40	32	60	2	120	159	Steel	2: Star delta	1: Indoor	Installed
105	1	V-01																				
106	2	V-05																				
107	3	V-02																				
108	4	V-03																				
109	5	V-04																				
110	6	V-06																				
111	7	V-07																				
112	8	V-08																				
113	9	V-09																				









Water Supply System Data Base

State No	File No	WSS ID	B-9 Water Quality											B-10 Availability of alternative water source. If operation of water supply service is seasonal or service is stopping.				C-1				C-2		C-3	C-4	
			pH	Temperature a (°C)	EC (mS/m)	TDS (mg/l)	Total Coll	E. Coli	Fe (mg/l)	F (mg/l)	As (mg/l)	Residual Chlorine (mg/l)	NO <sub>3</sub> (mg/l)	Type of Water Source	Specify for Other	Distance from the nearest water source	Times of Fetching (unimposed)	Diameter of Pipe (mm)	Material of Pipe	Length of Conduit (km)	Condition of Pipe	Specify for Partially Deteriorated	What is the Problem			
																								3: Irrigation canal	3: Irrigation canal	0.4km
22	8	R-08	5.4	10	33.4	166	1	0.4	0.4	< 0.2	< 0.2	< 1	3: Irrigation canal		0.4km	not limited	425	steel	0.6	1: No problem						
23	9	R-09											3: Irrigation canal		0.6km	not limited										
24	10	R-27											1: Vabshah Conduit	Irrigation Canal	0.6km	3	150	steel	1.4	1: No problem						
25	11	R-10	5.2	19	66.5	170	1	0.5	0.4	< 0.2	< 1	3: Irrigation canal		0.7km	2											
26	12	R-11	5.8	12	33.3	164	0	0.05	< 0.4	< 0.2	< 1	3: Irrigation canal		0.6km	3											
27	13	R-13											4: Other	Vabshah river	0.3km	3										
28	14	R-14											1: Vabshah Conduit	Irrigation Canal	3.0km	2										

Water Supply System Data Base

Serial No.	File No.	WSS ID	B-9 Water Quality										B-10 Availability of alternative water sources. If operation of water supply service is seasonal or service is stopping.				C-1 Diameter of Pipe (mm)				C-2 Material of Pipe	C-3 Length of Conduit (km)	C-4 Condition of Pipe	Specify for Partially Deteriorated	What is the Problem					
			pH	Temperature (°C)	EC (mS/m)	TDS (mg/l)	Total Coll.	E. Coll.	Fe (mg/l)	F (mg/l)	As (mg/l)	Residual Chlorine (mg/l)	NO <sub>3</sub> (mg/l)	Type of Water Source	Specify for Other	Distance from the nearest water source	Times of Fetching (immediacy)													
																		NC <sub>3</sub> (mg/l)	NC <sub>2</sub> (mg/l)	NC <sub>1</sub> (mg/l)						NC <sub>0</sub> (mg/l)				
29	15	R-28	5.1	16	33.4	166	0	1	0.05	0.4	<0.3	<0.2	<1	4: Other	Vaishah river	0.5km	not limited													
30	16	R-12	5.9	17	32.5	165	1	1	0.05	0.4	<0.2	<0.2	1	3: Irrigation canal		0.9km	1													
31	17	R-29	6.7	15	66.4	337	0	1	0.5	0.4	<0.3	<0.2	<1	3: Irrigation canal		0.3km	4													
32	18	R-15												3: Irrigation canal		0.5km	2													
33	19	R-30												3: Irrigation canal		0.4km	2													
34	20	R-33	5.9	16	33.4	172	0	1	0.05	0.4	<0.2	<0.1	<2	3: Irrigation canal		0.3km	4													
35	21	R-01												3: Irrigation canal		0.7km	3													
36	22	R-18	5.7	16	33.8	165	1	1	0.05	0.4	<0.2	0.2	1	3: Irrigation canal		0.2km	3													





Water Supply System Data Base

Site No	File No	WSS ID	B-9 Water Quality										B-10 Availability of alternative water source, if operation of water supply service is seasonal or service is stopping.				C-4 Aqueduct (conduit from water source to a reservoir or distribution tank)							
			pH	Temperature (°C)	EC (mS/m)	TDS (mg/l)	Total Coli	E. Coli	Fe (mg/l)	F (mg/l)	As (mg/l)	Residual Chlorine (mg/l)	NO <sub>3</sub> (mg/l)	Type of Water Source	Specify for Other	Distance from the nearest water source	Times of Fetching (immediacy)	Diameter of Pipe (mm)	Material of Pipe	Length of Conduit (km)	Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	
																								C-1
49	35	R-38	5.3	15	32.3	162	0	0	0.05	0.4	<0.2	<1	<2	1: Valhish Conduit	0.4km	not limited								
50	36	R-25												3: Irrigation canal	0.4km	3								
51	37	R-35	8.7	18	33.4	166	1	1	0.06	0.4	<0.2	<0.2	<1	1: Valhish Conduit	0.5km	3								
52	38	R-31	5.5	17	32.5	168	0	0	0.04	0.4	<0.2	<0.2	<1	1: Valhish Conduit	Groundwater of Uzun 1				0.07	steel	0.07	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required	Decept facility





Water Supply System Data Base

Serial No.	File No.	WSS ID	B-9 Water Quality													B-10 Availability of alternative water source. If operation of water supply service is seasonal or service is stopping.				C-1				C-2		C-3		C-4	
			pH	Temperature (°C)	EC (mS/m)	TDS (mg/l)	Total Coli.	E. Coli	Fe (mg/l)	F (mg/l)	As (mg/l)	Residual Chlorine (mg/l)	NO <sub>3</sub> (mg/l)	Type of Water Source			Distance from the nearest water source	Times of Fetching (times/week)	Diameter of Pipe (mm)	Material of Pipe	Length of Conduit (km)	Condition of Pipe		Specify for Partially Deteriorated	What is the Problem				
														3: Irrigation canal	Other	Specify for Other						2-2: Deteriorated (partially)	3: Urgent rehabilitation is required						
66	13	J-13	5.13	16	33.4	136	6	4	0.05	0.4	0.01	0.2	2	3: Irrigation canal	Yaabsh river	1.2km	not limited	425	steel	7.2	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required	50%	Lack of water in the Vaabsh conduit					
67	14	J-14												3: Irrigation canal		0.3km	not limited	273	steel	0.2	1: No problem								
68	1	N-03	8.3	16	33.4	106	1	1	0.05	0.4	<0.2	0.2	1	3: Irrigation canal		0.4km	2	76	steel	0.03	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		No operator					
68	2	N-01	9	16	33.4	166	1	1	0.05	0.4	<0.2	0.2	1	3: Irrigation canal		0.5km	2	273	steel	0.7	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrept facility					
70	3	N-02												3: Irrigation canal		0.3km	3	76	steel	3.5	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Corroded conduit					



Water Supply System Data Base

Serial No.	File No.	WSS ID	B-9 Water Quality													B-10 Availability of alternative water sources, if operation of water supply service is seasonal or service is stopping.				C-1 to C-4					
			Water Quality													Type of Water Source	Specify for Other	Distance from nearest water source	Times of Fetching (linearity)	Diameter of Pipe (mm)	Material of Pipe	Length of Conduit (km)	Condition of Pipe	Specify for Partially Deteriorated	What is the Problem
			pH	Temperature (°C)	EC (mS/cm)	TDS (mg/l)	Total Coll.	E. Coli	Fe (mg/l)	F (mg/l)	As (mg/l)	Radical Chlorine (mg/l)	NO <sub>3</sub> (mg/l)												
77	7	P-04	9	16	33.4	166	1	1	0.05	0.4	<0.2	<0.2	<1	2: Groundwater	not limited	150	steel	0.5	1: No problem						
78	8	P-07	9	16	35.4	166	1	1	0.05	0.4	<0.2	0.2	1	2: Groundwater 3: Irrigation canal	not limited	150	steel	0.01	1: No problem						
79	9	P-08	9	16	33.4	166	1	1	0.05	0.4	<0.2	0.2	1	2: Groundwater											
80	10	P-10	5-8	17	37.4	177	1	1	<0.4	0.4	<0.2	<0.2	<2			219-273	steel	0.8	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required						
81	11	P-13												2: Groundwater	not limited	150	steel	0.15	1: No problem						

Water Supply System Data Base

Site No.	File No.	WSS ID	B-9 Water Quality										B-10 Availability of alternative water sources, if operation of water supply service is seasonal or service is stopping.				C-1 Diameter of Pipe (mm)				C-2 Material of Pipe	C-3 Length of Conduit (km)	C-4 Condition of Pipe		Specify for Partially Deteriorated	What is the Problem				
			pH	Temperature (°C)	EC (mS/m)	TDS (mg/l)	Total Col.	E. Coli	Fe (mg/l)	F (mg/l)	As (mg/l)	Residual Chlorine (mg/l)	NO <sub>3</sub> (mg/l)	Type of Water Source	Specify for Other	Distance from the nearest water source	Times of Freeding (frequency)	Diameter of Pipe (mm)	Material of Pipe	Length of Conduit (km)	Condition of Pipe	Condition of Pipe								
82	12	P-18																	2: Groundwater		not limited	150	steel	0.15	1: No problem					
83	13	P-11																	2: Groundwater			150	steel	0.01	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required			Decrepit facility	
84	14	P-01																	2: Groundwater		not limited									
85	15	P-14																	3: Irrigation canal		not limited	100	steel	0.05	1: No problem					
86	16	P-12																	3: Irrigation canal		not limited	114	steel	0.08	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required			Decrepit facility	
87	1	Q-01	8.4	18	33.4	154	1	1	0.5	0.4	<0.2	<1						3: Irrigation canal	0.1km	3	250	steel	0.1	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required			Decrepit facility		
88	2	Q-02																	3: Irrigation canal	0.5km	not limited				2-2: Deteriorated (partially)	3: Urgent rehabilitation is required			No pump is installed and problem of conduit network	

Water Supply System Data Base

Saline No.	File No.	WSS ID	B-9 Water Quality											B-10 Availability of alternative water sources, if operation of water supply service is seasonal or service is stopping.				C-1 Diameter of Pipe (mm)				C-2 Material of Pipe	C-3 Length of Conduit (km)	C-4 Condition of Pipe		Specify for Partially Deteriorated	What is the Problem					
			pH	Temperature (°C)	EC (mS/m)	TDS (mg/l)	Total Coli	E Coli	Fe (mg/l)	F (mg/l)	As (mg/l)	Residual Chlorine (mg/l)	NO <sub>3</sub> (mg/l)	Type of Water Source	Specify for Other	Distance from the nearest water source	Times of water Fetching (times/day)	Diameter of Pipe (mm)	Material of Pipe	Length of Conduit (km)	Condition of Pipe	Condition of Pipe										
																							Distance from the nearest water source	Times of water Fetching (times/day)								
69	3	Q-08										3: Irrigation canal		0.8km	not limited																	
90	4	Q-03										3: Irrigation canal		0.7km	not limited																	
91	5	Q-07										3: Irrigation canal		0.7km	not limited																	
92	6	Q-08										3: Irrigation canal		0.8km	not limited			425	steel	2.2	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required										No operator
93	7	Q-04										3: Irrigation canal		0.7km	not limited			225	steel	0.22	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required										Destruct facility







Water Supply System Data Base

Site No	File No	WSS ID	C-5				Coordinates			D. Reservoir				E. Chlorination System								
			Valve			Other	Latitude N	Longitude E	altitude (m)	Capacity (m <sup>3</sup> )	Material of Reservoir	Specify for Other	Water Level		Condition of Reservoir	Specify for Partially Deteriorated	What is the Problem	E-1 Facility	E-2 Aged Used for Chlorination	F-1 Diameter of Pipe (mm)	F-2 Material of Pipe	F-3 Distance of Water Line (km)
			Silico Valve	Check Valve	Air Valve								High Water Level (m)	Low Water Level (m)								
1	1	K-10	4p-d 150 mm	2p-d 150 mm	2p-d 50 mm	1p x 2.3 m dia 1.5 m	37°10.724	108°11.320	374	1000	1. Concrete		4.8	0.5	1. No problem		2. Not installed		200	Steel	0.32	
2	2	K-08															2. Not installed					
3	3	K-03	2p-d 100 mm	1p-d 100 mm																		
4	4	K-09															2. Not installed					
5	5	K-12	2p-d 100 mm 2p-d 150 mm	1p-d 150 mm	1p-d 25 mm												2. Not installed					
6	6	K-02	3p-d 80mm	1p-d 80mm																	1. Installed Chloride time	
7	7	K-05	4p-d 150 mm	2p-d 150 mm	1p-d 25 mm	Valve: 3p-d 20 mm	37°04.716	068°08.223	348	40	2. Steel	6	0.2	1. No problem								



Water Supply System Data Base

Field No.	File No.	WSS ID	C-5 Valve				Coordinates			D. Reservoir				E. Chlorination System				F-3 Distance of Water Line (km)						
			Sluice Valve	Check Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (m)	Capacity (m <sup>3</sup> )	Material of Reservoir	Specify for Other	D-3 Water Level		Condition of Reservoir	Specify for Particular Deteriorated	What is the Problem		E-1 Facility	E-2 Agent Used for Chlorination	F-1 Diameter of Pipe (mm)	F-2 Material of Pipe		
													High Water Level (m)	Low Water Level (m)										
16	2	R-06	2p-d 150 mm	2p-d 150 mm			37°35.848	068°30.277	370	60	1: Concrete	2.3	0.3	1: No problem		2: Not installed								
17	3	R-04																						
18	4	R-05					37°30.027	068°30.367	374	2000 (2p)	1: Concrete	4	0.7	1: No problem		1: Installed	chlorine lime							
18	5	R-38														2: Not installed								
20	6	R-32																						
21	7	R-07																						

Water Supply System Data Base

Serial No	Station No	WSSM	D. Reservoir										E. Chlorination System							
			Coordinates			Capacity (m <sup>3</sup> )	Material of Reservoir	Water Level		Specify for Partially Deteriorated	What is the Problem	E-1 Facility	E-2 Agent Used for Chlorination	F-1 Diameter of Pipe (mm)	F-2 Material of Pipe	F-3 Distance of Water Line (km)				
			Latitude N	Longitude E	Altitude (m)			High Water Level (m)	Low Water Level (m)											
C-5 Valve			D-1		D-2		D-3		D-4		E-1		E-2		F-1		F-2		F-3	
Sluice Valve	Check Valve	Air Valve	Other																	
22	B	R-08	2p-d 400 mm	4p-d 200 mm	4p-d 25 mm		37°28.631	068°37.888	384	500	1: Concrete	3.8	0.5	1: No problem		1: installed	Chloride of lime	325	Steel	0.02
23		R-09																		
24		R-27	2p-d 150 mm		1p-d 20 mm		37°38.323	068°37.361	369	1000	1: Concrete	3.8	0.5	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		2: Not installed		150	Steel	0.1
25		R-10																		
26		R-11														2: Not installed				
27		R-13																		
28		R-14														2: Not installed				

Water Supply System Data Base

Serial No.	T.S. No.	W.S.A. ID	C-5				Coordinates			D, Reservoir				E, Chlorination System			F-3		
			Valve			Capacity (m <sup>3</sup> )	Material of Reservoir	Specify for Other Reservoir	Water Level		Condition of Reservoir	Specify for Partially Deteriorated	What is the Problem	E-1 Facility	Agent Used for Chlorination	F-1 Diameter of Pipe (mm)		F-2 Material of Pipe	
			Sluice Valve	Check Valve	Air Valve				Other	Latitude N									Longitude E
29	15	R-26																	
30	18	R-12													2: Not installed				
31	17	R-29																	
32	18	R-15													2: Not installed				
33	19	R-30																	
34	20	R-33													2: Not installed				
35	21	R-01																	
36	22	R-18													2: Not installed				



Water Supply System Data Base

Serial No.	File No.	WSS ID	D. Reservoir										E. Chlorination System										
			C-5 Valve			Coordinates			D-1 Capacity (m <sup>3</sup> )	D-2 Material of Reservoir	D-3 Water Level		D-4 Condition of Reservoir	Specify for Partially Deteriorated	What is the Problem	E-1 Facility	E-2 Agent Used for Chlorination	F-1 Diameter of Pipe (mm)	F-2 Material of Pipe	F-3 Distance of Water Line (km)			
			Sluice Valve	Check Valve	Air Valve	Other	Latitude N	Longitude E			Altitude (m)	High Water Level (m)									Low Water Level (m)		
43	29	R-02																					
44	30	R-23																					
45	31	R-22	11p-d 150 mm, 4p-d 200 mm, 8p-d 100 mm	4p-d 150 mm	4p-d 25 mm	Pit: 6 mts d 1.5 m		37°30.532	068°38.848	568	500	1: Concrete	3.5	0.5	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required								
46	32	R-24																					
47	33	R-39																					
48	34	R-03																					

Water Supply System Data Base

Serial No.	File No.	WSS ID	C-5 Valve				Coordinates			D-1				D-2		D-3		D-4		E. Chlorination System			F-3		
			Sluice Valve	Check Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (m)	Capacity (m <sup>3</sup> )	Material of Reservoir	Specify for Other	Water Level		Condition of Reservoir	Specify for Partially Deteriorated	What is the Problem	E-1 Facility	E-2 Agent Used for Chlorination	F-1 Diameter of Pipe (mm)	F-2 Material of Pipe				
													High Water Level (m)	Low Water Level (m)											
49	35	R-36																							
50	36	R-25																							
51	37	R-35																							
52	39	R-31	4p-ø800 mm	4p-ø300mm	2p-ø25mm	Valve 3p-ø25mm		37°30.502	068°36.848	372	2000 (7p)	1: Concrete	5	0.6	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Leakage of the reservoir and clogged pipe (ø800mm)	1: Installed	chloride of lime	720	steel		0.09	

Water Supply System Data Base

Serial No.	File No.	WSS ID	C-5 Valve			Coordinates			D-1 Capacity (m <sup>3</sup> )				D-2 Material of Reservoir		D-3 Water Level		D-4 Condition of Reservoir		Specify for Partially Deteriorated		What is the Problem		E-1 Facility		E-2 Agent Used for Chlorination		F-1 Diameter of Pipe (mm)	F-2 Material of Pipe	F-3 Distance of Water Line (km)
			Silcock Valve	Check Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (m)	Capacity (m <sup>3</sup> )	Material of Reservoir	Specify for Other	Water Level		Condition of Reservoir	Specify for Partially Deteriorated	What is the Problem		E-1 Facility	Agent Used for Chlorination	Diameter of Pipe (mm)	Material of Pipe	Distance of Water Line (km)						
													High Water Level (m)	Low Water Level (m)			High Water Level (m)	Low Water Level (m)											
53	39	R-26	3p-d150mm, 3p-d200mm		2p-d22mm	PH: 348-d1.5m		37°30.001	089°38.034	373	500 (2P)	1: Concrete	3.6	0.5	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required	Decrepit reservoir	2: Not installed		150	steel	0.14							
54	1	J-02															2: Not installed		80	steel	0.6								
55	2	J-01	2 P- d 150 mm		1 P- d 32 mm												2: Not installed												
56	3	J-03															2: Not installed												
57	4	J-04															2: Not installed												
58	5	J-05	4 pcs-d 100 mm, 2 pcs-d150 mm														2: Not installed												



Water Supply System Data Base

Site No	F# No	WSS ID	C-5 Valve				Coordinates			D. Reservoir				E. Chlorination System										
			Sluice Valve	Check Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (m)	Capacity (m <sup>3</sup> )	Material of Reservoir	Specify for Other	D-3 Water Level		Condition of Reservoir	Specify for Partially Deteriorated	What is the Problem	E-1 Facility	E-2 Agent Used for Chlorination	F-1 Diameter of Pipe (mm)	F-2 Material of Pipe	F-3 Distance of Water Line (km)		
													High Water Level (m)	Low Water Level (m)										
66	13	J-13	1p-d 400mm, 2p-d 300 mm		2p-d 25 mm			37°52.156	068°28.265	358	500	1: Concrete		3.6	0.3	1: No problem		2: Not installed						
67	14	J-14	5p-d 250 mm			Pit 3p-d 1.5m		37°29.373	068°24.678	357	1000	1: Concrete		3.5	0.5	1: No problem		2: Not installed		200	Steel	0.025		
68	1	N-03	2p-d 80 mm		2p-d 50 mm	Pit 2 kts d 1.5 m												2: Not installed						
69	2	N-01	0p-d 150 mm		3p-d 150 mm	Pit 3 kts d 1.5 m		37°17.285	068°02.550	398	500	1: Concrete		3.4	0.3	1: No problem		1: installed	chloride of lime	273	steel	120		
70	3	N-02	3p-d 80 mm		1p-d 80 mm													2: Not installed						

Water Supply System Data Base

Serial No.	File No.	WSS ID	C-5 Valve				Coordinates			D. Reservoir				E. Chlorination System											
			Sluice Valve	Check Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (m)	Capacity (m <sup>3</sup> )	Material of Reservoir	Specify for Other	D-3 Water Level		Condition of Reservoir	Specify for Partly Deteriorated	What is the Problem	E-1 Facility	Agent Used for Chlorination	F-1 Diameter of Pipe (mm)	F-2 Material of Pipe	F-3 Distance of Water Line (km)			
													High Water Level (m)	Low Water Level (m)											
71	1	P-15																	100	steel	0.08				
72	2	P-05	2p-d 100 mm, 2p-d 150 mm	1p-d 150 mm	1p-d 20 mm	Pk: 2 kha d 1.5 m																			
73	3	P-02	2p-d 100 mm	1p-d 100 mm	1p-d 25 mm																				
74	4	P-08	8p-d 100 mm, 8p-d 150 mm																						
75	5	P-09	4p-d 100 mm, 4p-d 150 mm	2p-d 150 mm	2p-d 25 mm																				
76	6	P-03	2p-d 150 mm, 3p-d 100 mm	1p-d 150 mm	1p-d 20 mm																				







Water Supply System Data Base

Serial No.	File No.	WSS ID	C-5 Valve			Coordinates			D. Reservoir				E. Chlorination System				F-2	F-3						
			Sluice Valve	Check Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (m)	Capacity (m <sup>3</sup> )	Material of Reservoir	Specify for Partially Deteriorated	What is the Problem	E-1 Facility	Agent Used for Chlorination	E-1			E-2					
																				D-1	D-2	D-3 Water Level		D-4
94	6	Q-05	2p-d 200mm		4pos-d 50mm		37°24' 155	068°39' 285	378	500 (2pos)	1: Concrete		3.5	0.5	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required	Necessary to repair the reservoir capacity. 500m <sup>3</sup> No. 1 and No.2	2: Not installed		210	steel	0.1		
95	1	S-03	7p-d 50 mm, 5p-d 100 mm, 2p-d 150 mm															2: Not installed						
96	2	S-07																		159	steel	0.3		
97	3	S-02																						
98	4	S-04																						
99	5	S-08					37°15' 414	068°06' 445	359	100	1: Concrete		3.2	0.3	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required	Oversepit facility	2: Not installed						
100	6	S-05	2p-d 300 mm, 3p-d 150 mm																					
101	7	S-08	2p-d 150 mm, 2p-d 100 mm																					

Water Supply System Data Base

ID	D. Reservoir										E. Chlorination System										
	C-5			Coordinates			D-1	D-2	D-3		D-4	What is the Problem	E-1	E-2	F-1	F-2	F-3				
	Sluice Valve	Check Valve	Air Valve	Other	Latitude N	Longitude E			Altitude (m)	Capacity (m <sup>3</sup> )								Material of Reservoir	Specify for Other	High Water Level (m)	Low Water Level (m)
102	8	S-10												2: Not installed							
103	9	S-01												2: Not installed		159	steel	7.5			
104	10	S-06	3p-d 250 mm	3p-d 25 mm	3p-d 20 mm		37°45.810	068°56.295	363	2000	1: Concrete		4.8	0.5	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required	Not operating	2: Not installed	425	steel	0.25
105	1	V-01												2: Not installed							
106	2	V-05	4p-d 200 mm				37°48.317	068°52.094	434	500	1: Concrete		3.8	0.5	1: No problem			1: Installed	219	steel	0.022
107	3	V-02	2p-d 200 mm	2p-d 200 mm	1p-d 25 mm	Valve 2p-d 100 mm	37°48.377	068°52.714	439	500	1: Concrete		2.8	0.5	1: No problem			1: Installed	200	steel	0.085
108	4	V-03	2p-d 150 mm	1p-d 150 mm	1p-d 25 mm		37°48.210	068°52.575	431	500	1: Concrete		3.8	0.5	1: No problem			1: Installed	150	steel	0.3
109	5	V-04	2p-d 200 mm				37°48.421	068°51.521	443	1000	1: Concrete		3.8	0.5	1: No problem			1: Installed	219	steel	0.022
110	6	V-06												2: Not installed							
111	7	V-07												1: Installed							
112	8	V-08	2p-d 500 mm	2p-d 50 mm	1p-d 25 mm		37°45.738	068°52.253	443	500	1: Concrete		3.6	0.5	1: No problem			1: Installed	325	steel	0.9
113	9	V-09					37°42.655	068°51.132	438	500	1: Concrete		3.8	0.5	1: No problem			1: Installed	325	steel	0.01



Water Supply System Data Base

Aqueduct, Transmission, Tank, Distribution, etc.																		
F. Transmission line (water line from reservoir to distribution tank)																		
Serial No.	File No.	WSS ID	F-4		F-5			Coordinates			G. Distribution Tank							
			Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	Silice Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (m)	Type	Capacity (m <sup>3</sup> )	Material of Tank	Specify for Other	Condition of Reservoir		
1	K-10		1: No problem			4p-d 200 mm	3p-d 32 mm	P4, 4 lbs d 1.0 m		37°18.724	068°11.320	380	1: Elevated	25	2: Steel		2-2: Deteriorated (partially)	3: Urgent rehabilitation is required
2	K-08									37°24.252	068°10.983	402	1: Elevated	25	2: Steel		1: No problem	
3	K-03									37°24.252	068°10.982	398	1: Elevated	25	2: Steel		2-2: Deteriorated (partially)	3: Urgent rehabilitation is required
4	K-09									37°28.218	068°09.992	410	1: Elevated	25	2: Steel		2-2: Deteriorated (partially)	3: Urgent rehabilitation is required
5	K-12									37°25.457	068°11.343	426	1: Elevated	25	2: Steel		2-2: Deteriorated (partially)	3: Urgent rehabilitation is required
6	K-02												1: Elevated	25	2: Steel		2-2: Deteriorated (partially)	3: Urgent rehabilitation is required
7	K-05									37°04.554	068°07.098	341	1: Elevated	40	2: Steel		1: No problem	

Water Supply System Data Base

Serial No.	File No.	WSS ID	F. Transmission line (water line from reservoir to distribution tank)				F-3 Valve			Coordinates			G. Distribution Tank					
			F-4		What is the Problem	Subs Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (ft)	Type	Specify for Other	Capacity (m <sup>3</sup> )	Material of Tank	Specify for Other	Condition of Reservoir	
			Condition of Pipe	Specify for Partially Deteriorated														
8	8	K-01																
9	9	K-14								37°20.101	088°12.001	379	1: Elevated		20	2: Steel		1: No problem
10	10	K-06								37°20.300	088°01.003	380	1: Elevated		25	2: Steel		2.2: Deteriorated (partially) 3: Urgent rehabilitation is required
11	11	K-04																
12	12	K-13								37°11.474	088°13.003	372	1: Elevated		25	2: Steel		1: No problem
13	13	K-11																
14	14	K-07								37°11.690	088°12.838	380	1: Elevated		25	2: Steel		1: No problem
15	1	R-37																

Water Supply System Data Base

F. Transmission line (water line from reservoir to distribution tank)												G. Distribution Tank								
Serial No.	File No.	WSS ID	F-4			F-5			Coordinates			G-1		G-2	G-3	G-4				
			Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	Sluice Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (m)	Type	Specify for Other	Capacity (m <sup>3</sup> )	Material of Tank	Specify for Other	Condition of Reservoir			
16	2	R-06																		
17	3	R-04																		
18	4	R-05																		
19	5	R-38																		
20	6	R-32																		
21	7	R-07																		

Water Supply System Data Base

F. Transmission line (water line from reservoir to distribution tank)										G. Distribution Tank							
Serial No.	File No.	WSS ID	F-4		What is the Problem	F-5 Valve			Coordinates			G-1		G-2	G-3	G-4	
			Condition of Pipe	Specify for Partially Deteriorated		Sluice Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (m)	Type	Specify for Other				Capacity (m <sup>3</sup> )
22	6	R-08	1: No problem			4p-d 300 mm	4p-d 25 mm										
23	9	R-09															
24	10	R-27	2-2: Deteriorated (partially)		3: Urgent rehabilitation is required	4p-d 150 mm	2p-d 32 mm										
25	11	R-10															
26	12	R-11															
27	13	R-13															
28	14	R-14															

Water Supply System Data Base

F. Transmission line (water line from reservoir to distribution tank)										G. Distribution Tank							
Serial No.	Tie No.	WSS ID	F-4		What is the Problem	F-5 Valve			Coordinates			G-1		G-2	G-3	G-4	
			Condition of Pipe	Specify for Partially Deteriorated		Subs Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (m)	Type	Specify for Other				Capacity (m <sup>3</sup> )
29	15	R-28															
30	16	R-12															
31	17	R-29															
32	18	R-15															
33	19	R-30															
34	20	R-33															
35	21	R-01															
36	22	R-16															

Water Supply System Data Base

F. Transmission line (water line from reservoir to distribution tank)										G. Distribution Tank									
Serial No.	File No.	WSS ID	F-4		F-5			Coordinates			G-1		G-2		G-3		G-4		
			Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	Sluice Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (m)	Type	Specify for Other	Capacity (m <sup>3</sup> )	Material of Tank	Specify for Other	Condition of Reservoir		
37	23	R-17																	
38	24	R-18																	
39	25	R-19	2.2: Deteriorated (partially) 3: Urgent rehabilitation is required		Corroded conduit	2p-d 200 mm 3p-d 100 mm					37°36.295	069°38.893	380	1: Elevated		25	2: Steel		2.2: Deteriorated (partially) 3: Urgent rehabilitation is required
40	26	R-20																	
41	27	R-34																	
42	28	R-21	1: No problem			2p-d 100 mm 1p-d 25 mm					37°36.095	069°38.324	379	1: Elevated		25	2: Steel		1: No problem

Water Supply System Data Base

Serial No.	File No.	WSS ID	F. Transmission line (water line from reservoir to distribution tank)				F-5 Valve			Coordinates			G. Distribution Tank					
			F-4		What is the Problem	Sluice Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (m)	Type	Specify for Other	Capacity (m <sup>3</sup> )	Material of Tank	Specify for Other	Condition of Reservoir	
			Condition of Pipe	Specify for Partially Deteriorated														
43	29	R-02																
44	30	R-23																
45	31	R-22	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrept facility (using since 1902)	40-4 150 mm, 4pcd 200 mm	40-4 32 mm	Pfc: 2 kits 6 1.5 m										
46	32	R-24																
47	33	R-38																
48	34	R-03																

### Water Supply System Data Base

F. Transmission line (water line from reservoir to distribution tank)										G. Distribution Tank									
Serial No.	File No.	WSS ID	F-4			F-5			G-1			G-2	G-3	Condition of Reservoir					
			Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	Sluice Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (m)	Type	Capacity (m <sup>3</sup> )		Material of Tank	Specify for Other			
49	35	R-38																	
50	36	R-25																	
51	37	R-35																	
52	38	R-31	No problem				4p-d800 mm	2p-d25mm	PIE. 5ht. -02.0m										

Water Supply System Data Base

F. Transmission line (water line from reservoir to distribution tank)										G. Distribution Tank							
Serial No.	File No.	WSS ID	F-4		What is the Problem	F-5 Valve			Coordinates			G-1	G-2	G-3	G-4		
			Condition of Pipe	Specify for Partially Deteriorated		Suction Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (m)					Type	Capacity (m <sup>3</sup> )
53	R-26		3: Urgent rehabilitation is required		Decrept reservoir	2p-d10mm 4p-d150mm	2p-d25mm	Plus: 30x-d1.5m		37°30.001	089°38.634	983	1: Elevated	50	2: Steel	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required
54	J-02																
55	J-01																
56	J-03																
57	J-04																
58	J-05																

Water Supply System Data Base

Serial No.	Tie No.	WSS ID	F. Transmission line (water line from reservoir to distribution tank)				G. Distribution Tank											
			F-4		What is the Problem	F-5 Valve		Coordinates		G-1	G-2	G-3	G-4					
			Condition of Pipe	Specify for Partially Deteriorated		Sluice Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (m)	Type	Capacity (m <sup>3</sup> )	Material of Tank	Specify for Other	Condition of Reservoir		
59	6	J-06																
60	7	J-07	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Maintenance of the conduit and wells, replacement of taps and install reservoir (500m3) are necessary	2pc- d100mm, 2pc- d150mm, 2pc- d200mm	2 pc-d 50 mm			37°30.545	068°32.112	359	1: Elevated	50	2: Steel	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required	
61	8	J-09	1: No problem			4pc-200 mm, 6pc-150mm	2p-d20mm	valve: 4p-d150 mm, check valve 4p-d150mm										
62	9	J-10																
63	10	J-08																
64	11	J-11																
65	12	J-12	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decept facility	2 pc-d 150 mm	2 pc-d 32 mm			37°32.005	068°28.455	377	1: Elevated	50	2: Steel	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required	

Water Supply System Data Base

F. Transmission line (water line from reservoir to distribution tank)												G. Distribution Tank						
Serial No.	Tag No.	WSS ID	F-4			F-5			Coordinates			G-1		G-2	G-3		Condition of Reservoir	
			Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	Sluces Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (m)	Type	Specify for Other	Capacity (m <sup>3</sup> )	Material of Tank	Specify for Other		
66	13	J-13																
67	14	J-14	1: No problem			3p-200mm	3p-200mm	Pit. 3p-41.5mm		37°29.284	068°54.681	281	1: Elevated	50	2: Steel		1: No problem	
68	1	N-03								37°17.102	068°02.245	401	1: Elevated	25	2: Steel		1: No problem	
69	2	N-01	1: No problem			4p-d 250 mm	3p-d 25 mm											
70	3	N-02								37°16.370	068°03.705	379	1: Elevated	25	2: Steel		2-2: Deteriorated (partially)	3: Urgent rehabilitation is required

Water Supply System Data Base

F. Transmission line (water line from reservoir to distribution tank)												G. Distribution Tank				
Serial No.	File No.	WSS ID	F-4			F-5			G-1			G-2	G-3	G-4		
			Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	Stulosa Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (m)	Type	Specify for Other	Capacity (m <sup>3</sup> )	Material of Tank	Specify for Other
71	1	P-15	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Corroded conduit	2p-d 100 mm 3p - d 25 mm	PH: 204 - d 1.5 m		37°13.720	069°03.531	368	1: Elevated	25	2: Steel		2-2: Deteriorated (partially) 3: Urgent rehabilitation is required
72	2	P-05							37°12.371	069°07.946	360	1: Elevated	25	2: Steel		2-2: Deteriorated (partially) 3: Urgent rehabilitation is required
73	3	P-02							37°12.720	069°10.601	378	1: Elevated	25	2: Steel		1: No problem
74	4	P-06							37°17.320	069°03.743	349	1: Elevated	50	2: Steel		1: No problem
75	5	P-09							37°18.769	069°03.359	340	1: Elevated	50	2: Steel		2-2: Deteriorated (partially) 3: Urgent rehabilitation is required
76	6	P-03							37°18.988	069°02.401	350	1: Elevated	25	2: Steel		1: No problem

Water Supply System Data Base

Sof# No.	File No.	WSS ID	F. Transmission line (water line from reservoir to distribution tank)										G. Distribution Tank								
			P-4			P-5			Coordinates				G-1		G-2	G-3	G-4				
			Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	Sluice Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (m)	Type	Specify for Other	Capacity (m <sup>3</sup> )	Material of Tank	Specify for Other	Condition of Reservoir				
77	7	P-04										37°13.557'	08°259'	302	1: Elevated	100	2: Steel		2-2: Deteriorated (partially)		
78	8	P-07										37°10.780'	08°10.702'	376	1: Elevated	25	2: Steel		2-2: Deteriorated (partially)	3: Urgent rehabilitation is required	
79	9	P-08	3: Urgent rehabilitation is required		Decrept facility	4p-d 150 mm, 2p-d 100 mm	2p-d 32 mm			Pk. 4 kits d 1.5 mm											
80	10	P-10	3: Urgent rehabilitation is required		Decrept facility	4p-d 150 mm, 2p-d 100 mm	2p-d 32 mm			Pk. 4 kits d 1.5 mm											
81	11	P-13	2-2: Deteriorated (partially)									37°18.103'	08°17.140'	347	1: Elevated	25(2wa)	2: Steel		2-2: Deteriorated (partially)		



Water Supply System Data Base

Serial No.	File No.	WSS ID	F. Transmission line (water line from reservoir to distribution tank)				G. Distribution Tank													
			F-4		What is the Problem	F-5 Valve		Coordinates		G-1		G-3	G-4							
			Condition of Pipe	Specify for Partially Deteriorated		Air Valve	Other	Latitude N	Longitude E	Altitude (m)	Type			Specify for Other	Capacity (m <sup>3</sup> )	Material of Tank	Specify for Other	Condition of Reservoir		
89	3	Q-06																		
90	4	Q-03																		
91	5	Q-07																		
92	6	Q-09	3: Urgent rehabilitation is required		No operator	4 pc-d 300mm, 4pc-d 400mm	3 pc - d 32 mm	check valve 4p- d300 mm												
93	7	Q-04	2:2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrypt facility	8 pc-d 150 mm, 2 pc-d 200 mm	2 pc-d 50 mm	Plt. 2xlt d 1.5 m	37°20.291	069°42.201	386	1: Elevated	25 (2pc)	2: Steel	2:2: Deteriorated (partially)	3: Urgent rehabilitation is required				

Water Supply System Data Base

Serial No.	File No.	WSS ID	F. Transmission line (water line from reservoir to distribution tank)				G. Distribution Tank										
			P-4		What is the Problem	F-5 Valve		G-1		Material of Tank	Capacity (m <sup>3</sup> )	Specify for Other	Condition of Reservoir				
			Condition of Pipe	Specify for Partially Deteriorated		Sluice Valve	Air Valve	Other	Type					Specify for Other			
Coordinates		Latitude N	Longitude E	Altitude (m)													
84	8	Q-05	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Incomplete facility	6pcs-4 200mm	4pcs-4 50mm		37°24.155	069°09.265	378	1: Elevated		500 (2pcs)	2: Steel	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required
85	1	S-03							36°58.934	069°10.185	319	1: Elevated		25	2: Steel	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required
86	2	S-07	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrept facility	4pc-4 150 mm, 2pc-4 100 mm	4pc-4 25 mm		37°15.914	069°08.945	303	1: Elevated		150	2: Steel	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required
87	3	S-02							37°15.101	069°05.105	353	1: Elevated		25	2: Steel	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required
88	4	S-04							37°14.198	069°05.010	382	1: Elevated		25	2: Steel	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required
89	5	S-08															
100	8	S-06							37°23.102	069°08.108	306	1: Elevated		25	2: Steel	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required
101	7	S-08							37°12.102	069°08.202	340	1: Elevated		25	2: Steel	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required

Water Supply System Data Base

F. Transmission line (water line from reservoir to distribution tank)										G. Distribution Tank								
S# / No.	F# No.	WSS ID	F-4		What is the Problem	F-5 Valve			Coordinates			G-1		G-2	G-3	Specify for Other	Condition of Reservoir	
			Condition of Pipe	Specify for Partially Deteriorated		Sluice Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (m)	Type	Capacity (m <sup>3</sup> )					Material of Tank
102	8	S-10																
103	9	S-01	3: Urgent rehabilitation is required			5p-d 50 mm, 5p-d 100 mm, 5p-d 150 mm												
104	10	S-06	3: Urgent rehabilitation is required		Decapt facility	6p-d 200mm, 4p-d 300mm	2p-d 25mm	3p-d 25 mm			37°48.333	068°53.001	444	1: Elevated	25	2: Steel		1: No problem
105	1	V-01																
106	2	V-05	1: No problem			4p-d 210 mm	3p-d 25 mm	3p-d 25 mm										
107	3	V-02	1: No problem			4p-d 200 mm, 2p-d 150 mm, 2p-d 100 mm	3p-d 25 mm	3p-d 25 mm										
108	4	V-03	1: No problem			4p-d 150 mm	2p-d 20 mm	2p-d 20 mm										
109	5	V-04	1: No problem			4p-d 200 mm	2p-d 25 mm	2p-d 25 mm										
110	6	V-06																
111	7	V-07																
112	8	V-08	1: No problem			2p-d 300 mm												
113	9	V-09	1: No problem			3p-d 300 mm												

Water Supply System Data Base

Serial No.		F. Transmission line (water line from reservoir to distribution tank)		F-4		F-5		Coordinates			G-1		G-2	G-3		G-4		
WSS ID	FA No.	Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	Sluice Valve	Air Valve	Other	Latitude N	Longitude E	Altitude (m)	Type	Specify for Other	Capacity (m <sup>3</sup> )	Material of Tank	Specify for Other	Condition of Reservoir		
114	10	V-10																
115	11	V-12																
116	12	V-14																
117	13	V-13																
118	14	V-11																
118	15	V-15																

Water Supply System Data Base

Serial No.	File No.	WSR ID	H. Distribution Main										I. Public Tap			J-1		
			Specify for Partially Deteriorated	What is the Problem	Diameter of Pipe (mm)	H-2	H-3	Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	Air Valve	Sluice Valve	Other	Number of Taps	H-1		H-2	H-3
1	1	K-10		Decrept facility	250-100	Cast iron, steel	9.5	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required	Broken-down	8p-d 32 mm	10p-d 100 mm, 10p-d 150 mm		200	20	Steel	20-25	3: Jarmoat
2	2	K-08			114-76	Steel	8.8	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		1p-d 50 mm	2p-d 80 mm, 2p-d 100 mm	PIE 4 bits d 1.5 m	20	20	Steel	120	3: Jarmoat
3	3	K-03		Decrept facility	114-76	Steel	3.8	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required	Decrept facility	2p-d 50 mm	2p-d 80 mm, 4p-d 100 mm	PIE 8 bits d 1.0 m	24	20	Steel	20-25	3: Jarmoat
4	4	K-09		Decrept facility	150	Cast iron, steel	10.2	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required	Decrept facility	4p-d 50mm	12p-d 100 mm, 12p-d 150 mm	PIE 8 bits d 1.5 m	105	20	Steel	20-30	3: Jarmoat
5	5	K-12		Partial replacement of pipes (Ø114mm)	250	Steel	7.5	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required	Necessity of replacement of pipes	4p-d 25 mm	8p-d 200 mm 8p-d 150 mm 8p-d 100 mm		75	20	Steel	20-30	3: Jarmoat
6	6	K-02			100	Steel	2.8	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required	Decrept facility	1p-d 32 mm	4p-d 100 mm		35	20	Steel	20-25	3: Jarmoat
7	7	K-05			150	Steel	3	1: No problem			1p-d 25 mm	4p-d 150 mm		20	20	Steel	15-20	1: RWISA

Water Supply System Data Base

Serial No.	File No.	WSS ID	H. Distribution Main										I. Public Tap				Type of organization in charge for OdM	
			Specify for Partially Deteriorated	What is the Problem	H-1	H-2	H-3	H-4		H-5 Valve		Number of Taps	H-1	H-2	H-3			
					Diameter of Pipe (mm)	Material of Pipe	Total Length of Main (km)	Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	Air Valve	Sluice Valve	Other	Number of Taps	Diameter of Pipe (mm)	Material of Pipe	Mean Length of Service Line (m)	
8	8	K-01			300-150	Cast iron, steel	22	2-2: Deteriorated (partially)		Decrepit facility	8p-425 mm	4p-4300 mm, 8p-4150mm, 10p-4100mm	Pit 8 kts d 1.5 m	550	15-20	Steel	20-25	7: Other
9	9	K-14			110	PVH	0.8	1: No problem			1p-425 mm	3p-4100 mm		40	20	Steel	20-25	7: Other
10	10	K-08		Decrepit facility and no operator	158	Steel	4	2-2: Deteriorated (partially)		Decrepit facility	2p-425 mm	8p-4150 mm		75	20	Steel	30-35	3: Jamoat
11	11	K-04			100-150	Steel	3.5	2-2: Deteriorated (partially)		Decrepit facility	4p-450 mm	10p-4100 mm, 10p-4150 mm	Pit 20 kts d 1.5 m	80	20	Steel	30-35	3: Jamoat
12	12	K-13			100-150	Cast iron	12	2-2: Deteriorated (partially)		Decrepit facility	2p-425 mm	10p-4100 mm, 10p-4150 mm	Pit 10 kts d 1.5 m	200	20	Steel	25-30	3: Jamoat
13	13	K-11			100-150	Cast iron	5.4	2-2: Deteriorated (partially)		Decrepit facility	2p-432mm	10p-4100mm	Pit 20 kts d 1.5 m	200	20	Steel	30-35	3: Jamoat
14	14	K-07			100-150	Cast iron	2.8	2-2: Deteriorated (partially)		Decrepit facility	2p-432mm	2p-4100mm		22	20	Steel	25-30	3: Jamoat
15	15	R-37			100-150	Steel	3.2	2-2: Deteriorated (partially)		Decrepit facility	2p-450 mm	4p-4100 mm		75	20	Steel	25	7: Other

Water Supply System Data Base

Serial No.	File No.	WSS ID	H. Distribution Main										I. Public Tap			J-1		
			Specify for Partially Deteriorated	What is the Problem	H-1	H-2	H-3	H-4		H-4 Value			Number of Taps	I-1	I-2		I-3	Type of organization in charge for O&M
					Diameter of Pipe (mm)	Material of Pipe	Total Length of Main (km)	Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	Air Valve	Sluice Valve	Other		Diameter of Pipe (mm)	Material of Pipe	Mean Length of Service Line (m)	
18	2	R-06			76-140	Steel	1.7	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrepit facility		2p-d 100 mm, 2p-d 150 mm			20	Steel	15-20	7: Other
17	3	R-04			100-150	Cast iron, steel	5.2	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrepit facility		4p-d 150 mm, 6p-d 100 mm			65	Steel	20-30	7: Other
18	4	R-05			100-250	Cast iron, steel	17.5	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrepit facility		4p-d 650 mm, 2p-d 400 mm, 12p-d 150 mm, 14p-d 100 mm			250	Steel	15-20	7: Other
19	5	R-38			76	Steel	1.1	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrepit facility		2p-d 60 mm			15	Steel	10-15	7: Other
20	6	R-32			100	PVC	1.5	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrepit facility		2p-d 100 mm			20	Steel	25-30	7: Other
21	7	R-07			100	Steel	2.6	2-1: Deteriorated (totally) 3: Urgent rehabilitation is required		Decrepit facility		2p-d 100 mm			20	Steel	15-20	5: Kolhoz

Water Supply System Data Base

Serial No.	File No.	WSS ID	H. Distribution Main				I. Public Tap				J-1						
			What is the Problem	H-1	H-2	H-3	H-4		H-5 Valve			I-1	I-2	I-3	Type of organization in charge for O&M		
			Specify for Partially Deteriorated	Diameter of Pipe (mm)	Material of Pipe	Total Length of Main (km)	Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	Air Valve	Sluice Valve	Other	Number of Taps	Diameter of Pipe (mm)	Material of Pipe	Mean Length of Service Line (m)	
22	8	R-08		425-500	Cast iron, steel	15.6	1: No problem			4p-d 50 mm	6p-d 500 mm RU-10						1: RWISA
23	9	R-09		80-100	Polyethylene	4.8	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required	Necessity to replace 50% of the polyethylene pipe	2p-d 50 mm	4p-d 100 mm		35	20	Steel	25	1: RWISA
24	10	R-27		100-150	Cast iron, steel	4.9	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required			4p-d 150 mm, 6p-d 100 mm		12	20	Steel	15-20	5: Kolhoz
25	11	R-10		100-150	PKN and cast iron	4.2	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required	Decrepit facility	4p-d 60 mm	4p-d 100 mm, 2p-d 150 mm		30	20	Steel	20-25	5: Kolhoz
26	12	R-11		100-150	Cast iron, steel	4.8	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required	Decrepit facility	2p-d 32 mm	4p-d 100 mm, 4p-d 150 mm		30	20	Steel	20-30	5: Kolhoz
27	13	R-13		50-100	Steel	6.2	2-1: Deteriorated (totally)	3: Urgent rehabilitation is required	Decrepit facility	4p-d 25 mm	8p-d 100 mm, 4p-d 50 mm						3: Jamoat
28	14	R-14		100	Steel	5.2	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required	Decrepit facility	2p-d 25 mm	2p-d 100mm		30	20	Steel	20-25	3: Jamoat

Water Supply System Data Base

Serial No.	File No.	WSS ID	H. Distribution Main										I. Public Tap				J-1		
			Specify for Partially Deteriorated	What is the Problem	H-1	H-2	H-3	H-4		Specify for Partially Deteriorated	What is the Problem	Air Valve	Stops Valve	Other	Number of Taps	Diameter of Pipe (mm)		Material of Pipe	Mean Length of Service Line (m)
29	15	R-28			100-319	Steel	5.8	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrepit facility	4p-d32 mm	6p-d100 mm, 4p-d200 mm		85	20	Steel	20	3: Jamoat
30	16	R-12			100	Steel	1.4	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Lack of water pressure in the Vashan conduit	1p-d 25 mm	2p-d 100 mm		15	20	Steel	20-25	5: Kolhoz
31	17	R-29			100-150	Steel	5.5	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrepit facility	1p-d32 mm	2p-d 100 mm	PIE 60k-d1.5 m	25	20	Steel	15-20	3: Jamoat
32	18	R-15			100-150	Cast iron, steel	2.8	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Lack of water		4p-d 150 mm		25	20	Steel	20-30	3: Jamoat
33	19	R-30			100	Steel	1.4	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrepit facility and lack of water pressure in the Vashan conduit		3p-d 100 mm		26	20	Steel	20-25	3: Jamoat
34	20	R-33			100	Steel	2.1	1: No problem				2p-d 25 mm	5p-d 100 mm		15	20	Steel	15-20	7: Other
35	21	R-01			100-200	Cast iron, steel	4.2	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Lack of water	2p-d32 mm	6p-d100 mm, 4p-d150 mm, 4p-d200 mm	PIE 60k-d1.5 m	25	20	Steel	20-25	3: Jamoat
36	22	R-16			100-150	Cast iron, steel	1.4	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrepit facility		4p-d 100 mm, 4p-d 150 mm		18	25	Steel	10-20	3: Jamoat

Water Supply System Data Base

Site No.	File No.	VSS ID	H. Distribution Main										I. Public Tap			Type of organization in charge for O&M			
			What is the Problem	Specify for Partially Deteriorated	H-1	H-2	H-3	H-4		H-5 Valve			Number of Taps	Diameter of Pipe (mm)	Material of Pipe		Mean Length of Service Line (m)		
					Diameter of Pipe (mm)	Material of Pipe	Total Length of Main (km)	Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	Air Valve	Sluice Valve	Other						
37	23	R-17			150	Steel	0.5	2-1: Deteriorated (totally) 3: Urgent rehabilitation is required		Decrepit facility		2p-d 150 mm					7: Other		
38	24	R-18			100	Steel	1.8	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrepit facility	2p-d 25 mm	9p-d 100 mm	Pit: 60x-41.5 m		25	25	Steel	15-20	3: Jammaat
39	25	R-19			100-200	Cast iron, steel	3	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrepit facility	3p-d 100 mm	2p-d 200 mm			28	20	Steel	30	3: Jammaat
40	26	R-20	Repair leakage and paint		100	Steel	2.8	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Necessary to repair leakage, maintenance of well and replace valves	2p-d 50 mm	4p-d 100 mm			30	20	Steel	15-20	3: Jammaat
41	27	R-24			100	Cast iron	1.6	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrepit facility	1p-d 25 mm	9p-d 100 mm, 2p-d 150 mm			38	20	Steel	15-20	3: Jammaat
42	28	R-21			76-150	Steel and polystyrene	3	2-1: Deteriorated (totally) 3: Urgent rehabilitation is required		Decrepit facility	1p-d 25 mm	2p-d 150 mm			40	40	Steel	30	1: RWBA

Water Supply System Data Base

Serial No.	File No.	WSSI ID	H. Distribution Main										I. Public Tap				Type of organization to charge for DAM	
			What is the Problem	Specify for Partially Deteriorated	H-1	H-2	H-3	H-4		What is the Problem	Air Valve	Slide Valve	Other	Number of Taps	I-1	I-2		I-3
					Diameter of Pipe (mm)	Material of Pipe	Total Length of Main (km)	Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	Air Valve	Slide Valve	Other	Number of Taps	Diameter of Pipe (mm)	Material of Pipe	Mean Length of Service Line (m)	
43	29	R-02			133	Steel	2.8	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrept facility	1p-d 32 mm	1p-d 80 mm, 2p-d 100 mm		20	20	Steel	15-20	5: Kolhoz
44	30	R-23			76-100	Polyethylene	3	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrept facility	2p-d 25 mm	2p-d 80 mm		32	20	Steel	25-30	3: Jamoat
45	31	R-22			100-325	Cast iron, steel	9.7	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrept facility				185	15-20	Steel	20-25	1: RWSA
46	32	R-24			76-100	Steel	1.9	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Incomplete facility	1p-d 32 mm	2p-d 80 mm, 1p-d 100 mm	Pit 3 mbs d 1.0 m	5	20	Steel	20-25	3: Jamoat
47	33	R-39			100-200	Cast iron, steel	3.8	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrept facility		2p-d 100 mm, 2p-d 150 mm		62	20	Steel	20	5: Kolhoz
48	34	R-03			100-200	Cast iron, steel	2	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrept facility		1p-d 100 mm, 2p-d 150 mm		12	20	Steel	20-25	5: Kolhoz

Water Supply System Data Base

Serial No.	File No.	WSS ID	H. Distribution Main				I. Public Tap				Type of organization in charge for O&M							
			Specify for Partially Deteriorated	What is the Problem	H-1 Diameter of Pipe (mm)	H-2 Material of Pipe	H-3 Total Length of Main (km)	H-4 Condition of Pipe	Specify for Partially Deteriorated	What is the Problem		Air Valve	Sluice Valve	Other	Number of Taps	I-1 Diameter of Pipe (mm)	I-2 Material of Pipe	I-3 Mean Length of Service Line (m)
49	35	R-38			100	Steel	5.5	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Deseript facility	2p-d50 mm 4p-d100 mm	2p-d80 mm, 4p-d100 mm	PIL 8M-d1.0 m	120	20	Steel	20	3: Jammat
50	38	R-25			100-160	Cast iron, steel	4.5	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Deseript facility	4p-d 25 mm	6p-d 100 mm, 6p-d 150 mm	PIL 4 kts d 1.5 m	30	20	Steel	25	5: Kolibhaz
51	37	R-35			150-200	Cast iron, polyethylene	3.8	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Deseript facility	2p-d 25 mm	2p-d 200 mm	PIL 6 kts d 1.5m	75	20	Steel	20	5: Kolibhaz
52	38	R-31			530-630	Steel	78	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Comoted conduit	12p-d 50 mm	2p-d 600 mm, 8p-d 500 mm, 4p-d 400 mm, 6p-d 300 mm						1: RWGA

Water Supply System Data Base

Serial No.	File No.	WSS ID	I. Distribution Main										I. Public Tap				Type of organization in charge for O&M									
			What is the Problem	Diameter of Pipe (mm)	H-2	H-3	H-4		H-5 Valve			Number of Taps	Diameter of Pipe (mm)	H-2	H-3											
			Specify for Partially Deteriorated		Material of Pipe	Total Length of Main (km)	Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	Air Valve	Sluces Valve	Other														
53	33	R-29		Broken-down	114	Steel	3	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Comoded conduit	2p-d 52 mm 3p-d 50 mm, 5p-d 100 mm	Pit: 4 kta d 1.0 m		45	20	Steel	20-25									5: Kolhoz
54	1	J-02			100	Steel	1	2-1: Deteriorated (totaly) 3: Urgent rehabilitation is required		Broken-down	2 pcs - d 100mm			14	15	Steel	25									3: Jamoat
55	2	J-01			100-140	Steel and PVC	3.4	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrept facility	1 pcs-d 32 mm 2 pcs-d 150 mm			16	20	Steel	20									5: Kolhoz
56	3	J-03			100-150	Cast iron, steel	1.6	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrept facility	1 pcs-d 32 mm 2 pcs-d 100 mm			15	20	Steel	15									3: Jamoat
57	4	J-04			100-150	Cast iron, PVC	1.9	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrept facility	1 pcs - d 50 mm 1 pcs - d 100 mm, 2 pcs - d 150 mm			15	20	Steel	15									3: Jamoat
58	5	J-05			100-150	Cast iron	5.6	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrept facility	4 pcs - d 100 mm; 2 pcs - d 150 mm			30	20	Steel	30									5: Kolhoz

Water Supply System Data Base

Serial No.	File No.	WSS ID	H. Distribution Main										I. Public Tap			J-1		
			H-1	H-2	H-3	H-4		H-4 Valve			H-1	H-2	H-3					
			What is the Problem	Diameter of Pipe (mm)	Material of Pipe	Total Length of Main (km)	Condition of Pipe		Specify for Partially Deteriorated	What is the Problem	Air Valve	Sluice Valve	Other	Number of Taps	Diameter of Pipe (mm)	Material of Pipe	Mean Length of Service Line (m)	Type of organization in charge for O&M
59	6	J-06		100	Steel	1.4	2-1: Deteriorated (totaly)	3: Urgent rehabilitation is required		Decrepit facility and corroded conduit	1 pcs - d 50mm	2 pcs - d 100mm	Pit: d 1.5 m 2 set	10	20	Steel	20	3: Jarroat
60	7	J-07	Decrepit facility	100-150	Cast iron, PVC	2.8	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrepit facility and corroded conduit	2 pcs-d 50 mm	6 pcs-d 100mm, 6 pcs-d 150mm, 6 pcs-d 200mm		25	20	Steel	20	3: Jarroat
61	8	J-08		100-219	Cast iron, steel	10.6	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrepit facility	4p-d25mm	4p-d200mm, 6p-d150mm, 6p-d100mm		289	15-20	Steel	20-25	7: Other
62	9	J-10		100	Steel	1.6	2-1: Deteriorated (totaly)	3: Urgent rehabilitation is required		Corroded conduit		2 pcs-d 100 mm		6	15	Steel	20	3: Jarroat
63	10	J-08		100-219	Steel	1.2	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Not connected to Valhsh Conduit	2 p- d 32 mm	2 p-d 200 mm, 4 p-d100mm	Pit: 2 sets-d 1.5 m	28	20	Steel	20-25	3: Jarroat
64	11	J-11		150	Steel	2.2	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrepit facility				28	20	Steel	20	7: Other
65	12	J-12	Repair and paint the lower	100-150	Cast iron, PVC	16.8	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrepit facility	2 pcs - d 50 mm	4 pcs - d 100 mm		40	20	Steel	40	5: Kobhuz

Water Supply System Data Base

Serial No.	File No.	WSS ID	H. Distribution Main										I. Public Tap				Type of organization in charge for O&M	
			Specify for Partially Deteriorated	What is the Problem	H-1	H-2	H-3	H-4		H-5 Valve		Number of Taps	H-1	H-2	H-3			
					Diameter of Pipe (mm)	Material of Pipe	Total Length of Main (km)	Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	Air Valve	Sluice Valve	Other		Diameter of Pipe (mm)	Material of Pipe	Mean Length of Service Line (m)	
66	13	J-13			425	Steel	7.2	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Corroded conduit and salty water	2pc-d 32	2 pc-d 400 mm	PIE: 2 set d 1.5 m		20	Steel	20	1: RWASA
67	14	J-14			100-200	Steel	12.6	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required						180	15-20	Steel	50	7: Other
68	1	N-03			159	Steel	12	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrepit facility	2p-d 32 mm	2p-d 100 mm	PIE: 2 lots d 1.5 m		30	Steel	16	1: RWASA
69	2	N-01			114-273	Steel	35	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrepit facility	12p-d 32 mm	14p-d 200 mm, 9p-d 250 mm	PIE: 18 lots d 1.5 m		65	Steel	65-80	1: RWASA
70	3	N-02		Decrepit facility	100	Steel	3.5	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrepit facility		4p-d 150 mm(RU-10) 4p-d 100 mm(RU-10)			5	Steel	30-50	1: RWASA

Water Supply System Data Base

Site No	Title No	WSS ID	H. Distribution Main										I. Public Tap				Type of Organization in charge for O&M
			What is the Problem	H-1 Diameter of Pipe (mm)	H-2 Material of Pipe	H-3 Total Length of Main (km)	H-4 Condition of Pipe		Specify for Partially Deteriorated	What is the Problem	Air Valve	Sluice Valve	Other	Number of Taps	H-1 Diameter of Pipe (mm)	H-2 Material of Pipe	
71	1	P-15	Corroded conduit	100-150	Cast iron, steel	3.2	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrepit facility	2p-d 32 mm 2p-d 100 mm, 2p-d 150 mm	Pit: 4 kits d 1.5 m	45	20	Steel	20	3: Jarmoat
72	2	P-05	Repair leakage and paint	100-150	Cast iron, steel	6.5	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrepit facility	4p-d 25 mm 4p-d 100mm, 4p-d 150mm	Pit: 2 kit d 1.5 m	30	20	Steel	30	3: Jarmoat
73	3	P-02		100-150	Cast iron, steel	5.2	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrepit facility	4p-d 25 mm, 3p-d 32 mm	Pit: 1,0 m 4 kit	30	20	Steel	20	3: Jarmoat
74	4	P-06		100-150	Cast iron, steel	1.5	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrepit facility	4p-d 25 mm, 3p-d 32 mm	Pit: 9 kit d 1.5 m	60	20	Steel	40	3: Jarmoat
75	5	P-09	Decrepit facility. Necessary to repair and paint	100-150	Cast iron, steel	7	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrepit facility	4p-d 100 mm, 3p-d 150 mm	Pit: 4 kits d 1.5 m	58	20	Steel	20	3: Jarmoat
76	6	P-03		100-150	Cast iron, steel	6.5	1: No problem				4p-d 150 mm, 4p-d 100 mm	Pit: 8 kits d 1.5 m	40	20	Steel	30	3: Jarmoat

Water Supply System Data Base

Serial No.	File No.	WSSI ID	H. Distribution Main										I. Public Tap				J-1	
			What is the Problem	Diameter of Pipe (mm)	H-2	H-3	Condition of Pipe	H-4	Specify for Partially Deteriorated	What is the Problem	Air Valve	Sluice Valve	Other	Number of Taps	Diameter of Pipe (mm)	I-2		I-3
77	P-04		Decrept facility	75, 114, 150, 200	Cast iron, steel, asbestos	3.5	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrept facility	4p-d 32 mm, 2p-d 25 mm	15p-d 100mm, 12p-d 150 mm	PK 6 lit d 1.5 m	250	15-200	Steel	30-40	7: Other
78	P-07		Repair leakage and paint	100-150	Cast iron, steel	3.8	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrept facility (necessity of replacement of 40% of the pipes)	2p-d 25 mm	2p-d 100 mm, 2p-d 150 mm	PK 4 lit d 1.5 m	20	20	Steel	50	3: Jamoat
79	P-08			100-219	Steel	4.8	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrept facility	4p-d 25 mm	4p-d 150 mm, 2p-d 100 mm	PK 4 lit d 1.5 m	40	20	Steel	30	1: RWASA
80	P-10			109-129	Steel	0	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrept facility	4p-d 25 mm	4p-d 150 mm, 2p-d 100 mm	PK 4 lit d 1.5 m	40	50	Steel	120	1: RWASA
81	P-13		Decrept facility	100-150	Cast iron, steel	0	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrept facility	2p-d 50 mm	4p-d 150 mm, 4p-d 100 mm	PK 9 lit d 1.0 m	40	20	Steel	40	3: Jamoat

Water Supply System Data Base

Serial No.	File No.	WSS ID	II. Distribution Main											I. Public Tap				Type of organization in charge for O&M		
			H-1			H-2		H-3		H-4			H-5 Valve			Number of Taps	I-1 Diameter of Pipe (mm)		I-2 Material of Pipe	I-3 Mean Length of Service Line (m)
			Specify for Partially Deteriorated	What is the Problem	Diameter of Pipe (mm)	Material of Pipe	Total Length of Main (km)	Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	Air Valve	Sluice Valve	Other							
82	12 P-16		Decrept facility	100-150	Cast iron, steel	2.8	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrept facility	2p-d 50 mm 2p-d 150 mm	4p-d 100 mm, 2p-d 150 mm	PK 4 kts d 1.5 m	20	Steel	20	3: Jamoat			
83	13 P-11		Repair leakage and paint	100-150	Cast iron, steel	2.8	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Corroded conduit	1p-d 50 mm, 2p-d 100 mm	4p-d 80 mm	PK 3 kts d 1.5 m	20	Steel	20	3: Jamoat			
84	14 P-01		Decrept facility	100-150	Cast iron, steel	6.2	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrept facility	2p-d 32 mm	4p-d 100 mm	PK 2kt-d 1.5 m	40	Steel	30	3: Jamoat			
85	15 P-14			100-150	Cast iron, steel	3.8	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrept facility	1p-d 25 mm	2p-d 100mm	PK 4 kts d 1.5 m	20	Steel	15	3: Jamoat			
86	16 P-12		Decrept facility	100-150	Cast iron, steel	4.8	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrept facility	2p-d 32 mm	4p-d 50 mm, 2p-d 100 mm	PK 4 kts d 1.5 m	30	Steel	30	3: Jamoat			
87	1 Q-01		Decrept facility	100-250	Cast iron, steel	20.5	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrept facility	12p-d 432 mm	30p-d 100mm, 5p-d 250mm	PK 14p-d 1.5 m	60	Steel	15-20	7: Other			
88	2 Q-02			100	PVC	2.6	2-1: Deteriorated (totaly)			Broken-down	1p-d 32 mm	2p-d 100 mm		26	Steel	20-25	7: Other			

Water Supply System Data Base

Serial No.	File No.	WSS ID	H. Distribution Main			I. Public Tap					Type of organization in charge for O&M									
			Specify for Partially Deteriorated	What is the Problem	Diameter of Pipe (mm)	H-2	H-3	Condition of Pipe	Specify for Partially Deteriorated	What is the Problem		Air Valve	Sluice Valve	Other	Number of Taps	Diameter of Pipe (mm)	I-1	I-2	I-3	
89	3	Q-06			76-100	Cast iron, steel	6.2	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrept facility		4p-d 50mm 4p-d 100mm 6p-d 80mm	4p-d 100mm 6p-d 80mm		40	20	Steel	30	1: RWASA
90	4	Q-03			78-100	Plastic	5.2	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		No operator		23-d 32mm	4p-d 100mm, 4p-d 80mm		30	20	Steel	150	1: RWASA
91	5	Q-07			100	Plastic	2.4	1: No problem					22-d 25mm	2p-d 100mm		24	20	Steel	20-25	1: RWASA
92	6	Q-08			150-273	Steel	18.5	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		No operator		2 pc-d 32 mm 16 pc-d 250mm, 16p-d 150 mm	16 pc-d 250mm, 16p-d 150 mm		80	20	Steel	35-40	7: Other
93	7	Q-04		Decrept facility	150-225	Cast iron, steel, PVC	35	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrept facility		8 p-d 32 mm	22p-d 100 mm, 4p-d 150mm, 6p-d 200mm	16 1/4"-d 1.5 m	88	20	Steel	25-30	5: Kulliboz

Water Supply System Data Base

Serial No.	File No.	WSID	H. Distribution Main										I. Public Tap				Type of organization in charge for O&M	
			Specify for Partially Deteriorated	What is the Problem	H-1	H-2	H-3	H-4		H-5 Valve		Number of Taps	I-1	I-2	I-3			
					Diameter of Pipe (mm)	Material of Pipe	Total Length of Main (km)	Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	Air Valve	Sluice Valve	Other		Diameter of Pipe (mm)	Material of Pipe	Mean Length of Service Line (m)	
94	8	Q-05		Incomplete facility	100-150-200	Steel	7	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrepit facility	4pcs-d 50mm	4pcs-d 150mm, 6pcs-d 20mm			20	Steel	40	7: Other
95	1	S-03		Decrepit facility	150	Steel	6.5	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrepit facility					20	Steel	25-30	3: Jamoat
96	2	S-07		Decrepit facility	150-325	Steel	15.5	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrepit facility	5p-d 32 mm	15p-d 150 mm, 10p-d 100 mm			20	Steel	20-25	7: Other
97	3	S-02		Decrepit facility	114	Steel	2	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrepit facility	2p-d 25mm	9p-d 100 mm	PH, 50x-d 1.5m		20	Steel	20	3: Jamoat
98	4	S-04		Decrepit facility	150	Steel	6.3	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrepit facility		10p-d 150 mm			20	Steel	20-30	3: Jamoat
99	5	S-08			100-150	Steel	7.5	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrepit facility					15	Steel	20-30	3: Jamoat
100	6	S-05		Decrepit facility	100-300	Steel	7.5	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrepit facility					20	Steel	25-35	3: Jamoat
101	7	S-09		Decrepit facility	100-150	Steel	6.5	2-2: Deteriorated (partially) 3: Urgent rehabilitation is required		Decrepit facility		8p-d 100 mm, 4p-d 150 mm			15	Steel	30-35	2: Jamoat

Water Supply System Data Base

S. No.	File No.	WSS ID	H. Distribution Main										I. Public Tap				Type of organization in charge for O&M	
			What is the Problem	Diameter of Pipe (mm)	H-2	H-3	H-4		H-5 Valve		Number of Taps	I-1	I-2	I-3				
			Specify for Partially Deteriorated				Total Length of Main (km)	Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	Air Valve	Sluice Valve	Other					
102	8	S-10		50-150	Steel	7.5	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrepit facility	3p-d 32mm	6p-d 150 mm, 8p-d 100 mm	Pits 50kt-d 1.5m	95	20	Steel	15-20	3: Jarmaat
103	9	S-01		50-100	Steel	5.5	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Corroded conduit		5p-d 50 mm, 5p-d 100 mm		35	15	Steel	15-20	3: Jarmaat
104	10	S-06		219-400	Steel	16	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrepit facility	2p-d 32mm	10p-d 200mm, 12p-d 150mm	Pits 16kt-d 1.5m	320	15-20	Steel	15-20	7: Other
105	1	V-01		160	Cast iron and layer color	2.5	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Corroded conduit	1p-d 32mm	2p-d 150mm		32	15	Steel	20	3: Jarmaat
106	2	V-05		100-219	Steel, plastic	7.5	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrepit facility	2p-d 25 mm	3p-d 100 mm		80	15-20	Steel	30	3: Jarmaat
107	3	V-02		100-150	Cast iron, steel		1: No problem				2p-d 25 mm	4p-d 200 mm		35	15	Steel	20	3: Jarmaat
108	4	V-03		159	Steel	2.5	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Corroded conduit	1p-d 25 mm	2p-d 150 mm		28	15	Steel	25	6: Sovkhoz
109	5	V-04		100	Cast iron, steel	4.15	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Corroded conduit	2p-d 25 mm	4p-d 100 mm		65	15-20	Steel	15	1: RWUSA
110	6	V-06		100	Steel	3.5	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrepit facility	2p-d 25 mm	4p-d 100 mm		48	15	Steel	15-20	3: Jarmaat
111	7	V-07		100-160	Steel, cast iron	6.5	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Decrepit facility	6p-d 100 mm			62	15	Steel	20	1: RWUSA
112	8	V-08		219-325	Steel, cast iron	3.4	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Corroded conduit	2p-d 25 mm	2p-d 200 mm		50	15	Steel	20	1: RWUSA
113	9	V-09		530	Steel	1.2	2-2: Deteriorated (partially)	3: Urgent rehabilitation is required		Incomplete facility								1: RWUSA

Water Supply System Data Base

Serial No.	File No.	CI WSS	H. Distribution Main		H.5 Valve					I. Public Tap				Type of organization in charge for O&M		
			Specify for Partially Deteriorated	What is the Problem	Diameter of Pipe (mm)	Material of Pipe	Total Length of Main (km)	Condition of Pipe	Specify for Partially Deteriorated	What is the Problem	Air Valve	Sluice Valve	Other		Number of Taps	Diameter of Pipe (mm)
H-1	H-2	H-3	H-4	H-4	H-4	H-4	H-4	H-4	H-4	H-4	H-4	I-1	I-2	I-3	I-4	
114	10 V-10															
115	11 V-12															
116	12 V-14															
117	13 V-13															
118	14 V-11															
119	15 V-15															

Water Supply System Data Base

Serial No.	File No.	WSS ID	Specify for Other	J. Operation and Maintenance System				K-1		K-2	Name, Specification and Quantity of Facility	
				Component of Organization	Water Tariff System		Water Tariff Collection System		Problems most concerned for improvement of living conditions of the village/community			
					Tariff System	Tariff	RWSA	Operator (selected in J-1)	1st Priority			2nd Priority
1	K-10		State system	2. Commodity Charge	0.12 Somoni/m <sup>3</sup>	1. Collector			Required to install system of the disinfection for reduction number to presenting of water diseases.	not used	1. Pump ECV 10-120-65 (2bits) 2. Control panel KASVAD (2bits) 3. Y-coupler 100x60 (2pcs) 4. Steel pipe d 150mm (3.2km) 5. Steel pipe d 100mm (3.0km) 6. Steel pipe d 250mm (1.5km) 7. Steel pipe d 200mm (2.0km)	
2	K-08		State system	2. Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1. Collector			not used	not used	1. Pump ECV 8-40-125 (1bit) 2. Sluice valve d 80mm (2pcs) 3. Sluice valve d 100mm (4pcs) 4. Pit d 1.0m (6bits) 5. Check valve d 80 mm (1bit) 6. Air valve d 32mm (1pc) 7. Valve d 15mm (20pcs) 8. Polyethylene pipe d 76mm (600m) 9. Polyethylene pipe d 100mm (1.2km) 10. Steel pipe d 20mm (120m) 11. Steel pipe d 25mm (60m) 12. Steel pipe d 114mm (40m) 13. Polyethylene pipe d 150mm (2.5km)	
3	K-03		State system	2. Commodity Charge	0.12 Somoni/m <sup>3</sup>	1. Collector			Necessary to create the association water user for collection of the money and exploitations of the systems.	not used	1. Pump ECV 8-40-125 (1bit) 2. Sluice valve d 80 mm (2pcs) 3. Sluice valve d 100 mm (4pcs) 4. Air valve d 50 mm (2pcs) 5. Pipe d 20 mm (200m) 6. Pit d 1.0 m (6bits) 7. Valve d 15 mm (24pcs) 8. Polyethylene pipe d 76 mm (600m) 9. Polyethylene pipe d 100 mm (30m) 10. Check valve d 80 mm (1pc) 11. Hammer (10m) 12. Flash (0.1km)	
4	K-06		State system	2. Commodity Charge	0.12 Somoni/m <sup>3</sup>	1. Collector			Required to install the system of the disinfection of water for reduction number to diseases of the ambience of the consumer(users).	not used	1. Sluice valve d 100 mm (12bits) 2. Sluice valve d 150 mm (12bits) 3. Pump ECV 10-120-60 (2bits) 4. Steel pipe d 20 mm (1km) 5. Pit d 1.5 mm (20bits) 6. Horator (1bit) 7. Polyethylene pipe d 100 mm (3km) 8. Polyethylene pipe d 150 mm (3km) 9. Water taps (105bits)	
5	K-12		State system	1. Flat Rate	3. Somoni/month	1. Collector			Required to clean the bore hole of the area Zinali for full provision of drinking water to population	not used	1. Sluice valve d 100 mm (6pcs) 2. Sluice valve d 150 mm (6pcs) 3. Sluice valve d 200 mm (6pcs) 4. Water taps (75pcs) 5. Steel pipe d 20 mm (600m) 6. Pit d 1.5 m (12-20bits) (2bits) 7. Pump ECV 10-120-60 (2bits) 8. Polyethylene pipe d 100 mm (3km) 9. Polyethylene pipe d 200 mm (1km) 10. Polyethylene pipe d 150 mm (4km) 11. Transformer 160-10 (1bit)	
6	K-02		State system	2. Commodity Charge	0.12 Somoni/m <sup>3</sup>	1. Collector			Necessary to install the system of the disinfection water for number of the diseases	not used	1. Pump ECV 8-40-125 (1bit) 2. Pipe d 114mm (60m) 3. Water tap (20bits) 4. Heavy repair water fence (18kg)	
7	K-05		State system	2. Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1. Collector	2: Transferring		Necessary build new reservoir in centre area for spare of water capacity 2000m <sup>3</sup>	not used	1. Pump ECV 8-40-125 (2bit) 2. Control panel of the type K60/105 (2bit) 3. Pipe PVP d 100 mm (1.5km) 4. Transformer 160/10cvt (1bit) 5. Welding unit (1pc)	

Water Supply System Data Base

Serial No.	File No.	WSS ID	Specify for Other	Component of Organization	J-3 Water Tariff System		J-4 Water Tariff Collection System	J-5 Role of organizations for repairing and replacement of facilities (including expense distribution)		K-1 Problems most concerned for improvement of living conditions of the village/community		K-2 Names of agricultural chemicals used in the area	Name, Specification and Quantity of Facility
					Tariff System	Tariff		RWISA	Operator (selected in J-1)	1st Priority	2nd Priority		
8	B	K-01	GUP-KUMIK	State system	2: Commodity Charge	0.12 Somoni/m <sup>3</sup>	1: Collector		Operator	Perfect system of the disinfection of water	not used	<ol style="list-style-type: none"> <li>1. Pump ECV 40-65-120 (2kg)</li> <li>2. Siluca valve d200 mm (4pcs)</li> <li>3. Siluca valve d200 mm (6pcs)</li> <li>4. Siluca valve d100 mm (14pcs)</li> <li>5. Air valve d25 mm (8pcs)</li> <li>6. Check valve d200 mm (4pcs)</li> <li>7. Control panel type Cascade (3kbs)</li> <li>8. Transformer KTF 400/10 (1pc)</li> <li>9. Electric motor 75kw 1500ob/min (4kts)</li> <li>10. Cable APV 95x16 (120m)</li> <li>11. Full tiles iron-concrete for LET (15kts)</li> </ol>	
9	9	K-14	OVP-Kafolat	State system	1: Flat Rate	3 Somoni/month	1: Collector			necessary to produce exploitation an organization	not used	<ol style="list-style-type: none"> <li>1. Pump ECV 40-65-120 (2kg)</li> <li>2. Control panel type cascade (2kts)</li> <li>3. Siluca valve d100 mm (4pcs)</li> <li>4. Check valve (2pcs)</li> <li>5. Pipe PVP d100 mm (800m)</li> </ol>	
10	10	K-06		State system	1: Flat Rate	3 Somoni/month	1: Collector			Required to install the system of the disinfection for reduction number to infectious diseases	not used	<ol style="list-style-type: none"> <li>1. Pump ECV 6-16-125 (1pc)</li> <li>2. Polyethylene cable-10 (120m)</li> <li>3. Rack cabinet control (1pc)</li> <li>4. Siluca valve d100 mm (9pcs)</li> <li>5. Water taps d 25 mm (20pcs)</li> <li>6. Steel pipe d 100 mm (2.2km)</li> <li>7. Polyethylene pipe d 100mm (1km)</li> <li>8. Cleaning bore hole (1bkg)</li> </ol>	
11	11	K-04		State system	2: Commodity Charge	0.012 Somoni/m <sup>3</sup>	1: Collector			Required to install the system of the disinfection for reduction number to diseases	not used	<ol style="list-style-type: none"> <li>1. Pump ECV 6-40-125 (1kt)</li> <li>2. Control panel (1kt)</li> <li>3. Check valve (20pc)</li> <li>4. Water taps (160m)</li> <li>5. Steel pipe d 150 mm (160m)</li> <li>6. Steel pipe d20 mm (200m)</li> <li>7. Heavy repair pumps station building (1bldg)</li> </ol>	
12	12	K-13		State system	2: Commodity Charge	0.12 Somoni/m <sup>3</sup>	1: Collector			Required to install system of the disinfection of water for the sake of reduction number to infectious diseases	not used	<ol style="list-style-type: none"> <li>1. Pump ECV 6-40-125 (1kt)</li> <li>2. Pipe d 114 mm (180m)</li> <li>3. Water taps (20kts)</li> <li>4. Pipe d 159 mm (80m)</li> <li>5. Siluca valve d 100 mm (4pcs)</li> <li>6. Inverse valve d 100 mm (2pcs)</li> <li>7. Heavy repair pump station building (1bldg)</li> </ol>	
13	13	K-11		State system	2: Commodity Charge	0.12 Somoni/m <sup>3</sup>	1: Collector				not used	<ol style="list-style-type: none"> <li>1. Pump ECV 6-40-125 (1kt)</li> <li>2. Control panel (1kt)</li> <li>3. Check valve (1kt)</li> <li>4. Water taps d 20mm (55pcs)</li> <li>5. Pipe d 15mm (100m)</li> <li>6. Pipe d 114mm (180m)</li> <li>7. Heavy repair pumps station building (1bldg)</li> <li>8. Blumen (0.8 ton)</li> <li>9. Rubberoid (100m<sup>2</sup>)</li> </ol>	
14	14	K-07		State system	2: Commodity Charge	0.12 Somoni/m <sup>3</sup>	1: Collector			Necessary to create association water users of the drinking purpose for collection of the money and service system	not used	<ol style="list-style-type: none"> <li>1. Water taps d20 mm (22pcs)</li> <li>2. Pipe d20 mm (200m)</li> <li>3. Siluca valve d100 mm (4pcs)</li> <li>4. Siluca valve d100 mm (4kts)</li> <li>5. Pump ECV 6-40-125 (2kts)</li> <li>6. Pipe steel d114 mm (0.2km)</li> <li>7. Pipe PVP d150 mm (1.2km)</li> <li>8. Heavy repair of the building to pumping station (1bldg)</li> </ol>	
15	15	R-37	Vodobanal	State system	2: Commodity Charge	0.12 Somoni/m <sup>3</sup>	1: Collector				not used	<ol style="list-style-type: none"> <li>1. Siluca valve d100 mm (4pcs)</li> <li>2. Air valve d50 mm (2pcs)</li> <li>3. Valve d15 mm (30pcs)</li> <li>4. PR 1.5 m (4kts)</li> <li>5. Pipe steel d20 mm (250m)</li> <li>6. Pipe steel d100 mm (80m)</li> <li>7. Pipe PVP d100 mm (3.2km)</li> <li>8. Blumen (0.5ton)</li> <li>9. Cement (0.6ton)</li> </ol>	

Water Supply System Data Base

Serial No.	File No.	WSS ID	Specify for Other	Component of Organization	J-3 Water Tariff System		J-4 Water Tariff Collection System	J-5 Role of organizations for repairing and replacement of facilities (including expense distribution)		K-1 Problems most concerned for improvement of living conditions of the village/community		K-2 Names of agricultural chemicals used in the area	Name, Specification and Quantity of Facility
					Tariff System	Tariff		RWSA	Operator (selected in J-1)	1st Priority	2nd Priority		
16	R-06		Central district hospital	State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector 2: Transferring						1. Sluice valve d 150 mm (2pcs) 2. Sluice valve d 100 mm (6pcs) 3. Sluice valve d 80 mm (4pcs) 4. Valve d 15 mm (14pcs) 5. Air valve d 25 mm (1pc) 6. Check valve d 80 mm (2pcs) 7. Check valve d 100 mm (1pc) 8. Check valve d 150 mm (2pcs) 9. Steel pipe d 25 mm (200m) 10. Steel pipe d 50 mm (100m) 11. Steel pipe d 75 mm (100m) 12. Steel pipe d 114 mm (200m) 13. Steel pipe d 159 mm (200m) 14. Polyethylene pipe d 140 mm (800m) 15. Polyethylene pipe d 100 mm (300m) 16. Polyethylene pipe d 75 mm (200m) 17. Pt d 1.5 m (60m) 18. Fireman fireplug 19. Pump K 65/60 40x4, 2900l/min (114) 20. Pump 3K-3, 22x4, 1500 l/min (114) 21. Tower 25 m3 (114) 22. Brick (1700pcs) 23. Cement (80m) 24. Iron (30m) 25. Slate (60pcs) 26. Door 2,0x1,9 m (114) 27. Window 1,5x1,2 m (114)
17	R-04		Vodokanal GUP "KHMK"	State system	2: Commodity Charge	0.12 Somoni/m <sup>3</sup>	1: Collector 2: Transferring		Required to install the system of the distribution of water for reduction number to diseases	Required to conduct the rehabilitation works main water to water			1. Sluice valve d 100 mm (4pcs) 2. Air valve d 50 mm (2pcs) 3. Valve d 15 mm (30pcs) 4. Pt d 1.5 m (40m) 5. Steel pipe d 100 mm (250m) 6. Steel pipe d 150 mm (60m) 7. Polyethylene pipe d 100 mm (3,2km) 8. Cement (0.6ton) 9. Bitumen (0.5ton)
18	R-05		Vodokanal GUP "KHMK"	State system	2: Commodity Charge	0.12 Somoni/m <sup>3</sup>	1: Collector 2: Transferring		necessary to produce heavy repair of the water building	Necessary perfect system of the disinfection			1. Pump 630/50 with electric motor 75 kw 1500 l/min/min (2pcs) 2. Pump 8N/DV, 180 kw, 1500 l/min/min (2pcs) 3. Pipe d 4200 mm (4,5km) 4. Pipe d 150 mm (3,2km) 5. Sluice valve d 250 mm (9pcs) 6. Sluice valve d 200 mm (9pcs) 7. Sluice valve d 150 mm (10pcs) 8. Sluice valve d 100 mm (12pcs) 9. Check valve d 200 mm (4pcs)
19	R-36		Vodokanal GUP "KHMK"	State system	2: Commodity Charge	0.12 Somoni/m <sup>3</sup>	1: Collector 2: Transferring						1. Sluice valve d 80 mm (2pcs) 2. Air valve d 25 mm (1pc) 3. Valve d 15 mm (15pcs) 4. Pipe steel d 15 mm (100m) 5. Pt d 1.0 m (26m) 6. Pipe PPR red 100 mm (1,1km) 7. Cement (0.4ton) 8. Bitumen (0.1ton) 9. Sand Gravel (3m3)
20	R-32		Vodokanal GUP "KHMK"	State system	2: Commodity Charge	0.12 Somoni/m <sup>3</sup>	1: Collector 2: Transferring						1. Sluice valve d 100 mm (2pcs) 2. Air valve d 25 mm (1pc) 3. Valve d 20 mm (20pcs) 4. Pt d 1.5 m (26m) 5. Steel pipe d 20 mm (180m) 6. PVC Pipe d 100 mm (1,5km) 7. Engraver (3m3) 8. Cement (0.4ton) 9. Bitumen (0.4ton)
21	R-07			State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector		Required to install system of the disinfection for protection of the population from disease	Required to conduct inwardly economic rehabilitations of the networks			1. Sluice valve d 100 mm (2pcs) 2. Air valve d 50 mm (2pcs) 3. Valve d 15 mm (200m) 4. Pipe d 20 mm (200m) 5. Pt d 1 m (26m) 6. Steel pipe d 15 mm (150m) 7. Polyethylene pipe d 100 mm (2,5km) 8. Bitumen (0,2ton) 9. Cement (0,3ton)

Water Supply System Data Base

Serial No.	File No.	WSS ID	Specify for Other	Component of Organization	J-3 Water Tariff System		J-4 Water Tariff Collection System	J-5 Role of organizations for repairing and replacement of facilities (including expense distribution)		K-1 Problems most concerned for improvement of living conditions of the village/community		K-2 Names of agricultural chemicals used in the area	Name, Specification and Quantity of Facility
					Tariff System	Tariff		RWSA	Operator (selected in J-1)	1st Priority	2nd Priority		
22	6	R-08	KHREY Qumsangir	State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector 2: Transferring			The lack of water	There is a problem with electric energy	not used	1. Sluice valve d 300 mm (4pcs) 2. Sluice valve d 200 mm (6pcs) 3. Transformer 10-400 KV (100) 4. Welding unit (100)
23	9	R-09	KHREY Qumsangir	State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector 2: Transferring			There are problem with drinking water.		not used	1. Sluice valve d 100 mm (4pcs) 2. Sluice valve d 80 mm (2pcs) 3. Air valve d 50 mm (2pcs) 4. Valve d 19 mm (30pcs) 5. Valve d 20 mm (200m) 6. PVC d 1.6 m (80m) 7. Polyethylene pipe d 100 mm (2.8km) 8. Steel pipe d 114 mm (200m) 9. Steel pipe d 78 mm (80m) 10. Cement (0.5ton) 11. Bitumen (0.2ton)
24	10	R-27		Of a collective farm	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector 2: Transferring			Install system of the disinfection.	Conduct the heavy repair of the system	not used	1. Sluice valve d 600 mm (1pc) 2. Water meter, d 150 mm (1pc) 3. Sluice valve d 150 mm (4pcs) 4. Valve d 16 mm (12pcs) 5. Water taps (12pcs) 6. Pipe d 2.0 m (100m) 7. Steel pipe d 150 mm (120m) 8. Cement (3.8ton) 9. Bitumen (1.0ton) 10. Flush (40kg) 11. Sand (4m <sup>3</sup> )
25	11	R-10		Of a collective farm	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector 2: Transferring			necessary to rehabilitate Vahshabiy main pipe line from main before Uzun-2		not used	1. Sluice valve d 150 mm (2pcs) 2. Sluice valve d 100 mm (4pcs) 3. Air valve d 32 mm (2pcs) 4. Valve d 15 mm (30pcs) 5. Pipe steel d 20 mm (200m) 6. Pipe steel d 159 mm (180m) 7. Pipe steel d 114 mm (200m) 8. Pipe PVP d 100 mm (1500m) 9. PVC d 1.0 m (400) 10. Cement (0.8ton) 11. Bitumen (0.3ton)
26	12	R-11		Of the collective farm	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector 2: Transferring			Required to conduct the rehabilitation on lines dovching networks.		not used	1. Sluice valve d 150 mm (4pcs) 2. Sluice valve d 100 mm (4pcs) 3. Air valve d 32 mm (2pcs) 4. Valve d 15 mm (19pc) 5. Steel pipe d 20 mm (200m) 6. Steel pipe d 114 mm (180m) 7. Steel pipe d 159 mm (200m) 8. Steel pipe d 100 mm (10m) 9. PVC d 1.0 m (400m) 10. Bitumen (0.4ton) 11. Cement (0.8ton)
27	13	R-13		State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector 2: Transferring			The Problem with drinking water	It is Necessary rehabilitation inventory economic set.	not used	1. Sluice valve d 50 mm (4pcs) 2. Sluice valve d 100 mm (6pcs) 3. Air valve d 50 mm (4pcs) 4. Valve d 15 mm (30pcs) 5. PVC d 1.0 m (80m) 6. Steel pipe d 150 mm (300m) 7. Steel pipe d 114 mm (100m) 8. Polyethylene pipe d 100 mm (4.1km) 9. Polyethylene pipe d 50 mm (2.1km)
28	14	R-14		State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector 2: Transferring			Necessary rehabilitation inventory economic set	Necessary install system of the disinfection of water for reduction number to diseases	not used	1. Sluice valve d 100mm (2pcs) 2. Air release valve d50mm (2pcs) 3. Valve d 15 mm (30pcs) 4. Pipe steel d 150 mm (300m) 5. PVC d 1.0 m (400m) 6. Pipe PVP d 100 mm (5.2km) 7. Cover d 150mm from pipes (150m) 8. Cement (0.5ton) 9. Bitumen (0.3ton)

Water Supply System Data Base

Serial No.	File No.	ISSN	Specify for Other	Component of Organization	J-3		J-4		J-5		K-1		K-2	Names, Specification and Quantity of Facility	
					Water Tariff System		Water Tariff Collection System		Role of organizations for repairing and replacement of facilities (including expense distribution)		Problems most concerned for improvement of living conditions of the village/community				Names of agencies/clients used in the area
					Tariff System	Tariff	Water Tariff Collection System	Operator (selected in J-1)	1st Priority	2nd Priority					
29	R-28			State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector			Problem with electric power	Problem with natural gas	not used	1. Sluice valve d200 mm (4pcs) 2. Sluice valve d150 mm (2pcs) 3. Sluice valve d100 mm (2pcs) 4. Pipe steel d150 mm (18cm) 5. Pipe steel d100 mm (1.2km) 6. Pipe steel d50 mm (1.5km)		
30	R-12			State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector					not used	1. Sluice valve d 100 mm (2pcs) 2. Valve d 15 mm (15pcs) 3. Air valve d 25 mm (1pc) 4. Steel pipe d 20 mm (100m) 5. Steel pipe d 14 mm (50m) 6. Polyethylene pipe d 100 mm (1.2km) 7. Pt d 1.0 m (2kts) 8. Bitumen (0.2ton) 9. Cement (0.2ton)		
31	R-29			State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector			Excess pressure on Vahshokom pipe line		not used	1. Sluice valve d100 mm (2pcs) 2. Air valve d25 mm (15pcs) 3. Valve d15 mm (1pc) 4. Water taps (15kts) 5. Pipe PVP d100 mm (500m) 6. Pipe steel d100 mm (200m) 7. Pt d1.5 m (2kts)		
32	R-15			State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector			Required to restore the main a pipe-wira Vahshit.		not used	1. Sluice valve d 100 mm (4pcs) 2. Sluice valve d 150 mm (4pcs) 3. Air valve d 32 mm (2pcs) 4. Valve d 15 mm (100m) 5. Steel pipe d 20 mm (200m) 6. Steel pipe d 100 mm (120m) 7. Steel pipe d 150 mm (200m) 8. Bitumen (0.2ton) 9. Cement (0.3ton) 10. Bolts d 16 mm (0.1ton)		
33	R-30			State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector			Send the system to water-supply to drinking purpose in hands of the private citizen since 90% these systems in collective farm and state farm become without care		not used	1. Sluice valve d100mm (3pcs) 2. Air valve d32 mm (1pc) 3. Valve d20 mm (25pcs) 4. Water taps (25pcs) 5. Pt d 1.5 m (3kts) 6. Pipe steel d100 mm (600m) 7. Pipe d20 mm (200m)		
34	R-33		Veckanast GUP 'Yobak'	State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector			Will Provide get fast grower of water on Vahshokom pipe line		not used	1. Sluice valve d 100 mm (3pcs) 2. Air valve d 25 mm (2pcs) 3. Valve d 15 mm (15pcs) 4. Pipe d 20 mm (100m) 5. Pt d 1.0 m (3kts) 6. Pipe polyethylene d 100 mm (1.1km) 7. Steel pipe d 14 mm (80m) 8. Cement (0.3ton) 9. Bitumen (0.2ton)		
35	R-01			State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector			Necessary to conduct heavy repair Vahshis main pipe line that worked to aggregate capacity		not used	1. Sluice valve d100 mm (2pcs) 2. Sluice valve d150 mm (2pcs) 3. Sluice valve d200 mm (2pcs) 4. Air valve d32 mm (2pcs) 5. Valve d15 mm (20pcs) 6. Pipe steel d20 mm (200m) 7. Pipe steel d100 mm (150m) 8. Pipe steel d219 mm (160m) 9. Cement (2.2ton) 10. Sand (4m) 11. Bitumen (0.6ton) 12. Engineer, macadam (2m <sup>2</sup> )		
36	R-18			State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector			Required to conduct heavy repair on diverting networks	Improve Pressure of water Vahshit.	not used	1. Sluice valve d 50 mm (16pcs) 2. Sluice valve d 100 mm (2pcs) 3. Water taps (15kts) 4. Polyethylene pipe d 100 mm (0.8km) 5. Steel pipe d 100 mm (100m) 6. Steel pipe d 25 mm (100m)		

Water Supply System Data Base

Serial No.	File No.	WSS ID	Specify for Other	Component of Organization	J-3 Water Tariff System		J-4 Water Tariff Collection System	J-5 Role of organizations for repairing and replacement of facilities (including expense distribution)		K-1 Problems most concerned for improvement of living conditions of the village/community		K-2 Names of agricultural chemicals used in the area	Name, Specification and Quantity of Facility
					Tariff System	Tariff		RWSA	Operator (selected in J-1)	1st Priority	2nd Priority		
37	23	R-17	KUMO / LAM and VR TR	State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector	2: Transferring		Required to restore the lines a bore hole to main pipe line for increasing of the pressure.	not used	<ol style="list-style-type: none"> <li>Sluice valve d 150 mm (2pcs)</li> <li>Sluice valve d 200 mm (2pcs)</li> <li>Air valve d 150 mm (2pcs)</li> <li>Pump D320/50 75kw 3000 turn/min (1kt)</li> <li>Pit d 1.5 m (2pcs)</li> <li>Reservoir 1000m<sup>3</sup> (1pc)</li> <li>Steel pipe d 150 mm (0.5km)</li> </ol>	
38	24	R-18		State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector	2: Transferring		Relax pressure on Vahsh pipe line	not used	<ol style="list-style-type: none"> <li>Sluice valve d 100 mm (2pcs)</li> <li>Pipe d 100 mm (100m)</li> <li>Pipe PVP d 100 mm (500m)</li> <li>Pipe steel d 25 mm (200m)</li> <li>Water tape (20pcs)</li> </ol>	
39	25	R-19		State system	1: Flat Rate	3 Somoni/month	1: Collector		Problem with drinking water	Problem with electro energy	not used	<ol style="list-style-type: none"> <li>Sluice valve d 200 mm (6pcs)</li> <li>Sluice valve d 150 mm (6pcs)</li> <li>Sluice valve d 100 mm (6pcs)</li> <li>Air valve d 32 mm (6pcs)</li> <li>Pump D320/50 75kw 3000 turn/min (1kt)</li> <li>Valve d 15 mm (16pcs)</li> <li>Pump K-85/90 3000 turn/min (2kts)</li> <li>Pipe steel d 150 mm (0.1km)</li> <li>Pipe steel d 200 mm (1km)</li> <li>Pipe steel d 100 mm (1km)</li> <li>Pit d 1.5 m (4kts)</li> <li>Block (1000pcs)</li> <li>Cement (40m)</li> <li>Sand (10m<sup>3</sup>)</li> <li>Lime (1ton)</li> <li>Slata (80pcs)</li> <li>El. frequent illuminations (4kldg)</li> <li>Paint-and-lacquer materials (0.1ton)</li> <li>Blumen (0.8ton)</li> </ol>	
40	26	R-20		State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector		The Necessary urgent heavy repair.		not used	<ol style="list-style-type: none"> <li>Sluice valve d 150 mm (2pcs)</li> <li>Sluice valve d 100 mm (6pcs)</li> <li>Sluice valve d 80 mm (2pcs)</li> <li>Valve d 15 mm (30pcs)</li> <li>Steel pipe d 20 mm (220m)</li> <li>Pit d 1.0 m (6kts)</li> <li>Pump D 320/70 75kw 3000 turn/min (1kt)</li> <li>Bath enamel (2kts)</li> <li>Steel pipe d 114 mm (200m)</li> <li>Steel pipe d 159 mm (700m)</li> <li>Polyethylene pipe d 100 mm (700m)</li> <li>Block (200pcs)</li> <li>Cement (4m)</li> <li>Lime (2ton)</li> <li>Blumen (0.3ton)</li> <li>Paint (50kg)</li> <li>Slata SY-40 (30pcs)</li> </ol>	
41	27	R-24		State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector	2: Transferring			not used	<ol style="list-style-type: none"> <li>Sluice valve d 100 mm (2pcs)</li> <li>Air valve d 32 mm (1pc)</li> <li>Valve d 15 mm (16pcs)</li> <li>Steel pipe d 100 mm (80m)</li> <li>Steel pipe d 20 mm (180m)</li> <li>Blumen (0.4ton)</li> <li>Cement (1.5ton)</li> <li>Carpet (3kts)</li> </ol>	
42	28	R-21		State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector	2: Transferring			not used	<ol style="list-style-type: none"> <li>Sluice valve d 150 mm (2pcs)</li> <li>Sluice valve d 200 mm (2pcs)</li> <li>Water-meter d 150 mm (1pc)</li> <li>Air valve d 150 mm (2pcs)</li> <li>Pump K 85/90 3000 turn/min (1kt)</li> <li>Pump K 85/90 with the electro motor 45kw, 2900turn/min (1kt)</li> <li>Pit d 1.5 m (2kts)</li> <li>Pipe d 150 mm (1km)</li> </ol>	

Water Supply System Data Base

Serial No.	File No.	WSS ID	Specify for Other	Component of Organization	J-3		J-4		J-5		K-1		K-2	Name, Specification and Quantity of Facility
					Tariff System	Tariff	Water Tariff Collection System	Role of organizations for repairing and replacement of facilities (including expense distribution)	Operator (selected in J-1)	1st Priority	2nd Priority	Names of agricultural chemicals used in the area		
43	29	R-02		Of the collective farm	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector 2: Transferring						not used	1. Sluice valve d 50 mm (1pc) 2. Sluice valve d 100 mm (2pcs) 3. Valve d 15 mm (20pcs) 4. Steel pipe d 20 mm (100m) 5. Polyethylene pipe d 50 mm (1km) 6. Polyethylene pipe d 100 mm (1km) 7. Pit d 1.0 m (2bits)
44	30	R-23		State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector 2: Transferring						not used	1. Sluice valve d 100 mm (2pcs) 2. Sluice valve d 80 mm (2pcs) 3. Air valve d 25 mm (2pcs) 4. Valve d 15 mm (24pcs) 5. Pit d 1.0 m (8bits) 6. Polyethylene pipe d 100 mm (1.5km) 7. Polyethylene pipe d 76 mm (600m) 8. Steel pipe d 114 mm (80m) 9. Bitumen (0.2ton) 10. Cement (0.2ton) 11. Rubberoid (100m <sup>3</sup> ) 12. Spare parts for the pipes d 100 mm (20bits) 13. Spare parts for the pipes d 80 mm (20bits) 14. Water meter d 100 mm (1bit)
45	31	R-22		State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector 2: Transferring				Required to supply with the latest technology of the disinfection		not used	1. Sluice valve d 150 mm (16pcs) 2. Sluice valve d 200 mm (6pcs) 3. Sluice valve d 50 mm (4pcs) 4. Air valve d 32 mm (4pcs) 5. Pit d 1.5 m (8bits) 6. Pump ECV 6-40-125 (2bits) 7. Pump ECV 10-120-200 (2bits) 8. Pump d 322 with electric motor 75kw, 15000 turn/min (4bits) 9. Steel pipe d 150 mm (1km) 10. Steel pipe d 219 mm (0.2km) 11. Steel pipe d 133 mm (0.2km) 12. Cement (2.6ton) 13. Bitumen (2ton) 14. Rubberoid (1200m <sup>3</sup> )
46	32	R-24	Village	Jamoat	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector						not used	1. Sluice valve d 80 mm (2pcs) 2. Sluice valve d 100 mm (1pc) 3. Air valve d 32 mm (1pc) 4. Pit d 1.0 m (4pcs) 5. Valve d 15 mm (15pcs) 6. Steel pipe d 20 mm (100m) 7. Pipe d 76 mm (0.05km) 8. Steel pipe d 114 mm (80m) 9. Pipe d 100 mm (1km)
47	33	R-38		Of the collective farm	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector 2: Transferring						not used	1. Sluice valve d 200 mm (1pc) 2. Sluice valve d 100 mm (2pcs) 3. Air valve d 32 mm (2pcs) 4. Valve d 15 mm (16pcs) 5. Pit 1.0 m (2bits) 6. Steel pipe d 200 mm (100m) 7. Steel pipe d 219 mm (80m) 8. Steel pipe d 114 mm (500m) 9. Polyethylene pipe d 100 mm (1km) 10. Cement (0.5ton)
48	34	R-03		Of the collective farm	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector 2: Transferring				required to rehabilitate system divorced network		not used	1. Sluice valve d 150 mm (1pc) 2. Sluice valve d 100 mm (2pcs) 3. Air valve d 50 mm (1pc) 4. Valve d 15 mm (12pcs) 5. Steel pipe d 15 mm (100m) 6. Polyethylene pipe d 100 mm (1.4km) 7. Steel pipe d 114 mm (60m) 8. Pit d 1.0 m (2bits) 9. Cement (0.2ton) 10. Bitumen (0.1ton)

Water Supply System Data Base

Serial No.	File No.	WSS ID	Specify for Other	Component of Organization	J-3 Water Tariff System		J-4 Water Tariff Collection System	J-5 Role of organizations for repairing and replacement of facilities (including expense distribution)		K-3 Problems most concerned for improvement of living conditions of the village/community		K-2 Names of agricultural chemicals used in the area	Name, Specification and Quantity of Facility
					Tariff System	Tariff		RWASA	Operator (selected in J-1)	1st Priority	2nd Priority		
49	R-36		Kolicho, Village	State system	1: Flat Rate	3 Somoni/month	1: Collector					not used	1. Sluice valve d80 mm (2pcs) 2. Sluice valve d100 mm (4pcs) 3. Valve d100 mm (2pcs) 4. Valve d15 mm (20pcs) 5. Water meter d100 mm (1set) 6. Pipe steel d20 mm (200m) 7. Pipe PVP d100 mm (2.4km) 8. Pipe steel d114 mm (80m) 9. Pt d1.0 m (80m)
50	R-25			Of the collective farm	2: Commodity Charge	0.0251 Somoni/m3	1: Collector		It is necessary to install the system of the disinfection			not used	1. Sluice valve d 100 mm (6pcs) 2. Sluice valve d 150 mm (6pcs) 3. Air valve d 50 mm (4pcs) 4. Pt d 1.5 m (60m) 5. Pipe d 15 mm (180m) 6. Valve d 15 mm (30pcs) 7. Cement (20m) 8. Bitumen (20m) 9. Rubberoid (300m3) 10. Water-meter d 150 mm (1pc) 11. Steel pipe d 159 mm (180m) 12. Polyethylene pipe d 180 mm (11km) 13. Polyethylene pipe d 110 mm (800m) 14. Steel pipe d 114 mm (120m)
51	R-35			State system	2: Commodity Charge	0.0251 Somoni/m3	1: Collector					not used	1. Sluice valve d 150 mm (4pcs) 2. Sluice valve d 200 mm (2pcs) 3. Air valve d 50 mm (2pcs) 4. Pt d 1.5 m (200m) 5. Steel pipe d 219 mm (250m) 6. Valve d 1.0 m (80m) 7. Bitumen (0.4ton) 8. Cement (0.5ton) 9. Steel pipe d 159 mm (60m) 10. Steel pipe d 219 mm (80m) 11. Steel pipe d 114 mm (240m) 12. Polyethylene pipe d 100 mm (1km) 13. Spare parts (80m) 14. Tap d 219 mm (80m) 15. Tap 159 mm (40m) 16. Tap d 11 mm (40m) 17. Tap d 11 mm (40m) 18. Water-meter d 150 mm (1set) 19. Diesel oil (1ton) 20. Diesel fuel (0.2ton)
52	R-31			State system	2: Commodity Charge	0.0251 Somoni/m3	1: Collector		It is necessary to supply the latest technology for disinfection water			not used	1. Sluice valve d 630 mm (4pcs) 2. Shutter d 600 mm (4pcs) 3. Air valve d 50 mm (4pcs) 4. Pump DG5090 250kv/1500l/min (2sets) 5. Steel pipe d 720 mm (70m) 6. Steel pipe d 630 mm (50m) 7. Fluid glass (1ton) 8. Rubberoid (400m2) 9. Bitumen (5ton)

Water Supply System Data Base

Serial No.	File No.	WSS ID	Specify for Other	Component of Organization	J-3 Water Tariff System		J-4 Water Tariff Collection System	J-5 Role of organizations for repairing and replacement of facilities (including expense distribution)		K-1 Problems most concerned for improvement of living conditions of the village/community		K-2 Names of agricultural chemicals used in the area	Name, Specification and Quantity of Facility
					Tariff System	Tariff		RWISA	Operator (selected in J-1)	1st Priority	2nd Priority		
53	39	R-26		Of the collective farm	2: Commodity Charge	0.0251 Somoni/m3	1: Collector			Will intensity system of the presenting of water at the first water fence (which is main pipe line)	Required to install the system of the distribution of water for reduction number to diseases	not used	<ol style="list-style-type: none"> <li>1. Sluice valve d 200 mm (4pcs)</li> <li>2. Sluice valve d 150 mm (4pcs)</li> <li>3. Sluice valve d 100 mm (4pcs)</li> <li>4. Sluice valve d 50 mm (2pcs)</li> <li>5. Air valve d 32 mm (4pcs)</li> <li>6. Valve d 15 mm (20pcs)</li> <li>7. Pump NDV-8 (50V) d 50 mm/min (3kts)</li> <li>8. Measurement (100m) (11kg)</li> <li>9. Measurement building (11kg)</li> <li>10. Coat (11kg)</li> <li>11. Galas and Improvement (11kg)</li> <li>12. Pit d 1.0 m (4kts)</li> <li>13. Pit d 1.5 m (4kts)</li> <li>14. Steel pipe d 20 mm (200m)</li> <li>15. Polyethylene pipe d 100 mm (2.5km)</li> <li>16. Polyethylene pipe d 50 mm (0.5km)</li> <li>17. Steel pipe d 114 mm (80m)</li> <li>18. Steel pipe d 150 mm (140m)</li> <li>19. Steel pipe d 219 mm (600m)</li> <li>20. Rubberoid (600m)</li> <li>21. Rubber (10m)</li> <li>22. Bitumen (0.1ton)</li> <li>23. Cement (4ton)</li> <li>24. Filled glass (0.2ton)</li> </ol>
54	1	J-02	Village	State system	2: Commodity Charge	0.0251 Somoni/m3	1: Collector			There are problems with the drinking water	There are the problems with the electro-energy	not used	<ol style="list-style-type: none"> <li>1. Sluice valve d 100 mm (2pcs)</li> <li>2. Tap d 15 mm (14pcs)</li> <li>3. Pipe d 50 mm (0.8km)</li> <li>4. Pipe d 100 mm (11m)</li> </ol>
55	2	J-01		Of the collective farm	2: Commodity Charge	0.0251 Somoni/m3	1: Collector			There is a problem with electro-energy.	Steady presenting of water.	not used	<ol style="list-style-type: none"> <li>1. Sluice valve d 150 mm (2pcs)</li> <li>2. Air valve d 50 mm (1pc)</li> <li>3. Water tap d 15 mm (16pcs)</li> <li>4. Pipe d 20 mm (180m)</li> <li>5. Steel pipe d 150 mm (60m)</li> <li>6. Steel pipe d 100 mm (70m)</li> <li>7. Cement (0.2ton)</li> <li>8. Bitumen (0.1ton)</li> </ol>
56	3	J-03		State system	2: Commodity Charge	0.0251 Somoni/m3	1: Collector			There is a problem with the drinking water.		not used	<ol style="list-style-type: none"> <li>1. Sluice valve d 100 mm (2pcs)</li> <li>2. Sluice valve d 150 mm (2pcs)</li> <li>3. Water tap d 15 mm (15pcs)</li> <li>4. Air valve d 50 mm (1pc)</li> <li>5. Steel pipe d 100 mm (80m)</li> <li>6. Steel pipe d 150 mm (80m)</li> <li>7. Cement (0.5ton)</li> <li>8. Bitumen (0.3ton)</li> </ol>
57	4	J-04		State system	2: Commodity Charge	0.0251 Somoni/m3	1: Collector					not used	<ol style="list-style-type: none"> <li>1. Sluice valve d 150 mm (2pcs)</li> <li>2. Sluice valve d 100 mm (1pc)</li> <li>3. Air valve d 50 mm (1pc)</li> <li>4. Water tap d 15 mm (15pcs)</li> <li>5. Pipe d 20 mm (130m)</li> <li>6. Steel pipe d 100 mm (50m)</li> <li>7. Steel pipe d 150 mm (70m)</li> <li>8. Cement (0.8ton)</li> <li>9. Bitumen (0.4ton)</li> </ol>
58	5	J-05		State system	2: Commodity Charge	0.0251 Somoni/m3	1: Collector			lack of water	There are problems with electro-energy.	not used	<ol style="list-style-type: none"> <li>1. Sluice valve d 100 mm (4pcs)</li> <li>2. Sluice valve d 150 mm (2pcs)</li> <li>3. Water tap d 15 mm (20pcs)</li> <li>4. Air valve d 50 mm (2pcs)</li> <li>5. Steel pipe d 20 mm (300m)</li> <li>6. Bitumen (0.2ton)</li> <li>7. Cement (4ton)</li> <li>8. Steel pipe d 100 mm (120m)</li> <li>9. Steel pipe d 150 mm (180m)</li> </ol>

Water Supply System Data Base

Serial No.	File No.	WSS ID	Specify for Other	J-2		J-3		J-4		J-5		K-1		K-2	Name, Specification and Quantity of Facility
				Component of Organization	Water Tariff System	Tariff System	Tariff	Water Tariff Collection System	Role of organizations for repairing and replacement of facilities (including expense distribution)	Operator (selected in J-1)	Problems most concerned for improvement of living conditions of the village/community	1st Priority	2nd Priority		
59	8	J-06		State system	2: Commodity Charge 0.0251 Somoni/m <sup>3</sup>	1: Collector	2: Transferring					There is a problem with dripping water	There is a problem with electro-energy	not used	<ol style="list-style-type: none"> <li>1. Sluice valve d 100 mm (2pcs)</li> <li>2. Pit d 1.0 m (2sets)</li> <li>3. Air valve d 50mm (1set)</li> <li>4. Water tap d 15mm (10pcs)</li> <li>5. Water pipe d 110mm (110m)</li> <li>6. Plastic pipe d 50mm (400m)</li> <li>7. Steel pipe d 114mm (40m)</li> <li>8. Bitumen (0.1ton)</li> </ol>
60	7	J-07		State system	2: Commodity Charge 0.0251 Somoni/m <sup>3</sup>	1: Collector						There are problems with drinking water.	There are problems with the electro-energy.	not used	<ol style="list-style-type: none"> <li>1. Sluice valve d 100 mm (2pcs)</li> <li>2. Sluice valve d 150 mm (2pcs)</li> <li>3. Sluice valve d 200 mm (2pcs)</li> <li>4. Air valve d 50 mm (2pcs)</li> <li>5. Air valve d 15 mm (25pcs)</li> <li>6. Water pump D 320x50 7.5 kw, 1500 cfm (2sets)</li> <li>7. Water tank 50m<sup>3</sup> (1set)</li> <li>8. Steel pipe d 100 mm (80m)</li> <li>9. Steel pipe d 20 mm (200m)</li> <li>10. Steel pipe d 50 mm (50m)</li> <li>11. Steel pipe d 200 mm (300m)</li> <li>12. Cement (8m<sup>3</sup>)</li> <li>13. Gravel (10m<sup>3</sup>)</li> <li>14. Bitumen (2ton)</li> <li>15. Diesel fuel (3ton)</li> </ol>
61	8	J-09	Vodokanal	State system	2: Commodity Charge 0.12 Somoni/m <sup>3</sup>	1: Collector	2: Transferring					There is a problem with the quality water	There is a problem with the electro tower	not used	<ol style="list-style-type: none"> <li>1. Water gauge d 500 mm (1pc)</li> <li>2. Pipe d 150 mm (300m)</li> <li>3. Pipe d 100 mm (100m)</li> <li>4. Sluice valve d 150 mm (6pcs)</li> <li>5. Sluice valve d 100 mm (4pcs)</li> <li>6. Sluice valve d 219 mm (10pcs)</li> <li>7. Sluice valve d 300 mm (2pcs)</li> <li>8. Sluice valve d 500 mm (1pc)</li> <li>9. valve d 15-20 mm (221pcs)</li> </ol>
62	9	J-10	community of Galasa village	State system	2: Commodity Charge 0.12 Somoni/m <sup>3</sup>	1: Collector						There is a problem with shortage of water		not used	<ol style="list-style-type: none"> <li>1. Pipe d 100 mm (1.6km)</li> <li>2. Sluice valve d 100 mm (2pc)</li> <li>3. Water tap d 15 mm (6pcs)</li> </ol>
63	10	J-08		State system	2: Commodity Charge 0.0251 Somoni/m <sup>3</sup>	1: Collector						there is a problem with clean water	there is a problem with electric powers	not used	<ol style="list-style-type: none"> <li>1. Sluice valve d 200 mm (2sets)</li> <li>2. Air valve d 50 mm (2sets)</li> <li>3. Pipe bend d 219 mm (6pcs)</li> <li>4. Pit d 1.5m (2sets)</li> <li>5. Rubberoid (1000m<sup>2</sup>)</li> <li>6. Pipe d 219 mm (1.2km)</li> <li>7. Diesel fuel (2ton)</li> <li>8. Diesel fuel (2ton)</li> <li>9. Engine oil (0.1ton)</li> <li>10. Cement (1.6ton)</li> <li>11. Gravel (3m<sup>3</sup>)</li> </ol>
64	11	J-11	Vodokanal	Jamoat Dzhalilau	2: Commodity Charge 0.0251 Somoni/m <sup>3</sup>	1: Collector								not used	<ol style="list-style-type: none"> <li>1. Cason pipe d 150 mm (300m) (FRP7)</li> <li>2. Sluice valve d 150 mm (2pcs)</li> </ol>
65	12	J-12		Of the collective farm	2: Commodity Charge 0.12 Somoni/m <sup>3</sup>	1: Collector						problem with water	problem with Electric power	not used	<ol style="list-style-type: none"> <li>1. Sluice valve d 100 mm (6pcs)</li> <li>2. Sluice valve d 150 mm (6pcs)</li> <li>3. Sluice valve d 200 mm (6pcs)</li> <li>4. Air valve d 50 mm (6pcs)</li> <li>5. Water tap d 15 mm (40pcs)</li> <li>6. Pump 4 set - 12, 17 kw, 3000 cfm (3sets)</li> <li>7. Vacuum pump BBT (2sets)</li> <li>8. Electronic part (4bidg)</li> <li>9. Timber (4m<sup>3</sup>)</li> <li>10. Pit 1.0 m (6sets)</li> <li>11. Steel pipe d 20 mm (400m)</li> <li>12. Steel pipe d 50 mm (400m)</li> <li>13. Steel pipe d 119 mm (400m)</li> <li>14. Steel pipe d 114 mm (200m)</li> <li>15. Bitumen (1ton)</li> <li>16. Cement (5ton)</li> <li>17. Crushed stone (8m<sup>3</sup>)</li> <li>18. Gravel (10m<sup>3</sup>)</li> <li>19. Sand (6m<sup>3</sup>)</li> <li>20. Lime (2.4ton)</li> <li>21. Paint (60kg)</li> </ol>

Water Supply System Data Base

Serial No.	File No.	WSS ID	Specify for Other	Component of Organization	J-3 Water Tariff System		J-4 Water Tariff Collection System	J-5 Role of organizations for repairing and replacement of facilities (including expense distribution)		K-1 Problems most concerned for improvement of living conditions of the village/community		K-2 Names of agricultural chemicals used in the area	Name, Specification and Quantity of Facility
					Tariff System	Tariff		RWSA	Operator (selected in J-1)	1st Priority	2nd Priority		
66	13	J-13		State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector	2: Transferring		To improve the water supply system	It is necessary install new technology for disinfection of water for decrease of sickness	not used	<ol style="list-style-type: none"> <li>1. Silica valve d 400 mm (2pc)</li> <li>2. Air valve d 80 mm (2pc)</li> <li>3. PI 2x2 (2pc)</li> <li>4. Pipe-bend d 400 mm (8pc)</li> <li>5. Diesel fuel (6ton)</li> <li>6. Engine oil (0.3ton)</li> <li>7. Tool (2400m<sup>2</sup>)</li> <li>8. Cement (4ton)</li> <li>9. Gravel (10m<sup>3</sup>)</li> <li>10. Steel pipe d 425x9 mm (1.8km)</li> </ol>
67	14	J-14	Public water to users villages Comitem	Public	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector			To improve the water supply system: A problem with the electro energy		not used	<ol style="list-style-type: none"> <li>1. Cleaning bore holes (test tube by split method) (5pc)</li> <li>2. Pump ESV 6-40-125 (5pc)</li> <li>3. Heavy transformer 250 kVA (1pc)</li> <li>4. List of the electric transmissions 4 km AS-50 with CNTLS (22pc)</li> <li>5. RIND (insulator) (1pc)</li> <li>6. Pump (Centrifugal) Jp-K 8545 (1pc)</li> <li>7. Electro-cable (1pc)</li> <li>8. Cobaltite (1kg)</li> <li>9. Heavy repair existing transformer KTP 250/10 (1kg)</li> <li>10. Steel pipe d 200mm (1.5km)</li> <li>11. Steel pipe d 150mm (2.6km)</li> <li>12. Pipe PVC d 100mm (4.9km)</li> <li>13. Water taps (160kts)</li> <li>14. Silica valve RU-10 d 200mm (8pc)</li> <li>15. Silica valve RU-10 d 150mm (10pc)</li> <li>16. Silica valve RU-10 d 100mm (22pc)</li> <li>17. Air valve d 80 mm (10pc)</li> <li>18. PI d 100 (10)</li> <li>19. Air valve d 25mm (10pc)</li> <li>20. Power cable APV 90/30 (180m)</li> <li>21. Heavy repair of the building pump station (1bkg)</li> </ol>
68	1	N-03		State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector			Required to install system of the disinfection for reduction number to the presenting of diseases.	Required to improve the system of disinfection for reduction number to the presenting of water.	not used	<ol style="list-style-type: none"> <li>1. Silica valve d 100 mm (2pc)</li> <li>2. Air valve d 80 mm (2pc)</li> <li>3. Air valve d 32 mm (2pc)</li> <li>4. Valve d 19 mm (10pc)</li> <li>5. Steel pipe d 78 mm (100m)</li> <li>6. Steel pipe d 78 mm (100m)</li> <li>7. Steel pipe d 114 mm (40m)</li> <li>8. Steel pipe d 159 mm (2.8km)</li> <li>9. Steel pipe d 50 mm (1.2km)</li> <li>10. Cement (2ton)</li> <li>11. soda fountain VC (80pc)</li> <li>12. Hulled nuts (160m)</li> <li>13. KTP 100-04 (1kg)</li> <li>14. Blumen (0.4ton)</li> <li>15. Ruberoid (2600m<sup>2</sup>)</li> </ol>
69	2	N-01		State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector	2: Transferring		Required to supply new technology and mechanism for exploitation of the systems		not used	<ol style="list-style-type: none"> <li>1. Pump GNS 105-147 (3kts)</li> <li>2. Pump ECV 15-20-40 (2kts)</li> <li>3. Control panel (3kts)</li> <li>4. Transformer KTP 100/10 (1kg)</li> <li>5. Silica valve d 200 mm and d 150 mm (20pc)</li> <li>6. Pipe d 159 mm (150m)</li> <li>7. Pipe d 219 mm (120m)</li> <li>8. Pipe d 273 mm (700m)</li> <li>9. Polyethylene Pipe d 219 mm (10km)</li> <li>10. PI d 4.5 m (12kts)</li> <li>11. Blumen (2ton)</li> <li>12. Cement (6ton)</li> <li>13. Pipe d 20 mm (650m)</li> <li>14. Air valve d 25 mm (10pc)</li> <li>15. Back (1200pc)</li> <li>16. Paint-and-lacquer materials (0.4ton)</li> <li>17. LET AC-35 mm, AC-50 mm (3km)</li> </ol>
70	3	N-02		State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector	2: Transferring		Required to install system of the disinfection for reduction number to infectious diseases.		used against local.	<ol style="list-style-type: none"> <li>1. The tool for boring the bore hole (1kg)</li> <li>2. Install new pillars d 273 mm (80m)</li> <li>3. Deep pump (1kg)</li> <li>4. Rack controlling cabinet (1kg)</li> <li>5. Deep cable AVP-d-125 (120m)</li> <li>6. Transformation TM-100/10 (1kg)</li> <li>7. LET-10 kts Volt (600m)</li> <li>8. Welding unit 250 volt (1pc)</li> <li>9. Polyethylene pipe d 150 mm (3km)</li> </ol>

Water Supply System Data Base

Serial No.	File No.	WSS ID	Specify for Other	Component of Organization	J-3 Water Tariff System		J-4 Water Tariff Collection System	J-5 Role of organizations for repairing and replacement of facilities (including expense distribution)		K-1 Problems most concerned for improvement of living conditions of the village/community		K-2 Name of agricultural chemicals used in the area	Name, Specification and Quantity of Facility
					Tariff System	Tariff		RWSSA	Operator (selected in J-1)	1st Priority	2nd Priority		
71	1	P-15		State system	2: Commodity Charge	0.12 Somoni/m3	1: Collector			Necessary to install the system of the disinfection of water for reduction number to diseases.	Necessary to perfect the system of the presenting of water	not used	1. Sluice valve d 100mm (4pcs) 2. Sluice valve d 150mm (4pcs) 3. Air release valve d 50mm (2pcs) 4. Check valve d 100mm (2pcs) 5. Taps (20pcs) 6. Pump ECV 10-120-60 (1kt) 7. Electronic paintar-threaded type of the cascade (1bdg) 8. PR (8kts) 9. Fence netlike water fence (1bdg) 10. Pipe steel d 20mm (0.3km) 11. Pipe polyethylene d 100mm (1km) 12. Pipe polyethylene d 150mm (0.8km)
72	2	P-05		State system	2: Commodity Charge	0.12 Somoni/m3	1: Collector			Necessary to avoid the drains beside the disinfection of water for pipes and perfect the system of the presenting of water.	Necessary to install the system of reduction number to diseases.	not used	1. Sluice valve d100mm (4kts) 2. Sluice valve d150mm (4kts) 3. Air valve d50mm (2kts) 4. Water tap (2kts) 5. Pipe d100mm (300m) 6. Pipe ECV 8-40-125 (1kt) 7. Heavy repair of the branch water fence (1bdg) 8. Pipe polyethylene d100mm (2km) 9. Pipe polyethylene d150mm (1km)
73	3	P-02		State system	1: Flat Rate	2 Somoni/month	1: Collector			Necessary perfect system of the presenting of water	Necessary to install the system of the disinfection of water for reduction number to infectious diseases amongst consumers	not used	1. Sluice valve d90mm (2pcs) 2. Sluice valve d100mm (2pcs) 3. Sluice valve d150mm (4pcs) 4. Air release valve d50mm (2pcs) 5. ECV 8-40-125 (1kt) 6. Pipe d20mm (200m) 7. Rows water wire (300m) 8. Pipe polyethylene d100mm (1.2km) 9. Pipe polyethylene d150mm (1.8km)
74	4	P-06	Private		1: Flat Rate	2 Somoni/month	1: Collector			Necessary perfect system of the presenting of water		not used	1. Sluice valve d100 mm (8kts) 2. Sluice valve d150 mm (8kts) 3. Air valve d50 mm (4kts) 4. PR d 1.5m (8kts) 5. Water tap (8kts) 6. Pump ECV 10-120-60 (3kts) 7. Heavy repair to pumping station (1bdg) 8. Pipe steel d20 mm (0.38km) 9. Pipe polyethylene d100 mm (3km) 10. Pipe polyethylene d150 mm (2.5km)
75	5	P-09	State system		1: Flat Rate	3 Somoni/month	1: Collector			Necessary will install the system of the disinfection for reduction number to infectious diseases.		not used	1. Sluice valve d 100mm (4kts) 2. Sluice valve d 150mm (4kts) 3. Air valve d 50mm (2kts) 4. Check valve d 100mm (2kts) 5. Pipe steel d 20mm (200m) 6. Water tap d 20mm (30pcs) 7. Pipe PPH d 100mm (2km) 8. Pipe PPH d 140mm (2km) 9. Pipe PPH d 150mm (1km) 10. PR in 1kt d 1m (4pcs) 11. Heavy repair to pumping station. (1bdg)
76	6	P-03	State system		2: Commodity Charge	0.12 Somoni/m3	1: Collector			Necessary to install the system of the disinfection of water for reduction number to diseases.		not used	1. Sluice valve d100 mm (8kts) 2. Sluice valve d150 mm (8kts) 3. PR d 1.5m (8kts) 4. ECV 8-40-125 (1kt) 5. Pipe d20mm (300m) 6. Water tap (4kts) 7. Pipe polyethylene d100 mm (2km) 8. Pipe polyethylene d150 mm (1.2km) 9. Heavy repair water fence (1bdg)

Water Supply System Data Base

Serial No.	File No.	WSS ID	Specify for Other	Component of Organization	J-3 Water Tariff System		J-4 Water Tariff Collection System	J-5 Role of organizations for repairing and replacement of facilities (including expense distribution)		K-1 Problems most concerned for improvement of living conditions of the village/community		K-2 Names of agricultural chemicals used in the area	Name, Specification and Quantity of Facility
					Tariff System	Tariff		RWSEA	Operator (selected in J-1)	1st Priority	2nd Priority		
77	P-04		Учредительский ГСЭП "НОМК"	State system	2: Commodity Charge	0.12 Somoni/m3	1: Collector		Necessary to fix the association water users which could perked the system of the presenting of water.		not used	<ol style="list-style-type: none"> <li>Sluice valve d100mm (15pcs)</li> <li>Sluice valve d150mm (21pcs)</li> <li>Check valve (250pcs)</li> <li>Water tap (250pcs)</li> <li>PK d 1.0-1.5 m (126ks)</li> <li>Pump ECV 10-120-30 (8kts)</li> <li>Repair to Pumping station. (1bkg)</li> <li>Construction site to administrative building (1bkg)</li> <li>Pipe steel d15-20 mm (2.5km)</li> <li>Pipe steel d78mm (5km)</li> <li>Pipe steel d100mm (5km)</li> <li>Pipe steel d150mm (7km)</li> </ol>	
78	P-07			State system	1: Flat Rate	2 Somoni/month	1: Collector					<ol style="list-style-type: none"> <li>Sluice valve d100 mm (2kts)</li> <li>Sluice valve d150mm (4kts)</li> <li>PK d1.0m (2kts)</li> <li>PK d1.5m (4kts)</li> <li>Water tap (20kts)</li> <li>Pump ECV 10-120-30 (150pc)</li> <li>Pump ECV 10-120-40 (11kts)</li> <li>Pipe PVP d100mm (2km)</li> <li>Pipe steel d150mm (0.8km)</li> </ol>	
79	P-08			State system	2: Commodity Charge	0.0251 Somoni/m3	1: Collector		Necessary to conduct the rehabilitation to pumping station for the sake of improvements of the presenting of water consumer		not used	<ol style="list-style-type: none"> <li>Sluice valve d 100 mm (4kts)</li> <li>Sluice valve d 150 mm (4kts)</li> <li>Sluice valve d 200 mm (4kts)</li> <li>Check valve d 100 mm (2kts)</li> <li>Check valve d 200 mm (2kts)</li> <li>Check valve d 150 mm (2kts)</li> <li>Water tap (40kts)</li> <li>PK d 1.5 m (12kts)</li> <li>Pump ECV 105-180 (2kts)</li> <li>Pump CNS 105-204 (2kts)</li> <li>KTP 400/10 (1kts)</li> <li>Electric motor 100kw, 1000 lum/min (1kts)</li> <li>Pipe steel d 20 mm (0.4km)</li> <li>Pipe steel d 40 mm (0.8km)</li> <li>Pipe steel d 150 mm (0.8km)</li> <li>Pipe steel d 273 mm (2km)</li> <li>Pipe steel d 219 mm (0.8km)</li> </ol>	
80	P-10			State system	2: Commodity Charge	0.0251 Somoni/m3	1: Collector				not used	<ol style="list-style-type: none"> <li>Sluice valve d 150mm (4kts)</li> <li>Sluice valve d 200mm (6kts)</li> <li>Valve d 50mm (19kts)</li> <li>PK d 1.0m (1kts)</li> <li>PK d 2.0m (1kts)</li> <li>Pump ACS-90-30, 180kv, 1000 lum/min (2kts)</li> <li>Pump CNS 105-204 (4kts)</li> <li>Водонапорная аппаратура насоса с корпусом 2-го и 3-го подвеса (2bkg)</li> <li>Материальный расход насосной станции (120m)</li> <li>Pipe steel d 50 mm (120m)</li> <li>Pipe steel d 159 mm (3.4km)</li> <li>Pipe steel d 219 mm (2km)</li> <li>Pipe steel d 273 mm (3km)</li> <li>Isol (1000m2)</li> <li>Cement (35m)</li> </ol>	
81	P-13			State system	2: Commodity Charge	0.0251 Somoni/m3	1: Collector		Necessary to install the system a disinfection for reduction number to diseases		not used	<ol style="list-style-type: none"> <li>Sluice valve d100mm (12pcs)</li> <li>Sluice valve d150mm (8pcs)</li> <li>Air release valve d50mm (2pcs)</li> <li>PK d1.0m (12kts)</li> <li>Water tap (40kts)</li> <li>Pipe steel d20mm (0.4km)</li> <li>Pipe Polyethylene d100mm (2km)</li> <li>Pipe Polyethylene d150mm (4km)</li> <li>Heavy repair water force (1bkg)</li> </ol>	

Water Supply System Data Base

Serial No.	File No.	WSS ID	Specify for Other	Component of Organization	J-3 Water Tariff System		J-4 Water Tariff Collection System	J-5 Role of organizations for repairing and replacement of facilities (including expense distribution)		K-1 Problems most concerned for improvement of living conditions of the village/community		K-2 Names of agricultural chemicals used in the area	Name, Specification and Quantity of Facility
					Tariff System	Tariff		RWSA	Operator (selected in J-1)	1st Priority	2nd Priority		
82	12	P-16		State system	1: Flat Rate	3 Somoni/month	1: Collector			Necessary to install the system a disinfection water for reduction number to infectious diseases.		not used	1. Silica valve d100 mm (6pcs) 2. Silica valve d150mm (4pcs) 3. Air release valve d50 mm (23lbs) 4. Water tap (20lbs) 5. Check valve d100mm (2kita) 6. Pump ECV 8-40-125 (1kit) 7. Heavy repair water fence (1bldg) 8. Pipe steel d20mm (0.2cm) 9. Pipe d100mm (0.6cm) 10. Pipe d150mm (0.8cm)
83	13	P-11		State system	2: Commodity Charge	0.12 Somoni/m3	1: Collector			Necessary to install the system of the disinfection water number for the sake of reduction to diseases		not used	1. Bolt d80mm (2kita) 2. Bolt d100mm (2kita) 3. Weld 1.5m (3kita) 4. Water wire rows (20kita) 5. Pump ECV 8-40-125 (1kit) 6. PIP 100mm (1kit) (200m) 7. Pipe steel d20mm (200m) 8. Fence and repair water fence (1bldg)
84	14	P-01		State system	2: Commodity Charge	0.12 Somoni/m3	1: Collector			Necessary to install system of the disinfection of water for reduction number to infectious diseases amongst consumers		not used	1. Bolt d100mm (4kita) 2. Bolt d150mm (4kita) 3. Air release valve d50mm (2kita) 4. Pit d1.5m (4kita) 5. Check valve (40pcs) 6. Pipe d. d20mm (300m) 7. Pump ECV 8-40-125 (2kita) 8. Pipe Polyethylene d100mm (2km) 9. Pipe Polyethylene d150mm (2.5km)
85	15	P-14		State system	1: Flat Rate	2 Somoni/month	1: Collector			It is Necessary to install the system of the disinfection for reduction number to diseases.	Perfect the system of the presenting of water.	not used	1. Silica valve d100 mm (4kita) 2. Air release valve d50 mm (1kit) 3. Water rows (20pcs) 4. Well d1.0m (8kita) 5. Pump ECV 8-40-125 (1kit) 6. Heavy repair to pumping station (1bldg) 7. Pipe polyethylene d100 mm (0.8cm) 8. Pipe polyethylene d 150 mm (0.4km)
86	16	P-12		State system	1: Flat Rate	2 Somoni/month	1: Collector			Necessary to install the system of the disinfection of water for reduction number to diseases.		not used	1. Fences nitline water fence (0.5ha) 2. ECV 10-120-40 (1kit) (2kita) 3. Silica valve d100mm (4kita) 4. Silica valve d150mm (4kita) 5. Check valve d 100 mm (2kita) 6. Water tap (30kita) 7. Pipe steel d20mm (300m) 8. Pipe d114mm (180m) 9. Pipe polyethylene d 100 mm (2km) 10. Pipe polyethylene d 150 mm (11m) 11. Transformer 100/04 (1pc) 12. Will Build chlorate and buildings for duty personnel (2bldgs)
87	1	Q-01	Nodhanal Kumrangir	State system	2: Commodity Charge	0.12 Somoni/m3	1: Collector			It is necessary rehabilitation of pump station	It is necessary install new technology for disinfection of water	not used	1. Water pump D32050 with electric engine 75 kv, 1500 ohm (4sets) 2. Steel pipe d 75 mm (4.8cm) 3. Steel pipe d 100 mm (2.8cm) 4. Steel pipe d 50 mm (3.7cm) 5. Silica valve d 100mm (8pcs) 6. Silica valve d 150mm (12pcs) 7. Silica valve d 50mm (25pcs) 8. Silica valve d 32mm (40pcs) 10. Pit d. 1.5 m (12pcs) 11. Pit d. 1.0 m (15pcs)
88	2	Q-02	Kumsangir RWWS	State system	2: Commodity Charge	0.0251 Somoni/m3	1: Collector			The lack of clean drinking water	There is a problem with electro-energy	not used	1. Silica valve d 100mm (2pcs) 2. Air valve d 50mm (1pc) 3. Water tap d 15mm (26pcs) 4. Steel pipe d 20mm (200m) 5. Pit (2sets) 6. Steel pipe d 114mm (800m) 7. Silica valve d 100mm (2km) 8. Cement (0.5cm) 9. Electrical part (1set) 10. Pump k-412 d17kv 2.000s/m (1set) 11. Shelter for the pump with fence (1set) 12. Electrical part (1set)

Water Supply System Data Base

Serial No.	File No.	WSS ID	Specify for Other	J-2		J-3		J-4		J-5		K-1		K-2	Name, Specification and Quantity of Facility
				Component of Organization	Water Tariff System	Tariff System	Tariff	Water Tariff Collection System	Role of organizations for repairing and replacement of facilities (including expense distribution)	Problems most concerned for improvement of living conditions of the village/community	1st Priority	2nd Priority	Narratives of agricultural chemicals used in the area		
89	Q-06		Kumsangir & RWWS	State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector	2: Transferring						not used	1. Sluice valve dia 80 mm (8pcs) 2. Sluice valve dia 100 mm (4pcs) 3. Air valve d 50 mm (2pcs) 4. Air valve d 100 mm (2pcs) 5. Well d 1.0 m (10wells) 6. Cement (1.0ton) 7. Bitumen (0.5ton) 8. Steel pipe d 20 mm (300m) 9. Steel pipe d 76 mm (0.8km) 10. Steel pipe d 114 mm (0.4km) 11. PVC pipe d 100mm (2.0km) 12. PVC pipe d 76 mm (1.0km)
90	Q-03		Kumsangir & RWWS	State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector							not used	1. Sluice valve d 80 mm (4pcs) 2. Sluice valve d 100 mm (4pcs) 3. Water tap d. 15 mm (4pcs) 4. Pit d 1.0m (30pcs) 5. Steel pipe d. 20mm (150m) 6. Steel pipe d. 76mm (100m) 7. PVC pipe d. 100mm (2km) 8. Steel pipe d. 100mm (12km)
91	Q-07		Kumsangir & RWWS	State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector					It is necessary to establish system of disinfecting for reduction of quantity of disease	It is necessary to improve system of water delivery	not used	1. Sluice valve d 100mm (2pcs) 2. Air valve d 50mm (2pcs) 3. Air valve d 100mm (2pcs) 4. Steel pipe d 20mm (480m) 5. Steel pipe d 114mm (400m) 6. PVC pipe d 100mm (2000m) 7. Pit (2pcs) 8. Cement (1.0ton) 9. Bitumen (0.5ton) 10. Shelter for the pump (1 bldg) 11. Electrical part (1bldg) 12. Type of pump 4k-12, 17hr 2,900 turn/min
92	Q-08		Vodohanal	Kumsangir Vodohanal	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector					Shortage of water	Problem with electric power	not used	1. Water pump 12x100, 250 kw (9000/m (3wells) 2. Major repairs pump station building (1bldg) 3. Electrical part (1bldg) 4. Water pump 8 HJBR110 kw (1set) 5. Sluice valve d 400mm (8pcs) 6. Sluice valve d 300mm (8pcs) 7. Sluice valve d 250mm (8pcs) 8. Sluice valve d 100mm (12pcs) 9. Sluice valve d 50mm (8pcs) 10. Check valve d 300mm (8pcs) 11. Water pump 10 HJBR 200 kw (2sets) 12. To replace compulsory electrical part on pump station No.1 & No.2 (2bldgs) 13. Major repairs electrical building No.1 & No.2 (2bldgs) 14. Water pump 11 kw BSH (1set) 15. Water tap (8pcs) 16. KTI 400/10 (1kl) 17. KTI 500/10 (1kl) 18. Steel pipe d 273 mm (4.5km) 19. Steel pipe d 426 mm (2km) 20. Steel pipe d 20 mm (0.9km) 21. PVC pipe d 110 mm (8km) 22. To cleaning collector from 8th-village to granitium factory (8km)
93	Q-04			Of the collective farm	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector					It is necessary to establish system of disinfecting for reduction of quantity of disease	It is necessary to improve system of water delivery	not used	1. Sluice valve d 150 mm (8pcs) 2. Sluice valve d 200 mm (12pcs) 3. Type of pump 320x50, c 8k 75xst, 150000/umh (3sets) 4. Vacuum pump VVN (2sets) 5. Well d 1.5m (2wells) 6. Trap (88pcs) 7. Steel pipe d 20mm (900m) 8. Steel pipe d 114mm (100m) 9. Steel pipe d 168mm (240m) 10. Steel pipe d 219mm (300m) 11. Steel pipe d 325 (400m) 12. PVC pipe d 100mm (0.2km) 13. Capital repair of waterworks pump station, duty works and l.d. (6rooms)

Water Supply System Data Base

Serial No.	File No.	VBS ID	Specify for Other	Component of Organization	J-3 Water Tariff System		J-4 Water Tariff Collection System	J-5 Role of organizations for repairing and replacement of facilities (including expense distribution)		K-1 Problems most concerned for improvement of living conditions of the village/community		K-2 Names of agricultural channels used in the area	Name, Specification and Quantity of Facility
					Tariff System	Tariff		RWSA	Operator (selected in --1)	1st Priority	2nd Priority		
94	8	Q-05	Kurmasingir RWWS	State system	2: Commodity Charge	0.0251 Somoni/m3	1: Collector	2: Transferring		Lack of water	The problem with selecto-energy.	not used	<ol style="list-style-type: none"> <li>1. Sluice valve d 100 mm (4pcs)</li> <li>2. Sluice valve d 150 mm (4pcs)</li> <li>3. Sluice valve d 200 mm (6pcs)</li> <li>4. Spares d100 mm., d150 mm., d 200 mm (1set)</li> <li>5. PI d 1.5 m (10sets)</li> <li>6. Water tap d 15 mm (40pcs)</li> <li>7. Steel pipe d 20 mm (400m)</li> <li>8. Steel pipe d 100 mm (10m)</li> <li>9. Steel pipe d 150 mm (10m)</li> <li>10. Steel pipe d 175 mm (10m)</li> <li>11. Transformer 400 kvA (1set)</li> <li>12. Diesel fuel (80oz)</li> <li>13. Diesel fuel (80oz)</li> <li>14. Lime (30oz)</li> <li>15. Steel plate 3 m (10oz)</li> <li>16. Transformer 400 kvA in set with KTP (1set)</li> <li>17. Rotary pump d 320150 1,500rpm 75 kvA (3sets)</li> <li>18. Supports CHBC 11 m (20pcs)</li> <li>19. Aluminum cable AC70 (3km)</li> </ol>
95	1	S-03		State system	2: Commodity Charge	0.12 Somoni/m3	1: Collector			Required to fix the system of the distribution of water for reduction number to infectious diseases amongst populations.		not used	<ol style="list-style-type: none"> <li>1. Pump ECV 8-16-110 (2kts)</li> <li>2. Pipes d 76mm (40m)</li> <li>3. Pipes polyethylene d 110mm (3.5km)</li> <li>4. Check of management (1pc)</li> <li>5. Device for disinfection d-25x3 (1pcs)</li> </ol>
96	2	S-07	GUP 'KINAK'	State system	2: Commodity Charge	0.12 Somoni/m3	1: Collector	2: Transferring		Necessary to conduct the heavy repair on pumping station		not used	<ol style="list-style-type: none"> <li>1. Pump ECV 10-120-60 (3kts)</li> <li>2. Electric motor 75 kw 3000 r/min/minutes (3pcs)</li> <li>3. Sluice valve d 250mm (4pcs)</li> <li>4. Sluice valve d 150mm (12pcs)</li> <li>5. Sluice valve d 100mm (12pcs)</li> <li>6. Checking valve d 150mm (4pcs)</li> <li>7. Pipe d 200mm (2.5km)</li> <li>8. Pipe d 150mm (3.2km)</li> <li>9. Pipe d 100mm (4km)</li> <li>10. Transformer 400/10 (1kvt)</li> </ol>
97	3	S-02		State system	2: Commodity Charge	0.12 Somoni/m3	1: Collector			Necessary to install system of the disinfection or reduction number to diseases		not used	<ol style="list-style-type: none"> <li>1. Pump ECV 8-40-110 (1kvt)</li> <li>2. Check of governing the type kaskad-32 (1pc)</li> <li>3. Pipe steel. d 88mm (400m)</li> <li>4. Pipe steel. d 100mm (600m)</li> <li>5. Welding unit (1 kit)</li> <li>6. Air release valve d 25mm (4pcs)</li> </ol>
98	4	S-04		State system	2: Commodity Charge	0.12 Somoni/m3	1: Collector					not used	<ol style="list-style-type: none"> <li>1. Pump ECV 8-40-125 (2kts)</li> <li>2. Sluice valve d 150mm (4pcs)</li> <li>3. Sluice valve d 100mm (12pcs)</li> <li>4. Pipe steel. d 100mm (2.5km)</li> <li>5. Pipe steel. d 76mm (1km)</li> <li>6. Welding unit (1pc)</li> </ol>
99	5	S-09		State system	2: Commodity Charge	0.12 Somoni/m3	1: Collector			Insulating the system of the disinfection reduction number to infectious diseases.	Required to perfect the system of the presenting of water.	not used	<ol style="list-style-type: none"> <li>1. Sluice valve d 100mm (8pcs)</li> <li>2. Sluice valve d 150mm (4pcs)</li> <li>3. Sluice valve d 200m (2pcs)</li> <li>4. Pump ECV 8-16-125 (2kts)</li> <li>5. Pipe steel d 200mm (2.2km)</li> <li>6. Pipe steel d 150mm (1.5km)</li> <li>7. Pipe steel d 100mm (1.5km)</li> <li>8. Pipe steel d 50mm (1km)</li> </ol>
100	6	S-05		State system	2: Commodity Charge	0.12 Somoni/m3	1: Collector			Required to make repair on building of the pumping station.	It is Necessary to fix system of the disinfection for the sake of reduction number to infectious diseases amongst consumers (users).	Against tourist.	<ol style="list-style-type: none"> <li>1. Depth pump. ECV 60-65-65 (2pcs)</li> <li>2. Depth cable AYP 5x8x8 (100m)</li> <li>3. Control panel (1pc)</li> <li>4. Sluice valve d 200mm (4pcs)</li> <li>5. Polyethylene pipe d 75-100 mm (3.5km)</li> <li>6. Welding unit 220 volt (1pc)</li> <li>7. Diesel generator. 8-10kw (1pc)</li> </ol>
101	7	S-08		State system	2: Commodity Charge	0.12 Somoni/m3	1: Collector			Improve presenting of water system		not used	<ol style="list-style-type: none"> <li>1. Pump ECV 8-25-125 (1pc)</li> <li>2. Steel pipe d 100 mm (50m)</li> <li>3. Steel pipe d 200 mm (30m)</li> <li>4. Steel pipe d 150 mm (20m)</li> <li>5. Steel pipe d 100 mm (20m)</li> <li>6. Steel pipe d 50 mm (1.5km)</li> </ol>

Water Supply System Data Base

Serial No.	File No.	VSS ID	Specify for Other	Component of Organization	J-3 Water Tariff System		J-4 Water Tariff Collection System	J-5 Role of organizations for repairing and replacement of facilities (including expense distribution)		K-1 Problems most concerned for improvement of living conditions of the village/community		K-2 Names of agricultural chemicals used in the area	Name, Specification and Quantity of Facility
					Tariff System	Tariff		RWSA	Operator (selected in J-1)	1st Priority	2nd Priority		
102	8	S-10		State system	2: Commodity Charge	0.12 Somoni/m <sup>3</sup>	1: Collector		Necessary to install system of the disinfection or reduction number to diseases		not used	<ol style="list-style-type: none"> <li>Rope bolt UGR-60 will knotted (1kt)</li> <li>Power ECV 25-110 (1kt)</li> <li>Welder ECV 25-110 (1kt)</li> <li>Steel pipes d 50mm (45pc)</li> <li>Steel pipes d 200mm (41m)</li> <li>Polyethylene pipes d 50-100mm (500m)</li> </ol>	
103	9	S-01		State system	2: Commodity Charge	0.12 Somoni/m <sup>3</sup>	1: Collector		Necessary to fix the system of the disinfection for reduction number to infectious diseases.		not used	<ol style="list-style-type: none"> <li>Transformer TLI 60/10.04 (1pc)</li> <li>Auto ECV 4-25-110 with cable for installing (2kts)</li> <li>Control panel Kestak-35 (1pc)</li> <li>Pipe steel d 150 mm (3.5km)</li> <li>Pipe steel d 50 mm (3.5km)</li> <li>Welding unit on 220 volt (1pc)</li> <li>Generator Diesel (1pc)</li> </ol>	
104	10	S-06	GUP 'KHNAK'	State system	2: Commodity Charge	0.12 Somoni/m <sup>3</sup>	1: Collector		Necessary to avoid drains and install on all water point water measured disinfection of water for reduction number to diseases		not used	<ol style="list-style-type: none"> <li>Sluice valve d 400mm (4pc)</li> <li>Sluice valve d 200mm (10 kts)</li> <li>Sluice valve d 150mm (12kts)</li> <li>Water taps d 20mm (320pc)</li> <li>Pipe steel d 20mm (800m)</li> <li>Pipe steel d 426mm (1450m)</li> <li>Pipe steel d 219mm (250m)</li> <li>Pipe PVP d 150mm (30m)</li> <li>Pipe PVP d 100mm (60m)</li> <li>Auto ECV 4-25-110 (2kts)</li> <li>Heavy repair equipment (1bdg)</li> </ol>	
105	1	V-01		State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector		Infectious disease increased in lack of drinking water last years amongst population	Different infectious disease especially will decrease in the event of provision of drinking water amongst and children	not used	<ol style="list-style-type: none"> <li>Steel pipe d 180mm (800m)</li> <li>Steel pipe d 60 mm (1.4km)</li> <li>Water meter d 20 mm (32pc)</li> <li>Sluice valve d 150 mm (4pc)</li> <li>Sluice valve d 100 mm (8pc)</li> </ol>	
106	2	V-05		State system	2: Commodity Charge	0.12 Somoni/m <sup>3</sup>	1: Collector		Drinking water acquires at the end village because of wear-out of the pump power equipment and partial damage of the pipe construction work (job functioning) because are provided (ensured, supplied) economic drinking water, and will decrease the infectious diseases.	Will Reduce amongst population to infectious diseases.	not used	<ol style="list-style-type: none"> <li>Pumps K-4566 (2kts)</li> <li>Electric motor 37kw (2kts)</li> </ol>	
107	3	V-02		State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector				not used	<ol style="list-style-type: none"> <li>Pump K-4566 with electric motor (3kts)</li> <li>The Closet(Rack cabinet) management (governing, control) pumping unit(kt)</li> <li>Pump D 320/50 (2kts)</li> </ol>	
108	4	V-03		State system	2: Commodity Charge	0.12 Somoni/m <sup>3</sup>	1: Collector		The Repair pipe line.	Produce working organization in Jamoat.	not used	<ol style="list-style-type: none"> <li>Pipe steel d 200 mm (200m)</li> <li>Pipe steel d 150 mm (1km)</li> <li>Pipe steel d 100 mm (1.5km)</li> <li>Sluice valve d 200 mm (4pc)</li> <li>Sluice valve d 150 mm (8pc)</li> <li>Sluice valve d 100 mm (8pc)</li> <li>Pump K 8545 with electric motor 55kw, 3600rpm/min (3kts)</li> </ol>	
109	5	V-04	Jamoat	State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector		It is Necessary to restore pipe drinking networks and will provide the population by clean drinking water.	Will Reduce the infectious diseases amongst population, basically amongst children, that at the last years has enlarged their ruin.	not used	<ol style="list-style-type: none"> <li>Closet control pumping unit(kt)</li> <li>Pumps with electric motors D 200, 1500 lumminutes and K 4566 (2kts)</li> <li>System disinfection Porcelain bath (3kts)</li> <li>Introductory box (1kt)</li> </ol>	
110	6	V-06		State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector		After recovering population will be provided by clean drinking water	Will Reduce infectious diseases amongst population.	not used	<ol style="list-style-type: none"> <li>Sluice valve d 100 mm (8pc)</li> <li>Air valve d 32 mm (4pc)</li> <li>Water taps d 20 mm (28kts)</li> <li>Steel pipe d 150 mm (8.9km)</li> </ol>	
111	7	V-07	Jamoat	State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector		Required perfect system of the disinfection(decontamination) to reduce the number to diseases of the ambulance population.	The problem with the electro-energy	not used	<ol style="list-style-type: none"> <li>Sluice valve d 100 mm (8pc)</li> <li>Pipe PVC d 100 mm (2.1km)</li> </ol>	
112	8	V-08		State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector		Install the system of the disinfection of water.	Will Reduce the number to infectious diseases.	not used	<ol style="list-style-type: none"> <li>Pump D 300/70 (3kts)</li> <li>Electric motor 160/3000 (3kts)</li> <li>Introductory closet(rack cabinet) (1pc)</li> <li>Closet(rack cabinet) of management pumping unit(kt) (3pc)</li> </ol>	
113	9	V-09		State system	2: Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector		In the event of reconstruction population PGT Vahob, Jamoat Roli Lenin, Gogaza and Yanglobod will be provided with ecological clean drinking water.	Reduce amongst population to infectious diseases.	not used	<ol style="list-style-type: none"> <li>Pump D-3200/28 S. Electric motor 160/738 (2pc)</li> <li>Closet management PEH (2pc)</li> <li>pipe d 530 mm (1.2km)</li> </ol>	

Water Supply System Data Base

Serial No.	File No.	WSR ID	Specify for Other	J-2 Component of Organization	J-3 Water Tariff System		J-4 Water Tariff Collection System	J-5 Role of organizations for repairing and replacement of facilities (including expense distribution)		K-1 Problems most concerned for improvement of living conditions of the village/community		K-2 Names of agricultural chemicals used in the area	Name, Specification and Quantity of Facility
					Tariff System	Tariff		RWISA	Operator (selected in J-1)	1st Priority	2nd Priority		
114	10	V-10		State system	2. Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector		Necessary to supply the population by clean drinking water.		not used	1. Sluice valve d 150mm (4pcs) 2. Sluice valve d 100mm (8pcs) 3. Water taps (35bits)	
115	11	V-12	Military base of Ministry on exceeding event	State system	2. Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector				not used	1. Sluice valve d 100mm (7pcs) 2. Air valve d 25mm (2pcs) 3. PK d 1.5m (2pcs) 4. Steel pipe d 100mm (0.6km) 5. Steel pipe d 200mm (0.3km) 6. Water taps d 15mm (12pcs) 7. System of the disinfection water (1kt)	
116	12	V-14		State system	2. Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector		Necessary to fix the association water users which could perfect the system of the presenting of water.		not used	1. System of the disinfection (1kt)	
117	13	V-13		State system	2. Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector		Necessary to fix the association water users which could perfect the system of the presenting of water.		not used	1. Sluice valve d 100mm (4pcs) 2. Air valve d 25mm (3pcs) 3. PK d 1.5m (3bits) 4. Steel pipe d 100mm (0.4km) 5. Steel pipe d 200mm (0.3km) 6. Water taps d 15mm (32pcs) 7. System of the disinfection water (1kt)	
118	14	V-11		State system	2. Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector		Necessary to fix the association water users which could perfect the system of the presenting of water.		not used	1. Sluice valve d 200mm (8pcs) 2. Sluice valve d 150mm (12pcs) 3. Sluice valve d 100mm (12pcs) 4. PK d 1.5m (8bits) 5. Air valve d 25mm (10pcs) 6. Water taps d 20mm (210pcs) 7. Steel pipe d 20mm (0.7km) 8. Steel pipe d 100mm (1.2km) 9. Steel pipe d 110mm (2.4km) 10. Welding unit (1kt) 11. Transformer 400V/10 (1kt) 12. System of the disinfection (1kt) 13. Tractor GAZ-13 (1pc)	
119	15	V-15		State system	2. Commodity Charge	0.0251 Somoni/m <sup>3</sup>	1: Collector		Necessary to fix the association water users which could perfect the system of the presenting of water.		not used		