

3.9 Summary Report of Residual Chlorine Control in “FMRP” (Action S6)

Summary of OJT activity about residual chlorine control In iron and manganese removal process

1. Purpose of OJT about chlorine control in iron and manganese removal process
 - Improvement of implementation capacity regarding operation and control of chlorination process
2. Target of achievement by OJT activity
 - 2-1 Improvement of stability and suitability of residual chlorine concentration of treated water
 - 1) Stable residual chlorine of clarified water in suitable concentration
 - 2) Stable residual chlorine of filtered water in suitable concentration
 - 3) Stable residual chlorine of transmission water in suitable concentration
 - 2-2 Improvement of water quality about color of water
 - 1) Supplying of transmission water to the network from FMRP without color
 - 2-2 Improvement of O&M activity
 - 1) Effective chlorine dosing
 - 2) Proper chlorine dosing rate
 - 3) Routine work of water quality analysis about residual chlorine by proper frequency
 - 4) Effective utilizing of water quality analysis record about residual chlorine
 - 5) Control activity about residual chlorine with control target of treated water
 - 6) Supplying of safety and comfortable water with high reliability to the network
 - 2-3 Improvement of O&M capacity
 - 1) Capacity to monitor residual chlorine of treated water
 - 2) Capacity to control the chlorinator to demanded flow rate of chlorine
 - 3) Capacity to set up and modify a required dosing rate of chlorine
 - 2-4) Improvement of operating cost about chlorine dosing
 - 1) Proper consumption of chlorine
 - As the result of above, if possible achievement of the reduction of chlorine consumption weight
2. Method
 - 2-1 Confirmation and check of the current condition of residual chlorine control
 - 1) Confirmation by records of water quality analysis about break-point and residual chlorine
 - 1-1) Frequency of analysis in a day and water sampling method
 - 1-2) Validity and availability of recorded values
 - 1-3) Utilizing of analysis records to the plant operation
 - 2) Confirmation of knowledge of laboratory staffs about residual chlorine control
 - 2-1) Kind of residual chlorine and feature of each
 - 2-2) Residual chlorine to be maintained in usual operation of FPRP
 - 2-3) Residual chlorine concentration to be kept of transmission water from FMRP
 - 2-4) Assessment of consumption of residual chlorine in iron and manganese removal process
 - 2-5) Treatment targets about residual chlorine in iron and manganese removal process
 - 2-6) Residual chlorine concentration to be kept of transmission water at final tap in the network
 - 2-7) Regulations or law about residual chlorine in Egypt

- 2-8) Letters or documents on above regulations or law
- 2-9) Functions of components in FMRP
- 2-10) Mechanism of iron and manganese removal from well water
- 2-11) Function of chlorination in iron and manganese removal process
- 3) Confirmation of current operation about control of dosing flow rate by chlorinator
 - 3-1) Communication between laboratory team and operation team
 - 3-2) Procedures for control operation of chlorinator when chlorine dosing flow rate should be changed
 - 3-3) Utilizing of records of raw water flow rate to control of the chlorine dosing flow rate
 - 3-4) Procedures to calculation of dosing flow rate of chlorine
 - 3-5) Frequency of change of chlorine dosing flow rate in a day
 - 3-6) Procedures for control of residual chlorine concentration in iron and manganese removal process
 - 3-7) Use of break-point test results for set-up of pre-chlorine dosing rate
 - 3-8) Consumption of residual chlorine in iron and manganese removal process
 - 3-9) Frequency of complains from customers by supplying of colored water
 - 3-10) Water quality of well water and filtered water
- 2-2 Lectures about control procedures for residual chlorine in water treatment process
 - 1) Importance of free residual chlorine and effectiveness over disinfection of potable water
 - 2) Necessity of water analysis about not only total residual chlorine but free residual chlorine
 - 3) Criteria of residual chlorine concentration of potable water by WHO guideline
 - 4) Functions of components in FMRP
 - 5) Mechanism of iron and manganese removal from well water
 - 6) Function of chlorination in iron and manganese removal process
 - 7) Necessity of control activity of residual chlorine concentration in iron and manganese removal process
 - 5) Achievements by control activity of residual chlorine concentration in iron and manganese removal process
 - 6) Functions of chlorine dosing and post-chlorine dosing
 - 7) Relation between pre-chlorine dosing rate and post-chlorine dosing rate
 - 8) Required activities to control of residual chlorine concentration in iron and manganese removal process
 - 9) Required records to control of residual chlorine concentration in iron and manganese removal process
 - 10) Affects of water quality of combined well water to iron and manganese removal
 - 11) Procedures for control of residual chlorine in iron and manganese removal process
- 2-3. OJT about residual chlorine control
 - 1) Set-up the treatment targets of residual chlorine about filter inlet water, filtered water and transmission water
 - 2) Taking records of residual chlorine under operation condition in the current for 3 days
 - 3) Taking records of raw water flow rate for 3 days
 - 4) Analysis about 3-days records of operation

- Differences between the target treatment value and actual records
 Study about variation of residual chlorine concentration in 5 days
 Study about differences between residual chlorine of clarified water and filtered water
 Study about relation between beak-point test results, pre-chlorine dosing rate and residual chlorine of clarified water
 Study about relation between chlorine dosing rate and residual chlorine of filtered water and generating of colored water in the network
 Calculation of consumption of residual chlorine in treatment process
 Study about causes of found differences
- 6) Focusing to required reviews about modification of current operation conditions
 - 7) Implementation of operation under condition of reviewed operation and taking of records for 5days
 - 8) Same as above 4) to 7)
 - 9) Setting the criteria for winter season about control of residual chlorine

2-4.OJT by expert about residual; chlorine control in FMRP to CP of H/Q and CP in model facility

Facility name	Date of OJT	OJT
Qenayate FMRP	29/Oct/2008	Lecture to H/Q CP from expert
	30/Oct/2008	Lecture to H/Q CP from expert
	04/Nov/2008	Investigation about current condition
	05/Nov/2008	Data collection start
	10/Nov/2008	Data analysis
	12/Nov/2008	Lecture to site CP from H/Q CP
	13/Nov/2008	Lecture to site CP from H/Q CP
	20/Nov/2008	Lecture to site CP from H/Q CP
	20/Jan/2009	Data analysis
	25/Jan/2009	Data analysis

Attendance of OJT about residual chlorine control in FMRP

Facility name	Date of OJT	H/Q CP team	Site CP team
	30/Oct/2008	Mr.Sharfi Ms.Heba Mr.Abd Allah	
	04/Nov/2008	Mr.Sharfi Ms.Heba Mr.Abd Allah	Mr.Attia Goda(Sector manager) Mr.Adel (Plant manager) Mr.Said Seyam (Supervisor) Mr.Saleem(Technitian Ms.Mona(Chemist)
	04/Nov/2008	Mr.Sharfi Ms.Heba	Mr.Attia Goda(Sector manager) Mr.Adel (Plant manager)

		Mr.Abd Allah	Mr.Said Seyam (Supervisor)
	10/Nov/2008	Mr.Sharfi Ms.Heba Mr.Abd Allah	Mr.Attia Goda Mr.Adel (Plant manager) Mr.Said Seyam (Supervisor) Mr.Saleem(Technitian Ms.Mona(Chemist)
	12-13/Nov/2009	Mr.Sharfi Ms.Heba Mr.Abd Allah	Mr.Attia Goda(Sector manager) Mr.Adel (Plant manager) Mr.Said Seyam (Supervisor) Mr.Saleem(Technitian
	20/Nov/2008	Mr.Sharfi Ms.Heba Mr.Abd Allah	Mr.Attia Goda(Sector manager) Mr.Adel (Plant manager) Mr.Said Seyam (Supervisor) Mr.Saleem(Technitian
	20/Jan/2008	Mr.Sharfi Ms.Heba Mr.Abd Allah	Mr.Noglan (Plant manager)
	25/Jan/2008	Mr.Sharfi Ms.Heba Mr.Abd Allah	Mr.Noglan (Plant manager)

2-5 Achievements by OJT about residual chlorine control as applying SOP to O&M activities on site

- 1) Water quality analysis about residual chlorine in treatment process has been conducted as one of the routine work of monitoring activity in FMRP model facility.
- 2) From October-2008, residual chlorine to monitor has been changed to free residual chlorine from total residual chlorine in FMRP model facility.
- 3) By implementation of control activity of residual chlorine, residual chlorine of filter inlet water and filtered water has been in stable condition.
- 4) By implementation of control activities of residual chlorine, operation on control of chlorine flow rate was improved as reliable adjustment handling of the chlorinator.
While residual chlorine control was not performed, when a well water flow rate was changed, the chlorine dosing flow rate was not changed into a considerable amount in many cases.
- 5) By above achievement, frequency of generation of colored supplying water to the network decreased and under the present status of operation, there is almost no customer complaint.
Before improvement of operation: Frequency of customer complaints 20 times/month
After improvement of operation: Frequency of customer complaints 1 time/month
- 6) By above achievement, O&M capacity regarding for the residual chlorine control of H/Q CP team and model facility CP team has been improved as following
 - 6-1) Capacity to associate the following factors when monitoring is carried out
Residual chlorine concentration of filter inlet water, filtered water, water in the network
set value of dosing flow rate of chlorinator, working numbers of well water

- 5-2) Capacities to perform a calculation of required chlorine dosing flow rate
- 5-3) Capacity to set a proper dosing rate of chlorine based on collected records
- 5-4) Capacity to modify a dosing rate of chlorine based on collected records
- 5-5) Capacity to consider required dosing rate according to seasonal change of chlorine demand
- 5-6) Capacity to consider that residual chlorine concentration is proper or not based on collected records.
- 5-7) Capacities to perform analysis and evaluations of effectiveness of chlorine dosing

2-8.Appendix

- 1) SOP documents regarding residual chlorine control activity
- 2) Records for reference

OJT scenario

Theme: Control procedures for control of free chlorine residual in Fe/Mn removal plant

30/10/2008

A.-Confirmation of current operation condition

1. Confirmation of current operation condition on water quality analysis and facility operation

Is the measured value of chlorine residual free chlorine residual?

What is the reason for using free chlorine residual or total chlorine residual?

Is the chlorine residual of filter inlet water measured and how much is the value?

Is the control target of chlorine residual in each process set up and how much is the value?

When actual measurement shift from control target value, what kind of actions are taken?

When the combination of the well to operate is changed, is the chlorine dosing rate changed?

Is the combination of the well operated based on what decided?

Is quantity of well water to be treated constant?

How much is there any concentration of free chlorine residual approximately?

Are there any data of the removal characteristics of manganese after filter washing?

2. Confirmation of water quality of well water and filtered water in operation condition of before and after replacing of filter media

The characteristics of differences and differences itself of water quality before and after replacing of filter media

Comparison with water standard

Comparison with chlorine residual of filtered water

3. Confirmation of chlorine dosing rate in current operation
4. Confirmation of dosing point of chlorine
5. Confirmation of condition of filter media in the current condition
(Confirmation of condition of filter media at the time of replacing, if filter media is available)
6. Measurement of free chlorine residual of aeration treated water
7. Measurement of free chlorine residual and turbidity of filter inlet water and filtered water

B-The target of OJT and how to advance OJT

1. Study on characteristics of water quality of well water
2. Study on chlorine demand for well water
3. Study on the difference in the oxidation force of free chlorine residual and combined chlorine residual
4. Study on effects which free chlorine residual in filter inlet water exerts on the oxidation force and life of filter media
5. Study on importance of maintaining the oxidation force



6. Study on the necessity for monitoring of free chlorine residual in each treatment process
7. Study on the procedures for control of chlorine residual and setting of chlorine dosing rate
8. A control action is actually performed and record is taken for the result
9. The effectiveness of removal of iron and manganese is checked

C-OJT scenario

1. Study on characteristics of water quality of well water
 - 1-1.Characteristics of well water quality are arranged and explained
 - Contained iron, manganese, ammonia
 - Chlorine demand and pH
 - 1-2.Consider the effect factors given to chlorine dosing rate and free chlorine residual of filtered water
 - With what kind of contained matter in well water is the dosed chlorine consumed how much?
 - In which process is the dosed chlorine consumed how much by what?
 - Just to make sure, the following is checked.
 - Calculation of chlorine dosing flow rate form dosing rate and flow rate of well water
 - Setting of dosing flow rate of chlorinator
 - 1-3. Consider that data on above 1-2 is available or not in the plant.
 - 1-4.When data is not available in the plant, required chlorine residual is measured
2. Study on chlorine demand for well water
 - Is chlorine demand for well water measured? Measurement frequency?
 - Does chlorine demand have a difference by a well?
 - Is chlorine demand unnecessary because of chlorine dosing rate setting out?
3. Study on the difference in the oxidation force of free chlorine residual and combined chlorine residual
 - Utilize material used for OJT of WTP
4. Study on effects which free chlorine residual in filter inlet water exerts on the oxidation force and life of filter media
 - The mechanism of manganese removal by manganese sand is explained plainly
 - If free chlorine residual is not available in filter inlet water, what will happen?
 - Why isn't effective in combined chlorine residual?
 - How much amount of free chlorine residual is required for oxidation by manganese sand?
5. The necessity for keeping of oxidation force of manganese sand is got to know
6. The necessity for monitoring of free chlorine residual concentration in each treatment process
 - Monitoring of free chlorine residual is that not only filtered water but filter inlet water is required
 - The relation between a chlorine dosing rate and free chlorine residual of filter inlet water is investigated
 - The relation between free chlorine residual of filter inlet water and filtered water


7. Control procedures for residual chlorine and setting up procedures of chlorine dosing rate are got to know
The flowcharts for water treatment plant is utilized modifying it partially
8. A control action is actually performed and record is taken for the result
The unified recording sheet is prepared
(The partial modification of the current recording sheet is carried out)

Cycle of Activity for continual improvement




Steps for OJT activities for FMRP

Group 1




Group 2



Manganese removal by manganese sand

Manganese Sand: Filter media with coated on surface from manganese dioxide and it is used as contact filter media





The reaction at condition of manganese sand and manganese in the water

1. The surface of manganese sand contacts the water having contained manganese
2. The manganese contained in the water oxidized by free residual chlorine with manganese sand
3. The oxidation force of residual chlorine with manganese sand is lost
4. Manganese sand and the free residual chlorine contained in the water contact
5. The oxidation force of free residual chlorine with manganese sand is recovered
6. Manganese sands work as catalyst in the process of manganese removal by manganese sand contact filtration.

Remarks

1. When there is not enough free residual chlorine concentration in the filter inlet water, the surface coated layer of manganese sand will be damaged and exfoliated. As a result, function as manganese sand is lost.
Hence, it is required sufficient free residual chlorine for the filter inlet water to oxidize manganese by manganese sand.
2. It is desirable to keep free residual chlorine of filtered water around 0.3 mg/l.
3. Depending on the manganese content in filtered water, a high concentration of free residual chlorine causes colored water.
Hence, in order to prevent generation of the colored water of filtered water, implementation of free residual chlorine control of filtered water is required.
4. In order to carry out free residual chlorine control of filtered water, chlorine dosing rate must be controlled by predicting change of the free residual chlorine in iron and manganese removal process.
5. In order to predict change of the free residual chlorine in iron and manganese removal process, the value of the free residual chlorine in each process must be monitored in the plant.



**Report
About**

Qenaia Iron & Manganese removal plant

**First visit
3/11/2008**

During the visit to Qenaia Iron & Manganese removal plant today 3/11/2008 and our observation for filter backwashing and the discussion with the operating staff and lab chemist we found the following:

1. filter backwashing is automatic through PLC based on time running for the filter and backwash cycle is pre determined as 8 minutes for backwashing, 5 minutes for rewash and 2 minutes for filter media stabilization
2. chlorine is added in the inlet pipe in the oxidization tower only
3. chlorine dose in kg/hour is fixed regardless of water quantity
4. no flow meter installed for measuring plant output

samples for water during backwashing had been taken for turbidity and free chlorine measurement

The preliminary reaction for the plant operation can be summarized as following :

- Generally the plant after rehabilitation are good and facilities provided are suitable to produce good water but,
 - Study required to control the residual chlorine after the tower in order to satisfy the requirement of development and activate the manganese sand inside the filter
 - Backwash cycle are required to be discussed with the plant designer based on the results of turbidity measures for backwashed water
 - Running time for filter needs to be discussed the plant designer to be based on differential pressure as a measure for backwashing rather than timings
 - Date record and analysis for water quantity, quality, chlorine consumption, and residual chlorine are required
 - Try to change the dosing point for chlorine and record the results are required.
 - Flow measuring and chlorine dose control based on water production are necessary .

**Report
About**

Qenaia Iron & Manganese removal plant

**Second visit
6/12/2008**

During the this visit to qenaia Iron & Manganese removal plant today 6/12/2008 in the presence of "Calligan" representative two subjects had been discussed:

1. Change filter backwashing is automatic through PLC regime from time based to differential pressure based
2. Change time sequence for backwashing and rewash cycle based on water turbidity
3. try to make one filter running for 36 hours instead of 24 hours

1- Change filter backwashing is automatic through PLC regime from time based to differential pressure based

The representative promised to study and give an offer to change the system since it need some changes an additional supplies

2- Change time sequence for backwashing and rewash cycle based on water turbidity

It is generally accepted but it does need repeat of washing cycle and measuring of turbidity in frequent bases to reach to the optimum time for backwashing and rewash time

3- try to make one filter running for 36 hours instead of 24 hours


It is accepted under condition that water quality shall be monitored in the additional 12 hours and filter washing shall be compared to the other two filters

chlorine dosing for Iron and Manganese plant

well water flow rate Q l/sec
 Dosing rate of chlorine A g/m³
 Dosing quantity of chlorine S kg/hr

$$S(\text{kg/hr}) = Q (\text{l/sec}) \times 60 \times 60 \times 1/1000 \times A (\text{g/m}^3) \times 1/1000$$




	S40	S80	S120
0.50	72.00	144.00	216.00
1.00	144.00	288.00	432.00
1.50	216.00	432.00	648.00
2.00	288.00	576.00	864.00
2.50	360.00	720.00	1080.00
3.00	432.00	864.00	1296.00



Monitoring results on residual chlorine concentration of Fe/Mn removal plant in Qenayate




1 The difference of free residual chlorine concentration by time

Free residual chlorine	(mg/l)					
	Day-1-Nov.		Day-2-Nov.		Day-2-Nov.	
	9:00	14:00	9:00	14:00	9:00	14:00
	9	14	9	14	9	14
Filter inlet water	0.77	0.72	0.95	0.4	0.95	0.52
Filter outlet water	0.21	0.28	0.34	0.19	0.22	0.22
Network water	0.17	0.16	0.17	0.12	0.14	0.19
	N0.2 & 6 wells		N0.1 & No.5 wells		N0.2 & 6 wells	



2 The difference of total residual chlorine concentration by time


Total residual chlorine	(mg/l)					
	Day-1-Nov.		Day-2-Nov.		Day-2-Nov.	
	9:00	14:00	9:00	14:00	9:00	14:00
	9	14	9	14	9	14
Filter inlet water	0.77	0.68	0.91	0.34	0.97	0.71
Filter outlet water	0.56	0.82	0.49	0.2	0.71	0.33
Network water	0.28	0.52	0.23	0.14	0.54	0.26
	N0.2 & 6 wells		N0.1 & No.5 wells		N0.2 & 6 wells	



3 The difference of combined residual chlorine concentration by time

(mg/l)

Combined residual chlorine	Day-1-Nov.		Day-2-Nov.		Day-2-Nov.	
	9:00	14:00	9:00	14:00	9:00	14:00
	9	14	9	14	9	14
Filter inlet water	0	0	0	0	0.02	0.19
Filter outlet water	0.35	0.54	0.15	0.01	0.49	0.11
Network water	0.11	0.36	0.06	0.02	0.4	0.07
	N0.2 & 6 wells		N0.1 & No.5 wells		N0.2 & 6 wells	



4 Comparison of free residual chlorine and total residual chlorine


(mg/l)

Free residual chlorine	Day-1-Nov.		Day-2-Nov.		Day-2-Nov.		
	9:00	14:00	9:00	14:00	9:00	14:00	
Filter inlet water	0.77	0.72	0.95	0.4	0.95	0.52	Free
	0.77	0.68	0.91	0.34	0.97	0.71	Total
Filter outlet water	0.21	0.28	0.34	0.19	0.22	0.22	Free
	0.56	0.82	0.49	0.2	0.71	0.33	Total
Network water	0.17	0.16	0.17	0.12	0.14	0.19	Free
	0.28	0.52	0.23	0.14	0.54	0.26	Total
	N0.2 & 6 wells		N0.1 & No.5 wells		N0.2 & 6 wells		

5 The difference of free residual chlorine concentration by day

(mg/l)

Free residual chlorine	Day-1	Day-2	Day-3	Day-1	Day-2	Day-3
	9:00	9:00	9:00	14:00	14:00	14:00
	1	2	3	1	2	3
Filter inlet water	0.77	0.95	0.95	0.72	0.4	0.52
Filter outlet water	0.21	0.34	0.22	0.28	0.19	0.22
Network water	0.17	0.17	0.14	0.16	0.12	0.19
	2&6	1&5	2&6	2&6	1&5	2&6
	Day-1 N0.2 & 6 wells		Day-2 N0.1 & No.5 wells		Day-3 N0.2 & 6 wells	





6 The chlorine consumption value in a process

Chlorine consumption

(mg/l)

	Free residual chlorine				Free residual chlorine			
	9:00 AM				14:00			
	Day-1	Day-2	Day-3	Ave.	Day-1	Day-2	Day-3	Ave.
Filter	0.56	0.61	0.73	0.63	0.44	0.21	0.3	0.32
Network	0.04	0.17	0.08	0.10	0.12	0.07	0.03	0.07




7 Change trend of free residual chlorine in Fe/Mn removal process

7-1 Data of 3 days


(mg/l)

	Filter inlet water	Filter outlet water	Network water
9:00:00-1	0.77	0.21	0.17
14:00:00-1	0.72	0.28	0.16
9:00:00-2	0.95	0.34	0.17
14:00:00-2	0.4	0.19	0.12
9:00:00-3	0.95	0.22	0.14
14:00:00-3	0.52	0.22	0.19




7-2 Data at 14:00 of each day

	Filter inlet water	Filter outlet water	Network water
9:00:00-1	0.77	0.21	0.17
9:00:00-2	0.95	0.34	0.17
9:00:00-3	0.95	0.22	0.14



7-3 Data at 14:00 of each day

	Filter inlet water	Filter outlet water	Network water
14:00:00-1	0.72	0.28	0.16
14:00:00-2	0.4	0.19	0.12
14:00:00-3	0.52	0.22	0.19



Quenayate

Dosing rate 1.75 mg/l
 Residual chlorine after aeration 0.24 mg/l
 Consumption during aeration 1.51 mg/l

Required chlorine to oxidation 0.3 mg/l
 Estimated required chlorine 0.045 mg/l

Iron contain in well water 0.15 mg/l
 Manganese contain in well water 0.32 mg/l
 Ammonia contain in well water 0.02 mg/l
 Algae affect (estimated) 7.6 mg/l
 Other contained element to be oxidised
 Total chlorine consumption by oxidation 0.1 mg/l
 Estimated required chlorine 0.152 mg/l

Estimated required chlorine 0.128 mg/l
0.152 mg/l
0.1 mg/l
0.525 mg/l

Chlorine consumption during aeration 0.985 mg/l

After change the chlorine dosing point from before aeration to after aeration
 By calculation 0.795 mg/l

Set up dosing rate of chlorine for trail 1.0-1.2 mg/l

Data of EI Seeds:

Usually chlorine is dosed into the reservoir located after aeration tower

Chlorine dosing flow rate 750 g/h
 Well water flow rate 298 m³/h
 Dosing rate by calculation 2.6 mg/l

Required chlorine to oxidation 0.3 mg/l
 Estimated required chlorine 0.15 mg/l

Iron contain 0.5 mg/l
 Manganese contain 1.2 mg/l
 Ammonia contain 0.2 mg/l
 Total chlorine consumption by oxidation 7.6 mg/l
 Estimated required chlorine 0.48 mg/l

Estimated required chlorine 0.48 mg/l
1.52 mg/l
2.15 mg/l

Calculated difference between dosed chlorine and chlorine to be oxidised 0.5 mg/l

Measured total residual chlorine concentration of treated water 0.8 mg/l

Chlorine , Raw Water and Treated Water Production from Oct., to Nov.,

Date	Well Water Quantity (lit/sec.)	Treated Water Quantity (lit/sec.)	chlorine Dosing Quantity (kg/hr.)	chlorine Dosing rate (mg/l)	Free residual chlorine before Reservoir to filter (mg/l)	Free residual chlorine for inlet water to filter (mg/l)	Free residual chlorine of filtered water (mg/l)	Free residual chlorine in network (mg/l)	color of water	Iron in well water	Iron before filter	Iron in filtered water	(Mn) in well water	Mn before filter	(Mn) in filtered water
22-11-2008	80	70	500	1.75	0.2	0.18	0.16	0.14	no color	0.36		0.09	0.4		0.36
23-11-2008	80	70	500	1.75	0.16	0.11	0.11	0.1	no color	0.38		0.12	0.34		0.3
24-11-2008	80	70	500	1.75	0.16	0.14	0.12	0.1	no color	0.38		0.1	0.36		0.33
25-11-2008	80	70	500	1.75	0.19	0.17	0.14	0.11	no color	0.26		0.08	0.38		0.36
26-11-2008	80	70	500	1.75	1.09	0.36	0.17	0.14	no color	0.36		0.1	0.34		0.31
27-11-2008	80	70	500	1.75	0.28	0.18	0.16	0.13	no color	0.28		0.09	0.38		0.35
29-11-2008	80	70	500	1.75	0.19	0.29	0.28	0.16	no color	0.36		0.08	0.38		0.35
2008/1/12	40	70	250	1.75	0.23	0.2	0.18	0.13	no color	0.36		0.09	0.36		0.32
2008/2/12	80	70	500	1.75	0.21	0.2	0.19	0.11	no color	0.41		0.1	0.35		0.31
2008/3/12	80	70	500	1.75	0.22	0.24	0.22	0.18	no color	0.35		0.08	0.4		0.35
2008/4/12	80	70	500	1.75	0.21	0.19	0.16	0.14	no color	0.36		0.08	0.4		0.35
2008/5/12	80	70	500	1.75	0.11	0.14	0.21	0.14	no color	0.28		0.19	0.38		0.33
2008/6/12	80	70	500	1.75	0.22	0.24	0.18	0.11	no color	0.35		0.1	0.38		0.32
2008/7/12	80	70	500	1.75	0.21	0.22	0.16	0.12	no color	0.28		0.1	0.07		
2008/8/12	80	70	500	1.75	0.23	0.19	0.18	0.14	no color	0.22		0.08			
2008/9/12	80	70	500	1.75	0.22	0.18	0.17	0.15	no color	0.19		0.07			

Average


Date	Chlorine consumption in the filtering process (mg/l)	Actual Dosing Rate of Chlorine (mg/l)
22-11-2008	0.02	1736.11
23-11-2008	0	1736.11
24-11-2008	0.02	1736.11
25-11-2008	0.03	1736.11
26-11-2008	0.19	1736.11
27-11-2008	0.02	1736.11
29-11-2008	0.01	1736.11
2008/1/12	0.07	1736.11
2008/2/12	0.09	1736.11
2008/3/12	0.06	1736.11
2008/4/12	0.05	1736.11
2008/5/12	0	1736.11
2008/6/12	0.13	1736.11
2008/7/12	0.1	1736.11
	0.05	1736.11
	0.03	1736.11
Average		1736.11

0.20


Date	Manganese removal (mg/l)
22-11-2008	0.04
23-11-2008	0.04
24-11-2008	0.03
25-11-2008	0.02
26-11-2008	0.03
27-11-2008	0.03
29-11-2008	0.03
2008/1/12	0.04
2008/2/12	0.04
2008/3/12	0.05
2008/4/12	0.05
2008/5/12	0.05
2008/6/12	0.06
2008/7/12	0.07
2008/8/12	0.00
2008/9/12	0.00

0.13


Relation between free residual chlorine concentration of inlet water and chlorine consumption in filter by day



Relation on free residual chlorine concentration between filter inlet water and filtered water by date



Relation between free residual chlorine of filter inlet water and manganese removal



3.10 Operation and Maintenance Plan for WTPs (Action S8)

O&M Plan
For
Water Treatment Plant
(The first step version)

SHAPWACO
H/Q Team and MF Team of Abbssa Water Treatment Plant
JICA Expert team

February-2009

5 – Staffing and Training (first step version)

- Organization Chart and Staff Allocation
 - ✧ Task Classification
 - ✧ Job Descriptions
- Training
 - ✧ SOP training
 - ✧ PC training

Note: SOP documents including Water Quality Control Program prepared in the Project will be referred to Chapters 2, 3 and 4.

“First step version” means collection of available information and compilation for improvement in the next O&M plan.

This O&P plan is the document as the first step version and the above all contents are not included in this plan. The all contents for O&M plan should be prepared in 2009. The prepared plan will be utilized for O&M activities at pleasure and documents for the content should be revised and added as needed.

Preface

O&P Plan should be developed by public water supplier to provide a written source of material that can be easily referred to guideline in operating water supply system.

O&M Plan will be a valuable reference tool for the operating personnel because standard operating procedures for the system and guidelines for start-up and emergency situation will be at their fingertips. The O&M Plan will also provide a ready reference for all equipment data which is necessary for performing normal maintenance and for ordering replacement parts and supplies. It will be an organized system for keeping records of the operation of the system. These records are useful for monthly and annual reports, as supporting documentation of proper operation, and to support the needs for replacement or upgrading of treatment facilities.

In SHAPWACO, SOPs for water supply facilities have been prepared for selected model facilities and the SOPs are applying to major activities in the water treatment process for the model facilities

Descriptions about facility component, operation criteria, operation procedures and so are included in SOPs. However, overall plan of O&M activities for the water supply facility are not included in SOPs. The O&M Plan should be necessary to compensate the starved description area in SOPs about planned activities and schedule of activities and so on.

SOPs and O&M Plan is a couple of the essential documents for water supply staffs.

O&M Plan contents were discussed by H/Q team and MF team of Abbassa WTP and proposed the contents as following.

“Operation & Maintenance Plan Contents for Abbassa WTP”

1 – Description of the Facility

- Overview
- Regulations
- **O&M Targets of the Facility**
- Equipment List

2 – Start-up and Normal Operating Procedures, Records and Reporting, and Quality Control

3 – Emergency Plan

4 – Planned Maintenance Program (first step version)

- Long term (Five-year) Plan
- Annual Maintenance Plan
- Equipment Data Base
 - ✧ Basic Equipment List
 - ✧ Individual Equipment List with a numbering system
 - ✧ Equipment Record Cards

I. Operation Plan

Decree Number 458 for the year 2007 by Ministry of health

1. Criteria & specifications for potable water

Limits for the criteria and specifications of the potable and domestic water

1-Natural Parameters:

Parameter	Maximum allowable limit
Color	Nil (nonexistent)
Taste	Acceptable
Odor	Nil (nonexistent)
Turbidity	1 unit (NTU)
PH-value	6.5-8.5

2-Inorganic materials which affect the taste and the domestic uses:

Parameter	Maximum allowable limit (mg/lit)
Total Dissolved Solids at 120 C° (TDS)	1000
Total hardness as CaCo	500
Calcium hardness as CaCo3	350
Magnesium hardness	150
Sulfates SO4	250
Chlorides Cl.	250
Iron (Fe)	0.3 mg/l
Manganese (MN)	0.4 mg/l
Copper (Cu)	2.0

Zinc (Zn)	3.0
Sodium (Na)	200
Aluminum (Al)	0.2

3- Chemical substances which affect on general health:

a) Inorganic materials

Parameter	Maximum allowable limit (mg/lit.)
Lead (Pb)	0.01
Mercury (Hg)	0.001
Arsenic (As)	0.01
Cyanide (Cn)	0.05
Cadmium (Cd)	0.003
Selenium (Se)	0.01
Chromium (Cr)	0.05
Ammonia as NH3	0.5
Nitrates as NO3	45
Nitrites as NO2	0.2
Fluorides F	0.8
Antimony Sb	0.02
Barium Ba	0.7
Boron B	0.5
Nickel Ni	0.02
Molybdenum Mo	0.07

b) Organic materials

Parameter	Maximum allowable limit(mg/lit)
Alchlor	0.02
Aldicarb	0.01
Dialdrin/Aldrin	0.00003
Atrazine	0.002
Bentazon	0.03
Carbofuran	0.007
Chlordan	0.0002
Chlprtoruion	0.03
D.D.T	0.001
1,2 Dibromo 3chloropropance(DBCP)	0.001
2,4 Dichlorophenoxyacetic acid (2,4 D)	0.03
1,2 Dichloropiopanc (1,2-DCP)	0.02
Hexachlorobenzene Isoproturon lindane	0.001
MCPA (Methylchlorophenoxyacetic acid)	0.002
Methoxchlor	0.02
Metolachlor	0.01
Molinate	0.006
Pendimethalin	0.02
Pentachlorophenol	0.009
Permethrin	0.02
Propanil	0.02
Smazine	0.002

Trifluralin	0.02
4,2 D B	0.09
2,4 Dichloroprop	0.01
Fenoprop	0.009
Mecoprop	0.01
2,4,5, T	0.009

Other organic materials:

Tributyltin Oxide	0.002
Phenol	0.002
Monochloramine	0.3
Di and Trichloramine	0.005
Bromate	0.01
Chlorate	0.7
2,4,6 Trichlorophenol	0.2
Trihalomethanes	0.1
Dichloroacetate	0.05
Trichloroacetate	0.1
Trichloroacetaldehyde	0.01

4- Microbiological Criteria:

a- Total bacteria count

By the Poured plate method
 (1) At 37° for 24 hours not exceeding 50cell/cm³
 (2) A 22° for 48 hours not exceeding 50cell/cm³

b- Pollutants:

1- Total coliform
 95 % from the samples checked during the year must be free of any coliform bacteria in 100cm³ of the sample.
 The sample must not contain more than 3 cell/100cm³ conditioned that this case has to be repeated in two consequent samples from the same source.
 2- Fecal coliform
 All samples must not contain any fecal coliform
 3-Fecal Streptococci
 All samples must not contain any fecal Streptococci

c- Biological check:

During the checking the water microscopically it must not contain Protozoa, all kinds of worms causing diseases.
 Microsetin should not be more than 1 microgram/L. This analysis will be applied in case that green algae appears.

5- Radiation substances:

Derivatives from Alfa type (A) 0.1 Bico curri /l
 Derivatives from Beta type (B) 1.0 Bico curri /l

Health of Ministry
 Protective affairs undersecretary

Criteria and specifications for the potable and domestic use water which admitted by high water committee in 26/2/1995

1-Natural Parameters:

Parameter	Maximum allowable limit
Color	20-30 as a maximum limit using platinum cobalt
Taste	Accepted
Odor	Nonexistence
Turbidity	5 NTU for surface water 10 NTU for ground water
PH-value	6.5-9.2

2-Inorganic materials which affect the taste and the domestic uses:

Parameter	Maximum allowable limit
Dissolved salts at 120m	1200mg/l
Iron (Fe)	0.3 mg/l for surface water 1.0 mg/l for ground water
Manganese (MN)	0.1 mg/l for surface water 0.5 mg/l for ground water
Copper (Cu)	1.0 mg/l
Zinc (Zn)	5.0 mg/l
Total hardness as CaCo	500mg/l
Calcium (Ca)	200mg/l
Magnesium (Mg)	150mg/l

Sulphates (So4)	400mg/l
Chlorides (Cl)	500mg/l
Sodium (Na)	200mg/l
Aluminum (Al)	0.2mg/l
Calcium ions balance	±0.1

3- Chemical substances which affect on general health:

a) Inorganic materials

Parameter	Maximum allowable limit
Lead (Pb)	0.05mg/l
Arsenic (As)	0.05mg/l
Cyanide (Cn)	0.05mg/l
Cadmium (Cd)	0.005mg/l
Selenium (So)	0.01mg/l
Mercury (Hg)	0.001mg/l
Chromium (Cr)	0.05mg/l
Nitrates	10mg/l
Nitrites	0.005mg/l
Fluorides	0.8mg/l

b) Organic materials

1- Pesticides

Parameter	Maximum allowable limit(micro gram/l)
Alchlor	20
Aldicarb	10
Dialdrin/Aldrin	0.03
Atrazinc	2

Bentazon	30
Carbofuran	5
Chlordanc	0.2
Chlprtofuion	30
D.D.T	2
1.2 Dibromo chloropropane	1
4.2 D	30
1.2 Dichloropiopanc	20
Hexachlorobenzene Isoproturon lindane	20
MCPA (chlorophenoxy)	1
Methoxchlor	9
Metolachlor	2
Molinate	2
Pendimethalin	20
Pentachlorophenol	10
Permethrin	6
Propanil	20
smazine	9
Trifluralin	20

2- Chlorophenoxy herbicides other than 4.2 D and MCPA

4.2 D B	90
2.4 Dichloroprop	100
Fenoprop	9
Mecoprop	10
2,4,5, T	9

3- Other organic materials:

Tributyltin Oxide	2
Phenol	2

Disinfectants and disinfectants by product

Monochloramine	3
Diand Trichloramine	5
Bromate	25
Chlorite	200
Triglorophonal	200
Trihalomethanes	100

Chlorinated Acetic acids

Dichloro acetic acid	50
Trichloro acetic acid	100
Trichloro acetylaldehyde	10

Halogenated acetonitriles

Dichloro acetonitrile	90
Dibromo acetonitrile	100
Trichloro acetonitrile	1
Cyanogen Chloride	70

Chlorinated Alkanes

Carbon tetrachloride	2
Dichloromethane	20
1,2 Dichloroethane	30
1,1,1 trichloroethane	200

Chlorinated Ethanes

Phenyl chloride	5
1,1 Dichloroethane	30
1,2 Dichloroethane	50
TriChloroethane	70
Tetrachloroethane	40
Total Hydrocarbons as Toluene	100
Benzene	10
Benzopyrine	0.7

Chlorinated Benzenes

Monochlorobenzene	300
1.2 Dichlorobenzene	1000
4.1 Dichlorobenzene	300
Trichlorobenzene	20
Di (Ethylhexyl) adipate	80
Di (Ethylhexyl) phthalate	8
Acrylimide	0.5
Hyperchlorohydrane	0.4
Hexachlorobutadiene	0.6
Edetic acid (EDTA)	200
Nitrotriacetie	200

name of equipment	name of facility	Nos.	Year of construction	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				additional condition	repair	replace		
1 Intake raw water basin	1-1 Intake raw water basin	2	1957-2004				local-German	
	1-2 Screen	2	1957-2004				local	
	1-3 Grate	1	2004				Tchek	1000mm diameter
2 Raw water reservoir	2-1 Raw water reservoir	3	1957-2004				local-German	800mm diameter
	2-2 Screen	6	2000-2004				local-German	
	2-3 Grate	1	2004				local	
3 Raw water pump	3-1 Raw water storage basin	4	1959				German	
	3-2 Raw water pump -Type 1	4	1959				German	
	3-3 Raw water pump -Type 2	4	1959				German	
4 Receiving well	4-1 pressure gauge	5	1994				Tchek	
	4-2 piping & valves	12	1957-1994				Tchek	
	4-3 Reserving well	2	1994				German/Tchek	
5 Flocculation basin	5-1 shaft & girdle	4	1994				local	
	5-2 Raw water flocculator	4	1994				local	
	5-3 flocculation basin	7	1959-1994				local	
6 Sedimentation basin	6-1 drive unit	22	1959-1994				local	
	6-2 common base	28	1959-1994				local	
	6-3 Sludge collector	29	1959-1994				local	
7 Sludge drainage	7-1 drive unit	7	1959-1994				German	
	7-2 common base	7	1959-1994				German	
	7-3 collector blade unit	14	1959-1994				German	
8 Rapid sand filter	8-1 drainage pump	6	1959-1994				German	
	8-2 motor	6	1959-1994				German	
	8-3 piping & valves	6	1959-1994				German	
9 Clear water reservoir	9-1 rapid sand filter basin	15	1959-1974				German	
	9-2 piping & valves	28	1994				in interval	the depth for the filter medium is 150mm sand and 20cm gravel
	9-3 composition of filter layer	4					in interval	32-64mm sand and 20cm gravel
10 Alum dosing facility	10-1 gravel 1	1					in interval	8-16mm3 gravel depth 20cm
	10-2 gravel 2	1					in interval	2-4mm3 gravel depth 5cm
	10-3 gravel 3	1					in interval	0.6-1.5mm3 gravel depth 1.15m

2. Equipment List

4. Microbiological Criteria:

a- Total bacteria count

- By the Poured plate method
- (1) at 37° for 24 hours not exceeding 50cell/cm³
- (2) at 22° for 48 hours not exceeding 50cell/cm³

b- Pollution evidences:

- 1- Total coliform
- 95 % from the samples checked during the year must be unoccupied by any coliform bacteria in 100cm³ from the sample.
- The sample must not contain more than 3 cell/100cm³ conditioned that this case has to be repeated in two consequent samples from the same source.
- 2- Fecal coliform
- All samples must not contain any fecal coliform
- 3-Fecal Streptococci
- All samples must not contain any fecal Streptococci

c- Biological check:

During the checking the water microscopically it must not contain Protozoa ,all kinds of worms causing diseases and bluegreen algae.

5- Radiation substances:

- Derivatives from Alfa type (A) 0.1 microcurri /l
- Derivatives from Beta type (B) 1.0 microcurri /l

name of equipment	name of facility	Nos.	Year of construction	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				additional condition	repair	replace		
1 Intake raw water basin	1-1 Intake raw water basin	2	1957-2004				local-German	
	1-2 Screen	2	1957-2004				local	
	1-3 Grate	1	2004				Tchek	1000mm diameter
2 Raw water reservoir	2-1 Raw water reservoir	3	1957-2004				local-German	800mm diameter
	2-2 Screen	6	2000-2004				local-German	
	2-3 Grate	1	2004				local	
3 Raw water pump	3-1 Raw water storage basin	4	1959				German	
	3-2 Raw water pump -Type 1	4	1959				German	
	3-3 Raw water pump -Type 2	4	1959				German	
4 Receiving well	4-1 pressure gauge	5	1994				Tchek	
	4-2 piping & valves	12	1957-1994				Tchek	
	4-3 Reserving well	2	1994				German/Tchek	
5 Flocculation basin	5-1 shaft & girdle	4	1994				local	
	5-2 Raw water flocculator	4	1994				local	
	5-3 flocculation basin	7	1959-1994				local	
6 Sedimentation basin	6-1 drive unit	22	1959-1994				local	
	6-2 common base	28	1959-1994				local	
	6-3 Sludge collector	29	1959-1994				local	
7 Sludge drainage	7-1 drive unit	7	1959-1994				German	
	7-2 common base	7	1959-1994				German	
	7-3 collector blade unit	14	1959-1994				German	
8 Rapid sand filter	8-1 drainage pump	6	1959-1994				German	
	8-2 motor	6	1959-1994				German	
	8-3 piping & valves	6	1959-1994				German	
9 Clear water reservoir	9-1 rapid sand filter basin	15	1959-1974				German	
	9-2 piping & valves	28	1994				in interval	the depth for the filter medium is 150mm sand and 20cm gravel
	9-3 composition of filter layer	4					in interval	32-64mm sand and 20cm gravel
10 Alum dosing facility	10-1 gravel 1	1					in interval	8-16mm3 gravel depth 20cm
	10-2 gravel 2	1					in interval	2-4mm3 gravel depth 5cm
	10-3 gravel 3	1					in interval	0.6-1.5mm3 gravel depth 1.15m

name of equipment	name of facility	Nos	year of constructed	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				additional construction	repair	replace		
chlorination facility	pump	2	1994				German	
	attached parts	4	1994				local	
	2) exhaust fan	0	1994					
	motor	12	1994				Tchek	
	Fan	12	1994				Tchek	
	attached parts	0						
	3) caustic soda solution tank	0						
	caustic soda solution tank	1	1994					
	solution tank	1	1994				Tchek	
	4) solution tank	1	1994					
	12-1) drainage basin							
	2) drainage pump							
	3) pipes & valves							
12-2) sludge drainage basin								
1) sludge drainage basin								
2) sludge thickener								
3) common base								
13-1) collector blade unit								
3) drainage pump								
13) treated water pump								
13-1) pump - type 1	4	1959				German	800mm cast iron main to Abu Hamad-	
motor	4	1959				German	900mm steel coated main to Zagazig-	
pressure gauge	2	1994				Tchek	900mm asbestos main to Papeete-	
13-2) pump - type 2	2	1994				Tchek	to prevent ground water leakage and	
pressure gauge	2	1994				Tchek	prevent mix of oil with water	
14-1) generator	1	1984				Tchek		
14-2) oil tank	1	1994				Tchek		
15-1) electrical switch board	2	1994				Tchek		
15-2) for Flow water pump	2	1994				Tchek		
15-3) for Flush motor	2	1994				Tchek		
15-4) for Flocculator	2	1994				Tchek		
15-5) for Flocculator	2	1994				German/Tchek		
15-6) for Flocculator	2	1994				German/Tchek		
15-7) for Flocculator	2	1994				German/Tchek		
15-8) for Flocculator	2	1994				German/Tchek		

name of equipment	name of facility	Nos	year of constructed	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				additional construction	repair	replace		
16) Stand-by generator	16-1) for Backwash pump	3	1994				Tchek	
	16-2) for chlorinator	3	1994				German	
	16-3) for Alum solution tank agitator	4	1994				Tchek	
	16-4) for chlorinator	0						
	16-5) for chlorinator	0						
	16-6) for chlorinator	2	1994				Tchek	
	16-7) for exhaust fan	12	1994				Tchek	
	16-8) for distribution pump	0						
	16-9) for treated water pump	0						
	16-10) for treated water pump	0						
	16-11) for sludge drainage pump	0						
	16-12) for sludge thickener	0						
	16-13) for Stand by generator	6	1994- 1994				Tchek	
	16-14) for Stand by generator	6	1994- 1994					
	16-15) for Stand by generator	6	1994- 1994					
	16-16) for Stand by generator	6	1994- 1994					
	16-17) for Stand by generator	6	1994- 1994					
	16-18) for Stand by generator	6	1994- 1994					
17) Transformer								
17-1) transformer 1	2	1959				German		
17-2) transformer 2	2	1994				Tchek		
17-3) transformer 3	2	1994				Tchek		
17-4) transformer 4	1	1959						
17-5) Chemical laboratory	1	1959						
17-6) Chemical laboratory	1	1959						
17-7) Chemical laboratory	1	1959						
17-8) Chemical laboratory	1	1959						
17-9) Chemical laboratory	1	1959						
17-10) Chemical laboratory	1	1959						
18) Maintenance equipment								
18-1) Moving tracks	2	1994				local	ABB1	
18-2) Workshop equipment	1	1957				England/local	Big Lathers & equipments	
18-3) Emergency device for chlorine gas	1	1957						
18-4) Emergency device for chlorine gas	1	1957						
19) Safety equipment								
19-1)								
19-2)								
19-3)								
19-4)								
19-5)								

name of equipment	name of facility	Nos	year of constructed	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)	
				additional construction	repair	replace			
1) Intake raw water basin	1-1) Intake raw water basin	3	2000				local	three local manual valves	
	1-2) screen	3	2000				local		
	1-3) Crane	0					local		
	1-4) number of lines for old intake	0							
	1-5) number of lines for raw intake	0							
	2) Raw water reservoir	2-1) Raw water reservoir	1	1994					600mm diameter
		2-2) Screen	0						500mm diameter
	3) Raw water pump	3-1) Raw water storage basin	1	1994				local	
		3-2) Raw water pump - type 1	1	1994					
		motor	3	1994				Tchek	38 kilowatt
		pump	3	1994	periodically maintenance			Tchek	
pressure gauge		3	1994	periodically maintenance			Roman		
3-3) Raw water pump - type 2		2	1994				Tchek	21 kilowatt	
motor		2	1994	periodically maintenance			Tchek		
pump		2	1994	periodically maintenance			Tchek		
pressure gauge		2	1994	periodically maintenance			Tchek		
3-4) piping & valves		5	1994						
4) Recirculation well									
4-1) Recirculation well	1	1994							
4-2) Flush meter	1	1994				Baby			
4-3) common base	1	1994				Baby			
4-4) shaft & paddle	1	1994				Baby			
5) Flocculation basin									
5-1) Flocculation basin	2	2000							
5-2) flocculator	2	2000							
5-3) drive unit	2	1994				Baby			
5-4) common base	2	1994				Baby			
5-5) shaft & paddle	2	1994				Baby			
6) Sedimentation basin									
6-1) Sedimentation basin	2	2000				Baby			
6-2) drive unit	2	1994				Baby			
6-3) common base	0					Baby			
6-4) drive unit	2	1994				Baby			
6-5) common base	2	1994				Baby			
6-6) collector blade unit	2	2000				Baby			
6-7) sludge pump	2	2000				France			
6-8) motor	2	2000				France	110 kilowatt		
6-9) pump	2	2000				France			
6-10) pressure gauge	2	2000				France			

name of equipment	name of facility	Nos	year of constructed	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				additional construction	repair	replace		
8) Rapid sand filter	8-1) piping & valves	3	2000				local	
	8-2) rapid sand filter basin	6	2000				local	
	8-3) composition of filter layer	1	2000				local	0.9mm - 7mm
	8-4) sand 1	1	2000				local	1.5mm - 2.5mm
	8-5) sand 2	1	2000				local	2.5mm - 3.5mm
	8-6) sand 3	1	2000				local	3.5mm - 7mm
	8-7) gravel 1	1	2000				local	
	8-8) gravel 2	1	2000				local	
	8-9) operation desk	6	2000				local	gravity flow
	8-10) backwash pump	2	2000				Tchek	125 kilowatt
9) clear water reservoir	9-1) pump	2	2000				Tchek	
	9-2) sludge gauge	2	2000				Tchek	
	9-3) storage for air wash	2	2000				Roman	
	9-4) blower	2	2000				France	90 kilowatt
	9-5) air storage tank	1	2000				local	
	9-6) clear water reservoir	2	1994				local	
	9-7) clear water reservoir	2	1994				local	each the capacity is 1000m3
	9-8) piping & valves	4	1994				local	2 sampls pumps
	9-9) other auxiliary	2	1994				Baby	
	9-10) alum storage yard	0	1994				local	
	9-11) alum storage tank	3	2000				local	
10) Alum dosing facility	10-1) alum storage tank	3	2000				local	
	10-2) liquid alum receiver tank	3	2000				local	
	10-3) liquid alum receiver tank	3	2000				local	
	10-4) agitator of solution tank	3	2000				local	
	10-5) alum dosing pump type 1	3	1994				Baby	
	10-6) alum dosing pump type 2	3	1994				local	
	10-7) alum dosing pump	3	2000				Baby	
	10-8) alum dosing pump	3	2000				Baby	
	10-9) pressure gauge	4	2000				Baby	
	10-10) backpressure valve	1	2000				local	
	10-11) relief valve	1	2000				local	
	10-12) strainers & valves	8	2000				local	
	10-13) cylinder storage base	2	2000				local	
11) chlorination facility	11-1) copper tube for chlorine gas	8	2000				local	
	11-2) auxiliary valves	0	2000				local	
	11-3) chlorine dosing device	2	2000				local	
	11-4) chlorine gas filter	2	2000				Baby	
	11-5) pressure for chlorine gas	2	2000				Baby	
	11-6) chlorine gas filter	2	2000				Baby	
	11-7) pre-chlorinator	2	2000				Baby	
	11-8) intermediate chlorinator	0					Baby	one of them is not working
	11-9) intermediate chlorinator	0					Baby	one of them is not working
	11-10) injector unit for gas chlorinator	1	2000				Baby	
	11-11) injector unit for gas chlorinator	1	2000				Baby	
11-12) injector unit for post chlorinator	1	2000				Baby		
11-13) piping & valves	0					Baby		

name of equipment	name of facility	Nos.	year of construction	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				repair	replace	cleaning of basin or tank		
1) intake raw water basin	1-1) intake raw water basin	2	1999			Arab contractors		
2) Raw water reservoir	2-1) Raw water reservoir	3	1999			Arab contractors		
3) Raw water pump	3-1) Raw water storage basin 3-2) Raw water pump (Type 1) 3-3) Raw water pump (Type 2)	4	1999			Arab contractors		
4) Receiving well	4-1) Receiving well	4	1999			Arab contractors		
5) Flocculation basin	5-1) flocculation basin 5-2) flocculator	30	1999			Arab contractors		
6) Sedimentation basin	6-1) Sedimentation basin 6-2) Sludge collector	12	1999			ZPA Pecky		
7) Sludge drainage	7-1) Sludge pump 7-2) Sludge collector	12	1999			ZPA Pecky		
8) Rapid sand filter	8-1) Rapid sand filter basin 8-2) Backwash pump 8-3) Operation desk	1	1999			FLYGT		

name of equipment	name of facility	Nos.	year of construction	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				repair	replace	cleaning of basin or tank		
1) Backwash pump	1-1) Backwash pump	2	1999			Arab contractors		
2) Raw water reservoir	2-1) Raw water reservoir	3	1999			Arab contractors		
3) Raw water pump	3-1) Raw water storage basin 3-2) Raw water pump (Type 1) 3-3) Raw water pump (Type 2)	4	1999			Arab contractors		
4) Receiving well	4-1) Receiving well	4	1999			Arab contractors		
5) Flocculation basin	5-1) flocculation basin 5-2) flocculator	30	1999			Arab contractors		
6) Sedimentation basin	6-1) Sedimentation basin 6-2) Sludge collector	12	1999			ZPA Pecky		
7) Sludge drainage	7-1) Sludge pump 7-2) Sludge collector	12	1999			ZPA Pecky		
8) Rapid sand filter	8-1) Rapid sand filter basin 8-2) Backwash pump 8-3) Operation desk	1	1999			FLYGT		

name of equipment	name of facility	Nos.	year of construction	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				repair	replace	cleaning of basin or tank		
13) Feeded water pump	13-1) Feeded water pump	3	1994			tehrak motor		
15) Electrical switch board	15-1) Electrical switch board	6	2000			Roman		

name of equipment	name of facility	Nos.	year of construction	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				repair	replace	cleaning of basin or tank		
14) Stand by generator	14-1) Stand by generator	2	2000			USA	400 & 800kw generator	
15) Electrical switch board	15-1) Electrical switch board	4	2006			local	12 volt American General selector key	
16) Transformer	16-1) Transformer	2	1994			Egypt	2000KVA	
17) Chemical laboratory	17-1) Chemical laboratory	1	1994			local	Laboratory for water analysis	
18) Maintenance equipment	18-1) Maintenance equipment	5	1994			local	Laboratory for water analysis	
19) Safety equipment	19-1) Safety equipment	4	1994			local	Laboratory for water analysis	

name of equipment	name of facility	Nos.	year of construction	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				repair	replace	cleaning of basin or tank		
9) Clear water reservoir	9-1) Clear water reservoir	2	1999			Arab contractors		
10) Alum dosing facility	10-1) Alum storage tank 10-2) Alum solution tank 10-3) Alum dosing pump (Type 1) 10-4) Alum dosing pump (Type 2) 10-5) Alum dosing pump (Type 3)	3	1999			Arab contractors		
11) Chlorination facility	11-1) Chlorinator 11-2) Chlorinator 11-3) Chlorinator 11-4) Chlorinator 11-5) Chlorinator 11-6) Chlorinator 11-7) Chlorinator 11-8) Chlorinator 11-9) Chlorinator 11-10) Chlorinator 11-11) Chlorinator 11-12) Chlorinator 11-13) Chlorinator 11-14) Chlorinator	4	1999			WALACE & TIERNAN		

name of equipment	name of facility	Nos.	year of construction	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				repair	replace	cleaning of basin or tank		
14) Stand by generator	14-1) Stand by generator	2	2000			USA	400 & 800kw generator	
15) Electrical switch board	15-1) Electrical switch board	4	2006			local	12 volt American General selector key	
16) Transformer	16-1) Transformer	2	1994			Egypt	2000KVA	
17) Chemical laboratory	17-1) Chemical laboratory	1	1994			local	Laboratory for water analysis	
18) Maintenance equipment	18-1) Maintenance equipment	5	1994			local	Laboratory for water analysis	
19) Safety equipment	19-1) Safety equipment	4	1994			local	Laboratory for water analysis	

NEW FAQUS WTP

name of equipment	name of facility	Nos.	year of constructed	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				additional construction	repair	replace		
1 Intake raw water basin	1-1 Intake raw water basin	1	1995			in intervals	local	3 manual local valves
1-2 screen		12	1995			in intervals	local	2 balanced rot. exist
1-3 Crane		2	1995		not working	do not	local	
1-4 Number of float for the intake		2				in intervals	local	600mm diameter
2 Raw water reservoir	2-1 Raw water reservoir	1	1995			in intervals	local	1000m ³ concrete
2-2		0						
2-3		0						
3 Raw water pump	3-1 Raw water storage basin	4	1980		periodically	in intervals	Tchek	8 suction thrust valves & 1000mm dia concrete
3-2	Raw water pump - type 1 motor	4	1980		periodically	in intervals	Tchek	
3-3	pressure gauge	8	1990		periodically	in intervals	Tchek	
3-4	water pump - type 2	0			not working	not working	Tchek	
3-5	motor	0						
3-6	pressure gauge	0	1995		greasing	in intervals	Tchek	
3-7	drainage & valves	0	1995			in intervals	Tchek	
4 Roving well	4-1	3	1980		gear box	in intervals	Tchek	
4-2	float mixer	3	1980		gear box	in intervals	Tchek	
4-3	drive unit	3	1995			in intervals	local	
4-4	common base	3	1995			in intervals	local	
4-5	float & valve	1	1980		not working	in intervals	Tchek	Fruchtoury
5 Flocculation basin	5-1 Flocculation basin	3	1995		not working	in intervals	local	
5-2	floculator	3	1995		need to repair	in intervals	local	need to change the paddles & repaint
5-3	drive unit	24	1990			in intervals	Tchek	concrete
5-4	drive unit	24	1995			in intervals	local	concrete type gravelly flow
5-5	shaft & paddle	24	1995			in intervals	local	18 for slow mixer 3 float mixer & 3 brd
6 Sedimentation basin	6-1 Sedimentation basin	3	1995			in intervals	local	
6-2	drive unit	3	1995			in intervals	local	
6-3	drive unit	24	1995			in intervals	local	
6-4	bridge	3	1995			in intervals	local	
6-5	collector blade unit	3	1995			in intervals	local	
7 Sludge drainage	7-1 drainage pump	2	1980			in intervals	swedish	
7-2	pressure gauge	2	1995			in intervals	local	
7-3	pressure gauge	10	1990			in intervals	local	1.8 bar
7-4	rapid sand filter basin	8	1995			in intervals	Tchek	7 valves suction & throat lines
7-5	pressure gauge	8	1995			in intervals	local	supply along with the depth turn in
8 Rapid sand filter	*8-1 rapid sand filter basin	4	1999			in intervals	local	1800mm (1.8m) sand and 45 cm gravel
*8-2	composition of filter layer	1	1989			in intervals	local	132-64mm ² gravel depth 20cm
*8-3	gravel 1	1	1989			in intervals	local	

name of equipment	name of facility	Nos.	year of constructed	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				additional construction	repair	replace		
chlorination facility	attached parts	2	1999					
	drainage & valves	24	1999			in intervals	Ozonovalnikh	2 automatic fans & 2 low pressure fans
	float tank	4	1999			in intervals		
	motor	4	1999			in intervals		
	attached parts	24	1999			in intervals		
	pressure gauge	24	1999			in intervals		
	coastic soda solution tank	2%	1999			in intervals	Arab contractors	
	sealant tank	1	1999			in intervals		
12 drainage facility	1-1 reaction & absorption tower	1	1999			in intervals		
	1-2 drainage basin	1	1999			in intervals		
	2-1 drainage pump	2	1999			in intervals		
	motor	2	1999			in intervals		
	3-1 pump & valves	3	1999			in intervals		
	12-2 sludge drainage basin	4	1999			in intervals		
	1-1 sludge thickener	1	1999			in intervals		
	drive unit	4	1999			in intervals		
	collector blade unit	4	1999			in intervals		
	bridge	4	1999			in intervals		
	3-1 drainage pump	2	1999			in intervals		
13 Treated water pump	1-3-1 pump - type 1	4	1999			in intervals	Sigma	
	motor	4	1999			in intervals	Sigma	
	pressure gauge	4	1999			in intervals	Sigma	
	1-3-2 pump - type 2	2	1999			in intervals		
	motor	2	1999			in intervals		
	pump	2	1999			in intervals		
	drive unit	2	1999			in intervals		
	1-4-1 generator	3	1999			in intervals	Dorman	1000mm diameter pre-tressed
14 Stand-by generator	1-4-2 of tank	1	1995			in intervals		
	1-5-1 battery	13	1999			in intervals	MEMCO	
	1-5-2 for float mixer	13	1999			in intervals	MEMCO	for all raw water pumps
15 Electrical switch board	1-5-3 for float mixer	10	1999			in intervals	MEMCO	
	1-5-4 for sludge collector	6	1999			in intervals	MEMCO	
	1-5-5 for Alum solution pump	2	1999			in intervals	MEMCO	
	1-5-6 for Alum solution tank agitator	2	1999			in intervals	MEMCO	
	1-5-7 for Alum solution tank agitator	2	1999			in intervals	MEMCO	

NEW FAQUS WTP

name of equipment	name of facility	Nos.	year of constructed	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				additional construction	repair	replace		
filter	gravel 2	1	1989			in intervals	local	8-16mm ² gravel depth 20cm
	gravel 3	1	1989			in intervals	local	2-4mm ² gravel depth 15cm
	sand 2	0				in intervals	local	0.1-1.5mm ² gravel depth 11.5m
	sand 3	0				in intervals	local	control air valves
*8-2	operation desk	8	1995			in intervals	local	
*8-3	Type of distribution	3	1995			in intervals	local	by gravity flow
*8-4	pressure gauge = suction	2	1991			in intervals	Tchek	1.0 KW power
*8-5	pressure gauge = suction	4	1995			in intervals	Tchek	4.15 /sec. flow rate
*8-6	blower for air wash	2	1991			in intervals	German	1.8 bar suction, 1.8 bar thrust
*8-7	air storage tank	2	1991			in intervals	France	245 KW power
*8-8	drainage & valves	1	1995			in intervals	local	2m ³ capacity 3 horse power with pressure
*8-9	pressure gauge	2	1995			in intervals	local	0.1-1.5mm ² gravel depth 11.5m
*8-10	drainage & valves	2	1995			in intervals	Tchek	4 valves 1.8 bar tank 1200mm
*8-11	other auxiliary	0				in intervals	local	
10 Alum dosing facility	10-1 alum storage yard	1	1995			in intervals	local	concrete and far from the field
	10-2 alum solution tank	3	1995			in intervals	local	concrete
	10-3 alum solution tank	3	1995			in intervals	local	concrete
	10-4 agitator of solution tank	3	1995			in intervals	Finland	
	10-5 alum dosing pump type 1	3	1995			in intervals	Finland	
	10-6 alum dosing pump type 2	3	1995			in intervals	Finland	
	10-7 alum dosing pump type 3	3	1995			in intervals	Tchek	pressure resistant
	10-8 pressure gauge	2	1995			in intervals	Tchek	Emergency valves for chlorine gas
	10-9 backpressure valve	2	1995			in intervals	Tchek	
	10-10 relief valve	2	1995			in intervals	Tchek	
	10-11 strainer	2	1995			in intervals	Tchek	
	10-12 piping & valves	12	1995			in intervals	Tchek	3 valves 1.3 valves 2.3 pipes 40mm, 1 pipe 100mm, 1 pipe 40mm
11 Chlorination facility	11-1 cylinder storage base	2	1995			in intervals	Tchek	need to be replaced
	11-2 support ribs for chlorine gas	6	2001			in intervals	local	
	11-3 cylinder changeover device	1	1995			in intervals	German	exist in the cylinders room
	11-4 pressure gauge for chlorine gas	1	1995			in intervals	German	
	11-5 chlorine gas filter	2	1991			in intervals	German	
	11-6 chlorine gas filter	0	1991			in intervals	local	
	11-7 chlorine gas filter	0	1991			in intervals	local	
	11-8 motor unit for a/c chlorinator	2	1991			in intervals	local	
	11-9 motor unit for a/c chlorinator	2	1991			in intervals	local	
	11-10 motor unit for int. chlorinator	0				in intervals	local	
	11-11 motor unit for int. chlorinator	0	1991			in intervals	local	
	11-12 motor unit for post chlorinator	8	1991			in intervals	local	4 valves 4.4 valves 1.5" pipes 1.5" and 2"
	11-13 pipes & valves	8	1991			in intervals	local	
	11-14 water booster pump for chlorination	1	1991			in intervals	local	1 set low 2" & end low 1.5"

name of equipment	name of facility	Nos. constructed	year of construction	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				repair	replace	cleaning of basin or tank		
1 Intake raw water basin	1-1 Intake raw water basin	1	1988	write		weekly	Egypt	
	1-2 Inlet screen	0	1989		write		Egypt	300mm diameter and far from the station & in wire net.
2 Raw water reservoir	2-1 Raw water reservoir	0					local	
	2-2 Screen pump	0		write		weekly	Egypt	
3 Raw water pump	3-1 Raw water storage basin	1	1932			weekly	local	
	3-2 Raw water pump -Type 1	2		write		weekly	Egypt	
4 Receiving well	4-1 Receiving well	4	1995				local	
	4-2 Intake motor	0					Egypt	
5 Flocculation basin	5-1 Flocculation basin	1	1977	fan	do	monthly	Egypt	
	5-2 Flocculation basin	0					local	
6 Sedimentation basin	6-1 Shaft & paddle	0	1932	write		weekly	local	
	6-2 Sludge collector	0					local	
7 Sludge drainage	7-1 Drainage pump	0					local	
	7-2 Drainage pump	0					local	
8 Rapid sand filter	8-1 Rapid sand filter basin	2	1932-1937	maintenance			England/Egypt	
	8-2 Composition of filter layer	3	1932	write		Daily	England/Egypt	
9 Solar water reservoir	9-1 Solar water reservoir	1	1924			weekly	local	
	9-2 Backpressure valve	0					local	
10 Alum dosing facility	10-1 Alum storage tank	1	2004			weekly	local	
	10-2 Alum storage tank	1				weekly	local	
11 Chlorination facility	11-1 Chlorination tank	2	1932			weekly	local	
	11-2 Chlorinator	0					local	
12 Drainage facility	12-1 Drainage basin	1	1995				local	
	12-2 Drainage pump	1	1995				local	
13 Stand-by generator	13-1 Stand-by generator	1	1980	not working			England	
	13-2 Stand-by generator	3	1980	not working			England	

name of equipment	name of facility	Nos. constructed	year of construction	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				repair	replace	cleaning of basin or tank		
15 Electrical switch board	15-1 Electrical switch board	6	1980				England	
	15-2 Fluorometer	4	1991				local	
16 Transformer	16-1 Transformer	2	1995				local	
	16-2 Transformer	2	1995				local	
17 Chemical laboratory	17-1 Chemical laboratory	1	1980				local	
	17-2 Chemical laboratory	1	1980				local	
18 Maintenance equipment	18-1 Maintenance equipment	3	1995				local	
	18-2 Maintenance equipment	2	1980				local	
19 Safety equipment	19-1 Safety equipment	2	1980				local	
	19-2 Safety equipment	1	1980				local	

name of equipment	name of facility	Nos. constructed	year of construction	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				repair	replace	cleaning of basin or tank		
1 Intake raw water basin	1-1 Intake raw water basin	1	1988	write		weekly	Egypt	
	1-2 Inlet screen	0	1989		write		Egypt	300mm diameter and far from the station & in wire net.
2 Raw water reservoir	2-1 Raw water reservoir	0					local	
	2-2 Screen pump	0		write		weekly	Egypt	
3 Raw water pump	3-1 Raw water storage basin	1	1932			weekly	local	
	3-2 Raw water pump -Type 1	2		write		weekly	Egypt	
4 Receiving well	4-1 Receiving well	4	1995				local	
	4-2 Intake motor	0					Egypt	
5 Flocculation basin	5-1 Flocculation basin	1	1977	fan	do	monthly	Egypt	
	5-2 Flocculation basin	0					local	
6 Sedimentation basin	6-1 Shaft & paddle	0	1932	write		weekly	local	
	6-2 Sludge collector	0					local	
7 Sludge drainage	7-1 Drainage pump	0					local	
	7-2 Drainage pump	0					local	
8 Rapid sand filter	8-1 Rapid sand filter basin	2	1932-1937	maintenance			England/Egypt	
	8-2 Composition of filter layer	3	1932	write		Daily	England/Egypt	
9 Solar water reservoir	9-1 Solar water reservoir	1	1924			weekly	local	
	9-2 Backpressure valve	0					local	
10 Alum dosing facility	10-1 Alum storage tank	1	2004			weekly	local	
	10-2 Alum storage tank	1				weekly	local	
11 Chlorination facility	11-1 Chlorination tank	2	1932			weekly	local	
	11-2 Chlorinator	0					local	
12 Drainage facility	12-1 Drainage basin	1	1995				local	
	12-2 Drainage pump	1	1995				local	
13 Stand-by generator	13-1 Stand-by generator	1	1980	not working			England	
	13-2 Stand-by generator	3	1980	not working			England	

name of equipment	name of facility	Nos. constructed	year of construction	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				repair	replace	cleaning of basin or tank		
1 Intake raw water basin	1-1 Intake raw water basin	1	1988	write		weekly	Egypt	
	1-2 Inlet screen	0	1989		write		Egypt	300mm diameter and far from the station & in wire net.
2 Raw water reservoir	2-1 Raw water reservoir	0					local	
	2-2 Screen pump	0		write		weekly	Egypt	
3 Raw water pump	3-1 Raw water storage basin	1	1932			weekly	local	
	3-2 Raw water pump -Type 1	2		write		weekly	Egypt	
4 Receiving well	4-1 Receiving well	4	1995				local	
	4-2 Intake motor	0					Egypt	
5 Flocculation basin	5-1 Flocculation basin	1	1977	fan	do	monthly	Egypt	
	5-2 Flocculation basin	0					local	
6 Sedimentation basin	6-1 Shaft & paddle	0	1932	write		weekly	local	
	6-2 Sludge collector	0					local	
7 Sludge drainage	7-1 Drainage pump	0					local	
	7-2 Drainage pump	0					local	
8 Rapid sand filter	8-1 Rapid sand filter basin	2	1932-1937	maintenance			England/Egypt	
	8-2 Composition of filter layer	3	1932	write		Daily	England/Egypt	
9 Solar water reservoir	9-1 Solar water reservoir	1	1924			weekly	local	
	9-2 Backpressure valve	0					local	
10 Alum dosing facility	10-1 Alum storage tank	1	2004			weekly	local	
	10-2 Alum storage tank	1				weekly	local	
11 Chlorination facility	11-1 Chlorination tank	2	1932			weekly	local	
	11-2 Chlorinator	0					local	
12 Drainage facility	12-1 Drainage basin	1	1995				local	
	12-2 Drainage pump	1	1995				local	
13 Stand-by generator	13-1 Stand-by generator	1	1980	not working			England	
	13-2 Stand-by generator	3	1980	not working			England	


name of equipment	name of facility	Nos. constructed	year of construction	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				repair	replace	cleaning of basin or tank		
15 Electrical switch board	15-1 Electrical switch board	6	1980				England	
	15-2 Fluorometer	4	1991				local	
16 Transformer	16-1 Transformer	2	1995				local	
	16-2 Transformer	2	1995				local	
17 Chemical laboratory	17-1 Chemical laboratory	1	1980				local	
	17-2 Chemical laboratory	1	1980				local	
18 Maintenance equipment	18-1 Maintenance equipment	3	1995				local	
	18-2 Maintenance equipment	2	1980				local	
19 Safety equipment	19-1 Safety equipment	2	1980				local	
	19-2 Safety equipment	1	1980				local	

name of equipment	name of facility	Nos.	year of construction	additional construction	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
					repair	replace	cleaning or tank		
1 Intake raw water basin	1-1 intake raw water basin	1	2001				local		
	1-2 screen	2	2001	the whole diameter	do				
	1-3 Orime								
	1-4 number of lines for new intake	2						800mm diameter & salhya branch for from Imajali canal 11 km	
2 Raw water reservoir	2-1 Raw water reservoir								
	2-2 Screen								
	2-3 Orime								
3 Raw water pump	3-1 Raw water storage basin		2000	do			local	suction parts	
	3-2 Raw water pump -Type 1	4	1997	do			France	gear change for motor 3	
	3-3 Raw water pump -Type 2	4	1997	do			France	gear change for motor 4	
	pressure gauge	4	1997	do			France	change 3 power supply	
	3-4 Raw water pump -Type 2	0							
	pressure gauge	0							
	3-5 piping & valves	11	1997				France		
	4 Receiving well	1	2001		do		local		
	4-1 Receiving well	1	1997	do			France		
	4-2 Receiving well	1	1997	do			France		
	4-3 Receiving well	1	1997	do			France		
	4-4 Receiving well	1	1997	do			France		
	4-5 Receiving well	1	1997	do			France		
	4-6 Receiving well	1	1997	do			France		
	4-7 Receiving well	1	1997	do			France		
	4-8 Receiving well	1	1997	do			France		
	4-9 Receiving well	1	1997	do			France		
	4-10 Receiving well	1	1997	do			France		
	4-11 Receiving well	1	1997	do			France		
	4-12 Receiving well	1	1997	do			France		
	4-13 Receiving well	1	1997	do			France		
	4-14 Receiving well	1	1997	do			France		
	4-15 Receiving well	1	1997	do			France		
	4-16 Receiving well	1	1997	do			France		
	4-17 Receiving well	1	1997	do			France		
	4-18 Receiving well	1	1997	do			France		
	4-19 Receiving well	1	1997	do			France		
	4-20 Receiving well	1	1997	do			France		
	4-21 Receiving well	1	1997	do			France		
	4-22 Receiving well	1	1997	do			France		
	4-23 Receiving well	1	1997	do			France		
	4-24 Receiving well	1	1997	do			France		
	4-25 Receiving well	1	1997	do			France		
	4-26 Receiving well	1	1997	do			France		
	4-27 Receiving well	1	1997	do			France		
	4-28 Receiving well	1	1997	do			France		
	4-29 Receiving well	1	1997	do			France		
	4-30 Receiving well	1	1997	do			France		
	4-31 Receiving well	1	1997	do			France		
	4-32 Receiving well	1	1997	do			France		
	4-33 Receiving well	1	1997	do			France		
	4-34 Receiving well	1	1997	do			France		
	4-35 Receiving well	1	1997	do			France		
	4-36 Receiving well	1	1997	do			France		
	4-37 Receiving well	1	1997	do			France		
	4-38 Receiving well	1	1997	do			France		
	4-39 Receiving well	1	1997	do			France		
	4-40 Receiving well	1	1997	do			France		
	4-41 Receiving well	1	1997	do			France		
	4-42 Receiving well	1	1997	do			France		
	4-43 Receiving well	1	1997	do			France		
	4-44 Receiving well	1	1997	do			France		
	4-45 Receiving well	1	1997	do			France		
	4-46 Receiving well	1	1997	do			France		
	4-47 Receiving well	1	1997	do			France		
	4-48 Receiving well	1	1997	do			France		
	4-49 Receiving well	1	1997	do			France		
	4-50 Receiving well	1	1997	do			France		
	4-51 Receiving well	1	1997	do			France		
	4-52 Receiving well	1	1997	do			France		
	4-53 Receiving well	1	1997	do			France		
	4-54 Receiving well	1	1997	do			France		
	4-55 Receiving well	1	1997	do			France		
	4-56 Receiving well	1	1997	do			France		
	4-57 Receiving well	1	1997	do			France		
	4-58 Receiving well	1	1997	do			France		
	4-59 Receiving well	1	1997	do			France		
	4-60 Receiving well	1	1997	do			France		
	4-61 Receiving well	1	1997	do			France		
	4-62 Receiving well	1	1997	do			France		
	4-63 Receiving well	1	1997	do			France		
	4-64 Receiving well	1	1997	do			France		
	4-65 Receiving well	1	1997	do			France		
	4-66 Receiving well	1	1997	do			France		
	4-67 Receiving well	1	1997	do			France		
	4-68 Receiving well	1	1997	do			France		
	4-69 Receiving well	1	1997	do			France		
	4-70 Receiving well	1	1997	do			France		
	4-71 Receiving well	1	1997	do			France		
	4-72 Receiving well	1	1997	do			France		
	4-73 Receiving well	1	1997	do			France		
	4-74 Receiving well	1	1997	do			France		
	4-75 Receiving well	1	1997	do			France		
	4-76 Receiving well	1	1997	do			France		
	4-77 Receiving well	1	1997	do			France		
	4-78 Receiving well	1	1997	do			France		
	4-79 Receiving well	1	1997	do			France		
	4-80 Receiving well	1	1997	do			France		
	4-81 Receiving well	1	1997	do			France		
	4-82 Receiving well	1	1997	do			France		
	4-83 Receiving well	1	1997	do			France		
	4-84 Receiving well	1	1997	do			France		
	4-85 Receiving well	1	1997	do			France		
	4-86 Receiving well	1	1997	do			France		
	4-87 Receiving well	1	1997	do			France		
	4-88 Receiving well	1	1997	do			France		
	4-89 Receiving well	1	1997	do			France		
	4-90 Receiving well	1	1997	do			France		
	4-91 Receiving well	1	1997	do			France		
	4-92 Receiving well	1	1997	do			France		
	4-93 Receiving well	1	1997	do			France		
	4-94 Receiving well	1	1997	do			France		
	4-95 Receiving well	1	1997	do			France		
	4-96 Receiving well	1	1997	do			France		
	4-97 Receiving well	1	1997	do			France		
	4-98 Receiving well	1	1997	do			France		
	4-99 Receiving well	1	1997	do			France		
	4-100 Receiving well	1	1997	do			France		
	4-101 Receiving well	1	1997	do			France		
	4-102 Receiving well	1	1997	do			France		
	4-103 Receiving well	1	1997	do			France		
	4-104 Receiving well	1	1997	do			France		
	4-105 Receiving well	1	1997	do			France		
	4-106 Receiving well	1	1997	do			France		
	4-107 Receiving well	1	1997	do			France		
	4-108 Receiving well	1	1997	do			France		
	4-109 Receiving well	1	1997	do			France		
	4-110 Receiving well	1	1997	do			France		
	4-111 Receiving well	1	1997	do			France		
	4-112 Receiving well	1	1997	do			France		
	4-113 Receiving well	1	1997	do			France		
	4-114 Receiving well	1	1997	do			France		
	4-115 Receiving well	1	1997	do			France		
	4-116 Receiving well	1	1997	do			France		
	4-117 Receiving well	1	1997	do			France		
	4-118 Receiving well	1	1997	do			France		
	4-119 Receiving well	1	1997	do			France		
	4-120 Receiving well	1	1997	do			France		
	4-121 Receiving well	1	1997	do			France		
	4-122 Receiving well	1	1997	do			France		
	4-123 Receiving well	1	1997	do			France		
	4-124 Receiving well	1	1997	do			France		
	4-125 Receiving well	1	1997	do			France		
	4-126 Receiving well	1	1997	do			France		
	4-127 Receiving well	1	1997	do			France		
	4-128 Receiving well	1	1997	do			France		
	4-129 Receiving well	1	1997	do			France		
	4-130 Receiving well	1	1997	do			France		
	4-131 Receiving well	1	1997	do			France		
	4-132 Receiving well	1	1997	do			France		
	4-133 Receiving well	1	1997	do			France		
	4-134 Receiving well	1	1997	do			France		
	4-135 Receiving well	1	1997	do			France		
	4-136 Receiving well	1	1997	do			France		
	4-137 Receiving well	1	1997	do			France		
	4-138 Receiving well	1	1997	do			France		
	4-139 Receiving well	1	1997	do			France		
	4-140 Receiving well	1	1997	do			France		
	4-141 Receiving well	1	1997	do			France		
	4-142 Receiving well	1	1997	do			France		
	4-143 Receiving well	1	1997	do			France		
	4-144 Receiving well	1	1997	do			France		
	4-145 Receiving well	1	1997	do			France</		


name of equipment	name of facility	Nos.	year of constructed	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				additional construction	repair	replace		
chlorination facility	1) chlorine gas neutralization	7	1997				France	from starting plant operation the system had to be
	2) caustic soda solution pump	3	1997				France	
	3) attached parts	3	1997				France	
	4) exhaust fan	5	1997				France	
	5) motor	4	1997				France	
	6) attached parts	4	1997				France	
	7) caustic soda solution tank	3	1997				local	
	8) caustic soda solution tank	3	1997				local	
	9) drainage basin	1	1997					
	10) drainage basin	1	1997					
	11) drainage basin	1	1997					
Treated water pump	1) drainage basin	1	1997					
	2) drainage basin	1	1997					
	3) drainage basin	1	1997					
	4) drainage basin	1	1997					
	5) drainage basin	1	1997					
	6) drainage basin	1	1997					
	7) drainage basin	1	1997					
	8) drainage basin	1	1997					
	9) drainage basin	1	1997					
	10) drainage basin	1	1997					
	11) drainage basin	1	1997					
Stand-by generator	1) generator	1	1997				England	1000mm cast iron main to the city
	2) generator	2	1997				England	1000mm cast iron main to the city
	3) generator	2	1997				England	1000mm cast iron main to the city
	4) generator	2	1997				England	1000mm cast iron main to the city
	5) generator	2	1997				England	1000mm cast iron main to the city
	6) generator	2	1997				England	1000mm cast iron main to the city
	7) generator	2	1997				England	1000mm cast iron main to the city
	8) generator	2	1997				England	1000mm cast iron main to the city
	9) generator	2	1997				England	1000mm cast iron main to the city
	10) generator	2	1997				England	1000mm cast iron main to the city
	11) generator	2	1997				England	1000mm cast iron main to the city
Electrical switch board	1) switch board	1	1997				local	
	2) switch board	1	1997				local	
	3) switch board	1	1997				local	
	4) switch board	1	1997				local	
	5) switch board	1	1997				local	
	6) switch board	1	1997				local	
	7) switch board	1	1997				local	
	8) switch board	1	1997				local	
	9) switch board	1	1997				local	
	10) switch board	1	1997				local	
	11) switch board	1	1997				local	


name of equipment	name of facility	Nos.	year of constructed	maintenance record			Name of manufacturer	specifications (Detail description should be described in annex sheet)
				additional construction	repair	replace		
Transformer	1) transformer	1	1997				local	
	2) transformer	2	2000				local	
	3) transformer	2	2000				local	
	4) transformer	2	2000				local	
	5) transformer	2	2000				local	
	6) transformer	2	2000				local	
	7) transformer	2	2000				local	
	8) transformer	2	2000				local	
	9) transformer	2	2000				local	
	10) transformer	2	2000				local	
	11) transformer	2	2000				local	
Maintenance equipment	1) maintenance equipment	1	1997				France	not used
	2) maintenance equipment	1	1997				France	not used
	3) maintenance equipment	1	1997				France	not used
	4) maintenance equipment	1	1997				France	not used
	5) maintenance equipment	1	1997				France	not used
	6) maintenance equipment	1	1997				France	not used
	7) maintenance equipment	1	1997				France	not used
	8) maintenance equipment	1	1997				France	not used
	9) maintenance equipment	1	1997				France	not used
	10) maintenance equipment	1	1997				France	not used
	11) maintenance equipment	1	1997				France	not used

FLOW DIAGRAM



FLOW DIAGRAM





01 El Seids in Ibrahimiyah FLOW DIAGRAM.dwg

3. PI Setting for Chemical Consumption in WTP

Setting indicators for optimum chemical consumption

1. Definition

1-1. Kind of available chemicals in water supply facility in model facilities

The Chemicals in following table are used in the water supply facility currently.

	Aluminum sulfate	Chlorine	Model Facility
WTP	○	○	Abbassa Zagazig
FMRP	—	○	Quenayate
BPS	—	—	Bilbeis
WPS	—	—	Asloug

1-2. The definition of "optimum chemical consumption"

"Optimum chemical consumption" is achieved by keeping the conditions of "optimum chemical dosing"

In this report, the meaning of "Optimum chemical dosing" condition is that the treatment process is kept under follow conditions.

- 1) The required function for the process is achieved.
- 2) Chemical dosing rate is not excessive.
- 3) Chemical dosing rate is not shortage

1-3. Explanations about "Optimum dosing of chemicals" condition

- 1) The required function for the process is achieved.

Regarding aluminum sulfate (aluminum sulfate abbreviates to alum), condition of the above is explained as following

"Turbidity of clarified water is within allowance range of treatment target for turbidity of the clarified water."

Regarding chlorine, condition of the above is explained as following

"Residual chlorine of treated water is within allowance range of treatment target for residual chlorine in each treatment process."

- 2) The condition which is not surplus of alum dosing flow rate
And
- 3) The condition which is not insufficient of alum dosing flow rate

Regarding alum, conditions of above two are shown as followings

Dosing rate of alum is suitable for raw water quality and conditions such as water temp.
Dosing flow rate of alum is controlled according to change of operation status

Regarding chlorine, conditions of above two are explained as followings

Dosing rate of chlorine is suitable for raw water quality and conditions such as water temp.

Dosing flow rate of chlorine is controlled according to change of operation status

1-4. Explanations about "Optimum consumption of chemicals"

"Optimum consumption of chemicals" is set as "Estimated optimum consumption of chemicals" by evaluation result of consumption in the previous year.

1-5. Procedures for setting "Estimated optimum consumption of chemicals"

Estimation of "Optimum consumption of chemicals" is carried out according to the following procedures.

1) Estimation of raw water flow rate for the plant in the target year

- 1-1) Confirmation of actual record of the integrated volume of raw water and transmission water in the previous year and confirm calculation results as follows;

- (A): Record of the monthly integrated volume of raw water in the previous year
- (B): Record of the monthly integrated volume of transmission water in the previous year

Q-raw-y: Calculated result of the integrated volume of raw water in the previous year

(B)(A): Calculated result of the ratio of integrated volume of raw water and transmission water

- 1-2) Estimation of the integrated volume of the raw water and transmission water in the target year

RP: Estimated population growth rate in the supply area

RC: Estimated increasing rate of consumption amount on the supply area

EQ-tr-y: Estimated integrated volume of the transmission water in the target year

EQ-raw-y: Estimated integrated volume of the raw water calculated by (B)(A) and EQ-tr-y

- 1-3) Confirmation of average dosing rate of chemicals in the previous year

Confirmation of actual record of the integrated amount of chemicals (alum and chlorine) in the previous year and confirm calculation results as follows;

- (F): Record of the monthly integrated amount of alum in the previous year
- (G): Record of the monthly integrated amount of chlorine in the previous year

W alum-y: Calculated result of the integrated amount of alum for the previous year

W cl-y: Calculated result of the integrated amount of chlorine for the previous year

DR alum-y: Calculated result of the ration of integrated amount of alum per Q-raw-y (This figure is actual average dosing rate of alum and chlorine in the previous year)

DR cl-y: Calculated result of the ration of integrated amount of chlorine per Q-raw-y (This figure is actual average dosing rate of alum and chlorine in the previous year)

$$DR \text{ alum-y (g/m}^3\text{)} = W \text{ alum-y} / Q\text{-raw-y}$$

$$DR \text{ cl-y (g/m}^3\text{)} = W \text{ cl-y} / Q\text{-raw-y}$$

- 1-4) Estimation of average dosing rate of chemicals in the target year

- Check and evaluate the value of DR alum and DR cl.
- Point of check and evaluation
 - Confirmation that calculated value is not usual
 - Check of a the validity of dosing rate value
 - Confirmation of change of water quality
 - Treatment target of turbidity of clarified water
 - Actual average turbidity of clarified water
 - Average filter run time, and so
 - Comparison with the calculated value for other facilities
 - The study about possibilities of reduction of consumption amount

Based on result of check and evaluation of the value DR alum and DR cl, estimated average dosing rate of chemicals EDR alum and EDR cl should be set for the year.

- EDR alum: Estimated average dosing rate of alum in the year
- EDR cl: Estimated average dosing rate of chlorine in the year
 - (DR alum and DR cl in the year will be evaluated by compared with EDR alum and EDR cl)

1-5) Estimation of chemical consumption

- EW alum-y**: Estimated integrated amount of alum for the previous year
(Estimated alum consumption in the target year)
- EW cl-y**: Estimated integrated amount of chlorine for the previous year
(Estimated chlorine consumption in the target year)

EW alum-y = EQ-raw-y (m3) x EDR alum (g/m3)
EW cl-y = EQ-raw-y (m3) x EDR cl (g/m3)

Case study by records of ZAGAZIG WTP (Refer to attached recoding sheet)

- 1-1) Confirmation of actual record of the integrated volume of raw water and transmission water in the previous year and confirm calculation results
 - Q-raw-y = 12,099,821 (m3)
 - EQ-tr-y = 10864,252 (m3)
 - (B)/(A) = 0.9
 - W alum-y = 289,801.3 (kg)
 - W cl-y = 58,524.1(kg)

1-2) Estimation of the integrated volume of the raw water and transmission water in the target year

- RP: Estimated population growth rate of the supply area
Estimation value of RP =1.2 % (Tentative value)
- RC: Estimated increasing rate of consumption amount of the supply area
Estimation value of RC =2.0 % (Tentative value)

EQ-tr-y: Estimated integrated volume of the transmission water in the target year
EQ-tr-y = 10864,252 (m3) x (1+0.012+0.02) = 11,211,908 (m3)
EQ-raw-y: Estimated integrated volume of the raw water calculated by (B)/(A) and EQ-tr-y
EQ-raw-y = Q-raw-y x (A)/(B)
= 11,211,908 x 1/0.9 = 12,487,015 (m3)

- 1-3) Confirmation of average dosing rate of chemicals in the previous year
 - DR alum-y = 24 (g/m3)
 - DR cl-y = 4.83 (g/m3)

1-4) Estimation of average dosing rate of chemicals in the target year

- Evaluation of average dosing rate of chemicals in the previous year
Alum EDR alum-y = 24 (g/m3)
Chlorine EDR cl-y = 4.83 (g/m3)

Evaluation result: 24 (g/m3) is reasonable.
EDR alum is set as the same value as previous year

Chlorine EDR cl-y = 4.83 (g/m3)

- Evaluation result: 4.83 (g/m3) will be able to reduced by adequate residual chlorine control.
EDR cl is set as 4.3 (g/m3)

1-5) Estimation of chemical consumption in the target year

(This value is set up as amount of optimum chemical consumption in the year)

EW alum-y = EQ-raw-y (m3) x EDR alum (g/m3)
= 12,487,015 (m3) x 24 (g/m3) = **299,688(kg)**

EW cl-y = EQ-raw-y (m3) x EDR cl (g/m3)
= 12,487,015 (m3) x 4.3 (g/m3) = **53,694(kg)**

1-6) Calculation value of chemical consumption in the target year calculated by value of same dosing rate as value of 2008

Alum CW alum-y = 299,699 (kg)
Chlorine CW cl-y = 60,371 (kg)

1-7) Estimation of reduction of chemical consumption in the target year

Alum **EW alum-y** - CW alum-y = 0 (kg)
Chlorine **EW cl-y** - CW cl-y = 6,677 (kg)

Month	(A) Design Capacity		(B) 400 (l/sec)		(C) Design Capacity		(D) Estimated population growth rate RP		(E) Estimated increasing rate of consumption		(F) 12%	
	Raw water quantity (m3/d)	Transmission water quantity (m3/d)	Raw water quantity (m3/d)	Transmission water quantity (m3/d)	Raw water quantity (m3/d)	Transmission water quantity (m3/d)	Raw water quantity (m3/d)	Transmission water quantity (m3/d)	Raw water quantity (m3/d)	Transmission water quantity (m3/d)	Raw water quantity (m3/d)	Transmission water quantity (m3/d)
January	230,669	120	230,669	120	230,669	120	230,669	120	230,669	120	230,669	120
February	652,735	610,156	652,735	610,156	652,735	610,156	652,735	610,156	652,735	610,156	652,735	610,156
March	862,439	786,119	862,439	786,119	862,439	786,119	862,439	786,119	862,439	786,119	862,439	786,119
April	921,275	798,662	921,275	798,662	921,275	798,662	921,275	798,662	921,275	798,662	921,275	798,662
May	1,108,030	994,612	1,108,030	994,612	1,108,030	994,612	1,108,030	994,612	1,108,030	994,612	1,108,030	994,612
June	1,169,090	1,050,016	1,169,090	1,050,016	1,169,090	1,050,016	1,169,090	1,050,016	1,169,090	1,050,016	1,169,090	1,050,016
July	1,197,198	1,050,350	1,197,198	1,050,350	1,197,198	1,050,350	1,197,198	1,050,350	1,197,198	1,050,350	1,197,198	1,050,350
August	1,291,246	1,139,240	1,291,246	1,139,240	1,291,246	1,139,240	1,291,246	1,139,240	1,291,246	1,139,240	1,291,246	1,139,240
September	1,047,480	930,960	1,047,480	930,960	1,047,480	930,960	1,047,480	930,960	1,047,480	930,960	1,047,480	930,960
October	997,029	898,537	997,029	898,537	997,029	898,537	997,029	898,537	997,029	898,537	997,029	898,537
November	999,500	899,960	999,500	899,960	999,500	899,960	999,500	899,960	999,500	899,960	999,500	899,960
December	923,130	841,570	923,130	841,570	923,130	841,570	923,130	841,570	923,130	841,570	923,130	841,570
Total in a year	12,099,821	10,864,252	12,099,821	10,864,252	12,099,821	10,864,252	12,099,821	10,864,252	12,099,821	10,864,252	12,099,821	10,864,252
	Q-raw-y		Q-raw-y		Q-raw-y		Q-raw-y		Q-raw-y		Q-raw-y	
Month	Alum dosing weight (kg)	Chlorine dosing weight (kg)	Alum consumption per raw water (g/m3)	Chlorine consumption per raw water (g/m3)	Estimated alum consumption (kg)	Estimated chlorine consumption (kg)	Estimated alum consumption (kg)	Estimated chlorine consumption (kg)	Estimated alum consumption (kg)	Estimated chlorine consumption (kg)	Estimated alum consumption (kg)	Estimated chlorine consumption (kg)
January	232667	232667	25.0	4.93	23,051	4,130	23,051	4,130	23,051	4,130	23,051	4,130
February	1,631,844	3221	25.0	4.93	16,167	2,897	16,167	2,897	16,167	2,897	16,167	2,897
March	2,038,911	4206.4	23.6	4.88	21,381	3,827	21,381	3,827	21,381	3,827	21,381	3,827
April	2,163,338	4483.8	23.5	4.87	22,818	4,098	22,818	4,098	22,818	4,098	22,818	4,098
May	2,590,021	5432.1	23.4	4.90	27,444	4,917	27,444	4,917	27,444	4,917	27,444	4,917
June	2,775,538	5726.4	23.7	4.90	28,956	5,188	28,956	5,188	28,956	5,188	28,956	5,188
July	2,802,721	5833.9	23.4	4.87	29,652	5,313	29,652	5,313	29,652	5,313	29,652	5,313
August	3,120,055	6305	24.2	4.88	31,882	5,730	31,882	5,730	31,882	5,730	31,882	5,730
September	2,519,355	5120.9	24.0	4.89	25,944	4,648	25,944	4,648	25,944	4,648	25,944	4,648
October	2,392,871	4886.7	24.0	4.90	24,694	4,424	24,694	4,424	24,694	4,424	24,694	4,424
November	2,348,735	4677.7	23.5	4.65	24,756	4,435	24,756	4,435	24,756	4,435	24,756	4,435
December	2,274,819	4073.4	24.6	4.41	22,864	4,096	22,864	4,096	22,864	4,096	22,864	4,096
Total in a year	28,901.3	58,524.1	24.00	4.83	299,688	53,694	299,688	53,694	299,688	53,694	299,688	53,694
	W alum-y	W cl-y	DR alum-y	DR cl-y	EW alum-y	EW cl-y	EW alum-y	EW cl-y	EW alum-y	EW cl-y	EW alum-y	EW cl-y
	299,688	58,524	24.00	4.83	299,688	53,694	299,688	53,694	299,688	53,694	299,688	53,694
	Alum consumption per production water quantity	Chlorine consumption per production water quantity	Reduction (%)	Reduction (%)	Alum (kg)	Chlorine (kg)	Alum (kg)	Chlorine (kg)	Alum (kg)	Chlorine (kg)	Alum (kg)	Chlorine (kg)
2008	26.7	26.7	0	0	299,688	53,694	299,688	53,694	299,688	53,694	299,688	53,694
2009	26.7	26.7	0	0	299,688	53,694	299,688	53,694	299,688	53,694	299,688	53,694
Alum cost(LE/m3)	0.03	0.03	0	0	299,688	53,694	299,688	53,694	299,688	53,694	299,688	53,694
Chlorine cost(LE/m3)	5.22	4.79	0.43	0.43	53,694	6,677	53,694	6,677	53,694	6,677	53,694	6,677
Chlorine cost(LE/m3)	0.0073	0.0067	0.0006	0.0006	53,694	6,677	53,694	6,677	53,694	6,677	53,694	6,677

Optimum consumption of chlorine

Qenayate FMRP

1. Estimation of status under adequate operation		
Well water flow rate-1	70 (l/sec)	252 (m3/hr)
Working days	365 days	
Chlorine dosing rate	1.75 (mg/l)	as chlorine weight
Chlorine dosing flow rate	0.44 (kg/hr)	as chlorine weight
Operation time	18 hours	from 6:00AM to 12:00 PM
Daily chlorine consumption-1	7.94 (kg)	as chlorine weight
Daily water quantity-1	4536 (m3)	
Yearly water quantity-1	1,655,640 (m3)	
Well water flow rate-2		
Well water flow rate-2	40 (l/sec)	144 (m3/hr)
Working days	365 days	
Chlorine dosing rate	1.75 (mg/l)	as chlorine weight
Chlorine dosing flow rate	0.25 (kg/hr)	as chlorine weight
Operation time	6 hours	from 12:00 PM to 6:00AM
Daily chlorine consumption-1	1.51 (kg)	as chlorine weight
Daily water quantity-1	864 (m3)	
Yearly water quantity-1	315,360 (m3)	
2. Estimation of consumption of chlorine under adequate operation		
Total daily chlorine consumption	9.45 (kg)	as chlorine weight
	0.009 (Ton)	as chlorine weight
Total yearly chlorine consumption	3449.3 (kg)	as chlorine weight
	3.4 (Ton)	as chlorine weight

Chlorine consumption per treated water quantity 1.75 (g/m3) as chlorine weight

Calculation formula for dosing flow rate of chlorine
 $W(\text{kg/hr}) = Q(\text{l/sec}) \times 60 \times 60 \times 1/1000 \times A(\text{mg/l}) \times 1/1000$

Raw water flow rate	Q	(l/sec)
Dosing rate of chlorine	A	(mg/l)
Dosing flow rate of chlorine	W	(kg/hr)

3. Estimation of status under inadequate operation		
Well water flow rate-1	70 (l/sec)	252 (m3/hr)
Working days	365 days	
Chlorine dosing rate	1.75 (mg/l)	as chlorine weight
Chlorine dosing flow rate	0.44 (kg/hr)	as chlorine weight
Operation time	18 hours	from 6:00AM to 12:00 PM
Daily chlorine consumption-1	7.94 (kg)	as chlorine weight
Daily water quantity-1	4536 (m3)	
Yearly water quantity-1	1,655,640 (m3)	

FMRP 1/3

Well water flow rate-2	40 (l/sec)	144 (m3/hr)
Working days	365 days	
Chlorine dosing rate	3.5 (mg/l)	as chlorine weight
Chlorine dosing flow rate	0.50 (kg/hr)	as chlorine weight
Operation time	6 hours	from 12:00 PM to 6:00AM
Daily chlorine consumption-1	3.02 (kg)	as chlorine weight
Daily water quantity-1	864 (m3)	
Yearly water quantity-1	315,360 (m3)	

Total water quantity in a year 1,971,000 (m3)

4. Estimation of consumption of chlorine under inadequate operation		
Total daily chlorine consumption	10.96 (kg)	as chlorine weight
	0.011 (Ton)	as chlorine weight
Total yearly chlorine consumption	4001.1 (kg)	as chlorine weight
	4.0 (Ton)	as chlorine weight

5. Difference of the above 2 consumptions		
Daily difference of consumption	1.51 (kg)	as chlorine weight
	0.002 (Ton)	as chlorine weight
Yearly difference of consumption	551.9 (kg)	as chlorine weight
	0.6 (Ton)	as chlorine weight

Unit price of chlorine	1.4 (LE/kg)
Difference of cost in a year	773 (LE)

6 Chlorine consumption per production water volume
 Flow meter is not available in Qanayat FMRP
 Therefore, chlorine consumption per actual production water volume cannot be calculated.
 Estimation of chlorine consumption per actual production water volume is as following

Estimation of production water volume	
Water volume for ackwashing and rinsing	
Time of back washing	8 min
Time of rinsing	5 min
Total	13 min

Water volume for ackwashing and rinsing	54.6 m3/wash
Frequency of filter washing	1/day
Water volume in a day for ackwashing and rinsing	54.6 m3/day
Water volume in a year for ackwashing and rinsing	19,929 m3/year
Rate of filter wash water to well water volume	1.01 %

Estimation of production water volume in a year ##### m3/year

Estimation of chlorine consumption per estimated production water volume	
Estimation of status under adequate operation	1.77 (g/m3)
Estimation of status under inadequate operation	2.05 (g/m3)

Difference 0.28 (g/m3)

FMRP 2/3

For reference, chlorine consumption per well water volume is as following
 Estimation of status under adequate operation 1.75 (g/m3)
 Estimation of status under inadequate operation 2.03 (g/m3)

Difference 0.28 (g/m3)


7 Target of PI about chlorine consumption per estimated production water volume in 2009

1.77 (g/m3)

The above target will be achieved by adequate operation and control of chlorine dosing under condition of same water quality in 2008


FMRP 3/3

5. PI Setting for Power Consumption



Actual record of power consumption in WTP in 2008

Month	Hihya	Zagazig	New Faqus	Simulation	1.38
1	258,460	246,730	1,045,632	757,785	1.38
2	240,400	182,716	903,525	634,674	1.42
3	271,500	224,230	838,417	743,595	1.13
4	277,400	228,436	819,650	758,754	1.08
5	328,400	268,658	933,152	895,587	1.04
6	320,760	282,333	851,573	904,640	0.94
7	343,880	299,902	1,442,995	965,673	1.49
8	346,050	305,954	1,250,530	978,006	1.28
9	330,870	258,473	1,357,310	884,015	1.54
10	332,500	247,379	2,172,412	869,819	2.50
11	258,400	259,061	1,199,506	776,192	1.55
12	365,900	238,077	1,071,344	905,966	1.18
Total	3,674,520	3,041,949	13,886,046	10,074,704	1.38



Zagazig WTP

Date	3-11	12/1-1/23	1/24-2/14	2/15-2/28	3-11	12/1-1/23	1/24-2/14	2/15-2/28	528	96	8760
Working time	8:00-9:00	8:00-9:00	8:00-9:00	8:00-9:00	8:00-9:00	8:00-9:00	8:00-9:00	8:00-9:00	8:00-9:00	8:00-9:00	8:00-9:00
Working day	2/5	3/2	2/2	2/2	2/5	3/2	2/2	2/2	2/2	2/2	2/2
Motor Qty	24	12	24	12	24	12	24	12	24	12	24
Admin load											
Raw water pump	3	2	3	2	3	2	3	2	3	2	3
Backwash pump	1	0	1	0	1	0	1	0	1	0	1
Blower	1	0	1	0	1	0	1	0	1	0	1
Drainage pump	1	0	1	0	1	0	1	0	1	0	1
Transmission pump	3	2	3	2	3	2	3	2	3	2	3
Existing	190	1	1	1	1	1	1	1	1	1	1
Extension	250	0	0	0	0	0	0	0	0	0	0
Flash mixer	1	1	1	1	1	1	1	1	1	1	1
Sludge collector	2	4	4	4	4	4	4	4	4	4	4
Fluocarbalar	7	5	8	8	8	8	8	8	8	8	8
Alum dosing pump	7	5	3	1	1	1	1	1	1	1	1
Sum	3,326,640	991,142	154,790	199,517	75,806	9,854	4,757,570	3,330,725			
Estimated margin for out put of motor											
Estimated power consumption of filter washing facility (kwh/year)											
Estimated power consumption of filter washing facility (kw/year)											
Estimated margin for out put of motor											
Estimated power consumption of filter washing facility (kwh/year)											
Estimated power consumption of filter washing facility (kw/year)											
Actual power consumption in Hihya WTP, 2008 (for reference)											
258,460	240,400	271,500	277,400	328,400	320,760	343,880	346,050	330,870	332,500	258,400	365,900
8760	8760	8760	8760	8760	8760	8760	8760	8760	8760	8760	8760
3,674,520	3,041,949	13,886,046	10,074,704								

Optimum consumption of electrical power

Aslouy WPS

Date	1-12	1-12	1-12	1-12	Ratio	
working time	8:00-0:00	0:00-8:00	8:00-0:00	0:00-8:00		
working day	365	365	365	365		
Motor	hr	16	8	16	8	
(kw)	Q/Y	Numbers of equipment to be operated	Power consumption in a year (kwh)	power/year (kwh)	Ratio	
Main load	60	2	1	350,400	175,200	0.4878
Well pump	60	2	1	350,400	175,200	0.4878
Well pump	60	2	1	350,400	175,200	0.4878
Filter pump	60	2	1	350,400	175,200	0.4878
Booster pump	3	2	1	17,520	8,760	0.0244
				1,077,480	525,600	1,000
				26,280	8,760	0.7
				1,077,480	525,600	754,236

Estimated margin for out put of motor
(except filter washing facility)

Power consumption in Aslouy WPS 1/1

Optimum consumption of electrical power

Qenayat FMRP

Date	1-12	1-12	1-12	1-12	Ratio	
working time	8:00-0:00	0:00-8:00	8:00-0:00	0:00-8:00		
working day	365	365	365	365		
Motor	hr	16	8	16	8	
(kw)	Q/Y	Numbers of equipment to be operated	Power consumption in a year (kwh)	power/year (kwh)	Ratio	
Main load	75	2	1	438,000	219,000	0.3000
Well pump	60	2	1	350,400	175,200	0.2400
Well pump	60	2	1	350,400	175,200	0.2400
Filter pump	60	2	1	350,400	175,200	0.2400
Booster pump	3	2	1	17,520	8,760	0.0120
				2,190,000	1,095,000	1,000
				26,280	8,760	0.7
				2,190,000	1,095,000	1,533,000

Estimated margin for out put of motor
(except filter washing facility)

Power consumption in FMRP 1/1

Optimum consumption of electrical power

Bilbeis BPS

Date	1-12	1-12	1-12	1-12	Ratio	
working time	8:00-0:00	0:00-8:00	8:00-0:00	0:00-8:00		
working day	365	365	365	365		
Motor	hr	10.32	13.68	10.32	13.68	
(kw)	Q/Y	Numbers of equipment to be operated	Power consumption in a year (kwh)	power/year (kwh)	Ratio	
Main load	200	2	1	753,360	0	0.6014
Booster pump-Large	100	2	0	499,320	0	0.3986
Booster pump-Small	100	2	0	499,320	0	0.3986
				1,252,680	0	1,000
				801,7715	0.64	

Estimated margin for out put of motor
Total estimated power consumption (kwh/y)
(except filter washing facility)

Numbers of equipment to be operated are shown as default values

Operation schedule of booster pumps

Quantity	Pump	Converted time in a day as hrs
5	No.1	0.43
100 l/sec	No.1	10.32
100 l/sec	No.2	0.215
200 l/sec	No.3	5.16
200 l/sec	No.4	0.57
100 l/sec	No.1	13.68
100 l/sec	No.2	6.84
200 l/sec	No.3	37.68

Operation rate	Actual data of power consumption
Large pump	1 97271 75605
Small pump	2 7324 40650
	3 61615 35791
	4 68600 50541
	5 60557 53135
	6 52354 62912
	7 76576 73945
	8 41209 85346
	9 33000 85981
	10 70009 91241
	11 67279 77343
	12 96695 61738
	732386 794335

PI setting about estimation of power consumption per supply water vol
Flow meter has been installed in Oct-2008
In the present a data collection by flow meter is going on.
The above estimation value cannot be calculated for the past data.

Power consumption in Bilbeis
BSP 1/1

6. PI Setting for Manpower

Component of technical staff in Abbassa WTP in the current

Job category	Team for Work		W/S total	P/H Others	WTP 01, 02, 13
	P/H	Others			
Supervisor & Technician	11	33	0.45	Laboratory	WTP01, 03, 04, 05, 08, 10, 11, 12, 20
Chemist	0	0	0.4	W/S	WTP 01-19
Labor	8	0	3.13		
Total	19	33	3.62		

category ratio = number of worker in each job category/total numbers of workers

	Ratio
Supervisor & Technician	0.73
Chemist	0.06
Labor	0.21

Standard Manpower working hours for Abbassa WTP

No.	Equipment	Required working time for required activity period (hour)			sv	sv supervisor, tec: technician, sp/t: special technician, che: chemist, wrk: labor	Interval	Activities
		Daily	Weekly	Monthly				
WTP01	Raw water intake	0.5	1	3	0.5	1	Daily	Check and monitoring
WTP02	Raw water pump/motor	8	12	as required	1	2	Monthly	Intake rate clearing
WTP03	Receiving well (Distribution shaft)	0.5	1.5	2	1	2	Yearly	Gate polishing, repair and paint
WTP04	Flocculation basin	0.5	0.5	12	1	1	Emergency	Drainage
WTP05	Sedimentation basin	1	0.5	12	1	1	Daily	Check and monitoring
WTP06	Sludge collector	0.5	1.5	2	1	2	Yearly	Check valve and drain valve check, greasing and oiling box, check valves and change defect parts
WTP07	Sludge drainage facility	3	4	as required	1	1	Monthly	Check water distributing and return
WTP08	Rapid sand filter	8	4 filter 38 filters 304 Total	8 filter 38 filters 304 Total	1	4	Yearly	Check valves and drain valve chamber
WTP09	Filter washing facility	8	12	as per required	1	2	Daily	Check float formation and mixers
WTP10	Clear water reservoir	3	4	2.40	1	1	Yearly	Drain, clean, and disinfection
WTP11	Alum dosing facility	3	8	2.40 tank 4 tanks 960 Total	1	1	Yearly	Check float formation and mixers
WTP12	Chlorination facility special technician: chlorine handling	4	16	as per required	1	1	Yearly	Check float formation and mixers

Standard Manpower or working hours for Quesayate FMRP

No.	Equipment	Required working time for required activity period (hour)			sv	sv supervisor, tec: technician, sp/t: special technician, che: chemist, wrk: labor	Interval	Activities	
		Daily	Weekly	Monthly					
FMR-1	Water well	0.5	3	3	0.5	1	Daily	Check water level	
FMR-2	Well pump/motor	1	3	as required	1	1	Yearly	Cleanse site and sampling	
FMR-3	Oxidation tower	5	4	120	1	1	Daily	Repair and paint	
FMR-4	Sedimentation basin	0.5	6	48	1	1	Yearly	Check and operation monitoring	
FMR-5	Filter	1.5	2	48	1	1	Yearly	Greasing and stuffing box check	
FMR-6	Filter pump	1	3	as required	1	2	Monthly	Annual overall and change defect	
FMR-7	Chlorination facility special technician: chlorine handling	4	16	as per required	1	1	Daily	Monitoring falling of water from the spraying holes in each floor	
FMR-8	Drainage facility	0.5	2	4	1	1	Monthly	General Maintenance	
FMR-9	Piping and valves	1	6	144	1	1	Yearly	Monitor basin level	
FMR-10	Instrumentation	1	2	as required	1	1	Yearly	Cleaning	
FMR-11	Electrical power supply	1	6	184	1	1	Yearly	Automatic or Manual backwash	
FMR-12	Laboratory	4	6	24	1	1	Yearly	General Maintenance	
FMR-13	Diesel generator	1	3	8	1	2	Yearly	Automatic or Manual backwash	
Total		22	62	583	0.5	13	5	2	23
Frequency		365	52	12	4	1	1	1	1
Total hours in a year (hrs)		8,030	744	0	1,166				
Gross hours in a year (hrs)		9,940							
Ratio of O&M activity		0.6							
Gross hours in a year (hrs)		16,567							

Estimated factor of ratio of O&M activity/whole activity in the plant

Estimated factor of ratio of O&M activity/whole activity in the plant

Estimated factor of ratio of O&M activity/whole activity in the plant

Standard Manpower or working hours for Abbassa WTP

No.	Equipment	Required working time for required activity period (hour)			sv	sv supervisor, tec: technician, sp/t: special technician, che: chemist, wrk: labor	Interval	Activities
		Daily	Weekly	Monthly				
WTP13	Transmission pump	8	12	as per required	1	2	Daily	Check and operation monitoring
WTP14	Drainage facility	8	12	as per required	1	2	Yearly	Greasing and stuffing box check
WTP15	Piping and valves	2	6	144	1	1	Yearly	Annual overall and change defect parts
WTP16	Monitoring room and instrumentation	1	2	as per required	1	1	Daily	Check instruments functions
WTP17	Electrical power supply	1	6	184	1	2	Yearly	Check and operation monitoring
WTP18	Diesel generator	1	3	8	1	1	Yearly	Check and operation monitoring
WTP19	Crane facility special technician: crane driver	1	3	6	1	2	Yearly	Check and operation monitoring
WTP20	Laboratory	8	10	12	1	1	Yearly	Check and operation monitoring
WTP21	Coordination with booster pump station	1	2	8	1	1	Yearly	Check and operation monitoring
Total		71	12	299	36	2	2	36
Frequency		365	52	12	4	1	1	1
Total hours in a year (hrs)		25,915	626	144	7173			
Gross hours in a year (hrs)		37,446						
Ratio of O&M activity		0.6						
Gross hours for whole works		62,410						

Estimated factor of ratio of O&M activity/whole activity in the plant

Estimated factor of ratio of O&M activity/whole activity in the plant

Estimated factor of ratio of O&M activity/whole activity in the plant

Estimated factor of ratio of O&M activity/whole activity in the plant

Estimated factor of ratio of O&M activity/whole activity in the plant

Estimated factor of ratio of O&M activity/whole activity in the plant

Estimated factor of ratio of O&M activity/whole activity in the plant

Estimated factor of ratio of O&M activity/whole activity in the plant

Estimated factor of ratio of O&M activity/whole activity in the plant

Estimated factor of ratio of O&M activity/whole activity in the plant

Estimated factor of ratio of O&M activity/whole activity in the plant

Estimated factor of ratio of O&M activity/whole activity in the plant

No.	Equipment	Daily	Weekly	Monthly	3-mo.	Yearly	Emergency	sv	te	spt	che	wk	Interval	Activities
-----	-----------	-------	--------	---------	-------	--------	-----------	----	----	-----	-----	----	----------	------------

Component of technical staff in the current in Qomayate PMRP

Job category	No.
Technician	3
Chemist	2
Labor	2
Total	7

No.	Equipment	Daily	Weekly	Monthly	3-mo.	Yearly	Emergency	sv	te	spt	che	wk	Interval	Activities
-----	-----------	-------	--------	---------	-------	--------	-----------	----	----	-----	-----	----	----------	------------

Component of technical staff in the current in Bilbes BPS

Job category	No.
Technician	3
Chemist	0
Labor	6
Total	9

Standard Manpower working hours for Astogy WPS

No.	Equipment	Required working time for required activity period (hour)						Resource (jobs)			Interval	Activities	
		Daily	Weekly	Monthly	3-mo.	Yearly	Emergency	sv	te	spt			
WPS 1	Water well	0.5		1		3	0.5		1		1	Daily	Check water level
												Monthly	Cleaning site and sampling
												Yearly	Repair and paint
WPS 2	Well pump/motor	1		3		as per required		1			1	Daily	Check and operation monitoring
												Yearly	Greasing and stuffing box check
												Yearly	check and adjust all relays
												Yearly	check and change defect parts
WPS 3	Diesel well pump (Not applicable)	1		3		as per required		1			1	Daily	check machine condition
												Yearly	annul overall and change defect parts
WPS 4	Piping and valves	1		6		144		1			1	Monthly	greasing and stuffing box check
												Yearly	polish and repaint all valves
WPS 5	Instrumentation	1		2		as per required		1			1	Monthly	check instrument functions
												Yearly	check measured data
WPS 6	Chlorination facility special technician: chlorine handling	4		16		as per required		1			2	Monthly	repair chlorine injection equipment
												Yearly	check and control dose
WPS 7	Electrical power supply	0.5		1		184		1			1	Daily	check and operation monitoring
												Yearly	repair and adjust all relays
WPS 8	Elevated tank	1		4		240		1			1	Monthly	check and operation monitoring
												Yearly	measuring transformer of properties
WPS 9	Crane facility special technician: crane driver	0.5		3		6		1			1	Monthly	check and operation monitoring
												Yearly	check and change defect parts
												Yearly	check and change bearings
												Yearly	annul check for gears and wires
												Yearly	oil and greasing bearings
												Yearly	annul check for gears and wires
	Total	10.5	0	39	0	577	0.5	7	6	2	1	11	
	Frequency	365	52	12	4	1							
	Total hours in a year (hrs)	3833	0	468	0	1154							
	Gross hours in a year (hrs)	5455											
	Ratio of O&M activity	0.6											
	Gross hours in a year (hrs)	9091											

Standard Manpower working hours for Bilbes BPS

No.	Equipment	Required working time for required activity period (hour)						Resource (jobs)			Interval	Activities	
		Daily	Weekly	Monthly	3-mo.	Yearly	Emergency	sv	te	spt			
BPS 1	Clear water reservoir	2		4		240		3	1		1	Monthly	monitor operation and water level
												Yearly	maintain the inlet gates
												Emergency	repair and paint gates, Cleaning & disinfection
BPS 2	Booster pump	8		12		as required		1	2		2	Monthly	check and operation monitoring
												Yearly	Greasing and stuffing box check
												Yearly	check and adjust all relays
												Daily	check water level
BPS 3	Chlorination facility special technician: chlorine handling	4		16		as required		1	1		2	Monthly	repair chlorine injection equipment
												Yearly	check and control dose
												Yearly	check all valves
BPS 4	Piping and valves	2		6		144		1			4	Monthly	greasing and stuffing box check
												Yearly	polish and repaint all valves
BPS 5	Instrumentation	1		2		as required		1			1	Monthly	check instrument functions
												Yearly	check measured data
BPS 6	Electrical power supply	1		6		184		1	2		2	Monthly	recalibration all instruments
												Yearly	check and operation monitoring
BPS 7	Diesel generator	1		3		8		1	2		2	Monthly	check and operation monitoring
												Yearly	repair and adjust all relays
												Daily	check machine condition
												Yearly	run at full load
												Daily	check cover and change defect parts
BPS 8	Crane facility special technician: crane driver	1		3		6		1	1		1	Monthly	check and operation monitoring
												Yearly	check and change bearings
BPS 9	Elevated tank	1		4		240		1	1		2	Monthly	annul check for gears and wires
												Yearly	operation and water level monitoring
												Yearly	maintain valves and level indicator
												Yearly	repair and paint valves
	Total	21	0	56	0	822		3	8	2	0	17	
	Frequency	365	52	12	4	1							
	Total hours in a year (hrs)	7665	0	672	0	1644							
	Gross hours in a year (hrs)	9981											
	Ratio of O&M activity	0.6											
	Gross hours in a year (hrs)	16635											

— Extra working hours shall be added as per required works. (estimated factor: 2)

(estimated factor of ratio of O&M activity/whole work hours of activity in the plant)


No.	Equipment	Daily	Weekly	Monthly	3-mo.	Yearly	Emergency	sv	acc	sp/	cle	wk	Interval	Activities
-----	-----------	-------	--------	---------	-------	--------	-----------	----	-----	-----	-----	----	----------	------------

Component of technical staff in the current in Asulougi WPS


worker No.	
Technician	3
Chemist	—
Laborer	6
Total	9

Numbers of worker are put into table as default value

operation schedule for Raw Pumps at Abbasa WTP



operation schedule for Raw Pumps at Abbasa WTP



7. Operation Schedule

zagazig wtp
operation schedule for alum pump

Alum pump 3	Alum pump 2	Alum pump 1	date
			1
			2
			3
			4
			5
			6
			7
			8
			9
			10
			11
			12
			13
			14
			15
			16
			17
			18
			19
			20
			21
			22
			23
			24
			25
			26
			27
			28
			29
			30

not work work

zagazig wtp
operation schedule for washing pump

wash pump no 2	wash pump no 1	date
		1
		2
		3
		4
		5
		6
		7
		8
		9
		10
		11
		12
		13
		14
		15
		16
		17
		18
		19
		20
		21
		22
		23
		24
		25
		26
		27
		28
		29
		30

not work work

zagazig wtp
operation schedule for booster pump

booster pump 2	booster pump 1	date
		1
		2
		3
		4
		5
		6
		7
		8
		9
		10
		11
		12
		13
		14
		15
		16
		17
		18
		19
		20
		21
		22
		23
		24
		25
		26
		27
		28
		29
		30

not work work

zagazig wtp
operation schedule for BLOWER

blower no 2	blower no 1	date
		1
		2
		3
		4
		5
		6
		7
		8
		9
		10
		11
		12
		13
		14
		15
		16
		17
		18
		19
		20
		21
		22
		23
		24
		25
		26
		27
		28
		29
		30

not work work

zagazig wtp
operation schedule for sludge pump

date	sludge pump 1	sludge pump 2
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		
25		
26		
27		
28		
29		
30		

not work
work

8. Emergency Plan

Assumption of Emergency Situation and The measures against Emergency Situation

SHAPWASCO
JICA Expert Team
14/February/2009
Ver-1

Preface

Water supply facility is one of the most important infrastructures for the people. The safe water and sufficient amount water shall be supplied to the people every day from the water supply facility with reasonable price. Hence, equipment and water treatment process shall be maintained in suitable condition always by adequate operation and maintenance activities.

However, generating of contingency situation in the water supply facility should not be avoided even by daily adequate operation and maintenance activities.

Under the above situations, persons in water supply facility should need to prepare the activity plan against the contingency situation beforehand. Some of the contingency may reach to the emergency situation by unsuitable response speed against contingency. Hence, the preparations of activity plans against emergency situation are useful and important for the water supply facility staff.

This document provides required items for the preparations of activity plans against emergency situations as following:

- 1) Definition of a emergency situation
- 2) Assumption of emergency situation
- 3) The acknowledgment of the risk and risk assessment
- 4) Required measures against emergency situation
- 5) Procedures for required activities against emergency situation

1. Definition of assumption of emergency situation in water supply facility

Emergency situations in water supply facility are as followings.

1-1.The situation that water supply facility is unable to function, or is predicted to unable function as a water supply facility.

The situation that it became impossible to secure or is predicted to secure required water quality or required water quality or required transmission water quantity, and required transmission water pressure

The assumed unusual conditions to lead to emergency

- 1) Unusual condition of source water quality
- 2) Unusual condition of intake facility
- 3) Unusual condition of transmission water facility
- 4) Power down
- 5) Unusual residual chlorine in transmission water
- 6) Unusual turbidity of transmission water

1-2.The condition that with a possibility of exerting a danger on environment around water supply facility

- 1) Leakage of chlorine gas

2. Detection of emergency situation

By early detection of emergency situation, it is possible that bad affects to the plant generated by emergency situation can be minimized. Periodical monitoring and check should be required to detect the assumed emergency situations in the generated early phase. The assumed unusual situations to lead to emergency should be monitored and checked every two (2) hours in a day.

1) The required measures against Emergency Situation

When the emergency situation will be generated, discoverer of the emergency situation shall inform the generation of emergency situation to plant manager.

If plant manager will be absent or it will not be able to contact with the plant manager, the discoverer shall inform to number two's person in charge who decided beforehand.

The plant manager or number two's person in charge who decided beforehand, shall grasp the actual current situation of emergency on site. After the above mentions, the situation will be judged as actual emergency situation by the plant manager, the plant manager shall carry out the correspondent treatment according to the procedures beforehand immediately. Simultaneously the plant manager shall contact or inform the generation of emergency situation to relative sections.

In case of actions against the emergency situation, the plant manager shall call the required staff and order the required materials for treatment of recovery of emergency situation and treat to recovery of the emergency situation immediately

3. Risk assessment for situation of assumed emergency situation

The degree of risk C is indicated by the calculation result of the product of A and B shown as following.

$$C = A \times B$$

A: Degree of effects by generation of unusual situation

B: Possibility of generation of unusual situation

C: Degree of the risk

In this document, A and B in the above mentions are set the three (3) stages individually for assessment of degree of the risk. A (Degree of effects by generation of unusual situation) is set as three (3) stages tentatively as following

Stage 3 Serious effects which affect a human body or a human life

Stage 2 Medium effects which affect the whole water supply facility

Stage 1 Light effect which affects a part of water supply facility

B (Possibility of generation of unusual situation) is set as three (3) stages tentatively based on experiences in the past as following

Stage 3 Case that possibility of generation will be more than twice in a year

Stage 2 Case that possibility of generation will be more than once in a year

3/7-F

Negative pressure will be remaining in chlorine gas pipes of the chlorinator at immediate after of stop of chlorine dose. However, remaining negative pressure will be decrease in a few hours and decrease of negative pressure will cause the chlorine leakage. Hence chlorine gas supply should be stopped from chlorine drum and check no leakage of chlorine gas from chlorine gas pipes and the chlorinator. In case of chlorine gas leakage, chlorine gas neutralization equipment shall be operated and leaked chlorine gas shall be neutralized and after that exhausted to outside.

1-2) Stop of flow out from the filter by close of outlet valve of the filter

In case of use the motor actuated valves for the filter piping, motor actuated valve is kept the condition at power down. Hence, the filter is kept the filtering and filtered water flows out into the reservoir even under condition of power down. In case of using of manual valves, same situation as the above mentions. During filtering under condition of power down, chlorine dose is stopped and chlorine is not dosed into the filtered water. This situation is continued during power down. Residual chlorine of clear water cannot be controlled.

1-3) Stop of alum dose

In Abbassa WTP, alum is dosed into the raw water by gravity. Alum is kept dosing during power down under situation that raw water supply to the distribution shaft is stopped. By this result, alum will be dosed into raw water excessively and unnecessarily. Excessive dose of alum will be cause of poor coagulation when plant operation will be resumed after recovery of power down. And excessive and unnecessary alum dose is waste consumption of alum.

Hence, alum dose shall be stopped immediately at generating of power down.

1-4) Other rotary machines

All rotary machines shall be in condition of stop by manually as one of the safety action. These machines will be stopped suddenly in condition of working of switches at generating of power down and these machines may start automatically at recovery of power down however this action is not necessary for machines with protection circuit to avoid automatic re-start after power down.

It is necessary to confirm and restart the machines immediately after recovery of power down.

1-5) Confirmation of water level in clear water reservoir

Water level in the clear water reservoir will be not decrease because the transmission pump is stopped during power down but may be increase by water flow from the filter. the filtered water will not flow into the reservoir under usual condition during power down. However, if water sealing ability of filtered water valves or inlet water for reservoir will not be sufficient, water will flow into the reservoir even under conditions of valve closed. In this case, water level in the reservoir may increase. And clear water may flow out through overflow pipe. If overflow pipe is not available in the reservoir, water will flow out to the outside from the reservoir through inspection opening. Flown out water from the reservoir may cause damage of other equipment as

5/7-F

Stage 1 Case that it may generate but possibility of generation is very low

According to the above mentions, calculation results of degree of the risk C is shown in following table.

Assumed unusual	Effect (A)	Possibility (B)	Risk (C)
Water quality of intake	3	1	3
Facility of intake	1	1	1
Facility of transmission	1	1	1
Power down	3	3	9
Residual chlorine of transmission water	3	1	4
Turbidity of transmission water	3	1	3
Chlorine leakage	3	2	6

The result of assessment on the risk is shown as following table

Risk level	Risk item
High	Power down and chlorine leakage
Medium	Water quality of intake, Residual chlorine and turbidity of transmission water
Low	Facility of intake and facility of transmission

Preparations for the measure against the emergency situation will be carried out depend on the risk level.

To decrease the risk level, it should be required that implementation of daily monitoring, maintenance of stand-by equipment and study about automatic detection system for generated unusual condition.

5. The required treatment against emergency situation

5-1 Power down

The cases of power down are separated to 2 kinds. One is the case that schedule of power down is informed by staff in power station. Another is the case of sudden happening. In case of former, stop of water supplying can be informed to the customers and preparations for power down can be carried out by staff in water supply facility such as preparation of operation of diesel engine generator.

In case of sudden power down, the function of water supply facility will be stopped in the meantime.

1) Treatment activities at power down

1-1) Stop of chlorine dose

Chlorine dose is carried out by suck of chlorine gas into the injector by vacuum pressure generated by injector and vacuum pressure in injector is generated by pressure water supply by booster pump. After power down, chlorine dose can not be performed because of stop of booster pump for injector. Hence, chlorine gas supply should be stopped to avoid chlorine gas leakage. Chlorine gas supply is stopped by close of valve for chlorine gas master valve of chlorine drum.

4/7-F

secondary accident. Hence during power down, water level in clear water reservoir shall be confirmed periodically and it shall be avoided that water level of the reservoir become high abnormally. Water level of reservoir can be avoided by handling of drainage valve to be opened.

2) The required treatment at recovery of power down

The activities and procedures for treatment at recovery of power down are almost same procedures as start up for water supply facility. After confirmation of water level in each basin and quality of water in the clear water reservoir, then start up the transmission pump. After that start up the raw water pump and chlorine and alum dose simultaneously. Flash mixer, flocculator, sludge collector should be started one by one.

The filtering should start after confirmation and adjustment of water level in the filter basin.

After completion of start up of all facilities, water quality of clarified water and filtered water shall be monitored. And alum dosing rate and/or chlorine dosing rate shall be adjusted as required for treatment process, if necessary. Tentative increase of chemical dose will be required often at start up of water supply plant.

5-2. The required treatment against accident of chlorine leakage

Chlorine gas is poisonous gas and it is the cause of inflicting an injury on a human life in case that the high concentration chlorine is attracted by a person. The chlorine gas leakage shall be detected early as soon as possible. Hence, the chlorine leakage shall be checked by chlorine gas detector automatically and continuously, and periodical check shall be carried out by operator by manually.

The rooms with a possibility that chlorine leakage may occur are container storage room and chlorinator room. The chlorine leakage in container room will be cases of leakages from containers and chlorine gas pipes and valves. The chlorine leakage in chlorinator room will be cases of chlorine leakages from the chlorinators and chlorine gas pipes and valves.

A possibility of generating of chlorine leakage will be high from chlorine gas pipes and valves, because that handling works of valves and tube in chlorine gas piping are one of the routine works accompanying container change activity for the operation staff in charge of chlorination equipment. The main causes of leakage from chlorine gas piping and valves will be degradation of gaskets and of sealing performance of piping and valves. Hence, the possibility of generating of chlorine leakage accident will be able to reduce by implementation of periodical inspection and replacement of parts.

1) The required treatment against high-concentration of chlorine leakage

(In case that concentration of chlorine leakage is more than 1ppm)

The action performed by discoverer of chlorine leakage accident is to close the doors of room under condition of leakage of chlorine. The diffusion of leaked chlorine gas to the open air shall be avoided by this action. After that chlorine gas neutralization equipment shall be

6/7-F

started.

The working chlorinator shall be kept working during the above actions.

Then the discoverer shall inform the actual status of chlorine leakage to the plant manager and shall arrange the staff to aid against chlorine leakage accident. The discoverer does not take action to treat for any repairing or investigation activity. The action by one person is very dangerous. The treatment action against chlorine leakage accident shall be carried out by 2 persons or more to ensure the safety for operator.

The investigation to find out the portion of chlorine leakage shall be carried out under condition with gas mask wearing. Prior to investigation master valve for container shall be closed at the first action.

After specifying the leakage portion, first-aid treatment shall be carried out in order to lessen the leaking chlorine amount and enforcement person once comes out of a room and waits until chlorine concentration in the room becomes low. Detail investigation and recovery or repairing activities shall be carried out after chlorine concentration in the room will be low.

Ammonia solution water shall be used to find out the leakage portion of chlorine gas. If the cloth in which aqueous ammonia was dipped is put closely to the leakage part of chlorine, white smoke will come out. We can specify the chlorine leakage portion to confirm that the place where white smoke comes is checked.

2) The required treatment against high-concentration of chlorine leakage

(In case that concentration of chlorine leakage is less than 1ppm)

In case that concentration of chlorine leakage is less than 1ppm, the action performed by discoverer of chlorine leakage accident is to open all the doors of room under condition of leakage of chlorine for the diffusion of leaked chlorine gas to the open air. After that, investigation and recovery or repairing activities shall be carried out after chlorine concentration in the room will be low.

5-3. Unusual concentration of residual chlorine in transmission water

1) Unusual low concentration of residual chlorine in transmission water

Unusual low concentration of residual chlorine in transmission water will be a fault of supply of safe water to the network. Residual chlorine concentration as free is checked by water analysis of the sampled water taken from the pipe of transmission pump and/or the transmission pipe line.

However, the water quality as concentration of residual chlorine in transmission water, shall be monitored the inlet water to the clear water reservoir, that is filtered water after dosing of post-chlorine, simultaneously. If concentration of residual chlorine in transmission water is unusual all the water in the reservoir shall be replaced to the suitable quality water, or be adjusted the concentration of residual chlorine of water in clear water reservoir to be suitable.

By the monitoring the water in the pre-process prior to final transmission water process, it is easy to

7/7-F

If condition of unusual high turbidity in transmission water is generated, the discoverer shall inform the fact to the plant manager and grasp the actual situation and investigate the cause of unusual condition. After grasping the actual situation and site investigation, the cause of unusual high turbidity in transmission water shall be specified and cause of unusual condition shall be removed. The filter or the reservoir cause of high turbidity water shall be specified. After specifying the causes, the filter and the reservoir, stop the working of specified filter or reservoir and the high turbidity water shall be drained as required. If unusual high turbidity condition is generated in the reservoir, the inside of reservoir shall be inspected totally and intimately under condition of empty.

5-5. Unusual condition of source water quality

The unusual condition of source water quality shall be detected in early stage of contamination of source water by implementation of daily monitoring of visual check, smell check and water analysis.

When the unusual condition is detected in source water, the unusual condition shall be informed to the plant manager immediately. And the actual unusual condition shall be confirmed by the plant manager the chemist and required treatment such as shut down of intake water shall be carried out immediately, if necessary. It becomes possible that the contamination of the facilities in the plant can be minimized for water supply facility, by early detection of contamination of source water and early judgment of shut down of intake water to avoid inflow of contaminated source water into the water facility. The unusual condition of source water quality shall be informed to the outside section of SHAPWASCO in charge of canal management in parallel to carry out required treatment activities for the water supply facility. The unusual condition of source water quality shall be informed to SHAPWASCO H/Q and SHAPWASCO H/Q shall inform the unusual condition of source water quality to the relative other water supply facilities in SHAPWASCO if necessary.

The check items for judgment of unusual situation of canal water are as following.

- 1) The case that color or turbidity of canal water is changed remarkably
(This case include the condition that oil and fat is floating remarkably on the water surface)
- 2) The case that smell of canal water is changed remarkably
- 3) The case that a large number of dead fishes are floating

The communication regime shall be provided between SHAPWASCO, water supply facilities and other relative outside and inside sections of SHAPWASCO to perform the rapid treatment activities in corporation with each relative section against the unusual situation of source water quality.

5-6. Unusual condition of intake facility and/or transmission facility

Stand-by equipment is installed to keep the function of water supply facility working.

Therefore, the above both facilities can be worked continuously with their functions in case that unusual condition is generated in a part of these facilities.

9/7-F

perform that concentration of residual chlorine in transmission water to be kept in a treatment target range by adjustment the dosing rate of post-chlorine.

2) Unusual high concentration of residual chlorine in transmission water

If condition of unusual high concentration of residual chlorine in transmission water is generated, the discoverer shall inform the fact to the plant manager and grasp the actual situation and investigate the cause of unusual condition. After grasping the actual situation and site investigation, the cause of unusual high concentration of residual chlorine in transmission water shall be specified and cause of unusual condition shall be removed. After that the high concentration water shall be drained of be adjusted the concentration of residual chlorine of water in clear water reservoir to be suitable.

When the high concentration water of residual chlorine is drained, the high concentration water of residual chlorine shall be diluted to the low concentration that drainage water does not affect to the ecosystem around the water supply facility. For reference, effects of residual chlorine to fishes are shown as following:

- A carp can be survived in the water under the condition that free residual chlorine is less than 10 mg/l.
- The survival rate of a carp is 20% in the water under the condition that free residual chlorine is less than 3 mg/l.

5-4. Unusual turbidity in transmission water

The turbidity of inlet water to the clear water reservoir shall be monitored to check the turbidity in transmission water by a same reason as the above mentions about motoring of residual chlorine of the transmission water. And turbidity in the water shall be motored the water of the upstream process such as filtering process. The causes which may generate unusual turbidity in transmission water are as following

- Unusual high turbidity of filtered water
- Contamination of the water in the clear water reservoir
- Contamination of the water flowing from the filter to the clear water reservoir

The condition of unusual high turbidity of filtered water is the high possibility cause which unusual turbidity in transmission water generates.

The major causes which may generate unusual turbidity in filtered water are as following

- Unusual high turbidity of clarified water
- Unusual high filtering rate
- Unusual filter run time
- Damage of under drain system

The monitoring and control of turbidity of filtered water are the essential activities to avoid the generation of unusual turbidity in transmission water.


8/7-F

However, stand-by equipment shall be carried out the inspection and check of the equipment and working conditions constantly. And if unusual condition is generated in a part of equipment, generated unusual condition shall be recovered with investigation of cause of unusual condition. Corrective action shall be carried out through the activities of investigations and analysis about detail cause of unusual condition such as operation status, frequency of maintenance activities, and so on. Depend on the unusual situation of the equipment, procurement of the component parts takes a long periods. Hence, consumable parts for the equipment should be store for stock in the plant as much as possible.

Flow charts for major procedures for required treatment activity against emergency situations are shown in next pages.

10/7-F

Major procedures for the required treatment activities at recovery of power down




3/7-F

1/7-F


Flow chart for major procedures for required treatment activity against emergency situations

Major procedures for the required treatment activities against chlorine leakage




4/7-F

Major procedures for required treatment activity against power down a accident




2/7-F

Major procedures for the required treatment activities against unusual condition of source water quality




7/7-F

Major procedures for the required treatment activities against unusual condition of residual chlorine of transmission water



5/7-F

Major procedures for the required treatment activities against unusual turbidity in transmission water



6/7-F

9. Trouble Shootings

Trouble Shootings for Water Treatment Plant

- 1) Trouble Shootings for System
- 2) Trouble Shootings for Process

SHAPWASCO

JICA Expert Team

February-2009 Ver-1

Name of System	Predicted Trouble	Cause	Remedy	Required Corrective Action
S-2 Coagulation and sedimentation system	S-2-2 Existing of foreign substances in the raw water basin	1) Inadequate setting up of intake screen 2) Clearances between screen bars of intake screen is too rough 3) Tapping of foreign substances into the intake channel from intake area	1-1) Check the setting up condition of intake screen and set the screen into the frame of screen if necessary 2-1) Modification of intake screen 3-1) Disposal of removed foreign substances	Daily inspection Periodical inspection Daily inspection
	S-2-3 Inadequate water level of raw water basin	1) Raw water quantity is not sufficient to the raw water basin from water intake 2) Clogging of the raw inlet valve of the raw water basin by the foreign substances 3) Clogging of the raw outlet valve of the raw water basin by the foreign substances	1-1) Refer to S-1-1 2-1) Check the intake channel condition and the condition of clogged pipe in the condition of having lowered the water level of the raw water basin 3-1) Disassemble the piping and cleaning or flushing inside of raw water outlet pipe of raw water basin	Refer to S-1-1 Periodical inspection Periodical inspection
	S-2-1 Inadequate distribution quantity for each distribution shaft	1) Inadequate opening degree of valves of raw water transfer pipes 2) Clogging of inside of pipe of raw water transfer pipe	1-1) Adjustment of valve opening degree locking at indicator of raw water flow 2-1) Cleaning of raw water transfer pipe by flushing the inside of pipe	Daily inspection Daily inspection
S-2-2 Inadequate distribution quantity of raw water to each sedimentation basin	1) Inadequate opening degree of raw water outlet valve of distribution shaft	1-1) check the opening degree of raw water outlet valve of distribution shaft	Daily inspection	Daily inspection
S-2-3 Insufficient mixing of raw water and chemicals in the rapid mixing basin	1) Stop of flash mixer	1-1) Check the flash mixer and repair, re-installing or overhaul of the flash mixer if necessary	Daily inspection	Periodical inspection

S-2/12

3.10-28

Trouble shooting sheets for system and process in WTP
S-3. Trouble shooting sheets for WTP system

Name of System	Predicted Trouble	Cause	Remedy	Required Corrective Action
S-1 Water Intake system	S-1-1 Raw water quantity is not sufficient to the raw water basin from water intake	1) Insufficient opening degree of intake water gates 2) Intake water screen is clogged by foreign substances 3) Intake channel is clogged by precipitated mud or foreign substances	1) Check opening degree of intake water gates to adequate opening degree 2-1) Check the screen condition and cleaning, remove mud or foreign substances in the intake channel, if necessary. Removed mud or foreign substances should be disposed. 3-1) Check the intake channel condition and clean up precipitated mud or foreign substances in the intake channel, if necessary. Removed mud or foreign substances should be disposed.	Confirmation of opening of water intake gate and open the gate Daily inspection Daily inspection
S-3 Filtering system	S-3-1 Inadequate water level in filter basin	1) Unusual condition of mixing shaft or paddle of flash mixer	2-1) Check the installation condition of mixer and paddle of flash mixer and repair or adjust the alignment of shaft should be conducted if necessary	Periodical inspection
		1) Clogging inside of sludge drainage pipe in the sedimentation basin	1-1) Check the condition of precipitated sludge around sludge collecting pit. If uneven precipitated condition of sludge is confirmed, review of it should be considered that modifying or sludge drainage pipings such as pipe diameter of sludge drainage pipe inside of the sedimentation basin	Daily inspection Periodical inspection
		2) Discharge pipe or valve is clogged	2-1) Flushing out inside of discharge pipe by compressed water supply or remove the foreign substances in valve by demanding of valve	Periodical inspection
		1) Inadequate filtering rate	1-1) The filtering rate should be kept in less than 120m ³ /d 2-1) The filter media should be refreshed according to the procedures of filter washing	Daily inspection Periodical inspection Periodical check of effectiveness of filter washing
		2) Clogging of filter media	2-2) Removal of fine surfacing sands 2-3) Completion of removal of air in sand layer prior to operation of the filter after maintenance activities of filter equipment Do not start the filter washing without air removal in the back wash water separator drain or sand layer	Periodical inspection Check prior to operation after maintenance activities Do not start the filter washing without air removal in the back wash water separator drain or sand layer
		1) Inadequate water level in the raw water basin	5-1) Check the condition of outlet valve and remove clogging foreign substances if necessary 6-1) Check the intake channel condition and flush out the water in the clogged pipe in the condition of having lowered the water level of the raw water basin	Periodical inspection and cleaning Periodical cleaning
		7) Clogging of the raw inlet valve of the raw water basin by the foreign substances	7-1) Check the condition of raw water inlet valve of raw water basin in the condition of having lowered the water level of the raw water basin	Periodical inspection

S-1/12

S-3/12

Name of System	Predicted Trouble	Cause	Remedy	Required Corrective Action
		3) Nonuniformity of filter media depth between left bank and right bank of filter basin	3-1) Check the depth of sand layer about left bank and right bank 3-2) Check the flow out of sand during filter washing time or filter washing water quantity is modified if necessary	Periodical inspection Periodical check of effectiveness of filter washing
		4) Unusual condition of under drain system with water collection equipment	4-1) When unusual condition is not observed in above mentions 1)2)3), there is possibility that under drain system is in unusual condition such as damage of water collection pipe or uneven arrangement of M or sand layer	Periodical inspection Do not start the filter washing without air removal in the back wash pipe, under drain or sand layer
	S-3-2 Inadequate filter rate	1) Inadequate valve opening degree of control valve of filtering rate 2) Nonuniformity of filter media depth between left bank and right bank of filter basin 3) Clogging of filter media 4) Unusual condition of under drain system with water collection equipment	1-1) Check the filtered water flow rate control valve of filtering rate to adequate flow rate 2-1) Refer to S-3-1 3-1) Refer to S-3-1 4-1) Refer to S-3-1	Daily inspection Refer to S-3-1 Refer to S-3-1 Refer to S-3-1

S-4/12

Name of System	Predicted Trouble	Cause	Remedy	Required Corrective Action
	S-3-3 Insufficient air scouring	1) Unusual condition of blower for air scouring 2) Wear of rotor of blower for air scouring 3) Clogging of suction air strainer 4) Clogging of air scouring pipe or valve 5) Clogging of filter media 6) Nonuniformity of filter media depth between left bank and right bank of filter basin 7) Opening degree of air scouring valve is not full	1-1) Investigation of cause according to the instruction manual of equipment 2-1) Check the condition of suction air filter and clean the strainer or replace the filter Frequency of replacement of strainer should be carried out according to the instruction manual of equipment. 3-1) Same as above mentions 4-1) There is a possibility that pipe is blocked with sand from filter through under drain. Check the pipe inside or valve by dismantling of pipe connection and clean inside of pipe or valve, if necessary 5-1) Refer to S-3-2 6-1) Refer to S-3-1 7-1) Check the opening of valve and inspection of valve, overhaul or repairing of valve or, if necessary	Daily inspection Periodical inspection Periodical inspection Periodical inspection Periodical inspection Periodical inspection Periodical inspection

S-5/12

Name of System	Predicted Trouble	Cause	Remedy	Required Corrective Action
	S-3-4 Nonuniform air bubbling by air scouring to the whole filter basin	1) Clogging of filter media 2) Clogging of air scouring pipe or valve 3) Nonuniformity of filter media depth between left bank and right bank of filter basin 4) Unusual condition of under drain system with water collection equipment	1-1) Refer to S-3-1 2-1) Refer to S-3-3 3-1) Refer to S-3-1 4-1) Refer to S-3-1	Refer to S-3-1 Refer to S-3-3 Refer to S-3-1 Refer to S-3-1
	S-3-5 Insufficient back washing	1) Insufficient opening degree of back wash valve 2) Unusual condition of back wash pump 3) Wear of main parts of back wash pump 4) Opening degree of back wash valve is not full 5) Clogging of filter media 6) Clogging of back wash pipe or valve 7) Air accumulator ball in back wash pipe	1-1) Adjustment of valve opening degree of back wash water discharge valve looking at indicator of filtered water flow meter Flow rate of back wash water should be approximately 0.5 m ³ /m ² /min 2-1) Investigation of cause according to the instruction manual of equipment 3-1) Check the inside of the pump according to the instruction manual of the pump and overhaul, replace parts if necessary 4-1) Check the opening of valve and inspection of valve, overhaul or repairing of valve or, if necessary 5-1) Refer to S-3-1 6-1) Refer to S-3-3 7-1) Completion of removal of air in sand layer prior to operation of the filter after maintenance activities of filter equipment	Daily inspection Periodical inspection Periodical inspection Periodical inspection Periodical inspection Refer to S-3-1 Refer to S-3-3 Check prior to operation after maintenance activities Do not start the filter washing without air removal in the back wash pipe, under drain or sand layer.

S-6/12

Name of System	Predicted Trouble	Cause	Remedy	Required Corrective Action
	S-3-6 Nonuniform back washing to the whole filter basin	1) Clogging of filter media 2) Clogging of back wash pipe or valve 3) Nonuniformity of filter media depth 4) Unusual condition of under drain system 1) Nonuniform level of filter sand layer	1-1) Refer to S-3-1 2-1) Refer to S-3-3 3-1) Refer to S-3-1 4-1) Refer to S-3-1 1) refer to S-3-6	Refer to S-3-1 Refer to S-3-3 Refer to S-3-1 Refer to S-3-1 refer to S-3-6
S-4 Chemical and chlorine dosing system	S-4-1 Coagulant is not dosed	1) Insufficient valve opening, supply valve of alum solution from alum supply tank is clogged 2) Outlet valve of alum solution supplying is clogged 3) Clogging of strainer for alum solution supply pipe 4) Clogging of inside of ball tap for alum solution supply 5) Clogging of inside of flow meter for measuring of alum dosing quantity 6) Damage of alum dosing pipe 7) Clogging or damage of alum dosing pipe	1) Open fully the alum supply valve 2) Check the inside of valve by disassembling of valve and cleaning of inside of valve if necessary 3) Cleaning of strainer mesh 4) Check the normal working of ball tap and disassemble and clean the needle valve of ball tap if necessary 5) Cleaning inside of flow meter by hot water 6) Check the solution level of alum dosing tray Check the discharge pressure of alum dosing pipe Cleaning inside on alum dosing pipe if necessary 7) Check the solution level of alum dosing tray Check the discharge pressure of alum dosing pipe Repair the damaged part of alum dosing pipe if necessary	Daily inspection Daily inspection Periodical cleaning Periodical cleaning Daily inspection Periodical cleaning Daily inspection Daily inspection Periodical cleaning Periodical cleaning Daily inspection

S-7/12

Name of System	Predicted Trouble	Cause	Remedy	Required Corrective Action
S-4	The set-up pre-chlorine dosing rate is not dosed into the raw water.	1) Unusual condition of chlorinator control valve of chlorinator	1) Refer to S-4-3	Refer to S-4-3
		2) Inadequate valve opening of flow rate control valve of chlorinator	2) Refer to S-4-3	Refer to S-4-3
		3) Clogging of a injector	3) Refer to S-4-3	Refer to S-4-3
		4) Insufficient water supply pressure for the injector	4) Refer to S-4-3	Refer to S-4-3
		5) Insufficient chlorine quantity in the in-use container(s)	5) Refer to S-4-3	Refer to S-4-3
		6) Valve of chlorine gas feeding line is not opened	6) Refer to S-4-3	Refer to S-4-3
		7) Unusual condition of chlorine gas pressure reducing valve such as clogging at needle valve part	7) Refer to S-4-3	Refer to S-4-3
S-4-5	Post-chlorine is not dosed	8) Unusual condition of chlorine water dosing pipe	8) Check the chlorine dosing pipe and repair the pipe if necessary.	Periodical inspection
		9) Check the chlorine dosing valve and open valve fully the valve opening if necessary.		Daily inspection
S-4-6	The set-up post-chlorine dosing rate is not dosed into the raw water.	1) Same as S-4-3	1) Refer to S-4-3	Refer to S-4-3
		1) Same as S-4-4	1) Refer to S-4-3	Refer to S-4-3
S-5	Inadequate water level of clear water reservoir	1) The raw water quantity is not an amount corresponding to the distribution water quantity	1) Raw water quantity should be controlled to be adequate water level range in clear water reservoir	The adequate control of raw water quantity based on collected data about change trend based on time progress in a day and seasonal water demand in network
		2) Water leakage from clear water reservoir by damage of clear water reservoir	2) Check the inside of clear water reservoir and repair it if necessary	Periodical inspection

S-10/12

Name of System	Predicted Trouble	Cause	Remedy	Required Corrective Action
S-5-2	Inadequate distribution water quantity	3) Damage of clear water inlet pipe or clear water outlet pipe of clear water reservoir	3) Check the water leakage of clear water inlet pipe or clear water outlet pipe of clear water reservoir and repair it if necessary	Periodical inspection
		4) Inadequate opening of outlet valve of filtered water	4) Check the valve opening degree of the outlet valve and the valve opening should be changed if necessary.	Daily inspection
		1) Inadequate working number of distribution pump	1) Check the indicator of distribution water flow meter and working number of distribution water pump should be changed according to requirement of water demand in the network, if necessary.	The adequate control of distribution water quantity based on collected data about change trend based on time progress in a day and seasonal water demand in network
		2) Low water level of distribution water pump sump	2) Check the inside of distribution water pump sump and repair it if necessary	Periodical inspection
S-5-3	Cavitation of distribution water pump	3) Check the working condition of the distribution water pump and the number of working pump should be set so that the discharge quantity of each distribution water pump may become below allowable value. Cavitation of pump has to avoid anytime.		Daily inspection
		4) Investigation of cause of unusual condition according to the instruction manual of equipment		Periodical inspection

S-11/12

Name of System	Predicted Trouble	Cause	Remedy	Required Corrective Action
S-4-2	The alum of set-up dosing quantity does not flow	8) Insufficient solution level in alum solution tank	8) Change the solution tank for use	Daily inspection
		9) Alum dosing pump is stopping	9) Investigation of cause according to the instruction manual of equipment.	Daily inspection
		10) Unusual operation of ball check valves inside of dosing pump	10) Check the inside of the dosing pump according to the instruction manual of the dosing pump and clean, overhaul.	Periodical inspection
		11) Clogging of inside of back pressure valve	11) Check the opening of back pressure valve and check inside of valve and clean the inside of valve if necessary	Daily inspection
		12) Inadequate pre-set pressure value of back pressure valve	12) Check the pressure indicator and re-set the set pressure of back pressure valve if necessary	Periodical inspection
		13) Unusual condition of alum dosing pump	13) Investigation of cause according to the instruction manual of equipment	Daily inspection
		1) Inadequate valve opening of valve for control of alum dosing flow rate	1) Adjust the valve opening of flow rate control valve to adequate flow rate. Adequate flow rate should be calculated based on raw water flow rate, alum dosing rate and concentration of alum solution.	Daily inspection
		2) Inadequate stroke setting of alum dosing pump for control of alum dosing flow rate	2) Adjust the control dial of dosing pump to adequate discharge flow rate. Stroke flow rate should be calculated based on water flow rate, alum dosing rate and concentration of alum solution.	Daily inspection
		3) Same as S-4-1	3-) Refer to S-4-1	Refer to S-4-1

S-8/12

Name of System	Predicted Trouble	Cause	Remedy	Required Corrective Action
S-4-3	Pre-chlorine is not dosed	1) Unusual condition of chlorinator	1) Check the chlorinator according to the instruction manual of the equipment and overhaul, replace parts if necessary.	Daily inspection
		2) Clogging of a injector	2) Disassemble and check the injector according to the instruction manual of the equipment and clean, overhaul, or replace the parts if necessary	Periodical inspection
		3) Insufficient water supply pressure for the injector	3) Check the indicator of water supply pressure and check the water pressure is supplied to the injector	Daily inspection
		4) Insufficient chlorine quantity in the in-use container(s)	4) Check the indicator of weighing scale of container(s) or pressure gauge of chlorine gas feeding line and chlorine container(s) should be changed over to stand-by container(s), if necessary	Daily inspection
		5) Valve of chlorine gas feeding line is not opened	5) Check the switching condition of valve installed to the line in from container before chlorinator, such as master valve for container, discharge valve from container, and so. Valves should be opened or closed adequately.	Periodical inspection
		6) Unusual condition of chlorine gas pressure reducing valve such as clogging at needle valve part	6) Disassemble and check the chlorine pressure reducing valve and clean, overhaul or replace the parts inside of the valve if necessary.	Periodical inspection
		7) Unusual condition of chlorine water dosing pipe	7) Check the chlorine dosing pipe and repair the pipe if necessary.	Periodical inspection
		8) Check the chlorine dosing pipe and repair the pipe if necessary.		Periodical inspection

S-9/12

Name of System	Predicted Trouble	Cause	Remedy	Required Corrective Action
	S-5-3 Inadequate distribution water pressure	3) Wear of impeller of distribution water pump 1) Inadequate working number of distribution pump 2) Unusual condition of distribution pump 4) Wear of impeller of distribution water	5) Check the impeller of the pump according to the instruction manual and the wear should be inspected and the impeller will be replaced if necessary. 1) Same as S-5-2 2) Same as S-5-2 3) Same as S-5-2 4) Same as S-5-2	Periodical inspection Same as S-5-2 Same as S-5-2 Same as S-5-2 Same as S-5-2

Name of Process	Predicted Trouble	Cause	Remedy	Required Corrective Action
		4-2) Control the coagulant dosing quantity to the value calculated by raw water flow rate and dosing rate of coagulant		Daily inspection
		5) Stop of flash mixer	1-1) Check the flash mixer and repair, re-installing or overhaul of the flash mixer if necessary	Daily inspection Periodical inspection
		6) Unusual condition of mixing shaft or paddle of flash mixer	2-1) Check the installation, condition of mixing shaft and paddle of flash mixer and repair or adjust the alignment of shaft should be conducted if necessary	Daily inspection Periodical inspection
		7) Inadequate operation of flocculator	7-1) Modifying of operating number of flocculators. 7-2) Inspection of shaft and paddles for flocculators and if necessary repair or re-fixing them	The adequate action based on collected data Periodical inspection
		8) Stop of flocculator by unusual condition	8-1) Inspection of insulation resistance and if necessary change or overhaul the motor 8-2) Inspection of power reduction unit and fuses and change or overhaul the power reduction unit 8-3) Insufficient quantity or quality of lubricant	Periodical inspection Daily inspection
		9) Change of meteorological condition (Air temperature, water temperature, weather)	9) There is a possibility that the growth-up flocs may be destroyed by flocculation. Coagulation reaction speed will be high cause of rising of raw water temperature and coagulation flocs will be grown up to be big flocs before flocculation. Modifying of operation number of flocculators Modifying of rotating number of flocculator Judgment of necessity of	The adequate action based on collected data

P-2/7

S-12/12

Trouble shooting sheets for system and process in WTP

P-1: Trouble shooting sheets for WTP process

Name of Process	Predicted Trouble	Cause	Remedy	Required Corrective Action
P-1	Water intake Process	P-1-1 Intake water turbidity changed to unusually high(30 NTU or more)	1) Unusual condition in water source 1-1) Modification of dosing rate of coagulant based on jar test results 1-2) Confirm the treatment condition of coagulation and sedimentation process and water level in clear water reservoir in raw water flow rate should be reduced within possible limit when required. 1-3) Frequency of sludge drainage from sedimentation basin should be modified based on coagulant dosing rate and turbidity of raw water. 1-4) Modifying of operations number of flocculators. 2) Temporary increasing of dosing rate of coagulant.	The adequate action based on collected data The adequate action based on collected data The adequate action based on collected data The adequate action based on collected data The adequate action based on collected data
P-2	Coagulation and Sedimentation Process	P-2-1 Intake water quality became unusual condition such as contamination by hazardous substances or unusual smell or unusual flocs is not sufficient	1) Contamination of source water 2) Re-mixing of removed hazardous substances beside intake channel into the intake channel 1) Change of water quality (pH, turbidity, alkalinity, algae accounts, water temperature, etc.) 2) Inadequate pH of raw water for coagulation reaction	According to emergency action plan. Daily inspection The adequate action based on collected data The adequate action based on collected data The adequate action based on collected data
P-2	Coagulation and Sedimentation Process	P-2-1 Growth of coagulation flocs is not sufficient	3) Inadequate dosing rate of coagulant 4) Inadequate dosing quantity of coagulant	The adequate action based on collected data Refer to S-4-1, S-4-2 of System trouble shooting sheets
P-2	Coagulation and Sedimentation Process	P-2-1 Growth of coagulation flocs is not sufficient	1) Refer to P-2-1 2) Partial rising of flow velocity of inlet water to the sedimentation basin from flocculation basin by partial clogging of inlet opening by prediluted sludge 3-1) Inadequate raw water flow rate to the distribution shaft. 3-2) Inadequate distribution of raw water quantity to the sedimentation basins Refer to S-2-2 1-1) Inadequate pre-chlorine dosing Refer to S-4-3 1-2) Inadequate pre-chlorine dosing flow rate 1-3) Inadequate pre-chlorine dosing rate Increasing of vapored free residual chlorine amount from water source to flocculation basin by rising of air temperature. Increasing of consumed free residual chlorine by rising of water temperature Increasing of chlorine demand of raw water by changing of raw water quality such as cause of increasing of algae accounts	Refer to P-2-1 Periodical inspection at the time of inside cleaning of sedimentation Modification of re-arrangement of sludge drainage pipes or modification of structure of inlet opening will be considered if necessary. Refer to P-2-1 Refer to S-2-1 Refer to S-2-2 Refer to S-4-3 Refer to S-4-4 The adequate action based on collected data

P-1/7

P-3/7

Name of Process	Predicted Trouble	Cause	Remedy	Required Corrective Action
P-2-4	Turbidity of clarified water is higher than the treatment target turbidity of clarified water	2) Many carry-over flocs in the effluent water from sedimentation basin 1) Growth of coagulation flocs is not sufficient 2) Many carry-over flocs in the effluent water from sedimentation basin 3) Inadequate dosing of coagulant 4) Inadequate dosing quantity of coagulant 5) Inadequate dosing rate of coagulant 1) Change of water quality (pH, turbidity, alkalinity, algae accounts, water temperature, etc) 2) Change of meteorological condition (Air temperature, water temperature, weather)	2) Refer to P-2-3 1) Refer to P-2-1 2) Refer to P-2-2 3) Refer to S-4-1 4) Refer to S-4-2 5) Refer to P-2-1 1) Refer to P-2-1 2) Refer to P-2-1	Refer to P-2-3 Refer to P-2-1 Refer to P-2-2 Refer to S-4-1 Refer to S-4-2 Refer to P-2-1 Refer to P-2-1 Refer to P-2-1
P-2-5	Free residual chlorine concentration of clarified water is out of range of the treatment target range of free residual chlorine concentration of clarified water	1) Change of water quality (pH, turbidity, alkalinity, algae accounts, water temperature, etc) 2) Change of meteorological condition (Air temperature, water temperature, weather)	1) Refer to P-2-1 2) Refer to P-2-1	Refer to P-2-1 Refer to P-2-1
P-2-6	Drained sludge concentration from sedimentation basin falls in a minute after start of sludge drainage	1) Clogging of sludge drainage pipes in the sedimentation basin 2) Sludge drainage is carried out not smoothly	1) Refer to S-2-4 2) Refer to S-2-5 of System trouble shooting sheets	Refer to S-2-4 Refer to S-2-5 of System trouble shooting sheets
P-2-7	Fishes live in the sedimentation basin	1) Inadequate free residual chlorine concentration of clarified water	1) Refer to P-2-3	Refer to P-2-3
P-3-1	Turbidity of filtered water is higher than the treatment target turbidity of filtered water	1) Turbidity of clarified water is higher than the treatment target turbidity of clarified water 2) Inadequate filter run time 3) Inadequate filtering rate 4) Soil of filter media or mud balls	1) Refer to P-2-4 2) Keeping the pre-set filter run time. Filter run time shall be less than 36 hours 3) Refer to S-3-1 of System trouble shooting sheets 4) Refer to S-3-3,4,5,6 of System trouble shooting sheets	Refer to P-2-4 The adequate action based on collected data Refer to S-3-1 of System trouble shooting sheets Refer to S-3-3,4,5,6 of System trouble shooting sheets
P-3	Filtering Process			

P-4/7

Name of Process	Predicted Trouble	Cause	Remedy	Required Corrective Action
P-3-2	Free residual chlorine concentration of filtered water is out of range of the treatment target range of free residual chlorine concentration of filtered water	1) Inadequate free residual chlorine concentration of clarified water 2) Soil of filter media or mud balls 3) Soil of inner wall of filter basin 4) Change of meteorological condition (Air temperature, water temperature, weather)	5) Refer to S-3-3,4,5,6 of System trouble shooting sheets 1) Refer to P-2-5 2) There is a possibility that the soil of filter media may cause of increase of consumption of free residual chlorine in filter basin. Refer to S-3-3,4,5,6 of System trouble shooting sheets 3-1) Inadequate free residual chlorine concentration of clarified water Refers to P-2-5 3-2) Periodical cleaning of inner wall 4) There is a possibility that the consumption amount of free residual chlorine in filter basin will increase by increasing of vaporized residual chlorine from water surface of filter basin cause of rising of air temperature or water surface evaporation. Modifying of pre-chlorine dosing rate. 1) Refer to P-2-5 2) Refer to P-2-4	Refer to S-3-3,4,5,6 of System trouble shooting sheets Refer to P-2-5 Refer to S-3-3,4,5,6 of System trouble shooting sheets Refer to P-2-5 Periodical inspection Periodical cleaning The adequate action based on collected data Refer to P-2-5 Refer to P-2-4 Refer to S-3-3,4,5,6 of System trouble shooting sheets Refer to P-2-5
P-3-3	Propagation of algae on the filter sand surface	1) Inadequate free residual chlorine concentration of clarified water 2) Inadequate turbidity of clarified water (water/algae account in the clarified water) 1) Inadequate operation of filter washing	1) Refer to P-2-5 2) Refer to P-2-4	Refer to P-2-5 Refer to P-2-4 Refer to S-3-3,4,5,6 of System trouble shooting sheets Refer to P-2-5
P-3-4	Soil of filter media or mud balls	1) Inadequate free residual chlorine concentration of clarified water	1) Refer to P-2-5	Refer to P-2-5
P-3-5	Big amount of algae adhesion to the wall and other parts in the filter basin	1) Inadequate free residual chlorine concentration of clarified water	1) Refer to P-2-5	Refer to P-2-5

P-5/7

Name of Process	Predicted Trouble	Cause	Remedy	Required Corrective Action
P-3-6	Fishes live in the filter basin	1) Inadequate free residual chlorine concentration of clarified water	Refer to P-2-5	Refer to P-2-5
P-3-7	Many air bubbles are arising from filter sand surface in filtering	1) Inadequate water level of filter basin in filtering 2) Inadequate filtering rate	1) Refer to S-3-1 of System trouble shooting sheets 2) Refer to S-3-1 of System trouble shooting sheets	Refer to S-3-1 of System trouble shooting sheets
P-4-1	Turbidity of transmission water is higher than the treatment target turbidity of transmission water	1) Turbidity of filtered water is higher than the treatment target turbidity of filtered water 2) Contamination of filtered water in the filtered water basin 3) Contamination of filtered water in the clear water reservoir	1-1) Inadequate filtering rate. Control the filtering rate to less than 120 m ³ /day by adjustment of valve opening of filtered water flow rate control valve 1-2) Inadequate filter run time. Keeping the filter run time in a range of pre-set value. In a case of sand filter with single layer filter media, filter run time is recommended less than 36 hours or less. 1-3) Soil of filter media. Refer to S-3-3,4,5,6 2) Inspect and repair the filter water basin, if necessary. 3) Refer to S-3-1	Refer to S-3-1 of System trouble shooting sheets The adequate action based on collected data Daily inspection Periodical inspection Periodical inspection Refer to S-5-1
P-4-2	Free residual chlorine concentration of transmission water is out of range of the treatment target range of free residual chlorine concentration of transmission water	1) Free residual chlorine concentration of filtered water is out of range of the treatment target range of free residual chlorine concentration of filtered water 2) Inadequate dosing of post-chlorine 3) Inadequate dosing quantity of post-chlorine	1) Refer to P-3-2 2) Refer to S-4-5 of System trouble shooting sheets 3-1) Refer to S-4-6 of System trouble shooting sheets	Refer to P-3-2 Refer to S-4-5 of System trouble shooting sheets Refer to S-4-6 of System trouble shooting sheets

P-6/7

Name of Process	Predicted Trouble	Cause	Remedy	Required Corrective Action
P-4-3	Unusual consumption of free residual chlorine during retention of clear water in the clear water reservoir	1) Contamination of filtered water by foreign substances in the clear water reservoir 2) Contamination of filtered water by foreign substances in the clear water reservoir 3) Soil of clear water reservoir 4) Change of meteorological condition (Air temperature, water temperature, weather)	Re-set post-chlorine dosing rate base on free residual chlorine of filtered water and free residual chlorine of transmission water. 4) Refer to P-4-1 5) Refer to P-4-1 6) Periodical cleaning of inside of clear water reservoir 7) Increase of consumption of free residual chlorine of water in the clear water reservoir cause of rising of water temperature. Modifying of post-chlorine dosing rate. 1) Refer to P-4-1 2) Contamination of clear water from inspection opening. Periodical inspection opening of clear water reservoir. 3) Periodical cleaning of clear water reservoir 4) Increase of consumption of free residual chlorine of water in the clear water reservoir cause of rising of water temperature. Modifying of post-chlorine dosing rate. 1) Refer to P-4-1 2) Contamination of clear water from inspection opening. Periodical inspection opening of clear water reservoir	The adequate action based on collected data Refer to P-4-1 Refer to P-4-1 Periodical inspection and cleaning The adequate action based on collected data Refer to P-4-1 Daily inspection Periodical inspection The adequate action based on collected data Refer to P-4-1 Daily inspection
P-4-4	Contamination of filtered water by foreign substances in the sump for transmission pump	1) Contamination of filtered water in the clear water reservoir 2) Keeping opened the cover for inspection opening of clear water reservoir	1) Refer to P-4-1 2) Contamination of clear water from inspection opening. Periodical inspection opening of clear water reservoir	Refer to P-4-1 Daily inspection

P-7/7

10. O&M Cost

Estimated reduction volume of filter washing water in ZAGAZIG water treatment plant

Filter washing regime	Before modification		After modification	
	Value	Unit	Value	Unit
Air scouring	3 min		5 min	
Air and backwash	5 min		5 min	
Backwashing	8 min		5 min	
Discharge volume of backwashing pump	475 l/sec		500 l/sec	
Filtering area	69 m ²		0.46 m ³ /m ² /min	
Water consumption per one filter per once washing	370.5 m ³		318.0 m ³	
Difference between before and after modification	53 m ³ /filter/washing			
Filter run time per one filter	24 hr		36 hr	
Frequency of filter washing in a week	7 times		5 times	
Total quantity of water consumption in a week	2,593.5 m ³ /filter		1,484.0 m ³ /filter	
Difference between before and after modification	1109.5 m ³ /week/filter			
Water reduction quantity in a day	158.5 m ³ /day/filter			
total reduction of water consumption in a day	951.0 m ³ /day/6 filters			
total reduction of water consumption in a month	28,530.0 m ³ /month/6 filters			

Estimation of reduction water volume for filter washing

1 Estimation of reduction water volume by modification of filter washing regime

WTP	Capacity of WTP (l/sec)	Capacity of WTP (m ³ /day)	Estimation of capacity operating rate (%)	Estimation of actual production water volume (m ³ /d)
1 Zagajigu	400	34,560	85	29,376
2 Abbasa	1,000	86,400	95	82,080
3 Kafr saqr	1,200	103,680	85	88,128
4 New faqus	1,200	103,680	85	88,128
5 Hussainia	400	34,560	85	29,376
Total	4,200	362,880		317,088

1-1 Estimation of reduction water volume per filter in a day
50 m³/day/filter

1-2 Estimation of reduction water volume at 5 WTP in a day

WTP	Number of the filter	Estimation of reduction water volume (m ³ /day/WTP)
1 Zagajigu	6	300
2 Abbasa	12	600
3 Kafr saqr	14	700
4 New faqus	14	700
5 Hussainia	6	300
Total	52	2600

1-3 Estimation of total reduction water volume at 5 WTP

In a day 2600 m³/day
In a month 78000 m³/month
In a year 936000 m³/year

2 Estimation of reduction water volume by decrease in washing frequency

2-1 Estimation of decrease in washing frequency

WTP	Washing frequency (a time/day)		Ratio of filter washin water volume per production water volume	
	The current condition	Estimation after improvement	The current condition (%)	Estimation after improvement (%)
1 Zagajigu	1	0.5	6	3.0
2 Abbasa	1	1	6	6
3 Kafr saqr	3	1	18	6
4 New faqus	3	1	18	6
5 Hussainia	1	0.67	6	4.0
Total	9	4	54	25.02

2-2 Estimation of reduction water volume by decrease in washing frequency

WTP	Estimation of actual production water volume (m ³ /d)	Water volume for filter washing of WTP (m ³ /day)		Estimation of reduction water volume (m ³ /d)
		The current condition	Estimation after improvement	
1 Zagajigu	27,648	1,659	829	829
2 Abbasa	82,080	4,925	4,925	0
3 Kafr saqr	88,128	15,863	5,288	10,575
4 New faqus	88,128	15,863	5,288	10,575
5 Hussainia	29,376	1,763	1,181	582
Total	315,360	40,072	17,511	22,562

3 Estimation of total reduction volume of water for filter washing at 5 WTP in SHAPWASCO

3-1 Estimation of total reduction volume of water for filter washing at 5 WTP in a day

WTP	Estimation of reduction water volume (m ³ /day/WTP)	Estimation of reduction water volume (m ³ /day/WTP)	Total	Reduction ratio per production water volume (%)
1 Zagajigu	300	829	1,129	3.8
2 Abbasa	600	0	600	0.7
3 Kafr saqr	700	10,575	11,275	12.8
4 New faqus	700	10,575	11,275	12.8
5 Hussainia	300	582	882	3.0
Total	2,600	22,562	25,162	7.9

3-2 Estimation of total reduction cost of water for filter washing at 5 WTP in a day

Estimation of production cost of water per m³ 0.72 LE

WTP	Estimation of cost reduction by save water (LE/day)
1 Zagajigu	813
2 Abbasa	432
3 Kafr saqr	818
4 New faqus	818
5 Hussainia	635
Total	18,116

Annual Maintenance Plan for Water Treatment Plants in SHAPWASCO (Issued in February 2009 as First Draft) Issued by HQ Team in SHAPWASCO in 14/February/2009

Name of facility	Activity	January	February	March	April	May	June	July	August	September	October	November	December
6	Alarm testing												
7	Chlorination												
	6-1	Check the amount of equip. activity											
	6-2	Calibration of alarm device quantity											
	6-3	Repairing of equip.											
	6-4	Check of leakage from chlorine tank											
	6-5	Check of operation condition of valves											
	6-6	Check of condition of gas pressure reducing											
	6-7	Check the sodium level of chemical tank											
	6-8	Check the sodium soda solution concentration											
	6-9	Inspection of copper lead pipe											
8	Drainage												
	7-1	Inspection of ammonia devices											
	7-2	Inspection of center equip.											
	7-3	Inspection of electrical equip.											
	7-4	Check of leakage from piping and valves											
	7-5	Check of leakage from chlorine tank											
	7-6	Check of operation condition of valves											
	7-7	Check of condition of gas pressure reducing											
	7-8	Check the sodium level of chemical tank											
	7-9	Check the sodium soda solution concentration											
9	Diesel generator												
	8-1	Inspection of electrical equip.											
	8-2	Check of battery and working											
	8-3	Check of alignment of centrifuge											
	8-4	Check of alignment of centrifuge											
	8-5	Removal of accumulated mud in drainage basin											
	8-6	Check of leakage from piping and valve											
	8-7	Inspection of piping & valve											
	8-8	Check of leakage from piping and valve											
	8-9	Check of leakage from piping and valve											
10	Power receiving												
	9-1	Inspection of electrical equip.											
	9-2	Check of battery and working											
	9-3	Check of alignment of centrifuge											
	9-4	Check of alignment of centrifuge											
	9-5	Removal of accumulated mud in drainage basin											
	9-6	Check of leakage from piping and valve											
	9-7	Inspection of piping & valve											
	9-8	Check of leakage from piping and valve											
	9-9	Check of leakage from piping and valve											
11	Laboratory												
	10-1	Inspection of electrical equip.											
	10-2	Check of battery and working											
	10-3	Check of alignment of centrifuge											
	10-4	Check of alignment of centrifuge											
	10-5	Removal of accumulated mud in drainage basin											
	10-6	Check of leakage from piping and valve											
	10-7	Inspection of piping & valve											
	10-8	Check of leakage from piping and valve											
	10-9	Check of leakage from piping and valve											

2. Materials for O&M Plan in Abbasa WTP

SHAPWASCO

Abu Hamad Markaz

First: Potable Water

The budget is by millions

A-Projects required to be completed			B-Projects required to be constructed			C-Projects required to be developed		
No.	Name of Project	Required budget	No.	Name of Project	Required budget	No.	Name of Project	Required budget
A1	Completion of development for Old station in Abbasa WTP for all the electrical, mechanical, civil, chlorine, alum and power factor improvement works	15	B1	Third extension of capacity 500 L/sec. for Abbasa WTP	100	C1	Rehabilitation for - Abu Hamad/Bibels water pipe line of length 6 km and diameter 400mm - Al Shibani pipe line of length 5 km and diameter 300 mm - The feeding pipe line for Kafr Al Azazi and Al Esodia of length 10 km and diameter 300mm	9
			B2	Constructing Transmission pipe line from Abbasa to Al Koreen City of length 7 km and of diameter 12"	2	C2	Networks in Abu Hamad Markaz of length 17 km and diameters 150 and 200 mm	1
			B3	Constructing a feeding pipe line for Al Sawa area of length 2.5 km and of diameter 12"	1	C3	Improvement and development for the low and medium voltage panels	5
			B4	Constructing water pipe lines in Abu Hamad City of different lengths and for a length of 1 km inside monitoring rooms	0.5			
No. of projects (1)		15	No. of projects (4)		103.5	No. of projects (3)		15

SHAPWASCO
Abu Hamad Branch

Completion of development for Old station in Abbasa WTP for all the electrical, mechanical, civil, chlorine, alum and power factor improvement works

NO.	ITEM	No. of pieces	Unit price		Total Price		Remarks
			L.E.	P.T.	L.E.	P.T.	
1	Replacement of medium and low voltage panels in the old station						
2	Replacement and changing of electrical panel board in for the old filters						
3	Replacement and changing of electric chargers D.C./110V						
4	Completion of lightning inside the plant						
5	Replacement of raw water pumps by new ones of discharge 350 l/sec						
6	Installation of Power factor devices						
7	Change of vacuum pumps basins and installing rest of motors						
8	Making a crane extension for the near by station						
9	Development of old raw water intake						
10	Installing flow meters for the facilities						
11	Replacement and installation for valves of different size 150-250-350-400mm						
12	Installation of 3 backwashing units 350 l/sec for filter backwashing						
13	Inside and Outside Repairing for 3 clarifiers						
14	Painting of electric panels and pumps						
15	Replacement of Bridges and mixers	3					
16	Installation of sludge collector for the old plant 350 l/sec	3					
17	Installation of flow meters for the filter facility and pressure gauges	16					

NO.	ITEM	No.of pieces	Unit price		Total Price		Remarks
			L.E.	P.T.	L.E.	P.T.	
18	Repainting for the old pump house						
19	Repairing for old filter facility i.e. concrete footings, repainting of the facility and flooring						
20	Construction of chlorine cylinders store of capacity(100 cylinder) safety devices have to be provided						
21	Changing old chlorinators and construction of new facility						
22	Preparing a room for getting rid of damaged cylinders						
23	Changing Alumfacility						
24	Construction for alum storage tank of 100 ton capacity						
25	Repairing of alum solution tank and installing measurement devices						
26	Completion of the lightening in the pump house and the filter facility						
27	Supplying a truck with hydraulic stairs for maintenance works						
28	Installation of air ventilators in old pump house and the second extension pump house						
29	Completion of paving works inside the station						

Total allocated budget (1500000) fifteen million egyptian pounds

**SHAPWASCO
Abu Hamad Branch**

Third extension of capacity 500 L/sec. for Abbasa WTP

NO.	ITEM	No.of pieces	Unit price		Total Price		Remarks
			L.E.	P.T.	L.E.	P.T.	
1	Construction of raw water intake on Ismailiya canal						
2	Construction of raw water basin						
3	Construction of Pump house for raw water and treated water pumps (3 raw water pumps of 500 l/sec flow rate)						
4	Construction of receiving well						
5	Construction of 3 clarifiers of 350 l/sec. capacity						
6	Construction of 6 filters of 100 l/sec. capacity						
7	Construction of ground clear water reservoir						
8	Construction of discharge and suction pipe lines with the required diameters						
9	Construction of sludge collectors and the pumps of 350 l/sec discharge						
10	Construction of alum and chlorine facilities						
11	Connecting the third extension with the old and new stations						
12	Construction of filter backwashing facility						

Total allocated budget (10000000)hundred million egyptian pounds

**SHAPWASCO
Abu Hamad Branch**

Improvement and development for the low and meduim voltage panels

NO.	ITEM	No.of pieces	Unit price		Total Price		Remarks
			L.E.	P.T.	L.E.	P.T.	
1	Installation of protection systems for the low and medium voltage electric panels						
2	Installation of control circuits for the low and medium voltage panels						
3	Changing the breakers for the low, medium voltage panels and the pumps						
4	Required maintenance works for low and medium voltage panels						
5	Repairing the diesel generator						

Total allocated budget (5000000)five million egyptian pounds

**SHAPWASCO
Abu Hamad Branch**

Constructing a feeding pipe line for Al Sawa area of length 2.5 km and of diameter 12"

NO.	ITEM	Unit	Quantity	Unit price		Total Price		Remarks
				L.E.	P.T.	L.E.	P.T.	
1	PVC pipes of 300 mm diameter	meter	2500	300		750000		
2	High pressure valve 12 inch diameter	piece	3	2000		6000		
3	Cast iron pieces like T and elbows	ton	3	7000		21000		
4	Reinforced concrete man hole 2*2m with cast iron cover	piece	3	10000		30000		
5	High pressure cast iron valve 4 inch diameter	piece	1	500		500		
6	Reinforced concrete man hole 1.5*1.5m with cast iron cover	piece	1	7000		7000		
7	Information Center fees	meter	2500	2		5000		
8	Excavation	meter	2100	10		21000		
Total						841125		

Total allocated budget (841125)eight hundred forty one thousand and one hundred twenty five egyptian pounds

SHAPWASCO
Abu Hamad Branch

Constructing water pipe lines in Abu Hamad City of different lengths and for a length of 1 km inside monitoring rooms

NO.	ITEM	Unit	Quantity	Unit price		Total Price		Remarks
				L.E.	P.T.	L.E.	P.T.	
1	PVC pipes of 8" diameter	meter	2200	200		440000		
2	PVC pipes of 6" diameter	meter	13700	100		1370000		
3	PVC pipes of 4" diameter	meter	7650	50		382500		
4	Valves of 8" diameter	piece	3	1000		3000		
5	Valves of 6" diameter	piece	22	800		17600		
6	Valves of 4" diameter	piece	15	500		7500		
7	Reinforced concrete man hole 150*150*150	piece	22	7000		154000		
8	Reinforced concrete man hole 120*120*120	piece	4	5000		20000		
9	Cast iron pieces	ton	14	7000		98000		
10	Aqueduct of thickness 6"	meter	24	350		8400		
11	Information Center fees	meter	19550	4		78200		
12	Repavement	meter	3050	50		152500		
13	Excavation	meter	19000	10		190000		
Total						2131135		

SHAPWASCO
Abu Hamad Branch

Networks in Abu Hamad Markaz of length 17 km and diameters 150 and 200 mm

NO.	ITEM	Unit	Quantity	Unit price		Total Price		Remarks
				L.E.	P.T.	L.E.	P.T.	
1	PVC pipes of 8" diameter	meter	7500	200		1500000		
2	PVC pipes of 6" diameter	meter	36000	100		3600000		
3	Valves of 8" diameter	piece	6	1000		6000		
4	Valves of 6" diameter	piece	42	800		33600		
5	Valves of 4" diameter	piece	28	500		14000		
6	Reinforced concrete man hole 200*200	piece	1	10000		10000		
7	Reinforced concrete man hole 150*150	piece	69	7000		483000		
8	Cast iron pieces	ton	20.25	7000		141750		
9	Aqueduct pipes of diameter 8"	meter	120	500		60000		
10	Aqueduct pipes of diameter 6"	meter	55	350		19250		
11	Information Center fees	meter	43500	2	25	97875		
12	Repavement	meter	5040	50		252000		
13	Excavation	meter	17300	10		173000		
Total						6335475		

SHAPWASCO
Abu Hamad Branch

Abu Hamad/Bilbeis water pipe line of length 3.55 km and diameter 400mm

NO.	ITEM	Unit	Quantity	Unit price		Total Price		Remarks
				L.E.	P.T.	L.E.	P.T.	
1	PVC pipes of 16" diameter	meter	3550	700		2485000		
2	PVC pipes of 4" diameter	meter	5000	500		2500000		
3	Valves of 16" diameter	piece	2	3000		6000		
4	Valves of 8" diameter	piece	3	1000		3000		
5	Valves of 6" diameter	piece	12	800		9600		
6	Valves of 4" diameter	piece	6	500		3000		
7	Reinforced concrete man hole 200*200	piece	2	10000		20000		
8	Reinforced concrete man hole 150*150	piece	14	7000		98000		
9	Cast iron pieces	ton	6	7000		42000		
10	Information Center fees	meter	5000	2	50	12500		
11	Repavement	meter	5000	50		250000		
Total						3179100		

SHAPWASCO
Abu Hamad Branch

The feeding pipe line for Kafr Al Azazi and Al Esadia of length 10 km and diameter 300mm

NO.	ITEM	Unit	Quantity	Unit price		Total Price		Remarks
				L.E.	P.T.	L.E.	P.T.	
1	PVC pipes of 12" diameter	meter	10000	300		3000000		
3	Valves of 12" diameter	piece	6	2000		12000		
	Valves of 8" diameter	piece	4	800		3200		
4	Valves of 6" diameter	piece	12	500		6000		
5	Valves of 4" diameter	piece	10000	2	25	22500		
7	Reinforced concrete man hole 150*150	piece	6	7000		42000		
8	Cast iron pieces	ton	10	7000		70000		
9	Aqueduct pipes of diameter 2"	meter	25	2000		50000		
11	Information Center fees	meter	6	1000		6000		
13	Excavation	meter	7500	10		75000		
Total						3223700		

Abbasia WTP Maintenance Plan (Electrical)

Facility	Daily	Weekly	Monthly	3months	6months	annually	Remarks
Transformers and Medium and low voltage electric panels	Medium voltage panels 11 KV						<p>Daily maintenance:</p> <ul style="list-style-type: none"> Check and observe pump motors if there is abnormal condition (temperature, vibration, Ampera, Volt) Check electric transformers Cleanliness of electrical cells <p>Weekly maintenance</p> <ul style="list-style-type: none"> Check voltages and ammeters Check cleanliness and shifton Use blowers to clean electric cells <p>Monthly maintenance</p> <ul style="list-style-type: none"> General cleanliness for electric cells and for the bus bars General maintenance for batteries and chargers 110V Use the avometer to check fuses and replace if damaged Check the safety of the operation switches and clean contact points <p>The 3 months maintenance</p> <ul style="list-style-type: none"> Open the lora and back openings in the panels if available Confirm that there is no electric charges on the bus bars and evacuate any electric charges Clean the bus bars using the air blower Clean the contact points using the proper cleaner
	General cleanliness for electric cells and inspect bus insulators						
	Check breakers						
	Check and inspect transformer oil						
	Clean and check the oil level for the starter						
	-1 Transformer no.1 - 11/5.3						
	-2 Transformer no.2 - 11/5.3						
	-3 Transformer no.3 - 380/3.3						
	-4 Transformer no.4 - 380/3.3						
	Check and inspect starter oil						
1- Raw water pumps (9)							
2- Treated water pumps (10)							
Inspect and check electrical chargers 110 V (2)							
Check electrical cells and breakers in low voltage panels							
Chemicals and chlorine	Alum dosing pumps						<p>Chemicals</p> <ul style="list-style-type: none"> Maintenance for the following : <ul style="list-style-type: none"> Motors and agitators for the solution tank Alum dosing pumps <p>Chlorine</p> <ul style="list-style-type: none"> Pre chlorine dosing pumps Post chlorine dosing pumps Chlorine heaters maintenance General maintenance for gas suction devices(ventilators) <p>Clarifiers</p> <ul style="list-style-type: none"> General maintenance for the following : <ul style="list-style-type: none"> Agitator, bridges and flocculators motors <p>Filters</p> <ul style="list-style-type: none"> Voltage Distribution panels 380 V Backwashing pumps motors Compressors motors Drainage pumps and hydrofour motors
	General maintenance for electric cells and inspect bus insulators						
	Check batteries and chargers						
	General cleanliness for electric cells and inspect bus insulators						
	Check electric switches						
	General maintenance for the following: <ul style="list-style-type: none"> raw water pumps motors treated water pumps motors vacuum pumps motors drainage pumps motors Check pump bearing oil or grease for raw water pumps Check pump bearing oil or grease for treated water pumps Make the necessary maintenance for the crane 						
	Sludge drainage operation panels						
	General cleanliness for electric cells and inspect bus insulators						
	General maintenance for sludge drainage motors						
	Check pump bearing oil or grease for sludge drainage motors						
Check electric switches and breakers							
Facility lightning units							
Lightening units in the station							

Abbasia WTP Maintenance Plan (Mechanical)

Facility	Daily	Weekly	Monthly	3months	6months	annually	Remarks
Raw water intake and raw water basin	Cleaning the screens (2)						<p>Daily maintenance:</p> <ul style="list-style-type: none"> Check the cleanliness of pump house around pumps areas and electric panels <p>Monitor and Clean the intake area and the gate</p> <p>Check the bearing temperature</p> <p>Check any abnormal condition like vibration</p> <p>Weekly maintenance</p> <ul style="list-style-type: none"> Check pump bearing oil or grease and add the necessary amounts Check unit fixation and adjust all fixing bolts equipment Check stuffing box gland backing and repair <p>Monthly maintenance</p> <ul style="list-style-type: none"> Add the necessary amount of oil or grease Check the bearing temperature Check and adjust pump bearing oil Close discharge valve totally during operation, check the performance curve and if any change occurs, check copper rings wearings <p>The 3 months maintenance</p> <ul style="list-style-type: none"> Clean and check the bearings
	Smoothen the intake valves operation (4)						
	Smoothen the intake valves operation for raw water basin (4)						
	Washing raw water basin access line						
	Sweeping precipitation from the basin						
	Repairing suction raw water pumps screen (9)						
	Repairing intake gates (4)						
	ALUM						
	Clean the pipes and basins						
	General Maintenance for valves and agitators						
Chemicals	General Maintenance for dosing devices						<p>Chlorine</p> <ul style="list-style-type: none"> Inspect pre and post chlorine connection General Maintenance for post chlorinators General Maintenance for pre chlorinators (7) Removing floating algae from clarifier(7) Cleaning the channels inside the clarifier(7) General Maintenance for sludge drainage valves (7) Smoothen the inlet and outlet valves for clarifiers Sweeping remaining water from bottom of clarificator Taking out precipitations from clarifiers Cleaning filter walls and weirs Cleaning the reservoirs below filters Inspect bottom of filter General maintenance for filter operation valves and their sustains General maintenance for drain pumps Checking sand level inside filters Checking the inlet and outlet valves for ground reservoirs General maintenance for backwashing pumps and attachments General maintenance for compressors and attachments General maintenance for the hydrofour unit and its attachments
	General Maintenance for dosing devices						
	Inspect pre and post chlorine connection						
	General Maintenance for post chlorinators						
	General Maintenance for pre chlorinators (7)						
	Removing floating algae from clarifier(7)						
	Cleaning the channels inside the clarifier(7)						
	General Maintenance for sludge drainage valves (7)						
	Smoothen the inlet and outlet valves for clarifiers						
	Sweeping remaining water from bottom of clarificator						
Taking out precipitations from clarifiers							
Cleaning filter walls and weirs							
Cleaning the reservoirs below filters							
Inspect bottom of filter							
General maintenance for filter operation valves and their sustains							
General maintenance for drain pumps							
Checking sand level inside filters							
Checking the inlet and outlet valves for ground reservoirs							
General maintenance for backwashing pumps and attachments							
General maintenance for compressors and attachments							
General maintenance for the hydrofour unit and its attachments							
Filters and ground reservoirs	General maintenance for the hydrofour unit and its attachments						<p>The 6 months maintenance</p> <ul style="list-style-type: none"> Check pump bearings or grease and add the necessary amounts Check pump and motor alignment and do necessary adjustment Check the unit performance during operation <p>Annual maintenance</p> <ul style="list-style-type: none"> Do annual overhaul for pumps and replace deflected parts General maintenance for the clarifiers and deflected parts General maintenance for the clarifiers and filters including civil works <p>Remark :</p> <ul style="list-style-type: none"> Major work performed for the raw and treated water pumps are done alternatively according daily operation condition
	General maintenance for the hydrofour unit and its attachments						
	General maintenance for the hydrofour unit and its attachments						
	General maintenance for the hydrofour unit and its attachments						
	General maintenance for the hydrofour unit and its attachments						
	General maintenance for the hydrofour unit and its attachments						
	General maintenance for the hydrofour unit and its attachments						
	General maintenance for the hydrofour unit and its attachments						
	General maintenance for the hydrofour unit and its attachments						
	General maintenance for the hydrofour unit and its attachments						

Facility	Daily	Weekly	Monthly	3months	6months	annually	Remarks
Pump House	Voltage distribution panels 3.3 V						<p>The 6 months maintenance</p> <ul style="list-style-type: none"> Open the lora and back openings in the panels if available Confirm that there is no electric charges on the bus bars Clean the bus bars using the air blower Earthing test for the earthing inside the bus bars Check electric switches and breakers <p>Annual maintenance</p> <ul style="list-style-type: none"> Open the lora and back openings in the panels if available Confirm that there is no electric charges on the bus bars Refilling and tight the bus bars with the coils Clean the bus bars using the air blower Test transformers oil and changing if possible Connect cable terminals in the transformers
	General cleanliness for electric cells and inspect bus insulators						
	Check breakers						
	Check batteries and chargers						
	Voltage distribution panels 380 V						
	General cleanliness for electric cells and inspect bus insulators						
	Check electric switches						
	General maintenance for the following: <ul style="list-style-type: none"> raw water pumps motors treated water pumps motors vacuum pumps motors drainage pumps motors Check pump bearing oil or grease for raw water pumps Check pump bearing oil or grease for treated water pumps Make the necessary maintenance for the crane 						
	Sludge drainage operation panels						
	General cleanliness for electric cells and inspect bus insulators						
General maintenance for sludge drainage motors							
Check pump bearing oil or grease for sludge drainage motors							
Check electric switches and breakers							
Facility lightning units							
Lightening units in the station							

Facility	Daily	Weekly	Monthly	3months	6months	annually	Remarks
Raw and treated water pump house	Raw water pumps						<p>The 6 months maintenance</p> <ul style="list-style-type: none"> Check pump bearings or grease and add the necessary amounts Check pump and motor alignment and do necessary adjustment Check the unit performance during operation <p>Annual maintenance</p> <ul style="list-style-type: none"> Do annual overhaul for pumps and replace deflected parts General maintenance for the clarifiers and deflected parts General maintenance for the clarifiers and filters including civil works <p>Remark :</p> <ul style="list-style-type: none"> Major work performed for the raw and treated water pumps are done alternatively according daily operation condition
	Pump no.1						
	Pump no.2						
	Pump no.3						
	Pump no.4						
	Pump no.5						
	Pump no.6						
	Pump no.7						
	Pump no.8						
	Pump no.9						
Pump no.10							
Vacuum treated water pumps							
Drainage pumps							
Crane							
Check and inspect pumps in facility no.1 (3)							
Check and inspect pumps in facility no.2 (3)							
Check and inspect the pumps at the bottom of facility							
Check inlet and outlet valves							

Facility	Daily	Weekly	Monthly	3months	6months	annually	Remarks
Sludge drainage facility	Raw water pumps						<p>The 6 months maintenance</p> <ul style="list-style-type: none"> Check pump bearings or grease and add the necessary amounts Check pump and motor alignment and do necessary adjustment Check the unit performance during operation <p>Annual maintenance</p> <ul style="list-style-type: none"> Do annual overhaul for pumps and replace deflected parts General maintenance for the clarifiers and deflected parts General maintenance for the clarifiers and filters including civil works <p>Remark :</p> <ul style="list-style-type: none"> Major work performed for the raw and treated water pumps are done alternatively according daily operation condition
	Pump no.1						
	Pump no.2						
	Pump no.3						
	Pump no.4						
	Pump no.5						
	Pump no.6						
	Pump no.7						
	Pump no.8						
	Pump no.9						
Pump no.10							
Vacuum treated water pumps							
Drainage pumps							
Crane							
Check and inspect pumps in facility no.1 (3)							
Check and inspect pumps in facility no.2 (3)							
Check and inspect the pumps at the bottom of facility							
Check inlet and outlet valves							

List of facility inventory

name of equipment	name of facility	Nos	year of constructed	additional construction	Maintenance record			Name of manufacturer	specifications (Detail description should be provided in annex sheet)
					repair	replace	cleaning of basin or tank		
1	Intake raw water basin	1-1	Intake raw water basin	2	1957-2004			Local-German	
		1-2	screen	8	1957-2004			Local	
		1-3	Crane	1	2004			Tcheek	
			number of intake lines for old	2					
			number of intake lines for new	3					1000mm diameter
		2-1	Raw water reservoir	2	1957-2004			Local-German	
		2-2	Screen	6	2004-2004			Local-German	
		2-3	Crane	1	2004			Local	
		3-1	Raw water storage basin	1	1957-1994-2004			Local	
		3-2	Raw water pump -type1	4	1959			German	
			pressure gauge	4	1959			German	
		3-3	Raw water pump -type2	5	1994			Tcheek	
			pressure gauge	5	1994			Tcheek	
		3-4	pipings & valves	12	1957-1994		replaced	German/Tcheek	
4	Receiving well	4-1	Receiving well	2	1994		Local		
		4-2	Flush mixer	4	1994		Local		

		gravel 3	1	1959-1994	German <th rowspan="2">in intervals</th> <th rowspan="2">in intervals</th> <th rowspan="2">gravel, depth 2-4mm3</th> <th rowspan="2">gravel, depth 5cm</th>	in intervals	in intervals	gravel, depth 2-4mm3	gravel, depth 5cm
9	clear water reservoir	8-3	operation desk	12, 16	1959-1994	German			
		8-4	type of underdrain	3	1994	German			
		8-5	backwash pump motor	3	1994	German			
			pressure gauge	0					
		8-6	air blower for air wash motor	242	1959-1994	German			
			blower	242	1959-1994	German			
			air storage	1	1994	German			
		*8-7	pipings & valves	168	1959-1994	local			
		9-1	clear water reservoir	6	1959-1994	local			
		9-2	pipings & valves	4	1959-1994	local			
		9-3	auxiliary	0					
		10-1	alum storage yard	1		local			
		10-2	alum solution	2	1994	local			
		10-3	liquid alum receiver tank	3	1959	local			
10-4	agitator of alum dosing	2	1959	local					
10-5	alum dosing pump -type1	0							
10-6	alum dosing pump -type2	0							
10-7	level gauge	4	1959	German					

5	Floculation basin	4-3	drive unit	4	1994	Local				
			shaft & common base	4	1994	Local				
			Raw water floometer			Local				
		5-1	Floculation basin	7	1959-1994	Local				
		5-2	floculator drive unit	22	1959-1994	Local				
			common base	28	1959-1994	Local				
			shaft & paddle	28	1959-1994	Local				
		6	Sedimentation basin	6-1	Sedimentation basin	7	1959-1994	Local		
					drains			Local		
				6-2	sludge collector	7	1959-1994	Local		
					drive unit	7	1959-1994	German		
		7	Sludge drainage		blade collector	7	1959-1994	German		
					blade unit	14	1959-1994	German		
				7-1	drainage pump	6	1959-1994	German		
	motor			6	1959-1994	German				
	pump			0	1959-1994	German				
	pressure gauge			0						
7-2	pipings & valves			15	1959-1974	German				
*8-1	sludge filter			28	1994	German				
8	Rapid sand filter			*8-2	composition of filter layer	4		Local		the depth for the filter medium is 45cm (sand and 45 cm gravel)
					gravel 1	1		Local		32-64mm3 gravel, depth 20cm
					gravel 2	1		Local		8-16mm3
					in intervals					

1	chlorination facility	10-8	pressure gauge	0		German			
		10-9	backpressure valve	2	1959	German			
		10-10	relief valve	0					
		10-11	strainer	0					
		10-12	pipings & valves	6	1959	German			
		11-1	lead tube for storage base	1	1994	local			
		11-2	chlorine gas auxiliary	1	1994	local			
		11-3	valves	1	1994	local			
		11-4	changeover devise	1	1994	local			
		11-5	pressure gauge for chlorine gas	2	1994	local			
		11-6	chlorine gas filter	1	1994	Tcheek			
		11-7	Pre-chlorinator	2	1994	Tcheek			
		11-8	intermediate chlorinator	0					
		11-9	injector unit for pre chlorinator	2	1959-1994	Tcheek			
11-10	injector unit for post chlorinator	1	1994	Tcheek					
11-11	injector unit for post chlorinator	2	1959-1994	Tcheek					
11-12	pipings & valves	1	1959-1994	local					
11-13	water booster	1	1959-1994	local					
11-14	chlorination								

1	Stand-by generator	14-1	Generator	1	1994	repaired		Tcheek	To prevent or leakage and prevent mix the oil with water
4		14-2	oil tank	1	1994	repaired		Tcheek	
5	Electrical switch board	14-3	battery	1	1994	repaired		Tcheek	
		15-1	for Raw water pump	2	1959-1994			German-Tcheek	
		15-2	for Flush mixer	4	1994			Tcheek	
		15-3	Floculator	22	1959-1994			German-Tcheek	
		15-4	for sludge collector	5	1959-1994			German-Tcheek	
		15-5	for Backwash Pump	3	1994			Tcheek	
		15-6	for Air wash Pump	5	1959-1994			German-Tcheek	
		15-7	for Alum agitator	2	1959			German	
		15-8	for Alum dosing Pump	4	1994			Tcheek	
		15-9	for chlorinator	0					
		15-10	for booster Pump for chlorinator	0					
		15-11	for caustic Pump	2	1994			Tcheek	
		15-12	fan	12	1994			Tcheek	
		15-13	for distribution Pump	0					
		15-14	for treated water pump	0					
		15-15	for drainage Pump	0					
		15-16	for sludge drainage Pump	0					

		15-17	for sludge thickener	0					
		15-18	for Stand by generator	0					
		15-19	for Crane	6	1959-1994			Tcheek	
		15-20							
		15-21							
		15-22							
		15-23							
		15-24							
		15-25							
6	Transformer	16-1	transformer 1	2	1959			German	
		16-2	transformer 2	2	1994			Tcheek	
		16-3	transformer 3	2	1994			Tcheek	
7	Chemical laboratory	17-1	Chemical laboratory	1	1959				
		17-2							
		17-3							
8	Maintenance equipment	18-1	Moving trucks	2	1994			local	ABB1
		18-2	Workshop equipment	1	1957			England-local	Big lathers & equipments
9	Safety equipment	19-1	Emergency kit for chlorine gas						
		19-2							
		19-3							
		19-4							
		19-5							

11-15	chlorine gas neutralization system	11-15	chlorine gas neutralization system	1	1994	motor pump	4	1994	Tcheek
1)	caustic soda solution tank	1)	caustic soda solution tank	2	1994	pressure gauge	4	1994	Tcheek
				2	1994	pipings & attached parts	8	1994	Tcheek
				4	1994	exhaust fan			German
2)	exhaust fan	2)	exhaust fan	12	1994	motor fan	12	1994	Tcheek
				0		attached parts	0		Tcheek
				0		pipings & valves	0		
3)	caustic soda solution tank	3)	caustic soda solution tank	1	1994	caustic soda solution tank	1	1959-1994	Tcheek
4)	drainage tower	4)	drainage tower	1	1959-1994	drainage basin	1	1959-1994	
1)	drainage basin	1)	drainage basin	1		drainage motor	1		
2)	drainage pump	2)	drainage pump	2		drainage pump	2		
3)	pipings & valves	3)	pipings & valves	4		pipings & valves	4		

12-2	sludge drainage basin	12-2	sludge drainage basin	1		sludge drainage basin	1		
1)	sludge drainage basin	1)	sludge drainage basin	1		sludge drainage basin	1		
2)	sludge thickener	2)	sludge thickener	1		sludge thickener	1		
				1		drive unit	1		
				1		common base	1		
				1		bridge	1		
				1		collector	1		
3)	drainage pump	3)	drainage pump	1		drainage pump	1		
				1		motor	1		
				4		pipings & valves	4		
13-1	pump -type1	13-1	pump -type1	4	1959	motor	4	1959	German
				4		pressure gauge	4		German
13-2	pump -type2	13-2	pump -type2	2	1994	motor	2	1994	Tcheek
				2		pressure gauge	2		Tcheek
				4		out going transmission line	4		800mm cast iron main to Abu elkhair station steel coated main to Zagazig-600mm asbestos main to Bilbais city

**Operation & Maintenance Plan
Contents (for reference - August 2008)
for Abbasa WTP**

Preface

1 – Description of the Facility

- Overview
- Regulations
- O&M Targets of the Facility
- Equipment List

2 – Start-up and Normal Operating Procedures, Records and Reporting, and Quality Control

3 – Emergency Plan

4 – Planned Maintenance Program

- Long term (Five-year) Plan
- Annual Maintenance Plan
- Equipment Data Base
 - ◊ Basic Equipment List (available: see attached table-1)
 - ◊ Individual Equipment List with a numbering system
 - ◊ Equipment Record Cards

5 – Staffing and Training

- Organization Chart and Staff Allocation
 - ◊ Task Classification
 - ◊ Job Descriptions
- Training
 - ◊ SOP training
 - ◊ PC training

Note: SOP documents including Water Quality Control Program prepared in the Project will be referred to Chapters 2, 3 and 4.

Explanation of the Table of Contents

Preface (Concept of O&M Plan from SOP overview)

O&M plan is developed to provide a material that can be easily referred to as guidance in the operating of the water system.

The O&M plan will also provide ready reference for following;

- All equipment data which is necessary for performing normal maintenance
- Ordering replacement parts and supplies
- Organized system for keeping records of O&M of the system
- Water sampling, analysis and testing which required for compliance with regulations
- Monitoring of the treatment process for compliance with accepted waterworks procedures.
- Information regarding start-up and normal operating procedures and emergency operating procedures

O&M plan will become a training manual to provide personnel with handy source reference while they learn to operate the facilities.

The experienced operator will usually refer to the O&M plan for confirmation of normal operation and maintenance procedures and as a reference guide for unusual operating conditions. The entry level operator should frequently refer to the O&M plan for guidance and instruction.

Equipment List and Equipment Record Cards

Individual components of equipment are numbered according to the facility they are associated with and their position in the process flow. The number becomes the equipment's identifier whenever maintenance is involved.

Each component of equipment is registered on a record card containing every feature about the unit. Where possible, this information is to be taken from the manufacturer's nameplate attached to the component. Manufacturer's name, address, phone number, contact person, purchase order number, and/or contract number should be included. Additionally, equipment related to the unit, such as the drive motor and gear reducer, is added to the card.

Task Classification

Task Classification (Task classifications identify responsibilities and are broken down into the following general categories).

1. Supervisory/ Management: Supervisors and managers provide the leadership and guidance for the overall operation of a facility. In general, managers plan the operation and supervisors put the plan into effect.
2. Clerical: Clerks manage the data and record keeping of a facility.
3. Laboratory: The laboratory staff performs analyses of water quality for various parameters from which decisions regarding plant operation are based.
4. Operations: The operations staff provide the technical skills required to operate the equipment and processes of a facility.
5. Maintenance: The maintenance personnel provide the skills required to keep the plant equipment in good operating order, and maintain a data base on equipment costs and repairs.
6. Buildings/Grounds: The buildings and grounds personnel keep the buildings and grounds in good repair

Table-1 List of Facility Inventory

name of equipment	name of facility	Nos of	year of constructed	Maintenance record					specifications (local description in annex sheet)	
				Additional construction	repair	repaint	replace	cleaning of basin or tank		Name of manufacturer
1	Intake raw water basin	raw water basin	1957-2004						local-German	
		screen	1957-2004						local	
		Crane	2004						Czech	
2	Raw water reservoir	Raw water reservoir	1957-2004						local-German	1000mm diameter
		Screen	2000-2004						local-German	600mm diameter
		Crane	2004						local	
3	Raw water pump	Raw water storage basin	1957-1994-2004						local	
		Raw water pump motor	1959						German	
		pressure gauge	1959						German	

9	clear water reservoir	*8-3	operation desk	12, 16	1959-1994	German	
		8-4	Type of under drain			German	
		8-5	backwash pump motor	3	1994	German	
			pressure gauge	0		German	
		8-6	air blower for air wash	2+2	1959-1994	German	
			blower motor	2+2	1959-1994	German	
			air storage tank	1	1994	German	
		*8-7	pipings & valves	168	1959-1994	local	
		9-1	clear water reservoir	6	1959-1994	local	
		9-2	pipings & valves	4	1959-1994	local	
10	Alum dosing facility	9-3	other auxiliary	0		local	
		10-1	alum storage yard	1		local	
		10-2	alum solution tank	2	1994	local	
		10-3	liquid alum receiver tank	3	1959	local	
10-4	agitator of solution tank	2	1959	local			

3-3	Raw water pump	-Type2	motor	5	1994	Czech	
			pump	5	1994	Czech	
			pressure gauge				
		3-4	Pipings & valves	12	1957-1994	German + Czech	replaced
		4-1	Receiving well	2	1994	local	
		4-2	Flush mixer	4	1994	local	
			drive unit	4	1994	local	
			common base	4	1994	local	
			shaft & paddle	4	1994	local	
		4-3	Raw water flow meter				
5	Flocculation basin	5-1	Flocculation basin	7	1959-1994	local	
		5-2	flocculator	7	1959-1994	local	
			drive unit	22	1959-1994	local	
			common base	28	1959-1994	local	
			shaft & paddle	28	1959-1994	local	
6	Sedimentation basin	6-1	Sedimentation basin	7	1959-1994	local	
		6-2	sludge collector	7	1959-1994	local	
			drive unit	7	1959-1994	German	

11	chlorination facility	10-5	alum dosing pump type1	0			
		10-6	alum dosing pump type2	0			
		10-7	level gauge for solution tank	4	1959	German	
		10-8	pressure gauge	0			
		10-9	backpressure valve	2	1959	German	
		10-10	relief valve	0			
		10-11	strainer	0			
		10-12	pipings & valves	6	1959	German	
		11-1	cylinder storage base	1	1994	local	
		11-2	lead tube for chlorine gas				
11-3	auxiliary valves	1	1994	local			
11-4	cylinder changeover device	1	1994	local			
11-5	pressure gauge for chlorine gas	2	1994	local			
11-6	chlorine gas filter	1	1994	Czech			

7	Sludge drainage	7-1	common base bridge collector blade unit drainage pump motor	7 7 14 6	1959-1994 1959-1994 1959-1994 1959-1994	German German German German	
			pump	6	1959-1994	German	
			pressure gauge	0			
		7-2	Pipings & valves	15	1959-1974	German	
		*8-1	rapid sand filter basin	28	1994		
		*8-2	*Marked items should be described on each filter.	4			in interval
			gravel 1	1			in interval
			gravel 2	1			in interval
			gravel 3	1			in interval
			sand 1	1			in interval

2. Shaft coupling	Rust	Visual observation	Rust appearance In case that rust is generated, repainting should be required	6 months	
	Loosening of bolting parts	Touching and by tools	Check bolting parts In case that loosening is generated, bolting parts should be tightened.	6 month	
	Rust of bolts and nuts	Visual observation	Check rust appearance In case that rust is generated, bolting parts should be repainting or replacing	6 months	
3. Mixing shaft and paddle	Damage	Visual observation	In case that damage is found, damaged part should be replaced. Investigation of cause of above	6 months	
	Loosening of bolting parts	Touching and by tools	Check bolting parts In case that loosening is generated, bolting parts should be tightened.	6 month	
	Wear	Touching By measurement by tools (slide gauge)	In case that abrasion is more than 1mm, shaft sleeve should be installed or shaft will be replaced.	1 year	

4/21

2/21

- Contents
- I. Mechanical Equipment
- (1) Flush Mixer & Slow mixer (Flocculator)
 - (2) Sludge collector
 - (3) Rapid sand filter
 - (4) Aluminum dosing facility
 - (5) Chlorinator & chlorine drum
 - (6) Pump facility

(2) Sludge collector

Name of Part	Inspection item	Method	Judgment Criteria	Frequency	Judgment
1. Power reducer	Load current	Current measurement By current meter or clamp meter	Less than rated current value In case that measured current is rated current or more, investigation should be required.	1 month	
	Abnormal sound	Auscultation	Check abnormal sound In case that abnormal sound is generated, overhaul is required.	Ever day	
	Vibration	Touching or visual observation or by vibration meter	Abnormal vibration Investigation of cause of above. In case that abnormal vibration is generated, bolting parts should be tightened.	Every day	
	Temperature	By touching or thermometer	Temperature of outside surface is less than ambient temperature +40) In case of 40 or more, an overload may be the causes. Investigation should be required	Every day Check by thermometer every 1 month	
	Lubricant quantity blackish color leakage	Visual observation and operation record	Check oil gauge sight glass Check bolting parts In case that insufficient level of oil, oil should be supplied. In case that oil color is blackish color and used hours of oil have been more than manufacturer recommendation time, oil should be changed.	1 month	

5/21

3/21

(1) Flush Mixer & Slow mixer (Flocculator)

Name of Part	Inspection item	Method	Judgment Criteria	Frequency	Judgment
1. Power reducer	Load current	Current measurement By current meter or clamp meter	Less than rated current value In case that measured current is rated current or more, investigation should be required.	1 month	
	Abnormal sound	Auscultation	Check abnormal sound In case that abnormal sound is generated, overhaul is required.	Ever day	
	Vibration	Touching or visual observation or by vibration meter	Abnormal vibration Investigation of cause of above. In case that abnormal vibration is generated, bolting parts should be tightened.	Every day	
	Temperature	By touching or thermometer	Temperature of outside surface is less than ambient temperature +40) In case of 40 or more, an overload may be the causes. Investigation should be required	Every day 1 month	
	Lubricant quantity blackish color leakage	Visual observation and operation record	Check oil gauge sight glass Check bolting parts In case that insufficient level of oil, oil should be supplied. In case that oil color is blackish color and used hours of oil have been more than manufacturer recommendation time, oil should be changed.	1 month	

Blower for air scouring	Discharge pressure	Visual observation of pressure gauge	Check the pressure gauge reading. In case that reading pressure is not sufficient, check the leakage of air from piping or relief valve and cleanliness of suction air filter. If, leakage and dirtiness of air filter are not found, check the parts inside of blower casing such as the impeller.	6 months
	Overheating of bearings and gears	Touching or measuring by thermometer	In case that overheating is happened, check bellows; Check lubricant, Check alignment Check belt tension, check wear of impeller and clearance between impellers. Detail checks should be carried out according to manufacturer's instruction manual.	Every day
	Vibration	Touching or measuring by vibration meter	In case that abnormal vibration is found, check bellows; Check alignment, check a wear of bearings/gear, Check looseness of coupling with shaft	Every day
	Oil leaking & cleanliness of oil	Visual observation	In case that oil leakage is found, check bellows; Check excessive oil level, oil seal leakage In case that oil dirtiness is found, oil should be replaced	1 months
	Belt tension	Touching	In case that inadequate belt tension is found, it should be adjusted.	6 months
	Suction air filter	Visual observation	In case that dirtiness is found, it should be cleaned. In case that air filter is worn, it should be replaced	3 months

8/21

2.Shaft coupling	Rust	Visual observation	Rust appearance In case that rust is generated, repainting should be required	6 months
	Loosening of bolting parts	Touching and by tools	Check bolting parts In case that loosening is generated, bolting parts should be tightened.	6 month
	Rust of bolts and nuts	Visual observation	Check rust appearance In case that rust is generated, bolting parts should be repainting or replacing	6 months
3.Mixing shaft and paddle	Damage	Visual observation	In case that damage is found, damaged part should be replaced. Investigation of cause of above	6 months
	Loosening of bolting parts	Touching and by tools	Check bolting parts In case that loosening is generated, bolting parts should be tightened.	6 month
	Abrasion	Touching By measurement by tools (slide gauge)	In case that abrasion is more than 1mm, shaft sleeve should be installed or shaft will be replaced.	1 year
4.Bridge	Rust	Visual observation	Rust appearance In case that rust is generated, repainting should be required	6 months

6/21

Backwash pump	Load current	Current measurement By current meter or clamp meter	Less than rated current value In case that measured current is rated current or more, investigation should be required.	1 month	
	Pressure indication	Visual observation	Check abnormal sound In case that abnormal sound is generated, overhaul is required.	Every day	
	Abnormal sound	Auscultation	Check abnormal sound In case that abnormal sound is generated, overhaul is required.	Ever day	
	Vibration	Touching or visual observation or by vibration meter	Abnormal vibration Investigation of cause of above. In case that abnormal vibration is generated, bolting parts should be tightened.	Every day 1 year	
	Temperature	By touching or thermometer	Temperature of outside surface and bearings is less than ambient temperature +40 degree In case of 40 or more, an overload may be the causes. Investigation should be required	Every day 1 month	
	Lubricant quantity blackish color leakage	Visual observation and operation record	Check oil gauge sight glass Check bolting parts In case that insufficient level of oil, oil should be supplied. In case that oil color is blackish color and used hours of oil have been more than manufacturer recommendation time, oil should be changed.	1 month	
	Rust	Visual observation	Rust appearance In case that rust is generated, repainting should be required	6 months	

9/21

(3) Rapid sand filter					
1.Motor valve Pneumatic valve Flow control valve	Inspection item	Method	Judgment Criteria	Frequency	Judgment
	Operation condition	Visual observation or Check a switching time by stopwatch	Check smooth operating of valve shaft Check a switching time In case of that operating of valve shaft is not smooth grease rise should be required.	6 months	
	Limit switch	Visual observation	Check the position of limit switch In case that location of the limit switch has shifted, location adjustment of limit switch should be required.	6 months	
	Valve Sealing	Visual observation or judgment by hearing of sound of water flow	In case that water leakage is found, overhaul of valve should be required.	6 months	
	Rust	Visual observation	Rust appearance In case that rust is generated, repainting should be required	6 months	
	Lubricant quantity blackish color leakage	Visual observation and operation record	Check oil gauge; sight glass Check bolting parts In case that insufficient level of oil, oil should be supplied. In case that oil color is blackish color and used hours of oil have been more than manufacturer recommendation time, oil should be changed.	1 month	
	Overhaul	Total inspection		5 years	

7/21

	Depth of sand layer	Measurement by measuring rod	In case that lack of depth of sand layer is found, the sand of an insufficient should be supplied. In case that uneven depth of sand layer between left and right bank, depth of sand layer should be adjusted to be even depth. Investigation of cause of above	1 month	
	Fineness of surface of sand layer	Visual observation	In case that unevenness of surface of sand layer is found, unevenness condition should be corrected to even. Investigation of cause of above	1 month	

12/21

	Alignment of the pump and motor	Measurement by dial gauge		6 months	
	Wear of rotating elements	Visual observation and measurement by slide gauge	According to instruction manual by manufacturer	1 year	
	Wear ring clearances	Measurement by slide gauge	According to instruction manual by manufacturer	1 year	
	Loosening of bolting parts	Touching and by tools	Check bolting parts In case that loosening is generated, bolting parts should be tightened.	6 month	
	Leakage from gland packing	Visual observation		Every day	
	Leakage of water	Visual observation		Every day	
2.Piping	Loosening of bolting parts	Touching and by tools	Check bolting parts In case that loosening is generated, bolting parts should be tightened.	6 month	
	Rust of bolts and nuts	Visual observation	Check rust appearance In case that rust is generated, bolting parts should be repainting or replacing	6 months	

10/21

(4) Aluminum Sulfate storage tank & Aluminum Sulfate dosing pump					
Name of Part	Inspection item	Method	Judgment Criteria	Frequency	Judgment
1. Alum storage tank 1-1. Outside condition	Leakage	Visual observation	Check outside of tank and pipe connection part. In case of that leakage is observed, repairing or re-tightening of bolts and nuts or pipe connection part should be required.	6 months	
	Damage & rust	Visual observation	Check damage, breakage, and rust. In case that damage or breakage is found, it should be repaired. In case that rust is found, it should be recovered by re-painting.	1 months	
	Damage & rust	Visual observation	Check damage, breakage, and rust. In case that damage or breakage is found, it should be repaired. In case that rust is found, it should be recovered by re-painting.	3 months	
1-2. Inside condition	Precipitate on the bottom	Visual observation	Check the condition of tank bottom or adhering on the wall inside. In case that precipitate is found, it should be removed and cleaned up.	1 month	
	Damage & rust	Visual observation	Check damage, breakage, and rust. In case that damage or breakage is found, it should be repaired. In case that rust is found, it should be recovered by re-painting.	6 months	
1-3. Level meter	Accurate indication & calibration	Confirm difference between actual indication and level meter indication	Check the difference between both readings at arbitrary point. In case that difference is 1 cm or more, calibration should be required.	6 months	

13/21

	Uniform air bubbling and uniform backwashing	Visual observation of filter washing condition	Check uniform air bubbling during air scouring and uniform backwashing during backwashing In case of that uneven bubbling or backwashing is observed, check of under drain should be required.	6 months	
4.Under drain	Damage	Visual observation	Check damage, breakage, uneven arrangement of parts, and clogging of holes at the time of inspection activity of under drain.	5 years	
5.Filter basin	Clean condition inside wall & water surface	Visual observation	Check cleanliness inside wall and water surface In case that garbage is observed in filter basin, it should be removed. In case that the adhered object such as algae is observed on wall inside, it should be removed and wall inside should be cleaned.	3 months	
6.Drainage trough	Damage & uniform drain out	Visual observation	Check the damage, breakage and uniform drain out from drain trough. In case that damage or breakage is found, repair should be required. In case that uneven drain out from drain trough is found, level adjustment of drain trough should be required.	Every day	
3.Filter media	The damage of filter media	Visual observation	In case that damage, mud balls or dirtiness is found, damaged part should be replaced and recovered the sand by compulsory washing. Investigation of cause of above	3 months	

11/21

Name of Part	Inspection item	Method	Judgment Criteria	Frequency	Judgment
Chlorine drum	Leakage of water	Visual observation		Every day	
	Leakage of chlorine	Visual observation & check by smell	Check by ammonia solution & smell In case that there is any leakage, leakage part should be found and repair or be tightened bolting part.	Every day	
	Supplied chlorine gas pressure or reading of indicator of weighing scale	Visual observation	Check indication of gas feeding pressure gauge or weighing scale. In case that indication value is not sufficient, the indicated value is observed periodically and change work of drum should be carried out when it is required.	Every day	
	Stock numbers of filled chlorine drum	Visual observation	The location in a storage room for empty drum and filling drum should be separated. The empty drum and the filling drum are identified by displaying.	Every day	

16/21

3.10-53

Name of Part	Inspection item	Method	Judgment Criteria	Frequency	Judgment
Alum dosing device	Accurate discharge quantity of dosing pump	Measuring of discharge quantity	Check the delivered quantity from dosing pump by measuring of the drop degree of a liquid level in solution tank.	6 months	
	Accurate delivered quantity from dosing pipe	Measuring of delivered quantity	Check the actual delivered quantity from dosing pipe used by measuring cylinder and stopwatch.	6 months	
	Abnormal noise	Hearing		Every day	
	Discharge pressure	Pressure gauge	Check the discharge pressure at set pressure of back pressure valve.	Every day	
Alum dosing pump	Leakage of alum	Visual observation		Every day	
	Lubricant quantity blackish color leakage	Visual observation and operation record	Check oil gauge sight glass Check bolting parts In case that insufficient level of oil, oil should be supplied. In case that oil color is blackish color and used hours of oil have been more than manufacturer recommendation time, oil should be changed.	1 month	
	Loose of bolting parts	Touching and by tools		6 months	
	Periodical check of mechanical parts	Overhaul		3 years	

14/21

Name of Part	Inspection item	Method	Judgment Criteria	Frequency	Judgment
(6) Pump facility	1. Motor valve	Visual observation or check a switching time by stopwatch	Check smooth operating of valve shaft Check a switching time In case of that operating of valve shaft is not smooth grease rise should be required.	6 months	
	Flow control valve	Visual observation	Check the position of limit switch In case that location of the limit switch has shifted, location adjustment of limit switch should be required.	6 months	
	Limit switch	Visual observation or judgment by hearing of sound of water flow	In case that water leakage is found, overhaul of valve should be required.	6 months	
	Valve Sealing	Visual observation and operation record	Check oil gauge sight glass Check bolting parts In case that insufficient level of oil, oil should be supplied. In case that oil color is blackish color and used hours of oil have been more than manufacturer recommendation time, oil should be changed.	1 month	
Chlorinator	Lubricant quantity blackish color leakage	Visual observation and operation record	Check oil gauge sight glass Check bolting parts In case that insufficient level of oil, oil should be supplied. In case that oil color is blackish color and used hours of oil have been more than manufacturer recommendation time, oil should be changed.	6 months	
	Overhaul	Total inspection		5 years	

(5) Chlorinator & chlorine drum

Name of Part	Inspection item	Method	Judgment Criteria	Frequency	Judgment
Chlorinator	Leakage of chlorine	Visual observation & check by smell	Check by ammonia solution & smell In case that there is any leakage, leakage part should be found and repair or be tightened bolting part.	Every day	
	Stable indication of flow meter indicator	Visual observation	Check stable indication of a float in indicator glass tube	Every day	
	Adequate dosing quantity	Visual observation of indicator reading	Check the raw water quantity and chlorine dosing rate. Calculate dosing quantity by above values. Confirm a actual dosing quantity and adjust the dosing quantity to required dosing quantity if necessary	Every day	
	No liquid chlorine in glass tube of indicator	Visual observation	Check indicator glass tube. In case that there is any liquid chlorine in glass tube, close the outlet valve of chlorine drum and continue working until liquid chlorine in glass tube is consumed. After that change the chlorinator in working to the stand-by. The chlorinator which was being operated till then should be carried out overhaul.	Every day	
Chlorinator	Adequate working of injector	Sound hearing	Check sound of vacuum occurrence from injector. In case that there is not sound, vacuum will be not sufficient. Injector should be checked by dismantling.	Every day	

17/21

15/21

	Vibration	Touching or visual observation or by vibration meter	Abnormal vibration Investigation of cause of above. In case that abnormal vibration is generated, bolting parts should be tightened.	Every day 1 year	
	Temperature	By touching or thermometer	Temperature of outside surface and bearings is less than ambient temperature +40 degree In case of 40 or more, an overload may be the cause. Investigation should be required	Every day 1 month	
	Lubricant quantity blackish color leakage	Visual observation and operation record	Check oil gauge sight glass Check bolting parts In case that insufficient level of oil, oil should be supplied. In case that oil color is blackish color and used hours of oil have been more than manufacturer recommendation time, oil should be changed.	1 month	
	Rust	Visual observation	Rust appearance In case that rust is generated, repainting should be required	6 months	
	Alignment of the pump and motor	Measurement by dial gauge		6 months	
	Water level of sump	Visual observation			
2.Piping	Loosening of bolting parts	Touching and by tools	Check bolting parts In case that loosening is generated, bolting parts should be tightened.	6 month	

20/21

Pump	Load current	Current measurement By current meter or clamp meter	Less than rated current value In case that measured current is rated current or more, investigation should be required.	1 month	
	Pressure indication	Visual observation		Every day	
	Abnormal sound	Auscultation	Check abnormal sound In case that abnormal sound is generated, overhaul is required.	Every day	
	Vibration	Touching or visual observation or by vibration meter	Abnormal vibration Investigation of cause of above. In case that abnormal vibration is generated, bolting parts should be tightened.	Every day 1 year	
	Temperature	By touching or thermometer	Temperature of outside surface and bearings is less than ambient temperature +40 degree In case of 40 or more, an overload may be the cause. Investigation should be required	Every day 1 month	
	Lubricant quantity blackish color leakage	Visual observation and operation record	Check oil gauge sight glass Check bolting parts In case that insufficient level of oil, oil should be supplied. In case that oil color is blackish color and used hours of oil have been more than manufacturer recommendation time, oil should be changed.	1 month	
	Rust	Visual observation	Rust appearance In case that rust is generated, repainting should be required	6 months	

18/21

	Rust of bolts and nuts	Visual observation	Check rust appearance In case that rust is generated, bolting parts should be repainting or replacing	6 months	
--	------------------------	--------------------	--	----------	--

21/21

	Alignment of the pump and motor	Measurement by dial gauge		6 months	
	Wear of rotating elements	Visual observation and measurement by slide gauge	According to instruction manual by manufacturer	1 year	
	Wear ring clearances	Measurement by slide gauge	According to instruction manual by manufacturer	1 year	
	Loosening of bolting parts	Touching and by tools	Check bolting parts In case that loosening is generated, bolting parts should be tightened.	6 month	
	Leakage from gland packing	Visual observation		Every day	
	Leakage of water	Visual observation		Every day	
Vacuum pump	Load current	Current measurement By current meter or clamp meter	Less than rated current value In case that measured current is rated current or more, investigation should be required.	1 month	
	Pressure indication	Visual observation		Every day	
	Abnormal sound	Auscultation	Check abnormal sound In case that abnormal sound is generated, overhaul is required.	Every day	

19/21

3.11 Water Quality Control Program for Water Supply Facilities (Action S9)

Reviewed by _____ Date: _____

Certification

I, _____ (NAME), hereby, declare that the contents written in this document are based on the fact that I witnessed during the auditing, conducted on the (DD/MM/YYYY), and any of my personal suspicion is prevented from this document.

Auditing Report for _____ Laboratory

3.11-1

Name of the Auditor: _____

Date: _____

Signature _____

DD/MM/YYYY

SHAPWASCO

(Laboratory of _____)



1. Abstract of the Laboratory

Name of the Lab	:	
Location	:	
Telephone	:	
Email (if any)	:	
Head of the Lab	:	
Number of Workers	:	

2. Abstract of the Auditing

Date	:	DD/MM/YYYY
Time	:	: ~ :
Interviewed with	:	
	:	
	:	



3. Checklists

Storage Location	:	
Storage Condition	:	Good / Acceptable / Terrible
Daily Checklist	:	All Completed / Partially Completed / Not Completed
Weekly Checklist	:	All Completed / Partially Completed / Not Completed
Monthly Checklist	:	All Completed / Partially Completed / Not Completed
Annual Checklist	:	Completed / Not to be done
Items NOT satisfy the requirement significantly, if any.	:	
Improvement Plan if any (optional)	:	



4. Result of the Auditing

The abstract of the auditing result is shown below. The detail of each auditing items should be referred the attached checklist.

General	/ 95
Ventilation	/ 5
Instruments	/ 20
Chemical	/ 50
Waste	/ 30
Total	/ 200 (%)

(3)

Auditing Report

Items NOT satisfy the requirement significantly, if any.	:	
Improvement Plan if any (optional)	:	
Other Notice (optional)	:	

(4)

Auditing Report



5. Result of the Interview

Please circle either one below. If the answer is (b), please fill the comment.

(1) General

- (a) The laboratory is generally satisfied with the general condition.
- (b) The laboratory is NOT satisfied with the general condition.

Why NOT satisfied?

(2) Ventilator

- (a) The laboratory is generally satisfied with the ventilator.
- (b) The laboratory is NOT satisfied with the ventilator.

Why NOT satisfied?

(3) Chemicals

- (a) The laboratory is generally satisfied with the chemicals.
- (b) The laboratory is NOT satisfied with the chemicals.

Why NOT satisfied?



(4) Waste

- (a) The laboratory is generally satisfied with the waste.
- (b) The laboratory is NOT satisfied with the waste.

Why NOT satisfied?

6. Request from the laboratory

Please write any requests raised from the laboratory.

راجعه :
التاريخ :

شهادة

أقر أنا _____ بأن المكونات المذكورة
بهذا المستند هي حقيقية وهذا طبقاً لما شاهدته أثناء عمل هذا الفحص وذلك في يوم _____
وهذا أقرار مني بذلك

تقرير مراقبة
لمعمل _____

إسم المراقب : _____

التاريخ : _____

التوقيع : _____

SHAPWASCO

(معمل _____)

(1) ملخص للمعمل

اسم المعمل	:
الموقع	:
تليفون	:
البريد الإلكتروني (إن وجد)	:
رئيس المعمل	:
عدد العمال	:

بيانات المراقبة

التاريخ	:
الوقت	:
تقابل مع	:
	:
	:

(1)

Auditing Report

(2) بيانات المراقبة

مكان التخزين	:
حالة التخزين	جيد
قائمة الفحص اليومية	تامة بعض البنود لم تنفذ
قائمة الفحص الأسبوعية	تامة بعض البنود لم تنفذ
قائمة الفحص الشهرية	تامة بعض البنود لم تنفذ
قائمة الفحص السنوية	تامة / لم تتم
البنود المخالفة للمتطلبات (إن وجدت)	
خطة التطوير (اختيارية)	

(2)

Auditing Report

3) نتيجة المراقبة

الجدول التالي يوضح ملخص نتائج المراقبة وتفاصيل كل بند من بنود المراقبة يجب ذكره في قائمة الفحص المرفقة

عامة	105/
التهوية	5/
الأجهزة	20/
الكمبيوترات	50/
المخلفات	30/
الإجمالي	(%) 210/

(3)

Auditing Report

البند المخالفة للمتطلبات (إن وجدت)	:
خطة التطوير (إن وجدت)	:
ملاحظات أخرى (اختيارية)	:

(4)

Auditing Report

(4) نتيجة الزيارة

برجاء وضع دارة على الإجابة التي توضح الحالة . إذا كانت الإجابة هي الحالة (ب) برجاء الإيضاح

- (1) عم
(أ) المعمل مطابق للمواصفات العامة
(ب)المعمل غير مطابق للإنتز لطات العامة

برجاء إيضاح أسباب عدم المطابقة ؟

- (2) التهوية
(أ) المعمل مجهز بشفاط هواء يعمل
(ب)الشفاط لا يعمل

برجاء إيضاح أسباب عدم المطابقة ؟

- (3) الكيماويات
(أ) الكيماويات بالمعمل كافية
(ب)الكيماويات غير كافية

برجاء إيضاح أسباب عدم المطابقة ؟

(5)

Auditing Report

- (4) المخلفات
(أ) المعمل مجهز بنظام لجمع المخلفات
(ب)المعمل غير مجهز بنظام لجمع المخلفات

برجاء إيضاح أسباب عدم المطابقة ؟

(6) طلبات المعمل

برجاء كتابة الطلبات التي يطلبها العاملون

(نهاية تقرير مراقبة المعمل)

(6)

Auditing Report

Water Quality Control Programme (SHAPWASCO Version)

1. Objectives

The objectives of the Water Quality Control Programme are summarised as the following 3 items:

- ◆ To establish SHAPWASCO's basic policy for analysis and water quality control
- ◆ To clarify the quality control system and its reliability to public
- ◆ To prepare for emergency case such as water pollution

2. Methodology

The Water Quality Control Programme is merely a paper, which is composed of nothing new but of the existing policy, procedure and idea of you should have acquired through your daily working activity.

All you need to do is to bring your daily activity on the paper. This activity will give you for clarifying the role of the laboratory and responsibility.

As model cases, Water Quality Control Programmes for 2 water treatment plants (Zagazig and Abbasa) shall be prepared.

The Expert expects the Counterpart firstly prepare the draft version of the Programme. The Draft version shall be prepared either by Computer typing or hand writing.

All work shall be completed by the Counterpart. However, since the target of the Programme is the existing water treatment plants, the Counterpart is required to build up the Programme with the assistance and consultation of those employees in the both plants.

3. Schedule

The JICA Expert will prepare the format of the Programme by the 20th of June, 2007. The Counterpart is expected to discuss the contents with the

Expert and understand what he should describe in the Programme by the 21st of June. The counterpart is also expected to start to write the Programme from the 23rd of June.

Since the Expert leaves Egypt on the 28th of June but will return on the 16th of September, the Expert requests the Counterpart should prepare the draft version (yet, covering the complete section) of the Programme by September.

4. Assistance by the Expert

The Expert will assist on the following points:

- ◆ Field Survey on finding potential source of pollution
- ◆ Describing the contents of the Programme which the Counterpart is expected to describe.
- 5. Contents of the Water Quality Control Programme (Tentative)

The main contents and the brief description of the Programme is described in Attachment. However, the content is not only limited as the Expert describes. The Counterpart is expected to expand the Programme with his and his colleagues own effort.

6. Questions

The Counterpart may encounter some difficulty during his work. If any question or suspicion arises, the Counterpart is able to contact to the expert through email or phone during his absence.

The Expert's contact address is:

Email: tk-hara@yachivo-eng.co.jp (Max Attachment: 10MB)

Phone: +81-3-59060187

Notice:

The expert requests to email weekly for reviewing and advising the progress of his works. Contact any of the JICA Expert staffs to send email.



SHAPWASCO
(Sharqiya Potable Water and Sanitary Company)



SHAPWASCO
(Sharqiya Potable Water and Sanitary Company)

Preface

Water Quality Control Programme
For
Abbasa Water Treatment Plant
(Draft Version)

October 2007
SHAPWASCO
(Sharqiya Potable Water and Sanitary Company)



[Table of Content]

1. Basic Policy of SHAPWASCO
 - (1) The Basic Policy of SHAPWASCO
 - (2) The Objectives of the Programme
 - (3) Target Year
 - (4) Summary of the Programme
2. Abstraction of the Abbasa Water Treatment Plant
 - (1) Location of the Plant
 - (2) Target Number of Water Receiver
 - (3) Organization Chart
 - (a) Relationship between SHAPWASCO and the Abbasa Water Treatment Plant
 - (b) Organization Chart in the Abbasa Water Treatment Plant
 - (4) Network System
 - (5) Purification Process
3. Water Quality Monitoring System and Facility
 - (1) Objectives of Water Quality Analysis
 - (2) Responsible Entities
 - (a) Abbasa Water Treatment Plant
 - (b) Holding Company
 - (c) Ministry of Health
 - (3) The Current condition and ability of the Facility in Abbasa Water Treatment Plant
 - (4) Summary of the Current Issues in Analysis
 - (5) Future Expansion Plan
4. Summary of Water Quality Analysis System in Abbasa Water Treatment Plant
 - (1) Objectives of Water Quality Analysis in Abbasa Water Treatment Plant
 - (2) Organization Chart
 - (3) Sampling Location
 - (4) Monitoring Items and Analysis Frequency
 - (5) Obligation of reporting
 - (6) Others



5. Current Water Quality Condition
 - (1) Past year's Raw Water Quality
 - (a) Water Quality
 - (b) Accident
 - (2) Past year's Processing Water Quality
 - (a) Water Quality
 - (b) Accident
 - (3) Past year's Treated Water Quality
 - (a) Water Quality
 - (b) Accident
6. Quality Assurance and Accuracy Control
 - (1) Objectives of Quality Assurance and Accuracy Control
 - (2) Current Conditions
 - (3) Quality Assurance and Accuracy Control Plan
 - (a) Self-Auditing
 - (b) Auditing
 - (c) Training
7. Emergency Case
 - (1) Definition of Emergency Case
 - (2) Emergency Case Organization Chart
 - (a) Communication System in SHAPWASCO
 - (b) Communication System in relating organizations
 - (3) Countermeasures



1. Basic Policy of SHAPWASCO
(1) The Basic Policy of SHAPWASCO

Water supply company has a social responsibility to protect public health and to continuous provision of water to the citizens. The duty is significant and, therefore, the role of SHAPWASCO is very much important in the Governorate.
For comprising such duty, SHAPWASCO should have basic policy to achieve their goal.
In this section, please write the SHAPWASCO's basic concept for enrolling such duty.
Do ask the Chairman for the topic.

- e.g.*
- ◆ Provide safe water.
 - ◆ No colour in water
 - ◆ Improve the quality of water through continuous effort and technical development
 - ◆ Get customer's satisfaction, etc.

(2) The Objectives of the Programme

In this section, the reason for formulation of the Programme will be described.

- e.g. The aim of the Water Quality Control Programme is to define the following contents;*
- ◆ Establishing systematic water quality control system
 - ◆ To establish SHAPWASCO's basic policy for analysis and water quality control
 - ◆ To clarify the quality control system and its reliability to public
 - ◆ To prepare for emergency case such as water pollution

(3) Target Year

It is understood that, under the current situation, it is difficult to achieve the ultimate goal (to analyse all items and meet the standard). Therefore, it is you should set the target year to achieve the goal for the above mentioned policy.



e.g. Our target year to achieve our goal, mentioned in the section (1), is 2015.

(4) Summary of the Programme

It is the summary of this paper. Therefore, write this section after completion of all items.

2. Abstraction of the Abbasa Water Treatment Plant

(1) Location of the Plant

Describe the location of the water treatment plant with a map as well as the source of water. The maps should be available from the other member of the JICA Expert team. Ask them if you need.

e.g. The Abbasa Water Treatment Plant is located outside of Abu Hamad City (approximately XX km) along the XXX Canal. The location of the plant is shown in Figure-1.






(2) Target Number of Water Receiver

Describe how many people receive the water from the plant. Additionally, it is better to describes how many people receive the water from wells and compact units.

e.g. The total number of the population in Abu Hamad Markaz is 142,313 in 2007. The drinking water source in the Markaz is classified into (i) potable water, (ii) well water and (iii) compact unit.

The serving population by each water source is shown in Figure-2. The Abbasa Water Treatment Plant serves approximately 75% of the total population of Abu Hamad Markaz.




(3) Organization Chart

(a) Relationship between SHAPWASCO and the Abbasa Water Treatment Plant

Describe that Abbasa is one of the main plant of SHAPWASCO with visibly easy organization chart.


e.g. The Abbasa Water Treatment Plant is one of the main Water Treatment Plant of SHAPWASCO.



(b) Organization Chart of the Abbasa Water Treatment Plant

Describe the organization in Abbasa Water treatment plant with chart. This gives the idea of classification of responsibility.

e.g. The organization chart of the Abbasa Water Treatment Plant is shown in Figure-4.





(4) Capacity of the Plant

Describe the capacity of the plant. The operators should know the detail of it. Therefore, ask the operators in Abbasa.

e.g. The summary of the Plant is summarised Table-1.

Area	35,466m ²
Construction	1952
Rehabilitation	1987
Extension	
Capacity	45,000 m ³ /day
Pump	XXX unit
Purification	Rapid Sand Filter
etc	
Serving Area	Abu Hamad Markaz, Zagazig Markaz

(5) Network System

Describe the network system. The operators should know the detail of it. Therefore, ask the operators in Abbasa.

e.g. The summary of the water supply network system is shown in Table-2 and Figure-5



Serving Area	Abu Hamad Markaz, Zagazig Markaz
Total Extension	XXX km

(6) Purification Process

Describe the purification process in the plant with a simple flow diagram.

e.g. The Abbasa Water Treatment Plant employs Rapid Sand Filter and XXXX in its purification process. Figure-7 summarises the purification process of the plant.



3. Water Quality Monitoring System and Facility

(1) Responsible Entities

There are 3 organization involved in water quality analysis in Abbasa. Describe the role of each entity.

e.g. The water quality monitoring in the Water Treatment Plant is conducted by the three agencies, namely, Abbasa Water Treatment Plant, the Holding Company and the Ministry of Health. Their responsibility, coverage area and role in water analysis are described below.

(a) Abbasa Water Treatment Plant

e.g. The laboratory of the Abbasa Water Treatment Plant is the primary responsible agency to conduct daily, weekly, monthly and emergent analysis of water.

(b) Holding Company

e.g. The Holding Company is the super-structural agent of SHAPWASCO. The duty of Holding Company in water quality monitoring is to supervise the SHAPWASCO's



routine water quality monitoring system. Additionally, the entity is bear on the role to analyse in accordance to their specific water quality control programme for securing public health and hygiene condition.
The analytical items and frequency are listed below;

(c) Ministry of Health

e.g. The Ministry of Health is the Governmental organization responsible for protecting public health, hygiene condition and improvement of the water environment. The Ministry irregularly take samples from several locations and monitor the water in the distribution networks.

(2) The Current condition and ability of the Facility in Abbasa Water Treatment Plant

Describe all instruments you have and their condition as a table. Additionally, describe which parameters you can analyse and which parameters you can not analyse at this moment with using tables.

e.g. The Laboratory of the Abbasa Water Treatment Plant currently owns the wide variety of analytical equipments for water analysis. Table 2 shows those analytical instruments held in the laboratory with the purchase year and objective analytical items.

Item	Year	Objectives
Colour Meter	1997	Measuring Cl...
Turbidity Meter	2001	Measuring Turbidity

(3) Summary of the Current Issues in Analysis

Briefly describe the issue in association with analysis such as analytical instruments, laboratory condition, etc.

e.g. Since the Abbasa Water Treatment Plant is one of the oldest plant in Sharqiya, the laboratory and some equipments have suffered from deterioration. Additionally,



although there are a variety of analytical instruments available in the laboratory, there are some analytical items which can not be analysed under the current conditions due to lack of hardware.

(4) Future Expansion Plan

For overcoming the weakness described (4), the tender will be held. Describe which instruments you will buy and what change you can expect.

e.g. SHAPWASCO has currently promoted to renew the analytical instruments of the laboratory. It is expected the following instruments listed in Table-4 will be procured on the December. The procurement and renew of the instruments will contribute to strengthen the analytical ability of the laboratory.

Item	Target Analytical Item
pH meter	pH
Turbidity Meter	Turbidity

4. Summary of Water Quality Analysis System in Abbasa Water Treatment Plant
(1) Objectives of Water Quality Analysis in Abbasa Water Treatment Plant

Why do you have to analyse water quality? It costs and takes time. But you have reasons. Describe the reason why you are required to analyse water quality.

e.g. The objectives of water quality analysis in Abbasa Water Treatment plant can be summarized as below;

- ◆ *To protect public safety*
- ◆ *To monitor the raw water quality*
- ◆ *To monitor the purification process and advise on operation if necessary*
- ◆ *etc*

(2) Responsibility of the laboratory

Describe the responsibility of Chemists in the process control, operation, maintenance and their routine analysis.




Silica, Sulphates, Chloride, Dissolved Oxygen تحليل كامل يشمل جميع العناصر الواردة في المواصفات القياسية كيميائي (طبيعي) - إشعاعي) - بيكرولوجي- Complete Analysis in accordance to the Standards	Silica, Sulphates, Chloride, Dissolved Oxygen تحليل كامل يشمل جميع العناصر الواردة في المواصفات القياسية كيميائي (طبيعي) - إشعاعي) - بيكرولوجي- Complete Analysis in accordance to the Standards	شهرياً (وعند الضرورة) Monthly and when necessary	4
--	--	---	---



(6) Obligation of reporting

Who write the report of the analysis? Who read it? Who make a decision making for alternation of operation? Who advise on operation? Who supervise the activity of the laboratory? Who assess the result of the analysis? Answer such questions with a simple diagram.

e.g. The result of the analysis is summarised in the format set by the Holding Company. The result is reviewed by the Plant Manager and Operation Manager and is utilized for improvement of operation. The result is also reviewed by the Head Quarter and if necessary, the Head Quarter request to cross-check the analysis.



(7) Others

If necessary, write something.

5. Current Water Quality Condition

This section should be written with several graphs of the past results. Therefore, it is expected to be filled in the late summer.

- (1) Past year' s Raw Water Quality
 - (a) Water Quality
 - (b) Accident



(2) Past year' s Processing Water Quality

- (a) Water Quality
- (b) Accident

(3) Past year' s Treated Water Quality

- (a) Water Quality
- (b) Accident

(4) Potential Source of Pollution

6. Quality Assurance and Accuracy Control

(1) Objectives of Quality Assurance and Accuracy Control

Describe why you have to do quality assurance and accuracy control

e.g. There are a wide variety of water analysis items. Their detected concentration is very much low. For minimizing the errors during analysis and securing the reliance of the analytical results, the laboratory of Abbasa Water Treatment Plant has conducted the following measures.

(2) Standard Procedure

Describe the reason why you need to have the standard procedure in the laboratory.

e.g. There are 4 chemists in the laboratory. To minimize the difference in result depending on the analysts, the laboratory prepares its own standard procedure book for each analytical procedure.

(3) Quality Assurance and Accuracy Control Plan

- (a) Self-Auditing

Describe the objectives and content of the self-auditing system.

e.g. To maintain the laboratory environment and withdraw the best performance in analysis, SHAPWASCO introduced self-auditing system in 2007. Self-auditing is conducted by the laboratory itself based on the checklist prepared by the Head Quarter. The checklist is divided into (i)daily,



(ii) weekly, (iii) monthly and (iv) annual, and each checklist focuses on the following points:

<i>Daily Checklist</i>	<i>Hygiene condition of the laboratory</i>
<i>Weekly Checklist</i>	<i>Safety and work environment of the laboratory</i>
<i>Monthly Checklist</i>	<i>Safety condition of the laboratory</i>
<i>Annual Checklist</i>	<i>Maintenance and periodical calibration</i>

(b) Auditing

Describe the objectives and content of the auditing system.

e.g. Auditing is an activity to evaluate the laboratory by performing to ascertain the validity and reliability of information, and also provide an assessment of a system's internal control. SHAPWASCO introduced auditing system in 2007 and conducted one in a year. The auditor is selected from laboratories of SHAPWASCO, and assesses and evaluates the conditions of laboratory. In accordance with the report by the auditor, the laboratory correct and improve its quality control system.

(c) Detection Limit

Describe how small you can analyse, which is a part of quality assurance.

e.g. The detection limits for all instruments are principally set at 1/10 of the drinking water quality standard or less. To achieve such small quantity, all instruments in the laboratory are periodically calibrated by the laboratory itself and the suppliers. Furthermore, the laboratory pays the maximum attention on prevention of any contamination in the laboratory.

(d) Training Programmes

Describe what kind of training programme you have for education of the employees.

e.g. The



7. Emergency Case

(1) Definition of Emergency Case

Define what is the emergency case


e.g. The emergency case is defined as the following events occur:

- ◆ *A number of dead fish body found on the surface of the water*
- ◆ *A significant change in colour observed*
- ◆ *A significant change in turbidity of the raw water observed*
- ◆ *A significant change in raw water quality is observed*
- ◆ *A significant change in odour is observed*
- ◆ *Any occasion customer's claim is received*

(2) Emergency Case Organization Chart

Describe the organization chart for sharing information (including report & order).

e.g. In the case of emergency, the Abbasa Water Treatment Plant and the Head Quarter of SHAPWASCO will share all necessary information with relating institutions including Abu Hamad City Office, local police station, the Holding Company, Sharqiya Governorate Office and the Ministry of Health. The organization chart for emergency case is shown in Figure-9 and -10.



(3) Countermeasures

Although the countermeasures differ depending upon the case, describe whatever you can think at this moment.

e.g. In the case of emergency, the following countermeasures can be considered.

- ◆ *Close the intake till pollution dispelled*
- ◆ *Continuous field survey till pollution dispelled*
- ◆ *Add activate carbon in the purification process*
- ◆ *Publicity for water contamination*



*SHAPWASCO
(Sharajwa Potable Water and Sanitary Company)*

[TABLE OF CONTENT]

1. OBJECTIVES OF THE DOCUMENT	1
2. DEFINITION	1
3. APPLICATION AND STRUCTURE	2
4. OVERALL WORK STRUCTURE	2
5. PREPARATION:	3
6. FIELD OBSERVATION	3
7. SAMPLING	4
8. PREPARATION FOR ANALYSIS	7
9. PRETREATMENT	8
10. ANALYSIS	9
11. POST ANALYSIS	16
12. DATA ANALYSIS	17
13. REPORTING	18
14. QUALITY CONTROL	20
15. EMERGENCY CASE:	21
16. WASTE	25
17. OTHERS	27

Laboratory Standard Operation Procedure

October 2007

Sharquiya Potable Water and Sanitary Drainage Company
(SHAPWASCO)

Japan International Cooperation Agency (JICA)

[Record of Revision]

The first edition was prepared by JICA Expert in October 2007.

Record of Modification		
Date	By	Chapter
Dec 2007	Mr. Osama	All (Translation)

1. OBJECTIVES OF THE DOCUMENT

- 1-1 **DOCUMENT:** This document set the standard procedure for sampling and analysis of the water taken from water treatment plants and networks.
- 1-2 **MODIFICATION:** The document shall be modified and improved at any occurrence when inadequate or better procedure is found. The record of modification shall be clearly written on the surface page.

2. DEFINITION

- 2-1 **ANALYTICAL METHOD:** The analytical method shall be in compliance with the standard methodology prepared by the American Water Work Association.
- 2-2 **SAMPLING:** "Sampling" means the activity taking water from set points for analysis.
- 2-3 **ANALYSIS:** "Analysis" means the activity for quantifying chemical components in the sample.
- 2-4 **ORDER:** "Order" means a direction made by the Head Quarter of SHAPWASCO for Laboratory Manager or by Laboratory Manager for chemists in the laboratory. The water treatment plants, Laboratory Manager and/or Chemists have obligation to conduct the order.
- 2-5 **REQUEST "Request"** means a comment made by the treatment plants and laboratories upon the order. The Head Quarter is obligated to discuss with the personnel raised the request immediately and seek the solution.
- 2-6 **WRITTEN DOCUMENT "Written Document"** means authorised letter or equivalent paper material with signature of authorised personnel.

3. APPLICATION AND STRUCTURE

- 3-1 APPLICATION: The document applies to all water treatment plants and their laboratories of SHAPWASCO.
- 3-2 COVER: The document covers the area of sampling, analysis and associated activities.

4. OVERALL WORK STRUCTURE

- 4-1 WORK COMPONENT: The overall work flowchart is shown in Fig-1. Sampling and Analysis are based on laboratory's quality control system.




Figure 1 Work Components

- 4-2 STANDARD METHOD: The standard method for XXXX is the standard procedure of sampling in SHAPWASCO.

- 4-3 AWWA's METHOD: The Holding Company sets the standard analytical procedure shall follow the methodology described in the standard procedure prepared by AWWA.

5. PREPARATION:

- 5-1 RESPONSIBILITY: It is the sampler's responsibility that the laboratory shall prepare all necessary equipments for his/her field work.

- 5-2 EQUIPMENTS: The following sampling equipments should be prepared

- ◆ Sampling Polyethylene Bottle (1 L) for Chemical Analysis
- ◆ Sampling Glass Bottle (250 ml) for Bacterial Analysis.
- ◆ Sampling glass bottle (250ml) for Fe & Mn
 - Note: The Bottle must be disinfected.
- ◆ Cooler Box
- ◆ Glass Bar
- ◆ Cotton for disinfection
- ◆ Alcohol for disinfection
- ◆ Lighter/Match
- ◆ Colored label / Seal
- ◆ Pen / Pencil
- ◆ Field Report (See Format-1)

6. FIELD OBSERVATION

- 6-1 GENERAL: Field Observation is an extremely important activity to understand the conditions of raw and treated water.
- 6-2 RESPONSIBILITY: The sampler shall have all responsibility for identification of any conditions and reporting.
- 6-3 CONTENTS: The sampler shall check the following points on the field Canal water condition including Water Colour, Odour and Oil Seal in the canal.

Raw water intake condition including Garbage in the field.
 Process water Condition including Garbage Condition, Water Colour
and Odour at each process.

6-4 **REPORTING:** The observed results should be written in the Field Report (Format-1) and hand to the laboratory chemists.

6-5 **UTILIZATION:** The field observation is the initial examination of the water quality. It is an extremely important activity since the results of the field observation will be the initial and base reporting for understanding the condition of the field.

6-6 **PHOTO RECORD:** It is important to take photographs as a record whenever the sampler discovers any symptom of pollution.

7. SAMPLING

7-1 **GENERAL:** Sampling is the key procedure of the water quality analysis.

7-2 **RESPONSIBILITY:** The sampler shall have all responsibility during his/her field work. However, the laboratory shall bear responsibility for supervising his/her work.

7-3 **FREQUENCY:** Frequency for sampling are determined in accordance with the instruction by the Holding Company. However, frequency of sampling may be intensified dependent upon the field conditions or the basic policy of the laboratory.

7-4 **HOURLY SAMPLING:** Water samples for pH, Turbidity and Residual Chlorine are taken every two hours from raw water, clarified water, filtered water and treated water.

7-5 **DAILY SAMPLING:** Water samples for daily analysis are taken from raw water, clarified water, filtered water and treated water. The samples are taken through the sampling taps equipped at the

laboratory.

7-6 **TAP WATER:** The sampling procedures from the tap should follow;

- ◆ Obtain one (1) sample for chemical analysis and one (1) sample for bacterial analysis from each sampling point.
- ◆ Before collecting sample remove any aerators or other devices from the faucet or hose bib.
- ◆ Disinfect the faucet or tap at the opening with flame. If flame is not obtained, use bleach.
- ◆ Open the tap for Five (5) minutes.
- ◆ Adjust water flow to the diameter of a pencil
- ◆ **(For Chemical Analysis Only)** Rinse the sample bottle and cap with the running water three (3) times.
- ◆ **(For Chemical Analysis Only)** Fill the water in the sampling bottle up to the top and do not allow any air layer remaining.
- ◆ **(For Bacterial Analysis Only)** Do NOT rinse the sampling bottle and cap.
- ◆ **(For Bacterial Analysis Only)** Fill the water in the sampling bottle.
- ◆ During and after filling water, do NOT breathe toward the sample and never touch the inside of the cap or bottle.

7-7 **SURFACE WATER:** The sampling procedure for chemical and bacterial analysis from the river/canal water should follow;

- ◆ Obtain one (1) sample for chemical analysis and one (1) sample for bacterial analysis from each sampling point.
- ◆ Find a suitable sampling collection point. The sampling should be conducted at the centre of the stream. Do NOT take water from a hollow. Ideally, if there is a bridge, conduct sampling from the centre of the bridge with a bucket. If there is no bridge, use a dipper to take water from the centre of the stream.
- ◆ The sampling depth should be 10-20cm under the surface. Do NOT take water from the surface.
- ◆ Do NOT disturb sediments if any present. If any sediments are disturbed during the sampling, postpone sampling till the turbidity of sediments settle.
- ◆ Do NOT take allow any rubbish in your sampling.
- ◆ **(For Chemical Analysis Only)** Rinse the sample bottle and cap with the sampled water three (3) times.

- ◆ (For Chemical Analysis Only) Fill the water in the sampling bottle up to the top and do not allow any air layer remaining.
 - ◆ (For Bacterial Analysis Only) Do NOT rinse the sampling bottle and cap.
 - ◆ (For Bacterial Analysis Only) Fill the water in the sampling bottle.
 - ◆ (For Fe & Mn Analysis Only) Add three (3) drops of Hydrochloric Acid (HCl) for preservation.
 - ◆ During and after filling water, do NOT breathe toward the sample and never touch the inside of the cap or bottle.
- 7-8 PESTICIDES: The sampling procedure for pesticides/herbicides analysis should follow;
- ◆ Obtain one (1) sample for chemical analysis.
 - ◆ Glass made container must be used (Polyethylene Bottle is NOT acceptable)
 - ◆ Rinse the sample bottle and cap with the sampled water three (3) times.
 - ◆ Fill the water in the sampling bottle up to the top and do not allow any air layer remaining.
 - ◆ During and after filling water, do NOT breathe toward the sample and never touch the inside of the cap or bottle.
 - ◆ Close the cap immediately and place the bottle in the cooler box. Once the sampling is completed, close the cover of the box and avoid direct sun shining on the sampling bottles.
 - ◆ Deliver the samples to the laboratory at least within six (6) hours.
- 7-9 LABELING: Each sample must have a label to avoid miss-conduction of experiment in different samples. The label should include, but not limited;
- ◆ Date, Time and Location
 - ◆ Sample ID
- 7-10 DELIVERY: Samples shall be immediately brought into the laboratory.
- ◆ Close the cap immediately after sampling and place the bottle in the cooler box. Once the sampling is completed, close the cover of the box and avoid direct sun shining on the sampling bottles.
 - ◆ Deliver the samples to the laboratory at least within six (6) hours.
 - ◆ If the delivery is expected more than six (6) hours, refrigerate the sample

- after measuring pH, temperature, etc.
8. PREPARATION FOR ANALYSIS
- 8-1 GENERAL: Preparation for analysis means necessary works to be completed before the actual analysis.
- 8-2 RESPONSIBILITY: All responsibility associated with works for preparation of analysis belongs to laboratory chemists. Therefore, the ultimate responsibility attributes to the Laboratory Manager.
- 8-3 PREPARATION: Preparation clean laboratory analytical equipments such as beakers, etc. If you suspect not clean or find remarks of previous use, wash the equipments with distilled water three (3) times.
- 8-4 WARM UP: Such analytical instruments including HPLC, AAS, etc., requires warm up time before use. The warm up duration should be clearly written in the maker's operation manual.
- 8-5 CLEANING: Such analytical instruments including HPLC, AAS, etc., requires cleaning before use. Deionised water or Distilled water shall be run three (3) times as normal analysis for cleaning inside instruments.
- 8-6 CALIBRATION: Calibration is an activity to adjust the analytical instruments with a known concentration standard. Manufacturers normally set the calibration timing for each instruments in their operation manuals. The set calibration timing is as in the followings;

Table 1 List of Instruments Requiring Calibration

<u>Instruments</u>	<u>Calibration Timing</u>
pH meter	: Daily
Turbidity Meter	: Daily
Chloride Meter	: Daily
Fridge	: First Saturday of Month
Incubator	: First Saturday in January

8-7 **CALIBRATION CURVE:** A calibration curve is a general method for determining the concentration of a substance in an unknown sample by comparing the unknown to a set of standard samples of known concentration. Therefore, known standard concentration standards for target elements should be prepared and preserved at the laboratory. The following instrument(s) require(s) making a calibration curve at a set duration in accordance with the manufacture's instruction.

Table 2 List of Instruments Requiring Calibration Curve

<u>Instruments</u>	<u>Calibration Timing</u>
Spectrophotometry	: Every time before analysis

9. PRETREATMENT

- 9-1 **GENERAL:** The samples taken may not be suitable for analysis. Additionally, it may be necessary to reserve the physical, chemical and biological characteristics of sampled water before analysis by pre-treatment.
- 9-2 **RESPONSIBILITY:** All responsibility associated with works for pretreatment belongs to laboratory chemists. Therefore, the ultimate responsibility attributes to the Laboratory Manager.

- 9-3 **FILTERING:** Water samples taken at river or canal should be filtered using 0.45um inline filter. In prior to filtering, all filters, including filtering paper and collection bottles shall be rinsed with the water, which is going to be filtered, three (3) times.
- 9-4 **PRESERVATION:** Physical preservation techniques are used for all samples and include cooling and keeping the samples out of the sunlight. Some of the water samples are also preserved with acid to prevent degradation of constituents before they are analyzed. All samples will be preserved immediately at the collection site.

9-4-1 **Metals**

Preserve metals in water for a 6 month hold time with nitric acid. Mercury has a hold time of only 28 days. 2 ml or 4 drops of 70% nitric acid is used for each 500 ml of sample water. The sample is also chilled to four (4) Degree Celsius at laboratory..

9-4-2 **Nutrients**

The 1,000 ml nutrient suite bottle requires 2 ml or 4 drops of H₂SO₄ and has a hold time of 28 days. The sample is also chilled to four (4) Degree Celsius in the field. Do NOT use nitric acid, otherwise, the sample is contaminated with nitrogen after sampling.

10. ANALYSIS

- 10-1 **GENERAL:** An analysis is a procedure to examine the material samples for gaining an understanding of their chemical composition and their quantification.
- 10-2 **RESPONSIBILITY:** All responsibility associated with works for analysis belongs to laboratory chemists. Therefore, the ultimate responsibility attributes to the Laboratory Manager.
- 10-3 **STANDARD METHOD:** The standard procedure for analysis is the American Water Work Association's (AWWA) method. Each laboratory

should equip original/copy of the most up-dated version of the standard procedures.

The applicable standard methods and their reference numbers are listed below, respectively.

Table 3 Standard Method Reference Number for Each Analysis

Parameter	Reference Number
1 Temperature	
2 Colour, Taste & Odour	
3 Conductivity	SM 2510 B
4 pH	XM 4500 H, B
5 Turbidity	SM 2130 B
6 Total Dissolved Solids (TDS)	
7 Suspended Solids	
8 Total alkalinity	SM 2320 B
9 Carbonate alkalinity	
10 Calcite Equilibrium	
11 Total hardness	SM 2340 C
12 Permanents hardness	
13 Temporary hardness	
14 Calcium hardness	SM 3500 Ca – B
15 Calcium (Ca ⁺⁺)	
16 Magnesium hardness	SM 3500 Mg – B
17 Magnesium (Mg ⁺⁺)	
18 Chlorides	SM 4500 Cl – B
19 Sulphates	SM 4500 SO ₄ - F
20 Fluoride	
21 Silica	
22 Iron	SM 3500 Fe – B
23 Manganese	SM 3500 Mn – B
24 Phosphate	
25 Oxygen dissolved	
26 Oxygen consumed	
27 Ammonia	
28 Nitrite	SM 4500 NO ₂
29 Nitrate	SM 4500 NO ₃
30 Bicarbonate (CO ₃)	
31 Chlorine residual	
32 HPC	
33 Total Coliform	SM 9221 B
34 Algae count	SM 10200
35 Microscopic examination	
36 Jar test	
37 Chlorine dose	

NOTE: Upon alternation of the standard method, the above table should be modified.

Non indicated parameters shall be subject to be filled when the standard methodology is set.

10-4 OTHER METHOD: If the standard procedure is not applicable, the USEPA's or other well known methods may be alternatively applied. However, when any methodology other than SHAPWASCO's standard procedures is applied, such application shall be clearly written in the result.

10-5 CHANGE OF STANDARD METHOD: Upon agreement among the chemists belonging to SHAPWASCO or direction from the Holding Company, the standard method employed in SHAPWASCO may be substituted to another.

If such change arises, the Head Quarter shall order to each laboratory with a WRITTEN DOCUMENT. In such occasion, this SOP shall be revised.

10-6 JAR TEST: The test used to determine the dosage rate for each chemical is the jar test. A jar test is an attempt to duplicate the water treatment processes in glass beakers with varying doses of chemicals so the floc formation and settling can be observed in a laboratory setting.

From the tests performed, the operator can select what appears to be the most effective combination of chemicals and then can set the chemical feed dosages accordingly. The jar test cannot duplicate exactly the actual plant conditions so the results of those chemical settings must be observed at the effluent of the sedimentation basin and adjustment made accordingly.

Prior to starting a jar test, a sample of the water (IMPORTANT: must be RAW WATER ONLY. Any water containing chloride is NOT acceptable. The existence of chloride indicates on-going of chemical reaction, and, therefore, the characteristics of water at the beginning and at the end of the experiment totally differ.) to be tested should be analyzed for turbidity, temperature, pH, alkalinity, hardness, and colour. The results should be recorded on a jar test results form. The amounts of chemicals to be added to each of the six beakers should be calculated and prepared for immediate addition to the beakers at the proper time.

The specified rate of rotation and rotating time differ upon the plant. The proper time and rotation speed for the jar test can be calculated from the actual retention time and rotation speed of the flocculation basin.

10-6-1 TEST METHOD

Jar test shall be conducted in the following manner.

- (a) Collect at least eight (8) liters sample of RAW WATER, which should not contain any chloride owing to any pre-treatment, to be tested.
- (b) Immediately measure six 1,000 ml quantities and place into six 1,000 ml beakers.
- (c) Place all six (6) beakers on the stirring apparatus.
- (d) With a measuring pipet, add increasing dosages of the coagulant solution to the beakers as rapidly as possible. For example, add enough solution to be equivalent to a 10 mg/l dose in beaker #1 and add enough solution to be equivalent to a 12 mg/l in beaker #2.
- (e) Add standard solutions and feed rates for any other chemicals normally used. If a coagulant aid is used, the alum feed rate may be uniform for all six jars and the coagulant aid could be the variable.
- (f) Quickly lower the stirring paddles into the beakers and activate the paddles immediately for one (1) minute at 80 rpm. The specified rate and time are typical of the action and detention time found in many treatment plants, but calculations have to be made to meet actual conditions present in your treatment process.
- (g) Reduce the mixer speed to 20 rpm for 20 minutes to simulate the flocculation basin conditions. Again, time and rate adjustments should be made according to the treatment plant conditions.
- (h) Record the time required for visible floc to form and describe the floc characteristics (pin-head sized floc, flake sized floc) during mixing.

- (i) Stop the stirrers. Allow the floc to settle for 30 minutes or for a period similar to your plant conditions. Observe and note how quickly the floc settled, the floc appearance, and the turbidity of settled water above the floc. You can remove a sample of the clear water with a pipet for testing.
- (j) Using the sample of clear water from each beaker, measure the turbidity, pH, and alkalinity of the water.

10-6-2 IMPOTANT NOTICE


The following three (3) points should be carefully considered.

It should be emphasized that coagulation efficiency is highly relate to the water condition (particularly with pH and alkalinity). Hence, the frequency of jar test is not limited in once in a day, but the test should be conducted upon the change of raw water condition.

The rotation speed and time duration of jar test are dependent upon the plant conditions. Each plant may have a specific rotation speed in flocculator and, therefore, there is no standard rotation speed or retention time in jar test. It is necessary to calculate the rotation speed and retention time by the laboratory in prior to the experiment.

It should be also addressed that the jar test cannot duplicate exactly the actual plant conditions so the results of those chemical settings must be observed at the effluent of the sedimentation basin and adjustment made accordingly.

Example of calculation for determining specified rotation speed and time:
The numbers in the blanket () are taken from Hhiya Water Treatment Plant



The rotation speed of jar test must be identical to the rotation speed of the flocculator.

Actual Rotation Speed of the Flush Mixer : Y (cm/sec)

$$Y = d (300 \text{ cm}) \times v (1 \text{ rpm}) \times \pi (=3.14) \div 60 (\text{sec/min}) = \underline{15.7 \text{ cm/sec}}$$

NOW, to adjust the jar test rotation speed with the actual rotation speed;

Rotation Speed of the Jar test: X (rpm)

$$X = Y (15.7 \text{ cm/sec}) \div db (6 \text{ cm}) \div \pi (=3.14) \times 60 (\text{sec/min}) = \underline{50 \text{ rpm}}$$

The actual mixing duration time is calculated from the volume of inflow raw water and the size of flocculation basin.

$$\text{Inflow raw water: } Vin (= 35,000 \text{ m}^3/\text{day}) = 1,458.3 \text{ m}^3/\text{hour} = 24.3 \text{ m}^3/\text{min} = 0.41 \text{ m}^3/\text{s}$$

$$\text{Volume of flocculation basin: } V (= 62.7 \text{ m}^3 \times 4 \text{ units})$$

Mixing duration time in flocculation basin: T

$$T = V (62.7 \text{ m}^3 \times 4 \text{ units}) \div Vin (=24.3 \text{ m}^3/\text{min}) = \underline{10 \text{ min}}$$

11. POST ANALYSIS

11-1 **CHEMICALS:** All chemicals utilised during the experiment shall be returned to the original shelf after closing the cap. If necessary upon the laboratory's own rule, the amount of chemicals used in the experiment shall be recorded.

It should be emphasized that any chemicals once transferred to glassware such as beaker from the original chemical solution bin should NOT pour back to the bin. It may cause contamination of the original solution. Therefore, any chemicals transferred to glassware should be disposed properly.

11-2 **ANALYTICAL INSTRUMENTS:** It is the analyst's responsibility to check, clean up and turn off the analytical instruments used for the experiment. All analytical instruments used at different location shall be returned to the original location.

11-3 **GLASSWARE:** Glassware shall be washed after analysis immediately. The washing of glassware is as following.

- ◆ Check the remaining chemicals in glassware. For unknown chemical remaining, if pH is significantly high or low (*i.e.* below pH 5 or above pH 9), the remaining water must be identified as highly hazardous. Therefore, these remaining chemical must be separately collected.
- ◆ Non-hazardous chemicals may be disposed through sink and public sewerage system. During discharge of remaining chemicals, do NOT stop water running for the purpose of dilution.
- ◆ Wash the glassware carefully with washing powder/liquid and brush.
- ◆ Rinse with tap water carefully.
- ◆ Rinse outside of glassware with distilled water once and inside three (3) times.
- ◆ Dry the Glassware and bring back to the original shelf.

12. DATA ANALYSIS

12-1 **GENERAL:** Data analysis is an activity to review and understand the result of the analysis.

12-2 **REQUIREMENT:** The person who conducts data analysis shall be well acknowledged with spread sheet such as Microsoft Excel.

12-3 **STANDARD:** The water quality standard, the criteria and specifications for the potable and domestic use water which admitted by high committee in 26/2/1995, is set by the Protective Affairs under Secretary of the Ministry of Health in Law 108:1995.

The Standard is seen in ATTACHMENT-2.

12-4 **TURBIDITY:** By agreement among the chemists, SHAPWASCO hereby set a further strict internal standard for turbidity. The standard set in SHAPWASCO is shown below.

Table 4 Turbidity Standard

NTU	Note
0.5	Desirable limit for operation in the Internal Agreement
1.0	Maximum limit in the Internal Agreement
5.0	Maximum limit for surface water by the law
10.0	Maximum limit for groundwater by the law

12-5 **DAILY DATA ANALYSIS:** As a daily data analysis, the analyst compares the result of the analysis with the standard listed above everyday after the experiment. The analyst may check if the result of the analysis is below or satisfy the standard. If the result of the analysis exceed the standard, it may be necessary to re-check (i) sample collection method, (ii) pre-treatment procedure, (iii) analytical procedure or (iv) other factors. Re-examination of the analysis may be necessary. If no error found, it is necessary to step forward to the emergency procedure described in the later section.

12-6 MONTHLY DATA ANALYSIS: A series of data collected from daily analysis should be arranged in a graphs or other proper manner at the last day of every month. The Head Quarter requires to make graphs of at least, but not limited to, pH, Turbidity and Alkalinity graphs for raw water, clarified water and treated water. The sample of the graph is available below.

The objective of making graphs is to show the general trend of raw water, clarified water and treated water. If any abnormal condition, exceeding the set standard found, other factors including chemical biological parameters of the found date should be carefully examined.




Figure 2 Example of Graph of Turbidity

12-7 ANNUAL: A series of monthly data graphs in a calendar year should be compiled in a report, which should be submitted to the Head Quarter.

13. REPORTING

13-1 GENERAL: The result of analysis should be clearly written and kept as a record and utilized for effective operation of the water treatment plant.

13-2 RESPONSIBILITY: The responsibility for preparation of the report

belongs to the analyst who conducted chemical examination. Additionally, it is important that the result of analysis is authorised with an approval of the laboratory manager's approval. Therefore, the Laboratory Manager shall ultimately bear all responsibility for reporting and the result of the analysis.

13-3 RECORD: The result of analysis shall be written in the standard format set by the Holding Company and the Head Quarter. Additionally, the result of the analysis shall be put on record as Excel format.

13-4 SUBMISSION: The analyst shall submit the record of analysis to his/her manager for approval of the result. The Laboratory Manager is obligatory to submit the record to the Station Manager for utilization of plant operation. These procedures shall be commenced immediately after completion of analysis.




Figure 3 Report Submission Organization Chart

13-5 RECORD PRESERVATION: The record of analysis shall be preserved at least three (3) years at minimum in accordance to the direction by the Holding Company.

14. QUALITY CONTROL

14-1 **QUALITY CONTROL:** Quality Control in analysis is an activity to check and assess the accuracy of analysis.

14-2 **RESPONSIBILITY:** The Laboratory Manager shall appoint a person who bears all responsibility for quality control of the laboratory. Otherwise unless the manager appoints, the manager himself/herself shall bear the responsibility for the quality control of the laboratory.

14-3 **DEFINITION:** Quality Control is a procedure or set of procedures intended to ensure that a manufactured product (*i.e.* treated water at tap of each customer's house) or performed service (*i.e.* water quality analysis) adheres to a defined set of quality criteria, or meets the requirements of the customer.

In a narrow definition through sampling and analysis, quality control is a procedure or set of procedure to ensure the result of analysis is accurate and is sufficient enough to determine the operation of the water treatment plant (*e.g.* amount of alum dose, *etc.*)

14-4 **TASKS:** The person in charge of quality control of laboratory should periodically check the accuracy of analysis conducted in the laboratory and laboratory general environment.

14-4-1 BLANK SAMPLE

Distilled water produced in the laboratory is used as a blank sample. The pre-treatment procedures should be identical as other environmental samples (*i.e.* if acid is applied for metal's preservation, acid must be added for blank sample, too). Analyses of blank is required to demonstrate freedom from contamination

Blank sample test should be conducted at the beginning of analysis. The application of analysis is limited in spectrophotometer (as of in the year 2007).

Since the blank sample is composed of distilled water, the result of analysis should not show any significant value. If there is any contamination found, it may attribute either analytical error or contamination in analytical instrument, and blank sample test must be repeated.

14-4-2 FIELD DUPLICATION

Two or more samples should be taken from one sampling location. These samples must be treated identically and run in analysis to find error in sampling.

This activity should be conducted at least once in a month.

14-4-3 INTERNAL DUPLICATION

An analysis of one (1) sample should be repeated twice or more in the same procedure. The result of the analysis gives an internal error either in analytical way or in analytical instrument.

This activity should be conducted at least once in a month.

15. EMERGENCY CASE:

15-1 **DEFINITION:** The definitions of emergency case are summarized as below:

A. During Field Work

- ◆ Radical changes in Colour and Turbidity are observed.
- ◆ Radical changes in Odour and Taste are identified.
- ◆ Numerous number of dead fish bodies are found.
- ◆ When the above phenomenon is likely long for a while or any alleviation of the phenomenon is unlikely expected.

B. In Water Treatment Plant

- ◆ No disinfection is available due to malfunction of chlorinator or lack of the

- chlorination.
 - ◆ Radical changes in Colour and Turbidity are observed.
 - ◆ Radical changes in Odour and Taste are identified
 - ◆ When the above phenomenon is likely long for a while or any alleviation of the phenomenon is unlikely expected.
- C. During and Post Analysis
- ◆ Any suspicious, including dissolve of hazardous materials or pathogens in the water, is raised.

15-2 **RESPONSIBILITY:** Each personnel in the laboratory shall bear the following responsibility.

- Head of Laboratory
- ◆ Reporting the condition to the Station Manager, the Head Quarter and relevant organization
 - ◆ Direct the laboratory for ceasing the case.

Chemist/Technicians

- Collect information on the cause of the emergency case
- Conduct necessary analysis
- Report to the Laboratory Manager
- Follow the order made by the Laboratory Manager

Head Quarter

- Direct the Laboratory Manager and Station Manager
- Report to the organizations including the Holding Company and the Ministry of Health.

15-3 **COMMUNICATION:** Any cases of emergency case shall be immediately reported to the Head of Laboratory. The laboratory should report to the necessary contact address including the Head Quarter and the Station Manager.

Emergency contact address and communication flow chart with the name of organization and person, and telephone number, shown in Appendix A, should

be clearly posted near the telephone.

15-4 **IDENTIFICATION:** Nevertheless ways of countermeasures differs dependent upon case, the priority action taken is to identify the source, pathway and receipt of the contamination.

- ◆ **Source:** to identify the location and type of the contamination
- ◆ **Pathway:** to identify how the contamination transmit to the receipt
- ◆ **Receipt:** to identify who and where is suffered by the contamination

15-5 **COUNTERMEASURES:** The countermeasures to be employed depend on the case of emergency. Therefore, there is no set standard countermeasure to be taken.

However, the principal methodology of countermeasure is (i) to stop or remove the source of contamination, (ii) to cut off the pathway and (iii) to stop the contamination before the receipt.

The following descriptions are examples of countermeasures. Appendix B shows some ideas of countermeasures against specific contamination.

e.g. If the source of the pollution is the effluent of a factory upstream, it is necessary to stop the factory's effluent. Such source of contamination is so-called Point Contamination Source. In this case, the type of the contamination may be heavy metal or specific organic chemicals. Meanwhile, it is important to stop the intake until all pollutant in the raw water disappears. Additionally, the raw water taken in the water treatment plant should be either discharged or treated with activated carbon, etc.

e.g. Another potential contamination likely occurs is discharge or runoff from agricultural land. Such source of contamination is so-called Non-Point Contamination Source. In this occasion, the type of contamination may attribute to nitrogen including nitrate, nitrite and ammonia, or phosphate. Nitrite is the most hazardous threaten among them. However, sufficient application of chlorination as disinfection alters nitrite into nitrate, and decrease the degree of toxicity.

e.g. If the source of the contamination is in the water treatment plant process, the first countermeasure taken is to stop water supply and investigate the source of the contamination.

e.g. If the source of the contamination is in network, the first countermeasure taken is to identify the source of the contamination. Bacterial contamination is the most likely contamination occurring in network due to inflow of sewerage water from the broken pipes. Another potential contamination occurring in network is rust/coloured water due to deterioration of the pipes.

e.g. If any complaints such as mingling of impure substances or coloured water arises from the customers after replacement of pipelines and/or water supply cut off, such complaints may attribute to the effect of the replacement work and/or water cut off. The water treatment plant shall ask the customers to leave the tap opening for 10 minutes till all alien substances generated due to water cut off flows out.

e.g. Typical groundwater contaminations in Sharqiya are saline water, bacteria, Mn and Fe. Additionally, it is necessary to pay particular attention on nitrate and nitrite.

15-6 **REPORTING:** The importance of reporting in emergency case is not only limited in acknowledging the accident, but also bears to share the information and experience with other chemists. The Report shall clarify, at least but not limited, the following contents,

- ◆ General Description of the Emergency Case
- ◆ Date, Time and Location
- ◆ Source and type of Contamination
- ◆ Results of chemical/biological analysis
- ◆ Countermeasures taken for ceasing the contamination
- ◆ Photographs

The report must be submitted to the Head Quarter within TWO (2) WEEKS after occurrence of accident.

16. WASTE

16-1 **GENERAL:** SHAPWASCO's basic policy on waste is (i) to minimize generation, (ii) to reuse if possible, and (iii) to deal with properly dispose.

16-2 **RESPNSIIBILITY:** All responsibility regarding waste control and management belongs to Laboratory Manager.

16-3 **GARBAGE BOX:** Laboratory must equip separate garbage boxes for general item, glasses and hazardous materials. Clear sign of general, glass or hazardous waste must be posted on or near the boxes. This is not only for identification of the type of the box but also for clear caution for securing all employees' safety.

16-4 **GENERAL GARBAGE:** Any non-contaminated solid materials including paper, small quantity of soil or sediment, chip of woods, *etc.* are categorised as general garbage. These wastes must be disposed in the general garbage box.

Reflecting upon the social background, once recycling system is established, plastics, bin, battery, *etc.*, shall be subjected on recycling.

16-5 **GLASS GARBAGE:** Any glass materials including bin, broken laboratory glassware such as pipette and beaker, *etc.*, are categorised as glass garbage. These wastes must be disposed in the glass garbage box.

It is important to rinse bin-made chemical containers before dispose for minimizing the hazardous characteristics of chemicals. On the other hand, broken glassware such as pipette or beakers is not subjected to rinse for protecting chemist's safety.

16-6 **HAZARDOUS GARAGE:** Hazardous garbage is defined as Hazardous Waste is a "solid waste" which because of its quantity, concentration,

or physical, chemical, or infectious characteristics may:

- ◆ Pose a substantial present or potential hazard to human health or the environment when improperly treated, stored or disposed of, or otherwise mismanaged; or
- ◆ Cause or contribute to an increase in mortality, or an increase in irreversible or incapacitating illness.
- ◆ These wastes are separately stored and final disposal should be commenced by an appropriate company which, for instance, deals with medical waste. When a large quantity of hazardous material is stored, the laboratory may consult with the Head Quarter regarding the final treatment of the waste.

16-7 **LIQUID WASTE:** Any remaining chemicals in beakers or other laboratory glassware after experiment are categorised as waste chemicals. It is important **NOT** to pour back to the original bin since it causes contamination in the original bin.

Most of liquid waste may be discharged to sewerage system through sink. While discharging chemical waste, tap water should be run through its dispose for dilution of the liquid.

However, those chemicals pH is lower than five (5) or higher than nine (9), containing Mercury and Cyanide, or containing chemicals more than the environmental standard set by the Ministry of Health can not be discharged into the sink. These solutions should be collected into separate containers. Their final disposal must be consulted with the Head Quarter.

Neutralization, separation, fixation, oxidation, and precipitation are useful methodology for minimizing the influence of hazard. However, particular attention for the following notes should be paid.

- ◆ Neutralization, separation, fixation, oxidation, and precipitation are chemical reactions. Therefore, heat and gas may be generated.
- ◆ Do NOT try any reaction if you are unforeseen the chemical reaction.
- ◆ Do NOT use strong acid such as chromic acid. 8N or less concentrated HCl or H₂SO₄ are the suitable acid.

17. OTHERS

17-1 **TRAINING:** SHAPWASCO's basic policy in water quality control is "Continuous effort on improving analytical techniques". Each laboratory manager is obligatory that all chemists and technicians shall have appropriate training.

The record of training attendant and the contents should be kept. The record should be kept in the laboratory for its quality control purpose. The sample of record is available in Appendix-C.

17-2 **PERIODICAL MEETING:** The chemists belonging to SHAPWASCO have a periodical meeting. The frequency of the meeting is once in three months.

Meeting call and organization of the meeting is conducted by the Head Quarter.

The contents of the meeting may be as followings;

- ◆ General condition of raw, process and treated water in the last three months.
 - Explain the characteristics of water with graphs
 - If unusual phenomenon occurs, explain the condition
- ◆ Specific topics for process control
- ◆ Other items such as waste control

17-3 **REVISION:** The Head Quarter have responsibility to review and improve this document periodically. The frequency is, at least but not limited to, once in a year.

However, depending upon change of conditions, this document may be altered any occasion.

17-4 **OTHERS:** Any contents not listed in this document should be subjected to the Head Quarter.

1st. SHAPWASCO LABORATORIES

1- Zagazig laboratory filtration station:

No	Instrument	Number	The condition
1	Incubator	2	Very good
2	Water bath	1	Good
3	Hotplate	3	Very good
4	Electricity Balance	1	Very good
5	Electricity Sensitive balance	1	Very good
6	Color meter to measure(residual chloride, Fe, Mn, Ammonia ,Nitrates and chlorides)	1	Acceptable
7	Turbidity meter		
8	pH meter comparator	1	Good
9	TDS & Conductivity Meter	1	Acceptable
10	Hot plate & Magnetic stirrer	1	Very good
11	Drying oven	1	Good
12	Muffle furnace	1	Very good
13	UV oven	1	Very good
14	Distiller Water Apparatus	2	Good
15	Membrane filter	1	Not operated yet
16	Alum Jar tester	1	Very good
17	Colony counter	1	Very good
18	Autoclave	1	Very good
19	Glassy water distiller	1	Out of work
20	Cooling unit	2	Good
21	Spectrophotometer	1	Acceptable & need additions
22	Microscope	1	Out of work

Instruments required for completing the laboratory:

- 1) Residual chlorine meter
- 2) Spectrophotometer
- 3) pH digital meter
- 4) Microscope
- 5) Membranes for filtration membrane

Name list of laboratories in SHAPWASCO

No	Lab Name
1	Zagazig laboratory filtration station
2	Abbasa laboratory station
3	Alqanayat laboratory
4	Ibrahimia laboratory
5	Menia Elqamh laboratory
6	Abu Kabier laboratory

Name list of laboratories in NOPWASD

(NOPWASD supervised station operation in it)

No	Lab Name
1	Faqus laboratory filtration station
2	Kafr Saqr laboratory station
3	Alhusainia laboratory station

2. Abbasa laboratory station:

No	Instrument	Number	The condition
1	Color meter to measure(residual chloride, Fe, Mn, Ammonia ,Nitrates and chlorides)	1	Acceptable
2	Fridge	1	Under maintenance
3	pH meter using color meter	1	Acceptable
4	Turbidity meter	1	Acceptable
5	TDS & Conductivity Meter	1	Working
6	Centrifuge	1	Working
7	Microscope	1	Good
8	Sand sieves	1	Good
9	Magnetic stirrer	1	Good
10	Drying oven	1	weak
11	Hot Plate	1	Out of work
12	Alum Jar tester	2	Out of work
13	Incubator	2	Good
14	Electricity Sensitive Balance		Good
15	Electricity Balance	1	Good
16	Drying oven	1	Out of work
17	Muffle furnace	1	Good
18	Disinfection meter	2	acceptable
19	Water bath	1	working
20	Disinfection meter	1	working
21	Stirrer	1	working
22	Electricity Sensitive balance	1	Out of work
23	Spectrophotometer “very old”	1	Out of work

Instruments required for completing the laboratory:

- 1) TDS & Conductivity Meter
- 2) Turbidity meter
- 3) pH digital meter
- 4) Spectrophotometer
- 5) Drying oven
- 6) Fridge
- 7) Three dimensional shaker for Sand sieves
- 8) Membrane filter
- 9) Colony counter
- 10) COD digester & reader

3- Alqanavat laboratory (Fe, Mn removal Plant):

No	Instrument	Number	The condition
1	Centrifuge	1	Good
2	Hot plate	1	Acceptable
3	Drying oven	1	Good
4	Disinfection meter	1	Good
5	TDS & Conductivity Meter	1	Acceptable
6	Electricity Sensitive balance	1	Good
7	Spectrophotometer	1	Good
8	Incubator	1	Good
9	Distiller Water Apparatus	1	Out of work
10	Fridge	1	Good
11	pH meter	1	Acceptable

Instruments required for completing the laboratory:

- 1) Colony counter
- 2) Distiller Water Apparatus
- 3) Turbidity meter
- 4) Membrane filter

4- Ibrahimia laboratory:

No	Instrument	Number	The condition
1	Alum Jar tester	1	Very Good
2	Distiller Water Apparatus	1	Very Good
3	Fridge	1	Very Good
4	TDS & Conductivity Meter	1	Acceptable
5	Drying oven	1	Good
6	Color meter	2	Acceptable
7	Centrifuge	1	Good
8	Microscope	1	Good
9	Turbidity meter	1	Out of work
10	Sensitive balance	1	Good

Instruments required for completing the laboratory:

- 1) Spectrophotometer
- 2) Incubator
- 3) Disinfection meter
- 4) Turbidity meter
- 5) Water bath
- 6) Muffle furnace
- 7) Colony counter

5-Menia Elqamh laboratory:

No	Instrument	The condition
1	Electricity Sensitive balance	Very Good
2	Spectrophotometer	Good
3	Alum Jar tester	Good
4	Residual chlorine meter	Acceptable
5	Drying oven	Good
6	Portable pH meter	Good

Instruments required for completing the laboratory:

- 1) TDS & Conductivity Meter
- 2) Incubator
- 3) Disinfection meter
- 4) Turbidity meter
- 5) Chlorine digital meter
- 6) Centrifuge
- 7) Fridge
- 8) pH meter

6- Abu Kabier laboratory:

No	Instrument	The condition
1	Turbidity meter	Out of work
2	TDS & Conductivity Meter	Acceptable
3	Distiller Water Apparatus	Good
4	Alum Jar tester	Out of work
5	Microscope	Out of work
6	Electricity Sensitive balance	Good
7	Drying oven	Good
8	Fridge	working
9	Incubator	acceptable
10	Hot plate	Good
11	Color meter	Acceptable

List of instruments required in shapwasco laboratory & what is been in tender:

No	Instrument	No. In Tender	Number
1	Centrifuge	-	1
2	Residual chlorine meter	2	2
3	Spectrophotometer	2	2
4	Ph meter(Digital)	4	3
5	Microscope	3	1
6	Membrane filter	1	2
7	Turbidity meter	4	4
8	TDS & Conductivity Meter	3	2
9	Colony counter	1	4
10	Incubator	3	2
11	Autoclave	3	2
12	Drying oven	-	1
13	Fridge	2	1
14	Distiller Water Apparatus	2	1
15	Water Bath	4	1
16	Muffle furnace	-	1
17	Sampler	-	6

2nd laboratories which NOP/WASD supervise the operation of its station:

1- Faqus Potable water station:

No	Instrument	Number	The condition
1	Alum Jar tester	1	Out of work
2	Magnetic Stirrer	1	Good
3	Fridge	1	Out of work
4	Autoclave	1	Acceptable
5	Incubator	1	Good
6	Turbidity meter	1	Out of work
7	TDS & Conductivity Meter	1	Out of work
8	pH Meter	1	Out of work
9	Balance	1	Out of work
10	Sand sieves	1	Good
11	Spectrophotometer	1	Out of work
12	Muffle furnace	1	Out of work
13	Microscope	1	Out of work
14	Drying oven	1	Acceptable
15	Water Bath	1	Good
16	Color meter	1	Acceptable
17	Hot Plate	1	Acceptable
18	UV Candle for Lab Disinfection	2	Good
19	Centrifuge	1	Out of work
20	Distiller Water Apparatus	1	Out of work
21	Electricity balance	2	Out of work
22	Electricity Sensitive balance	1	Out of work
23	Shaker	1	Acceptable
24	Distiller Water Apparatus	1	Good
25	Vacuum pump	1	Working

2- Kafr Saqr Laboratory Filtration Station:

No	Instrument	Number	The condition
1	TDS & Conductivity Meter	1	Out of work
2	Alum Jar tester	1	Out of work
3	Color meter	1	Acceptable
4	Turbidity meter	1	Out of work
5	Drying oven	1	weak
6	Spectrophotometer	1	Out of work
7	Sand sieves	1	Good
8	Balance	1	Out of work
9	Microscope	1	Out of work
10	Disinfection meter	1	weak
11	Fridge	1	Acceptable
12	Magnetic Stirrer	1	Good
13	Water Bath	1	Good
14	pH Meter	1	Out of work
15	Incubator	1	Weak
16	Centrifuge	1	Out of work
17	UV Oven	4	Good
18	Hot Plate	1	Weak
19	Suction Room for vapor & Gas	1	Out of work
20	Hot Plate	1	Out of work
21	Vacuum pump	1	Weak
22	Muffle furnace	1	working
23	Sensitive Balance	2	Out of work
24	Electric Sensitive Balance	1	Out of work
25	Disinfection meter	1	Good

Instruments required for completing the laboratory:

- 1) Spectrophotometer
- 2) Membrane filter
- 3) Electricity Sensitive balance
- 4) Turbidity meter
- 5) pH Meter
- 6) Alum Jar tester
- 7) TDS & Conductivity Meter
- 8) Colony counter
- 9) Autoclave
- 10) Incubator
- 11) Color meter
- 12) Microscope

Instruments required for completing the laboratory:

- 1) pH Meter
- 2) TDS & Conductivity Meter
- 3) Turbidity meter
- 4) Alum Jar tester
- 5) Centrifuge
- 6) Incubator
- 7) Microscope
- 8) Residual chlorine meter
- 9) Membrane filter
- 10) Electricity Sensitive balance
- 11) Spectrophotometer
- 12) Autoclave
- 13) Colony counter
- 14) Ice box

3- **Alhusainia laboratory station:**

No	Instrument	Number	The condition
1	Hot Plate	2	Very good
2	Turbidity meter	2	Weak
3	Centrifuge	1	Very good
4	pH & Ammonia & Florid Meter	1	Out of work
5	Spectrophotometer	1	Good
6	pH Meter	1	Out of work
7	Flame Photometer	1	Good
8	Turbidity meter	1	Out of work
9	TDS & Conductivity Meter	1	Acceptable
10	Deionizer	1	Weak
11	Alum Jar tester	1	Very good
12	Color Meter	3	Weak
13	Drying Oven	1	Good
14	Sand sieves	1	Good
15	Autoclave	1	Good
16	Sampler	1	Good
17	Vacuum pump	4	Good

Instruments required for completing the laboratory:

- 1) Colony counter
- 2) Microscope
- 3) Electricity Sensitive balance
- 4) Residual Chlorine meter
- 5) Fridge
- 6) pH Sensor

Hihya Laboratory Station:

No	Instrument	Number	The condition
1	Electrical balance	1	Good
2	Fridge	1	Good
3	Disinfection Meter	1	Good
4	Incubator	1	Good
5	Muffle furnace	1	Good
6	Water Bath	1	Good
7	Distiller Water Apparatus	1	Good
8	Microscope	1	Good
9	Colony counter	1	Good
10	Hot Plate	1	Good
11	Magnetic Stirrer	1	Good
12	Alum Jar tester	1	Good
13	Residual Chlorine Meter	1	Good
14	Turbidity Meter	1	Good
15	TDS & Conductivity Meter	1	Good
16	Color Meter using D.P.D	1	Good
17	Gas Ventilator	1	Good