

**THE DISTRICT GOVERNMENT ABBOTTABAD
NORTH WEST FRONTIER PROVINCE
THE ISLAMIC REPUBLIC OF PAKISTAN**

**PREPARATORY SURVEY REPORT
ON
THE PROJECT FOR
THE IMPROVEMENT OF WATER SUPPLY
SYSTEM IN ABBOTTABAD
IN
THE ISLAMIC REPUBLIC OF PAKISTAN**

November 2009

JAPAN INTERNATIONAL COOPERATION AGENCY

NIHON SUIDO CONSULTANTS CO., LTD.

and

JAPAN TECHNO CO., LTD.

GED
JR
09-118

PREFACE

Japan International Cooperation Agency (JICA) conducted the preparatory survey on the Project for the Improvement of Water Supply System in Abbottabad in the Islamic Republic of Pakistan.

JICA sent to Pakistan a survey team from April 15 to May 20, 2009.

The team held discussions with the officials concerned of the Government of Pakistan, and conducted a field study at the study area. After the team returned to Japan, further studies were made. Then, a mission was sent to Pakistan in order to discuss a draft outline design, and as this result, the present report was finalized.

I hope that this report will contribute to the promotion of the project and to the enhancement of friendly relations between our two countries.

I wish to express my sincere appreciation to the officials concerned of the Government of the Islamic Republic of Pakistan for their close cooperation extended to the teams.

November 2009

Kikuo Nakagawa
Director General,
Global Environment Department
Japan International Cooperation Agency

November 2009

Letter of Transmittal

We are pleased to submit to you the preparatory survey report on the Project for the Improvement of Water Supply System in Abbottabad in the Islamic Republic of Pakistan.

This survey was conducted by the Consortium of Nihon Suido Consultants Co., Ltd. and Japan Techno Co., Ltd., under a contract to JICA, during the period from March 2009 to November 2009. In conducting the survey, we have examined the feasibility and rationale of the project with due consideration to the present situation of Pakistan and formulated the most appropriate outline design for the project under Japan's Grant Aid scheme.

Finally, we hope that this report will contribute to further promotion of the project.

Very truly yours,

Hideki Asada
Project manager,
Preparatory Survey team on
the Project for the Improvement of
Water Supply System in Abbottabad
The Consortium of Nihon Suido
Consultants Co., Ltd. and Japan
Techno Co., Ltd.

Summary

Summary

(1) Outline of the Country

The Islamic Republic of Pakistan has total population of 176,000,000 (in 2009) and the national land of 796,000 km² is situated in-between Middle East and Asia, touching the Himalaya Mountains, the Karakorams and the Hindukukush Mountains east and west in the north and 8,000m high mountains like K2 and Nangapalapatt rising in Kashimir district. It is covered with the Suleimans in the west and with the Baluchistan highlands in the South west. In the east, Tar desert lies along the border of India. In about the center of the country, the Indus River flows through and forms the great plain. The country is extended long from north to south and climatically is much of variety from high mountainous ranges in the north to the Arabian Sea coastal regions in the south.

Administratively it is consisting of four provinces such as North West Frontier Province where Abbottabad District, the target area of this project is located, Punjab, Sindh and Balochistan, and in addition of FATA, NA and AJK.

Population of the target area is about 200,000 in total, where about 67,000 in Abbottabad TMA (where the water supply service is made by the municipality), 27,000 in Nawansher area and 105,000 in the surrounding area. The target area is in the valley of Hazara Mountains, located in the south east of North West Frontier Province and has been a place of strategic importance for NWFP where Karakoram Highway to China passes through. Dor River also flows down to South in the east of the valley.

The target area is situated at an altitude of 1,200m above sea level and is mild in summer but cold in winter. It snows sometimes in winter. The temperature in winter is below freezing and above 35°C in summer. Average monthly precipitation in June and August exceeds 200 mm, according to the data during 2000 to 2008 of Kakur meteorological observatory station which is located 10 km away to the north from the target area. In the other months, it is less than 100 mm.

As to the development strategy of Pakistan, they have listed 9 fields of importance such as “Stabilization and economic growth of macroeconomics”, “Welfare for the poverty and the weak of society”, “Improvement of agricultural productivity and added value”, ”Strengthening international competitiveness of industries” and etc., during 3 years of F/Y 2008/09 and F/Y 2010/ 11 according to the document No.11 on strategic decrease of the poor and needy announced in January 2009.

In addition, “Medium Term Development Framework 2005-2010” and “Vision 2030” for the long term development have been formulated.

(2) Background and Outline of the Project

According to the “Medium Term Development Framework 2005-2010”, the target of water supply improvement is to achieve the access ratio to potable water to 76% (96% in urban and 65% rural) of total population in 2010 from 65% (85% in urban and 55% in rural) of it in 2004/2005. Also, the policy target of “National Drinking Water Policy, 2007 (draft) ” states to supply potable and stable water for entire population by 2020, and to reduce water borne diseases and patients for improving the quality of life.

The water supplies in Abbottabad TMA and the surrounding U/Cs in Abbottabad District in North West Frontier Province (NWFP) have depended on groundwater as water sources for a long period. In recent years, however, the enhancement of water supply capacity is urgently required because of the rapid development and population increase in the target area, and the decrease of discharges of the existing wells. The service ratio of potable water at present is 57% only and in addition the duration time of water supply is less than one hour at many places. It is far from the situation of stable water supply. Also, the current water supply system, which is to pump up the well water to the distribution reservoirs located at a high elevation for water distribution, results the financial difficulty for water supply management due to high power cost. Further, the long term and stable operation is becoming difficult because of the shortage of well water due to excessive discharge of water and of the unexpected failures of pumps due to the lack of proper maintenance.

In due consideration of the situation mentioned above, the District Government Abbottabad has made a plan to introduce the surface water by gravity from a ravine in the east of Abbottabad TMA in 1990. As to this plan, F/S by ADB was carried out in 1994 and their request for Grant Aid Project to Japanese Government has been made in December 2000.

In response to their request, although Preliminary Study in 2002 and Basic Design Study in 2004 by JICA have been carried out, the implementation of the Grant Aid was cancelled because of the water rights conflict with the authorities down stream. However, since all the issues including water rights conflict has recently been settled, this Preparatory Survey of the project has been conducted.

(3) Outline of Preparatory Survey and its Contents

The objective of project is to mitigate the shortage of water supply capacity, to improve the water supply service ratio and to improve the living environment in Abbottabad TMA and the surrounding area in Abbottabad District.

The preparatory survey was conducted during the period from April 15 to May 20, 2009, and a discussion on a draft outline design was held during the period from September 9 to 19, 2009.

In order to achieve the objectives mentioned above, this Grant Aid Project consists of both the construction of surface water system and groundwater system including the development of new well units, and the capacity building based on Soft Component (Technical Assistance) for the sound operation and maintenance of facilities/systems, in Abbottabad TMA and the surrounding areas. Based on the request of Pakistan Government and results of discussion and survey at site, the planning of project has been carried out in accordance with the policies as follows.

① Policy for Target Year

Target Year is 2015 from the view point of high priority of Grant Aid and the size of the project.

② Policy for the design of facilities

- a) The target service coverage ratio is to achieve 92% of the population in 2015 from 57 % (population served of about 114,000) service coverage at present in 2009 and to cover the future population served of 216,000.
- b) In “National Drinking Water Policy, 2007 (draft)”, on domestic per capita consumption, it is recommended of 45 lpcd for rural area and 120 lpcd for urban area. The target area

of this Grant Aid is consisting of urban area and non-urban area, but commercial area is included. In due comprehensive consideration of this fact and as a result of discussion with the District Government Abbottabad, the design per capita consumption is decided as 90 lpcd which is in between 45 lpcd for rural area and 120 lpcd for urban area, recommended by the National policy.

- c) Surface water system is newly developed based on survey on the cost for pumping up and the possibility of groundwater quantity to be newly developed.
- d) Intake flow rate from surface water is maximum 200 liter/sec which is agreed upon water rights with local authorities in the down stream, and four locations of intake facilities are settled based on the survey of actual flow rate of the river, and in due consideration of stable intake throughout a year, checking water flow in dry season as well. The locations of intake facilities are also decided to be available by gravity, from the survey of the cost on both construction and O&M for the intake facilities and pumping stations.
- e) Surface water system is basically applied for distribution to the area of supply where is conveyed to distribution basin by gravity.
- f) Groundwater system is basically applied for compensation for the shortage of surface water against the maximum daily supply in 2015. Further, groundwater is planned to take from the existing well as much as possible.
- g) Water treatment system is designed to obtain the treated water quality meeting the water quality criteria specified in “National Standard of Drinking Water Quality (NSDWD) Pakistan Environmental Protection Agency, June 2008”, to be less chemicals requirement and to be user friendly operation and maintenance. From the view point of raw water characteristics, target treated water quality and etc., it is planned to apply Roughing Filters for medium fluctuation of turbidity and to apply Sedimentation Basins for high turbid water. For final treatment, Slow Sand Filters and Chlorine Disinfection are planned.
- h) “Guideline for Design Criteria for Waterworks Facilities, 2000 (Japan Water Works Association)” is referred for the design of water supply facilities, due to unavailability of such guidelines in Pakistan. However, the Building Code of Pakistan (Seismic Provisions - 2007) from Ministry of Housing & Works of the Government of Pakistan is complied with.

③ Policy for operation and maintenance

It is planned to carry out the promotion on activities of Soft Component (Technical Assistance) for the necessary capacity building for the proper operation and maintenance of surface water system and for the sound management of existing three water supply agencies.

The following Table shows the contents of request and the results of the preparatory survey.

The contents of request based on 2004 BD Study	The results of this preparatory survey	Explanation
1) Facilities	1) Facilities	
A. Surface Water System	A. Surface Water System	
- Intake: 4 nos.	- Intake: 4 nos.	No change
- Raw water transmission mains: 20.5 km	- Raw water transmission mains: 20.4 km	No change
- Water treatment plant: 17,300 m ³ /day (200 liter/sec)	- Water treatment plant: 17,280 m ³ /day (200 liter/sec)	No change
- Treated water transmission mains: 24.3 km	- Treated water transmission mains: 25.6 km	Length of 1.3 km increased due to rerouting

- Distribution reservoir: 6 nos., 2,020 m ³	- Distribution reservoir: 6 nos., 1,320 m ³	By reviewing capacity of reservoir
B. Groundwater System	B. Groundwater System	
- Tubewell: 4 nos.	- Tubewell: 4 nos.	No change
- Pump for new well: 4 nos.	- Pump for new well: 4 nos.	No change
- Pump to be replaced: 12 nos.	- Pump to be replaced: 12 nos.	No change
- Distribution reservoir: 3 nos., 530 m ³	- Distribution reservoir: 1 no., 300 m ³	By reviewing capacity of reservoir
- Water transmission mains: 6.2 km	- Water transmission mains: 3.6 km	By reviewing transmission and capacity of reservoir
2) Soft Component (technical assistance)	2) Soft Component (technical assistance)	
- Necessary capacity building for the proper operation and maintenance of surface water system and for the sound management of existing three water supply agencies.	- Necessary capacity building for the proper operation and maintenance of surface water system and for the sound management of existing three water supply agencies.	No change.

Based on the above-mentioned design policy, the contents of the outline design have been determined as shown in the following Table.

Facility	Explanation	Number and Dimension
A. Surface Water System		
(1) Intake	RC made, Bar screen type	4 nos. (Bagh River, Gaya River, Namly Mira River, Bandi River), Intake amount of 17,280 m ³ /day (200 liter/sec)
(2) Raw water transmission mains	SP, DIP	φ500mm ~ φ100mm, total length of 20.4 km
(3) Water treatment plant		Treatment capacity of 17,280m ³ /day (200 liter/sec)
	RC made	Sedimentation basin, 720 m ³ x 2 nos.
	RC made	Roughing filter, 40 m ² x 12 nos.
	RC made	Slow sand filter, 696 m ² x 6 nos.
	RC made	Clear water reservoir, 1,074 m ³ x 2 nos.
		Disinfection facilities
		Operation building, 216 m ² x 1 no.
		Yard piping
		Landscaping
(4) Treated water transmission mains	SP, DIP	φ500mm ~ φ100mm, total length of 25.6 km
(5) Distribution reservoir	RC made	6 nos., total capacity of 1,320 m ³ (Nawansher 340 m ³ , Sheikhul Bandi 130 m ³ , Salhad 180 m ³ , Mirpur 350 m ³ , Derawanda 220 m ³ , Banda Ghazan 100 m ³)
B. Groundwater System		
(1) Intake	New tubewell New pumps for renewal of existing tubewell	4 nos., 1,814 m ³ /day (21 liter/sec) 12 nos., 3,197 m ³ /day (37 liter/sec)
(2) Distribution reservoir	RC made	1 no., capacity of 300 m ³ (Dobathar 300 m ³)
(3) Water transmission mains	SP	φ150mm ~ φ100mm, total length of 3.6 km

(4) Implementation Period and Project Cost

The period of detailed design will be 4.5 months. The procurement and construction period will be 26 months.

The cost borne by the Pakistani Side	Rs. 577.4 Million (Approximately Yen 606 million)
1) Land Acquisition:	Rs. 80.00 million
2) Access Roads for Construction Sites:	Rs. 50.30 million
3) Power Supply, Water Supply, Drainage, Telephone, Office Furniture:	Rs. 43.50 million
4) Inter-linking of New/Old Reservoirs and Wells:	Rs. 31.60 million
5) Expansion and Rehabilitation of Distribution Network:	Rs. 154.80 million
6) Procurement and Installation of Water Meters:	Rs. 78.50 million
7) Provision for Creation of Project Sub-division (PMU):	Rs. 7.60 million
8) Commissions for Bank Arrangement, Custom Clearance:	Rs. 91.20 million
9) Provision for security arrangements for hiring Frontier Constabulary during project execution:	Rs. 37.10 million
10) Contingencies	Rs. 2.80 million

Conditions for Cost Estimates are as follows:

- 1) Date of Estimates: As of May, 2009
- 2) Exchange Rates: US\$ 1 = 95.77 Yen
Rs.1 = 1.05Yen
- 3) Period of Construction: 26.0 months
- 4) Others: The Project should be implemented in accordance with the procedures of Japan's Grant Aid Scheme.

(5) Project Evaluation and Recommendations

1) Project Evaluation

As stated previously, the objective of project is to mitigate the shortage of water supply capacity, to improve the water supply service ratio and to improve the living environment in Abbottabad TMA and the surrounding area in Abbottabad District. By implementing the project, the following effectiveness will be expected.

Present status and problems	Measures by the project	Direct effectiveness	Indirect effectiveness
<p>1) The water supplies in Abbottabad TMA and the surrounding U/Cs in Abbottabad District in NWFP have depended on groundwater as water sources for a long period.</p> <p>2) In recent years, the enhancement of water supply capacity is urgently required because of the rapid development and population increase in the target area, and the decrease of discharges of the existing wells.</p> <p>3) The service ratio of potable water at present is 57% only and in addition the duration time of water supply is less than one hour at many places. It is far from the situation of stable water supply.</p> <p>4) The current water supply system, which is to pump up the well water to the distribution reservoirs located at a high elevation for water distribution, results the financial difficulty for water supply management due to high power cost.</p> <p>5) The long term and stable operation is becoming difficult because of the shortage of well water due to excessive discharge of water and of the unexpected failures of pumps due to the lack of proper maintenance.</p>	<p>1) Providing surface water system</p> <p>2) Providing groundwater system</p> <p>3) Providing soft component (technical assistance)</p>	<p>1) Present population served in the target area is estimated at 114,000 in 2009. Providing water supply facilities both from surface water source and from groundwater source, safe and stable water supply will be available to the population of 216,400 in 2015.</p> <p>2) It is possible to improve service coverage ratio from 57% in 2009 to 92% in 2015 when surface water system is completed and groundwater system is properly maintained and operated.</p> <p>3) 24 hours a day continuous water supply will be available due to new water source obtained and proper utilization of well pumps, although water supply at present is unstable and less than a few hours because of frequent failure of well pumps.</p> <p>4) Stable and long term utilization of the well facilities will be secured by the proper operation of pumping facilities due to the reinforcement of capability for managing wells and O&M of pumps</p> <p>5) Newly established surface water committee and surface water supply unit and their proper management and operation will ensure the continuous supply of treated water to three existing water agencies.</p>	<p>Stable supply of safe water to the inhabitants is contributing the improvement of public health environment, and thus, the social & economic revitalization in the target area is expected.</p>

The following are the contents of baseline study executed for the project evaluation.

Contents of study	How to obtain	Results	Explanation	Effectiveness indicator after the project
Number of households in 2009	District Government Abbottabad	28,029	-	
Number of house connections in 2009	District Government Abbottabad	15,700	-	
Estimated population in 2009		200,249	Multiplying number of households and number of persons in household.	
Estimated population in 2015		235,226		Applying Increased ratio of census population in 1981 and 1998.
Service coverage in 2009		57%	Multiplying number of house connections and number of persons in household and divided by population.	
Service coverage in 2015		92%		Applying access ratio to potable water in MTDF 2005-2010.
Population served in 2009		114,000	Multiplying number of house connections and number of persons in household.	
Population served in 2015		216,400		Multiplying population and service coverage
Duration time of water supply in 2009	Interview to residents	Less than one hour at many houses		
Duration time of water supply in 2015		24 hours		By gravity flow of surface water system.
Monthly income per household	Interview to residents	Rs. 10,819 ~ 12,313 per month		For evaluation of socially affordable water tariff.

2) Recommendations

① Establishment of surface water supply unit

The existing water supply facilities in the service areas are operated and maintained by the three water supply agencies: 1) Works & Services Dept., the District Government Abbottabad, 2) Infrastructure, Abbottabad TMA and 3) Nawansher Service Unit.

There is no bulk water supply and experience in management of water treatment plant in Abbottabad District. It is therefore proposed to establish a new Surface Water Supply Unit under the District Government Abbottabad, which will supply water to the three water supply agencies. It is required to recruit human resources with qualification and capability suitable for the operation and maintenance of bulk water supply system.

Hence, it is necessary to provide advice and guidance through discussion with the three agencies and other related organizations, and facilitate preparation and coordination for establishment of the new Unit. To achieve the project goal, smooth operation by reinforcing the organizational structure and capacity building is indispensable.

For a purpose of consideration of setting of appropriate water tariff and distribution of bulk water supply to the three existing water supply agencies with appropriate manner, it is simultaneously proposed to establish Water Committee whose members consist of the representatives of the District Government, Abbottabad TMA and Nawansher Service Unit for regulation and advice to activities of the new Unit, and the coordination with the existing agencies. It is desirable to establish this Water Committee in an early stage obtaining the understanding of the relevant organizations.

The support with technical and managerial guidance is planned under the project for the establishment of Water Committee and Surface Water Supply Unit.

② Conservation and Control of Development of Groundwater Resource

The water balance of the basin in the project area is estimated to be currently balanced, with the intake of groundwater held to less than the recharge. The increasing intake of groundwater in the future, however, will eventually lead to decrease of yield, gradual fall of groundwater level, land subsidence and other environmental troubles across the area, unless measures for control of groundwater intake are taken. Impact is anticipated especially on the communities of the Western Terrace area as well as Nawansher, where tubewells are already congested. As a recommendation based on the results of this study, the development of groundwater resources in the area should be controlled with a regulation that new tubewells will be allowed to be installed only at locations more than 500 m apart from existing ones.

To ensure sustainable development and conservation of groundwater resources in the future at the same time, proper ground monitoring of discharges and water levels is indispensable. Immediate action should be taken for establishing such a monitoring system by rallying all the concerned stakeholders in the area.

③ Development of water distribution network

The Project is planned to supply bulk water to the distribution reservoirs of the three existing

water supply agencies, and the effect of the project can be born by the appropriate distribution of water to the service areas through the distribution networks. Therefore, execution of necessary strengthening and expansion of the existing distribution networks is required including rehabilitation of the existing pipelines where required in conjunction with the implementation of the Project. PC-1 contains the development cost for the existing distribution networks. It is essential to implement the development of the distribution network with steadily manner.

④ Improvement of drainage system and construction of sewerage system

The improvement of water supply by increasing supply capacity results increase of waste water. It will be necessary to consider the improvement of drainage system first against waste water increase followed by the construction of sewerage system in the future to minimize the water pollution to the downstream.

**Preparatory Survey Report
on
The Project for the Improvement of Water Supply System in Abbottabad
in the Islamic Republic of Pakistan**

- Contents -

Preface
Letter of Transmittal
Summary
Contents
Location Map/Perspective
List of Figures & Tables
Abbreviations


Chapter 1	Background of the Project -----	1 - 1
1-1	Background of the Project -----	1 - 1
1-2	Natural Conditions -----	1 - 1
1-3	Environmental and Social Considerations -----	1 - 11
 Chapter 2	 Contents of the Project -----	 2 - 1
2-1	Basic Concept of the Project-----	2 - 1
2-1-1	Overall Goal and Project Objective -----	2 - 1
2-1-2	General Description of the Project -----	2 - 1
2-2	Outline Design of the Japanese Assistance -----	2 - 3
2-2-1	Design Policy -----	2 - 3
2-2-2	Basic Plan-----	2 - 7
2-2-2-1	Population and Water Demand in the target year of 2015-----	2 - 7
2-2-2-2	Allocation Plan for Surface Water and Groundwater -----	2 - 10
2-2-2-3	Surface Water System-----	2 - 13
2-2-2-4	Groundwater system-----	2 - 24
2-2-2-5	Locations and Capacities of New Distribution Reservoirs ---	2 - 26
2-2-3	Outline Design Drawings-----	2 - 37
2-2-4	Implementation Plan -----	2 - 59
2-2-4-1	Implementation Policy -----	2 - 59
2-2-4-2	Implementation Conditions -----	2 - 60

2-2-4-3 Scope of Works -----	2 - 61
2-2-4-4 Consultant Supervision-----	2 - 62
2-2-4-5 Quality Control Plan-----	2 - 63
2-2-4-6 Procurement Plan -----	2 - 65
2-2-4-7 Operational Guidance Plan -----	2 - 66
2-2-4-8 Soft Component (Technical Assistance) Plan-----	2 - 66
2-2-4-9 Implementation Schedule -----	2 - 69
2-3 Obligations of Recipient Country -----	2 - 71
2-3-1 Land Acquisition -----	2 - 71
2-3-2 Construction of Access Roads to Intake Sites, Water Treatment Plant and Distribution Reservoirs-----	2 - 71
2-3-3 Power and Telephone Lines to the Project Site-----	2 - 71
2-3-4 Obligations for New and Existing Distribution Reservoirs -----	2 - 71
2-3-5 Right of Way for Raw and Treated Water Transmission Mains -----	2 - 72
2-3-6 Procurement and Installation of Water Meters -----	2 - 72
2-3-7 Implementation of Measures to Reduce Non-Revenue Water (NRW) -----	2 - 72
2-3-8 Approval of PC-1 -----	2 - 72
2-3-9 Other Requirements -----	2 - 72
2-4 Project Operation Plan-----	2 - 74
2-4-1 Organization for Management and Operation -----	2 - 74
2-4-1-1 Operation and Management of the Surface Water System ---	2 - 74
2-4-1-2 Operation and Management of the Groundwater System-----	2 - 75
2-4-1-3 Strengthening of Water Bill Collection -----	2 - 76
2-4-2 Operation and Maintenance of the Surface Water System-----	2 - 76
2-4-2-1 Operation and Maintenance of the Water Treatment Plant ---	2 - 76
2-4-2-2 Operation and Maintenance of Intake, Raw Water Transmission Mains and Treated Water Transmission Mains-	2 - 77
2-5 Project Cost Estimation -----	2 - 78
2-5-1 Initial Cost Estimation -----	2 - 78
2-5-2 Operation and Maintenance Cost-----	2 - 78
2-5-2-1 Water Tariff-----	2 - 78
2-5-2-2 Operation and Maintenance Costs and Water Revenues -----	2 - 80
2-6 Other Relevant Issues-----	2 - 84
Chapter 3 Project Evaluation and Recommendations -----	3 - 1
3-1 Project Evaluation-----	3 - 1
3-2 Recommendations-----	3 - 3


[Appendices]

- 1.----- Member List of the Study Team
- 2.----- Study Schedule
- 3.----- List of Parties Concerned in the Recipient Country
- 4.----- Minutes of Discussions
- 5.----- Soft Component (Technical Assistance) Plan
- 6.----- Other Relevant Data
- 7.----- References
 - 7-1 ----- Hydrogeological Background and Data
 - 7-2-----Allocation Plan for Surface Water & Groundwater
 - 7-3-----Questionnaire on Socio & Economic Conditions
 - 7-4-----Environmental Check List
 - 7-5 ----- Hydraulic Analysis of Water Transmission Mains

Location Map




Location Map of Abbottabad in Pakistan



Perspective View of Water Treatment Plant

Perspective View of Water Treatment Plant



List of Tables & Figures

List of Tables & Figures

List of Tables

Table 1-1-1	Outline of request based on 2004 BD Study.....	1-1
Table 1-2-1	Monthly Precipitation Data at Kakul Station (mm)	1-2
Table 1-2-2	Present Condition of Existing Tubewells and Future Measures	1-4
Table 1-2-3	List of Specifications of New Tubewells	1-5
Table 1-2-4	Range of Sustainable Groundwater Development in the Project Area	1-8
Table 1-2-5	Results of Groundwater Quality Analysis.....	1-9
Table 1-2-6 (1)	Flow Measurement Results in May and June of 2009	1-9
Table 1-2-6 (2)	Flow Measurement Results in July and August of 2009	1-9
Table 1-2-7	Yearly Minimum Flow Data for Dor River	1-10
Table 1-2-8	Monthly Precipitation Data at Kakul Station (mm)	1-11
Table 1-2-9	Results of Raw Water Quality Analysis in Four Intake Sites.....	1-11
Table 1-3-1	Mitigation Measures on the Environmental and Social Impacts	1-12
Table 2-2-1	Number of Households and House Connections	2-7
Table 2-2-2	The Current Population, Population Served and Service Coverage	2-7
Table 2-2-3	Future Population.....	2-8
Table 2-2-4	Service Coverage and Population Served in year 2015	2-9
Table 2-2-5	Future per capita Consumption, NRW ratio and Peak Factor.....	2-9
Table 2-2-6	Average Daily Water Demand and Maximum Daily Water Demand	2-10
Table 2-2-7	Existing and Under-construction Wells Available for the Future Supply	2-11
Table 2-2-8	Groundwater Development Plan including New Wells	2-12
Table 2-2-9	Distribution Plan for Groundwater and Surface Water in the Service Areas	2-13
Table 2-2-10	Pipe Diameters, Pipe Materials and Lengths of Pipelines for Raw Water Transmission Mains.....	2-14
Table 2-2-11	Major Features of the Water Treatment Plant	2-18
Table 2-2-12	Treated Water Transmission to Service Areas.....	2-20
Table 2-2-13	Diameters, Pipe Materials, Lengths of Pipelines for Treated Water Transmission Mains (Surface Water System)	2-23
Table 2-2-14	Existing and New Reservoirs Requiring Water Level Control Valves and Flowmeters.....	2-24
Table 2-2-15	List of Tubewells in Need of Pump Replacement	2-25
Table 2-2-16	List of New Transmission Pipelines for Groundwater System	2-26

Table 2-2-17	List of New Distribution Reservoirs to be constructed.....	2-26
Table 2-2-18	Scope of Well Construction and Existing Well Pump Replacement.....	2-61
Table 2-2-19	Scope of Intake Construction.....	2-61
Table 2-2-20	Scope of Raw and Treated Water Mains	2-61
Table 2-2-21	Scope of Water Treatment Plant Construction	2-61
Table 2-2-22	Scope of Distribution Reservoir Construction.....	2-62
Table 2-2-23	Major Work Items and Methods for Quality Control.....	2-64
Table 2-2-24	Procurement Plan for Major Construction Materials and Equipment.....	2-65
Table 2-2-25	Inland Transportation.....	2-66
Table 2-5-1	Abbottabad TMA 2008 Water Tariff.....	2-79
Table 2-5-2	Present Water Revenue and Operation & Maintenance Cost in 2007/2008.....	2-79
Table 2-5-3	Operation & Maintenance Cost for Surface Water System and Those Costs Incurred by Abbottabad TMA, Nawansher Service Unit and District Government Abbottabad.....	2-81
Table 2-5-4	Comparison of Annual Operation & Maintenance Costs and Water Revenues with Increased Water Tariff.....	2-82
Table 2-5-5	Degree of Water Tariff Increase and Effects on Household Income	2-83

List of Figures

Figure 1-2-1	Monthly River Flow Variation for the Past 9 Years	1-10
Figure 2-2-1	Location of Intakes, Raw Water Transmission Mains, Pressure Releasing Chambers, Water Treatment Plant.....	2-16
Figure 2-2-2	Location of Treated Water Transmission Main, Tube Wells and Reservoirs	2-22
Figure 2-2-3	Abbottabad City Water Supply Scheme (Aram Bagh System).....	2-27
Figure 2-2-4	Abbottabad City Water Supply Scheme (Kunj System)	2-28
Figure 2-2-5	Abbottabad City Water Supply Scheme (Jinnah System).....	2-29
Figure 2-2-6	Nawansher Water Supply Scheme	2-30
Figure 2-2-7	Abbottabad District Water Supply Scheme (Sheikhul Bandi System)	2-31
Figure 2-2-8	Abbottabad District Water Supply Scheme (Salhad System)	2-32
Figure 2-2-9	Abbottabad District Water Supply Scheme (Mirpur System).....	2-32
Figure 2-2-10	Abbottabad District Water Supply Scheme (Derawanda System).....	2-33
Figure 2-2-11	Abbottabad District Water Supply Scheme at Jhangi UC.....	2-34
Figure 2-2-12	Abbottabad District Water Supply Scheme (Banda Phugwarian System).....	2-36
Figure 2-2-13	Abbottabad District Water Supply Scheme (Dobather System)	2-36
Figure 2-2-14	Organizational Concept for Project Implementation	2-59
Figure 2-2-15	Implementation Schedule	2-70
Figure 2-4-1	Proportions of Dependence on Surface Water System and Groundwater System .	2-74
Figure 2-4-2	Organization Chart for the Surface Water Supply Unit	2-75
Figure 2-5-1	Balance of Operation and Maintenance Cost and Water Revenue after the Project.....	2-83

Abbreviations

Abbreviations

Abbreviations

ADB:	Asian Development Bank
ADO:	Assistant District Officer
AJK:	Azad Jammu Kashmir
A/P:	Authorization to Pay
BD (B/D):	Basic Design
BHN:	Basic Human Needs
BOD:	Biochemical Oxygen Demand
DCO:	District Coordination Officer
DDO:	Deputy District Officer
DIP:	Ductile Iron Pipe
EDO:	Executive District Officer
EIA:	Environmental Impact Assessment
E/N:	Exchange of Notes
FATA:	Federally Administered Tribal Areas
FS (F/S):	Feasibility Study
GAWS:	Greater Abbottabad Gravity Water Supply Scheme
G/A:	Grant Agreement
GDP:	Gross Domestic Product
GNP:	Gross National Product
IEE:	Initial Environmental Examination
IMF:	International Monetary Fund
JICA:	Japan International Cooperation Agency
JIS:	Japan Industrial Standards
KfW:	The German Development Bank
LGE&RDD:	The Local Government, Election and Rural Development
lpcd:	litre per capita day, unit water consumption per day per capita
LWL:	Low Water Level
M/D:	Minute of Discussion
NA:	Northern Areas
NOC:	No Objection Certificate
NSDWG:	National Standards for Drinking Water Quality

NUDP:	NWFP Urban Development Project
NWFP:	North West Frontier Province
PC-1:	Planning Commission-1
PHED:	Public Health Engineering Department
PMA:	Pakistan Military Academy
PMU:	Project Management Unit
PSDP:	Public Sector Development Programme
PVC:	Polyvinyl Chloride Pipe
SP:	Steel Pipe
SUDP:	Second Urban Development Project
TMA:	Town Municipal Administration
U/C:	Union Council
WASA:	Water and Sanitation Agency
WHO:	World Health Organization
WS&S:	Water Supply and Sanitation

Units

cm:	centimeter
kg/m ³ :	kilogram per cubic meter
km:	kilometer
km ² :	square kilometer
kW:	kilowatt
m:	meter
mm:	millimeter
m ³ :	cubic meter
m ³ /d:	cubic meter per day
l/s:	liter per second
lpcd:	liter per capita per day
N/mm ² :	Newton per square millimeter
Rs.:	Pakistan Rupee
Rs./m ³ :	Rupees per cubic meter
US\$:	United States Dollar

Chapter 1 Background of the Project

Chapter 1 Background of the Project

1-1 Background of the project

As there is a fear that the availability of groundwater resources in Abbottabad is declining due to the excess abstraction of groundwater in the area, the Public Health Engineering Department (PHED) of the District Government Abbottabad has formulated “The Greater Abbottabad Gravity Water Supply Scheme” in 1990, which uses surface water from the upstream of Dor River located at the east of Abbottabad. ADB loan was called for and the ADB conducted the Feasibility Study in 1994. Furthermore, PHED prepared “Addendum to Feasibility Study” but this project has not been funded by ADB.

Following to the above, the Government of Pakistan has applied to the Government of Japan for the request of the grant aid in December 2000.

In response to their request, although Preliminary Study in 2002 and Basic Design Study in 2004 by JICA (hereafter called “2004 BD Study”) have been carried out, the implementation of the Grant Aid was cancelled because of the water rights conflict with the authorities down stream. However, since all the issues including water rights conflict has recently been settled, this Preparatory Survey of the project has been conducted.

The outline of the request is shown in Table 1-1-1.

Table 1-1-1 Outline of request based on 2004 BD Study

1) Facilities
A. Surface Water System
- Intake: 4 nos.
- Raw water transmission mains: 20.5 km
- Water treatment plant: 17,300 m ³ /day (200 liter/sec)
- Treated water transmission mains: 24.3 km
- Distribution reservoir: 6 nos., 2,020 m ³
B. Groundwater System
- Tubewell: 4 nos.
- Pump for new well: 4 nos.
- Pump to be replaced: 12 nos.
- Distribution reservoir: 3 nos., 530 m ³
- Water transmission mains: 6.2 km
2) Soft Component (technical assistance)
- Necessary capacity building for the proper operation and maintenance of surface water system and for the sound management of existing three water supply agencies.

1-2 Natural conditions

1) General

The target area is in the Valley of Hazara Mountains, located in the south east of North West Frontier Province and has been a place of strategic importance for NWFP where Karakoram Highway to China passes through. Dor River also flows down to South in the east of the valley.

The target area is situated at an altitude of 1,200m above sea level and is mild in summer but

cold in winter. It snows sometimes in winter. The temperature in winter is below freezing and above 35°C in summer. As shown in Table 1-2-1, the average monthly precipitation in June and August exceeds 200 mm, according to the data during 2000 to 2008 of Kakul meteorological observatory station which is located 10 km away to the north from the target area. In the other months, it is less than 100 mm.

Table 1-2-1 Monthly Precipitation Data at Kakul Station (mm)

Year	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2000	87	58.5	70.4	10.8	26.5	99.6	287.6	288.5	130.9	29.6	2	50.2
2001	0.5	8.8	100.1	95.6	45.5	242.9	251.9	161.1	28.9	10.1	36.1	3.5
2002	63.1	90.1	76.1	39.4	29.9	83.1	166.3	301.4	127.2	28.9	1	1
2003	30.9	282.0	198.6	119.2	90.3	121.4	285.5	158.9	105.5	22.5	30.2	86.4
2004	108.3	45.9	13.4	133.4	65.4	89.6	209.7	221.5	71.7	124.1	40.5	47.2
2005	117.0	196.1	186.5	64.7	68.4	45.3	198.1	146.3	41.4	79.3	21.5	0.0
2006	125.5	78.5	61.5	74.7	61.7	68.1	329.7	191.5	62.0	37.0	84.6	121.6
2007	2.1	85.8	179.2	41.1	65.6	135.1	294.6	180.4	155.2	0.0	19.3	35.7
2008	200.0	67.8	20.3	131.0	45.1	248.7	269.1	161.6	39.5	36.1	77.0	111.5
Total	734.4	913.5	906.1	709.9	498.4	1133.8	2292.5	1811.2	762.3	367.6	312.2	457.1
Average	81.6	101.5	100.7	78.9	55.4	126.0	254.7	201.2	84.7	40.8	34.7	50.8

2) Existing tubewells

The hydrogeological study in 2009 undertook to examine the current status of existing tubewells of 31 in number, which were on duty as public water sources in 2004 BD Study. This study employed the same indicators as 2004 BD Study did, as follows:

- a. Running status of facilities
- b. Duration of daily operation
- c. Pumping rate
- d. Water levels (static and dynamic levels)
- e. Pump conditions
- f. Evaluation of facilities

This study found that 5 tubewells among 31 in 2004 BD Study had been abandoned during the past 5 years due to the decrease of discharges caused by "caving" (collapse of boreholes) or other reasons, reducing the total number of running wells to 27. The comparison shows that average yield was estimated at 160 lit/sec in 2004 BD Study, it has now been diminished to 141.1 lit/sec, due to the decrease of the total number of running tubewells as well as their discharges.

3) Tubewells Requiring Pump Replacement

A greater part of the existing tubewells was constructed in the latter part of 1990s, with pumping equipment installed at that time. These existing pumps have since been running for more than 10 years. A major part of pumps are of submersible motor pump type, while the service area of Abbottabad Nawansher mainly employs the type of vertical-shaft turbine pump of outdated design.

The 2004 BD Study recommended the replacement of the pumps at 12 tubewells. This study in 2009 found that one of those tubewells had been abandoned, including its pump and that another one had already been equipped with a new pump. The study also knew that frequent overhauls and repairs had been undertaken for the remaining pumping equipment (pumps/motors) of 10 in number plus additional 3 during the past 5 years (after 2005). Repairs of motors needed wire recoiling work, resulting in a long suspension of service while repair

continued as well as high repair cost. Pump failure, particularly wear of impellers due to intrusion of sand particles, resulted in the decrease of pump efficiency. Since the characteristics of vertical shaft turbine pumps tend to be lower in pump efficiency than those of submersible motor pumps, the latter is now dominantly prevailing model in the developed countries. The aged pumps are likely to require frequent overhauls and repairs, entailing long suspension of water service as well as high expenditure. As a result of the examination in this study, the pumps at three (3) additional wells are recommended to be added to the list of replacement, since they had increasingly been subject to repairs.

4) Well Failure such as drastic decrease of yield, caving

In the project area a part of tubewells has continuously been abandoned due to well failure such as drastic decrease of yield, caving (collapsing of formation around well screens), etc. This trend is found in progress in other running tubewells as well.

The direct cause for well failure is "sand pumping" due to poor well design or inadequate development. Furthermore after months or years of operation, localized clogging of screen openings with particles of sand or incrustation (scales) results in more or less lowered production. Efforts to increase production lead to a higher velocity of inflow through such partly closed opening and sand grains moved by such a higher velocity easily enter into the well. The effects of sand pumping include:

- a) Sand particles can accelerate wearing of pump impellers
- b) Sand deposits inside the well may close lower part of screens, resulting in further decrease of well yield.
- c) Excessive sand pumping results in removal of sand and gravel in a formation around the borehole and eventually causes caving (or collapsing of formation) leading to land sinking/subsidence in the tubewell site and collapsing of the tubewell structure itself.

When the above phenomena are found, tubewells are collapsed and buried by sand and gravel. Lama Maira No. 1 has already been buried by sand and gravel in the bottom of tubewell.

In Narrian area, all the tubewells except No. 6 had previously been abandoned due to caving. In this Study, five tubewells were confirmed to have been abandoned since 2004 BD Study, all due to similar reasons (Derawanda No. 1 and No. 2, Banda Phugwarian No. 2, Sheikhul Bandi No. 2, and Nawansher No. 1). Moreover, as a result of this study, the following 5 tubewells were found in danger of abandonment in the near future.

The status of the respective tubewells and future measures are shown in Table 1-2-2.

Table 1-2-2 Present Condition of Existing Tubewells and Future Measures

Area	T/W No.	Condition	S.W.L.	P.W.L.	Hours of Operation	Yield	Yield/day	Average of Yield	Specification of Pump	Pump Condition	Evaluation		
			m	m	hrs	l/sec	m ³ /d	l/sec	Head(m)				
1 Derawanda	No.1	Abandoned								Abandoned			
	No.2	Abandoned								Abandoned in June 2006			
	No.3	Working			8	5.53	159.3	1.8	122	8.8	Submersible pump was repaired in May 2007 and Nov.2008. Pump is overage.		
2 Jhangi	No.1	Working		10.2	9	7.08	229.4	2.7	152.5	12.6	Pump was repaired in Feb. 2006; Dec.2008, Jan. 2009 and Mar. 2009. Pump is Overage.		
	No.2	Working			8.5	4.35	133.1	1.5	289.7	7.6	Pump was repaired in Apr. 2005 and Apr. 2009.		
3 Lama Maira	No.1	Working		13.5	12	6.5	280.8	3.3	122	12.6	Submersible pump was repaired three times since 2005. Pump was replaced in 2006.		
4 Banda Phugwarian	No.2A	Abandoned								No.1 Well was abandoned in 1995			
	No.3	Working		6.26	12	2.8	121	1.4	274.5	7.6	Using the pump of No.2 Well. Pump was repaired nine times.		
5 Dobather	No.1	Working	12.1		10	5.82	209.5	2.4	305	9.5	Pump was Repaired two times.		
6 Banda Dilazak	No.1	Working	20.89(26.6)		9	7.21	233.6	2.7	189.1	7.6	Pump was repaired in Mar. 2006 and Mar. 2009.		
7 Banda Ghazan	No.1	Working	(20.9)	27.24(31.4)	9	5.61	181.8	2.1	289.7	12.6	Pump was repaired one time after 2005.		
8 Salhad	No.1	Working	8.58		16	5.4	311	3.6	192.1	5.3	Pump was repaired six times. Pump is overage.		
	No.2	Working		19.8	13	4.68	219	2.5	201.3	10.1	Pump was repaired four times. Pump is overage.		
	No.3(Spring)	Working			9						Water pumping up from reservoir constructed by the spring. Off the subject.		
9 Sheikhl Bandi	No.2	Abandoned											
	No.3	Working	11.88(14.7)	11	5.2	205.9	2.4	97.6	10.1	Pump was repaired in Sep. 2009	If pump will be changed, the well can be used continually.		
	No.4	Under repair	0.23	(13)	8	5.26	151.5	1.8	91.5	10.1	Pump was repaired three times after 2005. During this study it was under repairing.	If pump will be changed, the well can be used continually.	
10 Mirpur	No.1	Working		14.4	12	6.31	272.6	3.2	179.9	7.6	No problem to be used continually.		
	Spring												
11 Abbottabad TMA	Stoney Jheel	No.1	No Admittance		14	23.6	1189.4	13.8	37.1	16	No allowance into Cantonment. (Data from 2004 BD Study)	The operation and maintenance is difficult because	
		No.2	No Admittance						53	8.5	Cantonment Area. (Data 2004 BD Study)	•Area is designated No Admittance Area.	
		No.3	No Admittance		14	15.9	801.4	9.3	45.5	19.5	Cantonment Area. (Data 2004 BD Study)	•Eleven wells of MES, PMA and Cantonment Board causes mutual interference.	
		No.4	No Admittance		14	10	504	5.8	76.25	10.1	Cantonment Area. (Data 2004 BD Study)		
	Narrian Nawansher	No.6	Working	Flowing Well	20	3.89	280.1	3.2	51.8	22.7	Well is overage.	Well is planned to abandon because of caving	
		No.1	Abandoned								Abandon in Nov. 2008		
		No.3	Working	25.82	20	4.67	336.2	3.9	76.2	14	Submersible Pump was changed in 2007. Pump install depth 45m.	Well was abandoned because of ground sinking.	
		No.4	Working	9.18	25.47	20	7.78	560.2	6.5	76.2	22	Whole System are overage. Pump install depth 42m.	Well is planned to abandon or to reduce pumping up volume because of ground sinkage.
		No.5	Working		20	4.67	336.2	3.9	73.2	22.7	Pump was repaired five times.. Pump install depth 36m.	If pump will be changed, the well can be used continually. This pump will not be used in this study.	
		No.6	Working	0.12	(11.2)	20	17.8	1281.6	14.8	76.2	7	Pump was repaired three times. Pump is overage and ground causes sinkage.	Necessary to reduce Pumping up volume or to change Pump.
		No.7	Working	Flowing Well	2.09(2.8)	20	13.3	957.6	11.1	103.7	11	No problem to be used continually.	Necessary to reduce Pumping up volume or to change Pump.
12 Nawansher	No.1	Working	30		16	9.5	547.2	6.3	37.1	16	Pump was repaired three times after 2005. Well depth 120m.	No problem to be used continually.	
	No.2	Working			16	7.7	443.5	5.1	53	8.5	Pump was repaired two times after 2004. Well depth 90m.	No problem to be used continually.	
	No.3	Working	30		16	14	806.4	9.3	45.5	19.5	Pump was repaired two times after 2005.	No problem to be used continually.	
	No.4	Working			18	15.6	1010.9	11.7	76.25	10.1	Necessary to reduce pumping up volume because D.W.L. is very low. Pump Depth 66m.	If pump will be changed, the well can be used continually.	
	Spring				24	5	432	5					
					total	225.2	12195	141.1					

Note: () 2004 BD Study

5) Newly-Installed Tubewells through the support of Northern Pakistan Earthquake Recovery Fund

In the project area, 10 new tubewells were installed from 2007 to 2008 through the support of Northern Pakistan Earthquake Recovery Fund after the occurrence of the quake in 2005. These new wells are located in the areas in urgent need. The two (2) wells among 10 have already been on duty, with others ready whenever electrical connection could be provided. The information of these wells is listed in Table 1-2-3.

Table 1-2-3 List of Specifications of New Tubewells

	Service Area	Well No.	Status (*)	Dia.	Depth	Const. date	S.W.L.	D.W.L	Yield	Pump specification		Remarks
				(mm)	(m)		(m)	(m)	lit/s (lit/h)	head (m)	Rate (lit/s)	
1	Derawanda	No. 4	B	250	123.6	Dec. 07	5.24	29.14	7.5 (27)	246	10.1	(**) pump setting 51m, 50 HP
2	Derawanda	No. 5	B	250	85.8	Mar.08				420	5.0	pump setting 63m, 50 HP
3	Jhangi	No. 3	B	250	108.6	Dec. 07	7.68	21.96	8.75 (31.5)	180	7.6	(**) pump setting 51m, 30 HP
4	Lima Maira	No. 2	B	250	61.5					225	6.3	pump setting 42m, 40 HP
5	Banda Phugwarian	No. 4	B	250	105	Aug.07	2.09	24.42	11.4 (41.3)	294	7.6	(**) 50 HP
6	Banda Dilazak	No. 2	A	250	118.8	2007				180	7.6	pump setting 63m, 40 HP
7	Banda Ghazan	No. 2	B	250	120	2007	19.99	54.68	4.0 (14.4)	240	5.0	(**) pump setting 69m, 30 HP
8	Salhad	No. 3	B	250	114	2008				225	5.0	pump setting 66m, 30 HP
9	Sheikhul Bandi	No. 2	A	250	82.5	2007		13.09	10 (36)	120	10.8	Service started in Jan. 2009, pump setting 45m, 30 HP
10	Mirpur	No. 2	B	250	99	2007-08	30.93	31.36	7.5 (27)	186	6.3	(**) pump setting 36m, 30 HP

Legend: (*) Status of tubewell

(A) = In service already

(B)= Not yet in service because arrangement for electric connection has not been concluded.

(**) Tubewells with this tag were used for pumping test in this study 2009.

6) Groundwater

(1) Geology

Based upon this analysis through the existing well data, the regional geology features three-layer structure as follows:

a) 1st Layer

The 1st layer is predominantly clay and silt, partly with interbeds of gravel. While it is 30 to 40 m thick in the west side terrace, it increases the thickness in the central area of the plain to 70 to 80 m near Nawansher, where gravel interbeds in the west side is almost replaced by clay and silt.

b) 2nd Layer

The 2nd layer mainly consists of gravel. In the west side terrace, this feature is typically shown in its northern part such as Banda Dilazak and Dobathar, while it occurs as interbeds of gravel and clay in places such as Jhangi and Derawanda. In the plain, gravel becomes conspicuous with its thickness increasing from 30 to 40 m in Sheikhul Bandi and Nawansher. In Banda Phugwarian, it gets thicker than 50 m. In Mirpur, the northern area of the project site, this layer is 30 m thick, according to the well log at No. 2 tubewell (T/W2).

c) 3rd Layer

This is the underlying bedrock in the project site, represented by shale in the west side terrace and dolomite and limestone in the east side lowland around Sheikhul Bandi

Aquifers in the project area are identified as the first and the second layers - sand and sand/gravel - classified in the previous section. In the west side terrace the main aquifer is interbeds of sand/gravel alternately occurring with interbeds of clay, while in the plain area gravel overlying the bedrock develops a horizontally extending broad aquifer. The water bearing capacity of this layer as an aquifer is much better in the plain area than in the west side terrace, where limited distribution of gravel is likely to result in limited groundwater occurrence.

(2) Groundwater range and its intake

Encircled with mountainous areas, Abbottabad basin receives groundwater flow mainly from the following sources:

- a) groundwater flow in the terrace rising in the west mountains
- b) springs occurring in Mirpur in the north
- c) springs occurring in Kakul in the east
- d) groundwater flow occurring in limestone in the south

Groundwater moves into the central area of the plain with its levels varying from 1,190 to 1,210 m m.s.l. Springs in the east reportedly used to decrease the yield during the droughts, and groundwater from this source is likely to be subject to seasonal fluctuation. Part of the plain from Karakoram Highway, where the west side terrace falls into the plain, to the Cantonments in the east and south, forms an artesian flowing zone. They occur in the 2nd layer overlain by thick beds of clay and silt.

In the existing tubewells at of the project area, groundwater are taken from three-layer profile, in which the first and second layers are aquifers of sand and sand/gravel where groundwater mainly occurs. While these aquifers in the west terrace of the area consist of

alternately interbedded clay and sand/gravel, the second layer in the plain has the character of basal gravel horizontally extended across the area. The condition of aquifers is more favorable in the latter than in the former, where the aquifer is limited and discontinuous with smaller yield.

The tubewells in the western terrace of the study area tap both the first and second aquifers of sand and gravel. However, these aquifers tend to be thin-bedded with an average yield from the existing tubewells limited to 1 to 3 lit/sec. On the other hand, in the plain area of the site including Cantonment, Sheikul Bandi and Nawansher), most of the tubewells depend upon the second aquifer only, because the first layer consists of interbeds of clay and silt. However, this aquifer can generally provide larger yield than that in the terrace, ranging from 3 to 6 lit/sec on average, and reaching 10 lit/sec in a part of the area.

7) Groundwater Potential

(1) The volume of drainage of groundwater

Groundwater is constantly moving through aquifers under the local hydraulic gradient. The volume of such drainage of groundwater from aquifers may be roughly estimated through the analysis of the regional groundwater level contour map, employing Darcy's formula as follows:

$$Q = K \times A \times i$$

in which Q = Volume , K = hydraulic conductivity, A =Aquifer section (aquifer width \times thickness) and i = hydraulic gradient

To estimate a range of drainage in the plain, the following data are employed in this equation, as follows:

K = values obtained from the pumping test carried out under this study

Thickness of aquifers decided, based on the drilling data of existing tubewells

Width of aquifers (extent of aquifer distribution) decided through analysis of groundwater level contour map, and i decided through analysis of groundwater level contour map

Drainage into the plain occurs from all the four directions; a) from the west side terrace, b) from the north of the plain, c) from the spring area of the south and d) from the east. The flow from the east depends upon spring sources, although it is not clearly shown in the water level map. The calculation results are summarized as follows.

Estimated drainage from west terrace:	1,775 m ³ /d (647,875 m ³ /y)
Estimated drainage from North of plain:	2,310 m ³ /d (843,150 m ³ /y)
Estimated drainage from south springs	2,957 m ³ /d (1,079,232 m ³ /y)
Estimated drainage from east springs:	2,970 m ³ /d (1,084,050 m ³ /y)
Total:	10,012 m ³ /d (3,654,307 m ³ /y)

As a result of this estimate, a daily volume of drainage in the project area is about 10,000 m³/d (yearly about 3,700,000 m³).

(2) Criteria for Groundwater Development in the Project Area

In the project area groundwater including springs has so far been the sole water source, which is recharged by precipitation. If an overall discharge of groundwater throughout the area is within the range of recharge, it could be one of criteria for ensuring sustainable groundwater development. For this purpose, the previous studies, 2004 BD Study and the preliminary study in 2008 made efforts to estimate its range. This study proposes to reduce a natural drainage rate from aquifers estimated in the previous section from the recharge rate as a parameter for setting

sustainable rate of groundwater development. The estimation is summarized in the following table:

Table 1-2-4 Range of Sustainable Groundwater Development in the Project Area

2004 BD Study	Estimated recharge	15,801,000 m ³ /y	(1)
Preliminary	Estimated recharge	13,145,600 m ³ /y	(2)
This study	Drainage rate	3,664,307 m ³ /y	(3)
Overall sustainable development rate		12,146,693 m ³ /y	(1)–(3)
		9,491,293 m ³ /y	(2)–(3)
Average index rate for sustainable development		10,818,993	m ³ /year
		29,641	m ³ /day
		343	liter/sec

The result of this estimation suggests the daily amount of groundwater withdrawal for sustainable development is about 30,000 m³/day.

During 2004 BD Study, the total daily production of groundwater in the area was estimated at 26,000m³ (9,500,000 m³/year). Under the present study, there was no remarkable trend of water level fall witnessed in the area. Water levels in general appeared relatively stable, compared with the previous data. This fact indicates the continuation of balanced discharge within the recharge since the year 2004 in the project area.

However, further progress of groundwater development in the area is likely to result in the decline of discharge, accelerated fall of water level, environmental damages such as land subsidence, etc. The concerned areas include the west side terrace and Nawansher, where tubewells are congested without adequate spacing between them to minimize interference.

The results of water quality analysis for five wells are shown in Table 1-2-5. The groundwater was taken during pumping test. Turbidity is high at 10 to 18 degree and fecal coli form was found in all wells. However, currently working wells nearby are reported to have less problem for drinking purpose. Therefore, the reason why the water analysis data in the tested wells have shown high turbidity and coli form are supposed to be due to that the tests were carried out during pumping test without permanent pump installation and thus it is judged that the analysis data in question were different from those of usual water flow samples. It is recommended to conduct another water analysis test in the normal running conditions upon completion of installation of pumps, during detailed design stage in the future, whether or not the groundwater quality meets the requirements of National Standards for Drinking Water Quality (NSDWG), Pakistan Environmental Protection Agency. If it will not meet the standards, the results shall be reflected to the detailed design.

Table 1-2-5 Results of Groundwater Quality Analysis

No.	Name of Source Sampling Date and Time	National Standards for Drinking Water Quality	Unit	Banda Ghazan T/W No. 2	Jhangi T/W No. 3	Derawanda T/W No. 4	Mirpur T/W No. 2	Band Phugwarian T/W No. 4
				02/05/2009, 03:26	06/05/2009, 16:35	08/05/2009, 12:00	12/05/2009, 15:35	16/05/2009, 12:45
1	Total dissolved solids (TDS)	<1,000	mg/L	273	230	215	175	226
2	Alkalinity		mg/L	264	290	298.4	399.2	174.6
3	Calcium (Ca)		mg/L	107.40	61.94	90.31	99.93	8.33
4	Magnesium (Mg)		mg/L	45.19	47.61	15.96	41.00	67.63
5	Sodium (Na)		mg/L	12.73	11.62	15.86	2.48	13.7
6	Arsenic (As)	<0.005 (p)	mg/L	Nil	Nil	Nil	Nil	Nil
7	Manganese (Mn)	<0.5	mg/L	0.024	0.022	0.039	0.03	0.014
8	Fe		mg/L	Nil	Nil	Nil	Nil	Nil
9	pH	6.5 - 8.5		7.09	7.86	8.37	7.3	7.07
10	Turbidity	<5	NTU	19.23	81	10.16	16.53	17.13
11	Electric conductivity		µS/cm	604	451.66	307.66	577.33	600
12	Nitrite Nitrogen (NO2-N)	<3 (p)	mg/L	1.752	2.16	0.497	0.432	0.241
13	Nitrate Nitrogen (NO3-N)	<50	mg/L	7.76	9.56	2.202	1.763	0.13
14	Fecal bacteria	Must not be detected		Detected	Detected	Detected	Detected	Detected
15	Total Coliform	Must not be detected	CFU/100 mL	29	> 300	71	55	> 300

8) Water Flows of Surface Water Sources

Flow measurement results at the four intakes are shown in Table 1-2-6.

Table 1-2-6 (1) Flow Measurement Results in May and June of 2009

Source	Date of Measurement	Flow (l/sec)	Date of Measurement	Flow (l/sec)
Bagh River	May 2, 2009	154	June 6, 2009	148
Gaya River	May 2, 2009	269	June 4, 2009	246
Namly MiraRiver	May 6, 2009	605	June 3, 2009	564
BandiRiver	May 6, 2009	52	June 6, 2009	48
Total Flow		1,080		1,006

Table 1-2-6 (2) Flow Measurement Results in July and August of 2009

Source	Date of Measurement	Flow (l/sec)	Date of Measurement	Flow (l/sec)
Bagh River	July 9, 2009	156	August 4, 2009	148
Gaya River	July 6, 2009	258	August 4, 2009	246
Namly MiraRiver	July 4, 2009	573	August 6, 2009	552
BandiRiver	July 9, 2009	51	August 12, 2009	46
Total Flow		1,038		992

The results indicated that the total flow ranged from 992 l/sec to 1,080 l/sec during the period between May and August in 2009, which were approximately five times of the planned intake amount, 200 l/sec.

In addition, judging from the monthly minimum flow variation at Rajoia measurement point at Dor River for the past 9 years the minimum flows in May tend to be relatively lower than those in other months as shown in Figure 1-2-1. The yearly minimum flows for the past 9 years were observed in May three times as shown in Table 1-2-7.




Figure 1-2-1 Monthly River Flow Variation for the Past 9 Years

**Table 1-2-7 Yearly Minimum Flow Data for Dor River
(2000-2008 Rajoia Flow Measurement Point)**

	Jan	Feb	Mar	Apr	May	Jun	July	Aug	Sep	Oct	Nov	Dec
2008	2,929	4,779	4,316	3,699	3,545	3,545	4,470	3,699	4,470	3,545		3,237
2007	4,933	3,546	4,471	4,008	3,700	3,546	3,546	3,546	3,546	3,083	2,929	2,929
2006	1,850	1,850	1,988	1,695	1,542	1,695	1,695	3,700	4,471	3,546	3,546	2,929
2005	3,237	3,237	5,241	4,933	3,237	2,775	3,545	2,929	1,850	2,158	1,850	1,850
2004	2,884	3,112	2,884	1,742	1,588	1,850	3,237	4,162	3,391	2,312	3,083	3,083
2003	1,198	1,198	2,893	2,173	2,507	1,471	1,667	3,968	4,383	3,734	2,655	3,191
2002	1,492	1,433	1,775	1,832	883	693	1,223	1,663	1,666	1,096	973	856
2001	1,112	1,073	941	1,112	623	5,417	1,214	3,045	2,761	2,420	2,029	1,080
2000	2,999	2,971	2,999	2,999	2,999	2,771	2,771		4,618	2,467	1,348	1,073
Frequency	2	1	0	0	3	1	0	0	1	0	2	3

Frequency: Frequency that yearly minimum flow occurred in each month.
No data is available in November 2008.

Precipitation data from 2000 to 2008 at Kakul meteorological station also indicate that the rainfall levels decline in May, October, November and December. These facts implicate that both the river flows and precipitation are low in May. The river flow measurement results shows, however, that the total flow is maintained at around 1,000 l/sec in May 2009, which is not derived from the recent rainfall before the measurements. The precipitation data until April 29, 2009 were referred to and that shows only 12mm precipitation was observed on April 21 during the period from April 20 to April 29, 2009.

It is concluded from the above discussion that the planned intake amount can be secured.

Table 1-2-8 Monthly Precipitation Data at Kakul Station (mm)

Year	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
2000	87	58.5	70.4	10.8	26.5	99.6	287.6	288.5	130.9	29.6	2	50.2
2001	0.5	8.8	100.1	95.6	45.5	242.9	251.9	161.1	28.9	10.1	36.1	3.5
2002	63.1	90.1	76.1	39.4	29.9	83.1	166.3	301.4	127.2	28.9	1	1
2003	30.9	282.0	198.6	119.2	90.3	121.4	285.5	158.9	105.5	22.5	30.2	86.4
2004	108.3	45.9	13.4	133.4	65.4	89.6	209.7	221.5	71.7	124.1	40.5	47.2
2005	117.0	196.1	186.5	64.7	68.4	45.3	198.1	146.3	41.4	79.3	21.5	0.0
2006	125.5	78.5	61.5	74.7	61.7	68.1	329.7	191.5	62.0	37.0	84.6	121.6
2007	2.1	85.8	179.2	41.1	65.6	135.1	294.6	180.4	155.2	0.0	19.3	35.7
2008	200.0	67.8	20.3	131.0	45.1	248.7	269.1	161.6	39.5	36.1	77.0	111.5
Total	734.4	913.5	906.1	709.9	498.4	1133.8	2292.5	1811.2	762.3	367.6	312.2	457.1
Average	81.6	101.5	100.7	78.9	55.4	126.0	254.7	201.2	84.7	40.8	34.7	50.8

Table 1-2-9 shows the results of raw water quality analysis in four intake sites. Since ammonium nitrogen and nitrate nitrogen are low, raw water is not contaminated. Turbidity of 2 to 15 degree is treated by the planned sedimentation basin and roughing filter. General bacteria and total coliform are treated by slow sand filter and chlorination.

Table 1-2-9 Results of Raw Water Quality Analysis in Four Intake Sites

	Bagh River	Gaya River	Namly Mira River	Bandi River	Pakistan NSDWG
Ammonium Nitrogen (mg/l)	< 0.16	< 0.16	< 0.16	< 0.16	< 1.5 (1993 WHO Guidelines)
Nitrite Nitrogen (mg/l)	< 0.006	< 0.006	< 0.006	< 0.006	< 3
Nitrate Nitrogen (mg/l)	0.23 - 0.4 6	0.23 - 0.4 6	0.46 - 1.15	0.46	< 50
General Bacteria	Detected	Not detected	Detected	Detected	Must not be detected
Total Coliform	Detected	Not detected	Detected	Detected	Must not be detected
Turbidity (NTU)	< 2	< 15	< 5	< 5	< 5

1-3 Environmental and Social Considerations

EIA is not required for the project as confirmed on the M/Ds dated April 27, 2009 and September 16, 2009. The Pakistan side assured that No Objection Certificates for the IEE issued in 2004 would be extended accordingly when it is necessary before its expiration in May 2010.

Some negative impacts might be caused by the project according to the "JICA's guideline of social and environmental considerations". In order to mitigate the negative impacts, the Pakistani side agreed to take the measures as shown in Table 1-3-1.

Pakistan side completed the Environmental Checklist as shown in Appendix 7-4.

Table 1-3-1 Mitigation Measures on the Environmental and Social Impacts

Item	Mitigation measures
Explanation to the Public	Pakistan side is planning to set the water tariff based on the amount of the water used by the users. The plan is going to be explained to the users during implementation of the soft component program.
Impacts during Construction	<ul style="list-style-type: none"> - During the construction, water will be sprayed on the road to settle the dust. Daily and periodical inspection of the construction machines will be conducted in order to reduce the exhaust gases, noise and vibrations. The contractors will also take appropriate measures for the disposing the wastes. Soil erosion would be minimized by constructing appropriate concrete-made drainage and fully compacting road. - Annoyance to the general public living in the vicinity by transporting materials for the construction would be minimized through informing the date and time in advance. - The contractor will prepare safety action plan and will provide safety training especially to the workers.
Air Quality	Currently, there is no standard regarding the use of bleaching powder in Pakistan. However, like in Japan, appropriate safe measures such as use of mask, glasses, safety wear etc. would be required for the workers in order to prevent direct contact with the powder.
Groundwater	Subsidence may occur if a large volume of ground water is extracted. Therefore, extraction of the groundwater from the tubewells should be implemented with appropriate pumping rate. In addition, the groundwater level of the tubewells should be monitored periodically.

Chapter 2 Contents of the Project

Chapter 2 Contents of the Project

2-1 Basic Concept of the Project

2-1-1 Overall Goal and Project Objective

According to the “Medium Term Development Framework 2005-2010”, the target of water supply improvement is to achieve the access ratio to potable water to 76% (96% in urban and 65% rural) of total population in 2010 from 65% (85% in urban and 55% in rural) of it in 2004/2005. Also, the policy target of “National Drinking Water Policy, 2007 (draft)” states to supply potable and stable water for entire population by 2020, and to reduce water borne diseases and patients for improving the quality of life.

The objective of project is to mitigate the shortage in water supply capacity, to improve the water supply service ratio and to improve the living environment in Abbottabad TMA and the surrounding area. Within the overall goal, the project objective is to increase the population served to 216,400 in 2015, from the estimated 2009 figure of 113,900. This is equivalent to increasing the service ratio from 57% to 92%, by developing the surface water system in addition to the present groundwater system in order to supply a further 102,500 people.

2-1-2 General Description of the Project

In order to achieve the above mentioned overall goals and project objective and meet the water demand in 2015 of 357 liter/sec. The scope of the project was formulated as follows;

- 1) Surface water system (196 liter/sec)
 - Construction of Intake facilities: 4 nos.
 - Installation of raw water transmission mains: 20.4 km
 - Construction of water treatment plant: 17,280 m³/day
 - Installation of treated water transmission mains: 25.6 km
 - Construction of distribution reservoirs: 6 nos. (1,320 m³)
- 2) Groundwater system (161 liter/sec)
 - Construction of wells: 4 nos.
 - Installation of new well pumps: 4 nos.
 - Replacement of the existing well pumps: 12 nos.
 - Construction of distribution reservoir: 1 no. (300 m³)
 - Installation of transmission mains: 3.6 km

To achieve the project objective, it is necessary to implement the following initiatives:

- | |
|---|
| <ul style="list-style-type: none">- To establish a new organization to supply surface water (Surface water system unit)- To use groundwater effectively- Proper operation and maintenance of the surface water system- Proper management of the three different organizations involved in water services |
|---|

The following technical assistance package is proposed, to assist the establishment of a new organization and the capacity development of personnel.

- Training for tubewell management and operation and maintenance of pumps
- Capacity development for operation and maintenance of slow sand filtration systems
- Assistance in establishing a surface water system unit
- Improvement in water tariff collection systems

2-2 Outline Design of the Japanese Assistance

2-2-1 Design Policy

The design of project has been carried out in accordance with the policies as follows.

1) Basic Policy

(1) Policy for Target Year

Target Year is 2015 from the view point of high priority of Grant Aid and the size of the project.

(2) Policy for the design of facilities

- a) The target service coverage ratio is to achieve 92% of the population in 2015 from 57 % (population served of about 114,000) service coverage at present in 2009 and to cover the future population served of 216,000.
- b) In “National Drinking Water Policy, 2007 (draft)”, on domestic per capita consumption, it is recommended of 45 lpcd for rural area and 120 lpcd for urban area. The target area of this Grant Aid is consisting of urban area and non-urban area, but commercial area is included. In due comprehensive consideration of this fact and as a result of discussion with the District Government Abbottabad, the design per capita consumption is decided as 90 lpcd which is in between 45 lpcd for rural area and 120 lpcd for urban area, recommended by the National policy.
- c) Surface water system is newly developed based on survey on the cost for pumping up and the possibility of groundwater quantity to be newly developed.
- d) Intake flow rate from surface water is maximum 200 liter/sec which is agreed upon water rights with local authorities in the down stream, and four locations of intake facilities are settled based on the survey of actual flow rate of the river, and in due consideration of stable intake throughout a year, checking water flow in dry season as well. The locations of intake facilities are also decided to be available by gravity, from the survey of the cost on both construction and O&M for the intake facilities and pumping stations.
- e) Surface water system is basically applied for distribution to the area of supply where is conveyed to distribution basin by gravity.
- f) Groundwater system is basically applied for compensation for the shortage of surface water against the maximum daily supply in 2015. Further, groundwater is planned to take from the existing well as much as possible.
- g) Water treatment system is designed to obtain the treated water quality meeting the water quality criteria specified in “National Standard of Drinking Water Quality (NSDWD) Pakistan Environmental Protection Agency, June 2008 “, to be less chemicals requirement and to be user friendly operation and maintenance. From the view point of raw water characteristics, target treated water quality and etc., it is planed to apply Roughing Filters for medium fluctuation of turbidity and to apply Sedimentation for Basins for high turbid water. For final treatment, Slow Sand Filters

and Chlorine Disinfection are planned.

- h) “Guideline for Design Criteria for Waterworks Facilities, 2000 (Japan Water Works Association)” is referred for the design of water supply facilities, due to unavailability of such guidelines in Pakistan. However, the Building Code of Pakistan (Seismic Provisions - 2007) from Ministry of Housing & Works of the Government of Pakistan is complied with.

(3) Policy for operation and maintenance

It is planned to carry out the promotion on activities of Soft Component (Technical Assistance) for the necessary capacity building for the proper operation and maintenance of surface water system and for the sound management of existing three water supply agencies.

2) Policy for Natural Conditions

- (a) Most of the proposed intake sites and raw water transmission routes for the surface water system are located in hilly areas. In order to avoid possible damage due to land sliding or rock falls, special attention shall be paid in the design to the structure of the facilities, pipe materials, pipe protection, and maintenance access roads.
- (b) The surface water system is a gravity flow system utilizing the height difference between the intakes and water treatment plant site. Depending on the elevation of the raw water transmission routes, the static internal pipe pressure at the low elevation points be very high. Accordingly, special consideration shall be given to selecting suitable pipes and valves that can withstand high water pressure. In addition, pressure releasing chambers shall be considered where necessary.
- (c) Raw water turbidity shows a sharp upward trend during the rainy season. Accordingly, the water treatment plant should be designed so that it can respond to rapid changes in water quality.

3) Policy for Socio-economic Conditions

- (a) The major raw water transmission pipe route is along Murree Road, which is managed by the Provincial Government. This road has been developed by cutting sharp mountain slopes to connect Abbottabad and Murree, and there is no alternative connecting route between these cities. Care should be taken during the construction period in order to facilitate transport requirements and avoid any potential accidents.
- (b) The present water tariff appears to be very low. In order to improve the water supply management after the implementation of the Project, discussion with the implementing agency is necessary in order to raise the water tariff, with due consideration of household income level, affordability for consumers and subsidy levels borne by the relevant governments. It is necessary to propose an appropriate and feasible water tariff level.

4) Policy for Construction and Procurement

- (a) One major component of the Project is the pipeline construction work. Pipes with a diameter less than 250mm are to be steel pipe, which is locally produced and widely

used in Pakistan. However, pipes with a diameter greater than 300mm are to be Ductile Cast Iron Pipe (DIP), due to its strength against external load, high pressure resistance and ease of installation. As DIP is not available locally, procurement from other countries is to be considered.

5) Policy for Utilizing Local Contractors

- (a) There are contractors available in Abbottabad District and North West Frontier Province with experience in tubewell construction in Abbottabad Basin, and those contractors will be utilized for the Project. Pumps for tubewells are also manufactured locally and will be utilized for the Project.
- (b) Regarding the construction works for the water treatment plant, intakes, raw water and treated water transmission mains and reservoirs, the utilization of major contractors in Pakistan should be considered in view of the magnitude of the works.

6) Policy for the Management Capacity of Implementation Agency

- (a) It is necessary to set up a new organization to operate and manage the new surface water gravity system. It is also necessary to clearly define the roles and responsibilities of the three agencies, namely Abbottabad TMA, Nawansher Service Unit and Abbottabad District (Works & Services Dept), in operating the new system. With regard to the establishment and effective commencement of the new institution, managerial guidance by the Japanese consultants should be considered in order to assist the process.
- (b) The water treatment plant introduced in the Project will be the district's first experience in operation and maintenance of a water treatment plant. Technical guidance from the Japanese consultants should be also provided to ensure capacity building for operation and maintenance of the new system.

7) Policy for Facilities

The major components of the facilities are intake facilities, raw water transmission facilities, water treatment plant, treated water transmission facilities and distribution reservoirs for the surface water system. For the groundwater system, the major components are tubewells, treated water transmission facilities and distribution reservoirs.

- (a) Regarding raw water transmission mains installed along sharp slopes upstream of Namly Maira River, Bagh River and Gaya River, various alternative pipe installations should be considered. This applies not only to underground pipes but to exposed installations, hanging installations etc, depending on the surrounding site conditions.
- (b) The raw water transmission facilities are one of the most important facilities in the surface water system. As the static water pressure in the pipeline becomes very high at the lower elevations of the pipeline route, it is necessary to consider these high pressures when selecting pipe materials and valves. Pressure releasing chambers should be constructed at the appropriate locations to achieve the maximum static pressure of 25kg/cm².
- (c) The treatment plant facilities are designed to achieve a finished water quality which

complies with the National Standards for Drinking Water Quality (NSDWG), Pakistan Environmental Protection Agency, June 2008. Adopting facilities with easier operation and maintenance should be considered, so that manual operation is preferred rather than automatic control.

- (d) In order to avoid the excess abstraction and well caving issues observed in the existing tubewells, it is necessary to set appropriate abstraction capacities for the wells to be constructed or rehabilitated in the Project. In addition, devices to ensure minimum monitoring and controlling of the operation of the wells should be provided.

8) Policy for Construction Method and Period

- (a) Access to the upstream areas of the rivers is not easy, as only footpaths with sharp slopes are available. In such sites tractors may be used to carry construction materials as far as possible, and then manpower used to transfer materials to the construction sites. Widening the existing footpaths may be necessary in such cases.
- (b) The construction site for the water treatment plant is mostly covered with rock, and excavation with giant breakers, backhoes and blasting will be required. The volume of rock excavation is significant, and sufficient time for this excavation work must be considered in the construction schedule.
- (c) The magnitude of pipe laying work is significant. As the total construction period is very limited, the pipe laying work should be done simultaneously by several teams dedicated exclusively to pipe laying. It is necessary to deploy sufficient contractors as well as local consultant staff to inspect the different sites.

2-2-2 Basic Plan

2-2-2-1 Population and Water Demand in the target year of 2015

1) Number of Households and House Connections in the Project Areas

The number of households and house connections in the Project Area at present are confirmed by Abbottabad TMA and Abbottabad District, and are shown in the table below. The total number of house connections is 15,700, while the total number of household is 28,029

Table 2-2-1 Number of Households and House Connections

Project Area	Union council (U/C)	No. of households in 2009	No. of house connections (domestic)
(1) Abbottabad TMA (urban)	Kehal, Malik Pura, Central Urban	8,875	5,800
(2) Nawansher Service Unit (urban)	Nawansher	3,645	3,603
(3) Sheikhul Bandi	Sheikhul Bandi	2,799	1,129
(4) Salhad	Salhad	3,440	1,052
(5) Mirpur	Mirpur	1,954	887
(6) Jhangi UC			
(i) Derawanda	Jhangi	1,529	747
(ii) Jhangi	Jhangi	771	426
(iii) Lama Maira	Jhangi	703	330
(iv) Banda Ghazan	Jhangi	540	458
(v) Banda Dalazak	Jhangi	882	493
(vi) Band Phugwarian	Jhangi	794	498
(Vii) Dobathar	Jhangi	2,097	277
Total		28,029	15,700

2) The Current Population, Population Served and Service Coverage in the Project Area

The population in 2009 has been calculated as 200,249 by multiplying the number of households by the number of persons in a household, which was estimated by interviewing residents. The population served in 2009 has also been calculated as 113,923 by multiplying the number of house connections by the number of persons in a household. The average persons per household is 7.6 in Abbottabad TMA, 7.5 in Nawansher Service Unit and 6.8 non-urban areas. The table below shows the number of households and the estimated population.

The service coverage ratio in Nawansher Service Unit shows a high figure of 99%, and the ratio in Abbottabad TMA is 65%. The ratio in non-urban areas ranges from 13% in Dobathar to 85% in Banda Ghazan.

Table 2-2-2 The Current Population, Population Served and Service Coverage

Project Area	No. of persons per household	2009 Population Served	Service coverage (%)
(1) Abbottabad TMA (urban)	7.6	67,450	65

(2) Nawansher Service Unit (urban)	7.5	27,338	27,023	99
(3) Sheikhul Bandi	6.8	19,033	7,677	40
(4) Salhad	6.8	23,392	7,154	31
(5) Mirpur	6.8	13,287	6,032	45
(6) Jhangi UC				
(i) Derawanda	6.8	10,397	5,080	49
(ii) Jhangi	6.8	5,243	2,897	55
(iii) Lama Maira	6.8	4,780	2,244	47
(iv) Banda Ghazan	6.8	3,672	3,114	85
(v) Banda Dalazak	6.8	5,998	3,352	56
(vi) Band Phugwarian	6.8	5,399	3,386	63
(Vii) Dobathar	6.8	14,260	1,884	13
Total		200,249	113,923	57

3) Future Population in the Project Area

The population increase ratio in the 1981 and 1998 censuses has been used as annual average population increase up to 2015. The applied increase ratio is 2.3% in Abbottabad TMA, 1.9% in Nawansher Service Unit and 2.6% to 3.9% in the other areas. Total population in the project area is estimated as 235,226 in 2015.

Table 2-2-3 Future Population

Project Area	2009 Population	Growth rate (1981-1998, %)	2015 Population
(1) Abbottabad TMA (urban)	67,450	2.3	77,310
(2) Nawansher Service Unit (urban)	27,338	1.9	30,606
(3) Sheikhul Bandi	19,033	3.1	22,859
(4) Salhad	23,392	2.6	27,287
(5) Mirpur	13,287	3.9	16,716
(6) Jhangi UC			
(i) Derawanda	10,397	3.3	12,633
(ii) Jhangi	5,243	3.3	6,371
(iii) Lama Maira	4,780	3.3	5,808
(iv) Banda Ghazan	3,672	3.3	4,462
(v) Banda Dalazak	5,998	3.3	7,288
(vi) Band Phugwarian	5,399	3.3	6,560
(Vii) Dobathar	14,260	3.3	17,327
Total	200,249		235,226

4) Service Coverage Ratio and Service Population

The service coverage ratio in 2015 is set as 100% in Abbottabad TMA and Nawansher Service Unit. The ratio is 85% in other areas, while 90% is applied for Banda Ghazan, considering the

achievement of 85% in 2009. This results in an estimated total population served of 216,353 in 2015.

Table 2-2-4 Service Coverage and Population Served in year 2015

Project Area	2015 Population	2015 Service Coverage (%)	2015 Population Served	2009 Service Coverage (%)
(1) Abbottabad TMA (urban)	77,310	100	77,310	65
(2) Nawansher Service Unit (urban)	30,606	100	30,606	99
(3) Sheikhul Bandi	22,859	85	19,430	40
(4) Salhad	27,287	85	23,194	31
(5) Mirpur	16,716	85	14,208	45
(6) Jhangi UC				
(i) Derawanda	12,633	85	10,738	49
(ii) Jhangi	6,371	85	5,415	55
(iii) Lama Maira	5,808	85	4,937	47
(iv) Banda Ghazan	4,462	90	4,016	85
(v) Banda Dalazak	7,288	85	6,195	56
(vi) Band Phugwarian	6,560	85	5,576	63
(Vii) Dobathar	17,327	85	14,728	13
Total	235,226	92	216,353	

5) Water Demand

Water demand in the project area has been estimated as follows:

The same figures used in the Basic Design (B/D) in 2004 have been applied for the major indicators of water demand forecast, such as Per Capita Water Consumption (lpcd), Non Revenue Water Ratio, and Peak Factor (Day Max./Day Ave.), while the figure for Non-domestic water consumption is revised in this Study. Non-domestic water consumption was estimated as 15% (13 lpcd) of domestic consumption in Abbottabad TMA and 5% (5 lpcd) in Nawansher Service Unit in the B/D in 2004. Considering the similarities in the commercial areas of Nawansher and Abbottabad TMA, the same non-domestic consumption (13 lpcd) has been applied for Abbottabad TMA and Nawansher Service Unit in this Study.

Table 2-2-5 Future per capita Consumption, NRW ratio and Peak Factor

Item	B/D in 2004 (Target Year: 2010)		This Study (Target Year: 2015)	
	Abbottabad Urban	Nawansher & Other U/C	Abbottabad Urban & Nawansher Urban	Other U/C
1. Domestic Water Consumption (lpcd)	90	90	90	90
2. Non-domestic Water Consumption (lpcd)	13	5	13	5
3. Total Water Consumption (lpcd)	103	95	103	95
Non Revenue Water Ratio (%)	20%	20%	20%	20%
4. Day Average Water Demand	129	119	129	119
Peak Factor (Day Max./Day Ave.)	1.15	1.15	1.15	1.15

By using the figures in the above table, the 2015 Average Daily Water Demand is estimated as 26,826 m³/day and the Maximum Daily Demand is estimated as 30,852 m³/day (356.9 l/s).

Table 2.2.6 Average Daily Water Demand and Maximum Daily Water Demand

Project Area	2015 Population Served	2015 Water Demand (lpcd)	2015 Average Daily Demand (m ³ /day)	2015 Maximum Daily Demand (m ³ /day)	2015 Maximum Daily Demand (liter/sec)
(1) Abbottabad TMA (urban)	77,310	129	9,973	11,469	132.7
(2) Nawansher Service Unit (urban)	30,606	129	3,948	4,540	52.5
(3) Sheikhlul Bandi	19,430	119	2,312	2,659	30.8
(4) Salhad	23,194	119	2,760	3,174	36.7
(5) Mirpur	14,208	119	1,691	1,945	22.5
(6) Jhangi UC					
(i) Derawanda	10,738	119	1,278	1,470	17.0
(ii) Jhangi	5,415	119	644	741	8.6
(iii) Lama Maira	4,937	119	588	676	7.8
(iv) Banda Ghazan	4,016	119	478	550	6.4
(v) Banda Dalazak	6,195	119	737	848	9.8
(vi) Band Phugwarian	5,576	119	664	764	8.8
(Vii) Dobathar	14,728	119	1,753	2,016	23.3
Total	216,353		26,826	30,852	356.9

2-2-2-2 Allocation Plan for Surface Water and Groundwater

Based on the evaluation of potential yields from groundwater sources, the existing wells including springs, which can be utilized continuously in the future, will abstract 12,149 m³/day (140 liter/sec) as shown in Table 2-2-7. The daily maximum water demand in 2015 is projected to be 30,852 m³/day (357 liter/sec), and water deficit will be 18,703 m³/day (217 liter/sec).

The water deficit will be covered by the surface water system as well as groundwater systems in line with the following concept:

- Surface water intake amount should not exceed 200 liter/sec as agreed with the Pakistan side.
- The existing groundwater system should be utilized as much as possible. The balance between water demand and the available groundwater abstraction is covered by surface water.

The water deficit, 18,703 m³/day (217 liter/sec), will be covered by new wells with a capacity of 1,809 m³/day (21 liter/sec) and the surface water system with a capacity of 16,894 m³/day (196 liter/sec).

Table 2-2-7 Existing and Under-construction Wells Available for Future Supply

Wells and Springs	Average Abstraction (liter/sec)
- Wells by Earthquake Reconstruction Fund: 10 wells	60
- Nawansher Wells under construction: 2 wells	7
- Existing Wells : 17 wells (including 12 well rehabilitation)	68
- Spring : 1	5
Total	140

Table 2-2-8 shows the groundwater development plan including new wells.

Table 2-2-9 explains the distribution plan for groundwater and surface water in the service area.

The detailed explanation is shown in Appendix-7-2 Allocation Plan for Surface Water and Groundwater.

Table 2-2-8 Groundwater Development Plan including New Wells

Service Area	Well Name and Well No.	Status (Selected:◎)				Year 2004 B/D (pump replace: ◎)	2009 B/D Field Investigation				Abstraction Plan					
		Existing	New wells	New Wells by this B/D	Remarks		Pump Replace : ◎	To be abandoned : x	Daily abstraction (May 2009) (m³)	Max. abstraction (l/sec)	Evaluation (usable : ◎)	Safe Yield (l/sec)	Year 2004 B/D	Case 1	Case 2	Case 3
(1) Abbottabad TMA (urban)						suspend			1,189.4	13.8						
	Stoney Jheel No.1 (off-limits area)	◎(in operation)				suspend										
	Stoney Jheel No.2 (off-limits area)	◎(pump failure)				suspend			801.4	9.3						
	Stoney Jheel No.3 (off-limits area)	◎(in operation)				suspend			504.0	5.8						
	Stoney Jheel No.4 (off-limits area)	◎(in operation)				suspend										
	Nawansher No.1	abandoned						x	336.2	3.9						
	Nawansher No.3	◎(in operation)						x	560.2	6.5						
	Nawansher No.4	◎(in operation)						x	336.2	3.9	◎	3.9				
	Nawansher No.5	◎(in operation)						x	1,281.6	14.8						
	Nawansher No.6	◎(in operation)						x	957.6	11.1	◎	11.1			11.1	
	Nawansher No.7	◎(in operation)						x	280.1	3.2						
	Narrian No.6	◎(in operation)														
	Total	10	0	0					6,246.7	72.3		15.0	0	0	11.1	0
(2) Nawansher Service Unit (urban)																
	Nawansher No.1	◎(in operation)				Use			547.2	6.3	◎	6.3	6.3	6.3	6.3	6.3
	Nawansher No.2	◎(in operation)				Use			443.5	5.1	◎	5.1	5.1	5.1	5.1	5.1
	Nawansher No.3	◎(pump failure)				Use			806.4	9.3	◎	9.3	9.3	9.3	9.3	9.3
	Nawansher No.4	◎(in operation)				Use ◎	◎		1,010.9	11.7	◎	11.7	11.7	11.7	11.7	11.7
	Spring	◎(in operation)				Use			432.0	5.0	◎	5	5.0	5.0	5.0	5.0
	Nawansher (ADB1)	◎							3.5	◎	3.5	3.5	3.5	3.5	3.5	3.5
	Nawansher (ADB2)	◎							3.5	◎	3.5	3.5	3.5	3.5	3.5	3.5
	Total	5	2	0					3,240.0	44.4		44.4	37.4	44.4	44.4	44.4
(3) Sheikbul Bandi																
	Sheikbul Bandi No.2	abandoned														
	Sheikbul Bandi No.3	◎(in operation)				Use	◎		205.9	2.4	◎	2.4	2.4	2.4	2.4	2.4
	Sheikbul Bandi No.4	◎(in operation)				Use	◎		151.5	1.8	◎	1.8	1.8	1.8	1.8	1.8
	Sheikbul Bandi No.2	◎				Use			-	8.9	◎	8.9	8.9	8.9	8.9	8.9
	Total	2	1	0					357.4	13.1		13.1	4.2	13.1	13.1	13.1
(4) Salhad																
	Salhad No.1	◎(in operation)				Use ◎	◎		311.0	3.6	◎	3.6	3.6	3.6	3.6	3.6
	Salhad No.2	◎(in operation)				Use ◎	◎		219.0	2.5	◎	2.5	2.5	2.5	2.5	2.5
	Spring	◎(in operation)				abandon			-	4.2	◎	4.2	4.2	4.2	4.2	4.2
	Salhad No.3	◎							530.0	10.3		10.3	6.1	10.3	10.3	10.3
	Total	3	1	0												
(5) Mirpur																
	Mirpur No.1	◎(in operation)				Use			272.6	3.2	◎	3.2	3.2	3.2	3.2	3.2
	Spring	◎(in operation)				abandon			-	7.5	◎	7.5	7.5	7.5	7.5	7.5
	Mirpur No.2	◎(Pumping test done)							272.6	10.7		10.7	3.2	10.7	10.7	19.7
	Mirpur No.3 - No.5	◎(Case 3)							-							9.0
	Total	2	1	0		3			272.6	10.7		10.7	3.2	10.7	10.7	19.7
(6) Jhangi UC																
(i) Derawanda																
	Derawanda No.1	abandoned							0							
	Derawanda No.2	abandoned				Use ◎			0							
	Derawanda No.3	◎(in operation)				Use ◎	◎		159.3	1.8	◎	1.8	1.8	1.8	1.8	1.8
	Derawanda No.4	◎(Pumping test done)				Use			-	5.0	◎	5	5.0	5.0	5.0	5.0
	Derawanda No.5	◎							159.3	4.9	◎	4	4.0	4.0	4.0	4.0
	Sub-total	1	2	0					159.3	10.8		10.8	1.8	10.8	10.8	10.8
(ii) Jhangi																
	Jhangi No.1	◎(in operation)				Use ◎	◎		229.4	2.7	◎	2.7	2.7	2.7	2.7	2.7
	Jhangi No.2	◎(in operation)				Use ◎	◎		133.1	1.5	◎	1.5	1.5	1.5	1.5	1.5
	Jhangi No.3	◎(Pumping test done)				Use			-	6.6	◎	6.6	6.6	6.6	6.6	6.6
	Sub-total	2	1	0					362.5	10.8		10.8	4.2	10.8	10.8	10.8
(iii) Lama Maira																
	Lama Maira No.1	◎(in operation)				Use ◎		x	280.8	3.3		3.3				
	Lama Maira No.2	◎				Use			-	5.3	◎	5.3	5.3	5.3	5.3	5.3
	Sub-total	1	1	0					280.8	8.6		5.3	3.3	5.3	5.3	5.3
(iv) Banda Ghazan																
	Banda Ghazan No.1	◎(in operation)				Use ◎	◎		181.8	2.1	◎	2.1	2.1	2.1	2.1	2.1
	Banda Ghazan No.2	◎(Pumping test done)				Use			-	4.0	◎	4.0	4.0	4.0	4.0	4.0
	Sub-total	1	1	0					181.8	6.1		6.1	2.1	6.1	6.1	6.1
(v) Banda Delazak																
	Banda Delazak No.1	◎(in operation)				Use ◎	◎		233.6	2.7	◎	2.7	2.7	2.7	2.7	2.7
	Banda Delazak No.2	◎				Use			-	6.3	◎	6.3	6.3	6.3	6.3	6.3
	Sub-total	1	0						233.6	9.0		9.0	2.7	9.0	9.0	9.0
(vi) Banda Phugwarian																
	Banda Phugwarian No.2	abandoned							0							

Table 2-2-9 Distribution Plan for Groundwater and Surface Water in the Service Areas

Service Areas	Year 2015 Day Maximum Supply (m ³ /day)	Existing Groundwater Sources (m ³ /day)	Water Deficit (m ³ /day)	Newly Developed (m ³ /day)	
				Groundwater	Surface Water
Abbotabad City Total	11,469	959	10,510	0	10,510
Nawansher District	4,540	3,836	704	0	704
Abbotabad Province					
(a) Sheikhul Bandi	2,659	1,132	1,527	0	1,527
(b) Salhad	3,174	890	2,284	0	2,284
(c) Mirpur	1,945	924	1,021	0	1,021
(d) Jhangi					
(i) Derawanda	1,470	933	537	0	537
(ii) Jhangi	741	741	0	0	0
(iii) Lama Maira	676	458	218	0	218
(iv) Banda Ghazan	550	527	23	0	23
(v) Banda Dalazak	848	778	70	0	70
(vi) Band Phugwarian	764	764	0	0	0
(vii) Dobathar	2,016	207	1,809	1,809	0
Abottabad Province Total	14,843	7,354	7,489	1,809	5,680
Grand Total	30,852 (357 liter/sec)	12,149 (140 liter/sec)	18,703 (217 liter/sec)	1,809 (21 liter/sec)	16,894 (196 liter/sec)

2-2-2-3 Surface Water System

1) Intake Facilities

(i) Elevations of Intake Points

The intake points are sited at the elevations as shown below to enable gravity flow up to the proposed water treatment plant of which is at an elevation of approximately 1360m.

Intake River	Bagh River	Bandi River	Gaya River	Namly Mira River
Elevation of Intake Point	1429m	1428m	1422m	1626m

The elevation of Namly Mira River Intake Point is 1626m as there is an elevation of 1600m on the route of the raw water transmission mains.

(ii) Method of Intake

A bar screen intake type, which has screen in front of the intake mouth to avoid floating materials entering the intake, has been adopted. This design takes into consideration the intake volume of raw water and the surrounding conditions of the intakes, as this type can ensure stable intake by avoiding damage from upstream rockfalls.

2) Raw Water Transmission Mains

The raw water flow is set at 200 liter/sec, assuming that the water loss from treatment processes in the treatment plant is about 2.0 % of the total water supplied by the surface water system, ie 195.4 liter/sec.

(i) Raw Water Transmission Routes

The raw water transmission routes are shown in Figure 2-2-1. Each route is divided into several segments depending on the site conditions for pipe laying work.

- (a) At the sharp slopes along Bagh River, Gaya River and Namly Mira River
(segment: 1 to 2, 4 to 6, 5-1 to 5, 5-2 to 5, 5 to 6)
- (b) From the confluence of Bagh River and Gaya River to Muree Road where vehicles can not get access
(segment: 6 to 7)
- (c) Along the narrow road from Namly Mira River to Muree Road with several bends and 4m road width
(segment: 2 to 3)
- (d) Along Muree Road with sharp gradient and several bends, most of this route is rock
(segment: 3 to 7)
- (e) Along Muree Road near the foot of the Treatment Plant site with narrow road shoulders
(segment: 7 to 7b)
- (f) At the very sharp slope of the hill to the Treatment Plant
(segment: 7b to 8)

Table 2-2-10 shows the list of raw water transmission facilities.

Table 2-2-10 Pipe Diameters, Pipe Materials and Lengths of Pipelines for Raw Water Transmission Mains

Facilities	Route	Reference No.	Flow (liter/sec)	Specification	Quantity (m)
Raw Water Transmission Mains	From Namly Mira Intake to Namly Mira Bridge	1 to 2	52	Dia250, SP	1,560
	From Namly Mira Bridge to the connecting point with Muree Road	2 to 2a	52	Dia250, SP	1,460
		2a to 3	52	Dia200, SP	670
	From the connecting point with Muree Road to the connecting point with Bagh/Gaya raw water mains	3 to 7	52	Dia150, SP	1,780
	From Gaya Intake to the confluence with Bagh River	4 to 6	49	Dia200, SP	700
	From Bagh Intake to the confluence with Bandi River	5-1 to 5	54	Dia250, SP	930
	From Bandi Intake to the confluence with Bagh River	5-2 to 5	45	Dia150, SP	240
	From the confluence with Bagh River and the Bandi River to the confluence with the Bagh River and Gaya River	5 to 6	99	Dia250, SP	500
	From the confluence with the Bagh River and Gaya River to the connecting point with the raw water main from Namly Mira	6 to 7	148	Dia350, DIP	1,750
	From the connecting point with the raw water mains from Bagh/Gaya and Namly Mira to the water treatment plant (along the Muree Road)	7 to 7a	200	Dia450, DIP	6,130
		7a to 8	200	Dia500, DIP	4,680

	Total length of raw water transmission main				20,400
Pressure Releasing Chambers		①, ②, ③		RC Structure	3 sets

As the elevation at the Namly Mira Intake is as high as 1626m it is necessary to control the static water pressure in the raw water transmission main. For this purpose, pressure releasing chambers are to be constructed at the locations No. ①, ②, ③ in Figure 2-2-1. The elevations of these chambers are approximately, 1550m, 1400m and 1370m, respectively. Setting free water tables in these chambers allows for raw water transmission at the maximum water pressure of 2.5 MPa (25 kg/cm²).

(ii) Selection of Pipe Material

Due to the topographic features of the raw water transmission route such as fluctuating elevations and the surrounding natural conditions of Muree Road where the raw water trunk main runs (dia. $\geq 350\text{mm}$), it is recommended to select pipe materials which have strong resistance to high internal water pressure and external shock load. In this regard, Ductile Cast Iron Pipe (DIP) and Steel Pipe (SP) are both advantageous. However, SP requires skillful welding work for the pipe connections, and extra excavation in the trench is necessary for welding work. Furthermore, welded parts must be tested and treated to prevent possible leakage and corrosion. SP requires a relatively longer pipe laying timeframe when compared with DIP, and is inferior to DIP in ease of the pipe laying work. Accordingly, DIP has been adopted for the raw water trunk main ($\geq 350\text{mm}$).

The smaller diameter pipes $\leq 250\text{mm}$ are installed where the internal pressure is not high, and locally produced steel pipes are utilized. Accordingly, SP has been adopted for the smaller diameter pipes ($\leq 250\text{mm}$).




Figure 2-2-1 Location of Intakes, Raw Water Transmission Mains, Pressure Releaseing Chambers, Water Treatment Plant

3) Water Treatment Plant

Raw water turbidity is usually low, but tends to increase sharply for a certain period following rainfall. Raw water quality meets the criteria of the NSDWG, with the exception of coliform bacteria.

Taking into account the result of raw water quality analysis mentioned above and the result of continuous measurement of raw water turbidity carried out on the basic design survey in 2004, the following treatment processes are required.

① Sedimentation Basin (Raw Water Reservoir) → ② Roughing Filter → ③ Slow Sand Filter
→ ④ Chlorination → ⑤ Clear Water Reservoir

(i) Sedimentation Basin

It is assumed that extremely high raw water turbidity may occur several times a year. During these periods of high turbidity the treatment plant should suspend operations. Sedimentation basins are planned to avoid this highly turbid water entering into the subsequent treatment processes, by retaining inflow so that the operator can take necessary action against the high turbidity. In practical terms, a certain period of time is necessary for the operators to judge whether to stop the operation (by closing a stop valve upstream of the sedimentation basin) after analyzing the turbidity. Considering this requirement, the retention time of the sedimentation basin is set at two hours. Desludging from the basin is designed to be via manual scraping after emptying the basin.

(ii) Roughing Filter

The filter run period of slow sand filters is severely limited by the increase in raw water turbidity after rainfall. In order to alleviate the turbidity load in the slow sand filters, roughing filters are introduced to reduce raw water turbidity by 50%. There are three types of roughing filters, namely horizontal flow, downflow and upflow. Horizontal flow is of simpler structure but requires a lower flow rate. The upflow type can achieve the highest filtration rate and the downflow type is designed for medium flow rate.

The upflow type is adopted in this project as it can obtain a higher filtration rate and filter media washing is easier. A filtration rate of 1.5 m/hr (36m/day) has been adopted.

(iii) Slow Sand Filter

Slow sand filters are commonly designed to have a filtration rate of 4 to 5m/day. If raw water turbidity is consistently low, a filtration rate of 8m/day can sometimes be applied. The raw water turbidity, however, must be reduced by roughing filters if the filtration rate of the slow sand filters is to be set at 5m/day. The filter media are sand and gravel which are locally available.

(iv) Clear Water Reservoir

The clear water reservoir is designed to provide constant and stable water transmission to the service areas and to maintain the transmission during periods when the raw water intake is suspended. According to the results of continuous measurement of raw water turbidity, the storage duration necessary if raw water inflow into the plant is cut off in an emergency is approximately six hours. Such cases, however, may happen only a few times a year. It is considered very conservative to have a full capacity of six hours. The capacity is designed at three hours, which is sufficient to maintain stable and constant transmission and provide effective chlorine contact time for disinfection.

(v) Disinfection Facilities

The existing water supply systems have no disinfection facilities, as water from deep wells is generally free from pathogenic contamination. However, the surface water sources are exposed to such contamination risk and disinfection processes are necessary to ensure the bacteriological

safety of water supply.

Considering the lack of experience in chlorination, chlorination using calcium hypochlorite is recommended, as liquid gas chlorine requires more careful handling and strict control of operations. Calcium hypochlorite is applied as a solution via gravity flow feeders at the clear water reservoir. The designed dosing rate for effective chlorine, considering the distance to consumers, is maximum 2mg/l.

(vi) Other Facilities

Water supply facilities are necessary to supply water used in the plant and in the preparation of chlorine solution. An Operation Building will be constructed to facilitate the operation and maintenance of the facilities. The Building accommodates the plant management room, office, a meeting room, laboratory, store, library, kitchen, and lavatories.

(vii) Operation & Maintenance Road

In addition to the daily operations at the plant, periodical access by vehicles is necessary to supply calcium hypochlorite and filter media to the plant. Also if valves or pipes require repair, heavy vehicles will need access to the plant. For these purposes, a paved operation and maintenance road of 5m width is required to connect the nearest public road to the plant.

The general features of major facilities of the water treatment plant are presented in Table 2-2-11.

Table 2-2-11 Major Features of the Water Treatment Plant

1	Treatment Capacity		$Q=17,280 \text{ m}^3/\text{day}$ (200 liter/sec)
2	Sedimentation Basin		
	Type	Rectangular Horizontal Flow Plain Sedimentation	
	No. Of Basin	N =	2 basins
	Retention Time	T =	2 hours
	Volume	V =	1,460 m^3
	Dimension	W 12 m x L 24 m x D (effective) 2.5 m x 2 basins	
	Miscellaneous	Inlet Pipe	Dia 400 mm
		Perforated Walls	1 unit
		Effluent Weir	1 unit
		Drain Valve (Dia 150mm)	1 unit/basin
		Drain Pipe (Dia 200mm)	1 unit
		Washing Pump and Piping	1 unit
3	Roughing Filter		
	Type	Upflow	
	No. of Basin	N =	12 basins
	Filtration Rate	V =	36 m/day (1.5 m/hr)
	Dimension	W 6.6 m x L 6.1 m x D (effective) 1.3 m x 12 filters	
	Filter Gravel	3 layers	Dia 16 to 24 mm x D 50 cm
			Dia 12 to 18 mm x D 30 cm
			Dia 8 to 12 mm x D 20 cm
	Underdrain System	RC Perforated Slab	
	Wash System Piping	Flow Rate	60 cm/min
		Inlet Main	Dia 350 mm
		Inlet Lateral	Dia 150 mm
		Outlet Main	Dia 300 mm

		Outlet Lateral	Dia 150 mm
		Washwater Main	Dia 600 mm
		Washwater Drain Lateral	Dia 400 mm
Miscellaneous	Outlet Weir	2	
	Washwater Weir	1	
	Washwater Tank	150 m ³	
4	Slow Sand Filter		
	Type	Constant Water Level at Inlet (Stop Log)	
	No. Of Filter	N =	6filters (Standby 1 filter)
	Filtration Rate	V =	5 m/day (0.2 m/hr)
	Dimension	W 16 m x L 43.5 m x D (effective) 2.35 m x 6 filters	
	Filter Sand	Effective Dia.	Dia 0.4 mm
		Uniformity Coefficient	2.0 at maximum
		Thickness	90 cm
	Filter Gravel	4Layers	Dia 60 mm x D 15 cm
			Dia 20 to 30 mm x D 10 cm
			Dia 10 to 20 mm x D 10 cm
			Dia 3 to 4 mm x D10 cm
	Underdrain System	Main	W 0.6 m x H0.3 m Concrete Block
		Lateral	Dia 100 mm Perforated Pipe (PVC)
	Piping	Inlet	Dia 200 mm
		Outlet	Dia 350 mm
		Backflow	Dia 150 mm
		Drain (Outlet Channel)	Dia 100 mm
	Miscellaneous	Inlet Weir	1unit
		Outlet Weir	1unit
		Sand Washer	1unit
5	Clear Water Reservoir		
	No. Of Basin	N =	2 basins
	Retention Time	T =	3 hours
	Volume	V =	2,148 m ³
	Dimension	W 16.5 m x L 21.7 m x D (effective) 3 m x 2 basins	
	Piping	Inlet	Dia 350 mm
		Outlet	Dia 350 mm
		Overflow	Dia 300 mm
		Drain	Dia 150 mm
6	Disinfection Facilities		
	Disinfectant	Calcium Hypochlorite	
	Dosage Rate	Maximum	2 mg/liter
		Average	1 mg/liter
	Dosing Method	Gravity Feeder	
	Dosing Point	Inlet at Clear Water Reservoir	
	Solution Tank	No. of Tank	2 unit (standby 1 unit)
		Volume	3 m ³
	Doser		2 unit (standby 1 unit)
7	Operation Building		
	Structure	RC W 12 m x L 18 m	216 m ²
		Enterance Hall	18 m ²

		Plant Manager Room	18 m ²
		Office	56 m ²
		Meeting Room	30 m ²
		Water Quality Laboratory	9 m ²
		Store/Library	22 m ²
		Kitchen/Lavatory/Corridor, etc	63 m ²
8	Water Supply and Sanitation		
	Water Tank	FRP	1 m ³
	Water supply Pump	75 liter/min	2 unit (standby 1 unit)
	Septic Tank	20 person cap.	1 unit
9	Yard Piping		
	Raw Water Inlet Pipe		Dia 500 mm
	Raw Water Flow Meter (Vane Type)		Dia 400 mm
	Interconnection from Sedimentation Basin to Roughing Filter		Dia 400 mm to 350 mm
	Interconnection from Roughing Filter to Slow Sand Filter		Dia 450 mm to 200 mm
	Interconnection from Slow Sand Filter to Clear Water Reservoir		Dia 350 mm
	Clear Water Transmission		Dia 500 mm
	Clear Water Transmission Flow Meter (Vane Type)		Dia 400 mm
10	Landscaping		
	Road		1,600 m ²
	Stone Masonry	H = 1.0 to 5.0 m	530 m
	Fence		475 m

4) Treated Water Transmission Mains

The total treated water transmission volume is planned to be 195.4 liter/sec in accordance with the result of the water demand predictions. Table 2-2-12 shows the supply volume to each service area.

Table 2-2-12 Treated Water Transmission to Service Areas

Service Area	Supply (liter/sec)	Facilities to Receive the Supply
Abbottabad City*1 (Total)	121.6	
Aram Bagh System	43.8	Connected to Existing Transmission Pipe to Existing Khola Kehal Reservoir
Kunj System	29.2	Connected to Existing Transmission Pipe to Kunj GadeemReservoir
Jinnah System	48.6	Connected to Existing Transmission Pipe to Jail Reservoirs
Nawansher City	8.1	Supplied to New Reservoir to be constructed
Abbottabad Prefecture (Total)	65.7	
Sheikuhlbandi U.C.	17.7	Supplied to New Reservoir adjacent to Existing Reservoir
Salhad U.C.	26.4	Supplied to New Reservoir
Mirpur U.C.	11.8	Supplied to New Reservoir to be constructed adjacent to Existing Reservoir
Jhangi U.C. (Total)	9.8	
Derawanda	6.2	Supplied to New Reservoir to be constructed adjacent to Existing Reservoir

Jhangi, Lama Maira, Banda Gazan, Banda Dilazak	3.6	Supplied to New Reservoir to be constructed adjacent to Existing Reservoir
Grand Total	195.4	

Note : *1 Distribution to the three systems in Abbottabad City is determined by proportions of the existing reservoir capacities.

(i) Treated Water Transmission Routes for Surface Water System

The Treated Water Transmission System for the Surface Water Gravity System is divided into two routes as shown in Figure 2-2-2.

(a) Abbottabad – Salhad Route

The transmission main will be laid along the sharp hill slope from the treatment plant and takes the western route after meeting Murree Road. Then, it branches towards New Sheikulbandi Reservoir and goes along Shinar/Link Road. It will be connected to the existing transmission pipes at Aram Bagh Booster Pump Station and Kunj Booster Pump Station. After meeting Kala Kolum Highway (KKH) it divides further into two directions - one to Jinnah Booster Pumping Station and the other to the new and existing Salhad Reservoirs. The pipes to Salhad are installed along KKH, which is a national highway.

(b) Nawansher – Mirpur Route

The transmission pipeline to this route branches from the transmission main at Murree Road. It goes through Nawansher City and then reaches KKH via PMA Road. After that it is divided into the northern direction and southern direction. The former will be extended through KKH to New Mirpur Reservoir and will also branch to New Derawanda Reservoir. The latter will be laid along KKH to supply water for New Banda Gazan Reservoir.

(ii) Diameters, Pipe Materials and Pipeline Lengths of Treated Water Transmission Main

Table 2-2-13 tabulates the diameter, pipe material and length of each pipeline to be newly installed for the surface water system.




Figure 2-2-2 Location of Treated Water Transmission Main, Tubewells and Reservoirs

Table 2-2-13 Diameters, Pipe Materials, Lengths of Pipelines for Treated Water Transmission Mains (Surface Water System)

Pipeline Route	Reference No. in Fig. 2-2-3	Flow (liter/sec)	Diameter, Pipe Material	Quantity (m)
1. Salhad Direction				
Water Treatment Plant – Connection with Muree Road	0 to 1	195.4	Dia 500, DIP	2,320
Connection with Muree Road – Branch Point to Sheikhl Bandi Reservoir	1 to 2	165.7	Dia 400, DIP	670
Branch Point to Sheikhl Bandi Reservoir – Branch Point to Aram Bagh Booster Pump Station	2 to 3-1	148.0	Dia 400, DIP	1,440
Branch Point to Aram Bagh Booster Pump Station – Aram Bagh Booster Pump Station	3-1 to 3a	43.8	Dia 150, SP	200
Branch Point to Aram Bagh Booster Pump Station – Branch Point to Kunj Booster Pump Station	3-1 to 3-2	104.2	Dia 300, DIP	1,120
Branch Point to Kunj Booster Pump Station – Kunj Booster Pump Station	3-2 to 3b	29.2	Dia 200, SP	30
Branch Point to Kunj Booster Pump Station – Connection with KKH	3-2 to 4	75.0	Dia 300, DIP	300
Connection with KKH – Jinnah Booster Pump Station	4 to 3-3	48.6	Dia 200, SP	230
Connection with KKH – Branch Point to New Salhad Reservoir	4 to 5-1	26.4	Dia 200, SP	1,800
Branch Point to New Salhad Reservoir – New Salhad Reservoir	5-1 to 5a	13.2	Dia 150, SP	240
Branch Point to New Salhad Reservoir – Connecting Point with the Existing pipe	5-1 to 5-2	13.2	Dia 150, SP	660
Sub Total				9,010
2. Nawansher Direction				
Connection with Water Treatment Plant and Muree Road – Crossing with PMA Road	1 to 6-1	29.7	Dia 200, SP	1,650
Crossing with PMA Road - Branch Point to New Nawansher Reservoir	6-1 to 6-3	8.1	Dia 150, SP	850
Branch Point to New Nawansher Reservoir - New Nawansher Reservoir	6-3 to 6a	4.9	Dia 150, SP	740
Branch Point to New Nawansher Reservoir – Existing Mira Reservoir	6-3 to 6b	2.4	Dia 100, SP	230
Sub Total				3,470
3. Mirpur / Derawanda Direction				
Crossing with PMA Road – Connection with KKH	6-1 to 7	21.6	Dia 200, SP	5,710
Connection with KKH - Branch Point to New Derawanda Reservoir	7 to 8	18.0	Dia 200, SP	180
Branch Point to New Derawanda Reservoir - New Derawanda Reservoir	8 to 8a	6.2	Dia 150, SP	1,640
Branch Point to New Derawanda Reservoir - Branch Point to New Mirpur Reservoir	8 to 9	11.8	Dia 150, SP	750
Branch Point to New Mirpur Reservoir - New Mirpur Reservoir	9 to 9a	11.8	Dia 150, SP	1,520
Sub Total				9,800
4. Banda Gazan Direction				
Connection with KKH - Branch Point to New Banda Gazan Reservoir	7 to 10	3.6	Dia 100, SP	2,090
Branch Point to New Banda Gazan Reservoir - New Banda Gazan Reservoir	10 to 10a	3.6	Dia 100, SP	1,270
Sub Total				3,360
Grand Total				25,640

New treated water transmission pipelines will be connected to the existing transmission pipes when water is supplied to the existing reservoirs. Where water is supplied to new reservoirs, new pipelines will also be extended to these reservoirs.

(iii) Flow Control Facilities

In order to control the inflow into the reservoirs water level control valves will be installed at the reservoirs listed in Table 2-2-14.

Table 2-2-14 Existing and New Reservoirs Requiring Water Level Control Valves and Flowmeters

Supply System	Name of Reservoir	Existing/New	Capacity	Diameter of Inlet Pipe (mm)
Kehal System	Khola Kehal New	Existing	100,000GLS	300
Kunj System	Kunj Qadeem New	Existing	100,000GLS	150
	Kunj Qadeem Old	Existing	30,000GLS	150
	Banda Sapan	Existing	50,000GLS	150
Jannah-Jail System	Jail Old	Existing	200,000GLS	200
	Jail New	Existing	100,000GLS	200
Nawansher	Mira	Existing	50,000GLS	100
	New	New	340m ³	150
Salhad	Tank No.1	Existing	50,000GLS	150
	New	New	180m ³	150
Mirpur	New	New	350m ³	150
Sheikhul Bandi	New	New	130m ³	100
Derawanda	New	New	220m ³	150
Banda Gazan	New	New	100m ³	100

2-2-2-4 Groundwater system

1) Replacement of Existing Well Pumps

Needs of replacement of existing well pumps was decided taking into consideration as the blow;

- (1) The year of installation and degree of wearing of pumps,
- (2) The present operating conditions of pumps in comparison with the pump rating; for example, if the operation of pumps does not follow the rating, the pump head originally designed does not meet the actual situation due to change of tubewell operating water level, or the capacity of pumps has varied from the original design due to wear of pump impellers, etc., and
- (3) The matching of appropriate pumping discharge and pump rating; in other words, the excessive pumping rate is supposed if the pump rating exceeds the tubewell capability, and on the other hand, inefficient operation cannot be avoided if the pump rating is low comparing with the tubewell capability.

Among the existing 17 wells that will be available in the future, 12 wells are judged to be replaced as listed in Table 2-2-15. Prior to the replacement of these pumps, tubewell cleaning and simplified pumping test should be conducted. The water level for proper pump operation is confirmed by them. The appropriate pump specifications shall be decided.

Furthermore, it is necessary to add the following functions to ensure proper monitoring and operation of tubewells.

- (1) A guide pipe for inserting a water level meter should be installed in the casing for periodic monitoring of the water level in the tubewell.
- (2) A limit switch and water level meter should be provided to stop the pump operation in the case of abnormal drawdown of water level happens, for the protection of the pump.
- (3) Flow meter should be provided to monitor proper abstraction.

Table 2-2-15 List of Tubewells in Need of Pump Replacement

	Service Area	Well No.	Conditions of Pump	Type of Pump (*)	Year of installation
1	Derawanda	No. 3	Pump repairs twice since 2005	V	1995
2	Jhangi	No. 1	Repairs 4 times since 2005, aged	S	1979
3	Jhangi	No. 2	Repairs twice since 2005, aged	V	1992
4	Banda Phugwarian	No. 3	Was replaced with another one at Well No. 2A. Repairs 9 times, aged.	S	1996
5	Dobathar	No. 1	Repaired twice since 2005, aged	S	1986
6	Banda Dilazak	No. 1	Repaired twice since 2005, aged	S	1988
7	Banda Ghazan	No. 1	Repair once since 2005, discharge low	S	1988
8	Salhad	No. 1	Repaired 6 times since 2005, aged	S	1995
9	Salhad	No. 2	Repaired 4 times since 2005, aged	S	1996
10	Nawansher	No. 4	Repaired 3 times since 2005, aged	S	1998
11	Sheikhul Bandi	No. 3	Repaired 3 times since 2005, aged	S	1995
12	Sheikhul Bandi	No. 4	Repaired 4 times since 2005, aged	S	1995

Remark: Type of pump "V"= Vertical shaft pump, "S"=Submersible motor pump

2) New Tubewell Construction

The surface water system can not provide the water supply to Dobatar, as this area is at a higher elevation than the gravity flow can reach. New tubewell construction is necessary to satisfy the water demand in this area. According to the demand projection, an additional 21 liter/sec of groundwater exploitation is necessary. The new tubewell location is decided based on the following criteria;

- (1) The tubewell location should be close to the water service area.
- (2) Sufficient discharge is secured.
- (3) Tubewell construction is allowed and practically possible. (500m should be maintained in distance between any two tubewells)

Tubewell construction sites were selected at the eastern side of Karakoram highways as shown in Figure 2-2-2. These new tubewells are located at artesian field in Abbottabad basin, and specific discharge is estimated at 100 to 300 m³/day/m. The existing tubewells constructed in such places where high specific discharge is expected are being used to abstract high yields such as 10 to 20 liter/sec. However such discharge may cause caving. Accordingly it is proposed to maintain the lower yield, approximately 6 liter/sec, from each new tubewell constructed in the Project in order to prevent caving and achieve sustainable tubewell utilization.

To consider the water demand and pumping discharge per one tubewell, four new tubewells are required.

3) Transmission Pipelines from Groundwater

Groundwater discharged from four new tubewells is transmitted to the reservoir that the surface water system can not feed water. To connect four new tubewells, the transmission pipelines are to be renewed as shown in table 2-2-16.

Table 2-2-16 List of New Transmission Pipelines for Groundwater System

Route	Reference No. in Fig	Flow (liter/sec)	Diameter & type of pipe materials	Length (m)
Dobathar system				
New Tubewell No. 2~No. 3	11~12	6.0	φ100, SP	500
New Tubewell No. 3 ~ Connecting Pointwith Pipeline from New Tubewell No. 4	12~13-1	12.0	φ150, SP	710
New tubewell No. 4 ~ Connecting Pointwith Pipeline from New Tubewell No. 3	13~13-1	2.9	φ100, SP	300
Connecting Pointwith Pipeline from New Tubewell No. 3 & No. 4~ Connecting Pointwith Pipeline from New Tubewell No. 5	13-1~15	14.9	φ150, SP	130
New Tubewell No. 5 ~ Connecting Pointwith Pipeline from New Tubewell No. 2, No. 3 & No. 4	14~15	6.0	φ100, SP	470
Connecting Pointwith Pipeline from New Tubewell No. 2, No. 3, No. 4 & No. 5~Connecting point to existing pipeline	15~16	20.9	φ150, SP	1,510
Total Length of Transmission Pipelines for groundwater system				3,620

2-2-2-5 Locations and Capacities of New Distribution Reservoirs

The needs for a new distribution reservoir in each service area has been evaluated based on the following conditions. New reservoirs are planned where the capacities of the existing reservoirs are insufficient to meet projected water demands in 2015.

- (a) Required reservoir capacity is 4 hours based on the maximum daily water demand
- (b) The present transmission flows, such as adequate pumping capacity from the existing wells to the existing reservoirs, are adjusted.
- (c) The balance between the future water demand for each water supply area and the intake water capacity from the existing wells is covered by supply from the new surface water system
- (d) Existing Reservoirs and water sources are used as much as possible.
- (e) Principally the new surface water system supplies only the new reservoirs. Supply from the new surface water system to the existing reservoirs is only allowed when the above configuration can not balance the water demand and supply.

The results of the above analysis shows that nine reservoirs need to be constructed as listed in Table 2-2-17. The structure of new reservoirs is an RC structure.

Table 2-2-17 List of New Distribution Reservoirs to be constructed

System	Type of Water Sources	Capacity (m ³)
Sheikuhlbandi	Surface Water	130
Salhad	Surface Water	180
Nawansher	Surface Water	340
Mirpur	Surface Water	350
Derawanda	Surface Water	220
Banda Gazan	Surface Water	100
Dobatar	Groundwater	300

Figures 2-2-3 to 2-2-13 explain conceptually the modifications of water transmission and distribution in each system.




Figure 2-2-3 Abbottabad City Water Supply Scheme (Aram Bagh System)

Aram Bagh System of Abbottabad City Water Supply Scheme consists of lifting water from wells (Nawansher No.6 and No.7) at Nawansher field, transmitting to Aram Bagh reservoir, boosting to Khola Kehal Newreservoir, and distributing from the reservoir.

Nawansher No.6 of the existing wells is evaluated as to be renewed.

Improvement plan is to connect the surface water transmission pipe with the discharging pipes of the booster pump while utilizing the existing well Nawansher No.7 which pump is not necessary renewal. To fulfill the designed daily maximum water demand in the system at 47.8 l/s, the system is provided with surface water at 36.7 l/s plus ground water at 11.1 l/s. In practice, for 24 hours distribution will be made by ground water for 5.6 hours and by surface water for 18.4 hours.




Figure 2-2-4 Abbottabad City Water Supply Scheme (Kunj System)

Kunj System of Abbottabad City Water Supply Scheme consists of lifting water from wells (Nawansher No.3, No.4, and No.5) at Nawansher field and a well (Narian No.6) at Narian field, transmitting to Kunj Ground Old-2 reservoir, boosting to three reservoirs as Kunj Qadeem New, Kunj Qadeem Old, Banda Sapan, and distributing from the reservoirs.

Nawansher No.3, No.4 and Narian No.6 of the existing wells are evaluated as to be abandoned due to decrepit well itself. Pump of Nawansher No.5 is evaluated as to be renewed.

Improvement plan is to abandon the all wells and to connect the surface water transmission pipe with the discharging pipes of the booster pump. To fulfill the designed daily maximum water demand in the system at 31.8 l/s, the system is provided with surface water at 31.8 l/s.




Figure 2-2-5 Abbottabad City Water Supply Scheme (Jinnah System)

Jinnah System of Abbottabad City Water Supply Scheme consists of lifting water from wells (Stoney Jheel No.1, No.3, and No.4) at Stoney Jheel field, transmitting to Jinnah Bagh reservoir, boosting to two reservoirs as Jail New and Jail Old and distributing from the reservoirs.

The existing wells are located in Cantonment area where renewal works for pumps will not be able to be implemented since the site is in restricted area. While the previous study conducted in 2004 evaluated as to be abandoned due to decrepit well itself, all wells are to be abandoned.

Improvement plan is to abandon the all wells and to connect the surface water transmission pipe with the discharging pipes of the booster pump. To fulfill the designed daily maximum water demand in the system at 53.1 l/s, the system is provided with surface water at 53.1 l/s.




Figure 2-2-6 Nawansher Water Supply Scheme

Nawansher Water Supply Scheme consists of lifting water from wells (Nawansher No.1, No.2, No.3, and No.4) at Nawansher field and a spring located at southeast of the area, transmitting to five reservoirs, and distributing from the reservoirs.

Nawansher No.4 of the existing wells is evaluated as to be renewed. Two wells and two reservoirs are under construction by ADB fund. The elevated tank located in the commercial area leaks water caused due to the 2005 earthquake.

The proposed improvement plan is to intake all of the existing wells (Nawansher No.1, No.2, and No.3) and a spring. Thus, Nawansher No.4 pump is necessary to be renewed. New two wells under construction are also utilized. The surface water transmission pipe is to be connected to the existing reservoirs and to new proposed reservoir.

To fulfill the designed daily maximum water demand in the system at 52.5 l/s, the system is provided with ground water at 44.4 l/s plus surface water at 8.1 l/s. The amount of surface water is allocated 0.8 l/s to the elevated tank, 2.4 l/s to the existing reservoir and 4.9 l/s to the proposed reservoir. The proposed new reservoir is to distribute surface water to surrounding area of the built up area since new two wells and reservoirs under construction funded by ADB are planned to supply water to the center and the built up area.




Figure 2-2-7 Abbottabad District Water Supply Scheme (Sheikhul Bandi System)

Sheikhul Bandi Water Supply System of Abbottabad District Water Supply Scheme consists of lifting water from wells (Sheikhul Bandi No.3, No.4, and new No.2 constructed with the earthquake recovery fund) at Sheikhul Bandi area, transmitting to three reservoirs (No.1 and No.3, and new reservoir constructed with the earthquake recovery fund as No.2) and distributing from the reservoirs.

The proposed improvement plan is to intake all of the existing wells (Sheikhul Bandi No.3, No.4, and No.2) . However, Sheikhul Bandi No.3 and No.4 pumps are necessary to be renewed. The surface water transmission pipe is to be connected to the existing inlet pipes to existing reservoirs No.3. The proposed reservoir and the No.3 reservoir are to be connected. The both reservoirs are used for surface water supply.

To fulfill the designed daily maximum water demand in the system at 30.8 l/s, the system is provided with ground water at 13.1 l/s plus surface water at 17.7 l/s.




Figure 2-2-8 Abbottabad District Water Supply Scheme (Salhad System)

Salhad Water Supply System of Abbottabad District Water Supply Scheme consists of lifting water from wells (Salhad No.1 and No.2) at Sheikhul Bandi area and a spring having deterioration of water quality, transmitting to three reservoirs (No.1, No.2, and No.3), and new reservoir constructed with the earthquake recovery fund as No.2) and distributing from the reservoirs.

The proposed improvement plan is to intake all of the existing wells (Salhad No.1 and No.2) and new well under construction with the earthquake recovery fund. However, Salhad No.1 and No.2 pumps are necessary to be renewed. New well under construction is also utilized as Salhad No.3. The surface water transmission pipe is to be connected to the proposed reservoir. To fulfill the designed daily maximum water demand in the system at 36.7 l/s, the system is provided with ground water at 10.3 l/s plus surface water at 26.4 l/s.




Figure 2-2-9 Abbottabad District Water Supply Scheme (Mirpur System)

Mirpur Water Supply System of Abbottabad District Water Supply Scheme consists of lifting water from a well (Mirpur No.1) at Mirpur area and a spring having deterioration of water quality, transmitting to two reservoirs (No.1 and No.2), and distributing from the reservoirs.

The proposed improvement plan is to utilize the existing well (Mirpur No.1) and a new well (Mirpur No.2) under

construction with the earthquake recovery fund. The surface water transmission pipe is to be connected to the proposed new tank. The spring is to be abandoned.

To fulfill the designed daily maximum water demand in the system at 22.5 l/s, the system is provided with ground water at 10.7 l/s plus surface water at 11.8 l/s.




Figure 2-2-10 Abbottabad District Water Supply Scheme (Derawanda System)

Derawanda Water Supply System of Abbottabad District Water Supply Scheme consists of lifting water from a well at Derawanda area (Derawanda No.3), and transmitting to two reservoirs (No.1 and No.2), and distributing from the reservoirs. However, Derawanda No.3 pump is necessary to be renewed

The proposed improvement plan is to utilize the existing well (Derawanda No.3) and two new wells (Derawanda No.4 and No.5) under construction with the earthquake recovery fund. The surface water transmission pipe is to be connected to the proposed new tank.

To fulfill the designed daily maximum water demand in the system at 17.0 l/s, the system is provided with ground water at 10.8 l/s plus surface water at 6.2 l/s.




Figure 2-2-11 Abbottabad District Water Supply Scheme at Jhangi UC.

Abbottabad District Water Supply Scheme at Jhangi UC consists of seven independent water supply systems as Derawanda, Banda Dilazak, Banda Gazan, Lama Maira, Jhangi, Banda Phugwarian, and Dobather. Among the seven systems, the four systems (Banda Dilazak, Banda Gazan, Lama Maira, Jhangi) are adjacent while Banda Phugwarian and Dobather systems are supplying to higher ground elevation than the four and Derawanda system is located apart from the four. The four systems should be consolidated for effective facilities utilization in future.

(1) Banda Dilazak District

Banda Dilazak Water Supply System of Abbottabad District Water Supply Scheme consists of lifting water from two wells (Banda Dilazak No.2 and new No.3 constructed with the earthquake recovery fund) at Banda Dilazak area, transmitting to a reservoir (No.1), and distributing from the reservoir. However, Banda Dilazak No.2 pump is necessary to be renewed

The proposed improvement plan is to utilize the existing wells (Banda Dilazak No.2 and No.3) in order to fulfill the designed daily maximum water demand.

To fulfill the designed daily maximum water demand in the system at 9.8 ℓ/s, the system is provided with ground water at 9.0 ℓ/s plus surface water at 0.8 ℓ/s. The amount of surface water flow should receive from Banda Gazan system to have surface water input.

(2) Banda Gazan District

Banda Gazan Water Supply System of Abbottabad District Water Supply Scheme consists of lifting water from a well (Banda Gazan No.1) at Banda Gazan area, transmitting to a reservoir (Banda Gazan No.2), and distributing from the reservoir. However, Banda Gazan No.1 pump is necessary to be renewed

The proposed improvement plan is to utilize the existing well (Banda Gazan No.1) and a new Banda Gazan No.2 under construction with the earthquake recovery fund and to receive surface water in order to fulfill the designed daily maximum water demand. The surface water transmission pipe is to be connected to the proposed new tank.

To fulfill the designed daily maximum water demand in the system at 6.4 ℓ/s, the system is provided with ground water at 6.1 ℓ/s plus surface water at 0.3 ℓ/s. The new reservoir for surface water at Banda Gazan is located at the center of the four water supply systems as mentioned above. The distribution pipes of the four systems should be interconnected for accommodation of water in future.

(3) Lama Maira District

Lama Maira Water Supply System of Abbottabad District Water Supply Scheme consists of lifting water from a well (Lama Maira No.1) at Lama Maira area, transmitting to a new reservoir (Lama Maira No.1) constructed with the earthquake recovery fund, and distributing from the reservoir.

The proposed improvement plan is to utilize the new well (Lama Maira No.2) under construction with the earthquake recovery fund. The existing Lama Maira No.1 is to be abandoned due to decrepit well itself.

To fulfill the designed daily maximum water demand in the system at 7.8 ℓ/s, the system is provided with ground water at 5.3 ℓ/s plus surface water at 2.5 ℓ/s. The amount of surface water flow should receive from Banda Gazan system to have surface water input.

(4) Jhangi District

Jhangi Water Supply System of Abbottabad District Water Supply Scheme consists of lifting water from wells (Jhangi No.1 and No.2) at Jhangi area, transmitting to two reservoirs (Jhangi No.1 and No.2), and distributing from the reservoir.

The proposed improvement plan is to utilize the all existing wells (Jhangi No.1 and No.2) by renewal of the pumps plus Jhangi No.3 under construction with the earthquake recovery fund.

To fulfill the designed daily maximum water demand in the system at 8.6 l/s, the system is provided with ground water at 8.6 l/s.




Figure 2-2-12 Abbottabad District Water Supply Scheme (Banda Phugwarian System)

Banda Phugwarian Water Supply System of Abbottabad District Water Supply Scheme consists of lifting water from a well (Banda Phugwarian No.3) , transmitting to two reservoirs (Banda Phugwarian No.1 and No.2), and distributing from the reservoirs.

The proposed improvement plan is to utilize the existing well (Banda Phugwarian No.3) by renewal of the pumps plus Banda Phugwarian No.4 under construction with the earthquake recovery fund.

To fulfill the designed daily maximum water demand in the system at 8.8 l/s, the system is provided with ground water at 8.8 l/s.




Figure 2-2-13 Abbottabad District Water Supply Scheme (Dobather System)

Dobather Water Supply System of Abbottabad District Water Supply Scheme consists of lifting water from a well (Doabther No.1) , transmitting to a reservoir (Doabther No.1), and distributing from the reservoir.

The proposed improvement plan is to utilize the existing well (Doabther No.1) by renewal of the pump plus proposed four wells.

To fulfill the designed daily maximum water demand in the system at 23.3 l/s, the system is provided with the existing well at ground water at 2.4 l/s and plus the new wells at 20.9 l/s.

2-2-3 Outline Design Drawings

Based on the basic plan, the outline design drawings are prepared and shown in the succeeding paper. The list of the outline design drawings is as follows;

Surface Water System

Drawing No.


- 1 Namly Intake Plan
- 2 Gaya Intake Plan
- 3 Bagh Intake Plan
- 4 Bandi Intake Plan
- 5 Intake Structure
- 6 Structural and Piping Drawing of Bandi Intake
- 7 System Flow
- 8 General Plan of Water Treatment Plant
- 9 General Plan of Sheikhul Bandi Service Reservoir
- 10 General Plan of Salhad Service Reservoir
- 11 General Plan of Nawanshar Service Reservoir
- 12 General Plan of Derawanda Service Reservoir
- 13 General Plan of Mirpur Service Reservoir
- 14 General Plan of Banda Ghazan Service Reservoir
- 15 Typical Structure of Service Reservoir

Groundwater System


Drawing No.

- 1 Tubewell Pump Station General Plan (New)
- 2 Tubewell Pump Piping Plan (New)
- 3 Tubewell Pump Piping Plan (Existing)
- 4 General Plan of Dobathar Service Reservoir

Surface Water System




2 - 40




PROJECT

BASIC DESIGN STUDY ON THE PROJECT FOR IMPROVEMENT
OF WATER SUPPLY SYSTEM IN ABBOTTABADJICA JAPAN INTERNATIONAL
COOPERATION AGENCYNihon Suido Consultania Co., Ltd.
Japan Techno Co., Ltd.DESCRIPTION
Gaya Intake PlanDRAWING NO. 2
SCALE

2 - 41



2 - 42



PROJECT

BASIC DESIGN STUDY ON THE PROJECT FOR IMPROVEMENT
OF WATER SUPPLY SYSTEM IN ABBOTTABADJICA JAPAN INTERNATIONAL
COOPERATION AGENCYNihon Suido Consultants Co., Ltd.
Japan Techno Co., Ltd.DESCRIPTION
Bandi Intake Plan


DRAWING NO.

4


SCALE

General Drawing of Intake Structure
Structure


Plan




B-B Section




Intake Chamber Plan



A-A Section





C-C Section





0 5 Meters


RECD	BASIC DESIGN STUDY ON THE PROJECT FOR IMPROVEMENT OF WATER SUPPLY SYSTEM IN ABBOTTABAD	JICA JAPAN INTERNATIONAL COOPERATION AGENCY	Nihon Suido Consultants Co., Ltd. Japan Techno Co., Ltd.	DESCRIPTION Intake Structure	DRAWING NO.	SCALE
------	---	--	---	---------------------------------	-------------	-------






















PROJECT	BASIC DESIGN STUDY ON THE PROJECT FOR IMPROVEMENT OF WATER SUPPLY SYSTEM IN ABBOTTABAD	JICA	JAPAN INTERNATIONAL COOPERATION AGENCY	Nihon Suido Consultants Co., Ltd. Japan Techno Co., Ltd.	DESCRIPTION	DRAWING NO.	SCALE
					General Plan of Derawanda Service Reservoir	12	






PROJECT	BASIC DESIGN STUDY ON THE PROJECT FOR IMPROVEMENT OF WATER SUPPLY SYSTEM IN ABBOTTABAD	JICA JAPAN INTERNATIONAL COOPERATION AGENCY	Nihon Suido Consultants Co., Ltd. Japan Techno Co., Ltd.	DESCRIPTION	DRAWING NO.	SCALE
				General Plan of Banda Ghazan Service Reservoir	14	

Typical Structure of Service Reservoir



A-A Section




Service Reservoir	Capacity (m³)	Dimension (m)										
		tb	tw	ts	la	(x)la	Ia	A	Ib			
1. Sheikbul Bandi	130	0.40	0.35	0.30	4.600	1	4.25	9.55	4.050	2	7.75	8.45
2. Sahad	180	0.50	0.40	0.30	4.600	1	4.20	9.60	4.000	2	7.60	8.40
3. Nawanshehr	340	0.50	0.40	0.30	4.000	2	7.60	16.40	4.050	2	7.70	8.50
4. Mirpur	350	0.50	0.40	0.30	4.000	2	7.60	16.40	4.050	2	7.70	8.50
5. Derawanda	220	0.40	0.35	0.30	3.950	2	7.55	16.15	3.950	2	7.55	8.25
6. Banda Ghazan	100	0.40	0.35	0.30	4.000	1	3.65	8.35	3.950	2	7.55	8.25
7. Dobathar	300	0.40	0.35	0.30	3.750	2	7.15	15.35	3.650	3	10.60	11.30

Service Reservoir	Capacity (m³)	Dimension (m)									
		lc	ld	lh	tc	t1	h1	h2	h3		
1. Sheikbul Bandi	130	0.92	1.84	1.50	0.50	0.15	0.21	1.940	0.500	2.80	2.00
2. Sahad	180	0.92	1.84	1.50	0.50	0.15	0.21	2.940	0.500	3.80	3.00
3. Nawanshehr	340	0.80	1.60	1.50	0.50	0.15	0.15	3.000	0.500	3.80	3.00
4. Mirpur	350	0.80	1.60	1.50	0.50	0.15	0.15	3.000	0.500	3.80	3.00
5. Derawanda	220	0.79	1.58	1.50	0.50	0.15	0.15	2.000	0.500	2.80	2.00
6. Banda Ghazan	100	0.80	1.60	1.50	0.50	0.15	0.15	2.000	0.500	2.80	2.00
7. Dobathar	300	0.75	1.50	1.50	0.50	0.15	0.13	2.020	0.500	2.80	2.00

0 5 Meters 10 Meters


Groundwater System


Tube Well Pump Station General Plan (New)



Tube Well Pumps Newly Installed		
No.	Facility Name	Equipment Name
1	Tube Well Pump Station for Dabobher Area	Tube Well Pump No.2
2	Tube Well Pump Station for Dabobher Area	Tube Well Pump No.3
3	Tube Well Pump Station for Dabobher Area	Tube Well Pump No.4
4	Tube Well Pump Station for Dabobher Area	Tube Well Pump No.5


0 5 Meters





Dobathar Service Reservoir
General Plan

Area 700 m²



PROJECT	JICA	JAPAN INTERNATIONAL COOPERATION AGENCY	Nihon Suido Consultants Co., Ltd. Japan Techno Co., Ltd.	DESCRIPTION	DRAWING NO.	SCALE
BASIC DESIGN STUDY ON THE PROJECT FOR IMPROVEMENT OF WATER SUPPLY SYSTEM IN ABBOTTABAD				General Plan of Dobathar Service Reservoir	4	

2-2-4 Implementation Plan

2-2-4-1 Implementation Policy

1) Organization for the Implementation of the Project

The Project will be executed based on the scheme of the Grant Aid of the Government of Japan. After the Exchange of Note between the two governments regarding the implementation of the Project, the Government of Pakistan will select the consultant and contractor who must be both Japanese corporate entities for the implementation of the Project. Figure 2-2-14 shows the organizational concept for the Project implementation.




Figure 2-2-14 Organizational Concept for Project Implementation

(i) Implementing Agency

The implementing agency is the Abbottabad District Government under the Government of North West Frontier Province (NWFP). The Water Supply & Sanitation Section under the Works & Services Department is responsible for implementing the Project smoothly in cooperation with the provincial and central government organizations concerned.

(ii) Consulting Firm

The detailed design and construction supervision for the works financed by the Japanese side will be carried out by the consulting firm, having experiences in design and construction supervision for water supply facilities, and who is a Japanese corporate entity.

(iii) Contractor for Construction Work

The construction works financed by the Japanese grant aid will be carried out by the contractor who is a Japanese corporate entity. The construction sites for intake facilities and raw water mains for the surface water system are located in precipitous terrain in a mountainous area. The components of the facilities vary and include two systems: the surface water system (intake facility, raw water main, water treatment plant, treated water main, distribution reservoir) and

the groundwater system (new tubewells, replacement well pumps, water main, distribution reservoir). The contractor will be required to dispatch qualified engineers, construction materials and machinery necessary for the construction work, and must have sufficient capacity and experience to undertake the construction work.

2) Local Contractors

Local contractors with sufficient experience in similar construction works will also be utilized for the Project. Pakistan Engineering Council employs a registration system which categorizes and ranks the construction firms as shown below.

Rank of Construction Firms	Construction Scale (Million Rs.)
C-A	No Limit
C-B	Up to 1,000
C-1	Up to 500
C-2	Up to 200
C-3	Up to 100
C-4	Up to 50
C-5	Up to 20
C-6	Up to 10

In addition to the above ranking by the federal Government, the Government of North West Frontier Province (Contractors' Enlistment Committee, Works & Services Department, NWFP) sets the following registration system for construction firms dividing them by the field and scale.

1. Civil Works	2. Carriage Works
3. Electrical Works	4. Supply of Building Materials / Stories
5. Mechanical Works	6. Pipe Work & Bridge Substructure
7. Water Supply & Sanitation Works	8. Bridge Superstructure
9. Air Conditioning System	10. Electric Works

Rank of Construction Firms	Construction Scale (Million Rs.)
A	Up to 30
B	Up to 10
C	Up to 5

2-2-4-2 Implementation Conditions

Construction work for intake facilities and pipe laying work for raw water mains in the mountain areas are subject to risks such as rockfalls and landslides, especially in the rainy season. Special safety measures must be implemented at these site. Moreover, the pipeline route for the raw water main is mostly along the Murree Road, of which one side is mountain wall and the other side is cliffs. It is necessary to pay attention to traffic during the pipe laying work. Regarding the construction work in the mountains, there are several sites that are not accessible for vehicles and construction machinery. In such sites, transportation of materials may be by manpower or tractors, and the construction work must be undertaken using manpower. It is also necessary to consider the Islamic religious customs such as praying and fasting period.

2-2-4-3 Scope of Works

The Scope of Works for the Japanese Side and Pakistani Side are summarized in Tables 2-2-18 to 2-2-22.

Table 2-2-18 Scope of Well Construction and Existing Well Pump Replacement

Item	Japan	Pakistan
Land Acquisition and Site Clearance		○
Access Road Construction		○
Well Excavation	○	
Supply of Construction Materials	○	
Power Line Installation and Transformers		○
Control Panels and Low Voltage Power Receiving Facilities	○	
Supply and Installation of Well Pumps	○	
Dismantling of Existing Well Pumps and Supply and Replacement of Pumps	○	
Transportation and Scraping of Dismantled Materials		○
Pipe Laying and Connection from New Wells to Existing Pipelines	○	
Construction of Pumping House for New Wells	○	
Construction of Distribution Pipelines		○

Note : 4 Sites for New Wells, 12 Sites for Existing Well Pump Replacement

Table 2-2-19 Scope of Intake Construction

Item	Japan	Pakistan
Land Acquisition and Site Clearance		○
Access Road Construction		○
Construction of Intake	○	

Table 2-2-20 Scope of Raw and Treated Water Mains

Item	Japan	Pakistan
Securing of Right of Way		○
Construction of Raw Water Mains	○	
Construction of Treated Water Mains	○	
Connections to Existing Pipelines and Facilities	○	
Rehabilitation or Enhancement of Existing Clear Water Transmission Pipelines		○
Installation of Water Level Control Valves and Flowmeters for Existing Distribution Reservoirs	○	

Table 2-2-21 Scope of Water Treatment Plant Construction

Item	Japan	Pakistan
Land Acquisition, Pre-Excavation, and Site Clearance		○
Construction of Operation and Maintenance (O&M) Road		○
Maintenance of O&M Road (during construction)	○	
Cutting Ground (Excavation) until Designated Level	○	
Embankment and Masonry Work at Water Treatment Plant	○	
Construction of Water Treatment Plant Facilities	○	
Extension of Power Line to the Plant and Installation of Transformer		○

Installation of Low Voltage Power Receiving Facilities and Control Panels	<input type="radio"/>	
Construction of Drain Pipes from the Plant to the Discharge Point	<input type="radio"/>	

Table 2-2-22 Scope of Distribution Reservoir Construction

Item	Japan	Pakistan
Land Acquisition and Site Clearance (7 sites)		<input type="radio"/>
Access Road Construction		<input type="radio"/>
Construction of Distribution Reservoirs	<input type="radio"/>	
Pipe Laying and Connecting to Existing Pipelines from new Reservoirs (Only when new reservoirs are constructed adjacent to the existing reservoirs.)		<input type="radio"/>
Distribution Pipe Laying from New Reservoirs		<input type="radio"/>
Construction of Drain Pipes from the Reservoir to the Discharge Point		<input type="radio"/>

2-2-4-4 Consultant Supervision

The selected consultant will undertake the following supervision works:

- a) Checking and approval of working drawings and shop drawings prepared by the contractor
- b) Schedule control
- c) Quantity control
- d) Quality control
- e) Safety control
- f) Final inspection of the construction works
- g) Test operation and inspection of performance
- h) Inspection of construction materials
- i) Reporting of construction progress
- j) Defect inspection

The Project involves construction of a series of water supply facilities composed of Intake, Raw Water Mains, Water Treatment Plant, Treated Water Mains and Distribution Reservoirs for the Surface Water System, and New Well Construction, Replacement of Existing Well Pumps, Distribution Reservoir Construction and Transmission Pipeline Construction for the Groundwater System. The construction sites are some distance from Abbotabad TMA, for example the distance between the intake facilities and Abbotabad TMA is 24 to 25km. Considering these factors, it is necessary to deploy one resident engineer for the overall construction supervision, and also to dispatch the following engineers and specialists for construction supervisions at each site and facility.

Project Manager:	Commencement, Inspections
Resident Engineer:	Overall Construction Supervision
Civil Engineer: (Intake / Distribution Reservoir)	Construction supervision of Intake, distribution reservoir
Civil Engineer: (Water Treatment Plant)	Construction supervision of water treatment plant
Civil Engineer: (Raw Water Main / Treated Water Main)	Construction supervision of raw water main, treated water main

Well Specialist: Supervision of well construction and pump replacement

Moreover, the Project site is large, the construction sites are far apart from each other, and many construction works will be undertaken simultaneously at different sites. Accordingly, it is necessary to deploy the following local engineers at various construction sites to ensure adequate inspection works and safety measures at the sites.

Civil Engineer (Intake)

Civil Engineer (Water Treatment Plant)

Civil Engineer (Distribution Reservoir)

Pipeline Engineer (Raw Water Mains)

Pipeline Engineer (Treated Water Mains)

Well Specialist

2-2-4-5 Quality Control Plan

The quality control of the construction works is to be conducted in accordance with the technical specifications prepared by the consultants during the detailed design work. The major control work items are listed in Table 2-2-23 together with indicators, control methods, and standards to be adopted. JIS or other equivalent International Standards are, in principle, to be used for the quality control.

Table 2-2-23 Major Work Items and Methods for Quality Control

Category	Control Item	Control	Method of Control	Applicable Standards	Frequency of Test	Records	Remarks
Pump Facilities	Pump	Conform to the Standards	Observation Shop-Drawing Test Report	JIS B 8301 JIS B 8302	When Received Factory Inspection	Record Test Result Table Approval Drawings	In the presence of Consultant
Pipe Material	Ductile Cast Iron Pipe	Conform to the Standards	Shop-Drawing	JIS G 5526 JIS G 5527	For each pipe laying section	Approval Drawings	
		Type	Observation		For each type, when received	Record	In the presence of Consultant
Pipe Laying Work	Joint	Joint Condition	Observation	—	During the course of Jointing Work	Report	In the presence of Consultant
			Pressured Leakage Test		No leakage observed	Test Result Table	In the presence of Consultant
			Ultra Sonic Test		At one time for every 10 joints	Test Result Table	
Concrete Material	Reinforcing Bars	Type of Re-bar (deformed, round)	Observation	JIS G 3112 JIS G 3117	When received for each type	Record	In the presence of Consultant
		Conform to the Standards	Test Report			Test Result Table	
	Cement	Type of Cement	Observation	JIS R 5210	When received.	Record	In the presence of Consultant
		Conform to the Standards	Test Report			Test Result Table	
	Water	Piped Water or Clear River Water	Observation	—	When mixed	Concrete Mixture Table	In the presence of Consultant
		Water Quality (River Water)	Water Quality Test			Test Result Table	
	Aggregates	Maximum diameters of Aggregates	Observation	Reinforced Concrete : 25mm	When Received.	Record	In the presence of Consultant
		Grain Size	JIS A 1102			Test Result Table	
	Concrete Mixture	Conform to the Standards	Test Report	JIS A 6201-6207	When received	Test Result Table	When necessary.
	Storage of Materials	Place and Storage Conditions	Observation	—	When necessary.	Report	In the presence of Consultant
Concrete Placing Work	Concrete Design Mixture (Major Structures)	Test Mixture	Confirmation of Quality	28 day strength : 24N/mm ²	1 time before placing	Test Result Table	In the presence of Consultant
	On-site Concrete Mixture	Water Content of Small Aggregate Surface	JIS A 1111,1125	—	Each mixing	Test Result Table	In the presence of Consultant
		Grain Size of Aggregate	JIS A 1102	JIS A 5005	When received	Test Result Table	
		Temperatures of Water and Aggregates	Temperature Measurement	—	Each mixing	Test Result Table	In the presence of Consultant
		Water and Cement Volumes		Error: less than 1 %			

	Slump	Conform to the Specifications	JIS A 1101	10.0±2.5cm	Each placing	Test Result Table	In the presence of Consultant
	Air	Conform to the Specifications	JIS A 1128	±1.5%	Each placing	Test Result Table	In the presence of Consultant
Compressive Strength	Laboratory	—	Approval of Consultant	Prior to the test	—	—	
	Sampling	JIS A 1132	7day Strength: 3 pcs 28day strength : 3pcs	Every 50m ³ placing or 1 time per day 1time for one consecutive placing work	—	—	In the presence of Consultant
	Conform to the Specifications	JIS A 1108	Design Strength= 24 N/mm ²	Every 50m ³ placing or 1 time per day 1time for one consecutive placing work	Test Result Table	—	
	Leakage Test (Reservoir)	Conform to the Specifications	Water Level Measurement, Observation	No water level draw-down after 24 hours	After the structure is constructed	Test Result Table	In the presence of Consultant

2-2-4-6 Procurement Plan

Construction materials and equipment will be principally procured from Pakistan and Japan as well as other countries. Countries from which materials and equipment will be procured were determined taking into account the following conditions. Table 2-2-24 shows the procurement plan for major construction materials and equipment.

Table 2-2-24 Procurement Plan for Major Construction Materials and Equipment

	Pakistan	Third Countries	Japan
Construction Materials			
Common Construction Materials	○		
Materials for Temporary Work	○		○
Construction Machinery	○		○
Raw and Treated Water Transmission			
Steel Pipe	○		
Ductile Cast Iron Pipe		○	
Fittings and Valves		○	
Water Treatment Plant			
Yard Piping Materials		○	○
Filter Sand	○		
Sand Washing Machine			○
Disinfection Facilities			○
Well			
Well Pumps	○		
Electrical Equipment	○		

1) Local Procurement

For ease of maintenance after completion, it is preferred to select locally available construction materials and equipment as much as possible, as long as there is sufficient supply in the local market. Construction materials such as cement, aggregates, re-bars and steel materials are all available in Pakistan, and their quality is acceptable. Construction machinery is also available in Pakistan and can be leased from lease companies or construction companies.

2) Procurement by Importation

Pipe materials such as small diameter steel pipes are locally available with acceptable quality

and sufficient supply capacity in the market. These pipes are also recommended for the Project as the prices are relatively low and they are utilized for many water supply projects in Pakistan. It is, however, necessary to procure ductile cast iron pipes in medium-sized diameters from other countries, as these are not produced in Pakistan. Electrical equipment for wells can be procured locally.

3) Plan of Transportation

- i) Those procured in Japan will be shipped from Yokohama Port and delivered to Karachi Port. After the custom clearance they will be transported to Abbottabad through the inland route.
- ii) Those procured in the third countries will be shipped from the third countries to Karachi Port. After the custom clearance they will be transported to Abbottabad through the inland route.
- iii) The inland transportation routes are as shown in Table 2-2-25.

Table 2-2-25 Inland Transportation

Route	Items	Road Condition	Distance	Time for Transportation
Karachi – Abbottabad	Pipe Materials	Asphalt-paved National Highway	1,680 km	28 hours
Islamabad – Abbottabad	Construction Machinery/ Pipe Materials	Asphalt-paved National Highway	120km	2 hours
Abbottabad – Construction Sites	All Materials and Equipment	Asphalt-paved National Highway and Provincial Road. Narrow roads with/without pavement	Approx. 5~20km	30min~1 hour

2-2-4-7 Operational Guidance Plan

The Abbottabad District Government has no experience in the operation and maintenance of water treatment plants. Hence, after the completion of construction for the water treatment plant facilities, it will be necessary to provide technical knowledge transfer to surface water supply unit engineers and operators of the water treatment plant. The technical training for those staff will be carried out, covering surface water treatment techniques and operation and maintenance of water treatment plants, applying the slow filtering method. Training in operation and maintenance of wells and pumps will be carried out for operators of wells, after the completion of construction and replacement of wells and pumps.

2-2-4-8 Software Component (Technical Assistance) Plan

1) Objective

To achieve the project objective, it is necessary to implement the following actions:

- (1) Establish a new organization to supply surface water (Surface Water Supply Unit)
- (2) Use groundwater effectively
- (3) Proper operation and maintenance of the surface water system
- (4) Proper management of the three different agencies for water services

The following software component is proposed to assist in the establishment of the new organization and to developing the capacity of personnel:

- (1) Training on tubewell management and operation and maintenance of pumps
- (2) Capacity development in operation and maintenance of slow sand filtration systems
- (3) Assistance in establishing the Surface Water Supply Unit
- (4) Improvement of water tariff collection systems

2) Expected outputs

Implementation of the software component according to the above objective will have the following direct effects:

- (1) Training in operation and maintenance of tubewells
 - Enhance capacity development of operators for tubewell management and pump operation and maintenance
- (2) Management guidance for the management unit of the surface water supply system
 - Establish the committee for surface water supply system and become cross-functional with the existing water service agencies
 - Start-up of activities of the Surface Water Supply Unit
- (3) Capacity development for management and technical knowledge of the surface water supply
 - Enhance capacity development in managing the Surface Water Supply Unit
 - Enhance capacity development of operators in operation and maintenance of slow sand filtration systems
- (4) Improvement of water tariff collection system
 - Improve the metered tariff system transferred from the fixed tariff system

3) Activities

The groundwater system and surface water supply system will be constructed in this Project. To execute the software component, the following experts and activities are required.

- Japanese consultant (Tubewell management/Operation and Maintenance of pumps) 1 person
 - A Japanese consultant will undertake the lectures and on-the-job training for tubewell management and operation and maintenance of pumps. The Japanese consultant is responsible for:
 - Formulation and supervision of the Software Component program for tubewell management/Operation and Maintenance of pumps;
 - Reporting to the executing agency, Japanese side and coordination parties concerned in the program; and
 - Coordinating implementation of the program with the construction schedule.
- Japanese consultant (Institution): 1 person
 - A Japanese consultant will assist in enhancing the establishment of the surface water supply committee/unit by the executing agency. The Japanese consultant is responsible for:
 - Formulation and supervision of the Software Component program for organization enhancement;
 - Reporting to the executing agency, Japanese side, and coordination parties concerned in the program; and
 - Coordinating implementation of the program with the construction schedule.

- Japanese consultant (Operation and Maintenance of surface water supply system): 1 person

A Japanese consultant will undertake the lecturing and on-the-job training for operation and maintenance of the slow sand filtration system. The Japanese consultant is responsible for:

- Formulation and supervision of the Software Component program for operation and maintenance of the slow sand filtration system;
- Reporting to the executing agency, Japanese side, and coordination parties concerned in the program; and
- Coordinating implementation of the program with the construction schedule.

- Japanese consultant (Water tariff system): 1 person

A Japanese consultant will assist the executing agency in transitioning the fixed water tariff system to a metered water tariff system. The Japanese consultant is responsible for:

- Formulation and supervision of the Software Component program for assistance in the revision of the water tariff system and improvement of the billed collection system by the executing agency;
- Reporting to the executing agency, Japanese side, and coordination parties concerned in the program; and
- Coordinating implementation of the program with the construction schedule.

- Japanese consultant (Education): 1 person

A Japanese consultant will facilitate consensus-building efforts and public hearings between the executing agency and residents regarding the transition to the metered water tariff system by the executing agency. The Japanese consultant is responsible for:

- Formulation and supervision of the Software Component program for assistance in facilitating consensus-building efforts for transition of the water tariff system and improvement of the billed collection system by the executing agency;
- Reporting to the executing agency, Japanese side, and coordination parties concerned in the program; and
- Coordinating implementation of the program with the construction schedule.

- Local consultant

Since the executing agency has less experience and fewer skills in implementation of software component programs, an experienced local consultant will be employed to carry out the activities. Skills and technology will be transferred to the executing agency through lectures and on-the-job training. Staff from the local consultant must be experienced in implementation of similar programs and have fluent communication with the executing agency and residents.

- i) Institution / water tariff system: 4 persons

Under the supervision of a Japanese consultant, a local consultant (Institution/water tariff system) will act to establish the Surface Water Supply Unit and new water tariff system with the executing agency. The local consultant shall be experienced in establishment of operation and maintenance systems and capacity development for finance and accounting in similar programs.

- ii) Education: 1 person

Under the supervision of a Japanese consultant, a local consultant (Education) will act to carry out consensus building efforts between residents and the executing agency regarding the transition to a metered water tariff. The local consultant shall be experienced in the establishment of community-based management, participatory planning, monitoring and evaluation and capacity development.

2-2-4-9 Implementation Schedule

In terms of the project scale and components, the implementation schedule for the Project has been formulated over a term of multiple fiscal years. The expected periods are 4.5 months for detailed design and 26.0 months for construction and procurement.

Figure 2-2-15 shows the implementation schedule for the Project.




Figure 2-2-15 Implementation Schedule

2-3 Obligations of Recipient Country

2-3-1 Land Acquisition

Land acquisition for construction sites for Intake, Water Treatment Plant, Distribution Reservoirs, Wells and Pressure Releasing Chambers is the responsibility of the Government of Pakistan.

Intake (4 sites):

1) Namly Maira	153 m ²
2) Gaya	176 m ²
3) Bagh	238 m ²
4) Bandi	150 m ²

Water Treatment Plant:

1) Plant Site	15,650 m ²
2) Access and O&M Road	7,700 m ²

Distribution Reservoirs (7 sites):

1) Sheikhul Bandi	448 m ²
2) Salhad	400 m ²
3) Nawansher	600 m ²
4) Mirpur	413 m ²
5) Derawanda	480 m ²
6) Banda Ghazan	298 m ²
7) Dobathar	700 m ²

Wells (4 sites):

each 300 m² x 4 sites

Pressure Releasing Chamber (3sites):

1) No.1 50m ²
2) No.2 50m ²
3) No.3 100m ²

2-3-2 Construction of Access Roads to Intake Sites, Water Treatment Plant and Distribution Reservoirs

The access roads to the four intake sites, water treatment plant site and seven distribution reservoirs shall be constructed by the Pakistani side.

2-3-3 Power and Telephone Lines to the Project Site

It is the obligation of the Government of Pakistan to provide the power distribution lines to the water treatment plant site and the four well construction sites, as well as the installation of main circuit breakers and transformers and to provide the telephone line to the water treatment plant site. The capacity required is estimated at 15 KVA for the water treatment plant and 40 KVA for each well site.

2-3-4 Obligations for New and Existing Distribution Reservoirs

The construction works for the new distribution reservoirs to be carried out by Japanese side includes installation of water transmission pipes into the reservoirs, installation of water level control valves, installation of overflow pipes and drain pipes up to the manholes. The Pakistani side should install the overflow pipes and drain pipes extended to the discharge points.

The installation of distribution pipes is the full responsibility of the Pakistani side. The Japanese side, however, only has responsibility for the installation of outlet valves and outlet pipes at the reservoirs up to the valve chamber.

Regarding the installation of new water transmission pipes to the existing reservoirs, the Japanese side will install new pipelines to the connecting points with the existing transmission pipes as well as water level control valves. If the existing reservoirs' distribution pipes overflow pipes and drain pipes need any expansion or rehabilitation, these works are all the responsibility of the Pakistani side.

2-3-5 Right of Way for Raw and Treated Water Transmission Mains

The Implementing Agency should obtain necessary consents from the landowners where pipes are installed under private land or land under the control of other organizations. Regarding the pipe laying under the pavement, road shoulder, drainage and sidewalks of the National Highway, Provincial Roads and other roads, the implementing agency should obtain a No Objection Certificate (NOC) from the road authorities concerned. Road restoration is the responsibility of the Japanese side, but for issuing of the NOC, the implementing agency should deposit the advance rental charges for the roads.

2-3-6 Procurement and Installation of Water Meters

In conjunction with the implementation of the Project, the Pakistani side is planning to introduce the water meters for the Abbottabad TMA and the peripheral U/Cs. Procurement and installation of the water meters is the responsibility of the Pakistani side.

2-3-7 Implementation of Measures to Reduce Non-Revenue Water (NRW)

The water demand in 2015 includes 20% of NRW. Therefore, the implementation organization shall take necessary measures such as leakage reduction, to reduce NRW ratio to 20% in 2015.

2-3-8 Approval of PC-1

Planning Commission-1 (PC-1), which guarantees the obligations of the Pakistani side, shall be approved by the Central Government and Provincial Government for the implementation of the Project. The Pakistani side requires amendment of the PC-1 for approval as soon as possible.

2-3-9 Other Requirements

In addition to the above obligations, the Pakistani side shall take the following actions.

- (a) Provide facilities for the distribution of electricity, water supply, drainage and other incidental facilities for construction works;
- (b) Issue public notices regarding the effects of construction work;
- (c) Exempt any taxes, duties and levies for importing materials, equipment and products for the project;
- (d) Bear the following commissions to the Japanese bank for banking services based upon the B/A:
 - Advising commission of A/P
 - Payment Commission;

- (e) Bear the payment commissions to the Pakistani bank for banking services;
- (f) Ensure tax exemption and custom clearance of the products at the port of disembarkation in Pakistan;
- (g) Exempt Japanese nationals from customs duties, internal taxes and other fiscal levies which may be imposed in Pakistan with respect to the supply of the products and services under the verified contracts;
- (h) Accord Japanese nationals, whose service may be required in connection with the supply of the products and the services under the verified contract, such facilities as may be necessary for their entry into Pakistan and stay therein for the performance of their work;
- (i) Maintain and use properly and effectively the facilities constructed and equipment provided under the Grant; and
- (j) Bear all the expenses, other than those to be borne by the Grant, necessary for construction of the facilities as well as for the transportation and installation of the equipment.

2-4 Project Operation Plan

2-4-1 Organization for Management and Operation

After the completion of the Project, the water supply in the service area will be dependent on both the groundwater system and the surface water system. Figure 2-4-1 shows the proportion of the dependence on each system. Jhangi in Jhangi U/C, Banda Phugwarian and Dobatar systems are dependent 100% on the groundwater system, as they were previously. Abbottabad TMA, Nawansher, Sheikhl Bandi, Salhad and Mirpur U/Cs, and Derawanda, Lama Maira, Banda Ghazan and Banda Delazak in Jhangi U/C will be supplied by a combination of the groundwater system and the surface water system.

Regarding the wells, one existing well pump in Nawansher will be replaced. In the peripheral Union Councils, four new wells will be constructed and eleven well pumps will be replaced. Operation and maintenance of these wells will be the responsibility of the Abbottabad TMA, Nawansher Service Unit and Abbottabad District respectively.

The Surface Water System will provide bulk water supply to the existing systems operated by the three different agencies, namely Abbottabad TMA, Nawansher Service Unit and Abbottabad District. Therefore, it is very important to establish a new organization to operate and manage this new system. and to make sure the responsibility of each agency for this new system.




Figure 2-4-1 Proportions of Dependence on the Surface Water System and Groundwater System

2-4-1-1 Operation and Management of the Surface Water System

The existing water supply facilities in the service areas are operated and maintained by the three water supply agencies: 1) Water Supply & Sanitation, Works & Services Dept., the District Government Abbottabad, 2) Water Supply, Infrastructure, Abbottabad TMA and 3) Nawansher Service Unit controlled by Abbottabad TMA.

It is proposed that the newly established Surface Water Supply Unit will operate and maintain the new intakes, raw water transmission mains, water treatment plant, treated water transmission mains and supply water to the three existing three water supply agencies. On the other hand,

Abbottabad TMA, Nawansher Service Unit and Abbottabad District will receive bulk water supplies from the Surface Water Supply Unit through the treated water transmission mains. The distribution reservoirs, which receive the bulk supplies, will be operated by the three agencies, and water distributions from these reservoirs to consumers are the responsibility of the three agencies.

The new Surface Water Supply Unit will be established in the District Government Abbottabad. Initiatives for new installations will be proposed by the District Coordination Officer.




Figure 2-4-2 Organization Chart for the Surface Water Supply Unit

The structure of the Surface Water Supply Unit consists of an administrative section and a technical section. The technical section consists of two sections; one is to operate and maintain the water treatment plant, and the other section is to operate and maintain the intakes, raw water transmission mains and treated transmission mains up to the reservoirs, as shown in Fig.2-4-2.

2-4-1-2 Operation and Management of the Groundwater System

The three water supply agencies will continue to use groundwater wells in the future. The Project will include modifications to control abstraction by adding basic monitoring functions within the well pump replacement work. As only four wells are to be added to the peripheral Union Councils' area, it is not necessary to change the existing operating organization, however training on well management and operation and maintenance of pumps is necessary for the current operators. It is important for the operators to keep daily records of pump operating hours,

water pressure, flow data and periodic water level readings.

2-4-1-3 Strengthening of Water Bill Collection

A flat rate water tariff is presently adopted in Abbottabad TMA and Peripheral Union Councils. The Implementing Agency is, however, keen to introduce metered water charges in conjunction with the Project implementation. Water wastage by flat rate consumers is considered significant, and it is to the introduction of water meters will aid the conservation of water in an area already short of water resources. As Abbottabad TMA and Peripheral Union Councils have no experience in metered billing systems, it is necessary to build capacity in various areas such as water meter installation, meter reading, customer education, and new consumption-based bill collection systems.

Setting of the bulk supply tariff will be coordinated and determined among Abbottabad TMA, Nawansher Service Unit, Abbottabad District Works & Services Dept. and the Surface Water Supply Unit. To ensure sustainability, a self-supporting accounting system will be adopted.

It is recommended that a component of the consulting services are used to assist the capacity building of the agencies concerned in the management of the Surface Water System, introduction of water meters and revision of tariff policy.

2-4-2 Operation and Maintenance of the Surface Water System

2-4-2-1 Operation and Maintenance of the Water Treatment Plant

The Water Treatment Plant will operate on a 24-hour basis with three shifts of operators under the control of the engineer as shown in Fig.2-4-2. Major daily operation and maintenance work is as follows:

(a) Raw Water Quality Monitoring

Raw Water Quality is generally stable with low turbidity, but sudden increases may occur when it rains upstream of the intakes. It is necessary to monitor the raw water turbidity periodically and take immediate actions such as stopping the inflow when necessary.

(b) Sedimentation and Filtration Processes

Periodic observation is necessary to know the degree of accumulation of sediments in sedimentation basins, as well as the clogging of roughing filters and slow sand filters. Desludging from sedimentation basins, backwashing of roughing filters and scraping of slow sand filters will be carried out as required.

(c) Disinfection Process

Preparation of the bleaching powder solution and controlling the dosage to maintain appropriate residual chlorine is necessary.

(d) Data Record

Treatment process monitoring such as flow, water quality, frequency of filter washing, filter scraping and consumption of bleaching powder must be recorded.

The District Government Abbottabad has no experience in operating slow sand filtration system or disinfection by bleaching powder. It is necessary to provide technical training on operation of the treatment plant, through technical guidance as a component of the consulting services.

2-4-2-2 Operation and Maintenance of Intake, Raw Water Transmission Mains and Treated Water Transmission Mains

Periodic patrol of the intakes as well as water mains routes should be done by the operators under the control of the transmission engineer. It is important to identify any abnormal conditions at the facilities or their surrounds at an early stage. Leaks identified during the patrol should be immediately reported and repaired. The supply of bulk water to the distribution reservoirs is controlled by the water level control valves installed at the reservoirs. The operators should check the function of the valves and provide necessary maintenance.

In addition, the operators should read water flowmeters installed upstream of the inlet of each distribution reservoir, record the transmission flow data and check the function of the flowmeter.

Two operators will be deployed for operation and maintenance of the intakes, raw and treated water transmission mains, flow meters and water level control valves at the distribution reservoirs under the control of the transmission engineer as shown in Fig.2-4-2.

2-5 Project Cost Estimation

2-5-1 Initial Cost Estimation

The period of detailed design will be 4.5 months. The procurement and construction period will be 26 months.

The cost borne by the Pakistani Side	Rs. 577.4 Million (Approximately Yen 606 million)
1) Land Acquisition:	Rs. 80.00 million
2) Access Roads for Construction Sites:	Rs. 50.30 million
3) Power Supply, Water Supply, Drainage, Telephone, Office Furniture:	Rs. 43.50 million
4) Inter-linking of New/Old Reservoirs and Wells:	Rs. 31.60 million
5) Expansion and Rehabilitation of Distribution Network:	Rs. 154.80 million
6) Procurement and Installation of Water Meters:	Rs. 78.50 million
7) Provision for Creation of Project Sub-division (PMU):	Rs. 7.60 million
8) Commissions for Bank Arrangement, Custom Clearance:	Rs. 91.20 million
9) Provision for security arrangements for hiring Frontier Constabulary during project execution:	Rs. 37.10 million
10) Contingencies	Rs. 2.80 million

Conditions for Cost Estimates are as follows:

- 1) Date of Estimates: As of May, 2009
- 2) Exchange Rates: US\$ 1 = 95.77 Yen
Rs.1 = 1.05Yen
- 3) Period of Construction: 26.0 months
- 4) Others: The Project should be implemented in accordance with the procedures of Japan's Grant Aid Scheme.

2-5-2 Operation and Maintenance Cost

This section discusses the balance of the water revenue (water tariff collection) and expenses (power costs, chemical cost, personnel cost, etc), the need for water tariff revision, and the need for subsidy from the Provincial Government.

2-5-2-1 Water Tariff

Abbottabad TMA, Nawansher Service Unit and Abbottabad District Government (for peripheral UCs) are presently adopting different water tariff systems.

The water tariff of Abbottabad TMA is set as indicated in Table 2-5-1. It is the flat rate system which does not account for the actual consumption of customers. The water tariff falls into two categories for domestic use and commercial use. The tariff for commercial use is further divided into nine subcategories including hotels, barbershops, schools, and cinemas.

Table 2-5-1 Abbottabad TMA 2008 Water Tariff

	Type of Water Connection	Tariff (Per Month)	No of Water Connections	Total
1	Domestic	Rs. 100	5,800	580,000
2	Hotel (A class)	Rs. 500	13	6,500
3	Hotel 6-10 Rooms (B class)	Rs. 300	10	3,000
4	Hotel 1-5 Rooms (C class)	Rs. 225	9	2,025
5	Hotel (D class)	Rs. 150	130	19,500
6	Barber, Bakery, Clinic, Private School	Rs. 200	32	6,400
7	Barber (3 and above Bath)	Rs. 250	11	2,750
8	Barber (B Class)	Rs. 100	39	3,900
9	Gas Station	Rs. 400	5	2,000
10	Cinema	Rs. 500	1	500
	Monthly Total	-	6,050	626,575
	Yearly total			7,518,900

Nawansher Service Unit adopts water tariff based on consumption measured by water meters. The water tariff is divided into two categories: Rs.2.32/m³ for domestic use and Rs.3.0/m³ for commercial use. Of the total connections there are only 107 connections for commercial use, and the commercial use is defined as ‘non-domestic use’, which is ambiguous.

The Abbottabad District Government, which is operating the water supply systems in the peripheral U/Cs, adopts a flat rate water tariff which is fixed at Rs.100/month/connection for all users. It is acknowledged that none of the three agencies can cover their operation and maintenance costs from their water revenues, and deficits are experienced every year. Table 2-5-2 shows the balance of water revenues and operation and maintenance costs in the 2007/2008 fiscal year.

Table 2-5-2 Present Water Revenue and Operation & Maintenance Cost in 2007/2008

Agency	Present O&M Cost					Present Revenue		
	Electricity	Personnel Cost	Repair Cost	Others	Total	Water Revenue	Subsidy	Total
Abbottabad TMA & Nawansher Service Unit	19,800,000	9,047,000	1,200,000	400,000	30,447,000	9,910,000	20,537,900	30,447,900
District Government Abbottabad	23,394,795	27,512,278	3,900,000	365,000	55,172,073	8,832,161	46,339,912	55,172,073
Total	43,194,795	36,559,278	5,100,000	765,000	85,619,073	18,742,161	66,877,812	85,619,973

2-5-2-2 Operation and Maintenance Costs and Water Revenues

Operation and maintenance costs and water tariff revenues are estimated based on the following conditions:

- a. Personnel cost: Calculated from the present level of salaries
- b. Chemical cost: Calculated using the market price of bleaching powder for disinfection in Pakistan (Rs. 200/kg)
- c. Repair cost: 0.2% of the construction cost per year
- d. Power cost: Calculated from necessary electricity for pump operation based on WAPDA electricity tariff (Rs. 10/kWh, Tariff D-1)
- e. Non-Revenue Water ratio: Non-Revenue Water ratio is 20% of daily water demand in 2015.
- f. Water Tariff Increased annually considering the socially affordable tariff which is 4% of the average household income at maximum

Table 2-5-3 shows the annual operation and maintenance costs for the Surface Water System and the costs for Abbottabad TMA, Nawansher Service Unit and District Government Abbottabad. Table 2-5-4 shows a comparison of the annual operation and maintenance costs and water revenues by water tariff collection. The results of the comparison are explained as follows:

- i) Abbottabad TMA will be able to cover the operation and maintenance costs from their water revenue after the year of 2016, provided that water tariffs increase annually by 30%. Monthly water charges per connection as a proportion of average monthly household income is 1.90%.
- ii) Nawansher Service Unit will be able to cover the operation and maintenance costs from their water revenue after the year of 2020, provided that water tariffs increase annually by 30%. Monthly water charges per connection as a proportion of average monthly household income is 3.77%.
- iii) District Government Abbottabad will be able to cover the operation and maintenance costs from their water revenue after the year of 2019, provided that water tariffs increase annually by 30%. Monthly water charges per connection as a proportion of average monthly household income is 3.59%.

The overall water revenue of the three agencies will be almost balanced with the total cost in the year 2019, and revenue will exceed costs after this year. It is desirable to adopt a cross subsidy policy between the three water supply agencies, to reduce the burden on other U/Cs of District Government Abbottabad. Accordingly, the Provincial Government will subsidize the deficits that will occur for several years after the Project is completed.

Table 2-5-3 Operation & Maintenance Cost for Surface Water System and Those Costs Incurred by Abbottabad TMA, Nawansher Service Unit and District Government Abbottabad

		2013	2014	2015	2016	2017	2018	2019	2020
Total Water Demand (Max.Day)	m3/d	24,682	27,767	30,852	30,852	30,852	30,852	30,852	30,852
1 Bulk Water Supply System									
Water Production	m3/d	17,280	17,280	17,280	17,280	17,280	17,280	17,280	17,280
Annual Production	m3	5,484,522	5,484,522	5,484,522	5,484,522	5,484,522	5,484,522	5,484,522	5,484,522
Personnel Cost	'000Rs.	8,984	8,984	8,984	8,984	8,984	8,984	8,984	8,984
Power Cost	'000Rs.	109	109	109	109	109	109	109	109
Chemical Cost (Rs.0.34/m3)	'000Rs.	1,865	1,865	1,865	1,865	1,865	1,865	1,865	1,865
Maintenance Cost	'000Rs.	644	644	644	644	644	644	644	644
Total O&M Cost	'000Rs.	11,602	11,602	11,602	11,602	11,602	11,602	11,602	11,602
2 Abbottabad TMA System									
Water Production (Max.Day)	m3/d	9,175	10,322	11,469	11,469	11,469	11,469	11,469	11,469
Annual Production	m3	2,912,065	3,276,113	3,640,161	3,640,161	3,640,161	3,640,161	3,640,161	3,640,161
Power Cost	'000Rs.	1,816	2,043	2,270	2,270	2,270	2,270	2,270	2,270
Personnel /Maintenance Cost	'000Rs.	9,319	10,484	11,649	11,649	11,649	11,649	11,649	11,649
Bulk Water Supply	'000Rs.	7,216	7,216	7,216	7,216	7,216	7,216	7,216	7,216
Total O&M Cost	'000Rs.	18,351	19,743	21,135	21,135	21,135	21,135	21,135	21,135
3 Nawansher System									
Water Production (Max.Day)	m3/d	3,632	4,086	4,540	4,540	4,540	4,540	4,540	4,540
Annual Production	m3	1,152,765	1,296,861	1,440,957	1,440,957	1,440,957	1,440,957	1,440,957	1,440,957
Power Cost	'000Rs.	8,560	9,630	10,700	10,700	10,700	10,700	10,700	10,700
Personnel /Maintenance Cost	'000Rs.	3,689	4,150	4,611	4,611	4,611	4,611	4,611	4,611
Bulk Water Supply	'000Rs.	487	487	487	487	487	487	487	487
Total O&M Cost	'000Rs.	12,736	14,267	15,798	15,798	15,798	15,798	15,798	15,798
4 Other U/C System									
Water Production (Max.Day)	m3/d	11,874	13,359	14,843	14,843	14,843	14,843	14,843	14,843
Annual Production	m3	3,768,704	4,240,030	4,711,039	4,711,039	4,711,039	4,711,039	4,711,039	4,711,039
Power Cost	'000Rs.	38,328	43,119	47,910	47,910	47,910	47,910	47,910	47,910
Personnel /Maintenance Cost	'000Rs.	12,060	13,568	15,075	15,075	15,075	15,075	15,075	15,075
Bulk Water Supply	'000Rs.	3,898	3,898	3,898	3,898	3,898	3,898	3,898	3,898
Total O&M Cost	'000Rs.	54,286	60,585	66,883	66,883	66,883	66,883	66,883	66,883
Grand Total O&M Cost	'000Rs.	85,373	94,595	103,816	103,816	103,816	103,816	103,816	103,816

Table 2-5-4 Comparison of Annual Operation & Maintenance Costs and Water Revenues with Increased Water Tariff

Items		2013	2014	2015	2016	2017	2018	2019	2020
Water Tariff Increase 30% per annum									
Abbottabad TMA System									
1 Water Sales	m3	2,329,652	2,620,890	2,912,129	2,912,129	2,912,129	2,912,129	2,912,129	2,912,129
2 O&M Cost	'000Rs.	18,351	19,743	21,135	21,135	21,135	21,135	21,135	21,135
3 Revenue	'000Rs.	9,994	14,625	21,113	27,461	27,461	27,461	27,461	27,461
4 Balance	'000Rs.	-8,357	-5,118	-22	6,326	6,326	6,326	6,326	6,326
5 Water Tariff	Rs./mon	96	129	173	225	225	225	225	225
6 Ratio to Income	%	0.81	1.09	1.46	1.90	1.90	1.90	1.90	1.90
Nawansher System									
1 Water Sales	m3	922,212	1,037,489	1,152,766	1,152,766	1,152,766	1,152,766	1,152,766	1,152,766
2 O&M Cost	'000Rs.	12,736	14,267	15,798	15,798	15,798	15,798	15,798	15,798
3 Revenue	'000Rs.	2,555	3,735	5,395	7,009	9,107	11,839	15,389	20,012
4 Balance	'000Rs.	-10,181	-10,532	-10,403	-8,789	-6,691	-3,959	-409	4,214
5 Water Tariff	Rs./mon	54	78	110	143	186	241	314	408
6 Ratio to Income	%	0.50	0.72	1.02	1.32	1.72	2.23	2.90	3.77
Other U/C System									
1 Water Sales	m3	3,014,963	3,392,024	3,768,831	3,768,831	3,768,831	3,768,831	3,768,831	3,768,831
2 O&M Cost	'000Rs.	54,286	60,585	66,883	66,883	66,883	66,883	66,883	66,883
3 Revenue	'000Rs.	11,758	17,198	24,837	32,299	41,985	54,573	70,929	70,929
4 Balance	'000Rs.	-42,528	-43,387	-42,046	-34,584	-24,898	-12,310	4,046	4,046
5 Water Tariff	Rs./mon	76	110	155	201	262	340	442	442
6 Ratio to Income	%	0.62	0.89	1.26	1.63	2.13	2.76	3.59	3.59
Total									
1 Water Sales	m3	6,266,827	7,050,403	7,833,726	7,833,726	7,833,726	7,833,726	7,833,726	7,833,726
2 O&M Cost	'000Rs.	85,373	94,595	103,816	103,816	103,816	103,816	103,816	103,816
3 Revenue	'000Rs.	24,307	35,558	51,345	66,769	78,553	93,873	113,779	118,402
4 Balance	'000Rs.	-61,066	-59,037	-52,471	-37,047	-25,263	-9,943	9,963	14,586
5 Water Tariff	Rs./mon	80	112	155	201	237	283	342	356
6 Ratio to Income (Rs. 11,854 Rs. In Ave.%	%	0.67	0.94	1.31	1.70	2.00	2.39	2.89	3.00

As shown in Table 2-5-2, the present overall balance of water revenues and operation and maintenance costs results in an annual deficit of Rs.67 million. Figure 2-5-1 shows the comparison of annual water revenues and the O&M costs after the completion of the Project, assuming a 30% annual increase in water tariff. In the first year after the completion of the Project, the simulation indicates a deficit of approximately Rs.61 million, which is less than the deficit estimated in the fiscal year 2013. In 2019 the total revenue and total cost of the three agencies are almost balanced, as the balances, as Abbottabad TMA and District Government Abbottabad are in surplus and only Nawansher Service Unit is in deficit. Table 2-5-5 shows the water tariff levels for the three agencies in 2019 when the overall revenue and cost are nearly balanced.

Table 2-5-5 Degree of Water Tariff Increase and Effects on Household Income

Agency	Present Water Tariff (Rs./m ³)	Water Tariff necessary to achieve approximate overall balance of the Three Agencies nearly (Rs./m ³ , Year 2019)	Necessary Multiple for the Present Tariff	Water Tariff as a % of Average Household Income (%)
Abbottabad TMA	3.30	9.43	2.9	1.90
Nawansher Service Unit	2.13	13.35	6.3	2.90
Abbottabad District Government	3.00	18.82	6.3	3.59
Average	2.81	14.52	5.2	2.89

The above analysis implies that if the deficits of Nawansher Service Unit and District Government Abbottabad are filled by the profits of Abbottabad TMA, the total revenue and cost is balanced.




Figure 2-5-1 Balance of Operation and Maintenance Cost and Water Revenue after the Project (Annual Tariff Increase of 30%)

In conclusion, the following arrangements among the three agencies and support from the Provincial Government will be required:

- (i) The present water tariffs will be raised to the levels as indicated in Table 2-5-3. (Although the water tariffs are raised annually by 30% in the above simulation, it may be more practical to raise the tariffs twice up to those levels by the year 2019.)
- (ii) Abbottabad TMA, Nawansher Service Unit, District Government Abbottabad will fully collect the water tariffs from consumers. These three agencies are required to pay for the bulk supply provided by the Gravity Water Supply Unit according to the actual consumption measured by the flow meters installed in the Project.
- (iii) The full costs and revenues of the three agencies will balance in 2019. The balance for Abbottabad TMA and District Government Abbottabad (Peripheral U/Cs) are in surplus, but the balance for Nawansher Service Unit is in deficit. This deficit can be, however, covered by introducing cross subsidy among the three agencies so that the total water revenues of the three agencies cover the total operation and maintenance costs. If the tariff of each agency is set at 2.9% of the average household income, the cost and revenue will be balanced. This implies that if water management in the three agencies is integrated to one body, the total costs will be covered by the water revenues at the above tariff level.
- (iv) The Provincial Government will continue to subsidize the three agencies to cover the deficits after the completion of the Project. The amount of subsidy is, however, expected to reduce year by year if the water tariff is raised sufficiently and the tariff is collected effectively. According to the simulation the subsidy will be zero after the year 2019.
- (v) The water revenue is planned to cover the O&M cost in 2019 on the condition that the NRW ratio is reduced to 20% by 2015 and maintained thereafter. It is therefore necessary that the three agencies make every effort to reduce the water losses and unbilled authorized consumption, to achieve 20% NRW ratio by 2015. In the case that there is still deficit in 2019, the Provincial Government will continue to subsidize the three agencies to cover the deficits.

2-6 Other Relevant Issues

The Government of NWFP and the District Government Abbottabad had proceeded to acquire the land for the proposed facilities and access roads. The necessary procedures for land acquisition shall be completed before the commencement of the construction of the proposed facilities.

Chapter 3 Project Evaluation and Recommendations

Chapter 3 Project Evaluation and Recommendations

3-1 Project Evaluation

As stated previously, the objective of project is to mitigate the shortage of water supply capacity, to improve the water supply service ratio and to improve the living environment in Abbottabad TMA and the surrounding area in Abbottabad District. By implementing the project, the following effectiveness will be expected.

Present status and problems	Measures by the project	Direct effectiveness	Indirect effectiveness
<p>1) The water supplies in Abbottabad TMA and the surrounding U/Cs in Abbottabad District in NWFP have depended on groundwater as water sources for a long period.</p> <p>2) In recent years, the enhancement of water supply capacity is urgently required because of the rapid development and population increase in the target area, and the decrease of discharges of the existing wells.</p> <p>3) The service ratio of potable water at present is 57% only and in addition the duration time of water supply is less than one hour at many places. It is far from the situation of stable water supply.</p> <p>4) The current water supply system, which is to pump up the well water to the distribution reservoirs located at a high elevation for water distribution, results the financial difficulty for water supply management due to high power cost.</p> <p>5) The long term and stable operation is becoming difficult because of the shortage of well water due to excessive discharge of water and of the unexpected failures of pumps due to the lack of</p>	<p>1) Providing surface water system</p> <p>2) Providing groundwater system</p> <p>3) Providing soft component (technical assistance)</p>	<p>1) Present population served in the target area is estimated at 114,000 in 2009. Providing water supply facilities both from surface water source and from groundwater source, safe and stable water supply will be available to the population of 216,400 in 2015.</p> <p>2) It is possible to improve service coverage ratio from 57% in 2009 to 92% in 2015 when surface water system is completed and groundwater system is properly maintained and operated.</p> <p>3) 24 hours a day continuous water supply will be available due to new water source obtained and proper utilization of well pumps, although water supply at present is unstable and less than a few hours because of frequent failure of well pumps.</p> <p>4) Stable and long term utilization of the well facilities will be secured by the proper operation of pumping facilities due to the reinforcement of capability for managing wells and O&M of pumps</p> <p>5) Newly established surface water committee and surface water supply unit and their proper</p>	<p>Stable supply of safe water to the inhabitants is contributing the improvement of public health environment, and thus, the social & economic revitalization in the target area is expected.</p>

proper maintenance.		management and operation will ensure the continuous supply of treated water to three existing water agencies.	
---------------------	--	---	--

The following are the contents of baseline study executed for the project evaluation.

Contents of study	How to obtain	Results	Explanation	Effectiveness indicator after the project
Number of households in 2009	District Government Abbottabad	28,029	-	
Number of house connections in 2009	District Government Abbottabad	15,700	-	
Estimated population in 2009		200,249	Multiplying number of households and number of persons in household.	
Estimated population in 2015		235,226		Applying Increased ratio of census population in 1981 and 1998.
Service coverage in 2009		57%	Multiplying number of house connections and number of persons in household and divided by population.	
Service coverage in 2015		92%		Applying access ratio to potable water in MTDF 2005-2010.
Population served in 2009		114,000	Multiplying number of house connections and number of persons in household.	
Population served in 2015		216,400		Multiplying population and service coverage
Duration time of water supply in 2009	Interview to residents	Less than one hour at many houses		
Duration time of water supply in 2015		24 hours		By gravity flow of surface water system.
Monthly income per household	Interview to residents	Rs. 10,819 ~ 12,313 per month		For evaluation of socially affordable water tariff.

3-2 Recommendations

① Establishment of surface water supply unit

The existing water supply facilities in the service areas are operated and maintained by the three water supply agencies: 1) Works & Services Dept., the District Government Abbottabad, 2) Infrastructure, Abbottabad TMA and 3) Nawansher Service Unit.

There is no bulk water supply and experience in management of water treatment plant in Abbottabad District. It is therefore proposed to establish a new Surface Water Supply Unit under the District Government Abbottabad, which will supply water to the three water supply agencies. It is required to recruit human resources with qualification and capability suitable for the operation and maintenance of bulk water supply system.

Hence, it is necessary to provide advice and guidance through discussion with the three agencies and other related organizations, and facilitate preparation and coordination for establishment of the new Unit. To achieve the project goal, smooth operation by reinforcing the organizational structure and capacity building is indispensable.

For a purpose of consideration of setting of appropriate water tariff and distribution of bulk water supply to the three existing water supply agencies with appropriate manner, it is simultaneously proposed to establish Water Committee whose members consist of the representatives of the District Government, Abbottabad TMA and Nawansher Service Unit for regulation and advice to activities of the new Unit, and the coordination with the existing agencies. It is desirable to establish this Water Committee in an early stage obtaining the understanding of the relevant organizations.

The support with technical and managerial guidance is planned under the project for the establishment of Water Committee and Surface Water Supply Unit.

② Conservation and Control of Development of Groundwater Resource

The water balance of the basin in the project area is estimated to be currently balanced, with the intake of groundwater held to less than the recharge. The increasing intake of groundwater in the future, however, will eventually lead to decrease of yield, gradual fall of groundwater level, land subsidence and other environmental troubles across the area, unless measures for control of groundwater intake are taken. Impact is anticipated especially on the communities of the Western Terrace area as well as Nawansher, where tubewells are already congested. As a recommendation based on the results of this study, the development of groundwater resources in the area should be controlled with a regulation that new tubewells will be allowed to be installed only at locations more than 500 m apart from existing ones.

To ensure sustainable development and conservation of groundwater resources in the future at the same time, proper ground monitoring of discharges and water levels is indispensable. Immediate action should be taken for establishing such a monitoring system by rallying all the concerned stakeholders in the area.

③ Development of water distribution network

The Project is planned to supply bulk water to the distribution reservoirs of the three existing water supply agencies, and the effect of the project can be born by the appropriate distribution of water to the service areas through the distribution networks. Therefore, execution of necessary strengthening and expansion of the existing distribution networks is required including rehabilitation of the existing pipelines where required in conjunction with the

implementation of the Project. PC-1 contains the development cost for the existing distribution networks. It is essential to implement the development of the distribution network with steadily manner.

④ Improvement of drainage system and construction of sewerage system

The improvement of water supply by increasing supply capacity results increase of waste water. It will be necessary to consider the improvement of drainage system first against waste water increase followed by the construction of sewerage system in the future to minimize the water pollution to the downstream.