

参考資料-4 タフィーラ県及びマアン県対象地域の計画給水人口及び計画給水量

タフィーラ県対象地域の計画給水人口及び計画給水量

配水区	担当配水池	計画給水人口 (人)				計画一日平均使用水量 (m3/日)			計画一日平均給水量 (m3/日)			計画一日最大給水量 (m3/日)				時間最大配水量 (m3/日) 日換算					
		2010	2015	2020	2025	2010	2015	2020	2025	2010	2015	2020	2025	2010	2015	2020	2025	2010	2015	2020	2025
Al Mansoura	Tafieleh 低区	4,199	4,577	4,978	5,351	470	573	622	669	628	674	732	787	943	1,012	1,099	1,182	1,886	2,024	2,197	2,364
Tafieleh 低区東		12,432	13,373	14,004	14,504	1,392	1,672	1,751	1,813	1,857	1,967	2,060	2,133	2,786	2,952	3,090	3,201	5,572	5,903	6,180	6,401
Tafieleh 低区西		5,859	6,363	6,917	7,429	656	795	865	928	875	936	1,018	1,092	1,313	1,405	1,527	1,639	2,627	2,810	3,054	3,278
	小計	22,490	24,313	25,899	27,284	2,519	3,040	3,238	3,411	3,359	3,577	3,809	4,013	5,043	5,369	5,716	6,022	10,085	10,737	11,432	12,043
Tafieleh 高区東	Tafieleh 高区	2,073	2,252	2,414	2,556	232	282	302	320	310	332	355	376	465	498	533	564	929	995	1,066	1,128
Tafieleh 高区西		1,464	1,599	1,739	1,868	164	200	217	234	219	235	256	275	329	354	384	413	658	707	768	825
	小計	3,537	3,851	4,153	4,424	396	482	519	553	528	567	611	651	794	851	917	977	1,587	1,702	1,834	1,953
Tafieleh 最高区	Ain-El Baidha	70	77	84	91	8	10	11	11	10	11	12	13	16	17	19	20	31	34	37	40
Sanfahah		3,450	3,762	4,089	4,394	387	471	511	549	516	554	601	646	775	833	903	971	1,551	1,666	1,805	1,941
Nemta		159	174	189	204	18	22	24	26	24	26	28	30	36	39	42	45	72	77	84	91
Ain-El Baidha-Bsaira 間		10,918	11,893	12,935	13,900	1,224	1,488	1,618	1,739	1,632	1,752	1,902	2,045	2,452	2,631	2,857	3,071	4,903	5,261	5,714	6,142
	小計	15,870	17,299	18,814	20,225	1,779	2,165	2,353	2,530	2,373	2,550	2,766	2,976	3,567	3,831	4,155	4,470	7,135	7,661	8,309	8,939
Bsaira	Bsaira	9,522	10,378	11,222	11,997	1,068	1,298	1,404	1,500	1,424	1,528	1,651	1,764	2,140	2,295	2,479	2,649	4,279	4,590	4,958	5,298
Gharandal	Gharandal	4,739	5,169	5,625	6,045	531	646	703	756	709	761	827	889	1,065	1,142	1,243	1,335	2,130	2,285	2,485	2,669
Qhadesiyeh	Qhadesiyeh	7,660	8,348	9,078	9,754	858	1,045	1,135	1,220	1,145	1,230	1,335	1,435	1,721	1,847	2,004	2,155	3,442	3,694	4,008	4,309
Erawath-Qhadesiyeh 間	Erawath ポンプ場	77	84	91	98	9	11	11	12	12	13	13	15	18	19	20	22	35	38	40	44
給水区域外		605	658	718	773	68	82	90	97	91	97	106	114	137	146	159	171	273	292	318	342
合計		64,500	70,100	75,600	80,600	7,228	8,769	9,455	10,080	9,640	10,322	11,118	11,856	14,483	15,500	16,692	17,799	28,966	30,999	33,384	35,598

マアン県対象地域の計画給水人口及び計画給水量

配水区	地域詳細	計画給水人口 (人)				計画一日平均使用水量 (m3/日)				計画一日平均給水量 (m3/日)				計画一日最大給水量 (m3/日)				時間最大配水量 (m3/日) 日換算			
		2010	2015	2020	2025	2010	2015	2020	2025	2010	2015	2020	2025	2010	2015	2020	2025	2010	2015	2020	2025
Tahoonah																					
Tahoonah0dura 中部配水区	①Odurah	2,073	2,332	2,586	2,840	423	467	491	511	603	622	634	639	906	937	952	959	1,813	1,873	1,905	1,919
	②市中部	1,742	1,955	2,164	2,373	356	391	411	427	508	521	531	534	762	782	797	802	1,524	1,565	1,594	1,603
Tahoonah 市北部中部配水区	③市中部	2,359	2,647	2,929	3,211	481	529	557	578	687	706	718	723	1,031	1,059	1,077	1,084	2,063	2,119	2,155	2,168
	④市北部	1,691	1,910	2,118	2,326	345	382	403	419	492	510	519	524	741	768	780	787	1,482	1,535	1,559	1,573
Tahoonah 旧市街配水区	⑤旧市街	12,001	12,951	13,851	14,652	2,448	2,590	2,632	2,637	3,497	3,051	3,100	3,105	5,247	4,578	4,651	4,658	10,494	9,156	9,302	9,316
Samneh																					
Samneh 南西配水区	⑧市西部	248	282	315	348	50	56	60	63	71	76	76	78	109	115	116	118	217	228	232	236
	⑥市中部	1,578	1,773	1,962	2,151	322	355	373	387	460	473	481	484	690	710	722	726	1,380	1,420	1,443	1,453
	⑩市南西部	4,036	4,528	5,014	5,500	823	906	953	990	1,176	1,207	1,230	1,238	1,766	1,812	1,846	1,858	3,532	3,624	3,692	3,717
Samneh 南東配水区	⑦旧市街	3,941	4,305	4,563	4,820	804	861	867	868	1,149	1,013	1,020	1,021	1,723	1,520	1,531	1,531	3,446	3,040	3,061	3,062
	⑨市南東部	3,131	3,517	3,898	4,279	638	703	741	770	911	938	956	963	1,370	1,410	1,436	1,447	2,739	2,820	2,871	2,893
合計		32,800	36,200	39,400	42,500	6,690	7,240	7,488	7,650	9,554	9,117	9,265	9,309	14,345	13,691	13,908	13,970	28,690	27,380	27,814	27,940

配水区別																					
Tahoonah 配水区																					
Tahoonah0dura 中部配水区	3,815	4,287	4,750	5,213	779	858	902	938	1,111	1,143	1,165	1,173	1,668	1,719	1,749	1,761	3,337	3,438	3,499	3,522	
Tahoonah 市北部中部配水区	4,050	4,557	5,047	5,537	826	911	960	997	1,179	1,216	1,237	1,247	1,772	1,827	1,857	1,871	3,545	3,654	3,714	3,741	
Tahoonah 旧市街配水区	12,001	12,951	13,851	14,652	2,448	2,590	2,632	2,637	3,497	3,051	3,100	3,105	5,247	4,578	4,651	4,658	10,494	9,156	9,302	9,316	
小計	19,866	21,795	23,648	25,402	4,053	4,359	4,494	4,572	5,787	5,410	5,502	5,525	8,687	8,124	8,257	8,290	17,376	16,248	16,515	16,579	
Samneh 配水区																					
Samneh 南西配水区	5,862	6,583	7,291	7,999	1,195	1,317	1,386	1,440	1,707	1,756	1,787	1,800	2,565	2,637	2,684	2,702	5,129	5,272	5,367	5,406	
Samneh 南東配水区	7,072	7,822	8,461	9,099	1,442	1,564	1,608	1,638	2,060	1,951	1,976	1,984	3,093	2,930	2,967	2,978	6,185	5,860	5,932	5,955	
小計	12,934	14,405	15,752	17,098	2,637	2,881	2,994	3,078	3,767	3,707	3,763	3,784	5,658	5,567	5,651	5,680	11,314	11,132	11,299	11,361	
合計	32,800	36,200	39,400	42,500	6,690	7,240	7,488	7,650	9,554	9,117	9,265	9,309	14,345	13,691	13,908	13,970	28,690	27,380	27,814	27,940	

地区別																					
Odurah	2,073	2,332	2,586	2,840	423	467	491	511	603	622	634	639	906	937	952	959	1,813	1,873	1,905	1,919	
市中部	5,679	6,375	7,055	7,735	1,159	1,275	1,341	1,392	1,655	1,700	1,730	1,741	2,483	2,551	2,596	2,612	4,967	5,104	5,192	5,224	
市北部	1,691	1,910	2,118	2,326	345	382	403	419	492	510	519	524	741	768	780	787	1,482	1,535	1,559	1,573	
旧市街	15,942	17,256	18,414	19,472	3,252	3,451	3,499	3,505	4,646	4,064	4,120	4,126	6,970	6,098	6,182	6,189	13,940	12,196	12,363	12,378	
市西部	248	282	315	348	50	56	60	63	71	76	76	78	109	115	116	118	217	228	232	236	
市南東部	3,131	3,517	3,898	4,279	638	703	741	770	911	938	956	963	1,370	1,410	1,436	1,447	2,739	2,820	2,871	2,893	
市南西部	4,036	4,528	5,014	5,500	823	906	953	990	1,176	1,207	1,230	1,238	1,766	1,812	1,846	1,858	3,532	3,624	3,692	3,717	
合計	32,800	36,200	39,400	42,500	6,690	7,240	7,488	7,650	9,554	9,117	9,265	9,309	14,345	13,691	13,908	13,970	28,690	27,380	27,814	27,940	

参考資料—5 井戸の揚水試験結果

Well Pumping Test of Water Sources in Tafieleh Project Area

IDN	Station Name	Station Name	Duration (hr)	Yield (m <sup>3</sup> /hr)	Static Water Level (m, bmp)	Pumping water Level (m, bmp)	Drawdown (m)	Specific Capacity (m <sup>3</sup> /hr/m)	Yield (m <sup>3</sup> /day)
CF3015	Al Hasa 1	WADI RUWAK 1/HASA	24	115	46.9	47.43	0.53	216.98	2,300
CF3022	Al Hasa 2	WADI RUWAK 2 /HASA 6							2,664
CF3023	Al Hasa 3	WADI RUWAK 3 /HASA 5	48	143	47.65	47.8	0.15	953.33	2,860
CF3024	Al Hasa 4	WADI RUWAK 4 /HASA 7	48	130	68	68.35	0.35	371.43	2,600
CF3025	Al Hasa 5	WADI RUWEIHI/HASA	41	165	29.3	30.8	1.5	110	3,300
CF3014	Al Hasa 6	WADI ABU DHIBA/HASA	40	113	53.7	53.85	0.15	753.33	2,260
Subtotal				666					15,984

Source: WAJ HQ Groundwater Div.

Note: The data of well IDN CF3022 is not available and yield is estimated based on the average yield of other wells in the table.

Well Pumping Test of Water Sources in Ma'an Project Area

Station ID	Station Name	Duration (hr)	Yield (m <sup>3</sup> /hr)	Static Water Level (m, bmp)	Pumping water Level (m, bmp)	Drawdown (m)	Specific Capacity (m <sup>3</sup> /hr/m)	Yield (m <sup>3</sup> /day)
<b>Tahoonah</b>								
G 3186	TAHOUNEH NO 1A	89	50	73.4	76.7	3.3	15.2	1,000
G 1265	TAHOUNEH NO 2	24	98	55.2	57.05	1.85	52.97	1,960
G 3021	TAHOUNEH NO 3	24	139	29.87	47.6	17.73	7.84	2,780
G 3005	TAHOUNEH NO 4	40	66	9.7	47.9	38.2	1.73	1,320
G 3077	TAHOUNEH NO 5	43	70	64.85	77	12.15	5.76	1,400
G 3078	TAHOUNEH NO 6	48	65	64.52	75.32	10.8	6.02	1,300
G 3148	TAHOUNEH NO 7	100	22	93.55	110.6	17.05	1.29	440
G 3178	TAHOUNEH 8	28	65	85.4	92.88	7.48	8.7	1,300
G 3179	TAHOUNEH 9	41	64	83.75	95.8	12.05	5.3	1,280
G 3181	TAHOUNEH 10	44	100	46.8	51.2	4.4	22.7	2,000
G3246	TAHOUNEH 11		60	44		72.55		1,200
Subtotal								14,980
<b>Samneh</b>								
G 4086	SAMNEH 1	72	70	59	59.7	0.7	100	1,400
G 4096	SAMNEH 2	48	91	71.8	73.8	2	0	1,820
G 4099	SAMNEH 4	50	85	47.4	0	1.65	0	1,700
G 3206	SAMNEH 5	120	75	53.2	0	2.6	0	1,500
Subtotal								6,420
Total								20,200

Source: WAJ HQ Groundwater Div.

参考資料-6 タフィーラ県の送水システムの水理計算結果

NODE					LINK							
ID	Elevation m	Head m	Demand m <sup>3</sup> /d	Pressure m	ID	Length m	Diameter mm	Roughness	Flow m <sup>3</sup> /d	Velocity m/s	Unit head loss m/km	Status
Junc 24	1309.0	1314.5	2649.0	5.5	Pipe 24	454.98	200	110	2649	0.98	7.07	Open
Junc 25	1265.0	1317.7	0.0	52.7	Pipe 25	359.08	200	100	3512	1.29	14.21	Open
Junc 26	1296.0	1312.6	3512.0	16.6	Pipe 29	2890.2	300	110	4517.87	0.74	2.64	Open
Junc 30	1250.0	1345.4	0.0	95.4	Pipe 30	10136.07	200	100	1643.13	0.61	3.48	Open
Junc 31	1250.0	1334.6	0.0	84.6	Pipe 23	1360.35	300	110	4517.87	0.74	2.64	Open
Junc 32	1255.0	1341.8	0.0	86.8	Pipe 31	2733.47	300	110	4517.87	0.74	2.64	Open
Junc 33	1250.0	1332.4	0.0	82.4	Pipe 32	2297.16	250	110	4517.87	1.07	6.4	Open
Resvr 23	1353.0	1353.0	-6161.0	0.0	Pipe 33	822.05	300	110	4517.87	0.74	2.64	Open



参考資料-7 エラワスポンプ場の水撃防止対策の分析結果

W A T E R H A M M E R A N A L Y S I S NO. P10011 PAGE 1

Qhadesiyyeh

BASIC LEVEL 1292.000 m  
DELTA T .06252 sec

【 PIPELINE DATA 】

PIPELINE NO	LENGTH m	MATERIAL	DIA. mm	THICKNESS mm	ELASTIC MODULUS (LONG.)	UPSTREAM NO.	PIPE NO.	PUMP-SURGE VALVE	CONDITION	END VALVE	LOSS PIPE-LINE	INTERVAL TIME sec	PIPELINE CONSTANT	DIVISION
001	4560.0	FC03	200	10.0	2.100	001	1	0	0	0	45.000	7.0025	35.2700	112
002	2440.0	FC03	200	10.0	2.100	001	0	0	0	0	24.000	3.7470	35.2700	60

【 PUMP DATA 】

NO	QTY	TYPE	VALVE CLOSING	MOTOR	TOTAL HEAD m	FLOWRATE m <sup>3</sup> /m	GD2 (WHEEL) KE-m2	SPEED EFF. min-1 %	START CONDITION
1	1	1	1	200.0	380.000	1.500	5.000	2950 62	HEAD FLOW RATE SPEED TORQUE

【 PIPELINE ROUTE 】

001 002

【 PROFILE OF PIPELINE 】

NO	LENGTH m	LEVEL m	LENGTH m	LEVEL m	LENGTH m	LEVEL m
001	4560.0	1290.00	2840.0	1477.90	4360.0	1566.20
	4560.0	1568.50	6320.0	1567.50	6400.0	1567.20
	6620.0	1565.50	7000.0	1582.50		


1. CALCULATION INTERVAL 4

3. PRESSURE OF PIPELINE

NO	LENGTH m	M A X			M I N				
		TIME sec	FLOW RATE m <sup>3</sup> /m	HEAD m	WATER LEVEL m	TIME sec	FLOW RATE m <sup>3</sup> /m	HEAD m	WATER LEVEL m
001	0	21.008	.000	364.120	1656.120	7.253	.000	231.059	1523.059
001	285.0	20.789	.000	364.120	1656.120	7.471	.000	231.059	1523.059
001	570.0	20.570	.000	364.120	1656.120	7.690	.000	231.059	1523.059
001	855.0	20.351	.000	364.120	1656.120	7.909	.000	231.059	1523.059
001	1140.0	20.132	.000	364.120	1656.120	8.128	.000	231.059	1523.059
001	1425.0	19.913	.000	364.120	1656.120	8.347	.000	231.059	1523.059
001	1710.0	19.694	.002	364.001	1656.001	8.566	.000	231.059	1523.059
001	1995.0	19.476	.002	363.903	1655.903	8.784	.000	231.059	1523.059
001	2280.0	19.257	.001	363.741	1655.741	9.003	.000	231.059	1523.059
001	2565.0	15.974	-.157	351.205	1643.205	5.283	.306	251.573	1543.573
001	2850.0	16.193	-.170	352.189	1644.189	5.064	.306	251.456	1543.457
001	3135.0	16.412	-.172	352.378	1644.378	4.845	.306	251.340	1543.340
001	3420.0	16.631	-.172	352.415	1644.415	4.627	.306	251.223	1543.223
001	3705.0	16.850	-.172	352.452	1644.453	4.408	.306	251.106	1543.106
001	3990.0	17.069	-.172	352.490	1644.490	4.189	.306	250.989	1542.989
001	4275.0	17.287	-.172	352.527	1644.527	3.970	.306	250.872	1542.872
002	0	17.506	-.172	352.564	1644.564	3.751	.306	250.756	1542.755
002	122.0	17.600	-.172	352.580	1644.580	7.159	.306	250.706	1542.706
002	244.0	17.694	-.172	352.595	1644.595	7.065	.306	250.656	1542.656
002	366.0	17.725	-.172	352.611	1644.611	6.971	.306	250.606	1542.606
002	488.0	17.831	-.172	352.627	1644.627	6.877	.306	250.556	1542.556
002	610.0	17.537	-.172	352.643	1644.643	6.784	.306	250.506	1542.506
002	732.0	17.444	-.172	352.659	1644.659	6.690	.306	250.456	1542.456
002	854.0	17.350	-.172	352.674	1644.675	6.596	.306	250.407	1542.407
002	976.0	17.256	-.172	352.690	1644.690	6.502	.306	250.357	1542.357
002	1098.0	17.162	-.172	352.706	1644.706	6.409	.306	250.307	1542.307
002	1220.0	17.069	-.172	352.722	1644.722	6.315	.306	250.257	1542.257
002	1342.0	16.975	-.172	352.738	1644.738	6.221	.306	250.207	1542.207
002	1464.0	16.881	-.172	352.754	1644.754	6.127	.306	250.157	1542.157

3. PRESSURE OF PIPELINE

NO	LENGTH m	M A X			M I N		
		TIME sec	FLOW RATE m <sup>3</sup> /m	HEAD m	TIME sec	FLOW RATE m <sup>3</sup> /m	HEAD m
002	1586.0	16.787	-172	352.769	6.033	.306	250.107
002	1708.0	16.693	-172	352.785	5.940	.306	250.058
002	1830.0	16.600	-172	352.801	5.846	.306	250.008
002	1952.0	16.506	-172	352.817	5.752	.306	249.958
002	2074.0	16.412	-172	352.825	5.658	.306	249.908
002	2196.0	16.318	-172	352.839	5.564	.306	249.858
002	2318.0	16.224	-261	346.979	5.471	.439	258.180
							1542.108
							1542.058
							1541.958
							1541.858
							1550.180





Qhadesiyeh with air valves

BASIC LEVEL 1292.000 m  
DELTA T .06438 sec

【 PIPELINE DATA 】

PIPELINE NO	LENGTH m	MATERIAL	THICK- DIA. mm	ELASTIC MODULUS (LONG.) mm	UPSTREAM NO.	PIPE NO.	PUMP- SURGE VALVE	END FLOW	END FLOW RATE m <sup>3</sup> /m	LOSS PIPE LINE k	END VALVE	INTERVAL TIME sec	PIPELINE CONSTANT	DIVI- SION
001	4360.0	FCD3	200	10.0	2.100	0	0	0	0	1.500	43.000	6.6954	35.2700	104
002	2640.0	FCD3	200	10.0	2.100	001	0	0	1	1.500	26.000	4.0541	35.2700	64

【 PUMP DATA 】

NO	Q'TY	TYPE	VALVE	CLOSING	NO	HEAD	FLOWRATE	MOTOR	GD2	(WHEEL)	SPEED EFF.	START CONDITION
1	1	1	1	1	0	380.000	1.500	200.0	2	0	2950	62
												HEAD FLOW RATE
												1.500
												380.000
												1.500
												1.000

【 SURGE TANK DATA 】

NO	TYPE	HEAD	AREA	LOSS	NUM.	DIS- TANCE	PIPE MATERIAL	THIC- KNES	ELASTIC MODULAS	INTERVAL TIME	PIPELINE CONSTANT	DIVI- SION	INITIAL AIR	LOSS
1	6	0	276.200	999.990	.000	3	.0	0	0	.0	.0000	0	0	.0

【 PIPELINE ROUTE 】

001 002

【 PROFILE OF PIPELINE 】

NO	LENGTH m	LEVEL m	LENGTH m	LEVEL m	LENGTH m	LEVEL m
001	0	1290.00	2840.0	1477.90	4360.0	1566.20
	4560.0	1568.50	6320.0	1567.50	6400.0	1567.20
	6620.0	1565.50	7000.0	1582.50		

1. CALCULATION INTERVAL

4

2. FLUCTUATION OF WATER LEVEL IN TANK


NO	M A X		M I N		FLUCTUATION W. LEVEL m	SECTION AREA m <sup>2</sup>	DISCHARGE FLOW m <sup>3</sup>
	HEAD m	WATER LEVEL m	HEAD m	WATER LEVEL m			
1	276.200	1568.200	276.200	1568.200	.000	999.9900	.000

3. PRESSURE OF PIPELINE

NO	LENGTH m	M A X		M I N		TIME sec	FLOW RATE m <sup>3</sup> /m	HEAD m	WATER LEVEL m
		TIME sec	FLOW RATE m <sup>3</sup> /m	HEAD m	WATER LEVEL m				
001	0	17.640	.000	353.969	1645.969	6.824	.000	240.886	1532.886
001	335.4	17.382	-.110	346.218	1638.218	6.567	-.236	257.456	1549.456
001	670.8	17.125	-.110	346.235	1638.235	6.309	-.236	257.374	1549.374
001	1006.2	16.867	-.110	346.253	1638.253	6.052	-.236	257.293	1549.292
001	1341.5	16.610	-.110	346.271	1638.271	5.794	-.236	257.211	1549.211
001	1676.9	16.352	-.108	346.408	1638.408	5.537	-.236	257.129	1549.129
001	2012.3	19.185	.130	344.656	1636.656	5.279	-.236	257.047	1549.047
001	2347.7	19.442	.130	344.631	1636.631	5.022	-.236	256.965	1548.965
001	2683.1	19.635	.103	342.683	1634.683	4.764	-.236	256.883	1548.883
001	3018.5	17.382	.022	337.144	1629.144	4.506	-.236	256.801	1548.801
001	3353.8	17.640	.020	337.244	1629.244	4.249	-.236	256.719	1548.719
001	3689.2	17.897	.022	337.150	1629.150	3.991	-.236	256.637	1548.637
001	4024.6	18.155	.022	337.150	1629.150	3.734	-.236	256.555	1548.555
002	0	20.923	.201	335.170	1627.170	3.605	.638	276.200	1568.200
002	165.0	21.116	-.234	336.180	1628.180	7.339	-.638	275.906	1567.906
002	330.0	21.245	-.234	336.140	1628.140	7.210	-.638	275.612	1567.612
002	495.0	21.374	-.234	336.100	1628.100	7.082	-.638	275.318	1567.318
002	660.0	21.502	-.234	336.060	1628.060	6.953	-.638	275.024	1567.024
002	825.0	21.631	-.234	336.021	1628.021	6.824	-.638	274.730	1566.730
002	990.0	20.151	.121	329.496	1621.496	6.695	-.638	274.436	1566.436
002	1155.0	20.022	.121	329.485	1621.485	6.567	-.638	274.142	1566.142
002	1320.0	19.893	.121	329.474	1621.474	6.438	-.638	273.848	1565.848
002	1485.0	19.764	.121	329.464	1621.464	6.309	-.638	273.553	1565.553

3. PRESSURE OF PIPELINE

NO	LENGTH m	M A X			M I N		
		TIME SEC	FLOW RATE m <sup>3</sup> /m	HEAD m	TIME SEC	FLOW RATE m <sup>3</sup> /m	HEAD m
002	1650.0	19.764	.126	329.121	6.180	273.259	1565.260
002	1815.0	19.829	.133	328.964	6.052	272.965	1564.965
002	1980.0	19.957	.133	328.950	5.923	272.671	1564.671
002	2145.0	20.086	.133	328.937	5.794	272.377	1564.377
002	2310.0	20.215	.133	328.924	5.665	272.083	1564.083
002	2475.0	20.344	.133	328.912	5.537	271.789	1563.789



Gharandal(without flywheel)

BASIC LEVEL 1292.000 m  
DELTA T .09076 sec

【 PIPELINE DATA 】

PIPELINE NO	LENGTH m	MATERIAL	DIA. mm	THICKNESS mm	ELASTIC MODULUS (LONG.)	UPSTREAM PIPE NO.	PUMP SURGE VALVE	CONDITION	END FLOW RATE m <sup>3</sup> /m	PIPE LINE LOSS	END VALVE	INTERVAL TIME sec	PIPELINE DIVISION
001	3710.0	FC03	150	6.0	1.600	1	0	0	0	1	.950	48.000	59.6353

【 PUMP DATA 】

NO	QTY	TYPE	VALVE CLOSING	MOTOR kW	POLE TYPE	GD2 kg-m <sup>2</sup>	GD2 (WHEEL) kg-m <sup>2</sup>	SPEED EFF. %	START CONDITION
1	1	1	1	80.0	2	0	3.000	2950	HEAD FLOW RATE m <sup>3</sup> /m
								56	230.000
									1.000
									1.000
									1.000

【 PIPELINE ROUTE 】


001

【 PROFILE OF PIPELINE 】

NO	LENGTH m	LEVEL m	LENGTH m	LEVEL m	LENGTH m	LEVEL m
001	1290.00	1290.00	1390.0	1385.00	1550.0	1379.00
	1630.0	1382.00	2170.0	1397.30	2410.0	1380.40
	2550.0	1402.40	2830.0	1415.00	3050.0	1416.00
	3210.0	1410.00				

1. CALCULATION INTERVAL  
3. PRESSURE OF PIPELINE

NO	LENGTH m	M A X			M I N				
		TIME sec	FLOW RATE m <sup>3</sup> /m	HEAD m	WATER LEVEL m	TIME sec	FLOW RATE m <sup>3</sup> /m	HEAD m	WATER LEVEL m
001	0	11.980	.000	225.269	1517.269	.726	.000	116.693	1408.693
001	337.3	11.708	.000	225.269	1517.269	5.718	.000	116.693	1408.693
001	674.5	11.436	.000	225.269	1517.269	5.446	.000	116.693	1408.693
001	1011.8	11.164	.000	225.269	1517.269	5.173	.000	116.693	1408.693
001	1349.1	10.891	.000	225.269	1517.269	4.901	.000	116.693	1408.693
001	1686.4	10.619	.000	225.269	1517.269	4.629	.000	116.693	1408.693
001	2023.6	10.347	.000	225.269	1517.269	4.357	.000	116.693	1408.693
001	2360.9	10.074	.000	225.269	1517.269	4.084	.000	116.693	1408.693
001	2698.2	9.802	.000	225.269	1517.269	3.812	.000	116.693	1408.693
001	3035.5	9.530	.000	225.269	1517.269	3.540	.000	116.693	1408.693
001	3372.7	9.348	.005	221.987	1513.987	3.358	-.012	124.093	1416.093



Gharandal (with flywheel)

BASIC LEVEL 1292.000 m  
DELTA T .29951 sec

【 PIPELINE DATA 】

PIPELINE NO	LENGTH m	MATERIAL	DIA. mm	THICKNESS mm	ELASTIC MODULUS (LONG.)	UPSTREAM PIPE NO.	PUMP-SURGE VALVE	CONDITION	END FLOW RATE m <sup>3</sup> /m	LOSS PIPE-LINE	END VALVE	INTERVAL TIME sec	PIPELINE CONSTANT	DIVISION
001	3710.0	FCD3	150	6.0	1.600	1	0	0	0	1	.950	48.000	59.6353	20

【 PUMP DATA 】

NO	Q	TYPE	VALVE CLOSING	V-NO	TOTAL HEAD m	FLOWRATE m <sup>3</sup> /m	MOTOR kW	POLE	TYPE	GD2 kg-m <sup>2</sup>	(WHEEL) %	SPEED EFF. m/d-1	START CONDITION HEAD m	FLOW RATE m <sup>3</sup> /m	SPEED TORQUE
1	1	1	1	0	230.000	.950	80.0	2	0	3.000	7.000	2950	230.000	.950	1.000

【 PIPELINE ROUTE 】

001

【 PROFILE OF PIPELINE 】


NO	LENGTH m	LEVEL m	LENGTH m	LEVEL m	LENGTH m	LEVEL m
001	0	1290.00	950.0	1360.00	1390.0	1385.00
	1930.0	1382.00	1790.0	1375.00	2170.0	1397.30
	2550.0	1402.40	2770.0	1417.30	2830.0	1415.00
	3210.0	1410.00	3710.0	1472.00	3050.0	1416.00



1. CALCULATION INTERVAL 4

3. PRESSURE OF PIPELINE

NO	LENGTH m	M A X			M I N				
		TIME sec	FLOW RATE m <sup>3</sup> /m	HEAD m	WATER LEVEL m	TIME sec	FLOW RATE m <sup>3</sup> /m	HEAD m	WATER LEVEL m
001	.0	11.980	.000	225.269	1517.269	2.396	.000	116.693	1408.693
001	185.5	11.831	.000	225.269	1517.269	5.840	.000	116.693	1408.693
001	371.0	11.681	.000	225.269	1517.269	5.691	.000	116.693	1408.693
001	556.5	11.531	.000	225.269	1517.269	5.541	.000	116.693	1408.693
001	742.0	11.381	.000	225.269	1517.269	5.391	.000	116.693	1408.693
001	927.5	11.232	.000	225.269	1517.269	5.241	.000	116.693	1408.693
001	1113.0	11.082	.000	225.269	1517.269	5.092	.000	116.693	1408.693
001	1298.5	10.932	.000	225.269	1517.269	4.942	.000	116.693	1408.693
001	1484.0	10.782	.000	225.269	1517.269	4.792	.000	116.693	1408.693
001	1669.5	10.633	.000	225.269	1517.269	4.642	.000	116.693	1408.693
001	1855.0	10.483	.000	225.269	1517.269	4.493	.000	116.693	1408.693
001	2040.5	10.333	.000	225.269	1517.269	4.343	.000	116.693	1408.693
001	2226.0	10.183	.000	225.269	1517.269	4.193	.000	116.693	1408.693
001	2411.5	10.034	-.013	223.717	1515.717	4.043	.030	120.188	1412.188
001	2597.0	10.183	.003	221.782	1513.781	4.193	-.007	124.540	1416.540
001	2782.5	10.034	-.030	217.860	1509.860	4.043	.058	132.157	1424.157
001	2968.0	10.183	.003	213.839	1505.839	4.193	-.006	139.954	1431.954
001	3153.5	10.034	-.048	207.828	1499.828	4.043	.075	149.298	1441.298
001	3339.0	10.183	.005	201.409	1493.408	4.193	-.007	159.269	1451.269
001	3524.5	10.034	-.075	192.159	1484.159	4.043	.088	170.181	1462.181



## ウオータハンマ防止装置

### 1 Parmakianの簡易計算図表より検証をした。

電算機により以下の図の作成をした。

- ・配管縦断及び動水勾配線の作成
  - ・最低圧力勾配線の作成
  - ・概略再最高圧力勾配線図の作成
  - ・上記の図表より負圧地点をチェックする
  - ・電動機の出力からポンプの慣性時係数の算出
  - ・フライホイールの大きさの算定をする
- 以上添付図の電算機による表計算結果を参照

### 2 フライホイールの大きさ決定

フライホイールの外径、 $D_2$ は以下の式よりもとめる。

$$V = (\Pi \times D_2 \times N) / 60$$

ここに、

V: 周速 (m/sec.) 60m/secとする

N: 回転速度 (min<sup>-1</sup>) 2950 (ポンプ回転数)

$$60 = (3.14 \times D_2 \times 2950) / 60$$

$$D_2 = 0.39 \text{ m}$$

フライホイールの自重W(kgf)は以下の式から求める

$$GD_2 = (W \times (D_1^2 + D_2^2)) / 2$$

ここに、

$GD_2$ : 7kgf・m<sup>2</sup> (表解析から電算機の簡易計算により求められたフライホイールの慣性効果)

$D_1$ : フライホイールの内径 (m) 0.05とする

W: フライホイールの自重 (kgf)

$$7 = W \times 0.08125$$

$$W = 86.15 \text{ kgf}$$

フライホイールの厚さBは以下の式より求める

$$W = \Pi \times (D_2^2 - D_1^2) \times B \times G$$

ここに、

W: フライホイールの自重86.15 (kgf)

$D_1$ : フライホイールの内径 (m) 0.05とする

$\Pi$ : 円周率3.14

G: 単位厚席当たりの重量 = 7800 kgf/m<sup>3</sup>

$$86.15 = (3.14 \times 0.1575 \times 7800 \times B) / 4$$

$$B = 0.089 \text{ m}$$

以上の数値よりフライホイールの外形はおおよそ40cm直径、厚さ10cmとなる。
















ID	Length m	Diameter mm	Roughness	Flow m <sup>3</sup> /d	Velocity m/s	Unit head loss m/km	Status
Pipe 542	83.06	20	110	-5.33	0.2	5.33	Open
Pipe 543	84.99	25	110	12.25	0.29	8.39	Open
Pipe 544	79.28	50	110	61.15	0.36	5.63	Open
Pipe 545	40.76	50	110	42.18	0.25	2.83	Open
Pipe 546	34	50	110	21.85	0.13	0.84	Open
Pipe 547	53.42	25	110	4.8	0.11	1.48	Open
Pipe 548	85.33	50	110	71.41	0.42	7.51	Open
Pipe 549	42.23	200	110	2721.02	1	7.43	Open
Pipe 550	40.61	200	110	2711.35	1	7.38	Open
Pipe 551	83.82	200	110	2663.6	0.98	7.14	Open
Pipe 552	89.13	25	110	30	0.71	44.08	Open
Pipe 553	95.5	25	110	15	0.35	12.21	Open
Pipe 554	58.38	25	110	31.5	0.74	48.24	Open
Pipe 555	66.91	25	110	26.7	0.63	35.52	Open
Pipe 556	154.57	25	110	21.9	0.52	24.61	Open
Pipe 557	54.42	25	110	31.7	0.75	48.81	Open
Pipe 558	65.21	25	110	31.7	0.75	48.81	Open
Pipe 559	126.87	50	110	-64.29	0.38	6.12	Open
Pipe 561	64.33	25	110	34.5	0.81	57.1	Open
Pipe 562	115.86	50	110	-98.79	0.58	13.64	Open
Pipe 563	91.44	50	110	-133.29	0.79	23.79	Open
Pipe 564	41.87	100	110	29.07	0.04	0.05	Open
Pipe 565	68.69	150	110	835.69	0.55	3.39	Open
Pipe 566	129.22	25	110	-5.47	0.13	1.89	Open
Pipe 567	123.05	25	110	-17.47	0.41	16.19	Open
Pipe 568	108.76	25	110	6	0.14	2.24	Open
Pipe 569	34.39	100	110	596.78	0.88	13.08	Open
Pipe 129	88.45	25	110	14.1	0.33	10.89	Open
Pipe 146	74.27	25	110	14.1	0.33	10.89	Open
Valve 147	#N/A	100	#N/A	603.1	0.89	38.7	Active
Valve 336	#N/A	100	#N/A	783.7	1.15	30.38	Active
Valve 351	#N/A	100	#N/A	273.5	0.4	33.77	Active
Valve 310	#N/A	100	#N/A	766.1	1.13	13.06	Active








ID	Elevation m	Head m	Demand m3/d	Pressure m
Junc 178	1155.0	1195.2	18.3	40.2
Junc 179	1103.0	1154.6	14.7	51.6
Junc 180	1095.0	1157.3	14.7	62.3
Junc 181	1060.0	1090.1	38.8	30.1
Junc 182	1060.0	1090.9	74.6	30.9
Junc 183	1067.0	1103.5	59.1	36.5
Junc 184	1045.0	1086.6	38.8	41.6
Junc 185	1000.0	1084.5	10.8	84.5
Junc 186	1220.0	1269.3	16.2	49.3
Junc 187	1130.0	1198.0	27.1	68.0
Junc 188	1130.0	1160.0	27.1	30.0
Junc 189	1245.0	1291.1	9.0	46.1
Junc 191	1245.0	1298.1	9.0	53.1
Junc 192	1255.0	1298.1	9.0	43.1
Junc 193	1225.0	1285.7	10.6	60.7
Junc 194	1245.0	1293.1	12.3	48.1
Junc 195	1255.0	1293.9	12.3	38.9
Junc 196	1215.0	1284.7	10.6	69.7
Junc 197	1265.0	1298.7	9.0	33.7
Junc 54	1265.0	1298.8	9.0	33.8
Junc 145	1280.0	1298.7	23.0	18.7
Junc 190	1288.0	1298.2	18.0	10.2
Junc 198	1275.0	1291.2	11.3	16.2
Resvr 108	1305.0	1305.0	-5220.3	0.0

ID	Length m	Diameter mm	Roughness	Flow m3/d	Velocity m/s	Unit head loss m/km	Status
Pipe 206	74.5	25	110	14.7	0.4	11.7	Open
Pipe 207	50.1	50	110	135.9	0.8	24.7	Open
Pipe 208	167.6	25	110	-11.4	0.3	7.3	Open
Pipe 209	12.1	100	110	434.4	0.6	7.3	Open
Pipe 210	68.2	100	110	419.7	0.6	6.8	Open
Pipe 211	83.8	100	110	390.4	0.6	6.0	Open
Pipe 212	142.3	25	110	10.8	0.3	6.6	Open
Pipe 213	141.7	50	110	272.2	1.6	89.5	Open
Pipe 214	16.2	50	110	158.9	0.9	33.0	Open
Pipe 215	67.5	25	110	60.8	1.4	163.1	Open
Pipe 216	71.8	50	110	174.7	1.0	39.3	Open
Pipe 217	18.8	50	110	142.7	0.8	27.1	Open
Pipe 218	125.2	50	100	120.1	0.7	23.5	Open
Pipe 219	103.8	50	100	81.4	0.5	11.4	Open
Pipe 220	162.9	50	110	331.3	2.0	128.7	Open
Pipe 221	36.9	50	110	-51.0	0.3	4.0	Open
Pipe 222	11.1	150	100	2209.9	1.5	24.5	Open
Pipe 223	72.8	50	110	42.5	0.3	2.9	Open
Pipe 224	83.5	50	110	21.3	0.1	0.8	Open
Pipe 225	199.5	20	110	12.3	0.5	25.1	Open
Pipe 226	168.7	20	110	12.3	0.5	25.1	Open
Pipe 227	140.0	25	110	33.6	0.8	54.4	Open
Pipe 228	174.8	25	110	24.7	0.6	30.7	Open
Pipe 229	91.2	25	110	14.1	0.3	10.8	Open
Pipe 230	165.8	20	110	-3.5	0.1	2.4	Open
Pipe 15	77.1	100	110	266.9	0.4	3.0	Open
Pipe 16	71.9	100	110	235.0	0.4	2.3	Open
Pipe 34	182.3	50	110	23.0	0.1	0.9	Open
Pipe 39	227.3	50	110	18.0	0.1	0.6	Open
Pipe 43	238.0	25	110	11.3	0.3	7.2	Open
Pipe 45	15.0	50	110	197.6	1.2	49.5	Open
Valve 115	#N/A	200	#N/A	2835.2	1.0	36.0	Active
Valve 52	#N/A	100	#N/A	568.4	0.8	30.8	Active
Valve 65	#N/A	100	#N/A	699.2	1.0	21.1	Active
Valve 88	#N/A	200	#N/A	3962.6	1.5	4.4	Active
Valve 92	#N/A	200	#N/A	3468.0	1.3	30.6	Active
Valve 105	#N/A	100	#N/A	405.1	0.6	32.3	Active
Valve 116	#N/A	200	#N/A	2182.8	0.8	38.0	Active







ID	Elevation m	Demand m3/d	Head m	Pressure m
Junc 95	1405.0	1465.1	13.2	60.1
Junc 96	1403.0	1464.9	12.4	61.9
Junc 97	1410.0	1461.7	12.4	51.7
Junc 98	1370.0	1426.4	19.2	56.4
Junc 99	1310.0	1340.7	10.6	30.7
Junc 100	1303.0	1341.8	14.1	38.8
Junc 101	1300.0	1341.5	23.5	41.5
Junc 102	1300.0	1341.1	23.5	41.1
Junc 103	1312.0	1338.9	14.1	26.9
Junc 104	1320.0	1338.7	23.5	18.7
Junc 105	1260.0	1341.0	11.3	81.0
Junc 106	1275.0	1341.9	11.3	66.9
Junc 107	1277.0	1342.3	45.9	65.3
Junc 108	1385.0	1430.9	12.4	45.9
Junc 109	1355.0	1419.1	21.4	64.1
Junc 110	1325.0	1416.0	10.6	91.0
Junc 111	1343.0	1395.7	28.9	52.7
Junc 112	1337.0	1395.0	21.2	58.0
Junc 113	1335.0	1394.8	32.0	59.8
Junc 114	1358.0	1397.3	32.0	39.3
Junc 115	1353.0	1397.8	34.7	44.8
Junc 116	1360.0	1398.5	34.7	38.5
Junc 117	1358.0	1398.8	34.7	40.8
Junc 118	1353.0	1398.1	34.7	45.1
Junc 120	1357.0	1397.0	43.6	40.0
Junc 121	1350.0	1395.0	43.6	45.0
Junc 122	1343.0	1394.4	48.9	51.4
Junc 123	1355.0	1395.0	43.6	40.0
Junc 124	1335.0	1365.6	48.9	30.6
Junc 125	1353.0	1393.8	22.1	40.8
Junc 126	1345.0	1393.8	22.1	48.8
Junc 127	1345.0	1394.2	43.6	49.2
Junc 128	1338.0	1430.8	22.1	92.8
Junc 129	1360.0	1393.2	22.1	33.2
Junc 130	1375.0	1428.0	15.9	53.0
Junc 131	1368.0	1393.1	4.6	25.1
Junc 132	1370.0	1392.4	15.9	22.4
Junc 133	1362.0	1393.0	15.9	31.0
Junc 134	1390.0	1429.9	15.9	39.9
Junc 135	1370.0	1392.1	15.9	22.1
Junc 26	1360.0	1466.6	0.0	106.6
Resvr 57	1470.0	1470.0	-2597.9	0.0


ID	Length m	Diameter mm	Roughness	Flow m3/d	Velocity m/s	Unit head loss m/km	Status
Pipe 105	243.8	25	110	-19.2	0.5	19.3	Open
Pipe 106	121.2	50	110	120.2	0.7	19.7	Open
Pipe 107	149.4	25	110	7.1	0.2	3.1	Open
Pipe 108	64.9	50	110	57.6	0.3	5.1	Open
Pipe 109	184.2	25	110	9.1	0.2	4.8	Open
Pipe 110	206.2	25	110	-2.2	0.1	0.4	Open
Pipe 111	102.8	50	110	-49.3	0.3	3.8	Open
Pipe 112	107.4	50	110	-42.5	0.3	2.9	Open
Pipe 113	166.5	25	110	10.6	0.3	6.4	Open
Pipe 114	85.8	50	110	67.2	0.4	6.7	Open
Pipe 115	137.9	50	110	44.4	0.3	3.1	Open
Pipe 116	83.5	25	110	23.5	0.6	28.1	Open
Pipe 117	237.8	25	110	32.0	0.8	49.6	Open
Pipe 118	164.5	20	110	10.6	0.4	19.0	Open
Pipe 119	127.7	50	110	209.6	1.2	55.1	Open
Pipe 120	79.6	20	110	14.1	0.5	32.3	Open
Pipe 122	22.9	200	110	1593.9	0.6	2.8	Open
Pipe 123	133.5	25	110	12.3	0.3	8.5	Open
Pipe 124	139.9	25	110	15.9	0.4	13.6	Open
Pipe 125	67.8	50	110	74.4	0.4	8.1	Open
Pipe 126	79.5	25	110	4.6	0.1	1.4	Open
Pipe 127	56.9	50	110	47.7	0.3	3.6	Open
Pipe 128	65.5	25	110	15.9	0.4	13.6	Open
Pipe 129	44.1	25	110	15.9	0.4	13.6	Open
Pipe 130	108.5	25	110	18.6	0.4	18.1	Open
Pipe 131	81.3	50	110	70.9	0.4	7.4	Open
Pipe 132	88.0	50	110	11.1	0.1	0.2	Open
Pipe 133	79.0	50	110	79.1	0.5	9.1	Open
Pipe 134	124.3	50	110	107.0	0.6	15.9	Open
Pipe 135	104.0	50	110	152.5	0.9	30.6	Open
Pipe 136	104.6	50	110	111.6	0.7	17.2	Open
Pipe 138	129.1	50	110	82.1	0.5	9.7	Open
Pipe 139	59.1	50	110	69.7	0.4	7.2	Open
Pipe 140	88.0	50	110	44.4	0.3	3.1	Open
Pipe 141	88.7	25	110	9.7	0.2	5.5	Open
Pipe 142	106.5	25	110	-9.1	0.2	4.8	Open
Pipe 143	96.9	25	110	-9.4	0.2	5.1	Open
Pipe 144	57.1	50	110	57.3	0.3	5.0	Open
Pipe 145	129.3	25	110	13.2	0.3	9.7	Open
Pipe 146	65.3	50	110	-84.7	0.5	10.3	Open
Pipe 147	76.8	50	110	26.7	0.2	1.2	Open
Pipe 148	91.6	50	110	57.5	0.3	5.0	Open
Pipe 149	44.0	50	110	35.4	0.2	2.0	Open
Pipe 150	110.2	150	110	810.0	0.5	3.2	Open
Pipe 151	72.8	50	110	40.6	0.2	2.6	Open
Pipe 152	304.6	50	110	174.1	1.0	39.1	Open
Pipe 153	172.1	50	110	53.2	0.3	4.4	Open
Pipe 154	116.0	50	110	32.0	0.2	1.7	Open
Pipe 1	167.1	50	110	132.7	0.8	23.6	Open
Pipe 2	97.5	50	110	168.5	1.0	36.8	Open
Pipe 3	329.9	100	110	236.2	0.4	2.4	Open
Pipe 4	359.4	50	110	-236.2	1.4	68.8	Open
Valve 84	#N/A	200	#N/A	1609.7	0.6	33.8	Active
Valve 88	#N/A	100	#N/A	384.8	0.6	27.0	Active
Valve 19	#N/A	100	#N/A	316.8	0.5	26.7	Active
Valve 64	#N/A	200	#N/A	2261.6	0.8	31.2	Active
Valve 121	#N/A	100	#N/A	285.1	0.4	24.2	Active







ID	Elevation m	Head m	Demand m <sup>3</sup> /d	Pressure m	ID	Length m	Diameter mm	Roughness	Flow m <sup>3</sup> /d	Velocity m/s	Unit head loss m/km	Status
Junc 174	1405.0	1455.8	10.0	50.8	Pipe 207	147.1	25	110	5.5	0.1	1.9	Open
Junc 175	1395.0	1454.4	20.0	59.4	Pipe 208	120.4	25	110	-14.5	0.3	11.5	Open
Junc 176	1405.0	1457.2	10.0	52.2	Pipe 209	51.4	25	110	6.9	0.2	2.9	Open
Junc 177	1565.0	1592.4	30.0	27.4	Pipe 210	95.6	20	110	5.0	0.2	4.7	Open
Junc 178	1545.0	1591.7	5.0	46.7	Pipe 211	147.9	50	110	120.2	0.7	19.7	Open
Junc 179	1535.0	1588.8	5.0	53.8	Pipe 212	85.1	50	110	100.2	0.6	14.1	Open
Junc 180	1400.0	1448.4	10.0	48.4	Pipe 213	108.0	50	110	72.6	0.4	7.7	Open
Junc 181	1420.0	1448.9	10.0	28.9	Pipe 214	120.2	20	110	10.0	0.4	17.1	Open
Junc 182	1420.0	1450.4	10.0	30.4	Pipe 215	89.4	25	110	17.6	0.4	16.4	Open
Junc 183	1430.0	1445.2	10.0	15.2	Pipe 216	93.5	25	110	-2.4	0.1	0.4	Open
Junc 184	1420.0	1435.6	10.0	15.6	Pipe 217	69.4	25	110	-12.4	0.3	8.6	Open
Junc 185	1360.0	1432.8	10.0	72.8	Pipe 218	90.8	20	110	10.0	0.4	17.1	Open
Junc 186	1450.0	1479.4	10.0	29.4	Pipe 220	95.2	25	110	20.0	0.5	20.8	Open
Junc 187	1380.0	1443.0	20.0	63.0	Pipe 221	241.8	20	110	5.0	0.2	4.7	Open
Junc 188	1365.0	1437.6	20.0	72.6	Pipe 222	139.8	20	110	5.0	0.2	4.7	Open
Junc 189	1380.0	1435.1	10.0	55.1	Pipe 223	104.2	200	110	3992.4	1.5	15.1	Open
Junc 190	1455.0	1518.6	0.0	63.6	Pipe 224	164.9	200	110	3957.4	1.5	14.9	Open
Junc 191	1455.0	1485.0	0.0	30.0	Pipe 225	66.8	25	110	29.7	0.7	43.2	Open
Junc 103	1465.0	1519.1	0.0	54.1	Pipe 226	153.6	20	110	10.0	0.4	17.1	Open
Junc 106	1465.0	1519.1	0.0	54.1	Pipe 227	124.5	20	110	10.0	0.4	17.1	Open
Resvr 99	1601.0	1601.0	-4307.1	0.0	Pipe 228	207.9	50	110	46.0	0.3	3.3	Open
					Pipe 229	371.6	25	110	26.0	0.6	33.8	Open
					Pipe 230	302.6	20	110	10.0	0.4	17.1	Open
					Pipe 231	127.9	20	110	10.0	0.4	17.1	Open
					Pipe 232	131.6	20	110	10.0	0.4	17.1	Open
					Pipe 233	150.9	20	110	10.0	0.4	17.1	Open
					Pipe 235	146.6	20	110	10.0	0.4	17.1	Open
					Pipe 236	149.2	50	110	157.8	0.9	32.6	Open
					Pipe 237	212.7	50	110	137.8	0.8	25.4	Open
					Pipe 238	83.3	50	110	107.8	0.6	16.1	Open
					Pipe 4	116.7	50	110	-18.1	0.1	0.6	Open
					Pipe 13	141.0	100	110	258.0	0.4	2.8	Open
					Pipe 17	221.2	100	110	228.0	0.3	2.2	Open
					Pipe 27	103.6	100	110	285.2	0.4	3.3	Open
					Pipe 35	162.0	150	110	1428.8	0.9	9.2	Open
					Pipe 39	110.7	150	110	1323.5	0.9	7.9	Open
					Pipe 48	44.0	50	110	-54.2	0.3	4.5	Open
					Pipe 49	102.2	100	110	285.2	0.4	3.3	Open
					Pipe 54	144.4	100	110	285.2	0.4	3.3	Open
					Pipe 24	4.3	100	110	285.2	0.4	3.3	Open
					Valve 6	#N/A	200	#N/A	3747.1	1.4	26.7	Active
					Valve 107	#N/A	100	#N/A	475.6	0.7	23.6	Active
					Valve 108	#N/A	200	#N/A	3524.9	1.3	30.3	Active
					Valve 111	#N/A	150	#N/A	676.0	0.4	35.9	Active
					Valve 113	#N/A	150	#N/A	1323.5	0.9	33.6	Active
					Valve 18	#N/A	100	#N/A	285.2	0.4	33.6	Active



## 参考資料-9 土壌の腐食性試験結果

### (1) 腐食性判定結果

腐食性判定結果を次表に示す。点数が 10 点以上になると鑄鉄管に対しては腐食性を示すため防食対策が必要である。なお、参考のため、電蝕土壌腐食ハンドブックの比抵抗値による腐食性を参考のため下表に示す。

#### 腐食性の判定

	比抵抗値 ( $\Omega$ -cm)	Redox	硫酸塩	水分	pH 値	判定
タフィーラ県タフィーラ市 (病院) R-1	1600~3400 やや激しい腐食度 0点~8点	無測定	痕跡 2点	乾燥 0点	強アルカリ性 腐食性 3点	5~13点
タフィーラ県タフィーラ市 (病院) R-3 (漏水頻繁発生箇所)	1600~3800 やや激しい腐食度 0点~8点	無測定	痕跡 2点	乾燥 0点	強アルカリ性 腐食性 3点	5~13点
ブセイラ R-2	1600~3200 やや激しい腐食度 0点~8点	無測定	痕跡 2点	乾燥 0点	強アルカリ性 腐食性 3点	5~13点

#### 土壌比抵抗による腐食程度

腐食性	比抵抗値 ( $\Omega$ -cm)	例えの土壌
激しい	0~1,000	腐葉土 沼地
やや激しい	1,000~5,000	畑 (誘導性薬品のある場所)
中程度	5,000~10,000	一般土壌 黒土 畑
小程度	10,000~100,000	乾燥土 小石まじりの土
極めて小程度	100,000以上	火山灰 砂利層

電蝕土壌腐食ハンドブックより

### (2) 腐食性試験結果

#### Electrical Resistivity Survey

An electrical resistivity survey was conducted along the axis, assigned by the project study team, and as indicated on the drawings as required utilizing the Wenner configuration with the following spacings  $a = 1\text{m}, 2\text{m}, 3\text{m}, 4\text{m}$  and  $5\text{m}$ . This implies the following depths of penetration ( $h$ ) =  $0.6\text{m}, 1.2\text{m}, 1.8\text{m}, 2.4\text{m}$  and  $3\text{m}$  in successive order.

This resistivity meter measures the voltage difference between the potential electrode pair in response to an "AC" current (=  $200\text{mA}; 10\text{-}40\text{-Hz}$ ) driven into the ground via the pair of current electrodes. The

resistance between the potential electrodes is determined via an interval bridge circuit in which a resistance is altered using potentiometer to give the same output voltage as measured across the potential electrodes. The " $\rho_a$ " for the ground under the center (ground) electrode is then calculated from the measured resistance which in turn depends on the electrode geometrical factor this being " $a$ " for a Wenner configuration.

The complete ERP field equipment consists of:

1. A YEW 3244 Resistivity Meter Box containing an AC potentiometer, a voltmeter and galvanometer.
2. Five steel electrodes each 10 cm in length.
3. External 12 V-DC/30 AH Car Storage liquid battery.
4. Two 330m and two 110m measuring lead wires.

The specifications of the YEW Resistivity Meter are:

Range 0-30 ohm; 0.5 ohm/division

(Multiplier dials: x0.01, x1.0, x10).

Accuracy :  $\pm 1\%$  of full scale value below 10 ohms.  
 $\pm 3\%$  of indicated value between 10-30 ohms.

O/P Voltage: Setting dials 150,300 and 600 V-DC.

Current : Up to 200 mA.

Frequency : 10-40 Hz.

The measured resistance at each electrode spacing represents the average resistance of the earth material between the earth's surface and a depth equal to about 2/3 of the current electrode spacing. At all measuring points both the electric current (I) and the voltage (V) were changed and the resistance was calculated

$$\text{As } R \text{ (ohms)} = V \text{ (volt)} / I \text{ (ampere)} \dots \dots \dots (1)$$

Laboratory testing on three samples from test pits were assigned by the project study team. The laboratory tests include the soil corrosive testing to aid in checking the corrosive potential of soil along the proposed pipelines route. The laboratory tests were conducted according to the following Standards:

No.	Type of Tests	Reference Standards	Number of Tests
1.	Moisture Content Determination	ASTM D 2216	3
2.	Chloride Content of Soil	BS: 1377, Part 3	3
3.	Sulphate Content of Soil	BS: 1377, Part 3	3
4.	pH value of Soil	BS: 1377, Part 3	3



(1) Results of Tafieleh

**Soil Resistivity Measurement  
At T.P. 1A / Along Axis R1-R1**

Axis	Electrodes Spacing a (m)	Electrodes Depth, B (cm)	Voltage (V)	Current (mA)	Resistance Readings (R)	Specific Earth Resistance $\{(\Omega\text{-m})\}$
	1	10	12.0	150	2.5	16
	2	10	12.0	140	2.0	25
	3	10	12.0	160	1.8	34
	4	10	12.0	130	1.0	25
	5	10	12.0	100	0.5	16

**Soil Resistivity Measurement  
At T.P. 2A / Along Axis R2-R2**

Axis	Electrodes Spacing a (m)	Electrodes Depth, B (cm)	Voltage (V)	Current (mA)	Resistance Readings (R)	Specific Earth Resistance $\{(\Omega\text{-m})\}$
	1	10	12.0	140	3.0	19
	2	10	12.0	130	2.0	25
	3	10	12.0	160	1.7	32
	4	10	12.0	140	0.75	19
	5	10	12.0	100	0.5	16

**Soil Resistivity Measurement  
At T.P. 3A / Along Axis R3-R3**

Axis	Electrodes Spacing a (m)	Electrodes Depth, B (cm)	Voltage (V)	Current (mA)	Resistance Readings (R)	Specific Earth Resistance $\{(\Omega\text{-m})\}$
	1	10	12.0	140	3.5	22
	2	10	12.0	130	2.7	34
	3	10	12.0	150	2.0	38
	4	10	12.0	140	1.0	25
	5	10	12.0	140	0.5	16

Summary sheets of laboratory tests results are tabulated in Figure (3).

**GEOTECHNICAL ENGINEERING & MATERIALS TESTING CO.**  
**Summary of Tests Results**

**Site Investigation**  
**For**  
**The Project Of Rehabilitation And Expansion Of**  
**Water Facilities**  
**In Southern Governorates Of Tafieleh And Ma'an / Jordan**  
**(For Tafieleh Site)**

Job No. : S2010/C20/06-F2

Test Pit No.	Depth (m)	Moisture Content (%)	Grain Size Analysis				Atterberg Limits			Chloride (Cl) (%)	Sulphate (SO <sub>4</sub> ) (%)	pH value	Remarks
			Gravel (%)	Sand (%)	Silt (%)	Clay (%)	LL (%)	PL (%)	PI (%)				
TP 1A	1.0	3.6								0.0732	0.0355	9.182	
TP 2A	1.0	4.2								0.0576	0.0320	9.132	
TP 3A	1.0	3.3								0.0512	0.0213	8.991	

G.E.M.T

FIGURE 3

**(2) Results of Ma'an**

**Soil Resistivity Measurement**  
**At T.P. 3 / Along Axis R1-R1**

Axis	Electrodes Spacing a (m)	Electrodes Depth, B (cm)	Voltage (V)	Current (mA)	Resistance Readings (R)	Specific Earth Resistance {(Ω-m)}
	1	10	12.0	150	3.0	19
	2	10	12.0	130	1.5	19
	3	10	12.0	150	1.0	19
	4	10	12.0	140	0.5	13
	5	10	12.0	140	0.15	5

**Soil Resistivity Measurement**  
**At T.P. 5 / Along Axis R2-R2**

Axis	Electrodes Spacing a (m)	Electrodes Depth, B (cm)	Voltage (V)	Current (mA)	Resistance Readings (R)	Specific Earth Resistance {(Ω-m)}
	1	10	12.0	130	5.0	31
	2	10	12.0	100	3.0	38
	3	10	12.0	100	1.0	19
	4	10	12.0	110	0.05	1.3
	5	10	12.0	140	0.01	0.3

**Soil Resistivity Measurement  
At T.P. 6 / Along Axis R3-R3**

Axis	Electrodes Spacing a (m)	Electrodes Depth, B (cm)	Voltage (V)	Current (mA)	Resistance Readings (R)	Specific Earth Resistance $\{(\Omega\cdot m)\}$
	1	10	12.0	130	4.5	28
	2	10	12.0	100	3.5	44
	3	10	12.0	150	2.0	38
	4	10	12.0	140	1.0	25
	5	10	12.0	140	0.5	16

Summary sheet of laboratory tests results are tabulated in Figure (3).

<p align="center"><b>GEOTECHNICAL ENGINEERING &amp; MATERIALS TESTING CO.</b>  <i>Summary of Tests Results</i></p> <p align="center"><i>Site Investigation</i>  For  <b>The Project Of Rehabilitation And Expansion Of</b>  <b>Water Facilities</b>  In Southern Governorates Of Tafieleh And Ma'an / Jordan  (For Ma'an Site)</p> <p align="right">Job No. : S2010/C20/06-F1</p>													
Test Pit No.	Depth (m)	Moisture Content (%)	Grain Size Analysis				Atterberg Limits			Chloride (Cl) (%)	Sulphate (SO <sub>4</sub> ) (%)	pH value	Remarks
			Gravel (%)	Sand (%)	Silt (%)	Clay (%)	LL (%)	PL (%)	PI (%)				
TP 3	1.0	3.5								2.9080	0.9514	8.413	
TP 5	1.0	1.9								0.7477	0.4473	8.478	
TP 6	1.0	5.9								0.3435	0.0213	8.569	

G.E.M.T

FIGURE 3