

## 8.2.2 その他ワークショップとセミナー


## Diagnosis Boiler Problem

### Current Boiler Problems for Vindhyachal # 7

- Vindhyachal Unit 7 Boiler has the problem of lower Main Steam (MS)/High Reheater Steam (HRH) temperature than design value and Left/Right side unbalance in MS/HRH temperature since commissioning.

## Diagnosis Boiler Problem

### Vindhyachal # 7 side view



## Diagnosis Boiler Problem

The modification history of Boiler up to now is as follows;

### Step I

- Addition of wall superheater on the front wall (area: 922 m<sup>2</sup>, consisting of 216 tubes)
- Removal of outer tube in each of the 74 reheater (area: 722 m<sup>2</sup>)


### Step II

- To reduce the high metal temp of reheater, out of 74 nos, 44 nos. of off-set bend piping (54 mm) in pent house was replaced by 44.5mm piping to avoid the Reheater tube overheating.
- 75% size orifices were installed at reheater outlet header(LHS) to reduce the Left/right steam temp imbalance.

## Diagnosis Boiler Problem

Table 6.1.9 Boiler Furnace Dimension Comparison Table


No	Item	Unit	Same type of Boiler in Japan	Vindhyachal Unit 7
1	Rated Output	MW	300	500
2	Boiler High (HT)	m	56	63
3	Bottom of SH Panel to roof (H4)	m	14	16
4	Top Burner level to Bottom of SH Panel (H3)	m	17	18
5	Burner Zone (H2) Burner	m	10	13
6	Hogges Bend to bottom of Burner (H1)	m	66 stages (1.0 stage)	5
7	Hogges bend to Bottom of SH Panel (H1-H3)	m	30	36
8	Furnace width (FW)	m	16	19
9	Furnace depth (FD)	m	15	16
10	Furnace Area	m <sup>2</sup>	229	303
11	Furnace Volume	m <sup>3</sup>	10,700	16,424
12	1st SH Panel (Dev SH)	No.	6	40
13	Panel Pitch (No./FW)	m	2.6	0.40
14	2nd SH Panel (Platen SH)	No.	28	35
15	Panel Pitch (No./FW)	m	0.57	0.76
16	Coal Calorific value	kcal/kg	6600	3700
17	Ash	%	16.6	30



## Diagnosis Boiler Problem

Flue Gas temperatures measured with online instruments at Div SH outlet, platen SH outlet etc. However, those are not only one point measurement data.

It is necessary to verification of L & R flue gas temperatures unbalance in across the cross-section considering data with regard to steam temperature, SH/RH metal temperature, mill combination and angle of burner tilt.



## Diagnosis Boiler Problem

### Cross connection of the left and right side of superheater header connecting pipes




Fig.6.1.2 Outline of Steam Flow Diagram (Same type of Boiler in Japan)




Fig.6.1.3 Outline of Steam Flow Diagram (Vindhyachal Unit 7)

## Diagnosis Boiler Problem

---

### Recommendation

- Increase in the superheater heat transfer area

In order to reduce furnace heat absorption and to increase heat absorption in superheater section, to add wall SH left and right sides of furnace.

- Cross connection of the left and right side of superheater header connecting pipes

Those modification are required to review and re-design of total heat balance of boiler by the original boiler supplier.

## Combustion Simulation

1. About Combustion Simulation
2. Preparation of Condition
3. Preliminary/Base Case Study
  - \* Cross Connection between Dev SH & Platen SH
4. Simulation Study
  - \* Steam Temperature difference  
Increased O<sub>2</sub>% and Gas Recirculation  
Additional air port and OFA  
Division SH modification
  - \* SH and RH steam temperature  
Division SH modification




Figure 2.1 Sub models incorporated into Coal Combustion Simulator




Figure 2.2 Summary of the Input/Output Data in the combustion simulation




Figure 3.2 Unit 7&8 Mesh used for the base simulations

Table 3.1 Comparison of the Heating Areas etc. between Vindiyachal Unit7&8 and Simulation model

	Unit	Unit 7&8 *3) Effective Value	Simulation Model Total Value	note
Furnace Volume	[m <sup>3</sup> ]	16424	17813	*1)
Surface Area	[m <sup>2</sup> ]	—	—	—
Economiser	[m <sup>2</sup> ]	13105	Out of Domain	—
Furnace (Water wall)	[m <sup>2</sup> ]	4837	4140	*2)
Wall Super Heter	[m <sup>2</sup> ]	No Information	411	—
LTSH(Stage #1)	[m <sup>2</sup> ]	6864	Out of Domain	—
Divisional Panel(Stage #2)	[m <sup>2</sup> ]	1319	1644	—
Platen(Stage #3)	[m <sup>2</sup> ]	1385	1428	—
Reheaters	[m <sup>2</sup> ]	6018	1833	—
Assembly	[-]	—	—	—
Economiser	[-]	138	Out of Domain	—
Wall Super Heter	[-]	4	4	—
LTSH(Stage #1)	[-]	124	Out of Domain	—
Divisional Panel(Stage #2)	[-]	48	24	—
Platen(Stage #3)	[-]	25	14	—
Reheaters	[-]	74	28	—

\*1) This value is the total volume of the simulation model.

The volume except Reheater zone is 1614[m<sup>3</sup>].

\*2) This value does not include the area of Wall Super Heter.

\*3) 15Boiler\_Technical\_details.pdf




Figure 3.1 Unit 7&8 structure used for the base simulations





Table 3.2 Base condition for combustion simulation

Load	[MW]	5000.0
Heat Input	[MW/hr]	1.20E+08
Coal Flow Rate	[ton/hr]	300
Coal Type	[--]	Typical
Proximate Analysis		
Total Moisture	[%]	17.8
Ash	[%]	31.0
Volatiles Matter	[%]	22.4
Fixed Carbon	[%]	28.0
Gross calorific value(GCV)	[kcal/kg]	37000.0
Ultimate Analysis		
C	[wt%]	76.4
H	[wt%]	5.1
N	[wt%]	1.6
O	[wt%]	16.6
S	[wt%]	0.3
Pulverized Coal Size <200μ	[%]	83.5
Oxygen conc. in flue gas	[vol%]	3.0
Air Ratio	[--]	1.15
Stoichiometric Air	[kg/kgcoal]	5.08
Average Air/Coal for all mills	[ton/ton]	1.3
Total Air Flow Rate	[ton/hr]	1888.7
1st Air Flow Rate	[ton/hr]	420.0
1st Air Temperature	[deg.C]	75.0
2nd Air Flow Rate	[ton/hr]	1468.7
2nd Air Temperature	[deg.C]	350.0
Coal Flow Distribution	[--]	Uniform
2nd Air Flow Distribution	[--]	By Burner List
Mill Pattern (Top)	No service	AB
Mill Pattern (Middle)	No service	EF
Mill Pattern (Bottom)	No service	JK
Burner Tilt Angle	[deg]	-30,-10,0,+30
Additional Air(AA)	[%]	0.0
AA Temperature	[deg.C]	350.0
Gas Recirculation(GR)	[%]	0.0
GR Temperature	[deg.C]	350.0

Summary of the Simulation Cases

Burner pattern: Bottom, Middle, Top	
Bottom	No Service Mill: JK
Middle	No Service Mill: EF
Top	No Service Mill: AB
Bottom2	No Service Mill: GH
Top2	No Service Mill: CD

Tilt angle: -30,-10,0,+30






Table 3.4 Case number of all simulations (102 cases)

Sheet 0: Base Cases 0	Sheet 1: Operation Study: Additional Air 20%
Original Boiler	Original Boiler
Heat Input: 1.20E+08 [MW/hr]	Heat Input: 1.20E+08 [MW/hr]
Coal Flow Rate: 300 [ton/hr]	Coal Flow Rate: 300 [ton/hr]
Coal Type: Typical	Coal Type: Typical
Proximate Analysis	Proximate Analysis
Total Moisture: 17.8 [%]	Total Moisture: 17.8 [%]
Ash: 31.0 [%]	Ash: 31.0 [%]
Volatiles Matter: 22.4 [%]	Volatiles Matter: 22.4 [%]
Fixed Carbon: 28.0 [%]	Fixed Carbon: 28.0 [%]
Gross calorific value(GCV): 37000.0 [kcal/kg]	Gross calorific value(GCV): 37000.0 [kcal/kg]
Ultimate Analysis	Ultimate Analysis
C: 76.4 [wt%]	C: 76.4 [wt%]
H: 5.1 [wt%]	H: 5.1 [wt%]
N: 1.6 [wt%]	N: 1.6 [wt%]
O: 16.6 [wt%]	O: 16.6 [wt%]
S: 0.3 [wt%]	S: 0.3 [wt%]
Pulverized Coal Size <200μ: 83.5 [%]	Pulverized Coal Size <200μ: 83.5 [%]
Oxygen conc. in flue gas: 3.0 [vol%]	Oxygen conc. in flue gas: 3.0 [vol%]
Air Ratio: 1.15	Air Ratio: 1.15
Stoichiometric Air: 5.08 [kg/kgcoal]	Stoichiometric Air: 5.08 [kg/kgcoal]
Average Air/Coal for all mills: 1.3 [ton/ton]	Average Air/Coal for all mills: 1.3 [ton/ton]
Total Air Flow Rate: 1888.7 [ton/hr]	Total Air Flow Rate: 1888.7 [ton/hr]
1st Air Flow Rate: 420.0 [ton/hr]	1st Air Flow Rate: 420.0 [ton/hr]
1st Air Temperature: 75.0 [deg.C]	1st Air Temperature: 75.0 [deg.C]
2nd Air Flow Rate: 1468.7 [ton/hr]	2nd Air Flow Rate: 1468.7 [ton/hr]
2nd Air Temperature: 350.0 [deg.C]	2nd Air Temperature: 350.0 [deg.C]
Coal Flow Distribution: Uniform	Coal Flow Distribution: Uniform
2nd Air Flow Distribution: By Burner List	2nd Air Flow Distribution: By Burner List
Mill Pattern (Top): No service AB	Mill Pattern (Top): No service AB
Mill Pattern (Middle): No service EF	Mill Pattern (Middle): No service EF
Mill Pattern (Bottom): No service JK	Mill Pattern (Bottom): No service JK
Burner Tilt Angle: -30,-10,0,+30 [deg]	Burner Tilt Angle: -30,-10,0,+30 [deg]
Additional Air(AA): 0.0 [%]	Additional Air(AA): 0.0 [%]
AA Temperature: 350.0 [deg.C]	AA Temperature: 350.0 [deg.C]
Gas Recirculation(GR): 0.0 [%]	Gas Recirculation(GR): 0.0 [%]
GR Temperature: 350.0 [deg.C]	GR Temperature: 350.0 [deg.C]







Table 3.5 Case number of additional simulations (16 cases)







Sheet No.	Title	Contents
9	Base Case1d	Base Cases to have considered the effect of the ash layer - External Heat Transfer BC for furnace wall h=2000[W/m²·K], Text=623[K] - External Heat Transfer BC for Super Heaters h=5000[W/m²·K], Text=750[K] - This condition is employed with all the following cases - Studies to improve the steam temperature difference (3) - Division panel configuration is changed into heater1
10	Heater Configuration	
*Add cases Bottom2 & Top2 to confirm the effect of the Heater1		
Sheet 9: Base Cases 1		
Original Boiler		
Heat Input: 1.20E+08 [MW/hr]		
Coal Flow Rate: 300 [ton/hr]		
Coal Type: Typical		
Proximate Analysis		
Total Moisture: 17.8 [%]		
Ash: 31.0 [%]		
Volatiles Matter: 22.4 [%]		
Fixed Carbon: 28.0 [%]		
Gross calorific value(GCV): 37000.0 [kcal/kg]		
Ultimate Analysis		
C: 76.4 [wt%]		
H: 5.1 [wt%]		
N: 1.6 [wt%]		
O: 16.6 [wt%]		
S: 0.3 [wt%]		
Pulverized Coal Size <200μ: 83.5 [%]		
Oxygen conc. in flue gas: 3.0 [vol%]		
Air Ratio: 1.15		
Stoichiometric Air: 5.08 [kg/kgcoal]		
Average Air/Coal for all mills: 1.3 [ton/ton]		
Total Air Flow Rate: 1888.7 [ton/hr]		
1st Air Flow Rate: 420.0 [ton/hr]		
1st Air Temperature: 75.0 [deg.C]		
2nd Air Flow Rate: 1468.7 [ton/hr]		
2nd Air Temperature: 350.0 [deg.C]		
Coal Flow Distribution: Uniform		
2nd Air Flow Distribution: By Burner List		
Mill Pattern (Top): No service AB		
Mill Pattern (Middle): No service EF		
Mill Pattern (Bottom): No service JK		
Burner Tilt Angle: -30,-10,0,+30 [deg]		
Additional Air(AA): 0.0 [%]		
AA Temperature: 350.0 [deg.C]		
Gas Recirculation(GR): 0.0 [%]		
GR Temperature: 350.0 [deg.C]		
Sheet 10: Division Panel Configuration, Heater 1		
Modified Boiler		
Heat Input: 1.20E+08 [MW/hr]		
Coal Flow Rate: 300 [ton/hr]		
Coal Type: Typical		
Proximate Analysis		
Total Moisture: 17.8 [%]		
Ash: 31.0 [%]		
Volatiles Matter: 22.4 [%]		
Fixed Carbon: 28.0 [%]		
Gross calorific value(GCV): 37000.0 [kcal/kg]		
Ultimate Analysis		
C: 76.4 [wt%]		
H: 5.1 [wt%]		
N: 1.6 [wt%]		
O: 16.6 [wt%]		
S: 0.3 [wt%]		
Pulverized Coal Size <200μ: 83.5 [%]		
Oxygen conc. in flue gas: 3.0 [vol%]		
Air Ratio: 1.15		
Stoichiometric Air: 5.08 [kg/kgcoal]		
Average Air/Coal for all mills: 1.3 [ton/ton]		
Total Air Flow Rate: 1888.7 [ton/hr]		
1st Air Flow Rate: 420.0 [ton/hr]		
1st Air Temperature: 75.0 [deg.C]		
2nd Air Flow Rate: 1468.7 [ton/hr]		
2nd Air Temperature: 350.0 [deg.C]		
Coal Flow Distribution: Uniform		
2nd Air Flow Distribution: By Burner List		
Mill Pattern (Top): No service AB		
Mill Pattern (Middle): No service EF		
Mill Pattern (Bottom): No service JK		
Burner Tilt Angle: -30,-10,0,+30 [deg]		
Additional Air(AA): 0.0 [%]		
AA Temperature: 350.0 [deg.C]		
Gas Recirculation(GR): 0.0 [%]		
GR Temperature: 350.0 [deg.C]		

1. Preliminary/Base Case Study
2. Simulation Study
















Table 4.3.1 Comparison of the Furnace Heat Recovery Percent

Evaluation Item		Heat Recovery % of Furnace(HR)				$\Delta$ HR=HR-HR(Base)			
Position	Tilt	Base	O <sub>2</sub> =5%	GR=10%	GR=20%	O <sub>2</sub> =5%	GR=10%	GR=20%	
Bottom (JK)	-30	34.19	32.14	29.86	26.30	-2.05	-4.33	-7.89	
	-10	34.36	32.43	29.15	23.39	-1.93	-6.21	-10.97	
	0	32.40	30.34	27.77	23.58	-2.06	-4.63	-8.82	
	30	28.95	27.38	25.12	21.80	-1.58	-4.24	-7.15	
Middle (EP)	-30	34.48	32.38	30.49	26.61	-2.10	-4.00	-7.87	
	-10	32.96	31.05	29.99	23.81	-1.91	-3.97	-9.15	
	0	30.90	29.20	27.32	23.27	-1.70	-3.58	-7.63	
	30	29.14	27.38	24.50	21.87	-1.77	-4.44	-7.67	
Top (AB)	-30	35.62	33.32	32.40	28.00	-2.30	-3.22	-7.62	
	-10	33.35	31.08	27.12	23.25	-2.27	-6.22	-10.10	
	0	31.76	29.76	26.04	21.66	-2.00	-6.72	-10.10	
	30	26.65	25.31	22.01	19.18	-1.64	-4.95	-7.77	
Average Value		32.12	30.15	27.48	23.52	-1.98	-4.64	-8.60	

O<sub>2</sub>=5%:  
2% of HRf is decreased.  
GR=10%:  
5% of HRf is decreased  
GR=20%:  
8.5% of HRf is decreased

Table 4.3.2 Comparison of the Furnace exit gas temperature (nose level)

Evaluation Item		Furnace Exit Gas Temperature deg.C				$\Delta$ T=T-T(Base) deg.C			
Position	Tilt	Base	O <sub>2</sub> =5%	GR=10%	GR=20%	O <sub>2</sub> =5%	GR=10%	GR=20%	
Bottom (JK)	-30	1324.90	1268.30	1320.20	1299.00	-56.60	-4.70	-25.90	
	-10	1325.10	1287.80	1345.50	1312.80	-37.30	20.40	-12.30	
	0	1363.90	1326.20	1358.60	1329.60	-37.70	-6.30	-34.30	
	30	1392.50	1358.30	1375.10	1339.00	-34.20	-17.40	-53.50	
Middle (EP)	-30	1323.90	1289.70	1318.50	1284.70	-34.20	-5.40	-39.20	
	-10	1348.70	1309.80	1340.70	1320.00	-38.90	-6.00	-28.70	
	0	1363.90	1326.20	1358.60	1329.60	-37.70	-6.30	-34.30	
	30	1402.90	1360.30	1382.80	1348.50	-42.60	-50.00	-54.40	
Top (AB)	-30	1306.10	1271.40	1291.00	1293.60	-33.70	-24.10	-11.50	
	-10	1344.70	1309.80	1348.20	1329.20	-34.90	3.50	-15.50	
	0	1372.40	1330.60	1376.50	1350.40	-41.80	4.10	-22.00	
	30	1414.20	1373.80	1379.30	1355.10	-40.30	-35.90	-59.10	
Average Value		1355.98	1316.41	1348.12	1325.18	-39.58	-7.87	-30.81	

O<sub>2</sub>=5%:  
40deg.C is decreased.  
GR=10%:  
5deg.C is decreased.  
GR=20%:  
30deg.C is decreased

Table 4.3.3 Comparison of the SH Heat Recovery Percent

Evaluation Item		Heat Recovery % of Super Heater(HRsh) WRSH=CLP/(Base+Hater) %				$\Delta$ HRsh=HRsh-HRsh(Base) %			
		Tilt	Base	O <sub>2</sub> =5%	GR=10%	GR=20%	O <sub>2</sub> =5%	GR=10%	GR=20%
Bottom (JK)	-30	23.90	21.56	24.26	23.57	-2.34	0.36	-0.33	
	-10	23.58	22.67	23.15	22.22	-0.91	-0.43	-1.36	
	0	24.39	23.45	25.06	25.01	-0.94	-0.67	0.62	
	30	26.48	24.31	24.30	23.86	-2.17	-2.19	-2.62	
Middle (EP)	-30	22.40	21.54	22.29	20.59	-0.86	-0.11	-1.82	
	-10	23.42	22.47	23.97	21.73	-0.95	0.55	-1.69	
	0	24.62	23.81	23.51	23.62	-1.81	-1.11	-0.80	
	30	25.32	24.43	24.16	23.13	-0.89	-1.16	-0.19	
Top (AB)	-30	23.03	22.33	22.61	23.11	-0.70	-0.43	0.07	
	-10	24.43	23.65	24.53	23.23	-0.78	0.09	-1.20	
	0	25.67	24.39	26.21	25.31	-1.28	0.54	-0.36	
	30	25.56	24.67	26.06	26.33	-0.70	0.49	0.76	
Average Value			24.40	23.22	24.18	23.66	-1.19	-0.23	-0.74

O<sub>2</sub>=5%:  
1% of HRsh is decreased  
GR=10%:  
HRsh is almost equal.  
GR=20%:  
1% of HRsh is decreased

Table 4.3.4 Comparison of the RH IN gas temperature







Evaluation Item		Reheater in Gas Temperature deg.C				$\Delta$ T=T-T(Base) deg.C			
		Tilt	Base	O <sub>2</sub> =5%	GR=10%	GR=20%	O <sub>2</sub> =5%	GR=10%	GR=20%
Bottom (JK)	-30	971.30	964.63	969.16	1002.50	-6.67	18.86	31.20	
	-10	975.57	965.51	1003.20	1045.30	-10.06	47.63	69.73	
	0	980.93	964.60	1004.80	1009.50	3.67	23.87	22.57	
	30	1073.60	1000.20	1059.50	1037.20	16.60	44.90	23.60	
Middle (EP)	-30	990.22	967.37	1018.40	1041.40	-22.85	28.18	51.18	
	-10	999.49	965.63	1008.60	1050.20	-33.86	9.11	50.71	
	0	1076.10	1018.80	1018.70	1018.20	0.70	2.60	2.10	
	30	1037.60	1008.50	1069.00	1034.80	-29.10	31.40	-2.80	
Top (AB)	-30	965.35	962.30	963.15	992.84	-3.05	7.89	37.59	
	-10	978.31	972.52	1004.60	1036.70	-5.79	26.29	58.39	
	0	982.61	967.11	1016.00	1056.80	4.50	33.39	74.19	
	30	1073.60	1054.30	1077.50	1046.00	-19.30	3.30	-27.60	
Average Value			997.99	984.66	1021.06	1030.49	-13.33	23.16	32.57




O<sub>2</sub>=5%:  
Temp. is almost equal.  
GR=10%:  
20deg.C is increased.  
GR=20%:  
40deg.C is increased

Table 4.3.5 The effect of the oxygen conc. & gas recirculation to the heat recovery pattern

Heat Recovery % (furnace)		Nose Temperature[deg.C]	
Operation	Base	Effect	Effect
O <sub>2</sub> =5%	32.12	-1.98	1355.98 -39.58
GR=10%	32.12	-4.64	1355.98 -7.87
GR=20%	32.12	-8.60	1355.98 -8.60
Heat Recovery % (SH)		RH_IN Temperature[deg.C]	
Operation	Base	Effect	Effect
O <sub>2</sub> =5%	24.40	-1.19	997.89 -2.93
GR=10%	24.40	-0.23	997.89 23.16
GR=20%	24.40	-0.74	997.89 32.57
Heat Recovery % (RH)			
Operation	Base	Effect	
O <sub>2</sub> =5%	7.91	0.09	
GR=10%	7.91	0.79	
GR=20%	7.91	1.18	


Note1:SH (Wall Heater + Div + Platen) Arrow: Red is good, Blue is bad.  
 Note2:RH data are reference value.





Evaluation Item	R&L Deflection of Heat Recovery (Division Heater) % (Paired)					Heat Recovery % (Division Heater) % (Paired)					Heat Recovery % (Division Heater) % (Paired)					R&L Deflection of Heat Recovery (Left Super Heater) % (Paired)					
	Bottom	Top	Bottom2	Top2	Top	Bottom	Top	Bottom2	Top2	Top	Bottom	Top	Bottom2	Top2	Top	Bottom	Top	Bottom2	Top2	Top	
Bottom	-30	5.32	-2.50	-1.82	21.15	18.78	-1.38	23.80	21.89	-1.11	3.96	-1.82	4.56	-1.82	4.56	-1.82	4.56	-1.82	4.56	-1.82	4.56
Top	-10	5.48	0.80	-0.88	20.88	20.19	-0.69	23.58	23.43	-0.15	-0.58	-1.50	-1.48	-1.05	-1.48	-1.05	-1.48	-1.05	-1.48	-1.05	-1.48
Bottom2	0	12.19	2.83	-8.36	21.62	21.14	-0.48	24.39	24.62	0.22	7.33	4.52	-1.91	4.52	-1.91	4.52	-1.91	4.52	-1.91	4.52	-1.91
Top2	-30	9.87	-5.95	-0.85	23.66	23.16	-0.50	26.46	26.47	-0.01	3.37	-11.64	8.56	3.37	-11.64	8.56	3.37	-11.64	8.56	3.37	-11.64
Bottom2	-30	13.56	-16.19	2.63	18.62	19.22	0.60	19.24	21.83	2.59	-4.34	5.50	0.96	5.50	0.96	5.50	0.96	5.50	0.96	5.50	0.96
Top	-10	7.37	5.81	-1.76	20.94	20.30	-0.64	23.47	23.57	0.09	5.71	5.96	-1.15	5.96	-1.15	5.96	-1.15	5.96	-1.15	5.96	-1.15
Bottom2	0	11.84	4.13	-1.71	21.45	21.06	-0.37	24.04	24.38	0.35	7.88	5.50	-2.39	5.50	-2.39	5.50	-2.39	5.50	-2.39	5.50	-2.39
Top2	-30	11.70	-0.37	-14.74	20.03	19.96	-0.08	22.40	23.63	1.22	14.17	-19.82	-10.95	14.17	-19.82	-10.95	14.17	-19.82	-10.95	14.17	-19.82
Bottom2	-10	14.51	8.21	-4.31	20.92	20.75	-0.16	23.42	23.89	0.46	12.29	9.47	-2.82	9.47	-2.82	9.47	-2.82	9.47	-2.82	9.47	-2.82
Top	0	-12.53	-20.45	8.12	21.96	20.83	-1.13	24.62	23.82	-0.80	-22.47	-24.36	11.68	-24.36	11.68	-24.36	11.68	-24.36	11.68	-24.36	11.68
Bottom2	-30	27.20	3.99	-10.53	22.09	23.44	1.35	25.32	24.43	-0.89	-4.58	-1.84	-4.58	-1.84	-4.58	-1.84	-4.58	-1.84	-4.58	-1.84	-4.58
Top	-30	3.45	2.91	-0.55	20.82	19.82	-0.99	23.84	23.03	-0.81	-12.46	-29.36	-20.93	-29.36	-20.93	-29.36	-20.93	-29.36	-20.93	-29.36	-20.93
Bottom2	-10	5.57	-2.65	-1.32	21.56	20.42	-1.13	24.38	23.76	-0.63	1.06	-1.19	-0.11	-1.19	-0.11	-1.19	-0.11	-1.19	-0.11	-1.19	-0.11
Top	0	16.13	4.89	-11.24	21.96	21.19	-0.76	24.66	24.60	-0.06	4.46	2.91	-1.54	2.91	-1.54	2.91	-1.54	2.91	-1.54	2.91	-1.54
Bottom2	-30	11.36	-4.58	-0.76	23.45	23.12	-0.33	26.02	26.17	0.15	0.03	-16.27	16.12	0.03	-16.27	16.12	0.03	-16.27	16.12	0.03	-16.27
Bottom	-30	6.79	-1.81	-4.96	20.26	21.61	1.35	23.03	24.43	1.40	3.07	4.95	1.84	4.95	1.84	4.95	1.84	4.95	1.84	4.95	1.84
Top	-10	15.16	-0.17	-14.69	21.61	21.16	-0.45	24.43	24.77	0.34	4.95	3.95	-1.10	3.95	-1.10	3.95	-1.10	3.95	-1.10	3.95	-1.10
Bottom2	0	7.66	0.40	-1.28	22.60	21.58	-1.02	25.87	25.27	-0.60	8.41	2.38	-6.03	2.38	-6.03	2.38	-6.03	2.38	-6.03	2.38	-6.03
Top	-30	8.44	1.66	-0.36	22.35	24.16	1.79	23.56	24.16	0.60	1.76	-21.26	-11.26	-21.26	-11.26	-21.26	-11.26	-21.26	-11.26	-21.26	-11.26
Bottom2	-10	13.25	5.15	-3.13	21.56	21.45	-0.11	24.62	24.48	-0.14	5.14	-10.39	-1.79	-10.39	-1.79	-10.39	-1.79	-10.39	-1.79	-10.39	-1.79
Top	0	20.65	-0.55	-24.16	21.15	20.90	-0.25	24.62	24.16	-0.46	30.17	30.39	4.41	30.39	4.41	30.39	4.41	30.39	4.41	30.39	4.41
Bottom2	-30	3.45	6.17	-10.55	14.62	18.78	4.16	18.14	21.83	3.70	0.03	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96	0.96

Evaluation Item	Heat Recovery % (Platen)					Heat Recovery % (Div+Platen)					Temperature deg.C (SH Zone SH, Near wall)					Temperature deg.C (SH Zone SH, Far wall)				
	Bottom	Top	Bottom2	Top2	Top	Bottom	Top	Bottom2	Top2	Top	Bottom	Top	Bottom2	Top2	Top	Bottom	Top	Bottom2	Top2	Top
Bottom	-30	34.19	34.82	0.63	2.74	3.11	0.37	1324.90	1329.90	-5.00	971.30	982.00	-10.70	-10.70	-10.70	-10.70	-10.70	-10.70	-10.70	-10.70
Top	-10	34.36	35.12	0.76	2.70	3.24	0.54	1325.10	1330.30	5.20	975.57	977.35	-1.72	-1.72	-1.72	-1.72	-1.72	-1.72	-1.72	-1.72
Bottom2	0	32.40	32.56	0.16	2.77	3.48	0.70	1325.50	1330.20	4.70	980.93	979.71	-1.21	-1.21	-1.21	-1.21	-1.21	-1.21	-1.21	-1.21
Top2	-30	29.95	29.41	-0.54	1.80	3.29	1.49	1324.50	1329.80	5.30	1014.60	1014.60	0.00	0.00	0.00	1014.60	1014.60	0.00	1014.60	1014.60
Bottom2	-10	34.57	35.08	0.52	1.42	2.62	1.19	1325.70	1330.60	26.90	1048.80	1048.80	0.00	0.00	0.00	1048.80	1048.80	0.00	1048.80	1048.80
Top	0	32.39	32.30	-0.02	2.54	3.27	0.73	1323.10	1327.10	4.00	980.41	966.02	-14.39	-14.39	-14.39	980.41	966.02	-14.39	980.41	966.02
Bottom2	-30	29.25	29.60	0.35	2.89	3.24	0.35	1340.30	1340.00	5.00	1014.30	1014.30	0.00	0.00	0.00	1014.30	1014.30	0.00	1014.30	1014.30
Top	-30	34.48	34.43	-0.05	2.37	2.67	0.30	1323.90	1322.40	-1.50	990.22	989.97	-0.25	-0.25	-0.25	990.22	989.97	-0.25	990.22	989.97
Bottom2	-10	32.96	33.36	0.40	2.91	3.13	0.22	1348.70	1350.80	2.10	999.49	999.18	-3.30	-3.30	-3.30	999.49	999.18	-3.30	999.49	999.18
Top	0	30.90	31.37	0.46	2.66	2.99	0.32	1363.90	1367.30	3.40	1014.10	1017.70	3.60	3.60	3.60	1014.10	1017.70	3.60	1014.10	1017.70
Bottom2	-30	29.14	29.52	0.38	2.44	3.27	0.83	1430.20	1430.40	0.20	1017.00	1017.00	0.00	0.00	0.00	1017.00	1017.00	0.00	1017.00	1017.00
Top	-30	35.06	35.75	0.70	2.82	3.21	0.39	1321.40	1323.80	2.40	959.70	973.43	13.73	13.73	13.73	959.70	973.43	13.73	959.70	973.43
Bottom2	-10	33.51	33.63	0.12	2.83	3.33	0.50	1341.60	1347.50	5.90	977.23	973.64	-3.59	-3.59	-3.59	977.23	973.64	-3.59	977.23	973.64
Top	0	32.05	32.21	0.16	2.70	3.41	0.70	1363.10	1370.00	6.90	986.23	980.00	-6.23	-6.23	-6.23	986.23	980.00	-6.23	986.23	980.00
Bottom2	-30	29.87	30.06	0.21	1.80	3.69	1.89	1430.05	1431.20	1.15	1014.30	1014.30	0.00	0.00	0.00	1014.30	1014.30	0.00	1014.30	1014.30
Top	-30	35.62	35.95	-0.37	3.77	2.92	-0.85	1335.10	1344.70	9.60	955.35	976.31	20.96	20.96	20.96	955.35	976.31	20.96	955.35	976.31
Bottom2	-10	33.35	33.53	0.18	2.82	3.59	0.77	1344.70	1350.20	5.50	978.31	980.89	2.58	2.58	2.58	978.31	980.89	2.58	978.31	980.89
Top	0	29.76	29.96	0.20	3.07	3.69	0.62	1372.40	1374.40	2.00	960.61	967.62	7.01	7.01	7.01	960.61	967.62	7.01	960.61	967.62
Bottom2	-30	29.95	29.77	-0.18	3.18	3.18	0.00	1414.20	1423.80	9.60	1017.00	1017.00	0.00	0.00	0.00	1017.00	1017.00	0.00	1017.00	1017.00
Top	0	32.31	32.52	0.21	1.62	3.23	1.60	1430.30	1390.21	-40.09	996.25	990.24	-6.01	-6.01	-6.01	996.25	990.24	-6.01	996.25	990.24
Bottom2	-10	29.95	29.75	-0.20	1.07	3.69	2.62	1414.20	1423.80	9.60	1017.00	1017.00	0.00	0.00	0.00	1017.00	1017.00	0.00	1017.00	1017.00
Top	0	29.95	29.77	-0.18	1.42	2.65	1.23	1379.70	1389.80	10.10	955.35	960.00	4.65	4.65	4.65	955.35	960.00	4.65	955.35	960.00



Evaluation Item		R&L Deflection of Heat Recovery (Division Panel + Platen)			
Pattern	Tilt	Base	Heater	Heater1	Heater2
Straight (Heater1)					
		Straight	Straight	Cross	
Bottom (JK)	-30	5.32	2.50	-1.40	
	-10	3.48	2.33	-2.43	
	0	12.19	8.78	-0.42	
	30	6.81	4.83	-0.29	
Bottom2 (GH)	-30	13.56	-0.73	-11.73	
	-10	3.37	1.85	-3.56	
	0	11.84	6.96	-2.18	
	30	3.79	3.74	-0.10	
Middle (EF)	-30	16.10	8.25	-1.81	
	-10	14.51	7.41	-1.55	
	0	-12.53	-14.29	-6.10	
	30	27.20	11.73	-6.65	
Top2 (CD)	-30	3.45	-0.53	-3.72	
	-10	5.57	6.96	2.95	
	0	16.13	8.64	-3.26	
	30	11.36	6.87	-2.42	
Top (AB)	-30	6.78	4.83	-0.14	
	-10	15.16	6.81	-3.95	
	0	7.66	8.14	3.45	
	30	-8.22	-8.79	-8.52	
Average (ABS) (g/s)		10.29	6.25	3.48	
Max (ABS) (g/s)		27.20	14.29	11.73	
Min (ABS) (g/s)		3.45	0.53	0.10	




Figure 4.5.5 Effect of the Heater combination to the Right & Left Deflection

#### Ref. 1 Effect of each operations to the heat recovery percent of the re-heaters

Evaluation Item		Heat Recovery percent (Rad RH + Conv RH)							
Pattern	Tilt	Base	OC=5%	GR=10%	GR=20%	AA=20%	QFA=50%	Heater1	Heater2
		(%)	(%)	(%)	(%)	(%)	(%)	(%)	(%)
Bottom	-30	7.50	7.54	8.09	8.51	7.50	7.70	7.24	
	-10	7.22	7.24	8.66	9.33	7.22	7.42	7.14	
	0	7.48	7.58	8.17	8.50	7.48	8.61	7.33	
	30	8.37	8.67	9.61	9.40	8.37	8.44	8.39	
Bottom2 (GH)	-30	9.00	---	---	---	---	---	7.77	
	-10	7.54	---	---	---	---	---	7.06	
	0	7.57	---	---	---	---	---	7.34	
	30	8.39	---	---	---	---	---	8.42	
Middle (EF)	-30	7.82	8.01	8.64	9.33	8.66	8.60	7.78	
	-10	7.97	8.05	8.32	9.56	7.29	7.68	7.59	
	0	8.39	8.51	8.69	8.73	7.49	8.21	8.48	
	30	8.89	8.79	9.83	9.24	8.83	8.76	8.17	
Top2 (CD)	-30	7.10	---	---	---	---	---	7.29	
	-10	7.33	---	---	---	---	---	7.20	
	0	7.78	---	---	---	---	---	7.29	
	30	8.35	---	---	---	---	---	7.97	
Top (AB)	-30	6.66	6.93	7.24	8.14	7.67	6.65	7.29	
	-10	7.29	7.31	8.45	9.15	8.93	7.60	7.25	
	0	7.49	7.65	8.42	8.53	8.67	7.90	7.40	
	30	8.89	8.63	10.36	9.74	7.62	10.05	9.06	
Average		7.81	8.00	8.71	9.10	7.54	8.15	7.67	
Max		9.83	9.52	10.36	9.74	8.83	10.05	9.06	
Min		6.66	6.93	7.24	8.14	6.66	6.65	7.06	

#### Note:

The prediction of the convection heaters is not so accurate in this simulation. These data is submitted as a reference value.

#### Recommendation

##### 1. L & R deflection

- The Bottom pattern and the Tilt -10 degree operation for L & R deflection

Carry out trial operation by applying the best parameters written above to the current boiler. For further mitigation of temperature imbalance,

- Modify the boiler by applying the cross-connecting pipes between Division SH and Platen SH.
- ##### 2. SH and RH steam temperature
- To increase SH and RH steam temperature, remove front Division SH, and add the same heating surface to rear Division SH by modification of rear Division SH. In addition, apply wall SH at left and right sides of furnace where Division SH is located.

Removal of front Division SH is also effective for mitigation of temperature imbalance.

#### Boiler Combustion Simulation

##### Simulation of Air and Fuel Bias

- Additional Request to improve the R&L deflection

- (1) Right & Left 2<sup>nd</sup> Air Bias by changing the wind box draft.
- (2) Right & Left Fuel Bias (1st Air)
- (3) Right & Left Fuel Bias (1st Air) + 2nd Air Bias

Note: Simulation Conditions same as previous study report.

#### Simulation of Air and Fuel Bias

Sheet No. #1	Title	Contents
0	Base Case1	- Base Cases to have considered the effect of the ash layer - External Heat Transfer BC for furnace wall - External Heat Transfer BC for Super Heaters - This condition is employed with all the following cases
1	2nd Air Bias	Black -20% (Left = -10%, Right = +10%)
2		Black -10% (Left = -5%, Right = +5%)
3		Black +10% (Left = +5%, Right = -5%)
4		Black +20% (Left = +10%, Right = -10%)
5	1st Air Fuel Bias	Black -20% (Left = -10%, Right = +10%)
6		Black -10% (Left = -5%, Right = +5%)
7		Black +10% (Left = +5%, Right = -5%)
8		Black +20% (Left = +10%, Right = -10%)
9	1st/2nd Air Fuel Bias	Black -20% (Left = -10%, Right = +10%)
A		Black -10% (Left = -5%, Right = +5%)
B		Black +10% (Left = +5%, Right = -5%)
C		Black +20% (Left = +10%, Right = -10%)

\*1) Simulation Condition are described each sheet in next table

#### Boiler Combustion Simulation

Case number of all simulations (20 base cases)


Sheet 0: Base Cases 1					
1) Original Boiler	Heater 0	Furnace Heat Transfer: Realistic			
Heat Input	1.20E+09 [Kcal/hr]	1.39E+09 [W]			
O2=	3 [%]	OFA=	0 [%damper]		
GR=	0 [%]	AA=	0 [%]		
2nd Bias	0	1st Bias	0	Fuel Bias	0
Pattern	Tilt	-30	-10	0	30
Bottom		111	112	113	114
Middle		121	122	123	124
Top		131	132	133	134
Top2		141	142	143	144
Bottom2		151	152	153	154

Bottom No Service Mill: JK  
Bottom2 No Service Mill: GH  
Middle No Service Mill: EF  
Top2 No Service Mill: CD  
Top No Service Mill: AB






Case number of all simulations (240 Bias cases)


Project 1: Top Air & Right Bias -10%	Project 2: Top Air & Right Bias -5%	Project 3: Top Air & Right Bias 0%	Project 4: Top Air & Right Bias +5%	Project 5: Top Air & Right Bias +10%
<p>Original Bias: -10%</p> <p>Heat Input: 1.20E+09 (2.00E+08) 1.20E+09 (2.00E+08)</p> <p>Div: Div1 Div2 Div3 Div4</p> <p>Div Bias: -10% -10% -10% -10%</p> <p>Pattern: FR -10% -10% -10% -10%</p> <p>Bottom: -10% -10% -10% -10%</p> <p>Head: -10% -10% -10% -10%</p> <p>Tail: -10% -10% -10% -10%</p> <p>Total: -10% -10% -10% -10%</p>	<p>Original Bias: -5%</p> <p>Heat Input: 1.20E+09 (2.00E+08) 1.20E+09 (2.00E+08)</p> <p>Div: Div1 Div2 Div3 Div4</p> <p>Div Bias: -5% -5% -5% -5%</p> <p>Pattern: FR -5% -5% -5% -5%</p> <p>Bottom: -5% -5% -5% -5%</p> <p>Head: -5% -5% -5% -5%</p> <p>Tail: -5% -5% -5% -5%</p> <p>Total: -5% -5% -5% -5%</p>	<p>Original Bias: 0%</p> <p>Heat Input: 1.20E+09 (2.00E+08) 1.20E+09 (2.00E+08)</p> <p>Div: Div1 Div2 Div3 Div4</p> <p>Div Bias: 0% 0% 0% 0%</p> <p>Pattern: FR 0% 0% 0% 0%</p> <p>Bottom: 0% 0% 0% 0%</p> <p>Head: 0% 0% 0% 0%</p> <p>Tail: 0% 0% 0% 0%</p> <p>Total: 0% 0% 0% 0%</p>	<p>Original Bias: +5%</p> <p>Heat Input: 1.20E+09 (2.00E+08) 1.20E+09 (2.00E+08)</p> <p>Div: Div1 Div2 Div3 Div4</p> <p>Div Bias: +5% +5% +5% +5%</p> <p>Pattern: FR +5% +5% +5% +5%</p> <p>Bottom: +5% +5% +5% +5%</p> <p>Head: +5% +5% +5% +5%</p> <p>Tail: +5% +5% +5% +5%</p> <p>Total: +5% +5% +5% +5%</p>	<p>Original Bias: +10%</p> <p>Heat Input: 1.20E+09 (2.00E+08) 1.20E+09 (2.00E+08)</p> <p>Div: Div1 Div2 Div3 Div4</p> <p>Div Bias: +10% +10% +10% +10%</p> <p>Pattern: FR +10% +10% +10% +10%</p> <p>Bottom: +10% +10% +10% +10%</p> <p>Head: +10% +10% +10% +10%</p> <p>Tail: +10% +10% +10% +10%</p> <p>Total: +10% +10% +10% +10%</p>



Improve the R&L deflection  
 (1) Right & Left 2<sup>nd</sup> Air Bias  
 by changing the wind box draft.



On the other hand, the difference was also found in Div. Panel region under the condition of Top Mill & Tilt = 30[deg]  
The reason is that the good swirl would not be get in this condition.  
It would be very difficult to control R&L deflection by this operation.



Comparably Stable

Big changing was found in Div+30deg

Bias = -20%

Bias = -20%

Bias = 0%

Bias = 0%





Bias = +20%

Bias = +10%

Bottom Mill pattern , Tilt= -10[deg]

Top Mill pattern , Tilt= 30[deg]

Figure 4.2.5 Isothermal Surface = 1000 deg in SH Zone by changing 2<sup>nd</sup> Air Bias









Table 4.3.1 Effect of 2<sup>nd</sup> Air Bias on the R & L Deflection  
Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)				
		Straight -20	Straight -10	Straight 0	Straight 10	Straight 20
Bottom (JK)	-30	-11.09	-7.26	5.32	-21.13	-31.15
	-10	8.86	5.04	3.48	7.58	16.57
	0	9.12	10.44	12.19	2.73	2.12
	30	16.60	12.54	6.81	-21.47	-12.45
Bottom2 (GH)	-30	-10.56	-35.46	13.56	-6.87	32.81
	-10	10.51	26.68	7.37	11.90	5.54
	0	10.19	9.57	11.84	10.41	-6.33
	30	6.82	4.69	3.79	-19.69	-26.42
Middle (EF)	-30	14.77	28.75	16.10	-22.15	19.48
	-10	11.68	10.28	14.51	13.93	11.04
	0	15.81	11.52	-12.53	-19.81	16.65
	30	25.65	31.01	27.20	7.83	-17.76
Top2 (CD)	-30	3.11	9.21	3.45	3.29	14.61
	-10	14.00	19.51	5.57	3.98	19.86
	0	11.01	19.53	16.13	-12.36	2.90
	30	8.34	13.91	11.36	-46.92	-9.20
Top (AB)	-30	-0.50	7.53	6.78	-2.13	13.82
	-10	11.28	17.70	14.79	4.79	8.44
	0	18.98	13.82	7.86	4.53	-7.87
	30	28.00	23.44	-4.92	-33.22	-2.01
AverageABS(d%)		12.35	15.90	10.29	13.84	14.10
Max ABS(d%)		28.00	35.46	27.20	46.92	32.81
MIN ABS(d%)		0.50	4.69	3.45	2.13	2.01




Table 4.3.2 Effect of 2<sup>nd</sup> Air Bias with Cross 1 on the R & L Deflection  
Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)				
		Cross1 -20	Cross1 -10	Cross1 0	Cross1 10	Cross1 20
Bottom (JK)	-30	-3.44	-7.45	2.50	-17.17	-16.76
	-10	8.10	7.62	2.33	21.34	9.04
	0	1.81	7.70	8.78	16.14	7.57
	30	6.18	5.73	4.83	-5.18	-8.53
Bottom2 (GH)	-30	3.13	-13.02	-0.73	20.91	1.13
	-10	-2.89	8.89	1.85	17.37	9.38
	0	-2.05	4.78	6.96	3.04	6.22
	30	4.72	3.01	3.74	4.06	-19.48
Middle (EF)	-30	0.91	8.55	8.25	-9.68	6.25
	-10	4.34	4.28	7.41	20.79	7.94
	0	9.31	0.36	-14.29	-21.76	7.03
	30	3.76	11.85	11.73	25.57	-11.12
Top2 (CD)	-30	14.77	6.32	-0.53	7.69	4.72
	-10	4.13	11.27	6.98	17.78	9.50
	0	6.49	8.59	8.64	-1.04	7.64
	30	8.43	8.86	6.87	-29.61	-8.14
Top (AB)	-30	10.58	10.43	4.83	6.83	3.80
	-10	7.24	6.88	6.81	14.48	7.36
	0	6.40	4.16	8.14	0.73	5.95
	30	12.13	10.54	-8.79	-22.01	3.70
AverageABS(d%)		6.24	7.52	6.25	14.16	8.11
Max ABS(d%)		14.77	13.02	14.29	29.61	19.46
MIN ABS(d%)		0.91	0.36	0.53	0.73	1.13

ABS(Orange Frame) <±10%

Table 4.3.3 Effect of 2<sup>nd</sup> Air Bias with Cross 2 on the R & L Deflection  
Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)				
		Cross2 -20	Cross2 -10	Cross2 0	Cross2 10	Cross2 20
Bottom (JK)	-30	4.74	-2.48	-1.40	2.12	2.90
	-10	1.45	3.39	-2.43	10.10	-2.68
	0	-6.80	-0.24	-0.42	6.28	6.59
	30	-4.43	-2.65	-0.29	5.46	-0.57
Bottom2 (GH)	-30	8.60	9.64	-11.73	22.28	-21.41
	-10	-12.08	-10.51	-3.56	0.22	6.10
	0	-9.58	-3.44	-2.18	-8.63	11.74
	30	0.40	-1.11	-0.10	9.42	-4.60
Middle (EF)	-30	-10.36	-11.94	-1.81	-0.36	-6.97
	-10	-4.44	-2.74	-1.55	6.25	1.39
	0	-1.31	-8.19	-6.10	-6.28	-5.14
	30	-6.63	-10.92	-6.65	11.57	-2.11
Top2 (CD)	-30	13.31	0.25	-3.72	6.43	-4.59
	-10	-7.54	-2.82	2.95	7.22	-5.55
	0	-2.97	-5.36	-3.26	0.99	4.83
	30	0.85	-1.24	-2.42	0.35	-8.42
Top (AB)	-30	11.25	5.31	-0.14	8.93	-5.10
	-10	-1.35	-5.95	-3.95	5.78	1.98
	0	-8.14	-6.32	3.45	-13.68	11.98
	30	-7.95	-7.15	-9.52	-3.00	3.48
AverageABS(d%)		6.31	5.08	3.48	6.77	5.88
Max ABS(d%)		13.31	11.94	11.73	22.28	21.41
MIN ABS(d%)		0.40	0.24	0.10	0.22	0.51

ABS(Orange Frame) <±10%

Table 4.3.4 Effect of 2<sup>nd</sup> Air Bias with Cross 3 on the R & L Deflection  
Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)				
		Cross3	Cross3	Cross3	Cross3	Cross3
Bottom (JK)	-30	-2.92	-2.28	1.42	5.12	-11.49
	-10	2.21	0.81	-1.28	1.82	4.05
	0	0.50	2.51	2.99	-2.55	1.13
	30	5.99	4.16	1.68	-1.41	-9.43
Bottom2 (GH)	-30	-5.09	-12.80	2.56	15.32	10.27
	-10	1.32	7.28	1.96	-14.58	2.26
	0	2.65	1.35	2.70	-17.52	-0.81
	30	2.59	0.58	-0.05	0.20	-11.56
Middle (EF)	-30	3.50	8.27	6.05	-2.95	6.26
	-10	2.90	3.26	5.56	1.72	4.49
	0	5.18	2.98	-4.34	-8.72	4.48
	30	7.26	8.14	6.83	-0.71	-8.74
Top2 (CD)	-30	1.65	3.14	0.27	4.30	5.31
	-10	2.33	5.42	1.53	-0.02	4.80
	0	1.55	5.58	4.23	-4.63	0.09
	30	2.76	3.81	2.07	-6.06	-3.48
Top (AB)	-30	0.18	2.41	1.81	5.14	4.91
	-10	2.70	4.86	4.40	-1.22	2.66
	0	4.44	3.34	2.96	-20.40	-1.88
	30	7.92	8.75	-6.65	-6.61	-2.22
AverageABS(df%)		3.28	4.44	3.02	8.05	5.31
Max(ABS(df%))		7.92	12.80	6.83	20.40	11.56
MIN(ABS(df%))		0.18	0.58	0.05	0.02	0.09

ABS(Orange Frame)  
<±10%

Improve the R&L deflection  
(2)Right & Left Fuel Bias (1<sup>st</sup> Air).




Figure 4.4.1 Effect of Fuel & 1<sup>st</sup> Air Bias on the R & L Deflection  
Plus value = Left (high), Minus value = Right (high)




Figure 4.4.2 Isothermal Surface = 1000 deg in SH Zone




Figure 4.4.3 Isothermal Surface = 1000 deg in SH Zone




Figure 4.4.4 Isothermal Surface = 1000 deg in SH Zone





Table 4.4.1 Effect of Fuel & 1<sup>st</sup> Air Bias on the R & L Deflection  
Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)				
		Straight	Straight	Straight	Straight	Straight
Bottom (JK)	-30	-7.80	0.61	5.32	23.72	1.88
	-10	6.79	11.74	18.42	22.54	
	0	-9.35	1.82	12.19	16.98	21.08
	30	21.23	18.75	6.81	23.72	3.92
Bottom2 (GH)	-30	-34.36	-7.21	13.56	6.36	9.33
	-10	17.64	8.71	4.12	1.04	
	0	11.89	9.74	11.84	5.90	15.89
	30	8.45	6.21	3.79	10.01	7.24
Middle (EF)	-30	33.18	26.38	16.10	8.23	-7.82
	-10	13.13	13.76	14.51	12.27	7.02
	0	21.62	27.11	-12.53	-2.19	18.71
	30	34.26	32.36	27.20	23.36	16.25
Top2 (CD)	-30	9.60	7.78	3.45	6.87	4.25
	-10	17.40	17.43	5.57	8.23	12.23
	0	15.94	20.37	16.13	5.70	-1.96
	30	17.17	15.66	11.96	3.09	-4.06
Top (AB)	-30	7.71	6.23	6.78	6.62	7.99
	-10	15.79	15.59	15.16	12.82	9.78
	0	17.30	9.95	7.66	2.07	-3.37
	30	27.88	17.99	-4.92	-24.07	-28.68
AverageABS(df%)		16.96	13.54	10.29	11.24	10.25
Max(Abs(df%))		34.36	32.36	27.20	24.07	28.69
Min(Abs(df%))		0.35	0.61	3.45	2.07	1.04

- R & L deflection seems to be minimum in non-bias condition (Bias Fraction=0%).
- Effect of the Cross Combination 2 and 3:  
+ Cross combination 2 and 3 is very effective to minimize the deflection under a lot of operating conditions.
- + Cross combination 1 is also effective,  
but a big deflection is sometimes found in bias condition.
- It would be better to take non-bias condition with the cross combination.




Figure 4.4.7 Effect of the heater combination on the R & L Deflection under the Fuel + 1<sup>st</sup> Air bias condition

Table 4.4.2 Effect of Fuel & 1<sup>st</sup> Air Bias with Cross 1 on the R & L Deflection  
Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)				
		Cross1	Cross1	Cross1	Cross1	Cross1
Bottom (JK)	-30	5.62	-9.78	2.50	14.02	-3.04
	-10	7.57	9.39	2.33	7.87	12.74
	0	5.76	8.44	8.78	7.37	11.35
	30	7.71	7.55	4.83	14.02	0.99
Bottom2 (GH)	-30	-11.93	-10.98	-0.73	-9.66	-7.89
	-10	8.58	6.01	1.85	4.93	6.55
	0	6.91	10.47	6.96	5.75	10.13
	30	5.07	4.43	3.74	4.64	0.98
Middle (EF)	-30	11.05	9.55	8.25	6.64	-2.75
	-10	4.07	6.43	7.41	7.51	6.49
	0	11.80	11.84	-14.29	1.00	4.84
	30	12.11	12.67	11.73	11.07	9.26
Top2 (CD)	-30	6.82	5.78	0.53	1.35	0.20
	-10	8.11	5.56	6.98	7.95	8.26
	0	7.96	7.47	8.64	4.12	-1.99
	30	9.41	5.92	6.87	3.29	0.61
Top (AB)	-30	10.01	7.71	4.82	1.52	1.18
	-10	6.98	6.51	6.81	6.28	6.86
	0	7.73	5.75	6.14	5.50	6.38
	30	10.39	3.65	6.25	16.17	16.97
AverageABS(df%)		8.27	7.93	6.25	7.15	6.07
Max(Abs(df%))		12.11	12.67	14.29	18.17	19.37
Min(Abs(df%))		4.07	3.65	0.53	1.00	0.20

ABS(Orange Frame)  
< ± 10%

Table 4.4.3 Effect of Fuel & 1<sup>st</sup> Air Bias with Cross 2 on the R & L Deflection  
Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)				
		Cross2	Cross2	Cross2	Cross2	Cross2
Bottom (JK)	-30	10.28	-10.31	-1.40	-1.17	-3.46
	-10	3.16	1.38	-2.43	-5.13	-3.19
	0	6.10	7.11	-0.42	-4.77	-3.73
	30	-7.04	-6.16	-0.79	-1.17	-4.58
Bottom2 (GH)	-30	9.20	-9.25	-11.73	-14.52	-14.42
	-10	-3.69	0.26	-3.56	2.42	6.98
	0	-2.58	6.86	-2.18	1.41	-2.24
	30	-1.03	-0.72	-0.10	-4.71	-7.65
Middle (EF)	-30	-11.25	-7.95	-1.81	2.14	0.65
	-10	-4.37	-2.37	-1.55	-0.23	2.46
	0	-3.36	-8.13	-6.10	0.89	-11.84
	30	-12.66	-11.27	-8.65	-6.64	-4.00
Top2 (CD)	-30	0.83	0.58	-3.72	-3.40	-2.70
	-10	-5.23	-8.55	2.95	1.85	-1.19
	0	-3.39	-7.44	-3.26	-1.74	-3.55
	30	-2.29	-3.02	-2.42	-1.35	-0.10
Top (AB)	-30	4.68	3.42	-0.14	-3.60	-3.45
	-10	-4.05	-4.37	-3.95	-2.81	0.05
	0	-4.28	-1.92	3.45	3.68	8.89
	30	-11.14	-12.18	-9.52	-6.19	-4.39
AverageABS(df%)		5.54	5.51	3.46	3.50	4.58
Max(Abs(df%))		12.66	12.18	11.73	14.52	14.42
Min(Abs(df%))		0.83	0.26	0.10	0.23	0.05

ABS(Orange Frame)  
< ± 10%

Table 4.4.4 Effect of Fuel & 1<sup>st</sup> Air Bias with Cross 3 on the R & L Deflection  
Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)				
		Cross3		Cross3		Cross3
		-20	-10	0	10	20
Bottom (JK)	-30	-2.96	0.07	1.42	8.53	1.45
	-10	2.38	3.73	-1.29	5.42	6.62
	0	0.00	0.29	2.99	4.94	6.00
	30	6.48	5.04	1.68	8.53	-1.83
Bottom2 (GH)	-30	-13.22	-2.42	2.56	1.51	2.80
	-10	5.37	2.96	1.96	1.61	1.48
	0	2.40	2.13	2.70	1.55	3.52
	30	2.35	1.06	-0.05	0.66	-0.99
Middle (EF)	-30	10.87	8.84	6.05	3.73	-4.42
	-10	4.69	4.96	5.56	4.53	3.00
	0	6.66	7.14	-4.34	-2.31	2.04
	30	9.28	8.42	6.83	5.46	2.99
Top2 (CD)	-30	3.61	2.57	0.27	2.12	1.35
	-10	4.05	3.32	1.53	2.13	2.78
	0	4.59	5.45	4.23	-0.16	-3.52
	30	5.47	4.21	2.07	-1.58	-4.76
Top (AB)	-30	2.39	1.88	1.81	1.11	1.35
	-10	4.76	4.72	4.40	3.74	2.97
	0	5.29	2.28	2.96	0.24	-0.85
	30	6.35	1.56	-5.65	-12.09	-13.71
AverageABS(d%)		5.16	3.85	3.02	3.59	3.41
Max(ABS(d%))		13.22	8.84	6.83	12.09	13.71
MIN(ABS(d%))		0.00	0.07	0.05	0.16	0.85

ABS(Orange Frame)  
<±10%

Improve the R&L deflection  
(3)Right & Left Fuel Bias (1<sup>st</sup> Air) + 2<sup>nd</sup> Air Bias.




Figure 4.5.1 Effect of Fuel & 1<sup>st</sup> Air (+2<sup>nd</sup> Air) Bias on the R & L Deflection  
Plus value = Left (high), Minus value = Right (high)




Figure 4.5.2 Isothermal Surface = 1000 deg in SH Zone




Figure 4.5.3 Isothermal Surface = 1000 deg in SH Zone




Figure 4.5.4 Isothermal Surface = 1000 deg in SH Zone





Table 4.5.1 Effect of Fuel & 1<sup>st</sup> Air (+2<sup>nd</sup> Air) Bias on the R & L Deflection  
Plus value = Left (high), Minus value = Right (high)

Evaluation Item		R&L Deflection of Heat Recovery (Division Panel + Platen)					
Pattern	Tilt	Straight	Straight	Straight	Straight	Straight	Straight
Bottom (JK)	-30	16.08	14.01	5.32	-7.38	16.51	
	-10	15.14	6.58	3.45	13.27	5.23	
	0	14.58	14.01	12.19	9.40	2.18	
	30	23.41	18.72	8.81	-20.30	-23.82	
Bottom2 (GH)	-30	-3.16	-38.48	13.56	13.09	28.66	
	-10	0.64	0.42	7.10	4.37	2.64	
	0	16.85	7.89	11.84	-5.29	-11.23	
	30	11.07	7.71	3.79	-11.31	-24.88	
Middle (EF)	-30	3.89	30.43	16.10	2.35	21.46	
	-10	14.66	12.66	14.51	8.35	3.79	
	0	20.29	14.96	-12.53	20.70	12.99	
	30	26.89	29.27	27.20	12.09	-25.80	
Top2 (CD)	-30	5.22	10.31	3.45	9.22	13.03	
	-10	11.92	14.41	5.57	18.31	19.42	
	0	10.72	16.00	16.13	3.80	5.55	
	30	11.92	13.38	11.36	-16.71	-15.02	
Top (AB)	-30	-5.11	4.91	6.78	10.71	14.08	
	-10	14.92	13.32	15.16	8.62	3.60	
	0	20.21	16.58	7.66	-4.97	-6.95	
	30	29.00	29.00	-4.92	-8.16	-7.00	
AverageABS(df%)		13.79	15.55	10.29	10.54	13.75	
MaxABS(df%)		29.00	38.48	27.20	20.80	33.94	
MinABS(df%)		0.64	0.42	3.45	2.35	2.18	




Table 4.5.2 Effect of Fuel & 1<sup>st</sup> Air (+2<sup>nd</sup> Air) Bias with Cross 1 on the R & L Deflection  
Plus value = Left (high), Minus value = Right (high)

Evaluation Item		R&L Deflection of Heat Recovery (Division Panel + Platen)					
Pattern	Tilt	Cross1	Cross1	Cross1	Cross1	Cross1	Cross1
Bottom (JK)	-30	13.37	6.92	2.50	-8.32	7.45	
	-10	8.47	7.94	2.33	6.07	7.16	
	0	5.56	6.92	8.78	7.76	7.83	
	30	8.17	7.44	4.83	-14.91	-19.53	
Bottom2 (GH)	-30	2.32	-12.51	-0.73	-5.15	7.62	
	-10	-3.07	-3.59	1.85	6.53	8.03	
	0	-1.68	-3.68	6.96	9.07	5.80	
	30	5.99	4.94	3.74	-11.31	-13.80	
Middle (EF)	-30	0.56	6.35	8.25	-3.53	5.59	
	-10	4.65	4.09	7.41	7.19	5.27	
	0	9.58	10.20	-14.29	9.91	8.99	
	30	10.37	10.43	11.73	6.22	-9.41	
Top2 (CD)	-30	14.49	9.66	-0.53	2.90	4.47	
	-10	7.70	8.17	6.98	7.51	6.43	
	0	7.27	7.86	8.64	7.09	7.60	
	30	8.02	8.55	6.87	-16.41	-6.15	
Top (AB)	-30	9.62	11.11	4.83	3.14	3.65	
	-10	7.71	6.67	6.81	7.06	6.81	
	0	8.44	5.30	8.14	6.16	5.99	
	30	12.35	12.33	-8.79	-1.82	3.75	
AverageABS(df%)		7.47	7.83	6.25	7.30	7.67	
MaxABS(df%)		14.49	12.51	14.29	16.41	18.53	
MinABS(df%)		0.56	3.68	0.53	1.82	3.65	

ABS(Orange Frame) <±10%

Table 4.5.3 Effect of Fuel & 1<sup>st</sup> Air (+2<sup>nd</sup> Air) Bias with Cross 2 on the R & L Deflection  
Plus value = Left (high), Minus value = Right (high)

Evaluation Item		R&L Deflection of Heat Recovery (Division Panel + Platen)					
Pattern	Tilt	Cross2	Cross2	Cross2	Cross2	Cross2	Cross2
Bottom (JK)	-30	2.63	-3.72	-1.40	-3.41	-3.48	
	-10	-2.81	3.47	-2.43	-4.06	2.98	
	0	-5.59	-3.72	-0.42	0.60	6.69	
	30	-6.59	-5.18	-0.29	-4.59	-0.79	
Bottom2 (GH)	-30	3.94	11.24	-11.73	-13.27	-10.58	
	-10	-4.25	-6.85	-3.56	3.53	6.66	
	0	-13.63	-10.57	-2.18	14.02	14.36	
	30	-0.15	-0.39	-0.10	-6.69	0.44	
Middle (EF)	-30	-1.85	-15.65	-1.81	-6.27	-7.86	
	-10	-5.94	-4.81	-1.55	2.59	2.89	
	0	-4.42	0.01	-6.10	-5.77	-1.92	
	30	-7.97	-10.79	-8.65	-4.31	5.04	
Top2 (CD)	-30	11.54	3.24	-3.72	-3.05	-3.83	
	-10	-0.23	-2.20	2.95	-7.10	-8.88	
	0	-0.38	-3.83	-3.26	3.26	3.15	
	30	1.19	-0.17	-2.42	-9.42	-3.15	
Top (AB)	-30	13.30	8.19	-0.14	-4.02	-5.39	
	-10	-3.33	-3.19	-3.95	1.04	4.24	
	0	-6.75	-6.83	3.45	9.56	10.94	
	30	-7.33	-8.75	-9.52	1.00	6.76	
AverageABS(df%)		5.19	5.64	3.48	5.37	5.50	
MaxABS(df%)		13.63	15.65	11.73	14.02	14.36	
MinABS(df%)		0.15	0.01	0.10	0.60	0.44	

ABS(Orange Frame) <±10%

Table 4.5.4 Effect of Fuel & 1<sup>st</sup> Air (+2<sup>nd</sup> Air) Bias with Cross 3 on the R & L Deflection  
Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)				
		Cross3	Cross3	Cross3	Cross3	Cross3
		-20	-10	0	10	20
Bottom (JK)	-30	5.35	3.37	1.42	-4.45	5.58
	-10	3.86	2.11	-1.23	3.14	1.04
	0	3.43	3.37	2.99	2.25	1.04
	30	8.64	6.10	1.68	-10.48	-15.20
Bottom2 (GH)	-30	-1.55	-12.71	2.56	4.97	11.46
	-10	-0.54	-0.84	1.96	1.37	1.27
	0	4.90	1.00	2.70	-0.34	-2.67
	30	4.93	2.38	-0.05	-6.59	-10.65
Middle (EF)	-30	1.48	8.44	6.05	-0.39	8.01
	-10	4.08	3.76	5.56	3.74	1.40
	0	6.29	4.77	-4.34	5.02	2.08
	30	8.64	8.05	6.83	1.56	-11.46
Top2 (CD)	-30	2.27	3.89	0.27	3.27	4.72
	-10	4.00	4.04	1.53	3.70	4.13
	0	3.07	4.31	4.23	-0.03	1.10
	30	5.08	4.66	2.07	-11.72	-10.01
Top (AB)	-30	-1.43	1.99	1.81	3.54	5.03
	-10	3.89	3.46	4.40	2.60	1.03
	0	5.02	4.45	2.96	-1.57	-2.03
	30	9.32	7.93	-5.65	-5.34	-3.99
AverageABS(df%)		4.39	4.58	3.02	3.80	5.20
Max(ABS(df%))		9.32	12.71	6.83	11.72	15.20
MIN(ABS(df%))		0.54	0.84	0.05	0.03	1.03

ABS(Orange Frame)  
<±10%

## The result of Simulation

### Air and Fuel Bias

- R & L deflection dose not have a consistent tendency to the bias fraction.  
Tilt=-10deg:R & L deflection is stable by plus value.  
(Strong swirl flow in the furnace)  
Tilt=+30deg:The big changing by bias was predicted.  
(Weak swirl flow in the furnace)
- It would be very difficult to control R&L deflection by this bias operation.
- Effect of the Cross Combination 2 and 3:  
+ Cross combination 2 and 3 is very effective to minimize the deflection  
under a lot of operating conditions.  
+However, a big deflection is sometimes found in bias condition.
- It would be better to take non-bias condition with the cross combination.





JICA Study Team for Enhancing Efficiency of Operating Thermal Power Plant in NTPC-India

## Boiler RLA

JICA Study Team  
Boiler RLA

### Schedule for Boiler RLA demo

Schedule for Boiler RLA																					
	Month	October									November							~ January			
	Day	24	25	26	27	28	29	30	31	1	2	3	4	5	6	7	8		9	10	11
	Day of the week	Sa	Su	Mo	Tue	We	Th	Fr	Sa	Su	Mo	Tue	We	Th	Fr	Sa	Su		Mo	Tue	We
Singrauli UNIT6	Boiler Inspection																				
Unchahar UNIT2	Meeting																				
	Boiler Inspection																				
	◇Examination in Japan																				

3

JICA Study Team for Enhancing Efficiency of Operating Thermal Power Plant in NTPC-India Boiler RLA

### Target units

#### ➤ Singrauli Unit 6 (500MW Drum Boiler)

Cumulative operation hours: 172,000 hours  
(27<sup>th</sup> October to 1<sup>st</sup> November, 2009)

#### ➤ Unchahar Unit 2 (200MW Drum Boiler)


Cumulative operation hours: 139,098 hours  
(4<sup>th</sup> November to 9<sup>th</sup> November, 2009)



2

JICA Study Team for Enhancing Efficiency of Operating Thermal Power Plant in NTPC-India Boiler RLA

### Work organization



4

JICA Study Team for Enhancing Efficiency of Operating Thermal Power Plant in NTPC-India Boiler RLA

### Safety working

Following the instruction of power station, keeping Japanese safety management.

- ✓ Falling  
In danger of falling, working at 2m or more high altitude.
- ✓ Lack of oxygen  
In danger of lack of oxygen, working in the boiler furnace.
- ✓ Dropping  
In danger of equipments dropping at hanging in and out  
Maximum weight 50 kg.  
In danger of manual tools and small parts dropping.

\*Check the portion that asbestos used.  
If asbestos treating work begins, Interrupt working.

\*Information sharing to avoid working during upper portion working, γ-ray inspection, etc.



5

JICA Study Team for Enhancing Efficiency of Operating Thermal Power Plant in NTPC-India Boiler RLA

### Scope of work (1)

NO.	Parts	INSPECTION	Singrauli #6	Unchahar #2
1	WATER WALL	VT	* Mainly at burner level	
2		THICKNESS MEASUREMENT	* Erosion part	
3	SUPER HEATER	VT	* 20 points(5points each from 4corners)	
4		THICKNESS MEASUREMENT	* Mainly Platen super heater	
5		SAMPLE TUBE INSPECTION *	* 50 points around soot blower	
6		THICKNESS MEASUREMENT		
7		SAMPLE TUBE INSPECTION *	1 tube with 1m length for Platen SH including weld joint portion	2 tubes with 1m length from Final SH, 1 tubes with 1m length from Platen SH including weld joint portion that is selected by steam oxide scale measurement result.
8		THICKNESS MEASUREMENT		
9		CREEP RUPTURE TEST*	* 3 specimens from base metal, 3 specimens from weld joint from the tube identical to above.	* 3 specimens from base metal, 3 specimens from weld joint from the tube identical to above.
10		SUS SCALE DEPOSITION INSPECTION	* 50 points of bottom bend portion of austenitic steel tubes	* 29 ~3 points of bottom bend portion of austenitic steel tubes
11	REHEATER	VT	* Mainly around soot blower.	
12		THICKNESS MEASUREMENT	2 tubes with 1m length for Final RH (one each from furnace inside and penhouse) including weld joint portion.	
13		SAMPLE TUBE INSPECTION *	* 3 specimens from base metal, 3 specimens from weld joint from the tube identical to the one of the above sample tubes.	
14		THICKNESS MEASUREMENT		
15		CREEP RUPTURE TEST*	* 50 points of bottom bend portion of austenitic steel tubes	
16		SUS SCALE DEPOSITION INSPECTION		




6

JICA Study Team for Enhancing Efficiency of Operating Thermal Power Plant in NTPC-India Boiler RLA


## Scope of work (2)

NO.	Parts	INSPECTION	Singrauli #6	Unchahar #2
12		VT	*Visual inspection in penthouse	
13		PT(DPT)	*4 portions at stub weld of Inlet header .	*4 portions at stub weld of Platten inlet header right side.
14	SUPER HEATER HEADER	UT	*1 ring of circumferential weld of Final outlet header right side with UT and TOFD identical to the replica portion	* 1 point of circumferential weld portion of right side of Final outlet header.
15		REPLICA INSPECTION	*1 point on 1ring of circumferential weld of left outlet header. *1 point on base metal of left outlet header.	
16	DE SUPER HEATER PIPE	REPLICA INSPECTION	* 2 points ( one each from 1ring of circumferential weld right and left).	
17		VT	*Visual inspection in penthouse	
18	REHEATER HEADER	UT	*1ring of circumferential weld of outlet header with UT and TOFD identical to the replica portion	
19		REPLICA INSPECTION	*2 points (one each from circumferential weld of left and right of out let header.	* 3 points of circumferential weld portion of right and left side outlet header.
20	MAIN STEAM PIPE (near the stop valve weld joint)	REPLICA INSPECTION	*2 points on a circumferential weld of left main steam pipe	* 2 points on two circumferential welds of right main steam pipe
21	HOT RHEAT PIPE	REPLICA INSPECTION		*1 point on a circumferential weld of right High temperature reheat pipe.

## Inspection points ( Singrauli #6 )



## Inspection points ( Unchahar #2 )



## Findings (1) ( Singrauli #6 )

Components	Inspection method	Findings
Water wall tube	Visual check	*Erosion of a number of tubes around short soot blower were found. *No erosion at any other portions. *No erosion and decrease in thickness around burners.
	Thickness measurement of tubes	Thickness was measured at erosion regions around soot blowers near each 4 corner. Min. thickness was 3.7mm(2nd blower in front wall first from right. f 51* 5.6mm, SA210 Gr.C
Platten SH	Visual check	*Attrition of binding tube #4 and #5 was found. (Min.2.8mm) *Attrition of cooling spacer tube with front tube of #14 panel (Min.5.0mm) *Disorder of arrangement at lower part of panel with distortion to adjacent panel. *A number of disjointed slide spac
	Thickness measurement of tubes	*1:Outer tube of rear side portion at sootblower level(24points)⇒Min.6.3mm φ 63.5* 6.3mm SA213 TP347H *2:Outer bottom tube (24points)⇒Min.9.8mm φ 54.0* 9.5mm SA213 TP347H *3:Attrition of coolin
	SUS scale deposition inspection	Nos. exceeding 10% fullness : 7/50 (magnetized effect of material)
	Tube sampling for sample tube inspection (inspected in Japan).	#12-3(from leftside) f 47.63*8.6-f 47.63*10, SA213 T22
	Creep rupture test (inspected in Japan)	

## Findings (2) ( Singrauli #6 )

Components	Inspection method	Findings
Reheater	Visual check	*Disorder of arrangement at lower part of panel with distortion to adjacent panel.
	SUS scale deposition inspection	No exceeding 10% fullness
	Tube sampling for sample tube inspection (inspected in Japan).	#3-1(from leftside in penthouse) 1m including weld f 54*5.6, SA213 T22 #14-5(from rear side in furnace) (SA213T22 f 54*4.5-SA213T11 f 54*4.0)
	Creep rupture test (inspected in Japan) for 1 tube with 1m length.	
Super heater header	Visual check	*No appearance abnormality in stubs and other weld portion.
	DPT	#2(1,4,7,12) Indication was found in #2-12 stub at tube side. Indication disappeared after grinding off the tube in 1mm depth.
De superheater pipe	Replica inspection	*No crack in Base metal, HAZ(Heat Affected Zone) and weldmetal. *More detail microstructural observation is required in labo.
	Replica inspection	*No crack in Base metal, HAZ(Heat Affected Zone) and weldmetal. *More detail microstructural observation is required in labo.
Reheater header	Visual check	*No appearance abnormality in stubs and other weld portion.
	Replica inspection	*No crack in Base metal, HAZ(Heat Affected Zone) and weldmetal. *More detail microstructural observation is required in labo.
	UT	* No detection of flaw beyond H-detection line. * 4 detected flaw under H-detection line.
	TOFD	* A number of flaw considered as safe blow holes and slag inclusions were detected. * No considerable crack detected.
Main steam pipe (near the stop valve weld joint)	Replica inspection	*No crack in Base metal, HAZ(Heat Affected Zone) and weldmetal. *More detail microstructural observation is required in labo.


## Findings (3) ( Unchahar #2 )

Components	INSPECTION	Unchahar #2 Brief comment
WATER WALL	VT	Erosion of a number of tubes around short soot blower were found. Erosion of corner tubes at soot blower level.(Thickness measurement 28points (Min.4.2mm)
	THICKNESS MEASUREMENT	Eroded tubes around short soot blower were measured.(69points measured) Min 5.3mm (2nd short blower rear wall #1 form left)
SUPER HEATER	VT	Disorder of arrangement at lower part of panel with disjointed slide spacers. Slight erosion of rear tubes at the highest level of short soot blower.
	THICKNESS MEASUREMENT	Rear tubes at the highest level of short soot blower.(29points, Min.9.8mm) 2nd tubes from rear tubes at the highest level of short soot blower.(3points, Min.10.0mm) Rear tubes at the second highest level of short soot blower.(29points, Min.9.8mm)
	SAMPLE TUBE INSPECTION *	1 sample tube from Platten-SH in furnace (#3panel- 8th tube from rear) 2 sample tubes from Final-SH in furnace (#1-3rd tube from rear, #119-3rd tube from rear)
	CREEP RUPTURE TEST*	1 sample tube from Platten-SH in furnace (#3panel- 8th tube from rear), 1 sample tubes from Final-SH in furnace (#119-3rd tube from rear)
	SUS SCALE DEPOSITION INSPECTION	3 tubes with 15% fullness and 2 tubes with 10% fullness at front bend portion. 1 tube with 15% fullness and the others with less than 10%.
REHEATER	VT	No abnormality with panel or r_ agement Slight erosion of tubes at the highest level of short soot blower.


## Findings (4) ( Unchahar #2 )

Components	INSPECTION	Unchahar #2 Brief comment
SUPER HEATER HEADER	VT	No appearance abnormality in stubs and other weld portion.
	PT(DPT)	3 small circular indication patterns by ark strike at 4th tube from front.
	UT	No detection of flaw which echo exceeds L-line by UT. Continuous indication with fine flaws detected at 80mm depth from surface by TOFD.
	REPLICA INSPECTION	No crack in Base metal, HAZ(Heat Affected Zone) and weld metal. More detail microstructural observation is required in labo.
DE SUPER HEATER PIPE	REPLICA INSPECTION	No crack in Base metal, HAZ(Heat Affected Zone) and weld metal. More detail microstructural observation is required in labo.
REHEATER HEADER	VT	No appearance abnormality in stubs and other weld portion.
	REPLICA INSPECTION	No crack in Base metal, HAZ(Heat Affected Zone) and weld metal. Abnormal microstructure observed in base metal region of right-hand weld of header, which is considered to be the effect of ark during welding. More detail microstructural observation.
MAIN STEAM PIPE (near the stop valve weld joint)	REPLICA INSPECTION	No crack in Base metal, HAZ(Heat Affected Zone) and weld metal. More detail microstructural observation is required in labo.
HOT RHEAT PIPE	REPLICA INSPECTION	No crack in Base metal, HAZ(Heat Affected Zone) and weld metal. More detail microstructural observation is required in labo. Some deposit metal by welding attached to base metal near the weld ring.

## Visual inspection ( Singrauli #6 )



## Visual inspection ( Unchahar #2 )



## Thickness measurement

### Thickness measurement (1)

#### 【Equipment】

Ultrasonic thickness meter including a probe with a digital display and waveform indicator.




#### 【Couplant】

Glycerin paste or glycerin solution with the 75% concentration or more

### Thickness measurement (2)

#### 【Reference block】



- Reference block: RB-T and RB-E (for regular interval checking and daily checking)



### Thickness measurement (3)

#### 【Original reference block】

- Carbon steel
- Austenitic steel



### Thickness measurement (4)

#### 【Acceptance Criteria】

Measurement result is judged by the calculated value ( $t_{sr}$ : thickness required) based on "Technical standards for thermal power generation facilities" and JIS B 8201 : 2005.

$$t_{sr} = (Pd/2\sigma_a + P) + 0.005d \quad (\text{JISB8201})$$


$t_{sr}$  : Minimum required thickness of tube (mm)

$P$  : Maximum operating pressure(MPa)


$d$  : Outside diameter of tube (mm)

$\sigma_a$  : Allowable tensile stress of the material (N/mm<sup>2</sup>)


### Thickness measurement results of WW (Singrauli #6)



### Thickness measurement results of Platen SH (Singrauli #6)



### Thickness measurement results of Platen SH (Unchahar #2)



### Thickness measurement results

#### Thickness measurement of tubes (Singrauli #6)

Tube	Material	OD (mm)	t (mm)	Pressure P (kg/cm <sup>2</sup> )	Temp. (°C)	Allowable Stress S (MPa)	$t_{sr}$ (mm)	Measured (mm)	Note
Water wall	SA210 Gr.C	51.0	5.6	197.3	416	90.1	5.2	3.7	Erosion around short soot blower
PLATEN SH ST-II	SA213 TP347H	54.00	9.50	178	540*	92	> 4.9	9.8	
	SA213 TP347H	63.50	6.30	178	540*	92	> 5.8	2.8	Attrition with bind tubes
	SA213 TP347H	63.50	6.30	178	540*	92	> 5.8	6.3	Soot blower level (#1 from rear side)
	SA213 TP347H	54.00	6.00	178	540*	92	> 4.9	6.3	Soot blower level (#2 from rear side)


\*Designed value of header

#### Thickness measurement of tubes (Unchahar #2)

Tube	Material	OD (mm)	t (mm)	Pressure P (kg/cm <sup>2</sup> )	Temp. (°C)	Allowable Stress S (MPa)	$t_{sr}$ (mm)	Measured (mm)	Note
Water wall	SA-210, GR.A1	63.5	6.3	175.8	404	86.8	6.1	4.2	Erosion around short soot blower
PLATEN SH (ELE 1)	SA 213 T 22	51	9.6	175.8	566	39.7	9.4	9.8	Highest soot blower level
PLATEN SH (ELE 1)	SA 213 T 22	51	9.6	175.8	566	39.7	9.4	9.8	Second highest soot blower level
PLATEN SH (ELE 2)	SA 213 T 22	51	9.6	175.8	566	39.7	9.4	10.0	Highest soot blower level

$t_{sr} = PD/(2S+P)+0.005D$

## Thickness management




### 【 Critical thickness value 】

Japan : tsr ( thickness shell required ) by “Technical standards for thermal power generation facilities”

NTPC : Thickness reduction ratio to designed thickness


## Thickness management

### How to determine design thickness in Japan ?



## Thickness management


### How to determine design thickness in Japan ?



by Technical standards for thermal power generation facilities


## Thickness management

### How to determine design thickness in Japan ?




## Thickness management

### How to determine design thickness in Japan ?



## Thickness management

### How to determine design thickness in Japan ?



### How much margin to be taken from tsr by OEM ?


Designed thickness = tsr + margin

If the margin is small, 80% of designed thickness is not secure.

If the margin is large, 80% of designed thickness is conservative.



## Thickness management criteria



What is to be taken as criteria ?

Where is the origin of designed thickness ?

Integrity calculation documents by OEM is essential.



## Thickness criterion ( Unchahar #2 )

Thickness measurement of tubes

Tube	Material	Designed			Temperature (°C)	Allowable Stress S (MPa)	tsr (mm)	Measured (Min) (mm)	Note
		O.D. D(mm)	t (mm)	Pressure P (kg/cm <sup>2</sup> )					
Water wall	SA-210, GR.A1	63.5	6.3	175.8	404	86.8	6.1	4.2	Erosion around short soot blower
Platten SH (ELE 1)	SA 213 T 22	51	9.6	175.8	566	39.7	9.4	9.8	Highest soot blower level
Platten SH (ELE 1)	SA 213 T 22	51	9.6	175.8	566	39.7	9.4	9.8	Second highest soot blower level
Platten SH (ELE 2)	SA 213 T 22	51	9.6	175.8	566	39.7	9.4	10.0	Highest soot blower level

O.D.:Outer Diameter  
t:Thickness

$$tsr = PD/(2S-P)+0.005D$$



## Calculated designed creep life ( Unchahar #2 )

Creep life calculation of header and pipe based on designed condition

Header and Pipe	Material	Designed			Temperature (°C)	Allowable Stress S (MPa)	tsr (mm)	Hoop stress (MPa)	Estimated Life(h) calculated by creep rupture data
		O.D. D (mm)	t (mm)	Pressure P (kg/cm <sup>2</sup> )					
Platten SH outlet header	SA 335 P-22	323.9	56	163.8	534	58.2	37.5	35.3	8.58E+06
Re-Heater outlet header	SA 335 P-22	558.8	45	44.1	555	45.4	25.0	23.8	9.19E+06
LTSH outlet header	SA 335 P12	323.9	40	167.6	450	101.0	24.7	60.0	4.81E+08
Links to DESH	SA 335 P12	406.4	45	167.6	450	101.0	31.0	67.6	2.57E+08
DESH	SA 335 P12	406.4	45	167.6	450	101.0	31.0	67.6	2.57E+08
Links from DESH	SA 335 P12	406.4	45	167.6	427	102.8	30.5	67.6	2.25E+09
Platten SH inlet header	SA 335 P12	323.9	40	167.6	427	102.8	24.3	60.0	4.30E+09
Platten SH outlet header	SA 335 P-22	323.9	56	163.8	534	58.2	37.5	35.3	8.58E+06
Links to Final SH	SA 335 P-22	406.4	70	163.8	534	58.2	47.0	35.4	8.49E+06
SH Finish inlet header	SA 335 P-22	406.4	65	163.8	534	58.2	47.0	39.0	5.54E+06
SH Finish outlet header	SA 335 P-22	457.2	100	160.6	555	45.4	63.8	25.0	7.70E+06
Main Steam Pipe	SA 335 P-22	355.6	50.3	160.5	540	54.4	42.8	44.6	1.98E+06
Hot Reheat Pipe	SA 335 P-22	508	28	37.6	540	54.4	16.4	30.9	9.91E+06

$$tsr = PD / (2S + 2kP) + a \quad (\gamma=1, a=0)$$


k	Temperature(°C)					
	≤ 350	480	510	535	565	620
Ferritic steel	0.4	0.4	0.5	0.7	0.7	0.7

## Detection technique for scale deposition of SUS (Austenite Steel ) boiler tube

### Detection technique for scale deposition of SUS (Austenitic Steel ) boiler tube (1)

(Background)

Steam oxide scale of austenitic stainless steel (SUS steel) tubes such as TP304, TP321 used for SH and RH, exfoliates and deposits at the bottom inside during long term operation and blocks tube-coolant flow leading to over heat of the tube at down stream side.





Conventionally  $\gamma$ -ray transmission test method is applied.

From the view point of efficiency and safety

Using the induction principle, the magnetic scale inside of nonmagnetic tube was detected.

### Detection technique for scale deposition of SUS (Austenitic Steel ) boiler tube (2)

【Equipment and measurement image】



Example of standard curve



Measurement equipment




Measurement image



## Detection technique for scale deposition of SUS (Austenite Steel) boiler tube (3)


### [Detection principle]



37

## Detection technique for scale deposition of SUS (Austenite Steel) boiler tube (4)

### [Comparison between $\gamma$ -ray projection and scale detector results]



### [Detectable level]

Detectable level  $\geq 10\%$ .

### [Effect of outside surface of tube]

The effect of magnetic scale on the tube outside and local magnetization of the tube by long term heat.

Suspected signals require to be confirmed by  $\gamma$ -ray detection.

### [Scale with low permeability]

The deposit scale with lower permeability than one of reference scale is not detected, such as austenitic stainless steel tips by cutting and limescale etc.

JICA Japan International Cooperation Agency

38

## Detection technique for scale deposition of SUS (Austenite Steel) boiler tube (5)

### [Confirmation of scale deposition]

It is preferable to apply  $\gamma$ -ray detection besides scale detector, in order to recognize the effect of the outside surface of tube and the existence of the scale with low permeability.


Sampling inspection by  $\gamma$ -ray detection will improve the accuracy of scale deposition estimation.

JICA Japan International Cooperation Agency

39

## SUS scale deposition inspection results (Singrauli #6)


Platen SH (outermost tube)		RH (outermost tube)	
Front	Rear	Front	Rear
Panel No.	Fullness (%)	Panel No.	Fullness (%)
14	15	6	15
20	10	13	10
21	15	18	10
		21	15



JICA Japan International Cooperation Agency

40

## SUS scale deposition inspection results (Unchahar #2)













JICA Japan International Cooperation Agency





41

## DPT (Liquid Penetrant Testing)

## DPT procedure (Platen SH inlet header 4 stub weld portion)

Process			Content	
Pretreatment			Remove oil and dirt on the surface using cleaning agents with the defect opening, then dry thoroughly.	<div>More careful surface treatment with wire blush</div>
Dyeing treatment			Penetrant is painted on the surface. Keep for 5 to 60 minutes, so that penetrant penetrates enough into the defect.	
Removal / cleaning process			Penetrant on the surface is removed with dry waste cloth. Then wiped up with moisturized cloth.	<div>More carefully</div>
Development process			Developing powder is coated on the surface with a thin and uniform coating, after stirring developing powder spray sufficiently. Development time is usually 10 to 30 minutes.	
Observation			Observe the surface of test material in a bright place. Crack (flaw) appears as red indication on a white background.	

## DPT results (Platen SH inlet header 4 stub weld portion)

	After DPT	After grinding off
<b>【Singrauli #6】</b> ✓ One linear indication in tube side. ✓ Disappeared after grinding off 1mm depth from surface.		
<b>【Uncahar #2】</b> ✓ Two circular indication pattern were detected. ✓ After grinding off, a new circular indication pattern appeared, that was not judged as crack.		

## DPT (Liquid Penetrant Testing) (1)

### 【Classification of penetrant indication】

Based on JIS Z 2343-1:2005 「Non-destructive testing—Penetrant testing—Part 1 : General principles—Method for liquid penetrant testing and classification of the penetrant indication」







*Classification of the penetrant indication			
Classification of the penetrant indication		Mark	Definition
Isolated penetrant indication	Indication by cracking	C	Indication by cracking
	Indication with linear pattern	L	Indication in length more than 3 times as width except for cracking
	Indication with circular pattern	R	Non linear indication except for cracking
Continuous penetrant indication		F	A number of indication existing on a line
Dispersed penetrant indication		S	A number of indication existing in a constant area

## DPT (Liquid Penetrant Testing) (2)

### 【Classification by the position and direction in weld】

Based on JIS Z 2343-1:2005 「Non-destructive testing—Penetrant testing—Part 1 : General principles—Method for liquid penetrant testing and classification of the penetrant indication」

\*Classification by the position and the direction in weld

Position and direction of penetrant indication	Mark	Illustration (C,L,R,S in figures show classification of the penetrant indication)
Longitudinal direction along weld line	A	
Horizontal direction perpendicular to weld line	B	
In weld metal	X	
Longitudinal direction along HAZ line	C	
Horizontal direction perpendicular to HAZ line	D	
In Base metal	E	

8 x 2 F : More than 2 indications with 8mm in length on a line  
(0.5) : 0.5mm depth of flaw

## DPT (Liquid Penetrant Testing) (3)

### 【Criteria for indication by “Technical standards for thermal power generation facilities”】

Based on JIS Z 2343-1:2005 「Non-destructive testing—Penetrant testing—Part 1 : General principles—Method for liquid penetrant testing and classification of the penetrant indication」

- No penetrant indication by crack
- No linear penetrant indication and indication by linear flaw with longer than 1mm in length.
- No circular penetrant indication and indication by circular flaw with longer than 4mm in length.
- In case of 4 or more circular penetrant indications or circular indications by circular flaw located in a line, the spacing between adjacent indications needs to be longer than 1.5mm.
- No more than 10 or more circular penetrant indications or circular indications by circular flaw are included within the rectangular area of 3750mm<sup>2</sup> (short side length is longer than 25mm)

## Ultrasonic testing TOFD ( Time of Flight Diffraction)

## Ultrasonic testing (1)

Radiographic testing and ultrasonic testing are the typical nondestructive testing that inspects the inside of weld of tubes and pipes. In general, when setting Radiographic film is difficult, the ultrasonic testing is applied.

### 【Detecting equipment】

- **DSM35 Krautkramer**  
**Universal UltrasonicFlaw Detector**




### 【Couplant】

- **Glycerin paste or glycerin solution**  
**with the 75% concentration or more.**

## Ultrasonic testing (2)

### 【Principle of ultrasonic testing (UT)】

As for the butt-weld joint, "angle beam method" is usually applied because of weld reinforcement.




## Ultrasonic testing (3)

### 【Calculation of defect position】

Y can be measured with the scale and W can be read from CRT.  
The position of the defect can be calculated by the following formula.

$$d = W \times \cos \theta \quad \theta \text{ (angle of refraction) is measured beforehand,}$$


$$k = Y - W \times \sin \theta \quad \text{usually using nominal value 40,45,60,65,70.}$$



## Ultrasonic testing (4)

### 【Distinction of defect and measurement of echo height】

The echo that appears on CRT is judged whether a defect or not (shape echo) from the reflection source and the echo height. The reflection source is calculated from d and k in equations. If it is located in the weld, the echo is judged to come from a weld defect. The H-line is defined by linking the heights of the echo on CRT that reflects at the drilled hole with 3mm in the diameter of reference test block RB41. M-line is a half of H-line (-6db), L-line is a quarter of the height of H-line (-12db). These lines are called as "Dividing curves of echo height". That is made before flaw detection. The echo that exceeds L line in this echo height area during scanning the probe for flaw detection is judged to be a defect based on L line.




## Ultrasonic testing (5)

### 【Measurement of length of defect】

The range that exceeds L line during scanning the probe along the direction of the weld line is defined as "the indication length of defect".

(JIS Z3060:2002)



## Ultrasonic testing (6)

### 【Classification of flaw】

Echo height area and classification of flaw by indication length of flaw							
Area	Ⅲ in case of level M detection Ⅱ and Ⅲ in case of level L detection			Ⅳ			
	thickness (t)	$18 \leq t$	$18 < t \leq 60$	$60 < t$	$18 \leq t$	$18 < t \leq 60$	$60 < t$
Classification							
The first class		$\leq 6$	$\leq t/3$	$\leq 20$	$\leq 4$	$\leq t/4$	$\leq 15$
The second class		$\leq 9$	$\leq t/2$	$\leq 30$	$\leq 6$	$\leq t/3$	$\leq 20$
The third class		$\leq 18$	$\leq t$	$\leq 60$	$\leq 9$	$\leq t/2$	$\leq 30$
The fourth class	The one exceeding the third class						
JIS Z3060:2002							
from appendix 7 of examining ultrasonic wave of welded steel joint							

## Ultrasonic testing (7)

### 【Acceptance Criteria】

To satisfy either of the following (1) or (2).

- (1) Height of the reflected wave from the flaw in the weld on CRT must be below the height of reflected wave from the reference hole corrected by the probe to flaw distance.
- (2) The length of the flaw from which the height of the reflected wave on CRT beyond the height of reflected wave from the reference hole corrected by probe to flaw distance, must be the value or less as shown below.


Division of thickness of weld(mm)	Length(mm)
$t \leq 18$	6
$18 < t \leq 57$	1/3 of thickness of weld
$57 < t$	19

\*Technical standards for thermal power generation facilities



## TOFD ( Time of Flight Diffraction) method (1)

### 【UT inspection】

- ✓ Angle beam probe detection
- ✓ Angle of refraction  $70^\circ$



### 【TOFD inspection】



- ✓ High inspection efficiency
- ✓ Flaw sizing in depth direction
- ✓ High sensitivity

## TOFD ( Time of Flight Diffraction) method (2)

Time of Flight Diffraction (TOFD) method of Ultrasonic inspection is a very sensitive and accurate method for nondestructive testing of welds for defects.

### 【Detecting equipment】

- $\mu$ -Tomoscan(R/D Tech)
  - Amplitude linearity: within  $\pm 3\%$  based on JIS Z 2352 4.1.
  - Time base linearity: within  $\pm 1\%$  of full scale based on JIS Z 2352 4.2.

### 【Probes and Wedges】

- Probes for transmission and receiver are the longitudinal wave angle beam probe with the same performance.
  - Wave frequency:  $2 \sim 10\text{MHz}$
  - Resonator dimensions:  $0.25\text{in} \sim 0.5\text{in}$
  - Wedges: the longitudinal wave angle  $45^\circ$  or  $60^\circ$

### 【Couplant】

Glycerin paste or glycerin solution with the 75% concentration or more.

## TOFD ( Time of Flight Diffraction) method (3)

### 【Test sample】

- Test sample with same dimension as inspected part is preferable .

### 【An example of selection of transducers and transducers spacing】


Thickness of sample (mm)	Number of pair of transducers	Center wave frequency (MHz)	Dimension of transducers (mm)	Nominal refractive angle ( $^\circ$ )	Transducers spacing (mm)
25	1 pair	$5 \sim 10$	$2 \sim 6$	60	58
90	2 pairs	$5 \sim 10$	$2 \sim 6$	60	69
		$2 \sim 5$	$6 \sim 12$	45	140

## TOFD ( Time of Flight Diffraction) method (4)

### 【Sensitivity of detection】

- The sensitivity of detector is adjusted at the 80% of echo height from the horizontal cave that is the lowest echo. Also the noise level is kept at lower than 5 to 10%.



### Test sample



## TOFD ( Time of Flight Diffraction) method (5)

### 【Flaw detection】

- The pair of probes across the weld line is manually scanned in the direction parallel to the weld.
- The range of flaw to detect is within the extent to 1 inch (25.4mm) away from weld portion.




## TOFD ( Time of Flight Diffraction) method (6)

### 【Evaluation】

➢ Flaw (depth, length and height) is evaluated by D-scan image.


An example of flaw image by D-scan





## UT& TOFD inspection

### 【UT inspection】

- ✓ Angle beam probe detection
- ✓ Angle of refraction 70 °



### 【TOFD inspection】





- ✓ High inspection efficiency
- ✓ Flaw sizing in depth direction
- ✓ High sensitivity

## UT inspection results (Singrauli #6)

UT • TOFD inspection location



(RH outlet header)




UT detection results

Flaw ?	X	Y	W	d	k	Region of echo height	l	Remarks
1	582	93	104.6	37.5	-4.7	II	10	Out of scope of TOFD inspection
2	820	122	129.2	46.3	1.4	III	34	
3	940	51	26.8	9.6	26	II	6	
4	1110	101	101.3	36.3	6.4	II	8	


## UT inspection results (Singrauli #6)

UT detection results

Flaw ?	X	Y	W	d	k	Region of echo height	l	Remarks
1	582	93	104.6	37.5	-4.7	II	10	Out of scope of TOFD inspection
2	820	122	129.2	46.3	1.4	III	34	
3	940	51	26.8	9.6	26	II	6	
4	1110	101	101.3	36.3	6.4	II	8	



Dividing curves of echo height



【Acceptance Criteria】


Division of thickness of weld (mm)	Length (mm)
$t \leq 18$	6
$18 < t \leq 57$	1/3 of thickness of weld
$57 < t$	19

\*Technical standards for thermal power generation facilities


## Correspondence between UT and TOFD inspection result (Singrauli 6 unit)

UT detection results

Flaw ?	X	Y	W	d	k	Region of echo height	l	Remarks
1	582	93	104.6	37.5	-4.7	II	10	Out of scope of TOFD inspection
2	820	122	129.2	46.3	1.4	III	34	
3	940	51	26.8	9.6	26	II	6	
4	1110	101	101.3	36.3	6.4	II	8	



### 【 TOFD inspection result 】



## UT inspection results (Unchahar #2)


UT • TOFD inspection location



( Final SH outlet header)

- ✓ No flaw echo exceeding the criteria was detected by UT.

### 【 TOFD inspection result 】




- ✓ No flaw echo judged as a crack.
- ✓ Continuous subtle flaw echoes at about 80mm in depth from surface.



## Sample tube inspection

## Sample tube inspection (1)

### 【Examination items】



- 1: Scale thickness on inner surface of tube • Microstructure
- 2: Hardness
- 3: Tube Dimension
- 4-1: Scale volume on inner surface of tube (upper side)  
Observation of scale surface
- 4-2: Scale volume on inner surface of tube (under side)
- 5: Scale composition • Appearance of tube
- 6: Preservation

## Sample tube inspection (2)

### 【Tube appearance observation】

100 mm in length

Cutting the tube

Dissolve in the acid solution

H<sub>2</sub>O.....77.6 ml  
HCl.....22.2 ml (8%)  
Inhibitor.....0.2 ml (2%)  
at 60±5°C for 1~2Hr

or

Dissolve in the ammonia solution

H<sub>2</sub>O.....58.8 ml  
HCl.....40 ml (10%)  
H<sub>2</sub>O<sub>2</sub> ...1.2 ml (1.2%)  
40 ~ 50 °C for 60 to 90 minutes  
(until Cu is removed.)

Acid cleaning

Observation

Appearance of fireside of tube outside

As received


After acid cleaning



Appearance of fireside of tube inside

As received

After acid cleaning



## Sample tube inspection (3)

### 【Tube Dimension】

Cutting the tube

12~18mm in thickness

Acid cleaning

hydrochloric acid ammonia solution  
HCL(35%) ...29ml  
Inhibitor.....1ml (60±5°C)

or



Ammonia (28%) ...16ml  
Bromine acid soda..... 1 g  
Bicarbonate of ammonium 1.2g  
(room temperature)

Grinding

# 80 → # 600 waterproof SiC paper

Measurement

- Comparison with designed dimension
- Local thinning  
(High temperature corrosion, local corrosion)
- Deformation (Bulging)



## Sample tube inspection (4)

### 【Hardness measurement】

Cutting the tube

12~18mm in thickness



Grinding

# 80 → # 600 water proof SiC paper

Measurement

Vickers hardness test  
or  
Rockwell hardness test

- Comparison with virgin material data



No fin tube

Fin tube

Average of 3 times measurement for each points

## Sample tube inspection (5)

### 【Scale composition analysis】

Cutting the tube

100 mm in length

Dissolution of scale on inside surface

Dissolve in the acid solution  
H<sub>2</sub>O.....77.6 ml  
HCl.....22.2 ml (8%)  
Inhibitor.....0.2 ml (2%)  
at 60±5°C for 1~2Hr

or

Dissolve in the ammonia solution  
H<sub>2</sub>O.....58.8 ml  
HCl.....40 ml (10%)  
H<sub>2</sub>O<sub>2</sub> ...1.2 ml (1.2%)  
40 ~ 50 °C for 60 to 90 minutes  
(until Cu is removed.)

Evaporation to dryness

Dissolution in the acid solution for chemical analysis

Dissolve in the acid solution HCl 10cc, before HNO<sub>3</sub> 10cc  
for Atomic Absorption Spectrometry analysis

Atomic Absorption Spectrometry analysis

Analysis elements

Fe, Cu, Ni, Mn, Zn, Al

Fe<sub>3</sub>O<sub>4</sub> : Fe=1.38 : 1 ∴ Fe<sub>3</sub>O<sub>4</sub> =Fe×1.38


CuO=Cu×1.25, NiO=Ni×1.27, MnO=Mn×1.29,

ZnO=Zn×1.24, Al<sub>2</sub>O<sub>3</sub>=Al×1.89




## Sample tube inspection (6)

### 【Scale adhesion volume】




## Sample tube inspection (7)

### 【Scale observation】




## Sample tube inspection (8)

### 【Scale thickness measurement】



## Sample tube inspection (9)

### 【Microstructural observation】



## Sample tube inspection (Sample tube specification Singrauli #6)

Sample	Material	Designed OD×t(mm)	Designed Temperature(°C)	Designed Pressure (MPa)
Platen-SH #12-3	SA213T11®	φ 47.63×t8.6	Not available	17.46
	SA213T11	φ 47.63×t10.0	Not available	
RH #3-1 (in penthouse)	SA213T22®	φ 54.0×t5.6	540	5.27
	SA213T22	φ 54.0×t5.6	540	
RH #14-5 (in furnace)	SA213T22	φ 54.0×t4.5	Not available	5.27
	SA213T11®	φ 54.0×t4.0	Not available	

Chemical composition analysis results by spark discharge optical emission analysis (wt%)

Sample tube	C	Si	Mn	P	S	Cr	Mo
Platen-SH#12-3	0.10	0.53	0.38	0.026	0.012	1.14	0.46
RH #3-1 (in penthouse)	0.10	0.28	0.45	0.013	0.008	2.20	0.95
RH #14-5 (in furnace)	0.10	0.67	0.41	0.006	0.008	1.30	0.58
SA213T11 (JIS-STBA23)	≤0.15	0.50~1.00	0.30~0.60	≤0.030	≤0.030	1.00~1.50	0.45~0.65
SA213T22 (JIS-STBA24)	≤0.15	≤0.50	0.30~0.60	≤0.030	≤0.030	1.90~2.60	0.87~1.13

## Sample tube inspection (Sample tube specification Unchahar #2)

Sample	Material	Designed OD×t(mm)	Designed Temperature (°C)	Designed Pressure (MPa)
Platen-SH #3-8	SA213T22	φ 51.0×t9.6	553	17.24
	SA213T11®	φ 51.0×t7.1	503	
Final-SH #1	SA213T22	φ 51.0×t9.6	554	17.24
	SA213T22®	φ 51.0×t8.8	545	
Final-SH #119	SA213T22	φ 51.0×t9.6	545	17.24
	SA213T22®	φ 51.0×t8.8	534	

Chemical composition analysis results by spark discharge optical emission analysis (wt%)

Sample tube	C	Si	Mn	P	S	Cr	Mo
Platen-SH #3-8	0.09	0.58	0.44	0.032	0.010	1.12	0.49
Final-SH #1	0.10	0.24	0.42	0.030	0.012	2.20	0.95
Final-SH #119	0.10	0.24	0.42	0.030	0.013	2.22	0.96
SA213T11 (JIS-STBA23)	≤0.15	0.50~1.00	0.30~0.60	≤0.030	≤0.030	1.00~1.50	0.45~0.65
SA213T22 (JIS-STBA24)	≤0.15	≤0.50	0.30~0.60	≤0.030	≤0.030	1.90~2.60	0.87~1.13

## Portable chemical analysis equipment (for information)

Portable chemical composition analysis by spark excitation



元素	Low Alloy		High Alloy		High Alloy	
	0.010 ~ 4.3	0.01 ~ 1.8	0.01 ~ 3.16	0.01 ~ 4.50	0.01 ~ 6.30	0.01 ~ 10.00
C	0.01 ~ 18.5	0.01 ~ 5	0.01 ~ 5.60	0.01 ~ 4.50	0.01 ~ 6.30	0.01 ~ 10.00
Mn	0.01 ~ 18.5	0.01 ~ 2.1	0.01 ~ 10.00	0.01 ~ 10.00	0.01 ~ 10.00	0.01 ~ 10.00
Si	0.01 ~ 11.8	0.01 ~ 10.0	0.01 ~ 10.00	0.01 ~ 10.00	0.01 ~ 10.00	0.01 ~ 10.00
Al	0.01 ~ 9.5	0.01 ~ 1.8	0.01 ~ 8.00	0.01 ~ 10.00	0.01 ~ 10.00	0.01 ~ 10.00
Ni	0.01 ~ 5.4	0.01 ~ 1.5	0.01 ~ 45.00	0.01 ~ 10.00	0.01 ~ 10.00	0.01 ~ 10.00
Cr	0.01 ~ 2.3	0.01 ~ 1.5	0.01 ~ 4.0	0.01 ~ 10.00	0.01 ~ 10.00	0.01 ~ 10.00
Co	0.01 ~ 9.5	0.01 ~ 1.0	0.01 ~ 11.0	0.01 ~ 10.00	0.01 ~ 10.00	0.01 ~ 10.00
V	0.01 ~ 2.7	0.01 ~ 0.6	0.01 ~ 9.0	0.01 ~ 10.00	0.01 ~ 10.00	0.01 ~ 10.00
Ti	0.01 ~ 14.2	0.01 ~ 2.0	0.01 ~ 4.0	0.01 ~ 10.00	0.01 ~ 10.00	0.01 ~ 10.00
Mo	0.01 ~ 0.12	0.01 ~ 5.0	0.01 ~ 7.5	0.01 ~ 10.00	0.01 ~ 10.00	0.01 ~ 10.00
A	0.01 ~ 1.8	0.01 ~ 3.1	0.01 ~ 8.8	0.01 ~ 10.00	0.01 ~ 10.00	0.01 ~ 10.00
W	0.01 ~ 3.7	0.01 ~ 6.1	0.01 ~ 10.0	0.01 ~ 10.00	0.01 ~ 10.00	0.01 ~ 10.00
B	0.01 ~ 1.6	0.01 ~ 0.16	0.01 ~ 0.16	0.01 ~ 10.00	0.01 ~ 10.00	0.01 ~ 10.00
Pb	0.01 ~ 0.25	0.01 ~ 0.16	0.01 ~ 0.16	0.01 ~ 10.00	0.01 ~ 10.00	0.01 ~ 10.00
Mg	0.01 ~ 0.0	0.01 ~ 0.0	0.01 ~ 0.0	0.01 ~ 10.00	0.01 ~ 10.00	0.01 ~ 10.00
Fe	0.01 ~ 0.0	0.01 ~ 0.0	0.01 ~ 0.0	0.01 ~ 10.00	0.01 ~ 10.00	0.01 ~ 10.00

## Sample tube inspection items

Singrauli #6 Sample tube	Inspection item						
	1 Outer surface appearance	2 Internal surface appearance	3 Tube dimension + Hardness	4 Metallography	5 Scale analysis	6 RLA by microstructure degradation	7 Creep rupture test
Platen-SH #12-3	○	○	○	○	○	○	○
RH #3-1 (in penthouse)	○	○	○	○	○	○	○
RH #14-5 (in furnace)	○	○	○	○	○	○	○

Unchahar #2 Sample tube	Inspection item						
	1 Outer surface appearance	2 Internal surface appearance	3 Tube dimension + Hardness	4 Metallography	5 Scale analysis	6 RLA by microstructure degradation	7 Creep rupture test
Platen-SH	○	○	○	○	○	○	○
Final-SH#1	○	○	○	○	○	○	○
Final-SH#119	○	○	○	○	○	○	○


## Sample tube inspection (Outer surface appearance)

		Appearance before acid cleaning	After acid cleaning
Platen SH	Outside surface		
	Inside surface		


- ✓ Trace of corrosion at outside surface
- ✓ Slightly rough condition at inside surface

Dissolve in the acid solution  
 $H_2O$ .....77.6 ml  
 $HCl$ .....22.2 ml (8%)  
 Inhibitor.....0.2 ml (2%)  
 at  $60 \pm 5^\circ C$  for 1~2Hr


## Sample tube inspection (Tube dimension)




- ✓ OD of RH tubes in penthouse and in furnace was less than designed value.
- ✓ Thickness of RH tubes in penthouse was less than designed value.
- ✓ OD of each tube was less than designed value.
- ✓ Thickness of each tube was larger than the designed value.




## Sample tube inspection (Hardness)




- ✓ Hardness values were stable in circumferential direction.
- ✓ Measured values in SA213T11 were higher than the normal value of virgin material by Japanese steel manufacturer.
- ✓ Measured values in SA213T22 were lower than the normal value of virgin material by Japanese steel manufacturer.



## Sample tube inspection ( Steam oxide scale adhering condition)



- ✓ Among singrauli #6 tubes, average thickness of steam oxide scale was remarkably large in RH tube(in penthouse) 500  $\mu m$ .



## Sample tube inspection ( Steam oxide scale composition analysis)

	SEM Image (Scanning electron microscope)	Element Mapping Image by EPMA (Electron probe micro analyzer)		
Singrauli #6	Base metal	Fe	O	Cr
	Steam oxide	Fe	O	Cr
(Unchahar #2)	Base metal	Fe	O	Cr
	Steam oxide	Fe	O	Cr


- ✓ Dual layer composed of inner layer (Fe, O, Cr) and outer layer (Fe, O).



## Sample tube inspection (Metallography)

Singrauli #6			
	Platen-SH (SA213T11)	RH-Penthouse (SA213T22)	RH-Furnace (SA213T22)
Outside surface side			
Inside surface side			


- ✓ Slight degradation observed in RH-Penthouse (SA213T22).



## Sample tube inspection (Metallography)

Unchahar #2			
	Platen-SH #3 (SA213T11)	RH-Penthouse (SA213T22)	RH-Furnace (SA213T22)
Outside surface side			
Inside surface side			

- ✓ No remarkable degradation for each tube




## Creep rupture test


### Creep rupture test (1)

Creep rupture test is the most reliable method to evaluate the remaining creep life.

(Test machine)



(Example of specimen for creep rupture test)



- The larger size of specimen is better because of oxidation during the test.

(Test condition)

- Test condition is determined based on the hoop stress under operational condition.
- In order to shorten the test time, test stress or temperature are set at higher than operational condition.

### Creep rupture test (Parameter method) (2)

(Example of test condition and result by parameter method)


- The lowest stress is almost same stress as operational stress .  
The temperature is set so that the estimated creep rupture time is within about 3000hrs .
- With the test temperature and rupture time, LMP (Larson-Miller parameter) is obtained.

Sample	Material	Test condition		Estimated rupture time (h)	Rupture time t (h)	Rupture LMP C=15.8
		Temperature T (°C)	Stress (MPa)			
2nd SH tube	A213 T22	670	30	2,500	1,200	17,806
		670	40	1,500	600	17,522
		670	50	800	400	17,356
		670	60	400	100	16,788

$$LMP = (273.15 + T) (C + \log t)$$

### Creep rupture test (Parameter method) (3)

- If the reliable virgin material data is available, the equivalent temperature can be estimated and residual life is evaluated with the equivalent temperature instead of designed temperature.



Residual life "tr" at a temperature  $T$  :  $tr = 10^{(LMP_r/T - C)}$

The whole life "t" of the virgin material at a temperature  $T$  :  $t = 10^{(LMP_o/T - C)}$

To hold the assumption that "t = tr + to (to: operating hour)", appropriate  $T_E$  can be determined.

The residual life tr is calculated at temperature  $T_E$

$tr = 10^{(LMP_o/(273.15 + T_E) - C)}$

### Creep rupture test (Isostress method) (4)

(Example of test condition and result)


- The stress is set same as operational stress .
- The lowest temperature is set so that the estimated creep rupture time is within about 3000hrs .

Sample	Material	Test condition		Estimated rupture time	Rupture time
		Temperature T (°C)	Stress (MPa)		
2nd SH tube	A213 T22	650	30	2,500	2,400
		675	30	1,000	1,200
		700	30	200	400

### Creep rupture test (Isostress method) (5)


(Evaluation of test result by Isostress method)

- The rupture time is extrapolated to operation temperature.



### Creep rupture test (condition and test specimens) Singrauli #6

Sample tube	Portion	Material	Test condition		Shape of specimen
			Tem. (°C)	Stress (MPa)	
Platen-SH	Base Metal	SA213T11	665	49.0	φ 6mm round bar
			665	63.7	
			700	38.3	
	Weld Metal	SA213T11	665	49.0	φ 6mm round bar
			665	63.7	
			700	38.3	
RH(in furnace)	Base Metal	SA213T11	665	44.1	Arc shaped
			665	58.8	
			700	27.9	
	Weld Metal	SA213T11	665	44.1	Arc shaped
			665	58.8	
			700	27.9	




### Creep rupture test (condition and test specimens) Unchahar #2

Sample tube	Portion	Material	Test condition		Shape of specimen
			Tem. (°C)	Stress (MPa)	
Platen-SH	Base Metal	SA213T11	635	68.6	φ 6
			635	83.4	
			665	45.9	
	Weld Metal	SA213T11	665	68.6	φ 6
			665	83.4	
			700	45.9	
Final-SH #119	Base Metal	SA213T22	665	63.7	φ 6
			665	78.5	
			700	38.3	
	Weld Metal	SA213T22	665	63.7	φ 6
			665	78.5	
			700	38.3	



### Creep rupture test specimens before and after testing



## Creep rupture test results Singrauli #6


Component	Material	Test condition		Rupture time t (h)	LMP* C=19.95	Fracture elongation (%)	Reduction of area (%)
		Temp. T (°C)	Stress (MPa)				
Platen-SH	Base Metal SA 213 T11	665	49.0	187.7	20,852	102	97
		665	63.7	48.7	20,302	87	94
		700	38.3	76.1	21,248	88	94
	Weld Metal SA 213 T11	665	49.0	149.0	20,758	36	92
		665	63.7	39.0	20,212	44	92
		700	38.3	43.5	21,012	35	95
Component	Material	Test condition		Rupture time t (h)	LMP* C=17.52	Fracture elongation (%)	Reduction of area ** (%)
		Temp. T (°C)	Stress (MPa)				
RH(in furnace)	Base Metal SA 213 T11	665	44.1	457.0	18,933	53	57
		665	58.8	139.2	18,448	62	63
		700	27.9	319.4	19,488	39	55
	Weld Metal SA 213 T11	665	44.1	310.9	18,776	20	52
		665	58.8	69.3	18,164	13	53
		700	27.9	296.8	19,457	16	56

\*LMP=(273.15+T) (C+log t)

•Fracture elongation: (L-L<sub>0</sub>)/L<sub>0</sub>, L<sub>0</sub>: Initial gauge length, L: Gauge length after rupture

•Reduction of area: (A<sub>0</sub>-A)/A<sub>0</sub>, A<sub>0</sub>: Initial cross sectional area, A: cross sectional area after rupture

## Creep rupture test results Singrauli #6



NIMS :Natal Institute of Materials Science

✓Creep rupture strength of base metal in Platen-SH is lower than NIMS data.

✓ Creep rupture strength of base metal in RH (in furnace) is almost same as NIMS data.

\* LMP=(273.15+T) (C+log t)

## Residual life evaluation by creep rupture test Singrauli #6

Parameter method (evaluated at designed temp.)						
Component	Material	Hoop Stress σ (MPa)	LMP obtained by creep rupture test		Designed temp. T (°C)	Residual life tr (h)
			C=19.95 (SH)	C=17.52 (RH)		
Platen-SH	Base Metal SA 213 T11	38.3	21,248	540(※1)	1,505,000	0.10
	Weld Joint SA 213 T11	38.3	21,012	540(※1)	770,000	0.18
RH(in furnace)	Base Metal SA 213 T11	27.9	19,488	540(※2)	2,783,000	0.06
	Weld Joint SA 213 T11	27.9	19,457	540(※2)	2,549,000	0.06

※1; Designed temp. at Platen-SH Outlet Header

※2; Designed temp. at RH Outlet Header

Operation hours to: 172000 h

✓ Hoop stress  $\sigma = P (D-t) / 2t$

where P : Designed pressure

D : Measured OD of sample tube

t : Measured thickness of sample tube

✓  $tr = 10 (LMP/(273+T)-C)$

## Residual life evaluation by creep rupture test Singrauli #6

Parameter method (evaluated at equivalent temp.)							
Component	Material	Hoop Stress σ (MPa)	LMP obtained by creep rupture test		Equivalent temperature T <sub>E</sub> (°C)	Residual life tr (h)	Creep life consumption ratio φ <sub>c</sub> to/(to+tr)
			C=19.95 (SH)	C=17.52 (RH)			
Platen-SH	Base Metal SA 213 T11	38.3	21,248	21,339	553	598,000	0.22
	Weld Joint SA 213 T11	38.3	21,012	21,339	553(※3)	309,000	0.36
RH(in furnace)	Base Metal SA 213 T11	27.9	19,488	19,531	551	1,347,000	0.11
	Weld Joint SA 213 T11	27.9	19,457	19,531	551(※3)	1,235,000	0.12

※3; Same equivalent temperature used as base metal

Operation hours to: 172000 h

**Assumption : Initial creep rupture strength = NIMS data**

$$LMP_o = (273.15 + T_E) (C + \log (to + tr))$$


$$tr = 10 (LMP/(273.15 + T_E) - C)$$

## Creep rupture test results Unchahar #2

Component	Material	Test condition		Rupture time t (h)	LMP C=19.95	Fracture elongation (%)	Reduction of area (%)	Remark
		Temp. T (°C)	Stress (MPa)					
Platen-SH	Base Metal SA 213 T11	635	68.6	278.7	20,341	62	94	Ruptured
		635	83.4	90.8	19,899	57	91	Ruptured
		665	45.9	322.4	21,072	86	94	Ruptured
	Weld Metal SA 213 T11	635	68.6	264.3	20,320	16	81	Ruptured
		635	83.4	127.5	20,033	18	82	Ruptured
		665	45.9	287.5	21,026	13	80	Ruptured
Component	Material	Test condition		Rupture time t (h)	LMP C=15.77	Fracture elongation (%)	Reduction of area (%)	Remark
		Temp. T (°C)	Stress (MPa)					
Final-SH#119	Base Metal SA 213 T22	665	63.7	113.1	16,725	69	91	Ruptured
		665	78.5	32.1	16,212	55	92	Ruptured
		700	38.3	162.6	17,503	67	94	Ruptured
	Weld Metal SA 213 T22	665	63.7	86.0	16,614	30	84	Ruptured
		665	78.5	27.3	16,146	31	83	Ruptured
		700	38.3	143.7	17,451	22	81	Ruptured

LMP=(273.15+T) (C+log t)

## Creep rupture test results Unchahar #2



\* LMP=(273.15+T) (C+log t)

✓Creep rupture strength of SA 213 T22 is lower than NIMS data.

✓ Creep rupture strength of SA213 T11 is almost same as NIMS data.



## Creep rupture test results Unchahar #2

Parameter method (evaluated at designed temp.)								
Component		Material	Hoop Stress  (MPa)	LMP obtained by creep rupture test	Designed temp.T  (°C)	Residual life tr  (h)	Creep life consumption ratio $\phi_c$  to/(to+tr)	Evaluate residual life tr/2  (h)
				C=19.95 (T11) C=15.77 (T22)				
Platen-SH	Base Metal	SA 213 T11	45.9	21,072	503	15,726,180	0.01	7,800,000
	Weld Joint	SA 213 T11	45.9	21,026	503	13,692,433	0.01	6,800,000
Final-SH#119	Base Metal	SA 213 T22	38.3	17,503	534	812,994	0.15	400,000
	Weld Joint	SA 213 T22	38.3	17,451	534	700,466	0.17	350,000

Operation hours to: 139098 h

Parameter method (evaluated at equivalent temp.)									
Component		Material	Hoop Stress  (MPa)	LMP obtained by creep rupture test	LMPo by NIMS virgin material	Equivalent temperature T <sub>e</sub>	Residual life tr	Creep life consumption ratio φ c	Evaluated residual life tr/2
				C=19.95 (T11) C=15.77 (T22)		(°C)	(h)	to/(to+tr)	(h)
Platen-SH	Base Metal	SA 213 T11	45.9	21,072	21,072	Non evaluation(※1)			
	Weld Joint	SA 213 T11	45.9	21,026	21,072				
Final-SH#119	Base Metal	SA 213 T22	38.3	17,503	17,865	573	82,798	0.63	41,000
	Weld Joint	SA 213 T22	38.3	17,451	17,865	573(※2)	71,826	0.66	35,000


※1: Equivalent temperature could not be evaluated since the test results for base metal in Platen-SH tube indicate higher creep rupture strength than NIMS data.

※2: Same equivalent temperature used as base metal


## Sampling of replica and extracted replica

### Sampling of replica and extracted replica (1)


#### Microstructure of weld portion cross section



### Sampling of replica and extracted replica (2)



### Sampling of replica and extracted replica (3)



## Boiler remaining life assessment

## Japanese Boiler RLA Guideline (1)

To extend periodical inspection interval 2 year to 4year after 100,000 hours operation.

### (1) Degradation factor to be evaluated

- Creep rupture remaining life  
(Designed temperature beyond 450°C)

### (2) Components to be evaluated

- Furnace evaporation header
- Super heater header or Main steam pipe
- Reheater header or High temperature reheat pipe

Representative points among high heat loaded and high stressed portion in these components



Japan International Cooperation Agency

JICA Study Team for Enhancing Efficiency of Operating Thermal Power Plant in NTPC-India Boiler RLA

109

## Japanese Boiler RLA Guideline (2)

### (3) Method to assess the remaining life

- More than one method used as shown in table below

Method	Guideline		This study	
	Base metal	Weld (HAZ)	Base metal	Weld (HAZ)
Hardness measuring	—	○		
Electrical resistance	—	○		
Chemical composition of carbide	○	○		
Creep cavity evaluation	—	○		
Microstructural comparison	○	○	○	○
Ultra sonic scattering noise	—	○		
Interparticle spacing	○	—		
Crystal grain deformation	○	—		
Destructive test	○	○		
Analytical method	○	○		

○ : applicable, — : not applicable

### (4) Effective (countable) remaining life

- 1/2 of remaining life evaluated by above methods



Japan International Cooperation Agency

JICA Study Team for Enhancing Efficiency of Operating Thermal Power Plant in NTPC-India Boiler RLA

110

## Microstructural comparison method outline

Remaining life synthetically evaluated by three types of damage related to the creep damage ratio as shown below.

### 【Base metal】

- Evaluation of average diameter of grain boundary precipitates
- Comparison with the reference picture of microstructure
- Comparison with the reference picture of carbide precipitation

### 【Weld metal】

- Comparison with the reference picture of creep void and micro crack
- Comparison with the reference picture of microstructure
- Comparison with the reference picture of carbide precipitation




Japan International Cooperation Agency

JICA Study Team for Enhancing Efficiency of Operating Thermal Power Plant in NTPC-India Boiler RLA

111

## Microstructural comparison method




Japan International Cooperation Agency

JICA Study Team for Enhancing Efficiency of Operating Thermal Power Plant in NTPC-India Boiler RLA


112

## Microstructural comparison method (Base metal)




113

## Microstructural comparison method (Weld portion)




114


## Microstructural comparison method in this study (Base metal)




## Microstructural comparison method in this study (Base metal)




## Microstructural comparison method in this study (Base metal)




## Microstructural comparison method in this study (Base metal)




## Microstructural comparison method in this study (Base metal)



## Microstructural comparison method in this study (Weld)




## Microstructural comparison method in this study (Weld)



121

## Synthetic evaluation by microstructural comparison method in this study



JICA Study Team for Enhancing Efficiency of Operating Thermal Power Plant in NTPC-India Boiler RLA

122

## Replica inspection ( Singrauli #6 )

Component	Material	Designed				Hoop Stress (MPa)
		OD (mm)	t (mm)	Temp. (°C)	Pressure (MPa)	
Platen SH Outlet Header	SA335P12	508.0	80.0	540	17.46	46.69
De-SH		508.0	70.0	406	18.51	57.89
RH Outlet Header	Left	558.8	50.0	540	4.26	21.68
	Right					
Main Steam Pipe	SA335P22	520.0	85.0	540	17.46	44.67

123

## Replica inspection ( Unchahar #2 )

Component	Material	Designed				Hoop Stress (MPa)
		OD (mm)	t (mm)	Temp. (°C)	Pressure (MPa)	
Final SH Outlet Header	SA335P22	457.2	100.0	555	15.75	28.1
De-SH	Left	406.4	45.0	450	16.44	66.0
	Right					
RH Outlet Header	SA335P22	558.8	45.0	555	4.32	24.7
Main Steam Pipe		355.6	50.3	540	15.74	47.8
Hot Reheat Pipe		508.0	28.0	540	3.69	31.6

JICA Study Team for Enhancing Efficiency of Operating Thermal Power Plant in NTPC-India Boiler RLA

124

## Observation of replica

Observation item	Microstructure	Carbide precipitation	Precipitates free band width along grain boundary	Creep void grade	Average diameter of grain boundary precipitates	Average volume fraction of grain boundary precipitates
Observation method	Optical microscope	TEM (Transmission Electron Microscope)		SEM (Scanning Electron Microscope)		
Observed target	Micro crack and microstructural degradation	Morphology and distribution of precipitates	Quantitative evaluation of precipitates free band width	Micro crack and creep void	Quantitative evaluation of grain boundary precipitates	Quantitative evaluation of grain boundary precipitates
Observed magnification	×500 ×1000	×2000 ×10000	×2000	×500 ×2000	×3000 (Base metal) ×4000 (Fine grain HAZ)	
Observed area	Base metal	○	○		○	○
	Intermetallic zone	○				
	Fine grain HAZ	○	○		○	○
	Coarse grain HAZ	○	○	○		
	Weld metal	○	○			

125

## Microstructure observation results ( Singrauli #6 )

Components	Location	Observed region	Optical microscope observation	
			Microstructural features	
			Precipitation at grain boundary	Precipitates free zone along grain boundary
Reheater outlet header (SA 335 P22)	Left	Circumferential weld	Base metal	Not appeared
			Intermetallic zone	Not appeared
			Fine grain HAZ	Appeared
			Coarse grain HAZ	Not appeared
			Weld metal	
Main steam pipe (SA 335 P22)	Left	Circumferential weld (near the stop valve) intrados side	Base metal	Appeared
			Intermetallic zone	Appeared
			Fine grain HAZ	Appeared
			Coarse grain HAZ	Not appeared
			Weld metal	

JICA Study Team for Enhancing Efficiency of Operating Thermal Power Plant in NTPC-India Boiler RLA

126

## Microstructure observation results ( Singrauli #6 )

Components	Location	Observed region	OM ( Optical microscope observation)	
			Microstructural features	
RH outlet header left (SA 335 P22)	Base metal	Circumferential weld	Precipitation at gain boundary	Precipitates free zone along grain boundary
			Appeared	Not appeared
			Not appeared	Not appeared
			Appeared	
			Appeared	
Main steam pipe left (SA 335 P22)	Base metal	Circumferential weld (near the stop valve)	Appeared	Not appeared
			Appeared	Not appeared
			Appeared	
			Not appeared	

## Microstructure observation results ( Unchahar #2 )

Components	Location	Observed region	OM ( Optical microscope observation)	
			Microstructural features	
RH outlet header (SA 335 P22)	Base metal	Circumferential weld	Precipitation at gain boundary	Precipitates free zone along grain boundary
			Appeared	Not appeared
			Not appeared	Not appeared
			Appeared	
			Appeared	
Main steam pipe (SA 335 P22)	Base metal	Circumferential weld (near the stop valve)	Appeared	Not appeared
			Appeared	Not appeared
			Appeared	
			Not appeared	

## Microstructure observation results ( Unchahar #2 )

Components	Location	Observed region	OM ( Optical microscope observation)	
			Microstructural features	
RH outlet header (SA 335 P22)	Base metal	Circumferential weld	Precipitation at gain boundary	Precipitates free zone along grain boundary
			Appeared	Not appeared
			Not appeared	Not appeared
			Appeared	
			Appeared	
Main steam pipe right (SA 335 P22)	Base metal	Circumferential weld (near the stop valve)	Appeared	Not appeared
			Appeared	Not appeared
			Appeared	
			Not appeared	

## Observation of replica

Observation item	Microstructure	Carbide precipitation	Precipitates free band width along grain boundary	Creep void grade	Average diameter of grain boundary precipitates	Average volume fraction of grain boundary precipitates
Observation method	Optical microscope	TEM (Transmission Electron Microscope)	SEM (Scanning Electron Microscope)			
Observed target	Micro crack and microstructural degradation	Morphology and distribution of precipitates	Quantitative evaluation of precipitates free band width	Micro crack and creep void	Quantitative evaluation of grain boundary precipitates	Quantitative evaluation of grain boundary precipitates
Observed magnification	×500 ×1000	×2000 ×10000	×2000	×500 ×2000	×3000 (Base metal) ×4000 (Fine grain HAZ)	
Observed area	Base metal	○	○	○	○	○
	Intercritical zone	○			○	○
	Fine grain HAZ	○	○		○	○
	Coarse grain HAZ	○	○	○		
	Weld metal	○	○			

## Precipitates distribution observation results ( Singrauli #6 )

Components	Location	Observed region	TEM (Transmission Electron Microscope observation)				
			Carbide precipitates features				
			Precipitates free zone along grain boundary	Featherlike precipitates	Fine needlelike and granular precipitates	Needlelike precipitates	Fine needlelike and granular precipitates in bainite grain
Reheater outlet header (SA 335 P22)	Right	Circumferential weld	Not appeared	Remained		No decrease in ferrite grain	Remaining
						Remaining	
					Remaining		
					Remaining		
					Remaining		
Main steam pipe (SA 335 P22)	Left	Circumferential weld (near the stop valve) (arrows side)	Appeared	Disappeared		No decrease in ferrite grain	Partially disappeared
						Disappeared	
					Disappeared		
					Disappeared		
					Disappeared		

## Precipitates distribution observation results Singrauli #6

Components	Location	Observed region	Precipitates by extracted replica	Reference Picture
RH outlet header left (SA 335 P22)	Base metal	Circumferential weld		
Main steam pipe left (SA 335 P22)	Base metal	Circumferential weld (near the stop valve)		Fine needlelike precipitates in bainite grain disappeared



## Precipitates distribution observation results (Unchahar #2)

Components	Location	Observed region	TEM (Transmission Electron Microscope observation)					
			Precipitates features					
			Precipitates free zone along grain boundary	Featherlike precipitates	Fine needlelike and granular precipitates	Needlelike precipitates	Fine needlelike and granular precipitates in bainite grain	
Final SH outlet header (SA 335 P22)	Left outlet header	Circumferential weld	Base metal	Appeared	Disappeared		No decrease in ferrite grain	Partially disappeared
			Fine grain HAZ				Remaining	
			Coarse grain HAZ			Remaining		
			Weld metal			Remaining		
Main steam pipe (SA 335 P22)	Right	Circumferential weld (near the stop valve)	Base metal	Appeared	Disappeared		No decrease in ferrite grain	Disappeared
			Fine grain HAZ				Spheroidized	
			Coarse grain HAZ			Remaining		
			Weld metal			Remaining		

## Precipitates distribution observation results Unchahar #2

		Precipitates by extracted replica		Reference Picture	
Final SH outlet header (SA 335 P22)	Base metal				
Main steam pipe right (SA 335 P22)	Base metal				
					Fine needlelike precipitates in bainite grain disappeared

## Quantitative evaluation of precipitates free band width

Observation item	Microstructure	Carbide precipitation	Precipitates free band width along grain boundary	Creep void grade	Average diameter of grain boundary precipitates	Average volume fraction of grain boundary precipitates
Observation method	Optical microscope	TEM (Transmission Electron Microscope)			SEM (Scanning Electron Microscope)	
Observed target	Micro crack and microstructural degradation	Morphology and distribution of precipitates	Quantitative evaluation of precipitates free band width	Micro crack and creep void	Quantitative evaluation of grain boundary precipitates	Quantitative evaluation of grain boundary precipitates
Observed magnification	×500 ×1000	×2000 ×10000	×2000	×500 ×2000	×3000 (Base metal) ×4000 (Fine grain HAZ)	
Observed area	Base metal	○	○		○	○
	Intercritical zone	○				
	Fine grain HAZ	○	○		○	○
	Coarse grain HAZ	○	○	○		
	Weld metal	○	○			

## Quantitative evaluation of precipitates free band width

		Precipitates by extracted replica		Singrauli #6	
RH outlet header left (SA 335 P22)	Base metal				
Main steam pipe left (SA 335 P22)	Base metal				

Bar chart showing Precipitates free band width (μm) for Singrauli #6:

- RH-Right: ~1.2 μm
- RH-Left: ~1.0 μm
- MS-intrados: ~1.0 μm
- MS-extrados: ~1.0 μm

## Quantitative evaluation of precipitates free band width

		Precipitates by extracted replica		Unchahar #2	
Final SH outlet header (SA 335 P22)	Base metal				
Main steam pipe right (SA 335 P22)	Base metal				

Bar chart showing Precipitates free band width (μm) for Unchahar #2:

- Final-SH: ~1.2 μm
- MSP-nearSV: ~1.0 μm
- MSP-intrados: ~1.0 μm

## Observation of replica

Observation item	Microstructure	Carbide precipitation	Precipitates free band width along grain boundary	Creep void grade	Average diameter of grain boundary precipitates	Average volume fraction of grain boundary precipitates
Observation method	Optical microscope	TEM (Transmission Electron Microscope)			SEM (Scanning Electron Microscope)	
Observed target	Micro crack and microstructural degradation	Morphology and distribution of precipitates	Quantitative evaluation of precipitates free band width	Micro crack and creep void	Quantitative evaluation of grain boundary precipitates	Quantitative evaluation of grain boundary precipitates
Observed magnification	×500 ×1000	×2000 ×10000	×2000	×500 ×2000	×3000 (Base metal) ×4000 (Fine grain HAZ)	
Observed area	Base metal	○	○		○	○
	Intercritical zone	○				
	Fine grain HAZ	○	○		○	○
	Coarse grain HAZ	○	○	○		
	Weld metal	○	○			