






9/c

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

**Name of Component:** IP Steam Inlet  
**Location:** IP Steam Inlet T joint \_ Weld Metal \_ Replica No. 13  
 Hardness: 180-186HB.



200X






400X

**Observation:** Microstructure shows tempered Bainite with spheroidisation carbides.



Degradation Level- IIL

Fig: 84


<b>ALSTOM</b>	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
<b>NTPC ALSTOM</b> Power Services Pvt. Ltd.	<b>Document</b>	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

<p><b>Name of Component:</b> IP Steam Inlet  <b>Location:</b> IP Steam Inlet T joint _ Heat affected zone _ Replica No. 13  Hardness: 181-185HB.</p>	
	
	
200X	400X
<p><b>Observation:</b> Microstructure shows tempered Bainite with spheroidisation carbides.</p>	<p>Degradation Level- IIL</p>
Fig: 85	

8/17

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

**Name of Component:** IP Steam Inlet  
**Location:** IP Steam Inlet T joint \_ Parent Metal \_ Replica No. 13  
 Hardness: 158-162HB



200X





400X


**Observation:** Microstructure shows ferrite and Bainite with precipitation of carbides at grain boundary.

Degradation Level- IVL


Fig: 86

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B (RLA OF TURBINE)</b>

**Name of Component:** IP Steam Inlet  
**Location:** IP Steam Inlet \_ Parent Metal \_ Replica No. 12  
 Hardness: 203-209HB.



200X



400X



**Observation:** Microstructure shows tempered Bainite with spheroidisation carbides.




Degradation Level- IIL

Fig: 87

219



022

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

<p><b>Name of Component:</b> Main Steam Line  <b>Location:</b> Main Steam Line RHS on Bend_ Parent Metal _ Replica No. 10          Hardness: 128-138HB.</p>	
	
	
200X	400X
<p><b>Observation:</b> Microstructure shows ferrite and Bainite with precipitation of carbides at grain boundary.</p>	
<p>Fig: 88</p>	
<p>Degradation Level- IVL</p>	

<b>ALSTOM</b>	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
<b>NTPC ALSTOM</b> Power Services Pvt. Ltd.	<b>Document</b>	<b>FINAL REPORT VOL. I B (RLA OF TURBINE)</b>

**Name of Component:** Main Steam Line  
**Location:** Main Steam Line LHS on Bend\_ Parent Metal \_ Replica No. 11  
 Hardness: 130-134HB.



200X



400X




**Observation:** Microstructure shows ferrite and Bainite with precipitation of carbides at grain boundary. Degradation Level- IVL

Fig: 89

221



222

<b>ALSTOM</b>	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
<b>NTPC ALSTOM</b> Power Services Pvt. Ltd.	<b>Document</b>	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>


<p><b>Name of Component:</b> HPCV-1 Body  <b>Location:</b> HPCV-1 Body outer _ Parent Metal _ Replica No. 17          Hardness: 181-198HB.</p>	
	
	
200X	400X
<p><b>Observation:</b> Microstructure shows tempered Bainite with spherodisation carbides.          Fig: 90</p>	<p>Degradation Level- IIL</p>

<b>ALSTOM</b>	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
<b>NTPC ALSTOM</b> Power Services Pvt. Ltd.	<b>Document</b>	<b>FINAL REPORT VOL. I B (RLA OF TURBINE)</b>

**Name of Component:** HPCV-2 Body  
**Location:** HPCV-2 Body outer \_ Parent Metal \_ Replica No. 18  
 Hardness: 171-187HB.



200X



400X



**Observation:** Microstructure shows tempered bainite and carbides precipitation at grain boundary is observed.

Degradation Level- IVL



Fig: 91




722

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B (RLA OF TURBINE)</b>

**Name of Component:** IPCV-1 Body  
**Location:** IPCV-1 Body Inner\_ Parent Metal \_ Replica No. 19  
 Hardness: 175-178HB.



200X






400X

**Observation:** Microstructure shows ferrite and bainite and carbides at grain boundaries. Degradation Level- IVL



Fig: 92

<b>ALSTOM</b>	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
<b>NTPC ALSTOM</b> Power Services Pvt. Ltd.	<b>Document</b>	<b>FINAL REPORT VOL. I B (RLA OF TURBINE)</b>


<p><b>Name of Component:</b> IPCV-2 Body  <b>Location:</b> IPCV-2 Body Inner_ Parent Metal _ Replica No. 20  Hardness: 171-179HB.</p>	
	
	
200X	400X
<p><b>Observation:</b> Microstructure shows ferrite and bainite and carbides at grain boundaries. Degradation Level- IVL</p>	
Fig: 93	

225


922

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

**Name of Component:** LP Bypass  
**Location:** LP Bypass con \_ Parent Metal \_ Replica No. 38  
 Hardness: 171-181HB.



200X






400X



**Observation:** Microstructure shows tempered Bainite with spherodisation carbides. Degradation Level- IIL

Fig: 94


<b>ALSTOM</b>	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
<b>NTPC ALSTOM</b> Power Services Pvt. Ltd.	<b>Document</b>	<b>FINAL REPORT VOL. I B (RLA OF TURBINE)</b>

<p><b>Name of Component:</b> LP Bypass  <b>Location:</b> LP Bypass con _ Parent Metal _ Replica No. 39  Hardness: 191-201HB.</p>	
	
	
200X	400X
<p><b>Observation:</b> Microstructure shows tempered Bainite with spheroidisation of carbides.</p>	
<p>Degradation Level- IIL</p>	
<p>Fig: 95</p>	


82C

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B (RLA OF TURBINE)</b>

**Name of Component:** LP Bypass valve  
**Location:** LP Bypass Body\_ Parent Metal \_ Replica No. 51  
 Hardness: 185-196HB.



200X



400X



**Observation:** Microstructure shows tempered Bainite with spheroidisation carbides.

Degradation Level- IIL


Fig: 96

<b>ALSTOM</b>	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
<b>NTPC ALSTOM</b> Power Services Pvt. Ltd.	<b>Document</b>	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

**Name of Component:** HP Bypass valve  
**Location:** HP Bypass Body\_ Parent Metal \_ Replica No. 52  
 Hardness: 122-138HB.





200X




400X

**Observation:** Microstructure shows tempered Bainite with spheroidisation carbides. Degradation Level- IIL

Fig: 97

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

**Name of Component:** IPCV-3  
**Location:** IPCV-3 Inner body\_ Parent Metal \_ Replica No. 54  
 Hardness: 181-187HB



200X



400X



**Observation:** Microstructure shows ferrite and Bainite with precipitation of carbides at grain boundary.

Degradation Level- IVL


Fig: 98

<b>ALSTOM</b>	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
<b>NTPC ALSTOM</b> Power Services Pvt. Ltd.	<b>Document</b>	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

**Name of Component:** IPCV-4  
**Location:** IPCV-4 Inner body\_ Parent Metal \_ Replica No. 55  
 Hardness: 171-178HB

200X





400X


**Observation:** Microstructure shows ferrite and Bainite with precipitation of carbides at grain boundary. Degradation Level- IVL


Fig: 99




	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

**Name of Component:** HPCV-3  
**Location:** HPCV-3 outer body\_ Parent Metal \_ Replica No. 56  
**Hardness:** 186-196HB





200X



400X



**Observation:** Microstructure shows ferrite and Bainite with precipitation of carbides at grain boundary.

Degradation Level- IVL


Fig: 100

<b>ALSTOM</b>	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
<b>NTPC ALSTOM</b> Power Services Pvt. Ltd.	<b>Document</b>	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

**Name of Component:** HPSV -1  
**Location:** HPSV bush-1 \_ Parent Metal \_ Replica No. 57  
 Hardness: 150-164HB



200X





400X

**Observation:** Microstructure shows ferrite and Bainite with precipitation of carbides at grain boundary.



Degradation Level- IVL

Fig: 101

72

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

**Name of Component:** HPSV-2  
**Location:** HPSV con-2 \_ Parent Metal \_ Replica No. 58  
 Hardness: 180-192HB



200X





400X



**Observation:** Microstructure shows ferrite and Bainite with precipitation of carbides at grain boundary.

Degradation Level- IVL


Fig: 102

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

**Name of Component:** HPSV-3  
**Location:** HPSV bush-3 \_ Parent Metal \_ Replica No. 59  
 Hardness: 191-200HB





200X



400X

**Observation:** Microstructure shows tempered Bainite precipitation of carbides at grain boundary. Degradation Level- IVL


Fig: 103

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

**Name of Component:** HPSV-4  
**Location:** HPSV con-4 \_ Parent Metal \_ Replica No. 60  
 Hardness: 199-201HB



200X






400X

**Observation:** Microstructure shows tempered Bainite with spherodisation carbides.



Degradation Level- IIL

Fig: 104


<b>ALSTOM</b>	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
<b>NTPC ALSTOM</b> Power Services Pvt. Ltd.	<b>Document</b>	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

<p><b>Name of Component:</b> IPSV-1  <b>Location:</b> IPSV-1Bush _ Parent Metal _ Replica No. 1  Hardness: 156-161HB</p>		
		
200X	400X	
<p><b>Observation:</b> Microstructure shows tempered Bainite precipitation of carbides at grain boundary.</p>		Degradation Level- IVL
Fig: 105		


837

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

**Name of Component:** IPSV-3  
**Location:** IPSV-3Bush \_ Parent Metal \_ Replica No. 2  
 Hardness: 157-164HB



200X






400X

**Observation:** Microstructure shows tempered Bainite Degradation Level- IVL  
 precipitation of carbides at grain boundary.



Fig: 106

<b>ALSTOM</b>	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
<b>NTPC ALSTOM</b> Power Services Pvt. Ltd.	<b>Document</b>	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

<p><b>Name of Component:</b> IPSV-2  <b>Location:</b> IPSV-2 con _ Parent Metal _ Replica No. 3  Hardness: 140-148HB</p>	
	
	
200X	400X
<p><b>Observation:</b> Microstructure shows tempered Bainite precipitation of carbides at grain boundary.</p>	Degradation Level- IVL
Fig: 107	




072

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

**Name of Component:** IPSV-4  
**Location:** IPSV-4 con \_ Parent Metal \_ Replica No. 4  
 Hardness: 148-151HB



200X






400X

**Observation:** Microstructure shows ferrite and Bainite with precipitation of carbides at grain boundary..



Degradation Level- IVL

Fig: 108


<b>ALSTOM</b>	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
<b>NTPC ALSTOM</b> Power Services Pvt. Ltd.	<b>Document</b>	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>



<p><b>Name of Component:</b> IPCV-2  <b>Location:</b> IPCV-2 bush _ Parent Metal _ Replica No. 5  Hardness: 155-157HB.</p>		
		
200X	400X	
<p><b>Observation:</b> Microstructure shows ferrite and Bainite with precipitation of carbides at grain boundary.</p>		Degradation Level- IVL
Fig: 109		



267

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>



**Name of Component:** IPCV-4  
**Location:** IPCV-4 bush \_ Parent Metal \_ Replica No. 6  
 Hardness: 158-161HB



	
200X	400X
<b>Observation:</b> Microstructure shows tempered Bainite with precipitation of carbides.	
Degradation Level- IIL	
Fig: 110	

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

**Name of Component:** IPCV-3  
**Location:** IPCV-3 con \_ Parent Metal \_ Replica No. 7  
 Hardness: 168-171HB.



200X





400X



**Observation:** Microstructure shows tempered Bainite with spheroidisation carbides. Degradation Level- III

Fig: 111

h/c

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

**Name of Component:** IPCV-1  
**Location:** IPCV-1 con \_ Parent Metal \_ Replica No. 8  
 Hardness: 171-178HB.





200X



400X

**Observation:** Microstructure shows tempered Bainite  
 precipitation of carbides at grain boundary. Degradation Level- IVL

Fig: 112

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

**Name of Component:** HP CV-1  
**Location:** HP CV-1\_CONE  
Hardness: 160-162HB.



200X





400X



**Observation:** Microstructure shows tempered Bainite with precipitation of carbides..



Degradation Level- IIL

Fig: 113

9/c

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	FINAL REPORT VOL. I B(RLA OF TURBINE)


<b>Name of Component:</b> HP CV-1 <b>Location:</b> HP CV-1_BUSH Hardness: 162-165HB	
	
200X	400X
<b>Observation:</b> Microstructure shows tempered Bainite with precipitation of carbides. Degradation Level- IIL	
Fig: 114	

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	FINAL REPORT VOL. I B(RLA OF TURBINE)


**Name of Component:** HP CV-1

**Location:** HP CV-1\_BUSH

Hardness: 165-168HB



200X





**Observation:** Microstructure shows tempered Bainite with precipitation of carbides.



Degradation Level- IIL

Fig: 115





852

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>



<b>Name of Component:</b> HP CV-2 <b>Location:</b> HP CV-2_CONE Hardness: 160-163HB	
	
200X	400X
<b>Observation:</b> Microstructure shows tempered Bainite with precipitation of carbides.	Degradation Level- IIL
Fig: 116	



<b>ALSTOM</b>	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
<b>NTPC ALSTOM</b> Power Services Pvt. Ltd.	<b>Document</b>	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>



<b>Name of Component:</b> HP CV-2 <b>Location:</b> HP CV-2_BUSH Hardness: 158-160HB	
	
200X	400X
<b>Observation:</b> Microstructure shows tempered Bainite precipitation of carbides at grain boundary. Degradation Level- IVL	
Fig: 117	

249


052

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	FINAL REPORT VOL. I B (RLA OF TURBINE)

<b>Name of Component:</b> HP CV-2 <b>Location:</b> HP CV-2_BUSH Hardness: 160-163HB	
	
200X	400X
<b>Observation:</b> Microstructure shows tempered Bainite precipitation of carbides at grain boundary. Degradation Level- IVL	
Fig: 118	

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

**Name of Component:** HP CV-3  
**Location:** HP CV-3\_CONE  
 Hardness: 161-162HB



200X



400X



**Observation:** Microstructure shows tempered Bainite with precipitation of carbides.



Degradation Level- IIL



Fig: 119

251


252

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>


<b>Name of Component:</b> HP CV-3 <b>Location:</b> HP CV-3_BUSH Hardness: 160-162HB	
	
200X	400X
<b>Observation:</b> Microstructure shows tempered Bainite with precipitation of carbides..	Degradation Level- IIL
Fig: 120	

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	FINAL REPORT VOL. I B(RLA OF TURBINE)

**Name of Component:** HP CV-4  
**Location:** HP CV-4\_CONE  
Hardness: 163-165HB



200X





400X



**Observation:** Microstructure shows tempered Bainite precipitation of carbides at grain boundary. Degradation Level- IVL



Fig: 121



253

252

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

<b>Name of Component:</b> HP CV-4 <b>Location:</b> HP CV-4_BUSH Hardness: 155-158HB	
	
200X	400X
<b>Observation:</b> Microstructure shows tempered Bainite with precipitation of carbides.	Degradation Level- IIL
Fig: 122	



	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

<b>Name of Component:</b> HP CV-4 <b>Location:</b> HP CV-4_BUSH Hardness: 140-145HB	
	
200X	400X
<b>Observation:</b>	No significant degradation observed
Fig: 123	

255



95c

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	FINAL REPORT VOL. I B(RLA OF TURBINE)

**Name of Component:** IP CV-1  
**Location:** IP CV-1\_BUSH  
 Hardness: 135-139HB



200X



400X

**Observation:** Microstructure shows tempered Bainite precipitation of carbides at grain boundary.

Degradation Level- IVL

Fig: 124

<b>ALSTOM</b>	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
<b>NTPC ALSTOM</b> Power Services Pvt. Ltd.	<b>Document</b>	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

**Name of Component:** IP CV-1  
**Location:** IP CV-1\_BUSH  
**Hardness:**136-138HB



200X





400X

**Observation:** Microstructure shows tempered Bainite precipitation of carbides at grain boundary. Degradation Level- IVL

Fig: 125

852

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	FINAL REPORT VOL. I B(RLA OF TURBINE)

**Name of Component:** IP CV-2

**Location:** IP CV-2\_CONE

Hardness: 155-156HB



200X







400X

**Observation:** Microstructure shows ferrite and Bainite with precipitation of carbides at grain boundary.

Degradation Level- IVL



Fig: 126



	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>



<b>Name of Component:</b> IP CV-2 <b>Location:</b> IP CV-2_BUSH Hardness: 160-165HB	
	
200X	400X
<b>Observation:</b> Microstructure shows ferrite and Bainite with precipitation of carbides at grain boundary.	
Degradation Level- IVL	
Fig: 127	

259

096

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	FINAL REPORT VOL. I B(RLA OF TURBINE)


<b>Name of Component:</b> IP CV-3 <b>Location:</b> IP CV-3_BUSH Hardness: 140-145HB	
	
200X	400X
<b>Observation:</b> Microstructure shows tempered Bainite precipitation of carbides at grain boundary. Degradation Level- IVL	
Fig: 128	

	Client	J-Power (Electric Power Development Co. Ltd.,)
	Project	Turbine and System Assessment for NTPC-Korba Unit #4
	Order No.	CGP10028C
	Contractor	ALSTOM K.K. NASL Ltd. (Nominated subcontractor in India)
	Document	<b>FINAL REPORT VOL. I B(RLA OF TURBINE)</b>

**Name of Component:** IP CV-3  
**Location:** IP CV-3\_CONE  
Hardness: 145-150HB



200X



400X

**Observation:** Microstructure shows tempered Bainite with precipitation of carbides..

Degradation Level- IIL

Fig: 129