



Turbine Maintenance

Nobuchika KOIZUMI

J-POWER

Inspection Item at Periodical Maintenance

3. Turbine lubricating oil device
 - (1) MOP, AOP, JOP and EOP
 - Overhaul, repair and detailed and precision inspection
 - (2) Main Oil Tank and Oil Cooler
 - Cleaning and oiliness test of the inside of the tank
 - Cleaning of the oil cooler piping and the water chamber
 - (3) Oil filter, oil purifier
 - Cleaning of the inside and replacement of the filter
 - Overhaul and repair

Inspection Item at Periodical Maintenance

1. Main turbine
 - (1) Turbine rotor
 - Cleaning by honing
 - Detailed inspection and repair of the disk, the rotating blades and the rotor
 - Measurement of run-out and centering of the shaft
 - Inspection and repair of the coupling bolt
 - (2) Ejection Holes and Partitions
 - Cleaning by honing
 - Detail inspection and repair of the stationary blades and labyrinths
 - (3) Casing
 - Measurement of the clearance of the inside and the outside of casing
 - Detail inspection
 - Measurement of the level of the horizontal flange
 - Measurement of the alignment of the casing
 - Maintenance of the bolts, hardness test
 - (4) Bearing
 - Adjustment of the contact of the white metals
 - Measurement of the bearing gaps

Inspection Item of Condenser (1)

NO	ITEM	PURPOSE	METHOD
1	The inside of the cooling tubes	Clogging, corrosion, erosion	VI ET
2	The outer surface of the cooling tube	Erosion, damage	VI
3	The tube plate	To check marine creatures and dirty matter adhered To check the connecting part	VI
4	The inside of the water chamber	Swell, separation, damage, or a pin hole on the rubber lining Marine creatures and dirty matter adhered	VI PHT

VI: Visual Inspection ET: Eddy Current Test PT: Liquid Penetrant Test
 WT: Leak Test by Filling Water ST: Hardness Test PHT: Pin Hole Test
 DI: Dimensional Inspection MT: Fluorescent Magnetic Test DM: Thickness measurement

Inspection Item at Periodical Maintenance

2. Equipment attached to the turbine body
 - (1) Main Valves (MSV, CV, RSV, ICV)
 - Maintenance and inspection of the inside and the outside of the valves, the valve rods, the valve seats, and the valve bodies
 - Measurement of bend and the gaps of the valve rods
 - Inspection of the bolts
 - (2) Speed Governor and Emergency Stopping Device
 - Inspection of the speed governor mechanism and the piping for the control oil
 - (3) Turning Device
 - Detailed and precision inspection of the gears and the bearings
 - Inspection of the clutch mechanism

Inspection Item of Condenser (2)

NO	ITEM	PURPOSE	METHOD
5	The parts inside of the main body shell	Erosion, damage, scale, dust	VI PT
6	Rubber expansion joint	Deterioration	VI ST
7	Nozzle for steam pipe	Crack	VI PT

VI: Visual Inspection ET: Eddy Current Test PT: Liquid Penetrant Test
 WT: Leak Test by Filling Water ST: Hardness Test PHT: Pin Hole Test
 DI: Dimensional Inspection MT: Fluorescent Magnetic Test DM: Thickness measurement

Inspection Item of HP Feed Water Heater


NO	ITEM	PURPOSE	METHOD
1	Tube (steel)	Inlet attack	VI, DI
2	Tube (cu attribute)	Crack	ET
3	Water chamber	Crack	VI, PT, MT
4	Water chamber partition	Deformation	VI, DI
5	Shell	Erosion	VI, DM
6	Nozzle	Erosion	VI, DM

VI: Visual Inspection
 Leak Test by Filling Water
 DI: Dimensional Inspection

ET: Eddy Current Test
 ST: Hardness Test
 MT: Fluorescent Magnetic Test

PT: Liquid Penetrant Test
 WT: Thickness measurement
 PHT: Pin Hole Test
 DM: Thickness measurement

Turbine Forced Cool Down



Inspection Item of LP Feed Water Heater


NO	ITEM	PURPOSE	METHOD
1	Tube (steel)	Erosion	UT, ET
2	Tube (cu attribute)	Crack, ammonia attack	ET
3	Water chamber partition	Deformation	VI, DI
4	Shell	Erosion	VI, DM

VI: Visual Inspection
 Leak Test by Filling Water
 DI: Dimensional Inspection

ET: Eddy Current Test
 ST: Hardness Test
 MT: Fluorescent Magnetic Test

PT: Liquid Penetrant Test
 WT: Thickness measurement
 PHT: Pin Hole Test
 DM: Thickness measurement


Heater Leak Check



Turbine Shut Down and Preparation Works

1. Turbine Forced Cooling
2. Heater Leak Check
3. Operation and Maintenance Coordination

HP Turbine Inspection Points



HP Turbine Major Inspection - (1)

HP Turbine 1st Blade Erosion - Boiler Scale




Example (Wear due to Scale)

HP Turbine Major Inspection (3)

Example - Outer Casing (Stress Concentration)



Unit 2 HP Inner Casing



HP Turbine Major Inspection - (2)

Example (Wear due to Scale)




Unit 2 (Foreign Material)




HP Turbine Major Inspection - (4)

Creep - Shrouds and Roots



HP Turbine Major Inspection - (2)


Typical Erosion



MSV Strainer




LP Turbine Inspection Points



LP Turbine Major Inspection (1)




Unit 4 LP Last Blade - Stellite




Turbine Major Inspection - Other Area (2)

Balance Weight Flange



LP Turbine Major Inspection (2)

Casing Structure Welding





Turbine Major Inspection - Other Area (3)



Cleaning
↓
Thread Inspection
↓
PT


Turbine Major Inspection - Other Area (1)

Diaphragm Seal Ring Erosion (Efficiency Loss)



Turbine Major Inspection - Other Area (4)


White Metal Bonding Condition




Radial Bearing

Thrust Bearing


Turbine Piping Inspection



Turbine Commissioning - Vacuum Test



Turbine Auxiliary Inspection Point



Turbine Overhaul Improvement - Acceleration Work

1. Overhaul Period (300MW Class)
 - J-Power P/S 45 days
2. Area of Consideration
 - Work Schedule Improvement
 - Equipment Improvement
 - Oil Flushing Improvement

Turbine Commissioning

1. Heater Leak Test
2. Condenser Tube Leak Test
3. Condenser Vacuum Test
4. Turbine Steam Admission & AOP/EOP Test
5. Turbine Overspeed Test
6. Unit Interlock Test (MFT, Unit Trip)

Work Schedule Improvement

1. Turbine Cool Down Acceleration
2. Work Sequence Improvement



- Disassembly Improvement**
1. HP Turbine Casing Bolt
Loose Before Turning Gear
 2. Turbine Forced Cool Down
Disassemble Flow Guide earlier and lift LP Casing
 3. Lay down Area
- ↓
- Overhaul Schedule Optimization**




Turbine Overhaul Improvement - Induction Heater (1)

Heating with Burner



New Type - Induction Heater



Thank You !

This document shall not be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Electric Power Development Co.,LTD. Japan.


Turbine Overhaul Improvement - Induction Heater (2)

Resistance Wire




Saving Time

= 30min X 34 times = 1020 min (17 hrs)



Turbine Overhaul Improvement - Turbine Oil Flushing

Step 2 Oil Flushing after Bearing Assembly



Step 1 Oil Flushing before Bearing Assembly



JICA Study Team for Enhancing Efficiency of Operating Thermal Power Plants in NTPC-India

TURBINE RLA ASSESMENT

Nobuchika KOIZUMI
J-POWER



The 1st Work Shop 30-31 Jan., 2009

EXAMPLE OF ASSESMENT

Sr. No.	Item	Test Matrix for 200 MW LMZ Turbine				PRELIMINARY		
		UT	LI	MT	PT	Replica	Hardness	Special Tests
4.0 Integral Steam Piping & Valves								
4.1	Integral Steam pipes (HP casing)	100%	NO	NO	Critical Butt welds	Critical Butt welds	4 locations	Replicated locations
4.2	Integral Steam pipes (IP casing)	100%	NO	NO	Critical Butt welds	Critical Butt welds	4 locations	Replicated locations
4.3	Main steam Piping critical weld and bend (Turbine main steam stop valve to HP control valve)	100%	NO	NO	Critical Butt welds	Critical Butt welds	8 locations	Replicated locations
4.4	Hot Re-Heat Piping critical weld and bend (HP stop valve to HP control valve)	100%	NO	NO	Critical Butt welds	Critical Butt welds	8 locations	Replicated locations
4.5	Crank over pipe	100%	NO	NO	Weld joints	NO	NO	NO
4.6	ESV	100%	NO	NO	Weld cones, Chamber	Weld cones, Chamber	4 locations	Replicated locations
4.7	IP	100%	NO	NO	Weld cones, Chamber	Weld cones, Chamber	4 locations	Replicated locations
4.8	HP Control valves	100%	NO	NO	Weld cones, Chamber	Weld cones, Chamber	4 locations	Replicated locations
4.9	IP Control Valves	100%	NO	NO	Weld cones, Chamber	Weld cones, Chamber	4 locations	Replicated locations
4.10	IP/HP Bypass Main valves	100%	NO	NO	Weld cones, Chamber	Weld cones, Chamber	2 locations	Replicated locations

Legend:
UT: Visual Observations, LI:NDPT+Dye Penetrant Test, MT: Fluorescent Magnetic Inspection, UT: Ultrasonic Test, Replica in situ Metallography, Hardness: Portable rebound hardness



3

The 1st Work Shop 30-31 Jan., 2009

EXAMPLE OF ASSESMENT

Sr. No.	Item	Test Matrix for 200 MW LMZ Turbine				PRELIMINARY		
		UT	LI	MT	PT	Replica	Hardness	Special Tests
4.0 Main IP Turbine Boiler								
4.1	Rotor	100%	Journal region	100% accessible regions by coil yoke	through bore + externally accessible regions	2 locations	2 locations	Store UT, Videography Stress analysis of Rotor Shaft
4.2	Blades	100%	NO	100% accessible regions by coil yoke	NO	NO	NO	Deposit analysis Back Current and of moving blades
4.3	Shrouds	100%	NO	100% accessible regions by coil yoke	NO	NO	NO	NO
4.4	Sealing Grooves (welding)	100%	NO	100% accessible regions by coil yoke	NO	NO	NO	NO
4.5	Coupling Bolts	100%	NO	NO	NO	NO	NO	NO
4.0 HP and IP Casing								
4.1	Coupling Bolts	100%	Keys & keyways	100% to yoke	NO	NO	NO	Deposit analysis, Stress Analysis
4.2	Parting plane (Bolt and Fasteners)	100%	NO	100% to yoke	NO	NO	NO	high temperature bolts on one side each from HP and IP regions
4.0 HP and IP Diaphragm and Lovers								
4.1	Parting plane (Bolt and Fasteners)	100%	Keys & keyways	100% to yoke	NO	NO	NO	Deposit analysis
4.2	Parting plane (Fasteners)	100%	NO	100% to yoke	NO	NO	NO	high temperature bolts

Legend:
UT: Visual Observations, LI:NDPT+Dye Penetrant Test, MT: Fluorescent Magnetic Inspection, UT: Ultrasonic Test, Replica in situ Metallography, Hardness: Portable rebound hardness



1

The 1st Work Shop 30-31 Jan., 2009



Thank You !

This document shall not be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Electric Power Development Co.,LTD. Japan.



The 1st Work Shop 30-31 Jan., 2009

EXAMPLE OF ASSESMENT

Sr. No.	Item	Test Matrix for 200 MW LMZ Turbine				PRELIMINARY		
		UT	LI	MT	PT	Replica	Hardness	Special Tests
4.0 Bolted Flange and Surface								
4.1	Bolted flange and surface	100%	NO	NO	NO	NO	NO	NO
4.2	Sealing housing, sealant	100%	NO	NO	On parting plane	NO	NO	NO
4.0 IP Turbine Rotor and Casing								
4.1	Rotor	100%	Journal region	100% accessible regions by coil yoke	through bore + externally accessible regions	2 locations	2 locations	Store UT, Videography
4.2	Blades	100%	Journal, sampling area	100% accessible regions by coil yoke	NO	NO	NO	high pressure test of moving blades
4.3	Shrouds	100%	NO	100% accessible regions by coil yoke	NO	NO	NO	NO
4.4	Sealing Grooves (welding)	100%	NO	100% accessible regions by coil yoke	NO	NO	NO	NO
4.5	IP Casing Bolts	100%	NO	100% accessible regions by coil yoke	NO	NO	NO	NO
4.6	Coupling Bolts	100%	NO	NO	NO	NO	NO	NO

Legend:
UT: Visual Observations, LI:NDPT+Dye Penetrant Test, MT: Fluorescent Magnetic Inspection, UT: Ultrasonic Test, Replica in situ Metallography, Hardness: Portable rebound hardness



2

The 1st Work Shop 30-31 Jan., 2009



ASSESSMENT OF PUMP

BOILER FEED WATER PUMP

CIRCULATING WATER PUMP

TORISHIMA GLOBAL TEAM SERVICE

Service Function: Service Offering for much longer life

Pump Efficiency Testing: Yates Meter
Measuring of pump performance: Pressures, liquid temps etc

Improvement for pump Efficiency Up

- Recover inner clearances: Replaced inner parts
- Up-grading : Coating, Grade up of Materials
- Design-up : Floating Ring

TORISHIMA GLOBAL TEAM SERVICE

Service Function: REDU: Re-Engineering & Design Up Services

Analysis such as:

- Flow Analysis of Pump Inlet Casting
- Stress Analysis



Thank You !

This document shall not be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Torishima Engineering Co.,LTD. Japan.

TORISHIMA GLOBAL TEAM SERVICE

Service Function: REDU: Reference of Materials upgrades

UP GRADING OF RAW WATER INTAKE PUMPS


Recover Clearance & Material up

Coating for Impeller & Casing


Maker: Nijhuis Pompen
Capacity: 2.7 m³/s; Head: 18m; Power: 510 kW
Quantity: 4 Units




RETROFIT OF 200 KHI BOILER FEED WATER PUMP




3




1




4



2



5



6

6. Expected Improvement & Effects

Energy saving

- 1) Efficiency : before and after improvement
 Existing Sigma Pump E(ex) = 72%
 Newly replaced by Torishima E(n) = 83%
 * Improved EFF = 11%
- 2) Shaft power : before and after improvement
 Existing Sigma Pump SP(ex) = 2500KW
 * Expected Reducing SP = 2500KW x 0.11 = 275KW/hr
- 3) Yearly energy saving : after improvement
 * Expected Yearly saving energy = 275KW/hr x 8000hrs
 = 2,200,000KW/year

7



Thank You !

This document shall not be reproduced, transmitted, disclosed or used in whole or in part without the written authorization of Torishima Engineering Co.,LTD. Japan.



Thank You !




-Diagnosis of Transformer-

Jan. 2009

Internal Structure of Transformer

- In order to get induced electromotive force, transformer coils consist of conductor wound many times.
- Besides, coils are insulated from each other in each loops of wires.



Contents

1. Main components of transformer
2. The sorts of transformer diagnosis
3. Condition check diagnosis (Dissolved Gas Analysis)
4. Deterioration diagnosis & Remaining life diagnosis

1

Inspection & Diagnosis of Transformer (in Japan)

Transformer inspection

Inspection	Frequency	Inspection contents
Patrol inspection	Once/day	Oil temp., oil level, Oil leak, abnormal sound, smell, rust, etc
Dissolved gas analysis (DGA)	Once/year	Dissolved Gas Analysis
PI (simple inspection)	Once/2 years	Megger testing, Visual inspection, etc.
PI (detail inspection)	Once/6 years	Protection relay performance test, etc.
PI (special inspection)	Depending on the results of DGA	

PI: Periodical inspection

Transformer diagnosis


Diagnosis	Methods
Condition check diagnosis	Dissolved Gas Analysis
Deterioration diagnosis (Life-remaining diagnosis)	Furfural analysis(★) Carbon dioxide (CO ₂ + CO) analysis

★ : adaptable for insulating paper made from kraft pulp

4

Main Components of Transformer

Basic configuration of shell-type transformer



2

Dissolved Gas Analysis (DGA) (1)

- Various gases are generated by heat decomposition of insulating paper and insulating oil, when abnormal condition such as electric discharge and over heating occurs in a transformer.
- Abnormal condition is estimated and analyzed from the gas components, the gas volume and the ratio of generated gas.

Abnormal condition	Main generated gas
Over heating insulating oil	H ₂ , CH ₄ , C ₂ H ₆ , C ₂ H ₄ , C ₂ H ₂
Over heating at solid insulator	H ₂ , CH ₄ , C ₂ H ₆ , C ₂ H ₄ , C ₂ H ₂ , CO, CO ₂
Electric discharge in insulating oil	H ₂ , CH ₄ , C ₂ H ₄ , C ₂ H ₂
Electric discharge at solid insulator	H ₂ , CH ₄ , C ₂ H ₄ , C ₂ H ₂ , CO, CO ₂

5

JICA Dissolved Gas Analysis (DGA) (2)

Criteria of DGA (in Japan)

Unit : ppm

Gas	Caution I level	Caution II level	Abnormal level
CO	≥ 300	(1) $C_2H_2 : \geq 0.5$ or (2) Both $C_2H_4 : \geq 10$ and TCG : ≥ 500	(1) $C_2H_2 : \geq 5$ or (2) Both $C_2H_4 \geq 100$ & TCG at least 700 or (3) Both $C_2H_4 \geq 100$ & TCG increase \geq 70 ppm/month
H_2	≥ 400		
CH_4	≥ 100		
C_2H_6	≥ 150		
C_2H_4	≥ 10		
C_2H_2	-		
TCG*	≥ 500		

*TCG: Total Combustible Gas, the sum of CO to C2H2

Caution I level : The level that transformer is out of normal condition although it is not judged to be abnormal and dangerous condition


Caution II level : The level that transformer becomes abnormal condition gradually

Abnormal level : The level that transformer is clearly abnormal condition. (aggravating further from Caution II level)

6


The 1st Work Shop 30-31 Jan., 2009

JICA Analysis of the Transformer Trouble



The 1st Work Shop 30-31 Jan., 2009

JICA Diagnosis Flowchart with DGA



The 1st Work Shop 30-31 Jan., 2009

JICA Deteriorating Phenomenon of Transformer

- In transformers, deterioration of insulating materials are rather remarkable than that of metals
- In insulating materials, deterioration of mechanical function is proceeding faster than that of electrical.


Material type	Deteriorating phenomenon
Metal materials ● Conductor, silicon steel plate, etc.	● There are almost no mechanical/electrical deteriorating tendencies.
Insulating materials ● Insulating paper, Pressboard, etc. ● Insulating oil	● Deterioration of mechanical strength (tensile/ compressive) ● Decrease in breakdown voltage ● Generation of combustion gases, etc.

Insulating materials deteriorate faster than metal materials

10

The 1st Work Shop 30-31 Jan., 2009

JICA One Case of Transformer Troubles



After disassembling transformer, the iron core and windings were burnt out.

Burst-out of insulating oil

8

The 1st Work Shop 30-31 Jan., 2009

JICA Life of Transformer

- Among insulating materials, deteriorating severity of insulating oil is milder than others. Additionally, its function can be refreshed by degassing filtration treatment or exchanging to new one.
- Pressboard reaches its service limit slowly than insulating paper, because its temperature elevation is generally lower than insulating paper and its necessary function is compressive strength.
- When the insulating paper mechanical strength is decreased, there is an increased risk of breaking caused by electromagnetic force arising from surge current at the time of external short circuit fault and other accidents.


End of insulating paper life

- Basically, it is impossible to re-wind the insulating paper and to replace the transformer coils. Thus the insulating paper life means the transformer life.

11

The 1st Work Shop 30-31 Jan., 2009

JICA Mechanical & Electrical Strength of Insulating Paper



Insulating strength:
Mechanical strength deteriorates faster than electrical strength

12

The 1st Work Shop 30-31 Jan., 2009

JICA Organic constituents extracted from insulating paper aging

Various organic constituents are produced by chemical changes of the cellulose.

Inorganic	H ₂ O, CO, CO ₂
Hydrocarbon	CH ₄ Methane, ethane, propane, propylene
Alcohol	Ethyl alcohol, furfuryl alcohol
Aldehyde/ Ketone	Acetaldehyde, furfural, 5-methylfurfural, 5-hydroxymethyl-2-furfural, acetone, methyl ethyl ketone
Acid	Formic acid, 2-furan carboxylic acid, acidum tartaricum, butyric acid
Others	Furan methyl carboxylic acid, acetic ether (CH ₃ COOC ₂ H ₅), furan (C ₄ H ₄ O), 2-acetyl furan

The quantity of organic constituents marked by this symbol has close relevance with mechanical strength of insulating paper.


CO, CO₂ and Furfural are closely related with insulating paper strength Remaining life diagnosis is conducted with the relation.

The 1st Work Shop 30-31 Jan., 2009

JICA Insulation Paper Strength and Degree of Polymerization

Measuring the strength of insulating paper in a fully inspection costs a lot and is difficult to do accurate because of the insulation paper core set.

The degree of polymerization (DP) is the fiber density of insulating paper and is closely related with the mechanical strength of insulating paper.




13

The 1st Work Shop 30-31 Jan., 2009

JICA Average DP survival rate and deterioration indicator substances

The qty. of (CO+CO₂) and the qty. of furfural are closely related with the average DP remaining life rate of insulating paper. They can be therefore treated as deterioration indicators (the components which deterioration level can be measured).


One of the main reasons for the data spread is difference in the load factor of transformers.



The 1st Work Shop 30-31 Jan., 2009

JICA Weakening process of insulation paper strength (Generation of organic constituents)

The decrease of insulating paper mechanical strength is caused by chemical changes (glucose bond breaking and ring opening) of the cellulose.



14


The 1st Work Shop 30-31 Jan., 2009

JICA Judgment Criteria for Remaining Life Diagnosis (Deterioration Diagnosis) (Japanese case)

Reference values for the remaining life of insulating paper is set to Average DP 450

Based on this, the judgment criteria of deterioration indicators is developed.

	Level of caution	Level of danger
CO ₂ +CO qt.	0.2 (ml/g)	2.0 (ml/g)
Furfural qt.	0.0015 (mg/g)	0.015 (mg/g)



The 1st Work Shop 30-31 Jan., 2009

JICA Applicability of Gas Analysis

Applicability of CO and CO2

■ This method cannot be applied to open type transformers, because CO and CO2 in the transformer is released to the atmosphere.


Applicability of furfural method

- Furfural is a liquid of 161°C in boiling point and dissolves to insulating oil. Therefore, it can be detected even in an open type transformer.
- When adsorbing materials exist in a transformer, this method cannot be applied to because furfural is adsorbed to it.

18

The 1st Work Shop 30-31 Jan. 2009

JICA Flowchart of Transformer Preventive Maintenance



21

The 1st Work Shop 30-31 Jan. 2009


JICA Degassing correction method

Why need degassing correction?

■ Gas quantity is decreasing at the time of insulating oil exchange, degasification, etc. Therefore, degassing correction is needed.

How to correct?

■ Make clear the quantitative changes of deterioration indicator substances along with time in the event of insulating oil exchange, degasification, etc. Then, make corrections by linking balanced properties after degasification to those before degasification.



19

The 1st Work Shop 30-31 Jan. 2009



Thank You !

Quoted from Maintenance Management for Oil-immersed Transformer Vol. 54 No. 1 (Part 1) Published by Electric Technology Research Association (Japan)

No part of the contents of this presentation shall be reproduced or copied without the permission of Electric Technology Research Association (Japan)

JICA Remaining Life Diagnosis of Transformer


Remaining life diagnosis method by average DP

- The average DP is estimated by sampling approach, CO/CO2 method or furfural method, and the remaining life of transformer is calculated by Acker's regression formula.
- Remaining life diagnosis of transformer enable trouble prevention, reflection to replacement planning and so on.

Acker's regression formula

$$LR = L_0 (1 - r)^n$$

LR : DP
L₀ : Initial DP
r : coefficient estimated the results of diagnoses
n : Operating years



20

The 1st Work Shop 30-31 Jan. 2009



Instrumentation and Control Systems



Methods and features of temperature measurement at power station

Measurement methods	Temp. range	Applications at power plant	Features
1 Thermocouple	-200 ~ 1700°C	Feedwater temp. Steam temp. Different metal temp. * For general use	Different types according to different materials. Large thermo electromotive force and small variation in properties. Excellent in resisting heat and corrosion. Limitations on types due to measurement atmosphere. Reference junction temperature compensation required.
2 Resistance temperature detector	-200 ~ 650°C	Condense Water intake temperature * For precise measurement	Higher accuracy and stability than thermocouple. Slower responsiveness than thermocouple. Sensitive to mechanical shock and vibration.
• Two-wire			Susceptible to the influence of change in outside air temperature.
• Three-wire			Not susceptible to the influence of change in outside air temperature.
• Four-wire			Not affected to the influence of change in outside air temperature.



Contents

1. Instruments used in Japanese Power Stations
2. Control System Technology for Improving Performance
3. Assessment of Control System



Types of thermoelectric pyrometer

- Sheath thermocouple

Structure of measuring junction	Configuration of sheath thermocouple
<p>Grounding system</p>	<p>With terminal plate</p>
<p>Non-grounding system</p>	<p>Without terminal plate</p>

Instruments used in Japanese Power Stations

Main Instruments used in Japanese Power Stations

Item	Outline
• Thermometer	Thermocouple measurement features and applicable areas Resistance temperature detector measurement features and applicable areas
• Flow meter	Various flow meter measurement methods, features and applicable areas
• Waste gas analyzer	Various gas analyzer measurement methods and applicable areas



Methods and features of flow measurement at power station

Measurement methods	Target fluids			Application at power plant	Features
	Liquid	Gas	Steam		
1 Differential pressure	○	○	○	Main steam flow rate Main feedwater flow rate	Wide measuring range, low cost, and big error in low flow rate region.
2 Area	○	○	○	Auxiliary equipment cooling water flow rate	Simple structure & low cost. Subject to error in gas measurement
3 Positive Displacement	○	○	×	Incoming fuel flow rate Makeup water flow rate	High accuracy & for high viscosity but weak against dirt. In the bearing, there is longevity.
5 Electromagnetic	○	×	×	Desulfurization slurry Waste water treatment	Superb in resisting corrosion and wear. Electric conductivity required.
6 Vortex	○	○	○	Gas turbine fuel flow rate	Wide measuring range, high accuracy, but unsuitable for small flow.
7 Ultrasonic	○	○	△	Desulfurization slurry Waste water treatment	Superb in resisting corrosion and wear. Susceptible to influence of air bubbles.

Methods, Types and Areas of Waste Gas Analysis in Power Stations

Measurement Item	Measurement Method	Area of Use
1 NOx, SO2	Infrared method	Denitrification inlet, denitrification outlet, desulfurization inlet, desulfurization outlet, stack inlet
	Chemi-luminescent method	
2 O2	Zirconia method	ECO outlet (For optimum combustion control)
	Magnetic wind method	Denitrification inlet, denitrification outlet
	Magnetic pressure method	
3 Dust concentration	Transmission method	EP outlet
	Scattered light method	


6

The 1st Work Shop 30-31 Jan. 2009

Control technology for multi coal fired boiler

2. Necessity of control technology multi coal fired boiler

Table 1 Relationship between control operating element and change in boiler characteristics with respect to coal-fired boiler constraints



9

The 1st Work Shop 30-31 Jan. 2009

Control technology for multi coal fired boiler


- Coal-fired boiler constraints
 - Necessity of control technology for multi coal fired boiler
 - Basic concept of control technology for multi coal fired boiler
 - Division of multi coal fired boiler operational logic and boiler control logic
 - Adjustment of boiler control logic parameters
- Reference: Optimum combustion control

7

The 1st Work Shop 30-31 Jan. 2009

Control technology for multi coal fired boiler

2. Necessity of control technology for multi coal fired boiler



10

The 1st Work Shop 30-31 Jan. 2009

Control technology for multi coal fired boiler

- Coal-fired boiler constraints
 - Boiler heat capacity**
With variable-pressure boiler, pressure (saturation temperature) changes with load.
 - Consider:**
Heat quantity corresponding to evaporation when load changes + Heat quantity corresponding to change in heat capacity of retained water and steel of boiler tube header, etc.
- Change in characteristics with coal brand**
 - Change in fuel consumption due to difference in heating value
 - Change in heat absorption characteristics due to difference in combustibility
 - Change in mill capacity and coal supply characteristics due to difference in grindability
- Change in boiler characteristics over time**
Boilers tend to get dirty and their characteristics change greatly over time.
- Burner ignition/extinguishment time**
 - Since coal burner ignition takes time, the control designing should take into account the ignition/extinguishment time.
 - A mill motor is a large auxiliary machine; thus, it is unsuitable for repeated starts and stops. Therefore, it is difficult in practice to change loads with continuously changing the number of mills in operation.

8

The 1st Work Shop 30-31 Jan. 2009

Control technology for multi coal fired boiler

2. Necessity of control technology for multi coal fired boiler

Key points of control

- Proper grasp of heat transfer characteristics from combustion state of boiler, regardless of coal type data
 - Grasp of coal property changes in mill from mill's operating state
- Optimum correction of related parameters

To be more precise

- Grasp of distribution of furnace/superheater/reheater's heat absorption from estimation of heating surface's heat absorption state
- Grasp of coal heating value from estimation of boiler's total heating value
- Grasp of change in coal properties in mill from mill heat balance, mill current value, and other operating state quantities

Proper control parameter correction

Achievement of optimum boiler operation regardless of change in coal properties and contamination over time

11

The 1st Work Shop 30-31 Jan. 2009

JICA Control technology for multi coal fired boiler

3. Basic concept of control technology for multi coal fired boiler

Influencing factors and quantities involved in control of technology for multi coal fired boiler

Factor that Affects Control	Effect	Quantification of Influencing Factor	Correcting Control Item
Fuel ratio	Deviation in furnace heat absorption Deviation in degree of superheat	Heat absorption index	BIR for fuel, feedwater, air, etc. Steam temperature control Gas distributing damper control, other
Contamination	Deviation in furnace heat absorption Deviation in degree of superheat		
Heating value	Deviation in fuel feed rate Deviation in BIR	Total heating value	Heating value correction
Ash content	Deviation in feed rate	Change in mill state quantity	Mill outlet temperature control Mill pressurization equipment hydraulic control Mill rotary classifier control Mill primary air flow control
Water content	Delay in coal exhaustion		
Grindability	Change in mill's actual capacity Delay in coal exhaustion		

12

The 1st Work Shop 30-31 Jan. 2009

JICA Control technology for multi coal fired boiler

5. Adjustment of boiler control logic parameters

Basic concept


Adjustment of parameters based on combustion of standard coal



Adjustment of parameters based on combustion of coal with different fuel ratio



Automatic setting and control of other fuel ratio property parameters by three-point proportional division



15

The 1st Work Shop 30-31 Jan. 2009

JICA Control technology for multi coal fired boiler

3. Basic concept of Control technology for multi coal fired boiler

Quantified influencing factors

① Heat absorption index (HAI):

Value that shows distribution of heat absorption of furnace and superheater/reheater. Represents change in combustion due to change in burner position, contamination distribution, flammability (equivalent to fuel ratio) associated with coal properties, etc.

② Total heating value:

Represents change in fuel input due to change in water content, calorific value of fuel, etc.

③ Change in mill state quantity:

Utilizes changes in state quantities of mill roll lift, mill current value, and water content ratio estimated from the mill heat balance to represent the change in mill coal exhaustion capability caused by a change in coal properties.

Correction

Adjusted control parameters based on standard coal




Enables optimum control that suppresses changes in characteristics of multi-coal-type coal-fired boiler.

13

The 1st Work Shop 30-31 Jan. 2009

JICA Reference: Optimum combustion control

To improve the controllability of the ECO outlet gas O₂ deviation, multi point analyzers with zirconia type are used because of their fast response. As a result, optimum combustion is achieved.




16

The 1st Work Shop 30-31 Jan. 2009

JICA Control technology for multi coal fired boiler

4. Division of multi coal fired boiler operational logic and boiler control logic



14

The 1st Work Shop 30-31 Jan. 2009

JICA Assessment of control system

1. Objectives
2. Investigation Items
3. Investigation Method
4. Assessment Contents (Summary)

17

The 1st Work Shop 30-31 Jan. 2009

Assessment of control system

1. Objectives

The objectives is to confirm the state of key facilities at a power station and to investigate the feasibility of improving the reliability, operating performance and functionality of the power station through renovating or modifying its instrumentation and control systems.

2. Investigation Items

- Control performance of control systems
- Installed condition of control systems and field measuring instruments
- Weak regions of control systems

3. Investigation Method

- Acquired data analysis
- Observation of operating conditions
- Visual inspection of field equipment
- Interviews with personnel involved

18

The 1st Work Shop 30-31 Jan. 2009

Assessment of control system

4. Assessment contents (Summary)

- Grasp of control performance (operating data, observation, interviews)
 - Records of operating trends
 - Confirmation of the control mode
 - Conditions and causes of manual intervention by operators
 - Appropriateness of the installed state of equipment (control systems, field measuring instruments) (visual check)
 - Installed environment and state
 - Equipment maintenance conditions
 - Detection pipes
 - Gauging of control system weak regions (maintenance records)
 - Records of unit trip caused by the control system
 - Adjustment accuracy and inspection frequency of measuring instruments
 - Soot blower system operating history and conditions
- ↓
- Identification of parts of instrumentation and control systems that can be improved

Site investigation period
Around 3 days/1 unit

19

The 1st Work Shop 30-31 Jan. 2009



Thank You !

8.2.2 Other work shop and seminar


Diagnosis Boiler Problem

Current Boiler Problems for Vindhyachal # 7

- Vindhyachal Unit 7 Boiler has the problem of lower Main Steam (MS)/High Reheater Steam (HRH) temperature than design value and Left/Right side unbalance in MS/HRH temperature since commissioning.

Diagnosis Boiler Problem

Vindhyachal # 7 side view



Diagnosis Boiler Problem

The modification history of Boiler up to now is as follows;

Step I

- Addition of wall superheater on the front wall (area: 922 m², consisting of 216 tubes)
- Removal of outer tube in each of the 74 reheater (area: 722 m²)


Step II

- To reduce the high metal temp of reheater, out of 74 nos, 44 nos. of off-set bend piping (54 mm) in pent house was replaced by 44.5mm piping to avoid the Reheater tube overheating.
- 75% size orifices were installed at reheater outlet header(LHS) to reduce the Left/right steam temp imbalance.

Diagnosis Boiler Problem

Table 6.1.9 Boiler Furnace Dimension Comparison Table


No.	Item	Unit	Same type of Boiler in Japan	Vindhyachal Unit 7
1	Rated Output	MW	300	500
2	Boiler High (HT)	m	56	63
3	Bottom of SH Panel to roof (H4)	m	14	16
4	Top Burner level to Bottom of SH Panel (H3)	m	17	18
5	Burner Zone (H2) Burner	m	10 (6 stages)	13 (10 stages)
6	Hopper Bed to bottom of burner (H1)	m	3	5
7	Hopper bend to Bottom of SH Panel (H1-H2)	m	30	36
8	Furnace width (FW)	m	16	19
9	Furnace depth (FD)	m	15	16
10	Furnace Area	m ²	229	303
11	Furnace Volume	m ³	10,700	16,424
12	1st SH Panel (Dev. SH)	No.	6	40
13	Panel Pitch (No./FW)	m	2.6	0.40
14	2nd SH Panel (Platen SH)	No.	28	25
15	Panel Pitch/No./FW	m	0.57	0.76
16	Coal Calorific value	kJ/kg	6600	3700
17	Ash	%	16.0	30



Diagnosis Boiler Problem

Flue Gas temperatures measured with online instruments at Div SH outlet, platen SH outlet etc. However, those are not only one point measurement data.

It is necessary to verification of L & R flue gas temperatures unbalance in across the cross-section considering data with regard to steam temperature, SH/RH metal temperature, mill combination and angle of burner tilt.



Diagnosis Boiler Problem

Cross connection of the left and right side of superheater header connecting pipes




Fig. 6.1.2 Outline of Steam Flow Diagram (Same type of Boiler in Japan)




Fig. 6.1.3 Outline of Steam Flow Diagram (Vindhyachal Unit 7)

Diagnosis Boiler Problem

Recommendation

- Increase in the superheater heat transfer area

In order to reduce furnace heat absorption and to increase heat absorption in superheter section, to add wall SH left and right sides of furnace.

- Cross connection of the left and right side of superheater header connecting pipes

Those modification are required to review and re-design of total heat balance of boiler by the original boiler supplier.

Combustion Simulation

1. About Combustion Simulation
2. Preparation of Condition
3. Preliminary/Base Case Study
 - * Cross Connection between Dev SH & Platen SH
4. Simulation Study
 - * Steam Temperature difference
 - Increased O₂% and Gas Recirculation
 - Additional air port and OFA
 - Division SH modification
 - * SH and RH steam temperature
 - Division SH modification




Figure 2.1 Sub models incorporated into Coal Combustion Simulator




Figure 2.2 Summary of the Input/Output Data in the combustion simulation




Figure 3.2 Unit 7&8 Mesh used for the base simulations

Table 3.1 Comparison of the Heating Areas etc. between Vindiyachal Unit7&8 and Simulation model

	Unit	Unit 7&8 *3 Effective Value	Simulation Model Total Value	note
Furnace Volume	[m ³]	16424	17813	*1)
Surface Area				
Economiser	[m ²]	13105	Out of Domain	
Furnace (Water wall)	[m ²]	4837	4140	*2)
Wall Super Heter	[m ²]	No Information	411	
LTSH(Stage #1)	[m ²]	6864	Out of Domain	
Divisional Panel(Stage #2)	[m ²]	1319	1644	
Platen(Stage #3)	[m ²]	1385	1428	
Reheaters	[m ²]	6018	1833	
Assembly				
Economiser	[-]	138	Out of Domain	
Wall Super Heter	[-]	4	4	
LTSH(Stage #1)	[-]	124	Out of Domain	
Divisional Panel(Stage #2)	[-]	48	24	
Platen(Stage #3)	[-]	25	14	
Reheaters	[-]	74	28	

*1) This value is the total volume of the simulation model.
The volume except Reheater zone is 1614[m³].
*2) This value does not include the area of Wall Super Heater.
*3) 15Boiler_Technical_details.pdf




Figure 3.1 Unit 7&8 structure used for the base simulations




Figure 3.3 Configuration of the Additional Air(AA) Ports




Figure 2.5 Calculation procedure of the Coal Combustion Simulation

Table 3.2 Base condition for combustion simulation

Load	[MW]	500 \times α
Heat Input	[Gcal/hr]	1.20E+09
Coal Flow Rate	[ton/hr]	320
Coal Type	[--]	Typical
Proximate Analysis		
Total Moisture	[%]	17.8
Ash	[%]	31.0
Volatile Matter	[%]	22.4
Fixed Carbon	[%]	28.9
Gross calorific value(GCV)	[Gcal/kg]	3700.0
Ultimate Analysis		
C	[wt%]	76.4
H	[wt%]	5.1
N	[wt%]	1.6
O	[wt%]	11.6
S	[wt%]	0.3
Dulcified Coal Size <200μ	[%]	83.5
Oxygen conc. in flue gas	[ppm]	3.0
Air Rate	[--]	11.6
Stoichiometric Air	[kg/kgcoal]	5.09
Average Air/Coal for all mills	[ton/ton]	1.3
Total Air Flow Rate	[ton/hr]	1398.7
1st Air Flow Rate	[ton/hr]	420.0
1st Air Temperature	[deg.C]	75.0
2nd Air Flow Rate	[ton/hr]	1468.7
2nd Air Temperature	[deg.C]	350.0
Coal Flow Distribution	[--]	Uniform
2nd Air Flow Distribution	[--]	By burner list
Mill Pattern (Top)	[--]	No service AB
Mill Pattern (Middle)	[--]	No service EF
Mill Pattern (Bottom)	[--]	No service JK
Burner Tilt Angle	[deg]	-30,-10,0,+30
Additional Air(AA)	[%]	0.0
AA Temperature	[deg.C]	350.0
Gas Recirculation(GR)	[%]	0.0
GR Temperature	[deg.C]	350.0

Summary of the Simulation Cases

Burner pattern: Bottom, Middle, Top
 Bottom No Service Mill: JK
 Middle No Service Mill: EF
 Top No Service Mill: AB
 Bottom2 No Service Mill: GH
 Top2 No Service Mill: CD

Tilt angle: -30,-10,0,+30






Table 3.4 Case number of all simulations (102 cases)







Sheet 0: Original Boiler	Sheet 1: Original Boiler/Additional Air 2%
Sheet 2: Original Boiler/Additional Air 5%	Sheet 3: Original Boiler/Additional Air 10%
Sheet 4: Original Boiler/Additional Air 20%	Sheet 5: Original Boiler/Additional Air 30%
Sheet 6: Original Boiler/Additional Air 40%	Sheet 7: Original Boiler/Additional Air 50%
Sheet 8: Original Boiler/Additional Air 60%	Sheet 9: Original Boiler/Additional Air 70%
Sheet 10: Original Boiler/Additional Air 80%	Sheet 11: Original Boiler/Additional Air 90%
Sheet 12: Original Boiler/Additional Air 100%	Sheet 13: Original Boiler/Additional Air 110%
Sheet 14: Original Boiler/Additional Air 120%	Sheet 15: Original Boiler/Additional Air 130%
Sheet 16: Original Boiler/Additional Air 140%	Sheet 17: Original Boiler/Additional Air 150%
Sheet 18: Original Boiler/Additional Air 160%	Sheet 19: Original Boiler/Additional Air 170%
Sheet 20: Original Boiler/Additional Air 180%	Sheet 21: Original Boiler/Additional Air 190%
Sheet 22: Original Boiler/Additional Air 200%	Sheet 23: Original Boiler/Additional Air 210%
Sheet 24: Original Boiler/Additional Air 220%	Sheet 25: Original Boiler/Additional Air 230%
Sheet 26: Original Boiler/Additional Air 240%	Sheet 27: Original Boiler/Additional Air 250%
Sheet 28: Original Boiler/Additional Air 260%	Sheet 29: Original Boiler/Additional Air 270%
Sheet 30: Original Boiler/Additional Air 280%	Sheet 31: Original Boiler/Additional Air 290%
Sheet 32: Original Boiler/Additional Air 300%	Sheet 33: Original Boiler/Additional Air 310%
Sheet 34: Original Boiler/Additional Air 320%	Sheet 35: Original Boiler/Additional Air 330%
Sheet 36: Original Boiler/Additional Air 340%	Sheet 37: Original Boiler/Additional Air 350%
Sheet 38: Original Boiler/Additional Air 360%	Sheet 39: Original Boiler/Additional Air 370%
Sheet 40: Original Boiler/Additional Air 380%	Sheet 41: Original Boiler/Additional Air 390%
Sheet 42: Original Boiler/Additional Air 400%	Sheet 43: Original Boiler/Additional Air 410%
Sheet 44: Original Boiler/Additional Air 420%	Sheet 45: Original Boiler/Additional Air 430%
Sheet 46: Original Boiler/Additional Air 440%	Sheet 47: Original Boiler/Additional Air 450%
Sheet 48: Original Boiler/Additional Air 460%	Sheet 49: Original Boiler/Additional Air 470%
Sheet 50: Original Boiler/Additional Air 480%	Sheet 51: Original Boiler/Additional Air 490%
Sheet 52: Original Boiler/Additional Air 500%	Sheet 53: Original Boiler/Additional Air 510%
Sheet 54: Original Boiler/Additional Air 520%	Sheet 55: Original Boiler/Additional Air 530%
Sheet 56: Original Boiler/Additional Air 540%	Sheet 57: Original Boiler/Additional Air 550%
Sheet 58: Original Boiler/Additional Air 560%	Sheet 59: Original Boiler/Additional Air 570%
Sheet 60: Original Boiler/Additional Air 580%	Sheet 61: Original Boiler/Additional Air 590%
Sheet 62: Original Boiler/Additional Air 600%	Sheet 63: Original Boiler/Additional Air 610%
Sheet 64: Original Boiler/Additional Air 620%	Sheet 65: Original Boiler/Additional Air 630%
Sheet 66: Original Boiler/Additional Air 640%	Sheet 67: Original Boiler/Additional Air 650%
Sheet 68: Original Boiler/Additional Air 660%	Sheet 69: Original Boiler/Additional Air 670%
Sheet 70: Original Boiler/Additional Air 680%	Sheet 71: Original Boiler/Additional Air 690%
Sheet 72: Original Boiler/Additional Air 700%	Sheet 73: Original Boiler/Additional Air 710%
Sheet 74: Original Boiler/Additional Air 720%	Sheet 75: Original Boiler/Additional Air 730%
Sheet 76: Original Boiler/Additional Air 740%	Sheet 77: Original Boiler/Additional Air 750%
Sheet 78: Original Boiler/Additional Air 760%	Sheet 79: Original Boiler/Additional Air 770%
Sheet 80: Original Boiler/Additional Air 780%	Sheet 81: Original Boiler/Additional Air 790%
Sheet 82: Original Boiler/Additional Air 800%	Sheet 83: Original Boiler/Additional Air 810%
Sheet 84: Original Boiler/Additional Air 820%	Sheet 85: Original Boiler/Additional Air 830%
Sheet 86: Original Boiler/Additional Air 840%	Sheet 87: Original Boiler/Additional Air 850%
Sheet 88: Original Boiler/Additional Air 860%	Sheet 89: Original Boiler/Additional Air 870%
Sheet 90: Original Boiler/Additional Air 880%	Sheet 91: Original Boiler/Additional Air 890%
Sheet 92: Original Boiler/Additional Air 900%	Sheet 93: Original Boiler/Additional Air 910%
Sheet 94: Original Boiler/Additional Air 920%	Sheet 95: Original Boiler/Additional Air 930%
Sheet 96: Original Boiler/Additional Air 940%	Sheet 97: Original Boiler/Additional Air 950%
Sheet 98: Original Boiler/Additional Air 960%	Sheet 99: Original Boiler/Additional Air 970%
Sheet 100: Original Boiler/Additional Air 980%	Sheet 101: Original Boiler/Additional Air 990%
Sheet 102: Original Boiler/Additional Air 1000%	







Table 3.5 Case number of additional simulations (16 cases)

Sheet No.	Title	Contents		
9	Base	*Base Cases to have considered the effect of the ash layer		
	Case1d	*External Heat Transfer BC for furnace wall h=200[W/m².K], T_ext=623[K] *External Heat Transfer BC for Super Heaters h=5000[W/m².K], T_ext=750[K] *This condition is employed with all the following cases		
10	Heater Configuration	*Studies to improve the steam temperature difference (3) *Division panel configuration is changed into heater 1		
*Add cases Bottom2 & Top2 to confirm the effect of the Heater1				
Sheet 9: Base Cases 1				
Original Boiler	Heater 0	Furnace Heat Transfer Realistic		
Heat Input	1.20E+09 [Gcal/hr]	1.39E+09 [W]		
GR	0 [%]	0 [%]		
GR	0 [%]	0 [%]		
Pattern Tilt	-30	-10	0	30
Bottom2	141	142	143	144
Top2	151	152	153	154
Sheet 10: Division Panel Configuration, Heater 1				
Modified Boiler	Heater 1	Furnace Heat Transfer Realistic		
Heat Input	1.20E+09 [Gcal/hr]	1.39E+09 [W]		
GR	0 [%]	0 [%]		
GR	0 [%]	0 [%]		
Pattern Tilt	-30	-10	0	30
Bottom2	641	642	643	644
Top2	651	652	653	654

1. Preliminary/Base Case Study
2. Simulation Study












Table 4.3.1 Comparison of the Furnace Heat Recovery Percent

Evaluation Item	Tilt	Heat Recovery % of Furnace(HRF) %				Δ HR=HR- HRF(Base) %		
		Base	O ₂ =5%	GR=10%	GR=20%	O ₂ =5%	GR=10%	GR=20%
Bottom (JK)	-30	34.19	32.14	29.86	26.30	-2.05	-4.33	-7.89
	-10	34.36	32.43	28.15	23.39	-1.93	-6.21	-10.97
	0	32.40	30.34	27.77	23.58	-2.06	-4.63	-8.82
Middle (EP)	-30	29.95	27.98	25.12	21.80	-1.98	-4.84	-7.85
	-10	32.96	31.05	29.99	23.81	-1.91	-3.97	-9.15
	0	30.90	29.20	27.32	23.27	-1.70	-3.58	-7.63
Top (AB)	-30	29.14	27.98	24.50	21.27	-1.17	-4.64	-7.87
	-10	35.62	33.32	32.40	28.00	-2.30	-3.22	-7.62
	0	33.35	31.08	27.12	23.25	-2.27	-6.22	-10.10
Average Value		32.12	30.15	27.48	23.52	-1.98	-4.64	-8.60

O₂=5%:
2% of HRF is decreased.
GR=10%:
5% of HRF is decreased
GR=20%:
8.5% of HRF is decreased

Table 4.3.2 Comparison of the Furnace exit gas temperature (nose level)

Evaluation Item	Tilt	Furnace Exit Gas Temperature deg.C				Δ T=T-T(Base) deg.C		
		Base	O ₂ =5%	GR=10%	GR=20%	O ₂ =5%	GR=10%	GR=20%
Bottom (JK)	-30	1324.90	1268.30	1320.20	1299.00	-56.60	-4.70	-25.90
	-10	1325.10	1287.80	1345.50	1312.80	-37.30	20.40	-12.30
	0	1392.50	1358.30	1375.10	1339.00	-34.20	-17.40	-53.50
Middle (EP)	-30	1323.90	1289.70	1318.50	1284.70	-34.20	-5.40	-39.20
	-10	1348.70	1308.80	1340.70	1320.00	-39.90	-6.00	-28.70
	0	1363.90	1328.20	1358.60	1329.60	-35.70	-5.30	-34.30
Top (AB)	-30	1402.90	1360.30	1382.90	1348.50	-42.60	-10.00	-53.40
	-10	1306.10	1271.40	1291.00	1293.60	-33.70	-24.10	-11.50
	0	1374.20	1330.60	1348.20	1328.20	-43.60	-35.00	-46.00
Average Value		1355.98	1316.41	1348.12	1325.18	-39.58	-7.87	-30.81

O₂=5%:
40deg.C is decreased.
GR=10%:
5deg.C is decreased.
GR=20%:
30deg.C is decreased

Table 4.3.3 Comparison of the SH Heat Recovery Percent

Evaluation Item	Tilt	Heat Recovery % of Super Heater(HRsh) %				Δ HRsh=HRsh- HRsh(Base) %		
		Base	O ₂ =5%	GR=10%	GR=20%	O ₂ =5%	GR=10%	GR=20%
Bottom (JK)	-30	23.80	21.56	24.26	23.57	-2.24	0.36	-0.33
	-10	23.58	22.67	23.15	22.22	-0.91	-0.43	-1.36
	0	24.39	23.45	23.06	25.01	-0.94	0.67	0.62
Middle (EP)	-30	22.40	21.54	22.29	20.59	-0.86	-0.11	-1.82
	-10	23.42	22.47	23.87	21.73	-0.95	0.55	-1.69
	0	24.62	23.81	23.51	23.82	-1.81	-1.11	-0.80
Top (AB)	-30	25.32	24.43	24.16	25.13	-0.89	-1.16	-0.19
	-10	23.03	22.33	22.61	23.11	-0.70	-0.43	0.07
	0	24.43	23.65	24.53	23.23	-0.78	0.09	-1.20
Average Value		25.56	24.67	25.06	24.33	-0.70	0.49	0.16

O₂=5%:
1% of HRsh is decreased.
GR=10%:
HRsh is almost equal.
GR=20%:
1% of HRsh is decreased

Table 4.3.4 Comparison of the RH IN gas temperature







Evaluation Item	Tilt	Reheater in Gas Temperature deg.C				Δ T=T-T(Base) deg.C		
		Base	O ₂ =5%	GR=10%	GR=20%	O ₂ =5%	GR=10%	GR=20%
Bottom (JK)	-30	971.30	964.63	969.16	1002.50	-6.67	18.86	31.20
	-10	975.57	965.51	1002.20	1045.30	-10.06	47.63	69.73
	0	980.93	964.60	1004.80	1009.50	3.67	23.87	22.57
Middle (EP)	-30	1073.60	1070.20	1069.50	1073.20	16.60	44.90	23.60
	-10	990.22	997.37	1018.40	1041.40	-3.85	28.18	51.18
	0	999.49	995.63	1008.60	1050.20	-3.86	9.11	50.71
Top (AB)	-30	1076.10	1076.80	1078.70	1078.20	0.70	2.60	2.10
	-10	1037.60	1038.50	1068.00	1084.80	0.90	31.49	47.20
	0	995.25	992.20	993.15	995.94	-3.05	7.89	37.69
Average Value		978.31	972.52	1004.60	1036.70	-5.79	26.29	58.39

O₂=5%:
Temp. is almost equal.
GR=10%:
20deg.C is increased.
GR=20%:
40deg.C is increased

Table 4.3.5 The effect of the oxygen conc. & gas recirculation to the heat recovery pattern

Operation	Heat Recovery % (furnace)		Nose Temperature [deg.C]	
	Base	Effect	Base	Effect
O ₂ =5%	32.12	-1.98	1355.98	-39.58
GR=10%	32.12	-4.64	1355.98	-7.87
GR=20%	32.12	-8.60	1355.98	-8.60
Heat Recovery % (SH)		RH,IN Temperature [deg.C]		
Operation	Base	Effect	Base	Effect
O ₂ =5%	24.40	-1.19	897.89	-2.93
GR=10%	24.40	-0.23	897.89	23.16
GR=20%	24.40	-0.74	897.89	32.57
Heat Recovery % (RH)				
Operation	Base	Effect		
O ₂ =5%	7.91	0.09		
GR=10%	7.91	0.79		
GR=20%	7.91	1.18		

Note1:SH (Wall Heater + Div + Platen) Arrow: Red is good, Blue is bad.
Note2:RH data are reference value.









Table 4.5.1 Effect of the Heater1 to the Right & Left Deflection

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Div+Platen)			Heat Recovery % (Design Panel + Heater)			Heat Recovery % (Evaluation Panel + Heater + SH)			R&L Deflection of Heat Recovery (Heat Super Heater)		
		Base	Heater1	Δ % w/1	Base	Heater1	Δ % w/1	Base	Heater1	Δ % w/1	Base	Heater1	Δ % w/1
Bottom	-30	5.52	-2.50	-45%	21.15	18.78	-11%	23.90	21.89	-9%	3.36	-1.82	-54%
	-10	3.46	0.90	26%	20.96	20.19	-4%	23.58	23.43	-1%	-5.05	-1.50	-30%
	0	1.19	2.93	245%	21.62	21.14	-2%	24.39	24.62	1%	7.33	4.52	62%
Bottom2	-30	6.81	-5.95	-87%	23.65	23.14	-2%	26.45	26.47	0%	3.37	-1.44	-43%
	-10	1.37	5.61	408%	20.94	20.30	-3%	23.41	23.57	1%	5.71	5.06	89%
	0	11.84	4.13	-35%	21.45	21.06	-2%	24.04	24.38	1%	7.88	5.50	-30%
Middle	-30	1.79	-8.20	-458%	24.00	23.16	-3%	26.00	26.42	2%	4.29	-9.51	-223%
	-10	14.51	8.21	57%	20.92	20.75	-1%	23.42	23.89	2%	12.29	8.47	-32%
	0	-12.53	-20.46	-163%	21.96	20.83	-5%	24.62	23.82	-3%	-23.47	-24.35	-4%
Top	-30	27.20	3.99	-14%	22.29	23.44	6%	25.35	26.72	5%	13.54	-4.58	-34%
	-10	3.45	2.91	84%	20.92	19.82	-5%	23.00	23.00	0%	-12.46	-29.39	-237%
	0	5.57	-2.85	-51%	21.56	20.43	-5%	24.38	23.76	-3%	1.06	-11.19	-104%
Total	-30	14.13	4.89	-35%	21.96	21.19	-2%	24.66	24.60	-0%	4.46	2.39	54%
	-10	11.36	-4.58	-40%	22.43	22.12	-1%	26.00	26.17	1%	0.10	-16.17	-161%
	0	6.78	-1.81	-27%	20.28	21.61	10%	23.03	24.43	6%	4.00	4.95	124%
AB	-10	15.16	-20.17	-133%	21.61	21.18	-2%	24.43	24.77	1%	0.34	4.95	145%
	0	7.66	0.40	5%	22.60	21.58	-5%	25.87	25.27	-2%	0.40	2.38	60%
	30	13.92	6.44	46%	22.36	24.16	10%	26.56	26.14	-2%	1.76	-26.17	-148%
Average/AB Value	-10	15.02	-5.15	-34%	21.95	21.65	-1%	24.62	24.48	-1%	-5.14	-10.30	-20%
	0	7.66	0.40	5%	22.60	21.58	-5%	25.87	25.27	-2%	0.40	2.38	60%
	30	13.92	6.44	46%	22.36	24.16	10%	26.56	26.14	-2%	1.76	-26.17	-148%
Mer/AB Value	-10	15.02	-5.15	-34%	21.95	21.65	-1%	24.62	24.48	-1%	-5.14	-10.30	-20%
	0	7.66	0.40	5%	22.60	21.58	-5%	25.87	25.27	-2%	0.40	2.38	60%
	30	13.92	6.44	46%	22.36	24.16	10%	26.56	26.14	-2%	1.76	-26.17	-148%

Table 4.5.2 Effect of the Heater1 to the Heat Recovery Pattern

Evaluation Item	Tilt	Heat Recovery % (Furnace)			Heat Recovery % (Heat Super)			Temperature (deg C) (SH Zone, Platen Wall)			Temperature (deg C) (SH Zone)		
		Base	Heater1	Δ % w/1	Base	Heater1	Δ % w/1	Base	Heater1	Δ % w/1	Base	Heater1	Δ % w/1
Bottom	-30	34.19	34.82	1%	3.11	0.37	-12%	1324.80	1299.80	-2%	971.30	960.00	-1%
	-10	34.36	35.12	1%	2.76	0.24	0%	1325.10	1300.00	-2%	975.57	972.35	-0%
	0	32.40	32.56	0%	2.77	0.46	17%	1323.50	1300.00	-2%	965.92	979.71	1%
Bottom2	-30	39.35	39.41	0%	2.82	0.29	0%	1326.50	1302.80	-2%	1014.60	1014.60	0%
	-10	34.00	34.32	1%	2.54	0.27	0%	1333.10	1337.10	1%	988.41	966.00	-2%
	0	32.39	32.83	1%	2.59	0.28	0%	1343.40	1356.80	1%	990.71	979.66	-1%
Middle	-30	39.25	39.60	1%	2.89	0.24	0%	1400.00	1400.00	0%	1014.30	1014.30	0%
	-10	34.48	34.43	-0%	2.37	0.27	0%	1323.90	1322.40	-1%	990.22	989.97	-0%
	-10	32.96	33.36	1%	2.91	0.63	22%	1346.70	1350.80	1%	999.49	999.19	-0%
Top	-30	30.90	31.37	1%	2.66	0.32	12%	1363.90	1367.30	2%	1014.10	1017.70	1%
	-10	32.01	32.60	2%	2.59	0.58	23%	1346.70	1350.80	1%	999.49	999.19	-0%
	0	32.01	32.60	2%	2.59	0.58	23%	1346.70	1350.80	1%	999.49	999.19	-0%
Total	-30	35.06	35.75	1%	2.82	0.21	0%	1321.40	1323.80	2%	959.70	973.43	1%
	-10	33.51	33.63	0%	2.80	0.30	1%	1341.60	1347.50	1%	977.23	973.64	-0%
	0	32.05	32.21	0%	2.70	0.41	15%	1363.10	1370.00	1%	986.22	990.00	1%
AB	-30	39.37	39.36	0%	2.80	0.29	0%	1400.00	1400.00	0%	1014.30	1014.30	0%
	-10	33.35	33.53	1%	2.82	0.59	21%	1344.70	1360.20	1%	978.31	980.89	3%
	0	31.96	31.98	0%	2.67	0.46	17%	1372.40	1374.40	0%	962.61	967.60	1%
Average/AB Value	-30	39.35	39.36	0%	2.80	0.29	0%	1400.00	1400.00	0%	1014.30	1014.30	0%
	-10	33.52	33.52	0%	2.82	0.29	0%	1363.90	1367.30	2%	986.25	990.24	3%
	0	32.05	32.25	1%	2.70	0.46	17%	1374.40	1374.40	0%	1023.00	1023.00	0%
Mer/AB Value	-30	39.35	39.36	0%	2.80	0.29	0%	1400.00	1400.00	0%	1014.30	1014.30	0%
	-10	33.52	33.52	0%	2.82	0.29	0%	1363.90	1367.30	2%	986.25	990.24	3%
	0	32.05	32.25	1%	2.70	0.46	17%	1374.40	1374.40	0%	1023.00	1023.00	0%






Figure 4.5.5 Effect of the Heater combination to the Right & Left Deflection

Ref. 1 Effect of each operations to the heat recovery percent of the re-heaters

Evaluation Item	Tilt	Heat Recovery percent (Rad RH + Conv RH)						
		Base (%)	OC=5% (%)	GR=0% (%)	GR=20% (%)	AA=20% (%)	OF=50% (%)	Heater1 (%)
Bottom (JK)	-30	7.50	7.54	8.09	8.51	7.50	7.70	7.24
	-10	7.22	7.24	8.66	9.33	7.22	7.42	7.14
	0	7.48	7.58	8.17	8.50	7.48	8.61	7.33
	30	8.37	8.87	9.61	9.40	8.37	8.44	8.39
Bottom2 (GH)	-30	9.00	---	---	---	---	---	7.77
	-10	7.54	---	---	---	---	---	7.06
	0	7.57	---	---	---	---	---	7.34
	30	8.39	---	---	---	---	---	8.42
Middle (EF)	-30	7.82	8.01	8.64	9.33	6.86	8.00	7.78
	-10	7.97	8.05	8.32	8.56	7.29	7.58	7.59
	0	8.39	8.51	8.69	8.73	7.49	8.21	8.48
	30	8.89	8.79	9.83	9.24	8.83	8.76	8.17
Top2 (CD)	-30	7.10	---	---	---	---	---	7.28
	-10	7.33	---	---	---	---	---	7.20
	0	7.78	---	---	---	---	---	7.29
	30	8.35	---	---	---	---	---	7.97
Top (AB)	-30	6.66	6.93	7.24	8.14	7.67	6.65	7.29
	-10	7.29	7.31	8.45	8.15	8.83	7.60	7.25
	0	7.49	7.65	8.42	8.53	8.67	7.90	7.40
	30	8.89	8.63	10.36	9.74	7.62	10.05	9.06
Average		7.81	8.00	8.71	9.10	7.64	8.15	7.67
Max		9.83	9.52	10.36	9.74	8.83	10.05	9.06
Min		6.85	6.83	7.24	8.14	6.86	6.65	7.06

Note:
The prediction of the convection heaters is not so accurate in this simulation. These data is submitted as a reference value.

Recommendation

1. L & R deflection

- The Bottom pattern and the Tilt -10 degree operation for L & R deflection

Carry out trial operation by applying the best parameters written above to the current boiler. For further mitigation of temperature imbalance,

- Modify the boiler by applying the cross-connecting pipes between Division SH and Platen SH.

2. SH and RH steam temperature

- To increase SH and RH steam temperature, remove front Division SH, and add the same heating surface to rear Division SH by modification of rear Division SH. In addition, apply wall SH at left and right sides of furnace where Division SH is located.

Removal of front Division SH is also effective for mitigation of temperature imbalance.

Boiler Combustion Simulation

Simulation of Air and Fuel Bias

- Additional Request to improve the R&L deflection
 - Right & Left 2nd Air Bias by changing the wind box draft.
 - Right & Left Fuel Bias (1st Air)
 - Right & Left Fuel Bias (1st Air) + 2nd Air Bias

Note: Simulation Conditions same as previous study report.

Simulation of Air and Fuel Bias

Sheet No. #1	Title	Contents
0	Base	- Base Cases to have considered the effect of the ash layer - External Heat Transfer BC for furnace wall h=5000(W/m ² /K), Tenv=500[C] - External Heat Transfer BC for Super Heaters h=5000(W/m ² /K), Tenv=7500[C] - This condition is employed with all the following cases.
1		Bias* -20% (Left = -10%, Right = +10%)
2	2nd Air Bias	Bias* -10% (Left = -5%, Right = +5%)
3		Bias* +10% (Left = +5%, Right = -5%)
4		Bias* +20% (Left = +10%, Right = -10%)
5		Bias* -20% (Left = -10%, Right = +10%)
6	1st Air Fuel Bias	Bias* -10% (Left = -5%, Right = +5%)
7		Bias* +10% (Left = +5%, Right = -5%)
8		Bias* +20% (Left = +10%, Right = -10%)
9		Bias* -20% (Left = -10%, Right = +10%)
A	1st/2nd Air Fuel Bias	Bias* -10% (Left = -5%, Right = +5%)
B		Bias* +10% (Left = +5%, Right = -5%)
C		Bias* +20% (Left = +10%, Right = -10%)

*1) Simulation Condition are described each sheet in next table

Boiler Combustion Simulation


Case number of all simulations (20 base cases)

Sheet 0: Base Cases 1		Heater 0	Furnace Heat Transfer:Realistic
1)Original Boiler			
Heat Input	1.20E+09 [kcal/hr]		1.39E+09 [W]
O2=	3 [%]	OF=	0 [%damper]
GR=	0 [%]	AA=	0 [%]
2dn Bias	0	1st Bias	0
Fuel Bias	0		
Pattern	Tilt	-30	-10
		0	30
Bottom		111	112
		121	122
Middle		123	124
		131	132
Top		133	134
		141	142
Top2		143	144
		151	152
Bottom2		153	154




Bottom No Service Mill: JK
Bottom2 No Service Mill: GH
Middle No Service Mill: EF
Top2 No Service Mill: CD
Top No Service Mill: AB







Case number of all simulations (240 Bias cases)

Project Name	Case No.	Case Name	Case No.	Case Name	Case No.	Case Name
Project 1: Top Air & Burner -10%	1001	Top Air & Burner -10%	1002	Top Air & Burner -10%	1003	Top Air & Burner -10%
	1004	Top Air & Burner -10%	1005	Top Air & Burner -10%	1006	Top Air & Burner -10%
	1007	Top Air & Burner -10%	1008	Top Air & Burner -10%	1009	Top Air & Burner -10%
	1010	Top Air & Burner -10%	1011	Top Air & Burner -10%	1012	Top Air & Burner -10%
Project 1: Top Air & Burner -5%	1013	Top Air & Burner -5%	1014	Top Air & Burner -5%	1015	Top Air & Burner -5%
	1016	Top Air & Burner -5%	1017	Top Air & Burner -5%	1018	Top Air & Burner -5%
	1019	Top Air & Burner -5%	1020	Top Air & Burner -5%	1021	Top Air & Burner -5%
	1022	Top Air & Burner -5%	1023	Top Air & Burner -5%	1024	Top Air & Burner -5%
Project 1: Top Air & Burner 0%	1025	Top Air & Burner 0%	1026	Top Air & Burner 0%	1027	Top Air & Burner 0%
	1028	Top Air & Burner 0%	1029	Top Air & Burner 0%	1030	Top Air & Burner 0%
	1031	Top Air & Burner 0%	1032	Top Air & Burner 0%	1033	Top Air & Burner 0%
	1034	Top Air & Burner 0%	1035	Top Air & Burner 0%	1036	Top Air & Burner 0%
Project 1: Top Air & Burner 5%	1037	Top Air & Burner 5%	1038	Top Air & Burner 5%	1039	Top Air & Burner 5%
	1040	Top Air & Burner 5%	1041	Top Air & Burner 5%	1042	Top Air & Burner 5%
	1043	Top Air & Burner 5%	1044	Top Air & Burner 5%	1045	Top Air & Burner 5%
	1046	Top Air & Burner 5%	1047	Top Air & Burner 5%	1048	Top Air & Burner 5%
Project 1: Top Air & Burner 10%	1049	Top Air & Burner 10%	1050	Top Air & Burner 10%	1051	Top Air & Burner 10%
	1052	Top Air & Burner 10%	1053	Top Air & Burner 10%	1054	Top Air & Burner 10%
	1055	Top Air & Burner 10%	1056	Top Air & Burner 10%	1057	Top Air & Burner 10%
	1058	Top Air & Burner 10%	1059	Top Air & Burner 10%	1060	Top Air & Burner 10%



Improve the R&L deflection
 (1) Right & Left 2nd Air Bias
 by changing the wind box draft.









Table 4.3.1 Effect of 2nd Air Bias on the R & L Deflection Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)				
		Straight				
		-20	-10	0	10	20
Bottom (JK)	-30	-11.09	-7.26	5.32	-21.13	-31.15
	-10	8.86	5.04	3.48	7.58	16.57
	0	9.12	10.44	12.19	2.73	2.12
	30	16.60	12.34	6.81	-21.47	-17.45
Bottom2 (GH)	-30	-10.56	-35.46	13.56	-8.57	32.81
	-10	10.51	26.68	7.37	11.90	5.54
	0	10.19	9.57	11.84	10.41	-6.33
	30	6.92	4.69	3.79	-19.69	-26.42
Middle (EF)	-30	14.77	28.75	16.10	-22.15	19.48
	-10	11.68	10.28	14.51	13.93	11.04
	0	15.81	11.52	-12.53	-19.81	16.65
	30	25.65	31.01	27.20	7.83	-17.76
Top2 (CD)	-30	3.11	9.21	3.45	3.29	14.61
	-10	14.00	19.51	5.57	3.98	19.86
	0	11.01	19.53	16.13	-12.36	2.90
	30	8.34	13.91	11.36	-46.92	-9.20
Top (AB)	-30	-0.50	7.53	6.78	-2.13	13.82
	-10	11.28	17.70	15.16	4.79	8.44
	0	18.98	13.82	7.86	4.53	-7.87
	30	28.00	23.44	-4.92	-33.22	-2.01
AverageABS(d%)		12.35	15.90	10.29	13.84	14.10
MaxABS(d%)		28.00	35.46	27.20	46.92	32.81
MINABS(d%)		0.50	4.69	3.45	2.13	2.01




Table 4.3.2 Effect of 2nd Air Bias with Cross 1 on the R & L Deflection Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)				
		Cross1				
		-20	-10	0	10	20
Bottom (JK)	-30	-3.44	-7.45	2.50	-17.17	-16.78
	-10	8.10	7.62	2.33	21.34	9.04
	0	1.81	7.70	8.78	16.14	7.57
	30	6.18	5.73	4.83	-5.18	-9.33
Bottom2 (GH)	-30	3.13	-13.02	-0.73	20.91	1.13
	-10	-2.89	8.89	1.85	17.37	9.38
	0	-2.05	4.78	6.96	3.04	6.22
	30	4.72	3.01	3.74	4.06	-19.48
Middle (EF)	-30	0.91	8.55	8.25	-5.88	6.25
	-10	4.34	4.28	7.41	20.79	7.94
	0	9.31	0.36	-14.29	-21.76	7.03
	30	3.76	11.85	11.73	25.57	-11.72
Top2 (CD)	-30	14.77	6.32	-0.53	7.69	4.72
	-10	4.13	11.27	6.98	17.78	9.50
	0	6.49	8.59	8.64	-1.04	7.64
	30	8.43	8.86	6.87	-29.61	-8.14
Top (AB)	-30	10.58	10.43	4.83	6.83	3.80
	-10	1.24	6.88	6.81	14.48	7.98
	0	6.40	4.16	8.14	0.73	5.95
	30	12.13	10.54	-8.79	-22.01	3.70
AverageABS(d%)		6.24	7.52	6.25	14.16	8.11
MaxABS(d%)		14.77	13.02	14.29	29.61	19.46
MINABS(d%)		0.91	0.36	0.53	0.73	1.13

ABS(Orange Frame) <±10%

Table 4.3.3 Effect of 2nd Air Bias with Cross 2 on the R & L Deflection Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)				
		Cross2				
		-20	-10	0	10	20
Bottom (JK)	-30	4.74	-2.46	-1.40	2.12	2.90
	-10	1.45	3.99	-2.43	10.10	-2.69
	0	-6.80	-0.24	-0.42	6.28	6.59
	30	-4.43	-2.65	-0.29	5.46	-0.57
Bottom2 (GH)	-30	8.60	9.64	-11.73	22.28	-21.41
	-10	-12.08	-10.51	-3.56	0.22	6.10
	0	-9.58	-3.44	-2.18	-8.63	11.74
	30	0.40	-1.11	-0.10	9.42	-4.60
Middle (EF)	-30	-10.36	-11.94	-1.81	-0.38	-6.97
	-10	-4.44	-2.74	-1.55	6.25	1.99
	0	-1.31	-8.19	-6.10	-6.28	-5.14
	30	-6.63	-10.92	-8.65	11.57	-2.11
Top2 (CD)	-30	13.31	0.25	-3.72	6.43	-4.59
	-10	-7.54	-2.82	2.95	7.22	-5.55
	0	-2.97	-5.36	-3.26	0.99	4.83
	30	0.85	-1.24	-2.42	0.35	-8.42
Top (AB)	-30	11.25	5.31	-0.14	8.93	-5.10
	-10	-1.35	-5.95	-3.95	5.78	1.98
	0	-8.14	-6.32	3.45	-13.68	11.98
	30	-7.95	-7.15	-9.52	-3.00	3.48
AverageABS(d%)		6.31	5.08	3.48	6.77	5.88
MaxABS(d%)		13.31	11.94	11.73	22.28	21.41
MINABS(d%)		0.40	0.24	0.10	0.22	0.51

ABS(Orange Frame) <±10%

Table 4.3.4 Effect of 2nd Air Bias with Cross 3 on the R & L Deflection
 Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)				
		Cross3	Cross3	Cross3	Cross3	Cross3
Bottom (JK)	-30	-2.92	-2.28	1.42	5.12	-11.49
	-10	2.21	0.91	-1.28	1.82	4.85
	0	0.50	2.51	2.99	-2.55	1.13
	30	5.99	4.16	1.68	-1.41	-9.43
Bottom2 (GH)	-30	-5.09	-12.80	2.56	15.32	10.27
	-10	1.32	7.29	1.96	-14.58	2.26
	0	2.65	1.35	2.70	-17.52	-0.81
	30	2.59	0.58	-0.05	0.20	-11.56
Middle (EF)	-30	3.50	8.27	6.05	-2.95	6.26
	-10	2.90	3.26	5.56	1.72	4.49
	0	5.18	2.99	-4.34	-0.32	4.48
	30	7.26	8.14	6.83	-0.71	-8.74
Top2 (CD)	-30	1.65	3.14	0.27	4.30	5.31
	-10	2.33	5.42	1.53	-0.02	4.80
	0	1.55	5.58	4.23	-4.63	0.09
	30	2.76	3.81	2.07	-0.08	-3.68
Top (AB)	-30	0.18	2.41	1.81	5.14	4.91
	-10	2.70	4.86	4.40	-1.22	2.66
	0	4.44	3.34	2.96	-20.40	-1.88
	30	7.92	9.75	-8.65	-6.81	-7.22
AverageABS(d%)		3.28	4.44	3.02	8.05	5.31
Max(ABS(d%))		7.82	12.80	6.83	20.40	11.56
MIN(ABS(d%))		0.18	0.58	0.05	0.02	0.09

ABS(Orange Frame)
 <±10%

Improve the R&L deflection
 (2)Right & Left Fuel Bias (1st Air).




Figure 4.4.1 Effect of Fuel & 1st Air Bias on the R & L Deflection
 Plus value = Left (high), Minus value = Right (high)




Figure 4.4.2 Isothermal Surface = 1000 deg in SH Zone




Figure 4.4.4 Isothermal Surface = 1000 deg in SH Zone





Table 4.4.1 Effect of Fuel & 1st Air Bias on the R & L Deflection
 Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)				
		Straight	Straight	Straight	Straight	Straight
Bottom (JK)	-30	-7.80	0.61	5.32	23.72	1.88
	-10	6.79	11.74	18.42	22.54	21.08
	0	-9.35	18.2	12.19	16.98	21.08
	30	21.23	18.75	6.81	23.72	3.92
Bottom2 (GH)	-30	-34.36	-7.21	13.56	6.36	9.33
	-10	17.64	8.71	4.12	1.04	1.04
	0	11.89	9.74	11.84	5.90	15.89
	30	8.45	6.21	3.79	10.01	7.24
Middle (EF)	-30	33.18	26.38	16.10	8.23	-7.82
	-10	13.13	13.76	14.51	12.27	7.02
	0	21.62	27.11	32.53	-2.19	18.31
	30	34.26	32.36	27.20	23.36	16.25
Top2 (CD)	-30	9.60	7.78	3.45	6.87	4.25
	-10	17.40	17.43	5.57	8.23	12.23
	0	15.94	20.37	16.13	5.70	-1.96
	30	17.17	15.66	11.26	3.09	-4.06
Top (AB)	-30	7.71	6.23	6.78	6.62	7.99
	-10	15.79	15.59	15.16	12.82	9.78
	0	17.30	9.95	7.66	2.07	-3.37
	30	27.88	17.99	-4.92	24.07	-29.69
AverageABS(d%)		16.96	13.54	10.29	11.24	10.25
Max(ABS(d%))		34.36	32.36	27.20	24.07	28.69
MIN(ABS(d%))		0.35	0.61	3.45	2.07	1.04




Table 4.4.2 Effect of Fuel & 1st Air Bias with Cross 1 on the R & L Deflection
 Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)			
		Cross1	Cross1	Cross1	Cross1
Bottom (JK)	-30	5.62	-9.78	2.50	14.02
	-10	7.57	9.39	2.33	7.87
	0	5.76	8.44	8.78	7.37
	30	7.71	7.55	4.83	14.02
Bottom2 (GH)	-30	-11.93	-10.98	-9.66	-7.89
	-10	8.58	6.01	1.85	4.93
	0	6.91	10.47	6.96	5.75
	30	5.07	4.43	3.74	4.64
Middle (EF)	-30	11.05	9.55	8.25	6.64
	-10	4.07	6.43	7.41	7.51
	0	11.80	11.84	-14.29	1.00
	30	12.11	12.67	11.73	11.07
Top2 (CD)	-30	6.82	5.78	0.33	1.35
	-10	8.11	5.56	6.98	7.95
	0	7.96	7.47	8.64	4.12
	30	5.41	5.92	6.87	3.29
Top (AB)	-30	10.01	7.77	4.82	1.92
	-10	6.98	6.51	6.81	6.28
	0	7.73	5.75	6.14	5.50
	30	10.39	3.65	8.25	11.17
AverageABS(d%)		8.27	8.33	6.25	7.15
Max(ABS(d%))		12.11	12.67	14.29	18.17
MIN(ABS(d%))		4.07	3.65	0.53	1.00

ABS(Orange Frame) <±10%

Table 4.4.3 Effect of Fuel & 1st Air Bias with Cross 2 on the R & L Deflection
 Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)			
		Cross2	Cross2	Cross2	Cross2
Bottom (JK)	-30	10.26	-10.31	-1.40	-1.17
	-10	3.16	1.38	-2.43	-5.13
	0	6.10	7.11	-0.42	-4.77
	30	-7.04	-8.16	-0.78	-1.17
Bottom2 (GH)	-30	9.20	-8.20	-11.73	-14.52
	-10	-3.69	0.26	-3.56	2.42
	0	-2.58	6.86	-2.18	1.41
	30	-1.03	-0.72	-0.10	-4.71
Middle (EF)	-30	-11.26	-7.99	-1.81	2.14
	-10	-4.37	-2.37	-1.55	-0.23
	0	-3.36	-8.13	-6.10	0.89
	30	-12.66	-11.27	-8.65	-6.64
Top2 (CD)	-30	0.83	0.58	-3.72	-3.40
	-10	-5.23	-8.55	2.95	1.85
	0	-3.39	-7.44	-3.26	-1.74
	30	-2.29	-3.02	-2.42	-1.35
Top (AB)	-30	4.68	3.42	-0.14	-3.60
	-10	-4.05	-4.37	-3.95	-2.81
	0	-4.28	-1.92	3.45	3.68
	30	-11.14	-12.18	-9.52	-6.19
AverageABS(d%)		5.54	5.51	3.46	3.50
Max(ABS(d%))		12.86	12.18	11.73	14.52
MIN(ABS(d%))		0.83	0.26	0.10	0.23

ABS(Orange Frame) <±10%

Table 4.4.4 Effect of Fuel & 1st Air Bias with Cross 3 on the R & L Deflection
Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)				
		Cross3	Cross3	Cross3	Cross3	Cross3
		-20	-10	0	10	20
Bottom (JK)	-30	-2.96	0.07	1.42	8.53	1.45
	-10	2.38	3.73	-1.29	5.42	6.62
	0	0.00	0.29	2.99	4.94	6.00
Bottom2 (GH)	-30	6.48	5.04	1.68	8.53	-1.63
	-10	-13.22	-2.42	2.56	1.51	2.80
	-10	5.37	2.96	1.96	1.61	1.48
Middle (EF)	0	2.40	2.13	2.70	1.55	3.52
	30	2.35	1.06	-0.05	0.66	-0.59
	-30	10.87	8.84	6.05	3.73	-4.42
Top2 (CD)	-10	4.69	4.96	5.56	4.53	3.00
	0	6.66	7.14	-4.34	-2.31	2.04
	30	9.28	8.42	6.93	5.46	2.99
Top (AB)	-30	3.61	2.57	0.27	2.12	1.35
	-10	4.05	3.32	1.53	2.13	2.78
	0	4.59	5.45	4.23	-0.16	-3.52
AverageABS(d%)	30	5.47	4.21	2.07	-1.58	-4.78
	-30	2.39	1.88	1.81	1.11	1.35
	-10	4.76	4.72	4.40	3.74	2.97
MaxABS(d%)	0	5.29	2.28	2.96	0.24	-0.85
	30	6.35	1.56	-5.65	-12.09	-13.71
	MINABS(d%)	0.00	0.07	0.05	0.16	0.85

ABS(Orange Frame)
<±10%

Improve the R&L deflection
(3)Right & Left Fuel Bias (1st Air) + 2nd Air Bias.




Figure 4.5.1 Effect of Fuel & 1st Air (+2nd Air) Bias on the R & L Deflection
Plus value = Left (high), Minus value = Right (high)




Figure 4.5.2 Isothermal Surface = 1000 deg in SH Zone




Figure 4.5.3 Isothermal Surface = 1000 deg in SH Zone




Figure 4.5.4 Isothermal Surface = 1000 deg in SH Zone





Table 4.5.1 Effect of Fuel & 1st Air (+2nd Air) Bias on the R & L Deflection
 Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)				
		Straight	Straight	Straight	Straight	Straight
Bottom (JK)	-30	18.08	14.01	5.32	-7.38	18.51
	-10	15.14	6.58	3.45	13.27	5.23
	0	14.58	14.01	12.19	9.40	2.18
	30	23.41	18.72	8.81	-20.30	-23.83
	30	-3.15	-38.48	13.56	13.09	23.66
Bottom2 (GH)	-30	0.64	0.42	7.02	4.37	2.84
	-10	16.85	7.89	11.84	-5.29	-11.23
	0	11.07	7.71	3.79	-11.31	-24.88
	30	3.89	30.43	16.10	2.35	21.46
	30	14.66	12.66	14.51	8.35	3.79
Middle (EF)	-30	20.29	14.96	-12.53	20.70	12.99
	-10	26.89	29.27	27.20	12.09	-25.80
	0	5.22	10.31	3.45	9.22	13.03
	30	11.92	14.41	5.57	18.31	19.42
	30	10.72	16.00	16.13	3.80	5.55
Top2 (CD)	-30	11.92	13.38	11.36	-18.71	-15.02
	-10	-5.11	4.91	6.78	10.71	14.08
	0	14.92	13.32	15.16	8.62	3.60
	30	20.21	16.58	7.66	-4.97	-8.58
	30	29.00	29.00	-4.92	-3.16	-7.00
AverageABS(dfl%)		13.79	15.55	10.29	10.54	13.75
Max ABS(dfl%)		29.00	38.48	27.20	20.80	33.94
MIN ABS(dfl%)		0.64	0.42	3.45	2.35	2.18




Table 4.5.2 Effect of Fuel & 1st Air (+2nd Air) Bias with Cross 1 on the R & L Deflection
 Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)				
		Cross1	Cross1	Cross1	Cross1	Cross1
Bottom (JK)	-30	13.37	6.92	2.50	-8.32	7.45
	-10	8.47	7.94	2.33	6.07	7.16
	0	5.56	6.92	8.78	7.76	7.83
	30	8.17	7.44	4.83	-14.91	-19.53
	30	2.32	-12.51	-0.73	-5.15	7.62
Bottom2 (GH)	-30	-3.07	-5.99	1.95	6.53	8.03
	-10	-1.68	-3.68	6.96	9.07	5.80
	0	5.99	4.94	3.74	-11.31	-13.80
	30	0.56	6.35	8.25	-3.53	5.59
	30	4.65	4.09	7.41	7.19	5.27
Middle (EF)	-30	9.58	10.20	-14.29	9.91	8.99
	-10	10.37	10.43	11.73	6.22	-9.41
	0	14.49	9.66	-0.53	2.90	4.47
	30	7.70	8.17	6.98	7.51	6.43
	30	7.27	7.86	8.64	7.09	7.60
Top (AB)	-30	8.02	8.55	6.87	-16.41	-8.15
	-30	9.62	11.11	4.83	3.14	3.65
	-10	7.31	6.67	6.81	7.06	6.81
	0	8.44	5.30	8.14	6.16	5.99
	30	12.35	12.33	-8.79	-1.82	3.75
AverageABS(dfl%)		7.47	7.83	6.25	7.30	7.67
Max ABS(dfl%)		14.49	12.51	14.29	16.41	19.53
MIN ABS(dfl%)		0.56	3.68	0.53	1.82	3.65

ABS(Orange Frame) <±10%

Table 4.5.3 Effect of Fuel & 1st Air (+2nd Air) Bias with Cross 2 on the R & L Deflection
 Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)				
		Cross2	Cross2	Cross2	Cross2	
Bottom (JK)	-30	2.63	-3.72	-1.40	-3.41	-3.48
	-10	-2.81	3.47	-2.43	-4.06	2.98
	0	-5.59	-3.72	-0.42	0.60	6.69
	30	-6.59	-5.18	-0.29	-4.59	-0.79
	30	3.94	11.24	-11.73	-13.27	-10.58
Bottom2 (GH)	-30	-4.25	-6.85	-3.56	3.53	6.66
	-10	-13.63	-10.57	-2.18	14.02	14.36
	0	-0.15	-0.39	-0.10	-6.59	0.44
	30	-1.85	-15.65	-1.81	-6.27	-7.86
	30	-5.94	-4.81	-1.55	2.59	2.89
Middle (EF)	-30	-4.42	0.01	-6.10	-5.77	-1.92
	-10	-7.97	-10.79	-8.65	-4.31	5.04
	0	11.54	3.24	-3.72	-3.05	-3.63
	30	-0.23	-2.20	2.95	-7.10	-8.88
	30	-0.38	-3.63	-3.26	3.26	3.15
Top2 (CD)	-30	1.19	-0.17	-2.42	-9.42	-3.15
	-30	13.30	8.19	-0.14	-4.02	-5.39
	-10	-3.33	-3.19	-3.95	1.04	4.24
	0	-6.75	-6.83	3.45	9.56	10.94
	30	-7.33	-8.75	-8.52	1.00	6.76
AverageABS(dfl%)		5.19	5.64	3.48	5.37	5.50
Max ABS(dfl%)		13.63	15.65	11.73	14.02	14.36
MIN ABS(dfl%)		0.15	0.01	0.10	0.60	0.44

ABS(Orange Frame) <±10%

Table 4.5.4 Effect of Fuel & 1st Air (+2nd Air) Bias with Cross 3 on the R & L Deflection
 Plus value = Left (high), Minus value = Right (high)

Evaluation Item	Tilt	R&L Deflection of Heat Recovery (Division Panel + Platen)				
		Cross3	Cross3	Cross3	Cross3	Cross3
		-20	-10	0	10	20
Bottom (JK)	-30	5.35	3.37	1.42	-4.45	5.58
	-10	3.86	2.11	-1.23	3.14	1.04
	0	3.43	3.37	2.99	2.25	1.04
	30	8.64	6.10	1.68	-10.48	-15.20
Bottom2 (Gr)	-30	-1.55	-12.71	2.56	4.97	11.46
	-10	-0.54	-0.84	1.96	1.37	1.27
	0	4.90	1.00	2.70	-0.34	-2.67
	30	4.93	2.38	-0.05	-6.59	-10.65
Middle (EF)	-30	1.48	8.44	6.05	-0.39	8.01
	-10	4.08	3.76	5.56	3.74	1.40
	0	6.29	4.77	-4.34	5.02	2.08
	30	8.64	8.05	6.83	1.56	-11.46
Top2 (CD)	-30	2.27	3.89	0.27	3.27	4.72
	-10	4.00	4.04	1.53	3.70	4.13
	0	3.07	4.31	4.23	-0.03	1.10
	30	5.08	4.66	2.07	-11.72	-10.01
Top (AB)	-30	-1.43	1.99	1.81	3.54	5.03
	-10	3.89	3.46	4.40	2.60	1.03
	0	5.02	4.45	2.96	-1.57	-2.03
	30	9.32	7.93	-5.65	-5.34	-3.99
AverageABS(d%)		4.39	4.58	3.02	3.80	5.20
Max(ABS(d%))		9.32	12.71	6.83	11.72	15.20
MIN(ABS(d%))		0.54	0.84	0.05	0.03	1.03

ABS(Orange Frame)
 $\pm 10\%$

The result of Simulation Air and Fuel Bias

- R & L deflection dose not have a consistent tendency to the bias fraction.
 Tilt=-10deg:R & L deflection is stable by plus value.
 (Strong swirl flow in the furnace)
 Tilt=+30deg:The big changing by bias was predicted.
 (Weak swirl flow in the furnace)
- It would be very difficult to control R&L deflection by this bias operation.
- **Effect of the Cross Combination 2 and 3:**
 + Cross combination 2 and 3 is very effective to minimize the deflection
 under a lot of operating conditions.
 +However, a big deflection is sometimes found in bias condition.
- It would be better to take non-bias condition with the cross combination.