






### KEY PLAN

### LEGEND

-  Proposed Pipeline Route
-  Stop Valve
-  Water Tanker Filling Station
-  Public Tap Stands
-  Washout valve

**The Project for the Improvement  
of Water Supply System of Juba  
in Southern Sudan**

**Ministry of Water Resources and Irrigation  
Government of Southern Sudan  
Southern Sudan Urban Water Corporation**



**Japan International Cooperation Agency  
(JICA)  
Tokyo Engineering Consultants, Co., Ltd.**

Facility:  
**Distribution Pipe**

Title:  
**Distribution Main and  
Secondary Pipelines- 12**






Scale:  
**1/5000**  
Original Paper Size:  
**A3**

Drawing No.: **DSP-012**  
Date: **Nov. 2010**  
Revision: **Rev. 1.0**





### KEY PLAN

### LEGEND

-  Proposed Pipeline Route
-  Stop Valve
-  Water Tanker Filling Station
-  Public Tap Stands
-  Washout valve






<b>The Project for the Improvement of Water Supply System of Juba in Southern Sudan</b>	<b>Ministry of Water Resources and Irrigation</b> <b>Government of Southern Sudan</b>	<b>Japan International Cooperation Agency (JICA)</b>	Title: <b>Distribution Pipe</b>	Title: <b>Distribution Main and Secondary Pipelines- 13</b>	Scale: <b>1/5000</b>	Drawing No.: <b>DSP-013</b>
	<b>Southern Sudan Urban Water Corporation</b>	<b>Tokyo Engineering Consultants, Co., Ltd.</b>			Original Paper Size: <b>A3</b>	Date: <b>Nov. 2010</b>
						Revision: <b>Rev. 1.0</b>







**KEY PLAN**

**LEGEND**

-  Proposed Pipeline Route
-  Stop Valve
-  Water Tanker Filling Station
-  Public Tap Stands
-  Washout valve

<p><b>The Project for the Improvement of Water Supply System of Juba in Southern Sudan</b></p>	<p><b>Ministry of Water Resources and Irrigation Government of Southern Sudan</b></p>	<p><b>Japan International Cooperation Agency (JICA)</b></p>	<p>Scale:</p>	<p>Title:</p> <p><b>Distribution Main and Secondary Pipelines- 15</b></p>	<p>Scale:</p> <p><b>1/5000</b></p>	<p>Drawing No.:</p> <p><b>DSP-015</b></p>
	<p><b>Southern Sudan Urban Water Corporation</b></p>	<p><b>Tokyo Engineering Consultants, Co., Ltd.</b></p>	<p><b>Distribution Pipe</b></p>	<p>Original Paper Size:</p> <p><b>A3</b></p>	<p>Date:</p> <p><b>Nov. 2010</b></p>	<p>Revision:</p> <p><b>Rev. 1.0</b></p>







**KEY PLAN**

**LEGEND**

- Proposed Pipeline Route
- Stop Valve
- Water Tanker Filling Station
- Public Tap Stands
- Washout valve

<p>The Project for the Improvement of Water Supply System of Juba in Southern Sudan</p>	<p>Ministry of Water Resources and Irrigation Government of Southern Sudan</p>	<p>Japan International Cooperation Agency (JICA)</p>	<p>Scale: Distribution Pipe</p>	<p>Title: Distribution Main and Secondary Pipelines- 16</p>	<p>Scale: 1/5000</p>	<p>Drawing No.: DSP-016</p>
	<p>Southern Sudan Urban Water Corporation</p>	<p>Tokyo Engineering Consultants, Co., Ltd.</p>			<p>Original Paper Size: A3</p>	<p>Date: Nov. 2010</p>



The Project for the Improvement  
of Water Supply System of Juba  
in Southern Sudan

Ministry of Water Resources and Irrigation  
Government of Southern Sudan  
Southern Sudan Urban Water Corporation

Japan International Cooperation Agency  
(JICA)  
Tokyo Engineering Consultants, Co., Ltd.


Project:  
Distribution Pipe

Title:  
Water Pipe Bridge

Scale:  
1/100  
Original Paper Size:  
A3


Drawing No.:  
DSP-017  
Date:  
Nov. 2010  
Revision:  
Rev. 1.0

Standard Trench Section




DN	B
50	500
80	500
100	500
125	500
150	500
200	500
250	500
300	520
350	570
400	630
450	680
500	730


**Asphalt paved road  
(Normal part)**




**Asphalt pavement road  
(Rocky terrain)**




**Sidewalk pavement  
(Normal part)**




**Sidewalk unpaved  
(Rocky terrain)**



**Unpaved road  
(Normal part)**





**Unpaved road  
(Rocky terrain)**



# Concrete Thrust Anchor Block

( Static water pressure 1.0Mpa Surge pressure 0.50Mpa )




(mm)

DN	11°			22°			45°			45°+45°=90°			90°			Tee branch			Stop valve			45° Upward vertical band			45° Downward vertical band			90° Downward vertical band					
	B	H	L	B	H	L	B	H	L	B	H	L	B	H	L	B	H	L	B	H	L	B	H	L	B	H	L	B	H	L			
50																			300	250	300												
80																			500	450	600												
100																			650	500	900												
125																			650	600	900												
150																			850	700	1200												
200																			1200	900	1400												
250	700	700	800	1000	1000	1100	1200	1200	1700	1600	1200	2800	1600	1200	2800	1300	1200	2100	1400	1200	1500	—	—	—	—	—	—	—	—	—	—	—	—
300	800	800	1000	1200	1200	1200	1400	1200	2200	2100	1200	3000	2100	1200	3000	1600	1200	2600	1800	1200	1700	—	—	—	—	—	—	—	—	—	—	—	—
350	900	900	1200	1300	1200	1500	1700	1200	2500	2300	1200	3600	2300	1200	3600	1900	1200	2900	2150	1200	1800	1700	1200	1700	2000	2000	2300						
400	1000	1000	1200	1500	1200	1700	2000	1200	2700	2500	1200	4000	2500	1200	4000	2300	1200	3000	2350	1200	2200	2100	1200	1800	2200	2200	2400						
450	1200	1200	1200	1700	1200	1900	2200	1200	3000	2700	1200	4400	2700	1200	4400	2600	1200	3200	2500	1200	2800	—	—	—	—	—	—	—	—	—	—	—	—
500	1300	1200	1400	1800	1200	2200	2500	1200	3200	3000	1200	4600	3000	1200	4600	2800	1200	3500	2800	1200	3000	—	—	—	—	—	—	—	—	—	—	—	—




# Detail OF Distribution Pipe (1)



<b>The Project for the Improvement of Water Supply System of Juba in Southern Sudan</b>	<b>Ministry of Water Resources and Irrigation Government of Southern Sudan</b>	<b>Japan International Cooperation Agency (JICA)</b>	<b>Facility: Distribution Pipe</b>	<b>Title: Details of Distribution Pipe (1)</b>	<b>Scale: NONE</b>	<b>Drawing No.:</b> <b>DSP-020</b>
	<b>Southern Sudan Urban Water Corporation</b>	<b>Tokyo Engineering Consultants, Co., Ltd.</b>			<b>Original Paper Size: A3</b>	<b>Date:</b> <b>Mar. 2011</b>


# Detail OF Distribution Pipe (2)




<b>The Project for the Improvement of Water Supply System of Juba in Southern Sudan</b>	<b>Ministry of Water Resources and Irrigation Government of Southern Sudan</b>	<b>Japan International Cooperation Agency (JICA)</b>	<b>Facility</b>  <b>Distribution Pipe</b>	<b>Title</b>  <b>Details of Distribution Pipe (2)</b>	<b>Scale:</b> <b>NON</b>	<b>Drawing No.:</b> <b>DSP-021</b>
	<b>Southern Sudan Urban Water Corporation</b>	<b>Tokyo Engineering Consultants, Co., Ltd.</b>			<b>Original Paper Size:</b> <b>A3</b>	<b>Date:</b> <b>Nov. 2010</b>
						<b>Revision:</b> <b>Rev. 1.0</b>

# Detail OF Distribution Pipe (3)


Watercourse Crossing Point (1)




Watercourse Crossing Point (2)




Watercourse Crossing Point (3)




Watercourse Crossing Point (4)



Watercourse Crossing Point (5)



Watercourse Crossing Point (6)



## **Appendix-8 Design Calculation**



## Examination on Water Treatment Process

### 1. Raw water quality and target treated water quality

The substances to be removed in the treatment process is insoluble substances of about 30 NTU. The target treated water quality is set as 5 NTU or less according to the Draft Drinking Water Quality Guideline Value of Southern Sudan.

In the Development Study, three items of total iron, aluminum and antimony are pointed out the possibility of exceeding the guideline value. Among them, iron and aluminum are to be removed through the conventional coagulation and rapid filtration. Re-examination was carried out for antimony in this preparatory survey. As a result, it was confirmed that antimony contents is less than 0.002 mg/L which is lower than the guideline value of 0.005mg/L.

	Target water quality (Drinking Water Quality Guideline Value of Southern Sudan)	Raw water quality	Remarks
Turbidity	5NTU or less	16.6 - 56.9NTU	Development Study (October 2008 – May 2009, 13 samples)
		0.89 - 48.5NTU (14.15NTU on average)	Operation record of the existing plant (April 2009 – September 2009, 125 samples)
Antimony	0.005mg/L or less	Less than 0.002mg/L	Confirmed in this preparatory survey

From the above, the design criteria is formed as bellow.

Item	Criteria	Remarks
Production Capacity	10,800m <sup>3</sup> /day	
Turbidity of Raw Water	Ave. 15NTU, Max.60NTU	From water quality test results
Temperature of Raw Water	Ave. 28.4°C, Max.31°C	From operation record of existing plant (Ave. 28.4°C, Min. 25°C, Max.30.8°C)

### 2. Items to be taken into account from the evaluation of existing plant

Given the above raw water quality as well as target water quality, applicable water treatment processes are to be either of coagulation, sedimentation and rapid filtration, or membrane filtration. Considering the level of operation and maintenance technique, compatibility with the existing plant, economy, etc. the coagulation, sedimentation and rapid filtration is appropriate and adopted

as the treatment process of the Project. Items to be taken into account in examination of the treatment process are as follows.

- According to operation record of the existing plant (April 8, 2009 – September 14, 2009) , turbidity of the treated water is average 1.87NTU, minimum 0.41NTU and maximum 5.1NTU, that almost meet the guideline value. However, it exceeds in some days.
- The existing facility is insufficient in coagulation due to inappropriate dosing point of coagulant dosage. And formation of flock is insufficient due to lack of retention time in flocculation basin (approx. 0.76 min.). This results in insufficiency of removal effect of the sedimentation basin.
- The existing sedimentation tank was originally designed as the solid-contact clarifier. However, in practice, it is operated as the conventional upflow sedimentation basin which doesn't form the sludge blanket zone. Currently, one out of two basins is stopped and emptied for a half day in two-three weeks in order to de-sludging and cleaning. In this case, water flow is not properly controlled that allows excessive water flow into the other operating basin which causes carrying-over of flock from the effluent. In addition, operation is re-started before sludge is thoroughly de-sludged, that causes stirring of sludge in the bottom and muddy water flows into the filter bed.
- The existing filtration basin has non-cascade type inflow and outflow is not controlled, that causes unequal inflow to the filter basins. This results in degradation of treated water due to excessive flow into a basin which is not clogged compared to the others. Water level of the outlet of filter is designed to be lower than the surface of filter bed, which causes little water level above sand bed. Therefore, surface of filter bed is easily disturbed in the beginning of filtration, which causes uneven filtration and instability of water quality due to negative pressure. Currently filter backwashing is performed once in a day. However, possibility of mad ball is pointed out due to insufficiency of washing time.
- Since the proposed facility is planned to be constructed in the existing plant site, constraints of land availability shall be taken into account.

### 3. Design of Sedimentation Tank

Considering that raw water quality is approx. 30 NTU in turbidity, constraints of land availability and level of operation technique, conventional upflow sedimentation tank is adopted. Since the conventional upflow sedimentation tank is not specified in the “Water Supply Facility Design Guideline (JWWA: Japan Water Works Association, 2000)”, guideline values of “Integrated Design for Water Treatment Plant (1995, JWWA)” are referred to. Considering the

level of operation technique, sludge scraper is installed as the existing plant.

#### Comparison on Sedimentation Tank

Type	Horizontal flow	Solid-contact	Conventional upflow (Adopted in the Project)
Surface load	15~30mm/min <sup>※1</sup>	40~60mm/min <sup>※1</sup>	22~31mm/min <sup>※2</sup>
Required settling area	275m <sup>2</sup> or more	138m <sup>2</sup> or more	266m <sup>2</sup> or more
Retention time	2.2 ~ 4.5 hours (Effective depth: 4m)	1.5~2.0 hours <sup>※1</sup>	1.0~3.0 hours <sup>※2</sup>
Applicable to intermittent operation	Applicable	Not applicable	Applicable
Site	Difficult to layout rectangular basin (1:3~1:8)	Possible to layout	Possible to layout

※ 1 “Water Supply Facility Design Guideline (2000)”

※ 2 “Integrated Design for Water Treatment Plant (1995)”

#### Design Specification of Sedimentation Tank

Item	Specification	Remarks
Production capacity (Q)	11,880m <sup>3</sup> /day (8.25m <sup>3</sup> /min)	10,800m <sup>3</sup> /day × 1.1 (Plant loss 10%)
Number of tanks (N)	2 tanks	「Design Guideline」
Surface load (S <sub>L</sub> )	29.1mm/min	「Design Guideline」: 15~30mm/min (horizontal flow) 「Integrated design」: 22~31mm/min
Settling area (A <sub>0</sub> )	283.2m <sup>2</sup>	Q(m <sup>3</sup> /min) ÷ S <sub>L</sub> × 10 <sup>-3</sup> (m/min)
Area per one tank (A)	141.6m <sup>2</sup> /tank	11.9m × 11.9m (square)
Effective depth (H)	5.3m	「Integrated design」: 3~5m (radial upflow)
Effective volume (V)	1,501m <sup>3</sup>	A(m <sup>2</sup> ) × N (tank) × H(m)
Retention time (T)	3.03hours	V(m <sup>3</sup> ) ÷ Q(m <sup>3</sup> /day) 「Design Guideline」: 2.2~4.5hours 「Integrated design」: 1.0~3.0hours
Weir overflow rates	135m <sup>3</sup> /m/day	Q(m <sup>3</sup> /day) ÷ (11.9m × 4nos. × 2tanks) 「Design Guideline」: 350m <sup>3</sup> /m/day or less 「Integrated design」: 168m <sup>3</sup> /m/day or less (radial upflow) 「Water Treatment (AWWA)」: 250m <sup>3</sup> /m/day or less(Conventional basin)

In the proposed sedimentation tank, coagulation and flocculation process is enhanced so as to improve the removal efficiency of the sedimentation tank, while this process is not performed well in the existing plant. Desludging of the tank of the proposed facility will be carried out with ease by opening drain valve regularly without emptying the tank which is a practice done in the existing plant. Accordingly, current issues of overloading and dirty water intrusion will be prevented.



#### 4. Design of Filter Basin

##### (1) Items to be Taken into account

The following items are taken into account to design the new filtration facility.

- 1) Whereas the existing filter basin allows more water into a basin which is less clogged compared to the others, the proposed facility is equipped with inflow weir which allows equal inflow to the filter basin.
- 2) Water level of the outlet of filter is lower than the surface of filter bed, which causes disturbance of filter bed and uneven filtration. The outlet pipe of the proposed filter will be positioned at higher than the filter bed so as to keep the appropriate water level above sand bed. Therefore, filter bed will not be exposed in operation stop. In restarting, filtration rate increases according to increase of water level in filter bed (slow-start) which will not affect treated water quality.
- 3) The proposed filter bed will be equipped with drain of unstable quality of water immediately after the backwashing.

##### (2) Examination on Filter Media

Rapid sand filtration is a final process of turbid removal where micro-flock not removed from the sedimentation tank is adhered to the filter media. From the retention amount of turbidity in the filtration as well as filtration hours, diameter of filter media is examined as follows.

Filtration hours are decided by turbidity of inflow and retention amount of turbidity. In case that size of filter media is 0.6mm in diameter with uniformity coefficient of 1.4 (Design Guideline of Water Supply Facility, Japan), filter works in the surface layer. Given this, retention amount of SS (Suspended Solid) is reported as 1.3-1.5 kg/m<sup>2</sup> from the pilot experiment by the filter media manufacture (Nihon Genryo Co., Ltd.). By using these data, design conditions are summarized as below:

**Turbidity of Inflow and Filtration Hours**

①Producti on capacity (m <sup>3</sup> /day)	②Turbidity of inflow (Degree) <sup>*1</sup>	③Load of inflowing turbidity (kg)	④Total filter area (m <sup>2</sup> )	⑤Retention amount of turbidity (kg/m <sup>2</sup> )	⑥Filtration hours (1): 1.3kg/m <sup>2</sup> (Hr)	⑦Filtration hours (2): 1.5kg/m <sup>2</sup> (Hr)
11,880	20 (28.6 NTU)	237.6	96.2	2.47	12.6	14.6
11,880	18	213.8	96.2	2.22	14.1	16.2

①Producti on capacity (m <sup>3</sup> /day)	②Turbidity of inflow (Degree) <sup>*1</sup>	③Load of inflowing turbidity (kg)	④Total filter area (m <sup>2</sup> )	⑤Retention amount of turbidity (kg/m <sup>2</sup> )	⑥Filtration hours (1): 1.3kg/m <sup>2</sup> (Hr)	⑦Filtration hours (2): 1.5kg/m <sup>2</sup> (Hr)
	(25.7 NTU)					
11,880	16 (22.9 NTU)	190.1	96.2	1.98	15.8	18.2
11,880	14 (20.0 NTU)	166.3	96.2	1.73	18.0	20.8
11,880	12 (17.1 NTU)	142.6	96.2	1.48	21.1	24.3
11,880	10 (14.3 NTU)	118.8	96.2	1.23	25.4	29.3
11,880	8 (11.4 NTU)	95	96.2	0.99	31.5	36.4
11,880	6 (8.6 NTU)	71.3	96.2	0.74	42.2	48.6
11,880	5 (7.1 NTU)	59.4	96.2	0.62	50.3	58.1
11,880	4 (5.7 NTU)	47.5	96.2	0.49	63.7	73.5
11,880	2 (2.9 NTU)	23.8	96.2	0.25	124.8	144.0

<sup>\*1</sup>: Since turbidity is of silt matters, 1 degree of turbidity is equivalent to 1mg-SS/L. 1 NTU=0.7 degree of turbidity as shown in the bracket.

As average and maximum turbidity of raw water is 15 and 60NTU respectively, filtration hours is expected to be approx. 63 hours (see the case of inflow turbidity 4NTU, retention amount 1.30kg/m<sup>2</sup>) on condition that 6 NTU from the sedimentation tank. In operation of the facility, 48 hours of filtration hours are proposed in practice.

In case that filtration by whole layer by using filter media of about 1.0 mm is designed, filtration hours can be longer than the above case. However, this requires more thickness of filter bed and backwash water. Also there is a possibility of coarse effects of filtration. Therefore, in this Project size of filter media is designed to be 0.6mm as aforementioned.

### (3) Specification of filtration basin

Comparison between existing and proposed filtration basin is shown in table below.

	Existing Facility	Proposed Facility
Type	Open type gravity flow	Open type gravity flow
Filtration area	63 m <sup>2</sup>	96.2 m <sup>2</sup>
Number of filter basin	4basin (15.75m <sup>2</sup> per basin)	6 basin (19.24m <sup>2</sup> per basin, including one standby)
Filtration rate	120 m/day	123 m/day
Filter media	Diameter: 0.7mm, Sand layer:750mm	Diameter: 0.6mm, Sand layer:700mm
Supporting gravel	Gravel layer: 450mm	Gravel layer: 200mm
Backwashing	Air + backwash	Air + backwash

Backwash water	$0.83 \text{ m/min} \times 15.75\text{m}^2/\text{basin} \times 10\text{min}=131\text{m}^3$	$0.70 \text{ m/min} \times 19.24\text{m}^2/\text{basin} \times 6\text{min}=80.8\text{m}^3$
Under drain	Perforated pipe	Perforated block
Backwash tank	$150\text{m}^3$ , Head:12m	$137.9\text{m}^3$ , Head:4m

I Intake Facility

## 1. Intake Pipe

## 1. Condition

- ① Intake capacity  $Q = 10,800 \times 1.1 = 11,880$  [m<sup>3</sup>/day] =  $0.14$  [m<sup>3</sup>/sec]  
 ② No. of pipe  $N = 3$  [nos] (including one standby)  $N' = N - 0 = 3$  [nos]  
 ③ Velocity  $3$  [m/sec] or less (Design Guideline for Water Supply Facility)

## 2. Required pipe diameter

On assuming velocity  $V = 1.5$  [m/sec]

$$A = \frac{Q}{N' \times V} = \frac{0.14}{3 \times 1.5} = 0.0311 \text{ [m}^2\text{]}$$

$$\phi = \sqrt{(A \times 4 / \pi)} = 0.199 \text{ [m]} \rightarrow \Phi 250\text{mm}$$

## 3. Summary

Diameter	$\phi 250$	[mm]
Pipe No.	3	[nos]
Hydraulic gradient	11.1	[%]
Velocity	1.43	[m/sec]

## 2. Intake Pump

## 1. Condition

- ① Intake capacity  $Q = 10,800 \times 1.1 = 11,880$  [m<sup>3</sup>/day] =  $8.25$  [m<sup>3</sup>/min]  
 ② No. of pump  $3$  [units] (including one standby)

## 2. Discharge capacity per pump

On assuming No. of pumps:  $2$  [units]

$$Q = Q \div N = 8.25 \div 2.0 = 4.125 \text{ [m}^3\text{/min]} \quad 0.1375$$

## 3. Head

Given intake pipe = 80m, and transmission pipe = 70m, pipe head loss is:

$$\Delta h_1 = I_1 \times L_1 + I_2 \times L_2 = 80 \times 11.1\% + 70 \times 4.1\% = 1.18 \text{ [m]}$$

Actual head required:

$$\Delta h_2 = 465.00 - 450.47 = 14.53 \text{ [m]}$$

(HWL of receiving well) (LWL of river)

Head loss around pump:

$$\Delta h_3 = 5.00 \text{ [m]}$$

Consequently, required pump head is:

$$\Delta H = \Delta h_1 + \Delta h_2 + \Delta h_3 = 20.71 \text{ [m]}$$

## 3. Summary

Specification	$\phi 200$	[mm]	$\times$	4.1	[m <sup>3</sup> /min]	$\times$	21	[m]	$\times$	30	[kW]
Number of pump	3	[units]									

## 3. Raw Water Transmission Pipe

## 1. Condition

- ① Intake capacity  $Q = 10,800 \times 1.1 = 11,880$  [m<sup>3</sup>/day] =  $0.14$  [m<sup>3</sup>/sec]  
 ② number of pipe  $N = 1$  [nos]  
 ③ Velocity  $3$  [m/sec] or less (Design Guideline for Water Supply Facility)

## 2. Required pipe diameter

On assuming velocity:  $V = \boxed{1.5}$  [m/sec]

$$A = \frac{Q}{V} = \frac{0.14}{1.5} = 0.0933 \quad [\text{m}^2]$$

$$\phi = \sqrt{(A \times 4 / \pi)} = \boxed{0.345} \text{ [m]} \rightarrow \Phi 400\text{mm}$$

## 3. Summary

Pipe diameter	$\phi$ 400	[mm]
Number of pipe	$\boxed{1}$	[nos]
Hydraulic gradient	$\boxed{4.1}$	[%]
Velocity	$\boxed{1.11}$	[m/sec]

II Water Treatment Plant1. Receiving Well

## 1. Condition

- ① Flow  $Q = 10,800 \times 1.1 = 11,880 \text{ [m}^3/\text{day]} = 8.25 \text{ [m}^3/\text{min]}$
- ② No. of tank  $1 \text{ [tank]}$
- ③ Retention time  $1.5 \text{ [min]}$  or more (Design Guideline for Water Supply Facility)
- ④ Others To function also as grit removal basin  
 Surface Load  $AL = 200 \sim 500 \text{ mm/min}$   
 (Design Guideline for Water Supply Facility)  
 Ave. Velocity  $V_h = 2 \sim 7 \text{ cm/sec}$   
 (Design Guideline for Water Supply Facility)

## 2. Required capacity

On assuming retention time:  $10 \text{ [min]}$

$$V_0 = Q \times t = 8.25 \times 10.0 = 82.5 \text{ [m}^3\text{]}$$

## 3. Shape and Dimension

Rectangular, assuming one side  $B =$

Assuming one side  $B = 2.5 \text{ [m]}$  and effective depth  $H = 3.4 \text{ [m]}$   
 the other side  $L =$

$$L = \frac{V_0}{B \times H} = \frac{82.5}{2.5 \times 3.4} = 9.71 \rightarrow 9.85 \text{ [m]}$$

## 4. Effective capacity

$$V = B \times L \times H = 2.5 \times 9.85 \times 3.4 = 83.7 \text{ [m}^3\text{]}$$

## 5. Retention time

$$T = \frac{V}{Q} = \frac{83.7}{8.25} = 10.1 \text{ [min]} > 1.5 \text{ [min]}$$

## 6. Surface load

$$AL = \frac{Q}{B \times L} = \frac{8.25}{2.5 \times 9.85} = 0.335 \text{ m/min} = 335 \text{ mm/min}$$

## 7. Velocity in tank

$$V_h = \frac{Q}{B \times H} = \frac{8.25}{2.5 \times 3.4} = 0.971 \text{ m/min} = 1.62 \text{ cm/sec}$$

## 8. Summary

Dimension	$2.5 \text{ [mB]} \times 9.85 \text{ [mL]} \times 3.4 \text{ [mH]}$
No. of tank	$1 \text{ [tank]}$
Retention time	$10.1 \text{ [min]}$
Surface Load	$335 \text{ mm/min}$
Velocity in tank	$1.62 \text{ cm/sec}$

2. Rapid mixing tank

## 1. Condition

- ① Flow  $Q = 10,800 \times 1.1 = 11,880$  [m<sup>3</sup>/day] =  $8.3$  [m<sup>3</sup>/min]  
 ② No. of tank  $1$  [tank]  
 ③ Retention time  $1 \sim 5$  [min] (Design Guideline for Water Supply Facility)  
 ④ G value  $G = 150$  [1/sec] or more  $\rightarrow 350$  [1/sec]

## 2. Required capacity

Retention time  $1$  [min] is assumed

$$V_0 = Q \times t = 8.3 \times 1 = 8.3 \text{ [m}^3\text{]}$$

## 3. Shape and dimension

Square shape and one side  $B = 2.5$  [m] , Effective depth  $H = 1.5$  [m] is assumed

The other side L:

$$L = \frac{V_0}{B \times H} = \frac{8.3}{2.5 \times 1.5} = 2.21 \rightarrow 2.5 \text{ [m]}$$

## 4. Effective capacity

$$V = B \times L \times H = 2.5 \times 2.5 \times 1.5 = 9.4 \text{ [m}^3\text{]}$$

## 5. Retention time

$$T = \frac{V}{Q} = \frac{9.4}{8.3} = 1.10 \text{ [min]} \rightarrow 1 \sim 5 \text{ [min]} \quad \text{O. K.}$$

## 6. Required height to drop

$$H = \frac{G^2 \times V \times \mu}{\rho \times Q \times g} = \frac{350^2 \times 9.4 \times 0.001}{1,000 \times 0.14 \times 9.8} = 0.849 \text{ [m]} \rightarrow 1.2 \text{ [m]}$$

Where

$$\begin{aligned} \mu &: \text{Viscosity coefficient} && 0.001 \text{ [kg/m/sec]} \\ \rho &: \text{Specific gravity} && 1,000 \text{ [kg/m}^3\text{]} \\ g &: \text{Gravity acceleration} && 9.8 \text{ [m/sec}^2\text{]} \end{aligned}$$

## 7. G value

$$G = \sqrt{\frac{\rho \times Q \times g}{V \times \mu \times H}} = \sqrt{\frac{1,000 \times 0.14 \times 9.8}{9.4 \times 0.001 \times 1.2}} = 347 \text{ [1/sec]}$$

## 8. Summary

Dimension	$2.5$ [mB] $\times$ $2.5$ [mL] $\times$ $1.5$ [mH]
No. of tank	$1$ [tank]
Retention time	$1.10$ [min]
G value	$347$ [1/sec]

### 3. Flocculation Basin

#### 1. Condition

- ① Flow  $Q = 10,800 \times 1.1 = 11,880$  [m<sup>3</sup>/day] =  $8.25$  [m<sup>3</sup>/min]  
 ② No. of tank  $N = 2$  [tank]  
 ③ No. of train  $D = 4$  [train]  
 ④ Retention time 20~40 [min] (Design Guideline for Water Supply Facility)  
 ⑤ GT value  $GT = 23,000 \sim 210,000$   
 ⑥ Type Horizontal buffled channel

#### 2. Required capacity

Retention time  $20$  [min] is assumed

$$V_0 = Q \times t = 8.25 \times 20 = 165 \text{ [m}^3\text{]}$$

#### 3. Shape and dimension

Rectangular, one side  $B = 1.20$  [m] , Effective depth  $H = 1.6 \sim 2.2$  [m] assumed  
 (Ave.  $1.9$  [m] )

$$L = \frac{V_0}{B \times H \times N \times D} = \frac{165}{1.2 \times 1.9 \times 2 \times 4} = 9.05 \rightarrow 9.95 \text{ [m]}$$

#### 4. Effective capacity

$$V = B \times L \times H \times N \times D = 1.2 \times 9.95 \times 1.9 \times 2 \times 4 = 181.5 \text{ [m}^3\text{]}$$

#### 5. Retention time

$$T = \frac{V}{Q} = \frac{181.488}{8.25} = 22.0 \text{ [min]} = 1,320 \text{ [sec]}$$

#### 6. GT value

$$GT = \sqrt{\frac{\rho \times g \times \Delta h \times T}{\mu}} = \sqrt{\frac{1,000 \times 9.8 \times 0.6 \times 1,320}{0.001}} = 88,000$$

#### 7. Head loss calculation

1) Head loss by 180 deg. bend. :  $h_b$

$$h_b = f_b \times \frac{v_b^2}{2g}$$

Where,

$f_b$  : Head loss coefficient by 180 deg. bend. = 1.5

$v_b$  : Velocity at 180 deg. Bend =  $Q \div$  opening area

Flow (m <sup>3</sup> /sec)	$Q/2$	0.06875 (5,940m <sup>3</sup> /day/tank)			
Step	(-)	1	2	3	4
Channel width (m)	W	0.3	0.3	0.3	0.3
Channel height (m)	H	<b>0.5</b>	<b>0.57</b>	<b>0.7</b>	<b>0.8</b>
Opening area (m <sup>2</sup> )	A	0.15	0.171	0.21	0.24
Velocity (m/sec)	V	0.458	0.402	0.327	0.286
Head loss (m)	$h_{b1}$	0.0161	0.0124	0.0082	0.0063
Number.	(-)	14	14	14	14
Loss in step (m)	$h_b$	0.225	0.173	0.115	0.088
Total head loss (m)	$\Sigma h_b$	0.601			

2) Head loss in open channel :  $h_c$

$$h_c = \frac{L}{C^2 R} v_c^2 \quad C^2 = \frac{1}{n^2} R^{1/3}$$

Where,

$n$  : Manning's roughness coefficient 0.014 (Concrete)

$R$  : Hydraulic radius



Flow (m <sup>3</sup> /sec) Q/2	0.06875 (5,940m <sup>3</sup> /day)			
Step (-)	1	2	3	4
Ave. depth (m)	2.487	2.288	2.231	2.187
Channel width (m) B	0.66	0.66	0.66	0.66
Channel length (m) L	18	18	18	18
Area (m <sup>2</sup> ) A	1.642	1.51	1.472	1.443
Hydraulic radius (m) R	0.291	0.288	0.287	0.287
Chezy coefficient C <sup>z</sup>	3382.4	3370.7	3366.8	3366.8
Velocity V <sub>c</sub>	0.0419	0.0455	0.0467	0.048
Loss in step (m) h <sub>f</sub>	0.000	0.000	0.000	0.000
Total head loss (m) Σh <sub>f</sub>	0.000			

## 8. Summary

Shape and dimensions	1.2	[mB]	×	9.95	[mL]	×	1.9	[mH]
No. of tank	2	[tank]						
No. of train	4	[train]						
Retention time	22.0	[min]						
G T Value	88,000	[-]						

4. Sedimentation Tank

## 1. Condition

- ① Flow  $Q = \frac{10,800}{24} \times 1.1 = 495$  [m<sup>3</sup>/day] = 8.25 [m<sup>3</sup>/min]
- ② No. of tank  $N = 2$  [tank]
- ④ Surface Load  $S_L = \frac{15}{3} \sim \frac{30}{4}$  [mm/min] → 30 [mm/min]
- ⑤ Retention time  $T = 3 \sim 4$  [hour]

## 2. Required settling area

$$A_o = \frac{Q}{S_L \times 10^{-3}} = \frac{8.25}{30.0 \times 10^{-3}} = 275.0 \text{ [m}^2\text{]}$$

## 3. Shape and dimension

Rectangular, One side B = 11.9 [m] is assumed

The other side L =

$$L = \frac{A_o}{B \times n} = \frac{275.0}{11.9 \times 2} = 11.6 \text{ [m]} \rightarrow 11.9 \text{ [m]}$$

## Modified settling area

$$A^* = B \times L = 11.9 \times 11.9 = 141.6 \text{ [m}^2\text{]}$$

## 4. Effective capacity

Effective depth  $H = 5.3$  [m] is assumed.

$$V = 11.9 \times 11.9 \times 5.3 = 750.5$$

## 5. Retention time

$$T = \frac{V \times N}{Q} = \frac{750.5 \times 2}{8.25} = 182 \text{ [min]} = 3.03 \text{ [hour]}$$

## 6. Modified surface Load

$$SL = \frac{Q}{A^* \times 10^{-3} \times n} = \frac{8.25}{141.6 \times 10^{-3} \times 2} = 29.1 \text{ [mm/min]}$$

## 7. Summary

Shape and dimension	11.9 [mB] × 11.9 [mL] × 5.3 [mH]
No. of tank	2 [tank]
Retention time	181.9 [min]
Surface Load	29.1 [mm/min]

## 5. Rapid Sand Filtration

### 1. Condition

- ① Flow  $Q = 10,800 \times 1.1 = 11,880$  [m<sup>3</sup>/day] =  $8.3$  [m<sup>3</sup>/min]  
 ② Type Open gravity type  
 ③ Filtration rate  $120 \sim 150$  [m/day] (Design Guideline for Water Supply Facility)  
 ④ Filter media Silica sand Filter depth  $0.7$  [m]  
 ⑤ Backwash Air + backwashing  
 ⑥ Air wash flow  $q_a = 0.9$  [m<sup>3</sup>/day/m<sup>2</sup>]  
 ⑦ Backwash flow  $q_b = 0.7$  [m<sup>3</sup>/day/m<sup>2</sup>]  
 ⑧ Air wash time  $T_a = 5$  [min]  
 ⑨ Backwash time  $T_b = 10$  [min]  
 ⑩ Drain time  $T_d = 15$  [min]

### 2. Required filter area

Filtration rate:  $L V = 125$  [m/day] is assumed

$$A_0 = \frac{Q}{L V} = \frac{11,880}{125} = 95 \text{ [m}^2\text{]}$$

### 3. Shape and dimension

Calculated as follows:

$$\begin{aligned} \text{No. of tank } N &= \frac{6}{3.7} \text{ [basin]} \text{ (incl. standby)} = \frac{1}{1} \text{ [basin]} \rightarrow n' = 5 \text{ [basin]} \\ \text{Dimension } B &= 3.7 \text{ [m]} \times L = 5.2 \text{ [m]} = \frac{19.24}{96.2} \text{ [m}^2\text{/basin]} \end{aligned}$$

### 4. Effective filter area per basin

$$A = B \times L = 3.7 \times 5.2 = 19.24 \text{ [m}^2\text{]}$$

### 5. Modified filtration rate

$$L V = \frac{Q}{A \times n'} = \frac{11,880}{19.24 \times 5} = 123 \text{ [m/day]}$$

### 6. Air wash water volume

$$Q_a = A \times q_a \times T_a = 19.2 \times 0.9 \times 5 = 86.6 \text{ [m}^3\text{]}$$

### 7. Backwash water volume

$$Q_b = A \times q_b \times T_b = 19.2 \times 0.7 \times 10 = 134.7 \text{ [m}^3\text{]}$$

### 8. Drain water volume

$$Q_c = A \times L V \times T_c = 19.2 \times 123 \times 15 / 24 / 60 = 24.7 \text{ [m}^3\text{]}$$

### 9. Total discharged water volume

$$Q' = Q_b + Q_c + Q_d = 134.7 + 24.7 + 38.0 = 197.4 \text{ [m}^3\text{]}$$

$Q_d = \text{Maximum water volume remained in filter at beginning of backwash} = 38.0 \text{ [m}^3\text{]}$

### 10. Summary

Shape and dimension	3.7 [m] × 5.2 [m]
No. of basin	6 [basin] (incl. standby 1 [basin])
Filter area	19.24 [m <sup>2</sup> /basin]
Filtration rate	123 [m/day]
Discharged water volume	197.4 [m <sup>3</sup> ]

6. Clear Water Reservoir

## 1. Condition

- ① Water production  $Q = 10,800$  [m<sup>3</sup>/day] =  $7.50$  [m<sup>3</sup>/min]  
 ② Retention time  $T = 60$  [min] or more, to be 80 min. considering existing  $T=80$ min.  
 ③ No. of tank  $N = 2$  [tank]

## 2. Required capacity

$$V = Q \times T = 7.50 \times 80 = 600 \text{ [m}^3\text{]}$$

## 3. Shape and dimension

Square, one side  $B = 4.5$  [m] , Effective depth  $H = 2.8$  [m] is assumed

The other side  $L =$

$$L = \frac{V_0}{B \times H \times N} = \frac{600}{4.5 \times 2.8 \times 2} = 23.8 \rightarrow 24.0 \text{ [m]}$$

## 4. Effective capacity

$$V = B \times L \times H \times N = 4.5 \times 24.0 \times 2.8 \times 2 = 604.8 \text{ [m}^3\text{]}$$

## 5. Retention time

$$T = \frac{V}{Q} = \frac{604.8}{8} = 80.60 \text{ [min]} = 1.34 \text{ [hour]}$$

## 6. Summary

Shape and dimension	$4.5$ [m] W × $24.0$ [m] L × $2.8$ [m] H
No. of tank	$2$ [tank]
Effective capacity	$604.8$ [m <sup>3</sup> /tank]
Retention time	$80.6$ [min]

7. Chemical Dosing Facility1. Post Chlorination by using Calcium Hypochlorite ( $\text{CaO} \cdot 2\text{CaOCl}_2 \cdot 3\text{H}_2\text{O}$ )

Flow	:	10,800	( $\text{m}^3/\text{D}$ )
Dosing point	:	Inlet channel to clear water reservoir	
Dosing rate	:	1 ~ 5	(mg/l) (Ave. 3 mg/l)
Effective Chlorine	:	65	(%)
Dilution	:	3	(%) ( $30 \text{ kg}/\text{m}^3$ )
Specific gravity	:	1.05	(-)
Dosage	:	$10,800 \times 1 \sim 5 \times \frac{100}{65} \times \frac{100}{3} \times \frac{1}{1.05} \times \frac{1}{24} \times \frac{1}{1000}$ $= 22.0 \sim 109.9 \quad (\text{L/hr}) \rightarrow 20 \sim 110 \quad (\text{L/hr})$ <p style="text-align: center;">(Ave. 65.9 L/hr)</p> $10,800 \times 1 \sim 5 \times \frac{100}{65} \times \frac{1}{24} \times \frac{1}{1000}$ $= 0.7 \sim 3.5 \quad (\text{kg/hr}) \rightarrow 0.63 \sim 3.47 \quad (\text{kg/hr})$ <p style="text-align: center;">(Ave. 2.08 kg/hr)</p>	
No. of dosing pump	:	2 (units) (incl. one standby)	
Dissolving chemical Capacity	:	To be capable of 1 day of ave. dosage	
		$65.9 \times 24 \times 1 = 1.58 \text{ m}^3/\text{tank}$	
Dimension	:	W 1.0 m $\times$ L 1.2 m $\times$ H 1.4 m ( $1.68 \text{ m}^3/\text{tank}$ )	
No. of tank	:	4 tanks (same as the existing)	
Dissolving cycle	:	Dissolving 1 day $\rightarrow$ Standing 1 day $\rightarrow$ Use 1 day $\rightarrow$ Cleaning, dissolving	
Storage tank	:	3 hours of ave. consumption	
		$65.9 \times 3.0 = 197.8 \text{ L} \rightarrow 200 \text{ L}$	
Storage capacity	:	60 day of ave. consumption as Calcium hypochlorite	
		$2.1 \times 24 \times 60 = 2,995 \text{ kg} : 67 \text{ bag (1bag 45 kg)}$	

2. Aluminum Sulfate	$(Al_2(SO_4)_3 \cdot nH_2O)$
Flow	: 11,880 (m <sup>3</sup> /D)
Dosing point	: Upstream of flow measurement weir of receiving well
Dosing rate	: 20 ~ 50 (mg/l) ( Ave. 30 mg/l )
Effectiveness of Alumina	: 17 (%)
Dilution	: 8 (%)
Specific gravity	: 1.05 (-)
Dosage	: $11,880 \times 20 \sim 50 \times \frac{100}{8} \times \frac{1}{1.05} \times \frac{1}{24} \times \frac{1}{1000}$ $= 118.0 \sim 295.0$ (L/hr) $\rightarrow$ $\frac{110 \sim 300}{(Ave. 177)}$ (L/hr)
	: $11,880 \times 20 \sim 50 \times \frac{1}{24} \times \frac{1}{1000}$ $= 9.9 \sim 24.8$ (k g/hr) $\rightarrow$ $\frac{9.2 \sim 25.2}{(Ave. 14.9)}$ (k g/hr)
No. of dosing pump	: 3 (unit) (incl. one standby)
Dissolving chemical Capacity	: To be capable of 1 day of ave. dosage $177 \times 24 \times 1 = 4.25$ m <sup>3</sup> /tank
Dimension	: W 1.4 m $\times$ L 1.6 m $\times$ H 1.6 m ( 3.58 m <sup>3</sup> /tank)
No. of tank	: 3 tanks (same as the existing)
Dissolving cycle	: Dissolv. 1 day $\rightarrow$ Use 1 day $\rightarrow$ Cleaning, dissolving
Storage tank	: 2 hours of ave. consumption $177.0 \times 2.0 = 354$ L $\rightarrow$ 300 L
Storage capacity	: 30 day of ave. consumption as Aluminum Sulfate $14.9 \times 24 \times 30 = 10,728$ kg

## 8. Sludge treatment

### 1. Sludge volume

#### 1. Condition

① Water production	$Q$	$=$	$\boxed{10,800}$	$\times$	$1.1$	$=$	$\boxed{11,880}$	$[\text{m}^3/\text{day}]$
② Turbidity of (Ave.) Raw water (Max.)	$Tu_a$	$=$	$\boxed{30}$		$[\text{deg}]$			
	$Tu_m$	$=$	$\boxed{100}$		$[\text{deg}]$			
③ Iron in raw water (Ave.)	$Fe_a$	$=$	$\boxed{0}$		$[\text{mg/l}]$			
	$Fe_m$	$=$	$\boxed{0}$		$[\text{mg/l}]$			
④ Alum dosing rate (Ave.)	$\alpha_a$	$=$	$\boxed{30}$		$[\text{mg/l}]$			
	$\alpha_m$	$=$	$\boxed{50}$		$[\text{mg/l}]$			
⑤ Turbidity-SS Conversion factor	$E_1$	$=$	$\boxed{1.0}$		$[-]$			
⑥ Sedimentation (Ave.)	$Cs_a$	$=$	$\boxed{0.5}$		$[\%]$			
	$Cs_m$	$=$	$\boxed{1}$		$[\%]$			
⑦ Wastewater discharged from sand filter	$Q_w$	$=$	$\boxed{197.4}$		$[\text{m}^3]$			

#### 2. Generated solid volume (per one day)

To be calculated as follows:

$$Z = Q \times (Tu \times E_1 + \alpha \times E_2 \times \gamma / 100 + E_3 \times Fe) \times 10^{-3} \quad [\text{kgDS}/\text{day}]$$

Where

$$E_2 : \text{Ratio of Aluminum sulfate to oxidized aluminium} \quad \boxed{0.234}$$

Accordingly

$$\begin{aligned} \text{① Average} \\ Z_{ave} &= \boxed{11,880} \times (\boxed{30} \times \boxed{1.0} + \boxed{30} \times \boxed{0.234}) \times 10^{-3} \quad [\text{kgDS}/\text{day}] \\ &= \boxed{440} \quad [\text{kgDS}/\text{day}] \end{aligned}$$

$$\begin{aligned} \text{② Maximum} \\ Z_{max} &= \boxed{11,880} \times (\boxed{100} \times \boxed{1.0} + \boxed{50} \times \boxed{0.234}) \times 10^{-3} \quad [\text{kgDS}/\text{day}] \\ &= \boxed{1,327} \quad [\text{kgDS}/\text{day}] \end{aligned}$$

#### 3. Sludge discharge volume (per one day)

$$Y_s = Z \times (100 / C_s) \times 10^{-3} \quad [\text{m}^3/\text{day}]$$

$$\text{① Average} \\ Y_s = \boxed{439.8} \times (100 / \boxed{0.5}) \times 10^{-3} = \boxed{88.0} \quad [\text{m}^3/\text{day}]$$

$$\text{② Maximum} \\ Y_s = \boxed{1327.0} \times (100 / \boxed{1}) \times 10^{-3} = \boxed{132.7} \quad [\text{m}^3/\text{day}]$$

## 2. Sludge treatment lagoon

Wastewater discharged in treatment process is from backwash water and sedimentation sludge  
 Backwash water is to be returned to river, and sedimentation sludge is to be treated  
 Sludge is received in lagoon for solid-liquid separation, effluent is discharged to river  
 Thickened sludge is dried to take out for disposal.

## 1. Condition

- ① No. of tank  [tank] (Design Guideline)  
 ② Effective height 0.5m, Allowance 0.3m  
 ③ Surface load  mm/min (Design Guideline : 200~500cm/sec)  
 ④ Ave. velocity in tank  cm/sec (Design Guideline : 2~7cm/sec)

## 2. Receiving Sludge Volume

Discharge flow from sedimentation tank is capable of emptying one tank by  min

$$Q_d = \frac{11.9 \times 11.9 \times 5.7}{90} = 9.0 \rightarrow 9 \text{ [m}^3/\text{min]}$$

## 3. Required surface area

$$A_0 = \frac{9 \times 1000}{200} = 45 \text{ [m}^2\text{]}$$

## 4. Shape and dimension

Rectangular, one side B=  [m]

The other side L=

$$L = \frac{A_0}{B} = \frac{45}{5} = 9.0 \rightarrow 18.0 \text{ [m]}$$

## 5. Average Velocity in Tank

Ave. sludge depth  m

$$V_h = \frac{9.0 \times 100}{5.0 \times (1.0 - 0.5) \times 60} = 6.0 \text{ [cm/sec]}$$

## 6. Days for Retention of Sludge

In Average Turbidity

Sludge contents: % at ave. turbidity

$$\text{Days for retention } N_{ave} = \frac{5.0 \times 18.0 \times 0.5 \times 10 \times 1000}{440 \times 100} = 10.2 \text{ [day]}$$

Accordingly,

days for receiving sludge of ave. turbidity

days for standing, discharge effluent and take away the dry sludge

In Maximum Turbidity

Sludge contents: % of max. turbidity

$$\text{Days for retention } N_{max} = \frac{5.0 \times 18.0 \times 0.5 \times 10 \times 1000}{1327.0 \times 100} = 3.39 \text{ [day]}$$

Accordingly,

days for receiving sludge of max. turbidity

days for standing, discharge effluent and take away the dry sludge

## 5. Summary

- Shape and dimension  [m] ×  [m] × Effective depth  [m]
- No. of tank  [tank]



III. Transmission Facility

## 1. Transmission Pipeline

## 1. Condition

- ① Flow  $Q = \boxed{10,800}$  = 10,800 [m<sup>3</sup>/day] =  $\boxed{0.13}$  [m<sup>3</sup>/sec]  
 ② No. of pipe  $\boxed{1}$  [pipe]  
 ③ Velocity  $\boxed{3}$  [m/sec] or less (Design Guideline for Water Supply Facility)

## 2. Required Diameter

Velocity  $\boxed{1.5}$  [m/sec] is assumed

$$A = Q \div V = \boxed{0.13} \div 1.5 = \boxed{0.087} \text{ [m}^2\text{]}$$

$$\phi = \sqrt{(A \times 4 / \pi)} = \boxed{0.333} \text{ [m]} \rightarrow \text{to be 400mm in considering pipe head loss}$$

## 3. Summary

Diameter	$\phi$ 400 [mm]
No.	$\boxed{1}$ [pipe]
Hydraulic Gradient	$\boxed{3.3}$ [‰]
Velocity	$\boxed{1.1}$ [m/sec]

## 2. Transmission Pump

## 1. Condition

- ① Flow  $Q = \boxed{10,800}$  =  $\boxed{7.50}$  [m<sup>3</sup>/min] =  $\boxed{0.125}$  [m<sup>3</sup>/sec]  
 ② No. of pump  $N = \boxed{4}$  [units] (incl. 1 standby)

## 2. Discharge capacity of one pump

No. of pump  $\boxed{3}$  [units]

$$Q = Q \div N = \boxed{7.5} \div 3.0 = \boxed{2.500} \text{ [m}^3\text{/min]}$$

## 3. Discharge Head

Whereas length of transmission pipeline is approx. 4,400 m

Hazen-Williams Formula

$$\Delta h_1 = 10.666 \cdot C^{-1.85} \cdot D^{-4.87} \cdot Q^{1.85} \cdot L = \boxed{14.53} \text{ [m]}$$

Actual pump head:

$$\Delta h_2 = 511.80 - 456.00 = \boxed{55.80} \text{ [m]}$$

(HWL of service reservoir)

(LWL of clear water reservoir)

Head loss around pump

$$\Delta h_3 = \boxed{5.00} \text{ [m]}$$

Total head required:

$$\Delta H = \Delta h_1 + \Delta h_2 + \Delta h_3 = \boxed{75.33} \text{ [m]}$$

## 4. Summary

Specification	$\boxed{\phi 150}$ [mm] $\times$ $\boxed{2.5}$ [m <sup>3</sup> /min] $\times$ $\boxed{76}$ [m] $\times$ $\boxed{55}$ [kW]
No. of pump	$\boxed{4}$ [units] (incl. 1 standby)

IV. Distribution facility

## 1. Service Reservoir

## 1. Condition

- ① Dist. capacity (Max. day)  $Q = \frac{10,800}{1} = 10,800$  [m<sup>3</sup>/day] =  $\frac{0.13}{1}$  [m<sup>3</sup>/sec]  
 ② Dist. capacity (hour peak)  $Q = \frac{10,800}{2.4} \times 2.4 = 25,920$  [m<sup>3</sup>/day] =  $\frac{0.30}{1}$  [m<sup>3</sup>/sec]  
 ③ Retention time (Reservoir) 12 [hour] or more of max. daily flow (Design Guideline)  
 ④ Retention time (Elev. Tank) 10-30 [min] of hourly peak flow (Design Guideline)

## 2. Capacity of Service Reservoir

Capacity is examined taking into account of power supply condition and economic viewpoint

From hourly distribution flow pattern analysis, approx. 5,000 m<sup>3</sup> is required

20.0 × 32.0 × 4.0m × 2 tanks, Capacity: 5,000m<sup>3</sup>

## 3. Capacity of Elevated Tank

Elevated tank is designed to regulate water pressure in the service areas. In general, it does not intend to regulate changing water flow since it is always kept full capacity.

Required capacity of elevated tank is between 10-30min of the hourly peak flow.

Considering unstability of power supply, etc., 30min is adopted.

Capacity = 25,920 × 30 / 60 = 540m<sup>3</sup>

## 4. Raiser Pipe to Elevated Tank

Velocity  $\frac{2.0}{1}$  [m/sec] is assumed

$$A = Q \div v = \frac{0.30}{2.0} = 0.150 \text{ [m}^2\text{]}$$

$$\phi = \sqrt{A \times 4 / \pi} = 0.437 \text{ [m]} \rightarrow \text{to be 500mm considering pipe head loss}$$

Diameter	$\phi 500$	[mm]
No. of pipe	1.0	[pipe]
Hydraulic Gradient	5.6	[%]
Velocity	1.6	[m/sec]

## 2. Distribution Pump (Lifting Pump)

## 1. Discharge capacity of one pump

No. of pump  $\frac{3}{1}$  [units]

$$Q = Q \div n = \frac{18.0}{3.0} = 6.000 \text{ [m}^3\text{/min]}$$

## 2. Pump Head

Pipe length of raiser pipe to elevated tank. The pipe loss is:

$$\Delta h_1 = I \times L = 0.11 \text{ [m]}$$

Actual head

$$\Delta h_2 = 525.1 - 509.7 = 15.4 \text{ [m]}$$

(HWL of elevated tank)

(LWL of service reservoir)

Head loss around pump

$$\Delta h_3 = 5.00 \text{ [m]}$$

Total head required:

$$\Delta H = \Delta h_1 + \Delta h_2 + \Delta h_3 = 20.51 \text{ [m]}$$


## 3. Summary

Specification  $\frac{\phi 200}{4}$  [mm] ×  $\frac{6.0}{1}$  [m<sup>3</sup>/min] ×  $\frac{21}{1}$  [m] ×  $\frac{37}{1}$  [kW]  
 No. of pump  $\frac{4}{1}$  [unit (incl. 1 standby)]

Hourly Distribution Flow Analysis

	Unit	0-1	1-2	2-3	3-4	4-5	5-6	6-7	7-8	8-9	9-10	10-11	11-12	12-13	13-14	14-15	15-16	16-17	17-18	18-19	19-20	20-21	21-22	22-23	23-24	Total
Transmission	m <sup>3</sup> /h	450	450	450	450	450	450	450	450	450	450	450	450	450	450	450	450	450	450	450	450	450	450	450	450	10,800
Distribution	WTFS							401	802	802	802	802	802	802	802	802	802	802	402							7,620
	PTS						92	195	195	92	92	92	92	92	92	92	195	195	196							
Dist. Total	Leak	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	65	1,560
	Dist. Total	65	65	65	65	65	65	157	661	1,062	959	959	558	959	959	959	1,062	1,062	663	65	65	65	65	65	65	10,800
Required capacity for Service Reservoir	m <sup>3</sup> /h	0	0	0	0	0	0	211	612	509	509	108	509	509	509	612	612	213	0	0	0	0	0	0	0	4,913
Hourly Factor	m <sup>3</sup> /h	0.14	0.14	0.14	0.14	0.14	0.14	1.47	2.36	2.13	2.13	1.24	2.13	2.13	2.13	2.36	2.36	1.47	0.14	0.14	0.14	0.14	0.14	0.14	0.14	

- (N.B.)
1. Operation Hours of Water Tanker Filling Station: 7 : 30~17 : 30, assuming 50% of operating ratio during lunch time
  2. Operation hours of Public Tap Stands: 6 : 30~18 : 00, assuming 50% of operating ratio during lunch time
  3. Time lag caused by water flow in pipelines are not calculated by taking safer side.



From the Above analysis, Capacity of Service Reservoir is to be 5,000 m<sup>3</sup>, Hourly peak factor is to be 2.4

IV. Distribution facility

## 3. Hydraulic Calculation on Distribution Main

## 1. Condition

- ① Dist. capacity (Max. day)  $Q = \frac{10,800}{24} = 450$  [m<sup>3</sup>/day] = 125 [L/sec]  
 ② Dist. capacity (hour peak)  $Q = \frac{10,800}{10} \times 2.4 = 25,920$  [m<sup>3</sup>/day] = 300 [L/sec]  
 ③ HWL of Elev. Tank 525.1 [m]  
 ④ LWL of Elev. Tank 522.5 [m]  
 ⑤ Minimum Operating Pressure 1.5 [bar] (1.0 bar is accepted in high elevation)  
 ⑥ Maximum Operating Pressure 5.0 [bar]  
 ⑦ Maximum Static Pressure 7.5 [bar]

## 2. Water Demand

Ave. daily water consumption per one tap (water tanker filling station) 192 [m<sup>3</sup>/day-tap]  
 ... 8.0 [m<sup>3</sup>/hour-tap]

Water demand of public tap stands to be taken into account for hydraulic calculation

Total base demand 1620 [m<sup>3</sup>/day] / 0.85 (effective rate) / 10 hours = 203 [m<sup>3</sup>/hour]

Assuming one tap of filling station bear equal flow:

203 / 40 taps = 5.1 [m<sup>3</sup>/hour-tap] ... 1.4 [L/sec-tap]

## Base demand by station

For 4 taps: 8.0 x 4 taps / 0.85 (effective rate) = 5.1 x 4 taps = 58.0 [m<sup>3</sup>/hour]  
 ... 16.1 [L/sec]

For 6 taps: 8.0 x 6 taps / 0.85 (effective rate) = 5.1 x 6 taps = 87.1 [m<sup>3</sup>/hour]  
 ... 24.2 [L/sec]


## Peak flow by station

For 4 taps: 16.1 x 2.4 = 38.64 [L/sec]

For 6 taps: 24.2 x 2.4 = 58.08 [L/sec]

Summary of Hydraulic Status at Static Flow (00:00) and Peak Demand (08:00)

	Ground Elevation (+m)	Base Flow [Ave.] [L/sec]	Peak Flow [08:00] [L/sec]	Maximum Head [00:00] (+m)	Statistic Pressure [00:00] (+m)	Head at Peak flow [08:00] (+m)	Min. Op. Pressure [08:00] (+m)
El. Tank	507.5			525.1		525.1	
St. 1	476.0	24.2	58.08	525.1	49.1	508.07	32.1
St. 2	488.0	24.2	58.08	525.1	37.1	515.02	27.0
St. 3	489.0	16.1	38.64	525.1	36.1	511.61	22.6
St. 4	481.0	16.1	38.64	525.1	44.1	504.13	23.1
St. 5	502.0	16.1	38.64	525.1	23.1	511.82	9.8
St. 6	507.0	16.1	38.64	525.1	18.1	516.66	9.7
St. 7	465.0	24.2	58.08	525.1	60.1	497.34	32.3
St. 8	480.0	24.2	58.08	525.1	45.1	499.37	19.4



Network Link at Peak Flow (08:00)

Link ID	Start Node	End Node	Pipe Length (m)	Pipe Diameter (mm)	Peak Flow [08:00] (L/s)	Velocity at peak flow [08:00] (m/s)	Unit Head Loss [08:00] (m/km)	Pipe Head Loss [08:00] (m)
1	Tank	J1	230	500	386.88	2.0	6.61	1.52
2	J1	J2	480	450	193.44	1.2	3.06	1.47
3	J2	S2	1290	250	58.08	1.2	5.79	7.47
4	J2	S3	3450	400	135.36	1.1	2.81	9.69
5	S3	J4	2210	350	96.72	1.0	2.89	6.39
6	J4	S4	570	250	38.64	0.8	2.72	1.55
7	J4	S8	1100	250	58.08	1.2	5.79	6.37
8	J1	J3	400	450	193.44	1.2	3.06	1.22
9	J3	S6	1240	300	77.28	1.1	4.04	5.01
10	S6	S5	1740	250	38.64	0.8	2.72	4.73
11	J3	J5	1070	350	116.16	1.2	4.05	4.33
12	J5	S1	1810	350	116.16	1.2	4.05	7.33
13	S1	S7	1880	250	58.08	1.2	5.79	10.9

## Examination on NPSH of Pump

Net Positive Suction Head (NPSH) of the pump facilities to be designed in the Project are examined as below. As a result, it is confirmed that available suction head (NPSH available) are larger than required suction head (NPSH required).

		Intake pump	Backwash tank lift pump	Transmission pump	Distribution pump (Elevated tank lifting pump)
Type		Single suction	Single suction	Single suction	Double suction
Discharge (m <sup>3</sup> /min)	Q	4.125	3	2.5	5.5
Atmospheric pressure (m) , 460m above sea water level	Pa	9.78			
Saturated vapor pressure (m) water temperature 30°C	Hv	0.43			
Level of pump center (m)		452.9	459.7	459.7	506.8
Lowest level of suction (m)		450.5	456	456	507.5
Suction head (m)	Has	-2.4	-3.7	-3.7	0.7
Pipe loss (m)	Hsl	1	1	1	0.5
NPSH(av)		NPSH(av) = Pa – Hv – Has – Hsl			
		6.0	4.7	4.7	9.5
Pump rotating speed (min-1)	N	1475	1475	1475	1475
Suction specific speed (by manufactures data)	S	1100	1100	1100	1300
NPSH(rq)		NPSH(rq) = (N x Q <sup>0.5</sup> / S) <sup>4/3</sup>			
		3.8	3.1	2.7	2.3
Judge (NPSH(av) > NPSH(rq))		OK	OK	OK	OK

### Water Hammer Analysis of Transmission Pipeline

1. Purpose : To examine water hammer caused by stop of pump operation in transmission pipeline
2. Analysis : Fluid transient phenomenon analysis program by using characteristic curve method
3. Criteria : Allowable minimum pressure -0.058842 MPa

#### 4. Conditions

##### Specification of pumps

- |                        |                                      |
|------------------------|--------------------------------------|
| (1) Type               | : Single suction volute pump         |
| (2) Discharge capacity | : 2.5 m <sup>3</sup> /min            |
| (3) Total head         | : 78m                                |
| (4) Diameter           | : DN 150mm                           |
| (5) Motor              | : 55kW x 415V x 50Hz x 3 phase x 4 P |
| (6) Protection grade   | : IP44                               |
| (7) Isolation grade    | : More than type F                   |
| (8) Starting method    | : Star-Delta                         |
| (9) Flange Rate        | : JIS 10K or equivalent              |

#### 5. Results

As shown in Figure 1.1, column separation is expected without measures. Appropriate protective measures are required, such as:

- Installation of air valves
- Installation of Surge tank
- Installation of Flywheel

Pressure gradients of the cases of air valve and surge tank are shown in Figure 1.2 and 1.3 respectively. As for flywheel installation, it is not applicable since the negative pressure is too large as seen in Figure 1.1

In case of surge tank, it is not recommendable since it costs approx. USD 230,000, which also requires cost for maintenance in future. Therefore, installation of air valves is proposed to prevent column separation.




Figure 1.1 Hydraulic Grade Line without Countermeasure






Figure 1.2 Hydraulic Grade Line After Air Valve Installation




Figure 1.3 Hydraulic Grade Line After Surge Tank Installation



## **Appendix-9 Operation and Maintenance Cost**



### Operation and Maintenance Cost

(Cost in SDG, Price Level of July 2010)

[A] Production Capacity (m <sup>3</sup> /day)	[B] Revenue Water Ratio	[C] Annual Revenue Water (m <sup>3</sup> /year)	O&M Cost (SDG/year)					[K] O&M cost per revenue water (SDG/m <sup>3</sup> )  (USD0.38)		
			[D] Personnel	[E] Electricity	[F] Chemical	[G] Spareparts	[H] Staff Training		[I] Others	[J] Total
10,800	80%	3,153,600	1,199,160 (45%)	755,638 (28%)	485,713 (18%)	56,297 (2%)	59,958 (2%)	127,838 (5%)	2,684,604 (USD1,214,753)	0.85 (USD0.38)

[A] Production Capacity 10,800m<sup>3</sup>/day as incremental by the Project

[B] Revenue Water Ratio: Assumed to be 80%, i.e. NRW ratio to be 20% (Physical loss: 15%, Revenue collection ratio: 95%)

[C] Annual Revenue Water: [A: Production capacity] / 1.0 (max. daily factor) x [B: Revenue water ratio] x 365

[D] Personnel cost: Refer to attached "[D] O&M Cost: Personnel"

[E] Electricity cost: Refer to attached "[E] O&M Cost: Electricity"

[F] Chemical cost: Refer to attached "[F] O&M Cost: Chemical"

[G] Spareparts cost: Refer to attached "[G] O&M Cost: Spare parts"

[H] Staff training: 5% of [D: personnel cost] is assumed

[I] Others: 5% of total of ([D]+[E]+[F]+[G]+[H]) is assumed

[J] O&M cost per revenue water: [J: Total O&M cost] / [C: annual revenue water]

**[D] O&M Cost: Personnel**

			Year	2009 (Existing System)	2015
[1]	Production Capacity	m <sup>3</sup> /day	Existing: 7,200 m <sup>3</sup> /day, Proposed: 10,800 m <sup>3</sup> /day	7,200	18,000
[2]	No. House Connection	nos	2009: actual record of UWC (CES) Juba, Same number assumed in 2015	2,451	2,451
[3]	No. Non-Dom. Connect	nos	2009: actual record of UWC (CES) Juba, Same number assumed in 2015	228	228
[4]	No. Public Tap	nos	Existing:38, Proposed Tap Stands (Project): 120, Proposed Station (Project): 40	38	198
[5]	Total Connection	nos	Total of [1]+[2]+[3]+[4]	2,717	2,877
[6]	Staff Efficiency	staff per 1000 connection	2009: calculation [7: staff no.] / [5: connection] 2015: assumed to be 60	60	60
[7]	Est. Total Staff No.	persons	2009: actual number 2015: est. [5: connection] x [6: efficiency] / 1000	164	173
[8]	No of Managers	persons	2009: estimated from organization chart 2012-2015: assumed annual increase rate of 3%	6	7
[9]	No of Chief	persons	2009: estimated from organization chart 2012-2015: assumed annual increase rate of 3%	15	18
[10]	No of Staff	persons	2009: estimated from organization chart 2012-2015: assumed annual increase rate of 3%	100	119
[11]	No of Workers	persons	2009: estimated from organization chart 2012-2015: [7: total] - ([8]+[9]+[10])	46	29
[12]	Monthly salary (Manager)	SDG/month	2009: average salary estimated 2012-2015: annual growth of 3% is assumed	1,200	1,430
[13]	Monthly salary (Chief)	SDG/month	2009: average salary estimated 2012-2015: annual growth of 3% is assumed	1,000	1,190
[14]	Monthly salary (Staff)	SDG/month	2009: average salary estimated 2012-2015: annual growth of 3% is assumed	800	960
[15]	Monthly salary (Worker)	SDG/month	2009: average salary estimated 2012-2015: annual growth of 3% is assumed	600	720
[16]	Personnel cost (Manager)	SDG/year	[8] x [12] x 12	86,400	120,120
[17]	Personnel cost (Chief)	SDG/year	[9] x [13] x 12	180,000	257,040
[18]	Personnel cost (Staff)	SDG/year	[10] x [14] x 12	960,000	1,370,880
[19]	Personnel cost (Worker)	SDG/year	[11] x [15] x 12	331,200	250,560
[20]	Personnel cost (Total in SDG)	SDG/year	Total ([16]+[17]+[18]+[19])	1,557,600	1,998,600
[21]	Cost to be borne by the Project	SDG/year	[20] x 10800 / (10800+7200) Assumed that personnel cost distributed in proportion to production capacity	N/A	1,199,160

**[E] O&M Cost: Electricity**

	[1] Power output (kW)	[2] Average daily operation hours (hours/day)	[3] Power consumption (kWh)	[4] Unit power cost (SDG/kWh)	[5] Power cost (SDG)
[E-1] Intake Pump (New WTP)			[1] x [2] / 1.0 x 0.8 x 365	Price as of 2009	[3] x [4]
[E-2] Transmission Pump (New)	44	24	308,352	0.500	154,176
[E-3] Others (New WTP)	110	24	770,880	0.500	385,440
[E-4] Lifting Pump (Service)	111	10	107,923	0.500	53,962
			324,120	0.500	162,060
			Total [E]		755,638

(Note) [4]: Unit power cost as of July 2010

**[F] O&M Cost: Chemical**

	[1] Average daily flow (m <sup>3</sup> /day)	[2] Dosing rate (mg/L)	[3] Dosage (kg/day)	[4] Unit price (SDG/kg)	[5] Annual chemical cost (SDG)
[F-1] Aluminum Sulphate	11,800	30	[1] x [2] / 1000		[3] x [4] x 365
[F-2] Chlorine	10,800	3	354	3.120	403,135
			32	7.070	82,578
			Total [F]		485,713

(Note) [4]: Unit price as of July 2010

**[G] O&M Cost: Spareparts**

	[1] Electrical & Mechanical Equipment Cost (USD)	[2] Ratio of maintenance cost	[3] Maintenance Cost (SDG)
[G-1] Proposed WTP	3,670,000	3%	[1] x [2] / 2.26
[G-2] Proposed Service Reservoir	571,000	3%	48,717
			7,580
		Total [G]	56,297

(Note) [1]: Electrical and mechanical equipment cost, provisional estimation by the Team



