


SECTION C1: Calculation Sheets of Mechanical Equipment

C1.1 Calculation Sheets of Pumping Stations

Kanudi Pumping Station (PS-01)



Design Condition

1) Design Flow

Qadf : Daily average flow
 Qpdf : Peak flow (Ultimate) $Qpdf = 2.0 \times Qadf$

2) Type of Pumping Station

Type A Submersible station
 Basket Installed


3) Pump Number and capacity

Pump number : 1 duty + 1 standby

4) Force Main

Material : HDPE
 Diameter : Dia.110 mm
 Line number: 1 line

5) Outline (Assume)



Lifting Pump Calculation Sheet (PS-01)


ITEM	SYMBOL	DESIGN
1.1 Pump Sump Well		
Pump starts per hour	n	Motor 5.5kW < 7.5kW (F.W.) 4 times
Pump capacity	Q	6.0 L/sec/unit
Required volume	v	= 900 × Q / n/1000 ≥ 1.35 m ³
Sump Well square	A	4.90 m ² Dia. 2.5m
<p>Water Level in the Sump Well</p>		
1.2 Lift Pump		
Design flow	Qpdf	0.36 m ³ /min = 6.0 L/sec
Duty pump number		1 unit
Design flow per unit		Considered pipe velocity > 0.6m/s 6.0 L/sec/unit
Specification		
Type		Submersible non-clog sewage pump, automatic coupling type
Dia.	D	Approx. 100 mm
Capacity	Qp	6.0 L/sec/unit = 0.36 m ³ /min/unit
Total head	H	attached Table Pump calculation sheet 14.0 m
Motor	P	attached Table Pump calculation sheet approx. 5.5 kW
Number		Duty 1 unit Standby 1 unit Total 2 units
1.3 Monorail Hoist		
Weight of pump	W	Approx. 0.20 Tonf
Required hoist capacity	hc	W × 1.5 ≥ 0.30 Tonf
Specification		
Type		Manually Geared trolley
Capacity		Approx. 0.5 Tonf
Lift		Approx. 3.0 m
Number		Duty 1 unit Standby 0 unit Total 1 unit

Lifting Pump Calculation Sheet (PS-01)

1	Equip. No.	M01-001-01/02			
	Pump Name	Lifting Pump-1			
2	Pump Type	Submersible	Submersible		
3	q : Capacity (m³/min)	0.36	0.36		
4	N : Operation number	1	1		
	Pump	6.0L/s	6.0L/s		
	Pump Number	1D + 1S	1D + 1S		
	Total Head H=ha+hf1+hf2+hf3+hf4				
5	ha : Actual head (m) =DWL-SWL	2.7	1.3		
6	DWL (m)	1.100	-0.300		
7	SWL (m)	-1.600	-1.600		
8	hf1 : Straight pipe loss (m) = $\frac{(10.666 \times Q^{1.85}) \times L \times Cc}{(C^{1.85} \times D^{4.87})}$	6.031	9.812		
9	Q : Flow (m ³ /sec) =q × N/60	0.006	0.006		
10	C : Coefficient	130	130		
		0.11m × 1 line	0.11m × 1 line		
11	D : Inner Pipe Dia. (m)	0.0964	0.0964		
12	L : Pipe length (m)	670	1090		
13	Cc : Correction coefficient Water: 1.0 Sludge: WT99.2% :	1.0	1.0		
14	hf2	0.000	0.000		
15	hf3 : Pump around loss (m)	2	2		
16	hf4 : Other head	0	0		
17	H' =ha+hf1+hf2+hf3+hf4 (m)	10.73	13.11		
18	H : Total head (m)	11.0	14.0		
	Velocity	0.82	0.82		
	Motor Power				
19	BKW =0.163*SG*q*H/Pe (kW)	2.152	2.738		
20	SG : Specific gravity	1.0	1.0		
21	Pe : Pump efficiency	0.3	0.3		
22	kW =BKW × C	2.474	3.149		
23	C : Coefficient (1.15)	1.15	1.15		
24	Motor Power (kW)		5.5		

(adoption)

Idubada Pumping Station (PS-02)



Design Condition

1) Design Flow

Qadf : Daily average flow
 Qpdf : Peak flow (Ultimate) $Qpdf = 2.0 \times Qadf$

2) Type of Pumping Station

Type A Submersible station
 Basket Installed


3) Pump Number and capacity

Pump number : 1 duty + 1 standby

4) Force Main

Material : HDPE
 Diameter : Dia.110 mm
 Line number: 1 line

5) Outline (Assume)



Lifting Pump Calculation Sheet (PS-02)

ITEM	SYMBOL	DESIGN
2.1 Pump Sump Well		
Required cycle time	n	Motor = 22kW (F.W.) 4 times
Pump capacity	Q	10.80 L/sec/unit
Required volume	v	= 900 × Q / n/1000 ≥ 2.4 m ³
Sump Well square	A	4.90 m ² Dia. 2.5m
Water Level in the Sump Well		
2.2 Lift Pump		
Duty pump number		1 unit
Design flow per unit		10.8 L/sec/unit
Specification		
Type		Submersible non-clog sewage pump, automatic coupling type
Dia.	D	Approx. 100 mm
Capacity	Qp	10.8 L/sec/unit = 0.65 m ³ /min/unit
Total head	H	attached Table Pump calculation sheet 40.0 m
Motor	P	attached Table Pump calculation sheet approx. 22.0 kW
Number		Duty 1 unit Standby 1 unit Total 2 units
2.3 Monorail Hoist		
Weight of pump	W	Approx. 0.50 Tonf
Required hoist capacity	hc	W × 1.5 ≥ 0.75 Tonf
Specification		
Type		Manually Geared trolley
Capacity		Approx. 1.0 Tonf
Lift		Approx. 3.0 m
Number		Duty 1 unit Standby 0 unit Total 1 unit


Lifting Pump Calculation Sheet (PS-02)

1	Equip. No.	M01-002-01/02			
	Pump Name	Lifting Pump-2			
2	Pump Type	Submersible	Submersible		
3	q : Capacity (m ³ /min)	0.65	0.65		
4	N : Operation number	1	1		
	Pump	10.8L/s	10.8L/s		
	Pump Number	1D + 1S	1D + 1S		
	Total Head H=ha+hf1+hf2+hf3+hf4				
5	ha : Actual head (m) =DWL-SWL	4.2	18.2		
6	DWL (m)	0.200	14.200		
7	SWL (m)	-4.000	-4.000		
8	hf1 : Straight pipe loss (m) = $(10.666 \times Q^{1.85}) \times L \times Cc$ $(C^{1.85} \times D^{4.87})$	24.977	18.370		
9	Q : Flow (m ³ /sec) =q × N/60	0.011	0.011		
10	C : Coefficient	130	130		
		0.11m × 1 line	0.11m × 1 line		
11	D : Inner Pipe Dia. (m)	0.0964	0.0964		
12	L : Pipe length (m)	930	684		
13	Cc : Correction coefficient Water: 1.0 Sludge: WT99.2% :	1.0	1.0		
14	hf2	0.000	0.000		
15	hf3 : Pump around loss (m)	2	2		
16	hf4 : Other head	0	0		
17	H' =ha+hf1+hf2+hf3+hf4 (m)	31.18	38.57		
18	H : Total head (m)	30.0	40.0		
	Velocity	1.49	1.49		
	Motor Power				
19	BKW =0.163*SG*q*H/Pe (kW)	10.595	14.127		
20	SG : Specific gravity	1.0	1.0		
21	Pe : Pump efficiency	0.3	0.3		
22	kW =BKW × C	12.184	16.246		
23	C : Coefficient (1.15)	1.15	1.15		
24	Motor Power (kW)		22		

(adoption)

Hagara Pumping Station (PS-03)

---> Gravity
 —> Force main



Design Condition

1) Design Flow

Qadf : Daily average flow
 Qpdf : Peak flow (Ultimate) $Qpdf = 2.0 \times Qadf$

2) Type of Pumping Station

Type A Submersible station
 Basket Installed


3) Pump Number and capacity

Pump number : 1 duty + 1 standby

4) Force Main

Material : HDPE
 Diameter : Dia.225 mm
 Line number: 1 line

5) Outline (Assume)



Lifting Pump Calculation Sheet (PS-03)

ITEM	SYMBOL	DESIGN
3.1 Pump Sump Well		
Required cycle time	n	Motor =22kW (F.W.) 4 times
Pump capacity	Q	31.6 L/sec/unit
Required volume	v	= 900 × Q / n/1000 ≥ 7.1 m ³
Sump Well square	A	4.90 m ² Dia. 2.5m
<p>Water Level in the Sump Well</p>		
3.2 Lift Pump		
Duty pump number		1 unit
Design flow per unit		31.6 L/sec/unit
Specification		
Type		Submersible non-clog sewage pump, automatic coupling type
Dia.	D	Approx. 100 mm
Capacity	Qp	31.6 L/sec/unit
		= 1.9 m ³ /min/unit
Total head	H	attached Table Pump calculation sheet 25.0 m
Motor	P	attached Table Pump calculation sheet approx. 22.0 kW
Number		Duty 1 unit
		Standby 1 unit
		Total 2 units
3.3 Monorail Hoist		
Weight of pump	W	Approx. 0.50 Tonf
Required hoist capacity	hc	W × 1.5 ≥ 0.75 Tonf
Specification		
Type		Manually Geared trolley
Capacity		Approx. 1.0 Tonf
Lift		Approx. 3.0 m
Number		Duty 1 unit
		Standby 0 unit
		Total 1 unit


Lifting Pump Calculation Sheet (PS-03)

1	Equip. No.	M01-003-01/02			
	Pump Name	Lifting Pump-3			
2	Pump Type	Submersible	Submersible		
3	q : Capacity (m ³ /min)	1.9	1.9		
4	N : Operation number	1	1		
	Pump	31.6L/s	31.6L/s		
	Pump Number	1D + 1S	1D + 1S		
	Total Head H=ha+hf1+hf2+hf3+hf4				
5	ha : Actual head (m) =DWL-SWL	20.0	11.2		
6	DWL (m)	18.000	9.200		
7	SWL (m)	-2.000	-2.000		
8	hf1 : Straight pipe loss (m) = $\frac{(10.666 \times Q^{1.85}) \times L \times Cc}{(C^{1.85} \times D^{4.87})}$	2.104	4.742		
9	Q : Flow (m ³ /sec) =q × N/60	0.032	0.032		
10	C : Coefficient	130	130		
		0.225m × 1 lin	0.225m × 1 line		
11	D : Inner Pipe Dia. (m)	0.1976	0.1976		
12	L : Pipe length (m)	355	800		
13	Cc : Correction coefficient Water: 1.0 Sludge: WT99.2% :	1.0	1.0		
14	hf2	0.000	0.000		
15	hf3 : Pump around loss (m)	2	2		
16	hf4 : Other head	0	0		
17	H' =ha+hf1+hf2+hf3+hf4 (m)	24.10	17.94		
18	H : Total head (m)	25.0	18.0		
	Velocity	1.03	1.03		
	Motor Power				
19	BKW =0.163*SG*q*H/Pe (kW)	15.485	11.149		
20	SG : Specific gravity	1.0	1.0		
21	Pe : Pump efficiency	0.5	0.5		
22	kW =BKW × C	17.808	12.822		
23	C : Coefficient (1.15)	1.15	1.15		
24	Motor Power (kW)	22			

(adoption)

Hanuabada Pumping Station (PS-04)

---> Gravity
 —> Force main



Design Condition

1) Design Flow

Qadf : Daily average flow
 Qpdf : Peak flow (Ultimate) $Qpdf = 2.0 \times Qadf$

2) Type of Pumping Station

Type B Submersible station
 Basket Installed


3) Pump Number and capacity

Pump number : 1 duty + 1 standby

4) Force Main

Material : HDPE
 Diameter : Dia.355 mm
 Line number: 1 line

5) Outline (Assume)



Lifting Pump Calculation Sheet (PS-04)


ITEM	SYMBOL	DESIGN
4.1 Pump Sump Well		
Required cycle time	n	Motor = 22kW (F.W.) 4 times
Pump capacity	Q	80.0 L/sec/unit
Required volume	v	$= 900 \times Q / n / 1000$ $\geq 18.0 \text{ m}^3$
Sump Well square	A	12.00 m^2 4.0m x 3.0m
<p>Water Level in the Sump Well</p>		
4.2 Lift Pump		
Duty pump number		1 unit
Design flow per unit		63.3 L/sec/unit
Specification		
Type		Submersible non-clog sewage pump, automatic coupling type
Dia.	D	Approx. 200 mm
Capacity	Qp	80.0 L/sec/unit
		= 4.8 m ³ /min/unit
Total head	H	attached Table Pump calculation sheet 17.0 m
Motor	P	attached Table Pump calculation sheet approx. 22.0 kW
Number		Duty 1 unit
		Standby 1 unit
		Total 2 units
4.3 Monorail Hoist		
Weight of pump	W	Approx. 1.00 Tonf
Required hoist capacity	hc	$W \times 1.5$ $\geq 1.50 \text{ Tonf}$
Specification		
Type		Manually Geared trolley
Capacity		Approx. 2.0 Tonf
Lift		Approx. 3.0 m
Number		Duty 1 unit
		Standby 0 unit
		Total 1 unit

Lifting Pump Calculation Sheet (PS-04)

1	Equip. No.	M01-004-01/02			
	Pump Name	Lifting Pump-4			
2	Pump Type	Submersible	Submersible		
3	q : Capacity (m ³ /min)	4.8	4.8		
4	N : Operation number	1	1		
	Pump	80.0 L/s	80.0 L/s		
	Pump Number	1D + 1S	1D + 1S		
	Total Head H=ha+hf1+hf2+hf3+hf4				
5	ha : Actual head (m) =DWL-SWL	3.7	12.1		
6	DWL (m)	0.000	8.400		
7	SWL (m)	-3.700	-3.700		
8	hf1 : Straight pipe loss (m) = $(10.666 \times Q^{1.85}) \times L \times Cc$ $(C^{1.85} \times D^{4.87})$	4.859	1.577		
9	Q : Flow (m ³ /sec) =q × N/60	0.080	0.080		
10	C : Coefficient	130	130		
		0.355m × 1 lin	0.355m × 1 line		
11	D : Inner Pipe Dia. (m)	0.312	0.312		
12	L : Pipe length (m)	1365	443		
13	Cc : Correction coefficient Water: 1.0 Sludge: WT99.2% :	1.0	1.0		
14	hf2	0.000	0.000		
15	hf3 : Pump around loss (m)	2	2		
16	hf4 : Other head	0	0		
17	H' =ha+hf1+hf2+hf3+hf4 (m)	10.56	15.68		
18	H : Total head (m)	12.0	17.0		
	Velocity	1.05	1.05		
	Motor Power				
19	BKW =0.163*SG*q*H/Pe (kW)	13.413	19.001		
20	SG : Specific gravity	1.0	1.0		
21	Pe : Pump efficiency	0.7	0.7		
22	kW =BKW × C	15.424	21.851		
23	C : Coefficient (1.15)	1.15	1.15		
24	Motor Power (kW)		22		

(adoption)

Konedobu Pumping Station (PS-05)



Design Condition

1) Design Flow

Q_{adf} : Daily average flow
 Q_{pdf} : Peak flow (Ultimate) $Q_{pdf} = 2.0 \times Q_{adf}$

2) Type of Pumping Station

Type C Submersible station
 Basket Installed


3) Pump Number and capacity

Pump number : 2 duty + 1 standby

4) Force Main

Material : HDPE
 Diameter : Dia.450 mm
 Line number: 1 line

5) Outline (Assume)



Lifting Pump Calculation Sheet (PS-05)


ITEM	SYMBOL	DESIGN
5.1 Pump Sump Well (Existing)		
Existing Sump Well can not be available because Inlet pipe bottom level is much lower than required water depth.		
Required cycle time	n	Motor 55kW < 75kW (F.W.) 4 times
Pump capacity	Q	73.3 L/sec/unit
Required volume	v = 900 × Q / n/1000	≥ 16.5 m ³
Sump Well square	A	11.33 m ² Dia.3.8m
Water Level in the Sump Well		
New Sump Well will be installed.		
Required cycle time	n	Motor 55kW < 75kW (F.W.) 4 times
Pump capacity	Q	73.3 L/sec/unit
Required volume	v = 900 × Q / n/1000	≥ 16.5 m ³
Sump Well square	A	15.75 m ² 4.5m × 3.5m
Water Level in the Sump Well		
5.2 Lift Pump		
Duty pump number		2 units
Design flow per unit		73.3 L/sec/unit
Specification		
Type	D	Submersible non-clog sewage pump, automatic coupling type
Dia.	Qp	Approx. 200 mm
Capacity		73.3 L/sec/unit = 4.4 m ³ /min/unit
Total head	H	attached Table Pump calculation sheet 42.0 m
Motor	P	attached Table Pump calculation sheet approx. 55.0 kW
Number		Duty 2 units Standby 1 unit Stock 1 unit Total 4 units
5.3 Monorail Hoist		
Weight of pump	W	Approx. 1.60 Tonf
Required hoist capacity	hc	W × 1.5 ≥ 2.40 Tonf
Specification		
Type		Manually Geared trolley
Capacity		2.5 Tonf
Lift		Approx. 3.0 m
Number		Duty 1 unit Standby 0 unit Total 1 unit

Lifting Pump Calculation Sheet (PS-05)

1	Equip. No.	M01-005-01/04	1 pump operation	
	Pump Name	Lifting Pump-5	100%	120%
2	Pump Type	Submersible		
3	q : Capacity (m ³ /min)	4.4	4.4	5.28
4	N : Operation number	2	1	1
	Pump	73.3L/s		
	Pump Number	2D + 1S		
	Total Head H=ha+hf1+hf2+hf3+hf4			
5	ha : Actual head (m) =DWL-SWL	34.2	34.2	34.2
6	DWL (m)	28.500	28.500	28.500
7	SWL (m)	-5.700	-5.700	-5.700
8	hf1 : Straight pipe loss (m) = $(10.666 \times Q^{1.85}) \times L \times Cc$ $(C^{1.85} \times D^{4.87})$	4.607	1.278	1.790
9	Q : Flow (m ³ /sec) =q × N/60	0.147	0.073	0.088
10	C : Coefficient	130	130	130
		0.45m × 1 line	0.45m × 1 line	0.45m × 1 line
11	D : Inner Pipe Dia. (m)	0.3956	0.3956	0.3956
12	L : Pipe length (m)	1340	1340	1340
13	Cc : Correction coefficient Water: 1.0 Sludge: WT99.2% :	1.0	1.0	1.0
14	hf2	0.000	0.000	0.000
15	hf3 : Pump around loss (m)	2	2	2
16	hf4 : Other head	0	0	0
17	H' =ha+hf1+hf2+hf3+hf4 (m)	40.81	37.48	37.99
18	H : Total head (m)	42.0		
	Velocity	1.19	0.60	0.72
				> 0.60 m/sec
	Motor Power			
19	BKW =0.163*SG*q*H/Pe (kW)	46.342		
20	SG : Specific gravity	1.0		
21	Pe : Pump efficiency	0.65		
22	kW =BKW × C	53.293		
23	C : Coefficient (1.15)	1.15		
24	Motor Power (kW)	55		

Old Yacht Club Pumping Station (PS-06) Rehabilitation

---> Gravity
 —> Force main



Design Condition

1) Design Flow

Q_{adf} : Daily average flow
 Q_{pdf} : Peak flow (Ultimate) $Q_{pdf} = 2.0 \times Q_{adf}$

2) Type of Pumping Station

Circular type Existing Submersible station
 Basket Not Installed


3) Pump Number and capacity

Pump number : 1 duty + 1 standby

4) Force Main

Material : DCIP (Existing Pipe)
 Diameter : Dia.150 mm
 Line number: 1 line

5) Outline (Assume)




Lifting Pump Calculation Sheet (PS-06)

ITEM	SYMBOL	DESIGN
6.1 Pump Sump Well (Rehabilitation)		
Required cycle time	n	Motor 5.5kW < 7.5kW 10 times
Pump capacity	Q	10.80 L/sec/unit
Required volume	v	$= 900 \times Q / n/1000$ \geq 1.0 m ³
Sump Well square	A	2.83 m ² Dia. 1.9m
Water Level in the Sump Well		
Inlet pipe bottom level (Existing)		
6.2 Lift Pump		
Design flow	Qpdf	0.65 m ³ /min = 10.8 L/sec
Duty pump number		1 unit
Design flow per unit		10.8 L/sec/unit
Considered pipe velocity > 0.6m/s (Existing Pipe Available)		
Specification		
Type		Submersible non-clog sewage pump, automatic coupling type
Dia.	D	Approx. 100 mm
Capacity	Qp	10.8 L/sec/unit = 0.65 m ³ /min/unit
Total head	H	attached Table Pump calculation sheet 17.0 m
Motor	P	attached Table Pump calculation sheet approx. 5.5 kW
Number		Duty 1 unit Standby 1 unit Total 2 units
6.3 Monorail Hoist		
Weight of pump	W	Approx. 0.10 Tonf
Required hoist capacity	hc	$W \times 1.5$ \geq 0.15 Tonf
Specification		
Type		Manually Geared trolley
Capacity		Approx. 0.5 Tonf
Lift		Approx. 3.0 m
Number		Duty 1 unit Standby 0 unit Total 1 unit

Lifting Pump Calculation Sheet (PS-06)

1	Equip. No.	M01-006-01/02			
	Pump Name	Lifting Pump-6			
2	Pump Type	Submersible			
3	q : Capacity (m³/min)	0.65			
4	N : Operation number	1			
	Pump	10.8L/s			
	Pump Number	1D + 1S			
	Total Head H=ha+hf1+hf2+hf3+hf4				
5	ha : Actual head (m) =DWL-SWL	10.5			
6	DWL (m)	10.000			
7	SWL (m)	-0.500			
8	hf1 : Straight pipe loss (m) = $\frac{(10.666 \times Q^{1.85}) \times L \times Cc}{(C^{1.85} \times D^{4.87})}$	3.063			
9	Q : Flow (m ³ /sec) =q × N/60	0.011			
10	C : Coefficient	80			
		Existing DIP Pipe			
		0.15m × 1 line			
11	D : Inner Pipe Dia. (m)	0.15			
12	L : Pipe length (m)	400			
13	Cc : Correction coefficient Water: 1.0 Sludge: WT99.2% :	1.0			
14	hf2	0.000			
15	hf3 : Pump around loss (m)	2			
16	hf4 : Other head	0			
17	H' =ha+hf1+hf2+hf3+hf4 (m)	15.56			
18	H : Total head (m)	17.0			
	Velocity	0.61			
	Motor Power				
19	BKW =0.163*SG*q*H/Pe (kW)	4.503			
20	SG : Specific gravity	1.0			
21	Pe : Pump efficiency	0.4			
22	kW =BKW × C	5.178			
23	C : Coefficient (1.15)	1.15			
24	Motor Power (kW)	5.5			

Stanley Esplanade Pumping Station (PS-07) Rehabilitation



Design Condition

1) Design Flow

Q_{adf} : Daily average flow
 Q_{pdf} : Peak flow (Ultimate) $Q_{pdf} = 2.0 \times Q_{adf}$

2) Type of Pumping Station

Circular type Existing Submersible station
 Basket Not installed


3) Pump Number and capacity

Pump number : 1 duty + 1 standby

4) Force Main

Material : HDPE
 Diameter : Dia.160 mm
 Line number: 1 line

5) Outline (Assume)



Lifting Pump Calculation Sheet (PS-07)

ITEM	SYMBOL	DESIGN
7.1 Pump Sump Well (Rehabilitation)		
Required cycle time	n	Motor 15kW < 22kW 4 times
Pump capacity	Q	23.3 L/sec/unit
Required volume	v	= 900 × Q / n/1000 ≥ 5.2 m ³
Sump Well square	A	11.33 m ² Dia. 3.8m
<p style="text-align: center;">Water Level in the Sump Well</p>		
<p>$V > 3.5\text{m}^3$ $h = 0.5\text{m} \geq 0.46\text{m}$ $h = 0.55\text{m}$ Manufacturer recommendation (approx. 0.35m)</p>		
7.2 Lift Pump		
Duty pump number		1 unit
Design flow per unit		23.3 L/sec/unit
Specification		
Type		Submersible non-clog sewage pump, automatic coupling type
Dia.	D	Approx. 100 mm
Capacity	Qp	23.3 L/sec/unit = 1.4 m ³ /min/unit
Total head	H	attached Table Pump calculation sheet 24.0 m
Motor	P	attached Table Pump calculation sheet approx. 15.0 kW
Number		Duty 1 unit Standby 1 unit Total 2 units
7.3 Monorail Hoist		
Weight of pump	W	Approx. 0.45 Tonf
Required hoist capacity	hc	W × 1.5 ≥ 0.68 Tonf
Specification		
Type		Manually Geared trolley
Capacity		Approx. 1.0 Tonf
Lift		Approx. 3.0 m
Number		Duty 1 unit Standby 0 unit Total 1 unit


Lifting Pump Calculation Sheet (PS-07)

1	Equip. No.	M01-007-01/02			
	Pump Name	Lifting Pump-7			
2	Pump Type	Submersible	Submersible		
3	q : Capacity (m ³ /min)	1.4	1.4		
4	N : Operation number	1	1		
	Pump	23.3L/s	23.3L/s		
	Pump Number	1D + 1S	1D + 1S		
	Total Head H=ha+hf1+hf2+hf3+hf4				
5	ha : Actual head (m) =DWL-SWL	17.5	3.9		
6	DWL (m)	15.600	2.000		
7	SWL (m)	-1.900	-1.900		
8	hf1 : Straight pipe loss (m) = $\frac{(10.666 \times Q^{1.85}) \times L \times Cc}{(C^{1.85} \times D^{4.87})}$	4.241	7.422		
9	Q : Flow (m ³ /sec) =q × N/60	0.023	0.023		
10	C : Coefficient	130	130		
		0.16m × 1 line	0.16m × 1 line		
11	D : Inner Pipe Dia. (m)	0.1406	0.1406		
12	L : Pipe length (m)	240	420		
13	Cc : Correction coefficient Water: 1.0 Sludge: WT99.2% :	1.0	1.0		
14	hf2	0.000	0.000		
15	hf3 : Pump around loss (m)	2	2		
16	hf4 : Other head	0	0		
17	H' =ha+hf1+hf2+hf3+hf4 (m)	23.74	13.32		
18	H : Total head (m)	24.0	14.0		
	Velocity	1.50	1.50		
	Motor Power				
19	BKW =0.163*SG*q*H/Pe (kW)	10.954	6.390		
20	SG : Specific gravity	1.0	1.0		
21	Pe : Pump efficiency	0.5	0.5		
22	kW =BKW × C	12.597	7.348		
23	C : Coefficient (1.15)	1.15	1.15		
24	Motor Power (kW)	15			

(adoption)

Sea Park Pumping Station (PS-08)

Rehabilitation



Design Condition

1) Design Flow


Q_{adf} : Daily average flow
 Q_{pdf} : Peak flow (Ultimate) $Q_{pdf} = 2.0 \times Q_{adf}$

2) Type of Pumping Station
 Rectangular type , Existing Submersible station
 Basket Not installed

3) Pump Number and capacity
 Pump number : 1 duty + 1 standby

4) Force Main
 Material : HDPE
 Diameter : Dia.110 mm
 Line number: 1 line

5) Outline (Assume)



Lifting Pump Calculation Sheet (PS-08)


ITEM	SYMBOL	DESIGN
8.1 Pump Sump Well(Rehabilitation)		
Required cycle time	n	Motor = 7.5kW (F.W.) 4 times
Pump capacity	Q	10.0 L/sec/unit
Required volume	v	$= 900 \times Q / n/1000$ \geq 2.3 m ³
Sump Well square	A	11.50 m ² 3.5m x 3.3m
<p style="text-align: center;">Water Level in the Sump Well</p>		
8.2 Lift Pump		
Duty pump number		1 unit
Design flow per unit		10.0 L/sec/unit
Specification		
Type		Submersible non-clog sewage pump, automatic coupling type
Dia.	D	Approx. 100 mm
Capacity	Qp	10.0 L/sec/unit = 0.60 m ³ /min/unit
Total head	H	attached Table Pump calculation sheet 24.0 m
Motor	P	attached Table Pump calculation sheet approx. 7.5 kW
Number		Duty 1 unit Standby 1 unit Total 2 units
8.3 Monorail Hoist		
Weight of pump	W	Approx. 0.20 Tonf
Required hoist capacity	hc	$W \times 1.5$ \geq 0.30 Tonf
Specification		
Type		Manually Geared trolley
Capacity		Approx. 0.5 Tonf
Lift		Approx. 3.0 m
Number		Duty 1 unit Standby 0 unit Total 1 unit

Lifting Pump Calculation Sheet (PS-08)

1	Equip. No.	M01-008-01/02			
	Pump Name	Lifting Pump-8			
2	Pump Type	Submersible	Submersible		
3	q : Capacity (m ³ /min)	0.6	0.6		
4	N : Operation number	1	1		
	Pump	10.0L/s	10.0L/s		
	Pump Number	1D + 1S	1D + 1S		
	Total Head H=ha+hf1+hf2+hf3+hf4				
5	ha : Actual head (m) =DWL-SWL	5.6	6.0		
6	DWL (m)	2.100	2.500		
7	SWL (m)	-3.500	-3.500		
8	hf1 : Straight pipe loss (m) = $(10.666 \times Q^{1.85}) \times L \times Cc$ $(C^{1.85} \times D^{4.87})$	14.823	12.275		
9	Q : Flow (m ³ /sec) =q × N/60	0.010	0.010		
10	C : Coefficient	130	130		
		0.11m × 1 line	0.11m × 1 line		
11	D : Inner Pipe Dia. (m)	0.0964	0.0964		
12	L : Pipe length (m)	640	530		
13	Cc : Correction coefficient Water: 1.0 Sludge: WT99.2% :	1.0	1.0		
14	hf2	0.000	0.000		
15	hf3 : Pump around loss (m)	2	2		
16	hf4 : Other head	0	0		
17	H' =ha+hf1+hf2+hf3+hf4 (m)	22.42	20.28		
18	H : Total head (m)	24.0	21.0		
	Velocity	1.37	1.37		
	Motor Power				
19	BKW =0.163*SG*q*H/Pe (kW)	5.868	5.135		
20	SG : Specific gravity	1.0	1.0		
21	Pe : Pump efficiency	0.4	0.4		
22	kW =BKW × C	6.748	5.905		
23	C : Coefficient (1.15)	1.15	1.15		
24	Motor Power (kW)	7.5			

(adoption)

Davara Pumping Station (PS-09) Rehabilitation



Design Condition

1) Design Flow

Q_{adf} : Daily average flow
 Q_{pdf} : Peak flow (Ultimate) $Q_{pdf} = 2.0 \times Q_{adf}$

2) Type of Pumping Station

Circular type , Existing Submersible station
 Basket Not installed


3) Pump Number and capacity

Pump number : 2 duty + 1 standby

4) Force Main

Material : HDPE
 Diameter : Dia.450 mm
 Line number: 1 line

5) Outline (Assume)



Lifting Pump Calculation Sheet (PS-09)


ITEM	SYMBOL	DESIGN
9.1 Pump Sump Well (Rehabilitation)		
Required cycle time	n	Motor 15kW < 22kW 6 times
Pump capacity	Q	93.3 L/sec/unit
Required volume	v	= 900 × Q / n/1000 ≥ 14.0 m ³
Sump Well square	A	10.74 m ² Dia. 3.7m
<p>Water Level in the Sump Well</p>		
9.2 Lift Pump		
Duty pump number		2 units
Design flow per unit		93.3 L/sec/unit
Specification		
Type		Submersible non-clog sewage pump, automatic coupling type
Dia.	D	Approx. 200 mm
Capacity	Qp	93.3 L/sec/unit
		= 5.6 m ³ /min/unit
Total head	H	attached Table Pump calculation sheet 11.0 m
Motor	P	attached Table Pump calculation sheet approx. 15.0 kW
Number		Duty 2 units
		Standby 1 unit
		Stock 1 unit
		Total 4 units
9.3 Monorail Hoist		
Weight of pump	W	Approx. 0.45 Tonf
Required hoist capacity	hc	W × 1.5 ≥ 0.68 Tonf
Specification		
Type		Manually Geared trolley
Capacity		Approx. 1.0 Tonf
Lift		3.0 m
Number		Duty 1 unit
		Standby 0 unit
		Total 1 unit

Lifting Pump Calculation Sheet (PS-09)

1	Equip. No.	M01-009-01/04	1 pump operation	
	Pump Name	Lifting Pump-9	100%	120%
2	Pump Type	Submersible		
3	q : Capacity (m³/min)	5.6	5.6	6.72
4	N : Operation number	2	1	1
	Pump	93.3L/s		
	Pump Number	2D + 1S		
	Total Head H=ha+hf1+hf2+hf3+hf4			
5	ha : Actual head (m) =DWL-SWL	3.5	3.5	3.5
6	DWL (m)	0.600	0.600	0.600
7	SWL (m)	-2.900	-2.900	-2.900
8	hf1 : Straight pipe loss (m) = $(10.666 \times Q^{1.85}) \times L \times Cc$ $(C^{1.85} \times D^{4.87})$	3.760	1.043	1.461
9	Q : Flow (m ³ /sec) =q × N/60	0.187	0.093	0.112
10	C : Coefficient	130	130	130
		0.45m × 1 line	0.45m × 1 line	0.45m × 1 line
11	D : Inner Pipe Dia. (m)	0.3956	0.3956	0.3956
12	L : Pipe length (m)	700	700	700
13	Cc : Correction coefficient Water: 1.0 Sludge: WT99.2% :	1.0	1.0	1.0
14	hf2	0.000	0.000	0.000
15	hf3 : Pump around loss (m)	2	2	2
16	hf4 : Other head	0	0	0
17	H' =ha+hf1+hf2+hf3+hf4 (m)	9.26	6.54	6.96
18	H : Total head (m)	11.0		
	Velocity	1.52	0.76	0.91
			> 0.60 m/sec	
	Motor Power			
19	BKW =0.163*SG*q*H/Pe (kW)	12.873		
20	SG : Specific gravity	1.0		
21	Pe : Pump efficiency	0.78		
22	kW =BKW × C	14.804		
23	C : Coefficient (1.15)	1.15		
24	Motor Power (kW)	15		

Lawes Road Pumping Station (PS-10)

---> Gravity
 —> Force main



Design Condition

1) Design Flow

Qadf : Daily average flow
 Qpdf : Peak flow (Ultimate) $Qpdf = 2.0 \times Qadf$

2) Type of Pumping Station

Type C Submersible station
 Basket Installed


3) Pump Number and capacity

Pump number : 2 duty + 1 standby

4) Force Main

Material : HDPE
 Diameter : Dia.500 mm
 Line number: 1 line

5) Outline (Assume)




Lifting Pump Calculation Sheet (PS-10)

ITEM	SYMBOL	DESIGN
10.1 Pump Sump Well (New)		
Existing Sump Well can not be available because Inlet pipe bottom level is much lower than required water depth.		
Required cycle time	n	Motor 75kW > 55kW 2 times
Pump capacity	Q	103.3 L/sec/unit
Required volume	v	= 900 × Q / n/1000 ≥ 46.5 m ³
Sump Well square	A	11.33 m ² Dia.3.6m
<p>Water Level in the Sump Well</p> <p>Inlet pipe bottom level (Existing) is 0.03 m above L2.</p> <p>Vertical dimensions: H2 (HWL) to H1: h = 4.5m H1 to L2: h = 0.2m L2 to L1: h = 0.15m L1 to LLWL: h = 0.15m LLWL to Bottom: Manufacturer recommendati (Forced cooling type) (approx. 0.5 m)</p> <p>V > 46.5m³ h = 4.5m ≥ 4.10 m</p>		
New Sump Well will be installed.		
Required cycle time	n	Motor 75kW > 55kW 2 times
Pump capacity	Q	103.3 L/sec/unit
Required volume	v	= 900 × Q / n/1000 ≥ 46.5 m ³
Sump Well square	A	15.75 m ² 4.5m × 3.5m
<p>Water Level in the Sump Well</p> <p>Vertical dimensions: H2 (HWL) to H1: h = 3.0m H1 to L2: h = 0.2m L2 to L1: h = 0.15m L1 to LLWL: h = 0.15m LLWL to Bottom: Manufacturer recommendati (Forced Cooling type) (approx. 0.5m)</p> <p>V > 46.5m³ h = 3.0m ≥ 2.95 m</p>		
10.2 Lift Pump		
Duty pump number		2 units
Design flow per unit		103.3 L/sec/unit
Specification		
Type	D	Submersible non-clog sewage pump, automatic coupling type
Dia.	Qp	Approx. 250 mm
Capacity		103.3 L/sec/unit
Total head	H	attached Table Pump calculation sheet 42.0 m
Motor	P	attached Table Pump calculation sheet approx. 75.0 kW
Number		Duty 2 units Standby 1 unit Stock 1 unit Total 4 units
10.3 Monorail Hoist		
Weight of pump	W	Approx. 1.50 Tonf
Required hoist capacity	hc	W × 1.5 ≥ 2.25 Tonf
Specification		
Type		Manually Geared trolley
Capacity		2.5 Tonf
Lift		Approx. 3.0 m
Number		Duty 1 unit Standby 0 unit Total 1 unit

Lifting Pump Calculation Sheet (PS-10)

1 Equip. No.		M01-010-01/04		1 pump operation	
Pump Name		Lifting Pump-10		100%	120%
2 Pump Type		Submersible			
3 q : Capacity (m ³ /min)		6.2		6.2	7.44
4 N : Operation number		2		1	1
Pump		103.3L/s			
Pump Number		2D + 1S			
Total Head H=ha+hf1+hf2+hf3+hf4					
5 ha	: Actual head (m) =DWL-SWL	27.9		27.9	27.9
6 DWL	(m)	23.000		23.000	23.000
7 SWL	(m)	-4.900		-4.900	-4.900
8 hf1	: Straight pipe loss (m) = $(10.666 \times Q^{1.85}) \times L \times Cc$ $(C^{1.85} \times D^{4.87})$	10.657		2.956	4.142
9 Q	: Flow (m ³ /sec) =q × N/60	0.207		0.103	0.124
10 C	: Coefficient	130		130	130
		0.5m × 1 line		0.5 m × 1 line	0.5 m × 1 line
11 D	: Inner Pipe Dia. (m)	0.4397		0.4397	0.4397
12 L	: Pipe length (m)	2750		2750	2750
13 Cc	: Correction coefficient Water: 1.0 Sludge: WT99.2% :	1.0		1.0	1.0
14 hf2		0.000		0.000	0.000
15 hf3	: Pump around loss (m)	2		2	2
16 hf4	: Other head	0		0	0
17 H'	=ha+hf1+hf2+hf3+hf4 (m)	40.56		32.86	34.04
18 H	: Total head (m)	42.0			
Velocity		1.36		0.68	0.82
				> 0.60 m/sec	
Motor Power					
19 BKW	=0.163*SG*q*H/Pe (kW)	60.636			
20 SG	: Specific gravity	1.0			
21 Pe	: Pump efficiency	0.7			
22 kW	=BKW × C	69.731			
23 C	: Coefficient (1.15)	1.15			
24	Motor Power (kW)	75			

Koki Pumping Station (PS-11)



Design Condition

1) Design Flow


Q_{adf} : Daily average flow
 Q_{pdf} : Peak flow (Ultimate) $Q_{pdf} = 2.0 \times Q_{adf}$

2) Type of Pumping Station
 Type B Submersible station
 Basket Installed

3) Pump Number and capacity
 Pump number : 1 duty + 1 standby

4) Force Main
 Material : DCIP (Existing Pipe)
 Diameter : Dia.200 mm
 Line number: 1 line

5) Outline (Assume)



Lifting Pump Calculation Sheet (PS-11)


ITEM	SYMBOL	DESIGN
11.1 Pump Sump Well (New)		
Existing Sump Well can not be available because Inlet pipe bottom level is much lower than required water depth.		
Required cycle time	n	Motor 37kW < 55kW (F.W.) 4 times
Pump capacity	Q	43.3 L/sec/unit
Required volume	v	= 900 × Q / n/1000 ≥ 9.7 m ³
Sump Well square	A	8.03 m ² Dia. 3.2m
Water Level in the Sump Well		
New Sump Well will be installed.		
Required cycle time	n	Motor 37kW < 55kW (F.W.) 4 times
Pump capacity	Q	43.3 L/sec/unit
Required volume	v	= 900 × Q / n/1000 ≥ 9.7 m ³
Sump Well square	A	12.00 m ² 3mW × 4mL
Water Level in the Sump Well		
11.2 Lift Pump		
Duty pump number		1 unit
Design flow per unit		43.3 L/sec/unit
Specification		
Type	D	Submersible non-clog sewage pump, automatic coupling type
Dia.	Op	Approx. 200 mm
Capacity		43.3 L/sec/unit = 2.6 m ³ /min/unit
Total head	H	attached Table Pump calculation sheet 31.0 m
Motor	P	attached Table Pump calculation sheet approx. 37.0 kW
Number		Duty 1 unit Standby 1 unit Total 2 units
11.3 Monorail Hoist		
Weight of pump	W	Approx. 0.70 Tonf
Required hoist capacity	hc	W × 1.5 ≥ 1.05 Tonf
Specification		
Type		Manually Geared trolley
Capacity		1.5 Tonf
Lift		Approx. 3.0 m
Number		Duty 1 unit Standby 0 unit Total 1 unit

Lifting Pump Calculation Sheet (PS-11)

1	Equip. No.	M01-011-01/02			
	Pump Name	Lifting Pump-11			
2	Pump Type	Submersible	Submersible		
3	q : Capacity (m ³ /min)	2.6	2.6		
4	N : Operation number	1	1		
	Pump	43.3L/s	43.3L/s		
	Pump Number	1D + 1S	1D + 1S		
	Total Head H=ha+hf1+hf2+hf3+hf4				
5	ha : Actual head (m) =DWL-SWL	18.2	11.2		
6	DWL (m)	15.000	8.000		
7	SWL (m)	-3.200	-3.200		
8	hf1 : Straight pipe loss (m) = $(10.666 \times Q^{1.85}) \times L \times Cc$ $(C^{1.85} \times D^{4.87})$	9.315	14.217		
9	Q : Flow (m ³ /sec) =q × N/60	0.043	0.043		
10	C : Coefficient	80	80		
		Existing DIP Pipe	Existing DIP Pipe		
		0.2m × 1 line	0.2m × 1 line		
11	D : Inner Pipe Dia. (m)	0.2	0.2		
12	L : Pipe length (m)	380	580		
13	Cc : Correction coefficient Water: 1.0 Sludge: WT99.2% :	1.0	1.0		
14	hf2	0.000	0.000		
15	hf3 : Pump around loss (m)	2	2		
16	hf4 : Other head	0	0		
17	H' =ha+hf1+hf2+hf3+hf4 (m)	29.51	27.42		
18	H : Total head (m)	31.0	29.0		
	Velocity	1.38	1.38		
	Motor Power				
19	BKW =0.163*SG*q*H/Pe (kW)	21.896	20.484		
20	SG : Specific gravity	1.0	1.0		
21	Pe : Pump efficiency	0.6	0.6		
22	kW =BKW × C	25.181	23.556		
23	C : Coefficient (1.15)	1.15	1.15		
24	Motor Power (kW)	37			

(adoption)

Badili Pumping Station (PS-12) Rehabilitation



Design Condition

1) Design Flow

Q_{adf} : Daily average flow
 Q_{pdf} : Peak flow (Ultimate) $Q_{pdf} = 2.0 \times Q_{adf}$

2) Type of Pumping Station

Circular type , Existing Submersible station
 Basket Not installed


3) Pump Number and capacity

Pump number : 2 duty + 1 standby

4) Force Main

Material : HDPE
 Diameter : Dia.400 mm
 Line number: 1 line

5) Outline (Assume)




Lifting Pump Calculation Sheet (PS-12)

ITEM	SYMBOL	DESIGN
12.1 Pump Sump Well (Rehabilitation)		
Required cycle time	n	Motor 45kW < 55kW (F.W.) 4 times
Pump capacity	Q	58.3 L/sec/unit
Required volume	v	= 900 × Q / n/1000 ≥ 13.1 m ³
Sump Well square	A	10.74 m ² Dia. 3.7m
<p>Water Level in the Sump Well</p> <p>Existing Inlet pipe bottom level</p> <p>H2 (HWL)</p> <p>H1</p> <p>L2</p> <p>L1</p> <p>LLWL</p> <p>Bottom</p> <p>1.77 m</p> <p>$V > 13.1\text{m}^3$</p> <p>$h = 1.22\text{m}$ ≥ 1.22 m</p> <p>$h = 0.1\text{ m}$</p> <p>$h = 0.1\text{ m}$</p> <p>Manufacturer recommendati (Forced cooling type) (approx. 0.3m)</p>		
12.2 Lift Pump		
Duty pump number		2 units
Design flow per unit		58.3 L/sec/unit
Specification		
Type		Submersible non-clog sewage pump, automatic coupling type
Dia.	D	Approx. 200 mm
Capacity	Qp	58.3 L/sec/unit
Total head	H	= 3.5 m ³ /min/unit
Motor	P	attached Table Pump calculation sheet 33.0 m
Number		attached Table Pump calculation sheet approx. 45.0 kW
		Duty 2 units
		Standby 1 unit
		Stock 1 unit
		Total 4 units
12.3 Monorail Hoist		
Weight of pump	W	Approx. 1.60 Tonf
Required hoist capacity	hc	W × 1.5 ≥ 2.40 Tonf
Specification		
Type		Manually Geared trolley
Capacity		Approx. 2.5 Tonf
Lift		Approx. 3.0 m
Number		Duty 1 unit
		Standby 0 unit
		Total 1 unit

Lifting Pump Calculation Sheet (PS-12)

1	Equip. No.	M01-012-01/04	1 pump operation	
	Pump Name	Lifting Pump-12	100%	120%
2	Pump Type	Submersible		
3	q : Capacity (m ³ /min)	3.5	3.5	4.2
4	N : Operation number	2	1	1
	Pump	58.3L/s		
	Pump Number	2D + 1S		
	Total Head H=ha+hf1+hf2+hf3+hf4			
5	ha : Actual head (m) =DWL-SWL	25.7	25.7	25.7
6	DWL (m)	23.000	23.000	23.000
7	SWL (m)	-2.660	-2.660	-2.660
8	hf1 : Straight pipe loss (m) = $\frac{(10.666 \times Q^{1.85}) \times L \times Cc}{(C^{1.85} \times D^{4.87})}$	4.631	1.285	1.800
9	Q : Flow (m ³ /sec) =q × N/60	0.117	0.058	0.070
10	C : Coefficient	130	130	130
		0.40m × 1 line	0.40m × 1 line	0.40m × 1 line
11	D : Inner Pipe Dia. (m)	0.3517	0.3517	0.3517
12	L : Pipe length (m)	1160	1160	1160
13	Cc : Correction coefficient Water: 1.0 Sludge: WT99.2% :	1.0	1.0	1.0
14	hf2	0.000	0.000	0.000
15	hf3 : Pump around loss (m)	2	2	2
16	hf4 : Other head	0	0	0
17	H' =ha+hf1+hf2+hf3+hf4 (m)	32.29	28.94	29.46
18	H : Total head (m)	33.0		
	Velocity	1.20	0.60	0.72
				> 0.60 m/sec
	Motor Power			
19	BKW =0.163*SG*q*H/Pe (kW)	34.230		
20	SG : Specific gravity	1.0		
21	Pe : Pump efficiency	0.55		
22	kW =BKW × C	39.365		
23	C : Coefficient (1.15)	1.15		
24	Motor Power (kW)	45		

Kila Police Pumping Station (PS-13)



Design Condition

1) Design Flow

Qadf : Daily average flow
 Qpdf : Peak flow (Ultimate) $Qpdf = 2.0 \times Qadf$

2) Type of Pumping Station

Type A Submersible station
 Basket Installed


3) Pump Number and capacity

Pump number : 1 duty + 1 standby

4) Force Main

Material : HDPE
 Diameter : Dia.110 mm
 Line number: 1 line

5) Outline (Assume)




Lifting Pump Calculation Sheet (PS-13)

ITEM	SYMBOL	DESIGN
13.1 Pump Sump Well (New)		
Required cycle time	n	Motor 5.5kW < 7.5kW 10 times
Pump capacity	Q	6.0 L/sec/unit
Required volume	v	$= 900 \times Q / n / 1000$ \geq 0.5 m ³
Sump Well square	A	4.90 m ² Dia. 2.5m
<p>Water Level in the Sump Well</p>		
13.2 Lift Pump		
Design flow	Qpdf	$= 0.36 \text{ m}^3/\text{min}$ $= 6.0 \text{ L/sec}$
Duty pump number		1 unit
Design flow per unit		Considered pipe velocity > 0.6m/s 6.0 L/sec/unit
Specification		
Type		Submersible non-clog sewage pump, automatic coupling type
Dia.	D	Approx. 100 mm
Capacity	Qp	6.0 L/sec/unit
Total head	H	$= 0.36 \text{ m}^3/\text{min/unit}$ 20.0 m
Motor	P	attached Table Pump calculation sheet approx. 5.5 kW
Number		Duty 1 unit Standby 1 unit Total 2 units
13.3 Monorail Hoist		
Weight of pump	W	Approx. 0.10 Tonf
Required hoist capacity	hc	$W \times 1.5$ \geq 0.15 Tonf
Specification		
Type		Manually Geared trolley
Capacity		Approx. 0.5 Tonf
Lift		3.0 m
Number		Duty 1 unit Standby 0 unit Total 1 unit

Lifting Pump Calculation Sheet (PS-13)

1	Equip. No.	M01-013-01/02			
	Pump Name	Lifting Pump-13			
2	Pump Type	Submersible			
3	q : Capacity (m³/min)	0.36			
4	N : Operation number	1			
	Pump	6.0L/s			
	Pump Number	1D + 1S			
	Total Head H=ha+hf1+hf2+hf3+hf4				
5	ha : Actual head (m) =DWL-SWL	14.5			
6	DWL (m)	13.500			
7	SWL (m)	-1.000			
8	hf1 : Straight pipe loss (m) = $\frac{(10.666 \times Q^{1.85}) \times L \times Cc}{(C^{1.85} \times D^{4.87})}$	2.070			
9	Q : Flow (m ³ /sec) =q × N/60	0.006			
10	C : Coefficient	130			
		0.11m × 1 line			
11	D : Inner Pipe Dia. (m)	0.0964			
12	L : Pipe length (m)	230			
13	Cc : Correction coefficient Water: 1.0 Sludge: WT99.2% :	1.0			
14	hf2	0.000			
15	hf3 : Pump around loss (m)	2			
16	hf4 : Other head	0			
17	H' =ha+hf1+hf2+hf3+hf4 (m)	18.57			
18	H : Total head (m)	20.0			
	Velocity	0.82			
	Motor Power				
19	BKW =0.163*SG*q*H/Pe (kW)	3.912			
20	SG : Specific gravity	1.0			
21	Pe : Pump efficiency	0.3			
22	kW =BKW × C	4.499			
23	C : Coefficient (1.15)	1.15			
24	Motor Power (kW)	5.5			

Konebada Pumping Station (PS-14)



Design Condition

1) Design Flow

Q_{adf} : Daily average flow
 Q_{pdf} : Peak flow (Ultimate) $Q_{pdf} = 2.0 \times Q_{adf}$

2) Type of Pumping Station

Type A Submersible station
 Basket Installed


3) Pump Number and capacity

Pump number : 1 duty + 1 standby

4) Force Main

Material : HDPE
 Diameter : Dia.110 mm
 Line number: 1 line

5) Outline (Assume)




Lifting Pump Calculation Sheet (PS-14)

ITEM	SYMBOL	DESIGN
14.1 Pump Sump Well (New)		
Required cycle time	n	Motor = 7.5kW 4 times
Pump capacity	Q	7.5 L/sec/unit
Required volume	v	$= 900 \times Q / n / 1000$ \geq 1.7 m ³
Sump Well square	A	4.90 m ² Dia. 2.5m
Water Level in the Sump Well		
14.2 Lift Pump		
Duty pump number		1 unit
Design flow per unit		7.5 L/sec/unit
Specification		
Type		Submersible non-clog sewage pump, automatic coupling type
Dia.	D	Approx. 100 mm
Capacity	Qp	7.5 L/sec/unit = 0.45 m ³ /min/unit
Total head	H	attached Table Pump calculation sheet 24.0 m
Motor	P	attached Table Pump calculation sheet approx. 7.5 kW
Number		Duty 1 unit Standby 1 unit Total 2 units
14.3 Monorail Hoist		
Weight of pump	W	Approx. 0.20 Tonf
Required hoist capacity	hc	$W \times 1.5$ \geq 0.30 Tonf
Specification		
Type		Manually Geared trolley
Capacity		Approx. 0.5 Tonf
Lift		Approx. 3.0 m
Number		Duty 1 unit Standby 0 unit Total 1 unit

Lifting Pump Calculation Sheet (PS-14)

1	Equip. No.	M01-014-01/02			
	Pump Name	Lifting Pump-14			
2	Pump Type	Submersible			
3	q : Capacity (m ³ /min)	0.45			
4	N : Operation number	1			
	Pump	7.5L/s			
	Pump Number	1D + 1S			
	Total Head H=ha+hf1+hf2+hf3+hf4				
5	ha : Actual head (m) =DWL-SWL	17.4			
6	DWL (m)	15.300			
7	SWL (m)	-2.100			
8	hf1 : Straight pipe loss (m) = $(10.666 \times Q^{1.85}) \times L \times Cc$ $(C^{1.85} \times D^{4.87})$	3.129			
9	Q : Flow (m ³ /sec) =q × N/60	0.008			
10	C : Coefficient	130			
		0.11m × 1 line			
11	D : Inner Pipe Dia. (m)	0.0964			
12	L : Pipe length (m)	230			
13	Cc : Correction coefficient Water: 1.0 Sludge: WT99.2% :	1.0			
14	hf2	0.000			
15	hf3 : Pump around loss (m)	2			
16	hf4 : Other head	0			
17	H' =ha+hf1+hf2+hf3+hf4 (m)	22.53			
18	H : Total head (m)	24.0			
	Velocity	1.03			
	Motor Power				
19	BKW =0.163*SG*q*H/Pe (kW)	5.030			
20	SG : Specific gravity	1.0			
21	Pe : Pump efficiency	0.35			
22	kW =BKW × C	5.784			
23	C : Coefficient (1.15)	1.15			
24	Motor Power (kW)	7.5			

Gabutu Pumping Station (PS-15)



Design Condition

1) Design Flow

Q_{adf} : Daily average flow
 Q_{pdf} : Peak flow (Ultimate) $Q_{pdf} = 2.0 \times Q_{adf}$

2) Type of Pumping Station

Type A Submersible station
 Basket Installed


3) Pump Number and capacity

Pump number : 1 duty + 1 standby

4) Force Main

Material : HDPE
 Diameter : Dia.125 mm
 Line number: 1 line

5) Outline (Assume)




Lifting Pump Calculation Sheet (PS-15)

ITEM	SYMBOL	DESIGN
15.1 Pump Sump Well		
Required cycle time	n	Motor = 22kW (F.W.) 4 times
Pump capacity	Q	12.5 L/sec/unit
Required volume	v	= $900 \times Q / n / 1000$ \geq 2.8 m ³
Sump Well square	A	4.90 m ² Dia. 2.5m
Water Level in the Sump Well		
15.2 Lift Pump		
Duty pump number		1 unit
Design flow per unit		12.5 L/sec/unit
Specification		
Type		Submersible non-clog sewage pump, automatic coupling type
Dia.	D	Approx. 100 mm
Capacity	Qp	12.5 L/sec/unit
		= 0.75 m ³ /min/unit
Total head	H	attached Table Pump calculation sheet 43.0 m
Motor	P	attached Table Pump calculation sheet approx. 22.0 kW
Number		Duty 1 unit
		Standby 1 unit
		Total 2 units
15.3 Monorail Hoist		
Weight of pump	W	Approx. 0.50 Tonf
Required hoist capacity	hc	$W \times 1.5$ \geq 0.75 Tonf
Specification		
Type		Manually Geared trolley
Capacity		Approx. 1.0 Tonf
Lift		3.0 m
Number		Duty 1 unit
		Standby 0 unit
		Total 1 unit

Lifting Pump Calculation Sheet (PS-15)

1	Equip. No.	M01-015-01/02			
	Pump Name	Lifting Pump-15			
2	Pump Type	Submersible			
3	q : Capacity (m ³ /min)	0.75			
4	N : Operation number	1			
	Pump	12.5L/s			
	Pump Number	1D + 1S			
	Total Head H=ha+hf1+hf2+hf3+hf4				
5	ha : Actual head (m) =DWL-SWL	25.6			
6	DWL (m)	23.000			
7	SWL (m)	-2.600			
8	hf1 : Straight pipe loss (m) $= \frac{(10.666 \times Q^{1.85}) \times L \times Cc}{(C^{1.85} \times D^{4.87})}$	14.111			
9	Q : Flow (m ³ /sec) =q × N/60	0.013			
10	C : Coefficient	130			
		0.125m × 1 line			
11	D : Inner Pipe Dia. (m)	0.1098			
12	L : Pipe length (m)	760			
13	Cc : Correction coefficient Water: 1.0 Sludge: WT99.2% :	1.0			
14	hf2	0.000			
15	hf3 : Pump around loss (m)	2			
16	hf4 : Other head	0			
17	H' =ha+hf1+hf2+hf3+hf4 (m)	41.71			
18	H : Total head (m)	43.0			
	Velocity	1.32			
	Motor Power				
19	BKW =0.163*SG*q*H/Pe (kW)	17.523			
20	SG : Specific gravity	1.0			
21	Pe : Pump efficiency	0.3			
22	kW =BKW × C	20.151			
23	C : Coefficient (1.15)	1.15			
24	Motor Power (kW)	22			

Horsecamp Pumping Station (PS-16)



Design Condition

1) Design Flow

Qadf : Daily average flow
 Qpdf : Peak flow (Ultimate) $Qpdf = 2.0 \times Qadf$

2) Type of Pumping Station

Type A Submersible station
 Basket Installed


3) Pump Number and capacity

Pump number : 1 duty + 1 standby

4) Force Main

Material : HDPE
 Diameter : Dia.225 mm
 Line number: 1 line

5) Outline (Assume)




Lifting Pump Calculation Sheet (PS-16)

ITEM	SYMBOL	DESIGN
16.1 Pump Sump Well (New)		
Required cycle time	n	Motor 11kW < 22kW 4 times
Pump capacity	Q	25.0 L/sec/unit
Required volume	v	= 900 × Q / n/1000 ≥ 5.6 m ³
Sump Well square	A	4.90 m ² Dia. 2.5m
<p>Water Level in the Sump Well</p>		
16.2 Lift Pump		
Duty pump number		1 unit
Design flow per unit		25.0 L/sec/unit
Specification		
Type		Submersible non-clog sewage pump, automatic coupling type
Dia.	D	Approx. 100 mm
Capacity	Qp	25.0 L/sec/unit = 1.5 m ³ /min/unit
Total head	H	attached Table Pump calculation sheet 21.0 m
Motor	P	attached Table Pump calculation sheet approx. 11.0 kW
Number		Duty 1 unit Standby 1 unit Total 2 units
16.3 Monorail Hoist		
Weight of pump	W	Approx. 0.25 Tonf
Required hoist capacity	hc	W × 1.5 ≥ 0.38 Tonf
Specification		
Type		Manually Geared trolley
Capacity		0.5 Tonf
Lift		Approx. 3.0 m
Number		Duty 1 unit Standby 0 unit Total 1 unit

Lifting Pump Calculation Sheet (PS-16)

1	Equip. No.	M01-016-01/02			
	Pump Name	Lifting Pump-16			
2	Pump Type	Submersible			
3	q : Capacity (m ³ /min)	1.5			
4	N : Operation number	1			
	Pump	25.0L/s			
	Pump Number	1D + 1S			
	Total Head H=ha+hf1+hf2+hf3+hf4				
5	ha : Actual head (m) =DWL-SWL	16.3			
6	DWL (m)	12.100			
7	SWL (m)	-4.200			
8	hf1 : Straight pipe loss (m) = $\frac{(10.666 \times Q^{1.85}) \times L \times Cc}{(C^{1.85} \times D^{4.87})}$	2.296			
9	Q : Flow (m ³ /sec) =q × N/60	0.025			
10	C : Coefficient	130			
		0.225m × 1 line			
11	D : Inner Pipe Dia. (m)	0.1976			
12	L : Pipe length (m)	600			
13	Cc : Correction coefficient Water: 1.0 Sludge: WT99.2% :	1.0			
14	hf2	0.000			
15	hf3 : Pump around loss (m)	2			
16	hf4 : Other head	0			
17	H' =ha+hf1+hf2+hf3+hf4 (m)	20.60			
18	H : Total head (m)	21.0			
	Velocity	0.82			
	Motor Power				
19	BKW =0.163*SG*q*H/Pe (kW)	8.558			
20	SG : Specific gravity	1.0			
21	Pe : Pump efficiency	0.6			
22	kW =BKW × C	9.841			
23	C : Coefficient (1.15)	1.15			
24	Motor Power (kW)	11			

Kaugere Pumping Station (PS-17)



Design Condition

1) Design Flow


Qadf : Daily average flow
 Qpdf : Peak flow (Ultimate) $Qpdf = 2.0 \times Qadf$

2) Type of Pumping Station
 Type D Submersible station
 Basket Installed

3) Pump Number and capacity
 Pump number : 2 duty + 1 standby

4) Force Main
 Material : HDPE
 Diameter : Dia.710 mm
 Line number: 1 line

5) Outline (Assume)



Lifting Pump Calculation Sheet (PS-17)			
ITEM	SYMBOL	DESIGN	
17.1 Pump Sump Well			
Required cycle time	n	Motor 55kW < 75kW	4 times
Pump capacity	Q		208.3 L/sec/unit
Required volume	v	= 900 × Q / n/1000	≥ 46.9 m ³
Sump Well square	A		2.26 m ² Dia. 1.7m (Existing)
<p>Water Level in the Sump Well</p> <p>H2 (HWL)</p> <p>H1</p> <p>Inlet pipe bottom level (Existing) 0.03 m</p> <p>L2</p> <p>L1</p> <p>LLWL</p> <p>Bottom</p> <p>$V > 46.9\text{m}^3$ $h = 2.1\text{m}$</p> <p>$h = 0.2\text{m}$</p> <p>$h = 0.85\text{m}$</p> <p>Manufacturer recommendati (Forced cooling type) (approx. 0.75 m)</p>			
New Sump Well will be installed.			
Required cycle time	n	Motor 55kW < 75kW	4 times
Pump capacity	Q		208.3 L/sec/unit
Required volume	v	= 900 × Q / n/1000	≥ 46.9 m ³
Sump Well square	A		15.75 m ² 4.5m × 3.5m
<p>Water Level in the Sump Well</p> <p>H2 (HWL)</p> <p>H1</p> <p>L2</p> <p>L1</p> <p>LLWL</p> <p>Bottom</p> <p>$V > 46.9\text{m}^3$ $h = 3.1\text{m}$</p> <p>$h = 0.2\text{m}$</p> <p>$h = 0.85\text{m}$</p> <p>Manufacturer recommendation (approx. 0.75 m)</p>			
17.2 Lift Pump			
Duty pump number			1 units
Design flow per unit			208.3 L/sec/unit
Specification			
Type		Submersible non-clog sewage pump, automatic coupling type	
Dia.	D	Approx.	350 mm
Capacity	Qp		208.3 L/sec/unit
		=	12.5 m ³ /min/unit
Total head	H	attached Table Pump calculation sheet	15.0 m
Motor	P	attached Table Pump calculation sheet	approx. 55.0 kW
Number		Duty	2 units
		Standby	1 unit
		Stock	1 unit
		Total	4 units
17.3 Monorail Hoist			
Weight of pump	W	Approx.	1.40 Tonf
Required hoist capacity	hc	W × 1.5	≥ 2.10 Tonf
Specification			
Type		Manually Geared trolley	
Capacity		Approx.	2.5 Tonf
Lift			3.0 m
Number		Duty	1 unit
		Standby	0 unit
		Total	1 unit

Lifting Pump Calculation Sheet (PS-17)

1	Equip. No.	M01-017-01/04		1 pump operation	
	Pump Name	Lifting Pump-17		100%	120%
2	Pump Type	Submersible	Submersible		
3	q : Capacity (m ³ /min)	12.5	12.5	12.5	15.0
4	N : Operation number	2	2	1	1
	Pump	208.3L/s	208.3L/s		
	Pump Number	2D + 1S	2D + 1S		
	Total Head H=ha+hf1+hf2+hf3+hf4				
5	ha : Actual head (m) =DWL-SWL	11.8	3.1	10.6	10.6
6	DWL (m)	20.800	12.100	19.600	19.600
7	SWL (m)	9.000	9.000	9.000	9.000
8	hf1 : Straight pipe loss (m) = $\frac{(10.666 \times Q^{1.85}) \times L \times Cc}{(C^{1.85} \times D^{4.87})}$	0.669	5.144	0.185	0.260
9	Q : Flow (m ³ /sec) =q × N/60	0.417	0.417	0.208	0.250
10	C : Coefficient	130	130	130	130
		0.71m × 1 line	0.71m × 1 line	0.71m × 1 line	0.71m × 1 line
11	D : Inner Pipe Dia. (m)	0.6243	0.6243	0.6243	0.6243
12	L : Pipe length (m)	260	2000	260	260
13	Cc : Correction coefficient Water: 1.0 Sludge: WT99.2% :	1.0	1.0	1.0	1.0
14	hf2	0.000	0.000	0.000	0.000
15	hf3 : Pump around loss (m)	2	2	2	2
16	hf4 : Other head	0	0	0	0
17	H' =ha+hf1+hf2+hf3+hf4 (m)	14.47	10.24	12.79	12.86
18	H : Total head (m)	15.0	11.0		
	Velocity	1.36	1.36	0.68	0.82
				> 0.60 m/sec	
	Motor Power				
19	BKW =0.163*SG*q*H/Pe (kW)	43.661	32.018		
20	SG :Specific gravity	1.0	1.0		
21	Pe :Pump efficiency	0.7	0.7		
22	kW =BKW × C	50.210	36.821		
23	C :Coefficient (1.15)	1.15	1.15		
24	Motor Power (kW)	55			

(adoption)

C1.2 Calculation Sheets of STP

M02 Grit Chamber Facility

ITEM		SYMBOL	DESIGN		
1 Grit Chamber Inlet Gate					
1.Design Condition					
Design Flow		Q_{2-D}	36,800 m ³ /day	(Hourly Maximum)	
		Q_{2-S}	0.426 m ³ /sec	(Hourly Maximum)	
Type			Manually Operated Cast Iron Gate		
Unit Number		UN	Ope.	Stand-by	Total
			2 units	0 unit	2 units
2.Design Criteria					
Average Velocity		V1	Less than	1.0 m/sec	
3.Calculation					
Dimension	Depth	H	Arrangement		0.5 m
	Width	W	H : W = 1 : 1 or 1.5 : 1	therefore	0.5 m
Velocity		V2	$Q_{2-S} \times 1 / (H \times W \times 2) =$	0.85 m/sec	
				Less than 1.0m/sec	...OK
4.Specification			W 500mm × H 750mm × 2units (proposed)		
2 Medium Screen					
1.Design Condition					
Design Flow		Q_{2-D}	36,800 m ³ /day	(Hourly Maximum)	
		Q_{2-S}	0.426 m ³ /sec	(Hourly Maximum)	
Type			Automatic Drum Screen		
Unit Number		UN	Ope.	Stand-by	Total
			2 unit	0 unit	2 unit
Opening		OP	20 mm		
Flow Per Unit		Qu	$Q_{2-S} / UN =$	0.213 m ³ /sec =	18,400 m ³ /day
Cannel Width			Width 1.6 m		
2.Specification			Dia.1,400 mm × OP.20 mm × 2.2 kW × 2 units (proposed) (Based on Manufacturer's Information)		

ITEM	SYMBOL	DESIGN						
3 Screenings Container								
1.Design Condition								
Design Flow	Q_{1-D}	36,800 m ³ /day (Hourly Maximum)						
Type		Container (with handcart)						
Unit Number	UN	<table border="0" style="width:100%"> <tr> <td style="text-align:center">Ope.</td> <td style="text-align:center">Stand-by</td> <td style="text-align:center">Total</td> </tr> <tr> <td style="text-align:center">1 unit</td> <td style="text-align:center">3 units</td> <td style="text-align:center">4 units</td> </tr> </table>	Ope.	Stand-by	Total	1 unit	3 units	4 units
Ope.	Stand-by	Total						
1 unit	3 units	4 units						
Storage days	SD	3 days						
2.Design Criteria								
Unit Screenings Generation Volume	Vo1	0.001 m ³ /1000m ³ to 0.015 m ³ /1000m ³						
3.Calculation								
Design Screening Volume	Vo2	$Q_{1-D} \times 10^{-3} \times Vo1 =$ 0.04 m ³ /day to 0.55 m ³ /day However dehydrate to 70% water content (Raw Screening water content : 85%) therefore 0.018 m ³ /day to 0.28 m ³ /day						
Container Volume	Vo3	$Vo2 \times SD =$ 0.06 m ³ to 0.83 m ³						
4.Specification		0.5 m ³ × 4 units (proposed)						
4 Grit Collector								
1.Design Condition								
Design Flow	Q_{2-D}	36,800 m ³ /day (Hourly Maximum)						
Type	Q_{2-S}	0.426 m ³ /sec (Hourly Maximum)						
Unit Number	UN	Vortex Type <table border="0" style="width:100%"> <tr> <td style="text-align:center">Ope.</td> <td style="text-align:center">Stand-by</td> <td style="text-align:center">Total</td> </tr> <tr> <td style="text-align:center">2 units</td> <td style="text-align:center">0 unit</td> <td style="text-align:center">2 units</td> </tr> </table>	Ope.	Stand-by	Total	2 units	0 unit	2 units
Ope.	Stand-by	Total						
2 units	0 unit	2 units						
Grit Chamber Dimension		Dia 1.6m						
Channel Number		2 channels						
Flow Per Unit	Qu	$Q_{2-S} / (UN) =$ 0.213 m ³ /sec = 18,400 m ³ /d						
2.Specification		Dia.1,600 mm × 0.75 kW × 2 units (proposed) (Based on Manufacturer's Information)						

ITEM	SYMBOL	DESIGN						
5 Grit Pump								
1.Design Condition								
Type		Centrifugal Pump						
Unit Number	UN	<table style="width: 100%; border: none;"> <tr> <td style="width: 33%;">Ope.</td> <td style="width: 33%;">Stand-by</td> <td style="width: 33%;">Total</td> </tr> <tr> <td>1 units</td> <td>1 unit</td> <td>2 units</td> </tr> </table>	Ope.	Stand-by	Total	1 units	1 unit	2 units
Ope.	Stand-by	Total						
1 units	1 unit	2 units						
Sand Pit Volume	V _o	2 m ³						
2.Design Criteria								
Operation Time	T	Approximately 5 min Against Sand Pit Volume						
3.Calculation								
Discharge Flow Per Unit	QU	V _o /T = 0.5 m ³ /min						
Total Pump Head	H	From Calculation Sheet of Pumps (STP) 7 m						
4.Specification		Dia.80 mm × 0.5 m ³ / min × 7 m × 2.2 kW × 2 units (proposed)						
6 Grit Separator								
1.Design Condition								
Type		Screw Conveyor Type						
Unit Number	UN	<table style="width: 100%; border: none;"> <tr> <td style="width: 33%;">Ope.</td> <td style="width: 33%;">Stand-by</td> <td style="width: 33%;">Total</td> </tr> <tr> <td>1 unit</td> <td>0 unit</td> <td>1 unit</td> </tr> </table>	Ope.	Stand-by	Total	1 unit	0 unit	1 unit
Ope.	Stand-by	Total						
1 unit	0 unit	1 unit						
Grit Pump Discharge Flow	QU	0.5 m ³ /min						
2.Design Criteria								
Retention Time	T	More Than 30 sec Against Grit Removal Pump Discharge Flow						
3.Calculation								
Tank Volume	V _o	QU × T = more than 0.25 m ³						
4.Specification		0.5 m ³ / min × 0.75 kW × 1 unit (proposed)						

ITEM	SYMBOL	DESIGN		
7 Grit Container				
1.Design Condition				
Design Flow	Q_{1-D}	36,800 m ³ /day (Hourly Maximum)		
Type		Container (with handcart)		
Unit Number	UN	Ope.	Stand-by	Total
		1 unit	3 units	4 units
Storage days	SD	3 days		
2.Design Criteria				
Unit Grit Sedimentation Volume	Vo1	0.001 m ³ /1000m ³ to 0.02 m ³ /1000m ³		
3.Calculation				
Design Grit Volume	Vo2	$Q_{1-D} \times 10^{-3} \times Vo1 =$ 0.04 m ³ /day to 0.74 m ³ /day		
Container Volume	Vo3	$Vo2 \times SD =$ 0.11 m ³ to 2.2 m ³		
4.Specification		0.5 m ³ × 4 units (proposed)		

M03 Distribution Chamber Facility

ITEM	SYMBOL	DESIGN			
1 Distribution Weir					
1.Design Condition					
Design Flow	Q_{2-D}	36,800	m^3/day	(Hourly Maximum)	
Design Flow	Q_{2-S}	0.426	m^3/sec	(Hourly Maximum)	
Type		Adjustable Weir, Cast Iron			
Unit Number	UN	Ope.	Stand-by	Total	
		4 units	0 unit	4 units	
2.Design Criteria					
Effluent Height	H1	0.10	m to	0.30 m	
3.Calculation					
Weir Width	W	$(Q_{2-S})/UN/1.84/H1^{3/2} =$			
		=		1.8 m to	0.35 m
				therefore	0.8 m
Check		$\sqrt{(Q_{2-S}/N/1.84/W)^{2/3}}$		0.17	
4.Specification		W 800 mm × ST 400mm × 4 units (proposed)			

M04 Oxidation Ditch Facility

ITEM		SYMBOL	DESIGN			
1 Outlet Gate						
1.Design Condition						
Max. Design Flow		Q _{2-D}	18,400 m ³ /day (Daily Average + Return Sludge Flow + Bypass Frow)			
		Q _{2-S}	0.213 m ³ /sec			
Type			Manually Operated Cast Iron Gate			
Unit Number		UN	Ope.	Stand-by	Total	
			1 unit/train	0 unit	1 unit/train	
2.Design Criteria						
Average Velocity		V1	Less than 1 m/sec			
3.Calculation						
Dimension	Depth	H	Arrangement		0.5 m	
	Width	W	H : W = 1 : 1 or 1.5 : 1		therefore	0.5 m
Velocity		V2	Q _{2-S} / (H × W) / UN =		0.95 m/sec	
					Less than 1.0m/sec ...OK	
4.Specification			W 500 mm × H 500 mm × 3 units (proposed)			

ITEM	SYMBOL	DESIGN
2 Air diffuser		
1.Required Air Content		
a) Oxygen Demand		
For Removed BOD	D_B	$A \times [(Sc - Sc_{out}) - 2N, R_m] \times 10^{-3} \times Q_{3-D} = 270 \text{ kgO}_2/\text{day}$
		Design Flow (Daily Average)/ train $Q_{3-D} = 4,600 \text{ m}^3/\text{day}$
		Oxygen demand per removed BOD $A = 0.6 \text{ kgO}_2/\text{kgBOD}$
		Inlet BOD Quality $Sc = 190 \text{ mg/L}$
		Outlet BOD Quality $Sc_{out} = 20 \text{ mg/L}$
		Inlet Nitrogen Quality $T-N = 45 \text{ mg/L}$
		BOD consumption ratio for Denitrification $= 2 \text{ kgBOD}/\text{kgN}$
		Nitrogen removal $N, R_m = T-N \times N-R = 36 \text{ mg/L}$
		Denitrification ratio $N-R = 80 \%$
For Endogenous Respiration	D_E	$B \times MLVSS \times 10^{-3} \times VA \times R = 552 \text{ kgO}_2/\text{day}$
		Oxygen demand for unit endogenous respiration
		$B = 0.1 \text{ kgO}_2/\text{kgMLVSS-day}$
		Organic MLSS (MLSS $\times 80\%$) $MLVSS = 2,400 \text{ mg/L}$
		Aerated Zone Volume
		$VA = 4,600 \text{ m}^3$
		$R : \text{Ratio of Aerobic} \quad R = 0.5$
For Nitrification	D_N	$C \times T-N \times \alpha \times Q_{3-D} \times 10^{-3} = 757 \text{ kgO}_2/\text{day}$
		Oxygen consumed by Nitrification Reaction $C = 4.57 \text{ kgO}_2/\text{kgN}$
		Influent Nitrogen Quality $T-N = 45 \text{ mg/L}$
		$\alpha = 0.80 \text{ mg/L}$
For Residual Dissolved Oxygen	D_{DO}	$CA \times Q_{3-D} \times 10^{-3} = 7 \text{ kgO}_2/\text{day}$
		Residual dissolved oxygen concentration $CA = 1.5 \text{ mg/L}$

ITEM	SYMBOL	DESIGN
Actual Oxygen Demand	AOR	$D_B + D_E + D_N + D_{DO} = 1,586 \text{ kgO}_2/\text{day}$
Standard Oxygen Demand	SOR	$\text{SOR} = (\text{AOR} \times C_{sw} \times r) / (1.024^{(T-20)} \times \alpha \times (\beta \times C_s \times r - C_A)) / t$ $= 194.71 \text{ kgO}_2/\text{hr}$
		<p>C_{sw}: Oxygen saturation concentration in clean water at temperature 20 C_{sw} = 8.84 mg/l</p> <p>T: Temperature of Water T = 28</p> <p>α: Ratio of Oxygen transfer rate in the waste to that in clear water at the same temperature α = 0.83</p> <p>β: Ratio of Oxygen saturation concentration in the waste to that in clean water β = 0.95</p> <p>C_s: Oxygen saturation concentration in clean water at Temperature T C_s = 7.53 mg/l</p> <p>C_A: Residual dissolved oxygen concentration in the waste water C_A = 1.5 mg/l</p> <p>r : Correction of C_s from water depth</p> $r = 1 + (H/2)/10.24 = 1.28$ <p>H : Design Water Depth of Diffuser H = 5.7 m</p> <p>t : Aeration time per day t = 12 hr/day</p>
2.Design Condition		
Type		Air diffuser
Dissolutive Efficiency	Ea	31 %
OD Train Number	TN	1 trains
Unit Number	UN	10 units/train
		<p>Air Density ρ = 1.293 kg air/Nm³</p> <p>Oxygen weight per unit Air O_w = 0.233 kg O₂/kg air</p>
3.Calculation		An example which calculates the quantity of Diffuser is shown below.
(For example)		
Air Volume per Diffuser	Da	117 L/min
Air Demand	Qa	$\text{SOR} / (E_a \times 10^{-2} \times \rho \times O_w) / \text{TN} / 60 \times (293/273) = 36.9 \text{ Sm}^3/\text{min}/\text{train}$
Safety Factor	α	α = 1.10
Designed Air Demand		$Q_a \times \alpha = 40.6 \text{ Sm}^3/\text{min}/\text{train}$
Required Diffuser Number	n	$Q_a / D_a \times 10^3 = 346.7 \text{ pieces}$ therefore 360 pieces/train
4.Specification		Approx. 36 pieces / unit × 10 units × 3 trains (proposed)

ITEM	SYMBOL	DESIGN			
3 Aeration Blower					
1.Design Condition		Rotary Type Blower			
Type		Rotary Type Blower			
OD Train Number	TN	4 trains	(Ultimate)		
Unit Number	UN	Ope.	Stand-by	Total	(Ultimate)
		4 units	2 unit	6 units	
Air Demand	Qa	40.6 Sm ³ /min/train			
2.Design Criteria					
Allowance	AL	10 %			
3.Calculation					
Air Demand	Q	Qa × (1+AL/100)	=	40.6 Sm ³ /min/train	
			therefore	42 Sm ³ /min/train	
Total Blower Head		70.0 kPa			
4.Specification		Dia 200 mm × 42 Sm ³ /min × 70 kPa × 75 kW × 5 units (proposed)			
4 Reactor Tank Mixer					
1.Design Condition		Submersible Propeller Type Mixer			
Type		Submersible Propeller Type Mixer			
OD Train Number	TN	4 trains	(Ultimate)		
Unit Number	UN	Ope.	Stand-by	Total	
		4 units/ train	0 unit	4 units/ train	
OD Tank Volume	V	4,600 m ³ /tank			
2.Design Criteria	W	1.5 w/m ³			
3.Calculation		V × W / TN / UN /1000=		1.73 kW	
			therefore	2.3 kW Approx.	
4.Specification		Dia. Approx. 2.4 m × Approx. 2.3 kW × 12 units (4 units/train × 3 trains, proposed) (Based on Manufacture's Information)			

ITEM	SYMBOL	DESIGN						
5 Waste Sludge Pump								
1.Design Condition								
Type		Submersible Sewage Pump (Non-clog)						
Unit Number	UN	<table style="width: 100%; border: none;"> <tr> <td style="width: 33%; text-align: center;">Ope.</td> <td style="width: 33%; text-align: center;">Stand-by</td> <td style="width: 33%; text-align: center;">Total (Ultimate)</td> </tr> <tr> <td style="text-align: center;">4 units</td> <td style="text-align: center;">4 units</td> <td style="text-align: center;">8 units</td> </tr> </table>	Ope.	Stand-by	Total (Ultimate)	4 units	4 units	8 units
Ope.	Stand-by	Total (Ultimate)						
4 units	4 units	8 units						
Sludge volume	V	1,434 m ³ /day						
2.Design Criteria								
Operation Time	T	5.4 hr/day/unit						
3.Calculation								
Discharge Flow	QU	$V / (T \times 60) / UN =$ 1.11 m ³ /min therefore 1.1 m ³ /min						
Total Pump Head	H	From Calculation Sheet of Pumps (STP) 14 m						
4.Specification		Dia. 100 mm × 1.1 m ³ /min × 14 m × 5.5 kW × 6 units (proposed)						

M05 Clarifier Facility

ITEM	SYMBOL	DESIGN						
1 Clarifier								
1.Design Condition								
Design Flow	Q _{2-D}	18,400 m ³ /day (Ultimate Daily Average)						
Type		Center Driven Column Type						
Unit Number	UN	4 units (Ultimate)						
Dimension		Dia.25 m × WD 3.5 m × 4 units						
2.Specification		Dia.25 m × WD3.5 m × 0.75 kW × 3 units (proposed) (Based on Manufacture's Information)						
2 Return Sludge Pump								
1.Design Condition								
Type		Centrifugal Pump (Screw type)						
Unit Number	UN	<table style="width: 100%; border: none;"> <tr> <td style="text-align: center;">Ope.</td> <td style="text-align: center;">Stand-by</td> <td style="text-align: center;">Total (Ultimate)</td> </tr> <tr> <td style="text-align: center;">4 units</td> <td style="text-align: center;">4 units</td> <td style="text-align: center;">8 units</td> </tr> </table>	Ope.	Stand-by	Total (Ultimate)	4 units	4 units	8 units
Ope.	Stand-by	Total (Ultimate)						
4 units	4 units	8 units						
Design Flow	Q _{3-D} Q _{3-M}	18,400 m ³ /day (Ultimate Daily Average) 12.8 m ³ /min						
2.Design Criteria								
Return Sludge Ratio	RSR	100 %, (Max.200%)						
Operation Time	T	24 hr/day						
3.Calculation								
Discharge Flow	QU	$Q_{3-M} \times (RSR/100) / UN = 3.19 \text{ m}^3/\text{min}$ therefore $3.2 \text{ m}^3/\text{min}$						
Total Pump Head	H	From Calculation Sheet of Pumps (STP) 9 m						
4.Specification		Dia.150 mm × 3.2 m ³ /min × 9 m × 11 kW × 6 units (proposed)						

M06 Utility and Disinfection Facility

ITEM		SYMBOL	DESIGN		
1 Disinfection Inlet Gate					
1.Design Condition					
Design Flow		Q_{2-D}	36,800 m ³ /day	(Hourly Maximum)	
		Q_{2-S}	0.426 m ³ /sec	(Hourly Maximum)	
Type			Manually Operated Cast Iron Gate		
Unit Number		UN	Ope.	Stand-by	Total
			2 units	0 unit	2 units
2.Design Criteria					
Average Velocity		V1	Less than	1 m/sec	
3.Calculation					
Dimension	Depth	H	Arrangement		0.6 m
	Width	W	H : W = 1 : 1 or 1.5 : 1	therefore	0.4 m
Velocity		V2	$Q_{2-S} \times 1 / (H \times W) =$	0.89 m/sec	
				Less than 1.0m/sec	...OK
4.Specification			W 400 mm × H 600 mm × 2 units (proposed)		
2 Ultra Violet Disinfection Unit					
1.Design Condition					
Type			Medium Pressure Type		
Unit Number		UN	Ope.	Stand-by	Total
			2 lots	0 lot	2 lots
Design Flow		Q_{2-S}	36,800 m ³ / day	(Hourly Maximum)	
Coliform Reduction		%	99 %		
UV Transmittance		%	70 %		
2.Design Criteria					
Flow rate per Unit		QN	$Q_{3-D} / UN =$	18,400 m ³ /day	
Capacity per UV Lump		Q_{UV}	490 m ³ / day / lamp	(Based on Manufacture's Information)	
3.Calculation					
UV Lamp Number		UN	$Q_N / Q_{UV} =$	37.6 lamps per Unit	
			therefore	42 lamps per Unit	
4.Specification			18,400 m ³ /day × Approx.15.0 kW × (42 lamps/ lot) × 2 lots		

ITEM	SYMBOL	DESIGN			
3 Chlorine Facility (for back up)					
1) Dosing ratio		Effec. CL rate (mg/L)	Powder chlorine (mg/L)	Powder CL (kg/day)	Remarks
Powder chlorine : effective 60%		2	3.33	61.3	
Design flow : 18,400 m ³ /day		3	5.00	92.0	Average
		4	6.67	122.7	Maximum
Average dosing rate	Aav	mg/L		3	
Dosing quantity per day	Dq	for 18,400m ³ /d	kg/D	92.0	
Solution ratio	Sr		%	2	
Dosing flow per day	Df	$Dq \times 1/Sr \times 100/1000$	m ³ /d	4.60	
Dosing quantity per year	Dqy		kg/y	2,760 (Assumption 30 days)	
Required bag per year		45kg Chlorine per drum	bags/y	61	
2) Chlorine Solution Tank and Mixer					
Retention time	Rt		day	1	more
Required tank volume	Rv	$Df \times Rt$	m ³	4.6	more
Tank quantity	n		No.	1	tank
Required volume for one tank	Rvn	Rv / n	m ³	4.6	more
Tank type		Cylindrical PE tank with Mixer			
Dimension	ϕ		m	2.0	
	ED	Effective water depth	m	2.0	
	V	Effective volume	m ³	5.5	
			therefore	7.0	m ³
			kW	1.5	
3) Chlorine Dosing Charger					
Design flow	q.av	$Df/24$		0.19	m ³ /hr Average
	q.max			0.51	m ³ /hr Max.
Type		Manual flow control and gravity type, PVC			
Unit Number	N	Duty		1	unit
		Standby		1	unit
		Total		2	units
Capacity	C			0 to 0.3	m ³ /hr
4) Specification		7 m ³ × 1 unit, 0 to 0.3 m ³ /hr × 2 units (proposed) (Mixer 1.5kw)			

ITEM	SYMBOL	DESIGN						
<p>4 Utility TE Water Supply Unit</p> <p>1.Design Condition</p> <p>Type</p> <p>Unit Number</p> <p>2.Design Criteria</p> <p>Required Water Volume</p> <p>3.Calculation</p> <p>Discharge Flow Per Unit</p> <p>Total Pump Head</p> <p>4.Specification</p>	<p>UN</p> <p>QU2</p> <p>QU</p> <p>H</p>	<p>Two Submersible Pumps + Pressure Tank with Control Panel</p> <table border="0"> <tr> <td>Op.</td> <td>Stand-by</td> <td>Total</td> </tr> <tr> <td>1 unit</td> <td>0 unit</td> <td>1 unit</td> </tr> </table> <p>From Calculation of the Capacity of TE Unit</p> <p>0.6 m³/min</p> <p>From Calculation Sheet of Pumps (STP)</p> <p>42 m</p> <p>Dia.50mm × 0.6 m³/min × 42 m × 7.4kW × 1 lot (proposed) (2 pumps/ lot)</p>	Op.	Stand-by	Total	1 unit	0 unit	1 unit
Op.	Stand-by	Total						
1 unit	0 unit	1 unit						
<p>5 Defoaming Pump</p> <p>1.Design Condition</p> <p>Type</p> <p>Unit Number</p> <p>Nozzle Number</p> <p>2.Design Criteria</p> <p>Required Nozzle Water Volume</p> <p>3.Calculation</p> <p>Discharge Flow Per Unit</p> <p>Total Pump Head</p> <p>4.Specification</p>	<p>UN</p> <p>UN1</p> <p>Vo</p> <p>QU1</p> <p>H</p>	<p>Submersible Turbine Pump</p> <table border="0"> <tr> <td>Op.</td> <td>Stand-by</td> <td>Total</td> </tr> <tr> <td>1 unit</td> <td>1 unit</td> <td>2 units</td> </tr> </table> <p>12 units/train × 4 trains (Ultimate)</p> <p>From Calculation of the Capacity of Defoaming Pump</p> <p>8 L/min/nozzle</p> <p>0.6 m³/min</p> <p>From Calculation Sheet of Pumps (STP)</p> <p>29 m</p> <p>Dia.100 mm × 0.6 m³/min × 29 m × 3.7 kW × 2 units (proposed)</p>	Op.	Stand-by	Total	1 unit	1 unit	2 units
Op.	Stand-by	Total						
1 unit	1 unit	2 units						

M07 Sludge Treatment Facility

ITEM	SYMBOL	DESIGN	
1 Sludge Dewatering Unit			
1.Design Condition			
Type		Multi-Diskplate Screw Press	
Inlet SS Load	S	2,397	kg/ day
Inlet Sludge Volume	Vo	799	m ³ / day
Sludge Solids Content	Ssc	0.3	%
2.Design Criteria			
Solid Load per Unit	SL	179	kg-DS/hr
Operation Time	T1	94	hr/week (104hr × 0.9)
	T2	22	hours/day (24hr × 0.9)
2.Calculation			
Unit Number	UN	$S \times (7 / T1) / SL =$	1.0 unit
			therefore
		Ope.	
		Stand-by	1 unit
		Total	2 units
3.Specification		180 kg-DS/ hr × Approx.6 kW × 2 units (proposed)	

ITEM	SYMBOL	DESIGN
2 Polymer Dissolving Tank		
1.Design Condition		These tanks are used for sludge dewatering unit
Type		Cylindrical Steel Tank
Unit Number	UN	2 units
Inlet SS Load(Dewatering)	S2	2,397 kg/ day
Unit Number (Dewatering)	UNd	1 unit
Sludge Dewatering Unit Capacity	SLd	179 kg-DS/ hr
2.Design Criteria		
Dosage rate per DS(Dewatering)	Ird	1.5 %
Dissolving Concentration	DC	0.2 %
3.Calculation		
Polymer Consumption Weight(Dewatering)	W2	$S2 \times Ird \times 7/5 = 64 \text{ kg/ day}$
Tank Volume	Vo	$W2 \times 100 / DC \times 10^{-3} / UN = 16.1 \text{ m}^3 / \text{tank}$ therefore $17 \text{ m}^3 / \text{tank}$
Polymer Consumption Weight	C	$Vo \times DC = 34.0 \text{ kg/ tank}$
4.Specification		$17 \text{ m}^3 \times \text{Dia.} 2,700 \text{ mm} \times \text{Height } 3.6 \text{ m} \times 2 \text{ units (proposed)}$ (Agitator 11kw)

ITEM	SYMBOL	DESIGN			
3 Polymer Feeder					
1.Design Condition					
Type		Constant Chemical Feeder			
Unit Number	UN	2	units		
Polymer Consumption Weight	C	34.0	kg/tank		
Polymer Consumption Weight (Dewatering)	W2	64	kg/day		
Polymer Density	η_1	0.5	kg/L		
2.Design Criteria					
Feeding Time	T	20	min/tank		
Allowance	AL	30	%		
Storage Days (Hopper)	SD	more than	1	day	
3.Calculation					
Feeder Capacity	Q	$C / T \times (100 + AL) / 100 =$		2.21	kg/min
Hopper Volume	Vo	$(W1+W2) \times SD / UN / \eta_1 =$		64	L
				Therefore	100 L
4.Specification					
2.3 kg/ min \times 0.4 kW \times 2 units (proposed)					
4 Polymer Feed Pump For Dewatering					
1.Design Condition					
Type		Progressive Cavity Pump			
Unit Number	UN	Ope.	Stand-by	Total	
		1	1	2	units
Dewatring Solid Load	SL	179	kg-DS/hr		
2.Design Criteria					
Dosage rate per DS	Ir	1.5	%		
Dissolution Concentration	DC	0.2	%		
Control range	CR	50% to 150%			
3.Calculation					
Discharge Flow per Unit	QU	$SL \times Ir / DC \times 10^{-3} \times CR =$		0.7	m^3/hr to $2.0 m^3/hr$
Total Pump Head	H				20 m
				(Based on Manufacturer's Information)	
4.Specification					
Dia.50mm \times 0.7- 2.0 m^3/hr \times 20 m \times 1.5 kW \times 2 units (proposed)					

ITEM	SYMBOL	DESIGN						
5 Waste Water Tank Mixer								
1.Design Condition								
Type		Submersible Propeller Mixer						
Unit Number	UN	<table style="width:100%; border:none;"> <tr> <td style="width:33%;">Ope.</td> <td style="width:33%;">Stand-by</td> <td style="width:33%;">Total</td> </tr> <tr> <td style="text-align:center;">1 unit</td> <td style="text-align:center;">0 units</td> <td style="text-align:center;">1 unit</td> </tr> </table>	Ope.	Stand-by	Total	1 unit	0 units	1 unit
Ope.	Stand-by	Total						
1 unit	0 units	1 unit						
Tank Number	TN	1 tank						
Tank Volume	V	113 m ³ /tank (W 5m ×L 5m × WD4.5m)						
2.Design Criteria	W	5 w/m ³						
3.Calculation		$V \times TN \times W / UN / 1000 =$ 0.6 kW therefore 1.5 kW						
4.Specification		1.5 kW × 1 unit (proposed) (Based on Manufacture's Information)						
6 Waste Water Pump								
1.Design Condition								
Type		Non-clog Type Sludge Pump						
Unit Number	UN	<table style="width:100%; border:none;"> <tr> <td style="width:33%;">Ope.</td> <td style="width:33%;">Stand-by</td> <td style="width:33%;">Total</td> </tr> <tr> <td style="text-align:center;">1 units</td> <td style="text-align:center;">1 units</td> <td style="text-align:center;">2 units</td> </tr> </table>	Ope.	Stand-by	Total	1 units	1 units	2 units
Ope.	Stand-by	Total						
1 units	1 units	2 units						
Waste Water Tank Volume	Vo	113 m ³						
2.Design Criteria								
Operation Time	T	60 min Against Waste Water Volume						
3.Calculation								
Discharge Flow Per Unit	QU	$V_o / T / UN \times (1 + AL / 100) =$ 1.9 m ³ /min						
Total Pump Head	H	From Table1. Friction Loss Calculation Sheet 14 m						
4.Specification		Dia.100 mm × 2.0 m ³ / min × 14 m × 11 kW × 2 units (proposed)						

<p>7 Sludge Cake Hopper</p> <p>1.Design Condition</p> <p>Type</p> <p>Unit Number</p> <p>Sludge Volume (Solid)</p> <p>2.Specification</p> <p>3.Number Of Dump Trip (Ultimate)</p>	<p>UN</p> <p>Vo</p>	<p>Motor Driven Cutgate Type</p> <p>1 unit</p> <p>27 m³/day (Ultimate)</p> <p>15 m³ × (2.2 × 2) kW × 1unit (proposed)</p> <p>2 to 3 Times/day (Approx.)</p>
---	---------------------	---

ITEM	SYMBOL	DESIGN																
8 Biological Odor Control																		
1.Design Condition		Biological Odor Control																
Type																		
Unit Number	UN	<table border="0"> <tr> <td>Op.</td> <td>Stand-by</td> <td>Total</td> </tr> <tr> <td>1 unit</td> <td>0 unit</td> <td>1 unit</td> </tr> </table>	Op.	Stand-by	Total	1 unit	0 unit	1 unit										
Op.	Stand-by	Total																
1 unit	0 unit	1 unit																
Odor Gas Flow	Q	<table border="0"> <tr> <td>m³/min</td> <td>therefore</td> <td>40 m³/min</td> </tr> </table>	m ³ /min	therefore	40 m ³ /min													
m ³ /min	therefore	40 m ³ /min																
<table border="1"> <tr> <td>Grit Chamber Channel</td> <td>10.0 m³/min</td> </tr> <tr> <td>Machinery in Grit Chamber</td> <td>8.0 m³/min</td> </tr> <tr> <td>Distibution Chamber</td> <td>2.0 m³/min</td> </tr> <tr> <td>Dewatering Unit</td> <td>4.0 m³/min</td> </tr> <tr> <td>Machinery in Sludge Facilities</td> <td>10.0 m³/min</td> </tr> <tr> <td>Scum Pit</td> <td>4.0 m³/min</td> </tr> <tr> <td>Waste Water Tank</td> <td>2.0 m³/min</td> </tr> </table>		Grit Chamber Channel	10.0 m ³ /min	Machinery in Grit Chamber	8.0 m ³ /min	Distibution Chamber	2.0 m ³ /min	Dewatering Unit	4.0 m ³ /min	Machinery in Sludge Facilities	10.0 m ³ /min	Scum Pit	4.0 m ³ /min	Waste Water Tank	2.0 m ³ /min			
Grit Chamber Channel	10.0 m ³ /min																	
Machinery in Grit Chamber	8.0 m ³ /min																	
Distibution Chamber	2.0 m ³ /min																	
Dewatering Unit	4.0 m ³ /min																	
Machinery in Sludge Facilities	10.0 m ³ /min																	
Scum Pit	4.0 m ³ /min																	
Waste Water Tank	2.0 m ³ /min																	
2.Design Criteria																		
Gas Velocity	LV	0.1 m/sec																
	SV	200 m ³ /m ³ /h																
3.Calculation																		
Required Section Area	A	Q/LV/60=	More than	6.67 m ²														
Required Media Volume	V	Q×60/SV=	Approx.	12 m ³														
4. Specification		40 m ³ / min × 1 unit																

ITEM	SYMBOL	DESIGN		
9 Deodorization Fan				
1.Design Condition				
Type		Centrifugal Fan		
Unit Number	UN	Ope.	Stand-by	Total
		1 unit	1 unit	2 unit
Odor Gas Flow	Q	40 m ³ /min		
2.Calculation				
Total Fan Head	H	2.5 kPa		
3. Specification		40 m ³ / min × 2.5 kPa × 5.5 kW × 2 units		

Calculation sheet of pumps (STP)

1 Equip. No.	Pump Name	Grit Pump	Oil Discharge Pump	Sump Drain Pump	Scum Pump	Sump Drain Pump	Return Sludge Pump	Waste Sludge Pump	Utility Water Supply Unit	Deforming Pump	Waste Water Pump	Sump Drain Pump
2 Pump Type		Sub.	Sub.	Sub.	Sub.	Sub.	Hor.	Sub.	Sub.	Sub.	Sub.	Sub.
3	q : Capacity (m ³ /min)	0.5	0.2	0.3	0.5	0.3	3.2	1.1	0.6	0.6	2.0	0.3
4	N : Operation number	1	1	1	1	1	2	1	1	1	1	1
Total Head												
H=ha+hf1+hf2+hf3+hf4												
5	ha :Actual head (m) =DWL-SWL	5.0	3.3	5.0	10.5	5.0	2.78	7.8	5.0	5.0	9.5	1.0
6	DWL (m)				13.5		10.2				13.5	
7	SWL (m)				3.0		7.42				4.0	
8	hf1 : Straight pipe loss (m = (10.666 × Q ^{1.85}) × L × Cc (C ^{1.85} × D ^{4.85})	0.828	1.178	0.151	1.420	0.163	2.428	2.828	0.992	0.744	1.262	1.444
9	Q : Flow (m ³ /sec) =q × N/60	0.008	0.003	0.005	0.008	0.005	0.107	0.018	0.010	0.010	0.033	0.005
10	C : Coefficient DCIP:110 Steel pipe : 100 HDPE : 130	110	100	130	130	130	130	130	130	130	130	110
11	D : Pipe Dia. (m)	0.08	0.0657	0.08	0.0964	0.0788	0.2462	0.1406	0.1406	0.1406	0.1976	0.08
12	L : Pipe length (m)	12	30	10	90	10	100	200	280	210	200	70
13	Cc : Correction coefficient Water: 1.0 Sludge: WT99.2% : 1.3	1.3	1.3	1.0	1.0	1.0	1.3	1.3	1.0	1.0	1.0	1.0
14	hf2 : Bend and others loss (m) =hf1 × 0.3 (in the building)	0.248	0.353	0.045	0.426	0.049	0.728	0.848	0.298	0.223	0.379	0.433
15	hf3 : Pump around loss (m) Horizontal type : 2.0m Submersible type : 0.7m	0.7	0.7	0.7	0.7	0.7	2	0.7	0.7	0.7	0.7	0.7
16	hf4 :Other head	0	0	0	0	0	0	0	30	20	0	0
17	H' =ha+hf1+hf2+hf3+hf4 (m)	6.78	5.53	5.90	13.05	5.91	7.94	12.18	36.99	26.67	11.84	3.58
18	H : Total head (m)	7.0	6.0	6.0	14.0	6.0	9.0	14.0	42.0	29.0	14.0	5.0
V	Velocity	1.66	0.98	1.00	1.14	1.03	2.24	1.18	0.64	0.64	1.09	1.00
Motor Power							Max.					
19	BKW =0.163*SG*q*H/Pe (kW)	1.90	0.49	0.77	3.00	0.77	7.58	4.18	6.32	3.55	7.61	0.64
20	SG :Specific gravity	1.0	1.0	1.05	1.05	1.05	1.05	1.0	1.0	1.0	1.0	1.05
21	Pe :Pump efficiency	0.3	0.4	0.4	0.4	0.4	0.65	0.6	0.65	0.8	0.6	0.4
22	kW =BKW × C	2.187	0.562	0.886	3.444	0.886	8.721	4.811	7.267	4.077	8.748	0.738
23	C :Coefficient (1.15)	1.15	1.15	1.15	1.15	1.15	1.15	1.15	1.15	1.15	1.15	1.15
24	Motor Power (kW)	2.2	0.75	1.5	3.7	1.5	11	5.5	7.4	3.7	11	1.5
		80	65	80	100	80	250	150	150	150	200	80
	Above ground	304 SS	304 SS	DIP	DIP	DIP	DIP	DIP	SGPW	SGPW	DIP	DIP
	Under ground	-	HDPE		HDPE	HDPE	HDPE	HDPE	HDPE	HDPE	HDPE	-
			75	90	110	90	280	160	160	160	225	

Calculation of the Capacity of Utility TE Water Supply Unit

Facility	Purpose of Use	Total Number of Unit	①	②	③	④	⑤	⑥	⑦	Remarks
			Number of Duty Operation unit	Number of Simultaneous Operation unit	Water Supply Amount per Unit L/min·unit	Water Supply Hours Hr/d·unit	Maximum Instantaneous Water Supply Amount L/min	Hourly Maximum Water Supply Amount m ³ /h	Daily Water Supply Amount m ³ /d	
Grit Chamber										
	Washing Water for Screen	2	2	2	20	4.0	40	2.4	9.6	
	Washing Water for Grit Separator	1	1	1	40	0.5	40	1.2	1.2	
	Washing Water for Scum Screen	1	1	1	25	1.5	25	1.5	2.3	
	Spray Water for Oil Skimmer	1	1	1	32	0.3	32	0.6	0.6	8L/min/pc × 4pcs=32L/min
	Pressure Water for Grit Collector	2	2	1	50	0.2	50	0.6	1.2	
	Sub-Total						187			
Final Sedimentation Tank										
	Defoaming Water	4	4	4	32	3	128	7.7	23.0	8L/min/pc × 4pcs/train = 32L/min/train
	Sub-Total						128			
Sludge Treatment										
	Washing Water for Dewatering	2	1	1	20	24	20	1.2	28.8	
	Biological Odor Control	1	1	1	100	3	100	6.0	18.0	
	Sub-Total						120			
Others										
	Washing Water for Pippings, Cleaning Water	Each pipe	2	2	50	0.2	100	1.2	1.2	
	Sub-Total						100			
TOTAL										
	Strainer Water Supply Amount						535		86	⇒ Utility TE Supply Water Unit 0.6m ³ /min

Calculation of the Capacity of Defoaming Pump

Facility	Purpose of Use	Total Number of Unit	①	②	③	④	⑤	⑥	⑦	Remarks
			Number of Duty Operation unit	Number of Simultaneous Operation unit	Water Supply Amount per Unit L/min·unit	Water Supply Hours Hr/d·unit	Maximum Instantaneous Water Supply Amount L/min	Hourly Maximum Water Supply Amount m ³ /h	Daily Water Supply Amount m ³ /d	
Oxidation Ditch	Defoaming Water for OD Tank	4	4	4	96	3	384	23.0	69.1	8L/min/pc × 12pcs/train = 96L/min
TOTAL	Strainer Water Supply Amount						384		69	⇒ Defoaming Pump 0.6m ³ /min

Calculation of the Capacity of Potable Water Consumption for Chemical Dissolving

Facility	Purpose of Use	Total Number of Unit	①	②	③	④	⑤	⑥	⑦	Remarks
			Number of Duty Operation unit	Number of Simultaneous Operation unit	Water Supply Amount per Unit L/min·unit	Water Supply Hours Hr/d·unit	Maximum Instantaneous Water Supply Amount L/min	Hourly Maximum Water Supply Amount m ³ /h	Daily Water Supply Amount m ³ /d	
Sludge Treatment										
	Polymer Dissolving Water	2	2	1	300	1	300	18.0	36.0	17m ³ × 2 tanks
Chlorine Room										
	Calcium Hypochlorite Dissolving Water	1	1	1	150	1	150	9.0	9.0	8m ³ × 1 tanks
TOTAL	Potable Water Supply Amount						450		45	Max.

SECTION C2: Calculation Sheets for Water Hammer in the pressure mains**C2.1 Input data and Conclusion of Water Hammer**

PS-1 Condition of surge analysis

Pump spec.

Rated flow	6 Liter/sec/unit
Rated head	14 m
Pump output	5.5 kW
Duty pump unit	1 unit
Rated speed	1500 min ⁻¹
Standard inertia	0.5 Nm ²
Force main dia.;	96.4 mm ϕ
Length of force main;	1090 m
Number of force main;	1 unit
Material of force main;	HDPE (C = 130)
Elevation of pump;	-2.7 m
Grade level of sump well;	-1.6 m (LWL)
Elevation of discharge point;	-0.35 m
Grade level of discharge point	-0.3 m

Node No.	Length of force main from pump pit (m)	Center level of force main (m)	Others
Pump	0	-1.6	LWL
1	80	0.5	
2	80	1.1	
3	130	0.1	
4	60	0.0	
5	210	0.5	
6	130	1.0	
7	150	0.0	
8	75	0.0	
9	75	0.0	
10	50	-0.1	
Discharge Point	50	-0.3	

Result of surge analysis; (refer to attached sheet of surge analysis)

min. head	More than -9.4 m	>	-7 m	required fly-wheel
Required inertia (WR²)	More than 2.0 Nm²			
min. head	-6.98 m	<	-7 m	O.K.(with flywheel)

PS-2 Condition of surge analysis

Pump spec.

Rated flow	10.8 Liter/sec/unit
Rated head	40 m
Pump output	22 kW
Duty pump unit	1 unit
Rated speed	1500 min ⁻¹
Standard inertia	3.7 Nm ²
Force main dia.;	96.4 mm ϕ
Length of force main;	684 m
Number of force main;	1 unit
Material of force main;	HDPE (C = 130)
Elevation of pump;	-5.2 m
Grade level of sump well;	-4.0 m (LWL)
Elevation of discharge point;	13.7 m
Grade level of discharge point	14.2 m (Max. level)

Node No.	Length of force main from pump pit (m)	Center level of force main (m)	Others
Pump	0	-4.0	LWL
1	36	-0.6	
2	50	-0.3	
3	86	0.1	
4	58	0.2	
5	135	0.0	
6	30	0.2	
7	100	2.0	
8	28	3.7	
9	45	6.0	
10	44	12.2	
Discharge Point	72	14.2	Max. level

Result of surge analysis; (refer to attached sheet of surge analysis)

min. head	More than -7.2 m	> -7 m	required fly-wheel
Required inertia (WR²)	More than 15 Nm²		
min. head	-3.17 m	< -7 m	O.K.(with flywheel)

PS-3 Condition of surge analysis

Pump spec.

Rated flow	31.6 Liter/sec/unit
Rated head	25 m
Pump output	22 kW
Duty pump unit	1 unit
Rated speed	1500 min ⁻¹
Standard inertia	3.7 Nm ²
Force main dia.;	197.6 mm ϕ
Length of force main;	355 m
Number of force main;	1 unit
Material of force main;	HDPE (C = 130)
Elevation of pump;	-3.2 m
Grade level of sump well;	-2.0 m (LWL)
Elevation of discharge point;	17.9 m
Grade level of discharge point	18 m (Max. level)

Node No.	Length of force main from pump pit (m)	Center level of force main (m)	Others
Pump	0	-2.0	LWL
1	25	2.0	
2	93	5.3	
3	32	6.7	
4	15	7.0	
5	15	10.0	
6	15	11.0	
7	15	12.0	
8	15	13.0	
9	15	14.0	
10	15	15.0	
11	15	16.0	
12	15	16.6	
13	30	17.0	
Discharge Point	40	18.0	Max. level

Result of surge analysis; (refer to attached sheet of surge analysis)

min. head	-10 m	>	-7 m	required fly-wheel
Required inertia (WR²)	More than 6.2 Nm ²			
min. head	-6.46 m	<	-7 m	O.K.(with flywheel)

PS-4 Condition of surge analysis

Pump spec.

Rated flow	80 Liter/sec/unit
Rated head	17 m
Pump output	22 kW
Duty pump unit	1 unit
Rated speed	1500 min ⁻¹
Standard inertia	3.7 Nm ²
Force main dia.;	312 mm ϕ
Length of force main;	443 m
Number of force main;	1 unit
Material of force main;	HDPE (C = 130)
Elevation of pump;	-4.6 m
Grade level of sump well;	-3.6 m (LWL)
Elevation of discharge point;	8.25 m
Grade level of discharge point	8.4 m (Max. level)

Node No.	Length of force main from pump pit (m)	Center level of force main (m)	Others
Pump	0	-3.6	LWL
1	25	2.0	
2	25	4.3	
3	40	5.4	
4	60	4.2	
5	50	3.0	
6	20	3.0	
7	30	4.0	
8	30	5.0	
9	35	6.0	
10	35	7.0	
Discharge Point	93	8.4	Max. level

Result of surge analysis; (refer to attached sheet of surge analysis)

min. head	More than -10 m	>	-7 m	required fly-wheel
Required inertia (WR²)	More than 20 Nm ²			
min. head	-6.41 m	<	-7 m	O.K.(with flywheel)

PS-5 Condition of surge analysis

Pump spec.

Rated flow	73.3 Liter/sec/unit
Rated head	42 m
Pump output	55 kW
Duty pump unit	2 unit
Rated speed	1500 min ⁻¹
Standard inertia	12.9 Nm ²
Force main dia.;	395.6 mm ϕ
Length of force main;	1340 m
Number of force main;	1 unit
Material of force main;	HDPE (C = 130)
Elevation of pump;	-7 m
Grade level of sump well;	-5.7 m (LWL)
Elevation of discharge point;	27 m
Grade level of discharge point	28.5 m (HWL)

Node No.	Length of force main from pump pit (m)	Center level of force main (m)	Others
Pump	0	-5.7	LWL
1	245	0.5	
2	245	1.3	
3	135	-0.1	
4	100	-0.2	
5	100	-0.1	
6	100	-0.6	
7	100	5.7	
8	117	6.3	
9	33	11.3	
10	20	13.4	
11	30	17.8	
12	50	24.5	
13	20	27.1	
14	33	28.0	
Discharge Point	12	28.5	HWL

Result of surge analysis; (refer to attached sheet of surge analysis)

min. head	More than -10 m	> -7 m	required fly-wheel
Required inertia (WR²)	More than 37 Nm²		
min. head	-5.31 m	< -7 m	O.K.(with flywheel)

PS-6 Condition of surge analysis (No profile of existing force main)

Pump spec.

Rated flow	10.8 Liter/sec/unit	
Rated head	17 m	
Pump output	5.5 kW	
Duty pump unit	1 unit	
Rated speed	1500 min ⁻¹	
Standard inertia	0.75 Nm ²	
Force main dia.;	150 mm ϕ	connect to existing pipe
Length of force main;	400 m	
Number of force main;	1 unit	
Material of force main;	DCIP (C = 80)	
Elevation of pump;	-1.4 m	
Grade level of sump well;	-0.5 m (LWL)	
Elevation of discharge point;	9.25 m	
Grade level of discharge point	10 m (Max. level)	

No need fly-wheel due to more gradual condition than PS 11.

PS-7 Condition of surge analysis

Pump spec.

Rated flow	23.3 Liter/sec/unit
Rated head	24 m
Pump output	15 kW
Duty pump unit	1 unit
Rated speed	1500 min ⁻¹
Standard inertia	1.5 Nm ²
Force main dia.;	140.6 mm ϕ
Length of force main;	240 m
Number of force main;	1 unit
Material of force main;	HDPE (C = 130)
Elevation of pump;	-3.4 m
Grade level of sump well;	-1.9 m (LWL)
Elevation of discharge point;	14 m
Grade level of discharge point	15.6 m (Max. level)

Node No.	Length of force main from pump pit (m)	Center level of force main (m)	Others
Pump	0	-1.9	LWL
1	21	1.6	
2	10	3.0	
3	18	5.9	
4	25	7.5	
5	25	9.0	
6	25	10.5	
7	34	12.8	
8	41	14.2	
Discharge Point	41	15.6	Max. level

Result of surge analysis; (refer to attached sheet of surge analysis)

min. head	More than -10 m	>	-7 m	required fly-wheel
Required inertia (WR²)	More than 5 Nm²			
min. head	-6.13 m	<	-7 m	O.K.(with flywheel)

PS-8 Condition of surge analysis

Pump spec.

Rated flow	10 Liter/sec/unit
Rated head	24 m
Pump output	7.5 kW
Duty pump unit	1 unit
Rated speed	1500 min ⁻¹
Standard inertia	1.0 Nm ²
Force main dia.;	96.4 mm ϕ
Length of force main;	640 m
Number of force main;	1 unit
Material of force main;	HDPE (C = 130)
Elevation of pump;	-4.5 m
Grade level of sump well;	-3.5 m (LWL)
Elevation of discharge point;	0 m
Grade level of discharge point	2.1 m (HWL)

Node No.	Length of force main from pump pit (m)	Center level of force main (m)	Others
Pump	0	-2.5	LWL
1	49	0.2	
2	55	0.1	
3	58	0.3	
4	18	0.5	
5	39	0.2	
6	95	1.1	
7	66	0.5	
8	100	1.9	
9	50	2.5	
10	50	1.9	
Discharge Point	60	2.1	HWL

Result of surge analysis; (refer to attached sheet of surge analysis)

min. head	More than -10 m	>	-7 m	required fly-wheel
Required inertia (WR²)	More than 4.5 Nm ²			
min. head	-6.92 m	<	-7 m	O.K.(with flywheel)

PS-9 Condition of surge analysis

Pump spec.

Rated flow	93.3 Liter/sec/unit
Rated head	11 m
Pump output	15 kW
Duty pump unit	2 unit
Rated speed	1500 min ⁻¹
Standard inertia	2.3 Nm ²
Force main dia.;	395.6 mm ϕ
Length of force main;	700 m
Number of force main;	1 unit
Material of force main;	HDPE (C = 130)
Elevation of pump;	-3.5 m
Grade level of sump well;	-2.9 m (LWL)
Elevation of discharge point;	0.4 m
Grade level of discharge point	0.6 m (HWL)

Node No.	Length of force main from pump pit (m)	Center level of force main (m)	Others
Pump	0	-2.9	LWL
1	50	0.5	
2	100	0.6	
3	110	0.6	
4	87	-0.1	
5	79	-0.1	
6	74	-0.1	
7	100	0.0	
8	40	0.1	
9	30	0.4	
Discharge Point	30	0.6	HWL

Result of surge analysis; (refer to attached sheet of surge analysis)
min. head -7.44 m > -7 m

No need fly-wheel
(With air valve)

PS-10 Condition of surge analysis

Pump spec.

Rated flow	103.3 Liter/sec/unit
Rated head	42 m
Pump output	75 kW
Duty pump unit	2 unit
Rated speed	1500 min ⁻¹
Standard inertia	23 Nm ²
Force main dia.;	439.7 mm φ
Length of force main;	2750 m
Number of force main;	1 unit
Material of force main;	HDPE (C = 130)
Elevation of pump;	-6.2 m
Grade level of sump well;	-4.9 m (LWL)
Elevation of discharge point;	21 m
Grade level of discharge point	23 m (HWL)

Node No.	Length of force main from pump pit (m)	Center level of force main (m)	Others
Pump	0	-4.9	LWL
1	10	2.5	
2	185	5.2	
3	115	15.7	
4	137	17.1	
5	63	21.1	
6	183	23.5	A.V.
7	167	13.9	
8	220	5.7	
9	130	9.1	
10	250	5.4	
11	227	14.4	
12	373	5.9	
Discharge Point	700	23.0	HWL

min. head More than -10 m > -7 m
Required inertia (WR²) - Nm²
 min. head -6.6 m < -7 m

required closed surge tank

O.K.
 (With closed surge tank)
 only flywheel is not enough.

PS-11 Condition of surge analysis

Pump spec.

Rated flow	43.3 Liter/sec/unit
Rated head	31 m
Pump output	37 kW
Duty pump unit	1 unit
Rated speed	1500 min ⁻¹
Standard inertia	6.1 Nm ²
Force main dia.;	200 mm ϕ
Length of force main;	380 m
Number of force main;	1 unit
Material of force main;	DIP (C = 80)
Elevation of pump;	-4.4 m
Grade level of sump well;	-3.2 m (LWL)
Elevation of discharge point;	14 m
Grade level of discharge point	15 m (Max. level)

Node No.	Length of force main from pump pit (m)	Center level of force main (m)	Others
Pump	0	-3.2	LWL
1	40	0.0	
2	40	1.0	
3	40	2.0	
4	20	2.5	
5	20	3.0	
6	35	5.0	
7	35	7.0	
8	35	9.0	
9	35	12.0	
10	40	13.5	
Discharge point	40	15.0	Max. level

Result of surge analysis; (refer to attached sheet of surge analysis)

min. head -5.77 m < -7 m

No Need fly-wheel

PS-12 Condition of surge analysis

Pump spec.

Rated flow	58.3 Liter/sec/unit
Rated head	33 m
Pump output	45 kW
Duty pump unit	2 unit
Rated speed	1500 min ⁻¹
Standard inertia	5.6 Nm ²
Force main dia.;	351.7 mm ϕ
Length of force main;	1160 m
Number of force main;	1 unit
Material of force main;	HDPE (C = 130)
Elevation of pump;	-3.1 m
Grade level of sump well;	-2.66 m (LWL)
Elevation of discharge point;	21 m
Grade level of discharge point	23 m (HWL)

Node No.	Length of force main from pump pit (m)	Center level of force main (m)	Others
Pump	0	-1.4	LWL
1	100	1.6	
2	45	2.1	
3	25	2.6	
4	50	3.8	
5	35	4.1	
6	40	5.4	
7	52	6.5	
8	53	6.8	
9	60	6.1	
10	270	7.5	
11	150	10.0	
12	40	11.1	
13	60	15.9	
14	50	18.4	
15	60	20.4	
Discharge Point	70	23.0	HWL

Result of surge analysis; (refer to attached sheet of surge analysis)

min. head	More than -10 m	>	-7 m	required fly-wheel
Required inertia (WR²)	More than 45 Nm ²			
min. head	-6.66 m	<	-7 m	O.K.(with flywheel)

PS-13 Condition of surge analysis

Pump spec.

Rated flow	6 Liter/sec/unit
Rated head	20 m
Pump output	5.5 kW
Duty pump unit	1 unit
Rated speed	1500 min ⁻¹
Standard inertia	0.5 Nm ²
Force main dia.;	96.4 mm ϕ
Length of force main;	230 m
Number of force main;	1 unit
Material of force main;	HDPE (C = 130)
Elevation of pump;	-1.7 m
Grade level of sump well;	-1.0 m (LWL)
Elevation of discharge point;	13.4 m
Grade level of discharge point	13.5 m (Max. level)

Node No.	Length of force main from pump pit (m)	Center level of force main (m)	Others
Pump	0	-1.0	LWL
1	10	0.7	
2	20	1.1	
3	20	1.2	
4	20	1.0	
5	15	2.4	
6	15	2.8	
7	15	3.0	
8	15	3.5	
9	27	6.0	
10	28	8.5	
11	30	13.5	
Discharge Point	15	13.5	Max. level

Result of surge analysis; (refer to attached sheet of surge analysis)

min. head -6.94 m < -7 m

No need fly-wheel

PS-14 Condition of surge analysis

Pump spec.

Rated flow	7.5 Liter/sec/unit
Rated head	24 m
Pump output	7.5 kW
Duty pump unit	1 unit
Rated speed	1500 min ⁻¹
Standard inertia	1.0 Nm ²
Force main dia.;	96.4 mm ϕ
Length of force main;	230 m
Number of force main;	1 unit
Material of force main;	HDPE (C = 130)
Elevation of pump;	-2.8 m
Grade level of sump well;	-2.1 m (LWL)
Elevation of discharge point;	15.2 m
Grade level of discharge point	15.3 m (Max. level)

Node No.	Length of force main from pump pit (m)	Center level of force main (m)	Others
Pump	0	-2.1	LWL
1	20	3.3	
2	20	3.7	
3	20	4.3	
4	20	4.9	
5	30	6.2	
6	35	7.7	
7	20	9.2	
8	20	10.7	
9	20	12.2	
10	15	14.8	
Discharge Point	10	15.3	Max. level

Result of surge analysis; (refer to attached sheet of surge analysis)

min. head -8.11 m > -7 m

No need fly-wheel
(with Air Valve)

PS-15 Condition of surge analysis

Pump spec.

Rated flow	12.5 Liter/sec/unit
Rated head	43 m
Pump output	22 kW
Duty pump unit	1 unit
Rated speed	1500 min ⁻¹
Standard inertia	3.7 Nm ²
Force main dia.;	109.8 mm ϕ
Length of force main;	760 m
Number of force main;	1 unit
Material of force main;	HDPE (C = 130)
Elevation of pump;	-3.8 m
Grade level of sump well;	-2.6 m (LWL)
Elevation of discharge point;	21 m
Grade level of discharge point	23 m (HWL)

Node No.	Length of force main from pump pit (m)	Center level of force main (m)	Others
Pump	0	-2.6	LWL
1	50	1.0	
2	50	1.1	
3	80	2.3	
4	45	3.2	
5	55	4.6	
6	117	8.5	
7	68	13.0	
8	55	17.2	
9	110	21.8	
10	40	22.9	
Discharge Point	90	23.0	HWL

Result of surge analysis; (refer to attached sheet of surge analysis)

min. head	More than -10 m	>	-7 m	required fly-wheel
Required inertia (WR²)	More than 25 Nm ²			
min. head	-4.35 m	<	-7 m	O.K.(with flywheel)

PS-16 Condition of surge analysis

Pump spec.

Rated flow	25 Liter/sec/unit
Rated head	21 m
Pump output	11 kW
Duty pump unit	1 unit
Rated speed	1500 min ⁻¹
Standard inertia	1.3 Nm ²
Force main dia.;	197.6 mm ϕ
Length of force main;	600 m
Number of force main;	1 unit
Material of force main;	HDPE (C = 130)
Elevation of pump;	-5.2 m
Grade level of sump well;	-4.2 m (LWL)
Elevation of discharge point;	10 m
Grade level of discharge point	12.1 m (HWL)

Node No.	Length of force main from pump pit (m)	Center level of force main (m)	Others
Pump	0	-3.8	LWL
1	10	1.5	
2	30	-0.7	
3	30	-0.7	
4	37	-0.6	
5	38	-0.5	
6	33	0.2	
7	32	2.0	
8	55	2.0	
9	50	1.7	
10	100	2.3	
Discharge Point	165	12.1	HWL in STP

Result of surge analysis; (refer to attached sheet of surge analysis)

min. head -7.9 m > -7 m

No need fly-wheel
(with Air Valve)

PS-17 Condition of surge analysis

Pump spec.

Rated flow	208.3 Liter/sec/unit		
Rated head	15 m		
Pump output	55 kW		
Duty pump unit	1 unit		
Rated speed	1500 min ⁻¹	or	1000 min ⁻¹
Standard inertia	25.7 Nm ²		
Force main dia.;	624.3 mm ϕ		
Length of force main;	260 m		
Number of force main;	2 unit		
Material of force main;	HDPE (C = 130)		
Elevation of pump;	7.4 m		
Grade level of sump well;	9 m (LWL)		
Elevation of discharge point;	20.6 m		
Grade level of discharge point	20.8 m (Max. level)		


Node No.	Length of force main from pump pit (m)	Center level of force main (m)	Others
Pump	0	9.0	LWL
1	5	16.5	
2	25	15.0	
3	10	13.6	
4	25	16.0	
5	25	16.9	
6	35	17.8	
7	35	18.6	
8	35	19.5	
9	35	20.4	
Discharge Point	30	20.8	Max. level

Result of surge analysis; (refer to attached sheet of surge analysis)

min. head	-6.72 m	<	-7 m
min. head	-8.78 m	>	-7 m
Required inertia (WR²)	More than 50 Nm ²		
min. head	-7 m	<	-7 m

No need fly-wheel
in case of 1500 rpm
required fly-wheel
in case of 1000 rpm
O.K.(with flywheel)

C2.2 Simulation Data of Water Hammer in Pumping Stations




psi without flywheel

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	9.77	-4.43	265.099	95.843	-43.450	0.03687	14.82049
J-2	8.33	-5.63	287.993	81.744	-55.266	0.03687	14.63615
J-3	7.97	-5.65	211.092	78.207	-55.433	0.03687	14.15688
J-4	7.44	-6.01	196.714	73.029	-58.913	0.14747	14.19375
J-5	4.75	-8.04	273.505	46.564	-78.835	0.03687	13.38267
J-6	2.79	-9.54	284.300	27.332	-93.562	0.03687	13.41954
J-7	2.32	-9.24	205.488	22.723	-90.658	0.03687	13.08773
J-8	1.53	-9.32	240.621	15.023	-91.403	0.03687	12.90340
J-9	0.86	-8.36	257.874	8.463	-82.057	47.59457	12.71906
J-10	1.08	-6.34	264.141	10.585	-62.147	47.70517	12.60846
O-Pump-1	13.81	-0.61	3.687	135.448	-5.973	9.89089	15.00482
R-1	0.05	0.05	0.000	0.490	0.490	0.03687	0.03687
O-Pump-1	1.10	1.10	0.000	10.790	10.790	0.03687	0.03687

KYPipe
PIPE2310



pol with flywheel

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	9.77	-3.92	258.021	95.843	-38.477	0.03687	14.82049
J-2	8.33	-5.05	288.656	81.744	-49.531	0.03687	14.63615
J-3	7.97	-4.87	193.802	78.207	-47.733	0.03687	14.34122
J-4	7.44	-5.06	196.825	73.029	-49.593	0.14747	14.19375
J-5	4.75	-6.30	268.933	46.564	-61.765	0.03687	13.71447
J-6	2.89	-6.98	287.255	28.313	-68.474	0.03687	13.41954
J-7	2.32	-5.64	246.556	22.723	-55.367	0.03687	13.08773
J-8	1.53	-4.88	253.118	15.023	-47.858	0.03687	12.90340
J-9	0.75	-3.47	268.086	7.323	-34.032	0.03687	12.71906
J-10	0.32	-2.08	278.297	3.171	-20.368	0.03687	12.60846
O-Pump-1	13.81	-0.18	0.737	135.448	-1.739	9.99089	15.00482
R-1	0.05	0.05	0.000	0.490	0.490	0.03687	0.03687
O-Pump-1	1.10	1.10	0.000	10.790	10.790	0.03687	0.03687

KYPipe
PIPEPRO

pel with flywheel


SUMMARY OF MAX/MIN LINE PRESSURES:


START NODE	END NODE	MAX PRESS. psi or kPa	MIN PRESS. psi or kPa	Steady Press. at end nodes	Max/Probop at end nodes	Lowest/Press at end nodes
O-Pump-1	J-1	135.45	-38.48	135.45	95.84	137.19
J-1	J-2	95.84	-49.53	95.84	81.74	134.32
J-2	J-3	81.74	-49.53	81.74	78.21	131.27
J-3	J-4	78.21	-49.59	78.21	73.03	125.94
J-4	J-5	73.03	-61.77	73.03	46.56	122.62
J-5	J-6	46.56	-68.47	46.56	28.31	108.33
J-6	J-7	28.31	-68.47	28.31	22.72	96.79
J-7	J-8	22.72	-55.37	22.72	15.02	78.09
J-8	J-9	15.02	-47.86	15.02	7.32	62.88
J-9	J-10	7.32	-34.03	7.32	3.17	41.36
J-10	R-1	3.17	-20.37	3.17	0.49	23.54

***** END OF THIS SIMULATION *****

END RUN AT TIME 09:41:52

KYPipe Software






ps2 without flywheel

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	33.47	-6.67	4.890	328.332	-65.395	7.36611	12.72040
J-2	31.73	-7.66	4.766	311.256	-75.137	4.64260	12.59660
J-3	29.88	-9.31	4.240	293.088	-91.301	18.53900	12.41090
J-4	29.75	-9.98	3.745	291.892	-97.915	17.30098	12.28711
J-5	30.76	-10.12	2.662	301.715	-99.326	17.61049	11.97761
J-6	30.87	-10.12	2.445	302.875	-99.326	17.67239	11.91571
J-7	29.00	-10.04	2.259	284.492	-98.537	17.88904	11.73001
J-8	26.33	-10.12	2.600	258.336	-99.326	17.73429	11.66811
J-9	22.14	-10.11	2.755	217.150	-99.225	17.79639	11.63716
J-10	13.13	-10.12	11.761	128.807	-99.326	17.91999	11.54432
O-Pump-1	39.11	-1.53	1.424	383.630	-15.040	6.00431	12.01325
R-1	0.50	0.50	0.000	4.905	4.905	0.03095	0.03095
O-Pump-1	1.20	1.20	0.000	11.769	11.769	0.03095	0.03095

KYPipe PIPESYS




ps2 with flywheel

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	33.47	-0.27	0.093	328.332	-2.654	7.36611	12.93705
J-2	31.73	-0.64	0.186	311.256	-6.282	4.64250	12.81325
J-3	28.85	-1.04	0.248	283.027	-10.162	5.47816	12.62755
J-4	27.00	-0.95	0.186	265.654	-9.281	10.02779	12.50375
J-5	23.39	0.81	0.000	229.461	7.981	10.77058	12.19426
J-6	22.33	1.13	0.000	219.019	11.090	10.80153	12.13236
J-7	17.65	1.93	0.000	173.099	18.908	2.47600	11.91571
J-8	15.45	1.26	0.000	151.524	12.318	20.79839	11.85381
J-9	12.75	0.76	0.000	125.125	7.469	20.86029	11.76096
J-10	5.00	-3.17	3.590	49.002	-31.107	20.76744	11.66811
O-Pump-1	39.11	4.44	0.000	383.630	43.515	6.00431	13.02990
R-1	0.50	0.50	0.000	4.905	4.905	0.03095	0.03095
O-Pump-1	1.20	1.20	0.000	11.769	11.769	0.03095	0.03095

Flywheel Analysis Report




psi with flywheel


SUMMARY OF MAX/MIN LINE PRESSURES:

START NODE	END NODE	MAX PRESS. psi or kPa	MIN PRESS. psi or kPa	Steady Press. at end nodes	MaxPrDrop at end nodes	lowestPress at end nodes
0-Pump-1	J-1	383.63	-2.65	383.63	328.33	340.11
J-2	J-3	311.26	-10.16	311.25	283.02	317.54
J-1	J-2	328.33	-6.28	328.33	311.25	330.98
J-4	J-5	265.65	-9.28	265.65	229.46	274.93
J-3	J-4	283.03	-10.16	283.02	265.65	293.19
J-6	J-7	219.02	11.09	219.02	173.10	207.93
J-5	J-6	229.46	7.98	229.46	219.02	221.48
J-8	J-9	151.52	7.47	148.51	113.23	136.19
J-7	J-8	173.10	12.32	173.10	148.51	154.19
J-10	R-1	49.00	-31.11	39.97	4.90	71.08
J-9	J-10	185.13	-31.11	113.23	39.97	105.76

**** END OF THIS SIMULATION ****

END RUN AT TIME 09:53:40






ps3 without flywheel

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	34.82	-4.33	3.550	341.619	-42.473	22.92525	11.38740
J-2	29.04	-6.77	3.588	284.930	-66.400	13.78736	11.17490
J-3	26.88	-7.45	4.650	263.704	-73.055	13.86236	11.11240
J-4	26.09	-7.27	4.300	255.927	-71.281	13.89986	11.07490
J-5	22.77	-9.70	10.737	223.432	-95.124	19.60005	11.03740
J-6	20.70	-9.97	12.862	203.336	-97.796	19.56254	10.99990
J-7	18.94	-10.06	15.162	185.823	-98.721	13.77486	10.96240
J-8	17.70	-9.97	16.900	173.681	-97.803	13.81236	10.93740
J-9	15.18	-10.12	20.775	148.945	-99.326	13.79986	10.91241
J-10	12.60	-9.67	26.350	123.585	-94.857	13.81236	10.87491
J-11	9.87	-8.63	35.814	96.863	-84.663	13.78736	10.83741
J-12	6.83	-6.57	34.601	67.047	-64.412	13.76236	10.79991
J-13	3.98	-3.41	17.050	39.020	-33.436	16.77487	10.76241
O-Pump-1	41.17	0.67	0.000	403.915	6.568	22.92525	11.44990
R-1	0.10	0.10	0.000	0.981	0.981	0.01250	0.01250
O-Pump-1	1.20	1.20	0.000	11.770	11.770	0.01250	0.01250

KYPipe PIPESYS



po3 with flywheel

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	33.85	-2.17	2.475	332.020	-21.314	20.02507	11.39990
J-2	27.64	-3.93	2.700	271.194	-38.581	14.06236	11.18740
J-3	24.93	-4.29	3.000	244.579	-42.089	14.01236	11.11240
J-4	23.83	-3.95	1.925	233.799	-38.718	13.97486	11.07490
J-5	19.87	-6.21	9.125	194.936	-60.955	13.98736	11.03740
J-6	17.69	-6.36	10.975	173.587	-62.433	13.92486	10.99990
J-7	15.65	-6.37	12.350	152.584	-62.503	13.88736	10.96240
J-8	13.72	-6.22	14.500	134.695	-60.991	13.82486	10.92490
J-9	12.08	-6.46	18.650	118.521	-63.359	13.81236	10.91241
J-10	9.96	-6.01	22.313	97.688	-58.961	13.82486	10.87491
J-11	7.36	-5.28	29.363	72.156	-51.813	13.81236	10.83741
J-12	5.14	-3.82	25.713	50.400	-37.476	13.74986	10.79991
J-13	3.06	-1.77	11.825	29.974	-17.376	13.73736	10.78741
O-Pump-1	39.47	2.73	0.000	387.226	26.810	22.95025	11.44990
R-1	0.10	0.10	0.000	0.981	0.981	0.01250	0.01250
O-Pump-1	1.20	1.20	0.000	11.770	11.770	0.01250	0.01250

KYPipe
PIPE2016


p3 with flywheel


SUMMARY OF MAX/MIN LINE PRESSURES:

START NODE	END NODE	MAX PRESS. psi or kPa	MIN PRESS. psi or kPa	Steady Press. at end nodes	MaxFrDrop at end nodes	LowestPress at end nodes			
O-Pump-1	J-1	387.23	-21.31	230.33	177.54	203.52	198.86	26.81	-25.98
J-1	J-2	332.02	-38.58	177.54	138.57	198.86	177.15	-21.31	-60.29
J-2	J-3	271.19	-42.09	138.57	122.57	177.15	164.65	-38.58	-54.59
J-3	J-4	244.58	-42.09	122.57	118.56	164.65	157.28	-42.09	-46.10
J-4	J-5	233.80	-60.95	118.56	88.86	157.28	149.02	-38.72	-69.21
J-5	J-6	194.94	-62.43	88.86	77.19	149.02	139.62	-60.95	-71.83
J-6	J-7	173.59	-62.50	77.19	66.31	139.62	128.82	-62.43	-73.31
J-7	J-8	152.58	-62.50	66.31	55.44	128.82	116.43	-62.50	-73.38
J-8	J-9	134.60	-63.36	55.44	44.56	116.43	107.92	-60.99	-71.87
J-9	J-10	118.52	-63.36	44.56	33.69	107.92	92.65	-63.36	-74.23
J-10	J-11	97.69	-58.96	33.69	22.81	92.65	74.63	-58.96	-69.84
J-11	J-12	72.16	-51.81	22.81	15.86	74.63	53.34	-51.81	-58.76
J-12	J-13	58.40	-37.48	15.86	10.87	53.34	28.25	-37.48	-42.47
J-13	R-1	29.97	-17.38	10.87	0.98	28.25	0.00	-17.38	-27.27

***** END OF THIS SIMULATION *****

END RUN AT TIME 10:04:20






ps4 without flywheel

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	16.80	-10.12	12.077	164.763	-99.326	16.73884	14.11925
J-2	13.18	-10.12	38.894	129.341	-99.326	16.60565	12.92044
J-3	11.57	-10.12	80.320	113.544	-99.326	16.87204	11.10003
J-4	14.43	-9.16	39.427	141.595	-89.821	17.00524	11.72164
J-5	14.08	-8.14	13.107	138.162	-79.884	17.13044	11.58844
J-6	13.23	-8.22	12.077	129.793	-80.633	17.18284	11.54403
J-7	12.24	-9.31	26.640	120.106	-91.346	17.27164	11.43963
J-8	11.27	-9.89	37.562	110.576	-97.062	17.36043	11.43083
J-9	9.88	-10.12	42.535	96.902	-99.326	17.44923	11.32203
J-10	8.79	-10.12	74.015	86.182	-99.326	17.13844	11.27763
O-Pump-1	24.35	-0.39	1.376	238.906	-3.870	16.69444	11.98804
R-1	0.15	0.15	0.000	1.471	1.471	0.04440	0.04440
O-Pump-1	1.00	1.00	0.000	9.809	9.809	0.04440	0.04440

KYPipe PIPESOLO




ps4 with flywheel

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	15.97	-3.68	19.358	156.691	-36.127	18.73681	16.33925
J-2	13.02	-5.77	61.405	127.734	-56.635	18.78121	16.29485
J-3	11.09	-6.41	87.158	109.839	-62.858	18.55921	16.20605
J-4	11.60	-4.44	52.800	113.823	-43.550	18.42602	13.94165
J-5	11.96	-2.40	7.992	117.349	-23.519	18.29282	11.67724
J-6	11.65	-2.11	5.417	114.241	-20.688	18.24842	11.63284
J-7	9.96	-2.42	9.146	97.660	-23.739	18.15962	11.54403
J-8	8.19	-2.61	15.718	80.311	-25.598	18.07082	11.45523
J-9	6.33	-2.66	30.192	62.095	-26.062	17.98202	11.36643
J-10	4.37	-2.52	69.042	42.853	-24.763	17.89322	11.27763
O-Pump-1	23.05	2.69	0.000	226.160	26.347	18.73681	16.56125
R-1	0.15	0.15	0.000	1.471	1.471	0.04440	0.04440
O-Pump-1	1.00	1.00	0.000	9.809	9.809	0.04440	0.04440

2248913 Analysis Report




psd with Flywheel


SUMMARY OF MAX/MIN LINE PRESSURES

START NODE	END NODE	MAX PRESS. psi or kPa	MIN PRESS. psi or kPa	Steady Press. at end nodes	Max/Drop at end nodes	Lowest Press at end nodes
0-Pump-1	J-1	226.16	-36.13	149.48	82.55	122.13
J-1	J-2	156.69	-56.63	82.55	58.80	116.68
J-2	J-3	127.73	-62.86	58.80	46.12	115.44
J-3	J-4	113.82	-62.86	46.12	35.06	108.98
J-4	J-5	117.35	-43.55	55.06	64.46	98.61
J-5	J-6	117.35	-23.52	64.46	63.52	87.98
J-6	J-7	114.24	-23.74	63.52	52.29	84.21
J-7	J-8	97.66	-25.60	52.29	41.06	76.03
J-8	J-9	80.31	-26.06	41.06	29.60	66.66
J-9	J-10	62.09	-26.06	29.60	16.13	55.66
J-10	R-1	42.85	-24.76	16.13	1.47	42.89

***** END OF THIS SIMULATION *****

END RUN AT TIME 10:11:45







psb without flywheel

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	125.77	-10.12	37.017	1233.819	-99.326	292.06448	147.68663
J-2	130.60	-10.12	30.267	1281.183	-99.326	213.65703	159.15857
J-3	133.83	-10.12	29.403	1312.898	-99.326	199.72874	161.77687
J-4	127.51	-10.12	32.859	1250.871	-99.326	204.91136	161.96582
J-5	134.75	-10.12	36.396	1321.912	-99.326	212.82025	162.15477
J-6	135.77	-10.12	32.886	1331.919	-99.326	251.47394	162.37071
J-7	123.92	-10.12	44.362	1215.632	-99.326	212.49634	149.38718
J-8	123.05	-10.12	35.748	1207.087	-99.326	290.09290	149.65710
J-9	117.26	-10.12	47.575	1150.348	-99.326	203.69669	149.73808
J-10	116.79	-10.12	51.085	1145.740	-99.326	203.72368	144.44749
J-11	127.36	-10.12	63.991	1249.361	-99.326	203.80466	13.12207
J-12	95.01	-10.12	90.748	932.035	-99.326	203.69669	13.01407
J-13	91.11	-10.12	101.548	893.747	-99.326	203.64270	13.01407
J-14	72.92	-10.12	94.636	715.368	-99.326	209.36517	72.84701
O-Pump-1	166.58	-10.12	48.034	1634.160	-99.326	214.57478	147.11978
R-1	1.50	1.50	0.000	14.715	14.715	0.02700	0.02700
O-Pump-1	3.00	3.00	0.000	29.426	29.426	0.02700	0.02700

HydroAnalysis Export





psb with flywheel

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time		MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
			Reverse	Grad.				
J-1	48.27	-5.17	2.592		473.488	-50.731	21.81621	15.39010
J-2	46.76	-5.01	1.836		458.702	-49.187	21.27620	14.85010
J-3	47.43	-2.68	0.918		465.293	-26.043	20.97919	14.55309
J-4	46.82	-1.56	0.459		459.264	-15.334	20.76319	14.33709
J-5	45.75	-0.31	0.081		448.818	-3.077	20.54719	14.12108
J-6	44.95	2.06	0.000		440.972	20.206	20.33118	13.90508
J-7	36.85	-1.64	0.270		361.480	-16.062	20.11518	13.68908
J-8	33.01	2.82	0.000		323.782	27.625	19.84517	13.41907
J-9	27.24	-0.08	0.027		267.211	-0.805	24.94826	13.33807
J-10	25.09	-0.57	0.081		246.149	-5.558	25.00226	13.28407
J-11	20.64	-3.17	0.351		202.469	-31.114	25.05626	13.23007
J-12	10.89	-5.43	3.834		106.877	-53.304	25.00226	13.12207
J-13	6.03	-5.31	19.035		59.188	-52.130	24.94826	13.06807
J-14	1.71	-1.39	10.962		16.738	-13.597	24.86725	12.98707
O-Pump-1	66.06	1.89	0.000		648.044	18.589	22.35621	15.93011
R-1	1.50	1.50	0.000		14.715	14.715	0.02700	0.02700
C-Pump-1	1.30	1.30	0.000		12.749	12.749	0.02700	0.02700

KYPipe PIPESYS

paf with Flydms


SUMMARY OF MAX/MIN LINE PRESSURES

START NODE	END NODE	MAX PRESS. psi or kPa	MIN PRESS. psi or kPa	Steady Press. at end nodes	MaxPtDrop at end nodes	LowestPress at end nodes
O-Pump-1	J-1	648.04	-50.73	399.49	316.55	180.90
J-1	J-2	473.49	-50.73	316.55	299.33	367.28
J-2	J-3	465.29	-49.19	299.33	307.90	348.52
J-3	J-4	465.29	-26.04	307.90	305.06	333.95
J-4	J-5	459.26	-15.33	305.06	300.26	320.40
J-5	J-6	448.82	-3.08	300.26	301.34	303.33
J-6	J-7	440.97	-16.06	301.34	235.71	281.13
J-7	J-8	361.48	-16.06	235.71	225.35	251.77
J-8	J-9	323.78	-0.81	225.35	175.04	197.73
J-9	J-10	267.21	-5.56	175.04	153.68	175.85
J-10	J-11	246.15	-31.11	153.68	109.36	159.23
J-11	J-12	202.47	-53.30	109.36	41.73	140.48
J-12	J-13	106.88	-53.30	41.73	15.45	95.03
J-13	J-14	59.19	-52.13	15.45	5.36	67.58
J-14	R-1	16.74	-13.60	5.36	14.72	18.96

***** END OF THIS SIMULATION *****

END RUN AT TIME 10:32:08

KYPipe
PIPESTARS




ps7 without flywheel

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	89.40	-10.12	121.196	876.967	-99.326	280.86121	36.85197
J-2	90.96	-10.12	129.499	892.316	-99.326	268.47202	12.07676
J-3	78.37	-10.12	146.949	768.033	-99.326	288.81683	11.69937
J-4	77.17	-10.12	150.679	757.076	-99.326	294.98462	11.74377
J-5	71.80	-10.12	151.168	704.340	-99.326	110.93850	10.58939
J-6	70.96	-10.12	149.947	696.130	-99.326	75.28283	10.56719
J-7	62.13	-10.12	157.340	609.535	-99.326	298.02414	10.54499
J-8	55.37	-10.12	152.100	543.148	-99.326	174.63470	10.61158
O-Pump-1	106.59	-10.12	88.826	1045.692	-99.326	295.18430	36.27473
R-1	1.60	1.60	0.000	15.696	15.696	0.02220	0.02220
O-Pump-1	1.50	1.50	0.000	14.713	14.713	0.02220	0.02220

KYPipe PipeFlow



ps7 with flywheel

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	27.96	-0.51	0.400	274.317	-4.974	14.00813	11.05558
J-2	26.19	-1.76	1.754	256.875	-17.219	14.03033	11.03338
J-3	22.62	-4.28	6.860	221.918	-42.012	14.07473	10.98890
J-4	20.18	-5.12	9.857	197.984	-50.184	14.14133	10.92238
J-5	17.86	-5.53	12.654	175.250	-54.286	14.18573	10.85578
J-6	14.75	-5.61	15.274	144.677	-54.986	14.11913	10.78918
J-7	10.48	-6.13	30.569	102.775	-60.113	14.05253	10.72258
J-8	5.76	-4.02	33.144	56.459	-39.422	13.96373	10.63378
C-Pump-1	33.58	4.01	0.000	329.450	39.355	13.98593	12.85375
R-1	1.60	1.60	0.000	15.696	15.696	0.02220	0.02220
C-Pump-1	1.50	1.50	0.000	14.713	14.713	0.02220	0.02220

KYPE PIPE SYSTEMS


p17.4155.1129901


SUMMARY OF MAX/MIN LINE PRESSURES:

START NODE	END NODE	MAX PRESS. psi or kPa	MIN PRESS. psi or kPa	Steady Press. at end nodes	MaxPipeop at end nodes	Lowestpress at end nodes
0-bump-1	J-1	329.45	-4.97	211.25	190.10	192.99
J-1	J-2	274.32	-17.22	180.10	164.41	185.07
J-2	J-3	256.88	-42.01	164.41	132.45	181.63
J-3	J-4	221.92	-50.18	132.45	111.87	174.46
J-4	J-5	197.99	-54.29	111.87	92.28	162.06
J-5	J-6	175.15	-54.99	92.28	72.68	148.56
J-6	J-7	144.68	-60.11	72.68	43.48	127.67
J-7	J-8	102.78	-60.11	43.48	21.74	103.59
J-8	R-1	56.46	-39.42	21.74	15.70	61.16

***** END OF THIS SIMULATION *****

END RUN AT TIME 10:52:48






ps00 without flywheel

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	17.41	-10.12	42.281	170.746	-99.326	6.16000	13.63999
J-2	16.06	-10.12	37.120	157.572	-99.326	4.12000	13.79999
J-3	14.34	-10.12	45.321	140.682	-99.326	4.20000	14.31999
J-4	13.67	-10.12	49.001	134.088	-99.326	4.24000	14.27999
J-5	13.14	-10.12	30.600	128.883	-99.326	13.43999	14.35999
J-6	11.34	-10.12	69.881	111.243	-99.326	13.23999	11.27999
J-7	11.56	-10.12	37.360	113.408	-99.326	13.11999	11.35999
J-8	11.02	-10.12	121.402	108.093	-99.326	19.00006	11.39999
J-9	8.30	-10.12	187.952	81.448	-99.326	12.71999	11.43999
J-10	9.70	-10.12	118.882	95.109	-99.326	12.59999	11.55999
O-Pump-1	23.39	-1.44	2.680	229.464	-14.188	4.96000	11.95999
R-1	2.10	2.10	0.000	20.601	20.601	0.04000	0.04000
O-Pump-1	1.00	1.00	0.000	9.808	9.808	0.04000	0.04000

KYPipe
PIPEPRO 1.0



ps08 with flywheel

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	17.41	-4.24	36.120	170.746	-41.564	6.16000	12.75999
J-2	16.06	-4.64	29.120	157.572	-45.567	4.12000	12.63999
J-3	14.34	-5.33	30.520	140.682	-52.302	4.20000	12.51999
J-4	13.67	-5.66	37.160	134.088	-55.501	4.24000	12.47999
J-5	12.95	-5.65	18.720	126.993	-55.385	4.36000	12.39999
J-6	9.55	-6.92	64.801	93.713	-67.932	0.04000	12.19999
J-7	8.42	-6.10	13.160	82.613	-59.839	1.48000	12.03999
J-8	4.40	-6.13	129.242	43.142	-60.179	3.80000	11.79999
J-9	2.49	-5.36	223.387	24.387	-52.535	3.88000	11.67999
J-10	1.77	-2.67	73.161	17.405	-26.190	3.76000	11.55999
O-Pump-1	23.39	0.94	0.000	229.464	9.241	4.96000	12.87999
R-1	2.10	2.10	0.000	20.601	20.601	0.04000	0.04000
O-Pump-1	1.00	1.00	0.000	9.808	9.808	0.04000	0.04000

KYPE PIPE


psd8 with flywheel


SUMMARY OF MAX/MIN LINE PRESSURES:

START NODE	END NODE	MAX PRESS. psi or kPa	MIN PRESS. psi or kPa	Steady Press. at end nodes	MaxPrDrop at end nodes	LowestPress at end nodes
O-Pump-1	J-1	229.46	-41.56	229.46	170.75	220.22 -49.40
J-1	J-2	170.75	-45.57	170.75	157.57	212.31 -54.74
J-2	J-3	157.57	-52.30	157.57	140.68	203.14 -62.46
J-3	J-4	140.68	-55.50	140.68	134.09	192.98 -58.90
J-4	J-5	134.09	-55.50	134.09	128.99	189.59 -62.60
J-5	J-6	128.99	-67.93	128.99	93.71	182.36 -55.50
J-6	J-7	93.71	-67.93	93.71	82.61	161.65 -55.79
J-7	J-8	82.61	-60.18	82.61	43.14	142.45 -67.93
J-8	J-9	43.14	-60.18	43.14	24.39	103.32 -59.84
J-9	J-10	24.39	-52.54	24.39	17.40	76.92 -60.18
J-10	R-1	20.60	-26.19	17.40	20.60	43.59 -52.54
						0.00 -22.99

***** END OF THIS SIMULATION *****

END RUN AT TIME 10:56:14





p09 no need Flywheel (with air valve)

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	5.03	-5.33	144.673	49.350	-52.265	0.10005	12.53960
J-2	4.17	-6.10	153.779	40.928	-59.851	0.03335	12.77305
J-3	3.34	-6.82	150.711	32.742	-66.874	0.03335	12.57295
J-4	3.38	-6.66	34.517	33.135	-65.379	0.03335	12.37285
J-5	2.78	-7.12	34.851	27.256	-69.812	0.03335	12.20610
J-6	2.64	-7.44	36.152	25.942	-73.016	37.28559	12.03935
J-7	2.62	-7.26	39.387	25.691	-71.261	39.72028	11.80590
J-8	2.60	-6.08	30.515	25.522	-59.668	39.82034	11.70585
J-9	2.18	-4.43	30.582	21.432	-43.465	39.85369	11.63915
O-Pump-1	9.41	-0.99	6.537	92.311	-9.672	0.06670	13.13990
R-1	0.20	0.20	0.000	1.962	1.962	0.03335	0.03335
O-Pump-1	0.60	0.60	0.000	5.885	5.885	0.03335	0.03335

KYPipe
PIPERSTO


ps9 no need flywheel (with air valve)


SUMMARY OF MAX/MIN LINE PRESSURES:

START NODE	END NODE	MAX PRESS. psi or kPa	MIN PRESS. psi or kPa	Steady Press. at end nodes	MaxPcDrop at end nodes	LowestPress at end nodes			
O-Pump-1	J-1	92.31	-52.26	92.31	49.35	101.98	101.61	-9.67	-52.63
J-1	J-2	49.35	-59.05	49.35	40.93	101.61	100.70	-52.26	-60.69
J-2	J-3	40.93	-66.87	40.93	32.74	100.70	99.62	-59.85	-68.04
J-3	J-4	33.14	-66.87	32.74	33.14	99.62	98.51	-66.87	-66.48
J-4	J-5	33.14	-69.81	33.14	27.26	98.51	97.07	-65.30	-71.26
J-5	J-6	27.26	-73.02	27.26	21.75	97.07	94.77	-69.81	-75.32
J-6	J-7	25.34	-73.02	21.75	13.33	94.77	84.59	-73.02	-81.44
J-7	J-8	25.69	-71.26	13.33	9.37	84.59	65.04	-71.26	-75.22
J-8	J-9	25.52	-59.67	9.37	4.19	65.04	47.66	-59.67	-64.84
J-9	R-1	21.43	-43.86	4.19	1.96	47.66	0.00	-43.46	-45.70

***** END OF THIS SIMULATION *****

END RUN AT TIME 11:03:19







pa10 without surge tank

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-2	70.43	-10.12	150.457	690.946	-99.326	289.65991	11.47737
J-4	69.36	-10.12	162.846	680.376	-99.326	252.05147	11.67717
J-5	67.85	-10.12	197.169	665.648	-99.326	249.83131	11.63277
J-6	59.42	-10.12	215.441	582.916	-99.326	249.43169	11.92136
J-7	67.00	-10.12	135.693	657.260	-99.326	287.15286	79.43452
J-8	77.03	-10.12	24.686	755.667	-99.326	291.27951	95.61944
J-9	78.00	-10.12	38.539	765.168	-99.326	291.65668	86.71662
J-10	77.23	-10.12	19.935	757.608	-99.326	211.62247	151.54510
J-11	71.89	-10.12	96.352	705.218	-99.326	212.13310	79.03489
J-12	67.15	-10.12	18.137	658.754	-99.326	73.68432	132.09656
J-3a	84.00	-10.12	68.356	832.652	-99.326	251.42982	20.26842
O-Pump-1	106.71	-10.12	35.875	1046.842	-99.326	289.08307	23.19878
R-1	2.00	2.00	0.000	19.620	19.620	0.02220	0.02220
SBO-1	93.70	-10.12	65.115	919.197	-99.326	251.00800	20.46822
O-Pump-1	1.30	1.30	0.000	12.749	12.749	0.02220	0.02220

pa10 Analysis Report






ps10 with surge tank

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-2	17.60	0.39	0.000	174.665	3.874	0.02220	70.57610
J-4	15.82	-0.71	26.018	155.168	-7.006	0.13320	70.35409
J-5	11.55	-4.59	124.437	113.278	-44.993	0.02220	70.22088
J-6	8.36	-6.60	191.197	82.037	-64.723	0.02220	69.82125
J-7	17.25	3.39	0.000	169.189	33.218	0.02220	69.42162
J-8	24.50	12.11	0.000	240.377	118.818	0.48840	68.93319
J-9	20.55	9.02	0.000	201.555	88.509	0.55500	68.66677
J-10	23.17	13.38	0.000	227.337	131.295	0.02220	68.15614
J-11	13.20	5.02	0.000	129.499	49.224	0.51060	67.68990
J-12	20.10	14.65	0.000	197.194	143.679	0.02220	66.82404
J-3a	28.80	10.67	0.000	282.507	104.646	0.02220	70.30968
O-Pump-1	47.18	20.97	0.000	462.875	205.696	10.32299	66.40221
R-1	2.00	2.00	0.000	19.620	19.620	0.02220	0.02220
SDO-1	32.29	12.99	0.000	316.776	127.391	0.02220	66.77964
O-Pump-1	1.30	1.30	0.000	12.749	12.749	0.02220	0.02220

Hydra-PIPE Analysis Results




psi0 with surge tank


SUMMARY OF MAX/MIN LINE PRESSURES:

START NODE	END NODE	MAX PRESS. psi or kPa	MIN PRESS. psi or kPa	Steady Press. at end nodes	MaxPrDrop at end nodes	LowestPress at end nodes
0-Dump-1	SDO-1	462.88	127.39	402.54	316.78	196.85 189.38 205.70 119.93
SDO-1_0	J-3a	316.78	104.65	316.78	282.51	189.38 177.86 127.39 93.12
J-3a	J-2	282.51	3.87	282.51	174.66	177.86 170.79 104.65 -3.20
J-2	J-4	174.66	-7.01	174.66	155.17	170.79 162.17 3.87 -15.62
J-4	J-5	155.17	-44.99	155.17	113.28	162.17 158.27 -7.01 -48.90
J-5	J-6	113.28	-64.72	113.28	82.04	158.27 146.76 -44.99 -76.23
J-6	J-7	169.19	-64.72	82.04	169.19	146.76 135.97 -64.72 22.43
J-7	J-8	240.38	33.22	169.19	240.38	135.97 121.56 33.22 104.41
J-8	J-9	240.38	88.51	240.38	201.56	121.56 113.05 118.82 80.00
J-9	J-10	227.34	88.51	201.56	227.34	113.05 96.04 88.51 114.29
J-10	J-11	227.34	49.22	227.34	129.50	96.04 80.27 131.30 33.46
J-11	J-12	197.19	49.22	129.50	197.19	80.27 53.52 49.22 116.92
J-12	R-1	197.19	19.62	197.19	19.62	53.52 0.00 143.68 -33.90

***** END OF THIS SIMULATION *****

END RUN AT TIME 11:17:33





psll no need flywheel

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	29.14	-2.78	1.808	285.846	-27.275	13.85588	11.24791
J-2	27.48	-3.29	1.440	269.538	-32.258	13.82388	11.21591
J-3	25.68	-3.62	1.232	251.965	-35.505	13.79188	11.18391
J-4	24.73	-3.72	1.120	242.619	-36.505	13.77588	10.52792
J-5	23.74	-3.91	1.008	232.864	-38.381	13.75988	10.51192
J-6	20.61	-4.97	1.216	202.163	-48.711	13.72788	10.47992
J-7	17.26	-5.53	1.776	169.338	-54.236	13.69588	10.44792
J-8	13.57	-5.52	2.624	133.079	-54.110	13.66388	10.41592
J-9	8.53	-5.77	11.520	83.692	-56.579	13.63188	10.38392
J-10	4.54	-3.59	14.896	44.582	-35.257	13.59988	10.35192
O-Pump-1	35.94	1.27	0.000	352.580	12.488	15.88788	11.27991
R-1	1.00	1.00	0.000	9.810	9.810	0.01600	0.01600
O-Pump-1	1.20	1.20	0.000	11.769	11.769	0.01600	0.01600

KYPipe PIPESIG


psi no need flywheel


SUMMARY OF MAX/MIN LINE PRESSURES:

START NODE	END NODE	MAX PRESS. psi or KPa	MIN PRESS. psi or KPa	Steady Press. at end nodes	MaxDrop at end nodes	LowestPress at end nodes
O-Pump-1	J-1	352.58	-27.27	294.64	240.49	282.15
J-1	J-2	285.85	-32.26	240.49	219.70	267.77
J-2	J-3	269.54	-35.51	219.70	198.91	251.96
J-3	J-4	251.96	-36.50	198.91	188.51	234.42
J-4	J-5	242.62	-38.38	188.51	178.12	225.02
J-5	J-6	232.86	-48.71	178.12	148.89	216.50
J-6	J-7	202.16	-54.24	148.89	119.66	197.60
J-7	J-8	169.34	-54.24	119.66	90.43	173.90
J-8	J-9	131.08	-56.58	90.43	51.39	144.54
J-9	J-10	83.69	-56.58	51.39	25.70	107.97
J-10	R-1	44.58	-35.26	25.70	9.81	60.95


***** END OF THIS SIMULATION *****

END RUN AT TIME 11:19:42






psi2 without flywheel							
SUMMARY OF MAXIMUM AND MINIMUM HEADS:							
Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	80.41	-10.12	9.396	788.790	-99.326	294.16574	269.72821
J-2	80.97	-10.12	8.757	794.325	-99.326	294.19354	280.40399
J-3	79.22	-10.12	9.007	777.190	-99.326	294.30475	276.12256
J-4	93.02	-10.12	9.285	912.536	-99.326	294.52716	276.23376
J-5	95.56	-10.12	9.730	937.437	-99.326	294.44376	275.09390
J-6	86.84	-10.12	11.815	851.912	-99.326	295.69482	270.17303
J-7	77.70	-10.12	13.094	762.229	-99.326	290.66275	11.73156
J-8	78.43	-10.12	13.316	789.408	-99.326	295.38901	11.75936
J-9	81.96	-10.12	11.426	804.008	-99.326	295.16660	14.45592
J-10	80.58	-10.12	11.259	790.473	-99.326	293.08148	12.23196
J-11	85.26	-10.12	17.542	836.413	-99.326	295.08943	12.37095
J-12	81.13	-10.12	22.990	795.869	-99.326	291.88602	12.39875
J-13	69.99	-10.12	54.016	686.886	-99.326	292.08063	12.39875
J-14	65.44	-10.12	73.033	641.971	-99.326	296.13965	12.45435
J-15	81.11	-10.12	81.429	795.717	-99.326	299.36462	12.56555
O-Pump-1	110.43	-10.12	11.787	1003.303	-99.326	293.94333	269.47800
R-1	2.00	2.00	0.000	19.620	19.620	0.02780	0.02780
O-Pump-1	0.44	0.44	0.000	4.313	4.313	0.02780	0.02780



ps12 with flywheel

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	41.22	-2.78	1.696	404.333	-27.207	22.32321	15.01192
J-2	39.92	-3.12	1.751	391.582	-30.637	22.43441	14.90072
J-3	39.05	-3.54	1.863	383.102	-34.722	22.49001	14.84512
J-4	37.20	-4.55	2.113	364.919	-44.674	22.60121	14.73392
J-5	36.51	-4.69	2.057	358.181	-46.018	22.68461	14.65052
J-6	34.85	-5.02	2.307	341.889	-57.082	22.76801	14.56712
J-7	33.30	-6.66	2.660	326.640	-65.381	22.87921	14.45592
J-8	32.58	-6.65	2.502	319.628	-65.220	22.99040	14.34473
J-9	32.84	-5.46	1.807	322.199	-53.639	23.12940	14.20573
J-10	30.22	-3.36	0.806	296.480	-32.955	23.74099	13.59414
J-11	25.34	-2.30	0.448	248.592	-22.535	23.71319	13.26084
J-12	23.06	-2.21	0.448	226.176	-21.652	23.62980	13.17714
J-13	15.99	-4.63	3.558	156.061	-45.380	23.49080	13.03815
J-14	11.42	-4.80	7.673	112.010	-47.100	23.37960	12.92695
J-15	6.55	-3.19	7.867	64.284	-31.252	23.24060	12.78795
O-Pump-1	47.82	1.68	0.000	469.155	16.498	22.10092	15.23431
R-1	2.00	2.00	0.000	19.620	19.620	0.02780	0.02780
O-Pump-1	0.44	0.44	0.000	4.313	4.313	0.02780	0.02780



ps12 with flywheel


SUMMARY OF MAX/MIN LINE PRESSURES:


START NODE	END NODE	MAX PRESS. psi or kPa	MIN PRESS. psi or kPa	Steady Press. at end nodes	MaxPrincop at end nodes	LowestPress at end nodes
0-Pump-1	J-1	469.15	-27.29	307.30	256.85	290.00
J-1	J-2	404.33	-30.64	256.85	249.95	284.13
J-2	J-3	391.58	-34.72	249.95	243.94	289.59
J-3	J-4	383.10	-44.67	243.94	229.95	278.66
J-4	J-5	364.92	-46.02	229.95	225.46	274.63
J-5	J-6	358.18	-57.08	225.46	210.94	271.48
J-6	J-7	341.89	-65.38	210.94	197.85	268.02
J-7	J-8	326.64	-65.38	197.85	192.56	263.23
J-8	J-9	322.20	-65.22	192.56	196.77	257.78
J-9	J-10	322.20	-53.54	196.77	171.09	250.31
J-10	J-11	296.48	-32.95	171.09	139.92	204.04
J-11	J-12	248.59	-22.54	139.92	127.36	162.46
J-12	J-13	226.18	-45.39	127.36	77.62	149.01
J-13	J-14	156.86	-47.10	77.62	50.88	123.01
J-14	J-15	112.01	-47.10	50.88	28.60	97.98
J-15	R-1	64.20	-31.25	28.60	19.62	59.86

***** END OF THIS SIMULATION *****

END RUN AT TIME 11:24:47

PIPELINE ANALYSIS REPORT






p13 no need flywheel

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	25.93	-2.85	1.043	254.343	-27.997	12.74275	11.12218
J-2	25.04	-3.32	0.888	245.610	-32.599	12.78715	11.07778
J-3	24.59	-3.47	0.710	241.181	-34.060	12.83155	11.03338
J-4	24.53	-3.29	0.555	240.632	-32.311	12.87595	10.98898
J-5	22.97	-4.57	1.154	225.346	-44.785	12.92035	10.94458
J-6	22.53	-4.76	1.443	221.012	-46.732	12.96695	10.90018
J-7	22.33	-4.66	1.399	219.045	-45.740	13.03134	10.85578
J-8	21.85	-4.73	1.465	214.336	-46.373	13.07574	10.81138
J-9	18.70	-6.19	2.731	183.474	-60.765	13.08354	10.74478
J-10	14.11	-6.63	3.441	138.424	-65.000	12.98695	10.67818
J-11	4.98	-6.94	145.040	48.893	-68.101	12.92035	10.63158
O-Pump-1	20.49	-0.41	0.333	279.507	-4.048	12.74275	11.14438
R-1	0.10	0.10	0.000	0.981	0.981	0.02220	0.02220
O-Pump-1	0.70	0.70	0.000	6.865	6.865	0.02220	0.02220

Report's Analysis Report



puls no read (1/step)


SUMMARY OF MAX/MIN LINE PRESSURES:


START NODE	END NODE	MAX PRESS. psi or kPa	MIN PRESS. psi or kPa	Steady Press. at end nodes	Max/Min/avg at end nodes	Lowest/Press at end nodes			
Q-Pump-1	J-1	279.51	-28.00	174.03	150.23	170.94	170.22	-4.05	-28.71
J-1	J-2	284.34	-32.00	150.23	148.96	178.22	176.66	-20.00	-34.26
J-2	J-3	245.61	-34.04	144.06	140.84	176.66	174.98	-22.60	-35.82
J-3	J-4	242.18	-34.04	140.98	140.56	174.98	172.87	-34.04	-34.34
J-4	J-5	248.63	-44.78	140.54	125.14	172.87	169.93	-32.32	-47.33
J-5	J-6	225.35	-44.72	125.14	119.54	169.93	166.27	-44.70	-50.39
J-6	J-7	221.91	-44.72	119.54	115.89	166.27	161.63	-44.72	-50.38
J-7	J-8	219.85	-44.37	115.89	109.31	161.63	155.68	-45.74	-52.33
J-8	J-9	214.34	-48.76	109.31	81.76	155.68	142.52	-46.37	-70.92
J-9	J-10	183.47	-45.89	81.76	58.09	142.52	115.89	-60.74	-88.43
J-10	J-11	139.42	-48.10	54.03	1.68	115.89	85.78	-63.00	-117.41
J-11	R-1	88.89	-48.10	1.68	0.98	85.78	0.00	-49.10	-48.80

Cavitation Potential

***** END OF THIS ITERATION *****

END RUN AT TIME 11:29:38






ps14 no need flywheel (with air valve)

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	27.41	-6.21	4.729	269.936	-60.907	12.80935	11.01118
J-2	26.72	-6.51	4.618	262.167	-63.876	12.85375	10.96678
J-3	25.92	-6.94	4.906	254.245	-68.121	12.89815	10.92238
J-4	25.17	-7.29	4.973	246.921	-71.497	12.94255	10.87790
J-5	23.38	-8.00	5.217	229.317	-78.448	12.94255	10.81138
J-6	20.18	-7.96	4.063	197.955	-78.071	12.85375	10.72250
J-7	17.27	-8.11	4.373	169.458	-79.567	12.80935	10.67818
J-8	13.81	-7.59	4.462	135.435	-74.506	12.76495	10.63378
J-9	9.56	-5.96	3.863	93.740	-58.428	12.72055	10.58939
J-10	3.01	-3.35	17.072	29.494	-32.901	12.67615	10.54499
O-Pump-1	33.81	-0.16	0.067	331.705	-1.523	12.76495	11.05550
R-1	0.10	0.10	0.000	0.981	0.981	0.02220	0.02220
O-Pump-1	0.70	0.70	0.000	6.865	6.865	0.02220	0.02220

KYPipe2012 Analyser Results


KYPIPE
PIPE 2012


ps14 no need flywheel (with air valve)


SUMMARY OF MAX/MIN LINE PRESSURES:

START NODE	END NODE	MAX PRESS. psi or kPa	MIN PRESS. psi or kPa	Steady Press. at end nodes	MaxPrDrop at end nodes	LowestPress at end nodes
O-Pump-1	J-1	331.71	-60.91	214.62	151.74	212.65
J-1	J-2	268.94	-63.88	151.74	144.58	212.65
J-2	J-3	262.17	-68.12	144.58	135.45	208.45
J-3	J-4	254.25	-71.50	135.45	126.33	203.57
J-4	J-5	246.92	-78.45	126.33	108.71	197.82
J-5	J-6	229.32	-78.45	108.71	88.33	187.16
J-6	J-7	197.95	-79.57	88.33	70.37	166.40
J-7	J-8	169.46	-79.57	70.37	52.42	149.94
J-8	J-9	135.44	-74.51	52.42	34.46	126.92
J-9	J-10	93.74	-58.43	34.46	6.53	92.89
J-10	R-1	29.49	-32.90	6.53	0.98	39.43

***** END OF THIS SIMULATION *****

END RUN AT TIME 11:41:33

11/20/2010 11:41:33 AM






pa15 without flywheel

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	92.06	-10.12	23.025	903.090	-99.326	77.25316	45.82782
J-2	85.37	-10.12	22.492	837.480	-99.326	77.16426	45.96116
J-3	75.96	-10.12	21.828	745.138	-99.326	76.99647	46.18341
J-4	82.48	-10.12	22.936	809.134	-99.326	57.16227	46.49455
J-5	74.65	-10.12	23.470	732.324	-99.326	57.02893	46.31675
J-6	62.54	-10.12	27.559	613.552	-99.326	63.02952	44.80549
J-8	50.86	-10.12	59.563	498.933	-99.326	70.85252	11.42362
J-9	44.59	-10.12	101.611	437.406	-99.326	76.05304	11.51252
J-10	37.94	-10.12	144.149	372.238	-99.326	56.19440	11.55697
J-67	54.16	-10.12	39.605	531.275	-99.326	76.36418	11.42362
O-Pump-1	110.72	-10.12	14.491	1086.211	-99.326	77.34206	45.69447
R-1	2.00	2.00	0.000	19.620	19.620	0.04445	0.04445
O-Pump-1	1.20	1.20	0.000	11.768	11.768	0.04445	0.04445

Pa15-011 Analysis (10000)






ps15 with Flywheel

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	37.89	4.71	0.000	371.745	46.242	19.60246	16.31311
J-2	37.34	5.15	0.000	366.321	50.527	19.51356	16.22421
J-3	35.06	5.15	0.000	343.897	50.492	19.33576	16.04640
J-4	33.55	4.92	0.000	329.170	48.246	19.24686	15.95750
J-5	31.12	4.61	0.000	305.247	45.186	19.11350	12.62376
J-6	24.69	2.79	0.000	242.234	27.327	18.84680	12.35707
J-8	12.85	-2.99	3.245	126.072	-29.366	18.58010	12.09037
J-9	5.20	-4.35	39.738	51.052	-42.694	18.40229	11.86812
J-10	2.80	-3.76	140.948	27.457	-36.896	18.53564	11.77922
J-67	18.71	-0.46	0.133	183.530	-4.471	18.71345	12.22372
O-Pump-1	43.63	9.01	0.000	427.991	88.408	19.69136	16.49091
R-1	2.00	2.00	0.000	19.620	19.620	0.04445	0.04445
O-Pump-1	1.20	1.20	0.000	11.768	11.768	0.04445	0.04445

E:\ps15\Analysis\summary




psi5 with flywheel


SUMMARY OF MAX/MIN LINE PRESSURES:

START NODE	END NODE	MAX PRESS. psi or kPa	MIN PRESS. psi or kPa	Steady Press. at end nodes	MaxDrDrop at end nodes	LowestPress at end nodes
0-Dump-1	J-1	427.99	46.24	413.74	356.73	325.33
J-1	J-2	373.74	46.24	356.73	345.82	310.48
J-2	J-3	366.32	50.49	345.82	318.17	295.30
J-3	J-4	343.90	48.25	318.17	300.91	267.68
J-4	J-5	329.17	45.19	300.41	275.77	252.17
J-5	J-6	305.25	27.33	275.77	214.29	230.58
J-67	J-8	183.53	-29.37	156.65	104.53	181.12
J-8	J-9	126.07	-42.68	104.53	37.57	133.89
J-9	J-10	51.05	-42.68	37.57	18.84	80.26
J-10	R-1	27.46	-36.90	18.84	19.62	55.74
J-6	J-67	242.23	-4.47	214.29	156.65	186.96
						161.12
						27.33
						-30.31

***** END OF THIS SIMULATION *****

END RUN AT TIME 11:46:22






ps16 no need flywheel

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	25.07	-7.01	4.551	245.933	-68.781	15.51770	12.58735
J-2	25.60	-4.91	2.153	251.168	-48.162	15.58430	12.32096
J-3	24.61	-5.00	2.020	241.456	-49.029	15.65090	12.38756
J-4	23.70	-5.15	1.843	232.544	-50.551	15.73970	12.36536
J-5	23.11	-5.28	1.709	226.670	-51.845	15.82850	12.27656
J-6	22.17	-6.02	1.621	217.530	-59.035	15.89510	12.20996
J-7	20.23	-7.88	1.621	198.438	-77.314	15.96170	12.09896
J-8	20.16	-7.90	1.376	197.754	-77.527	16.09489	12.01016
J-9	20.45	-7.58	1.088	200.652	-74.379	16.20589	11.89916
J-10	19.88	-7.37	0.755	195.023	-72.298	16.42789	11.67717
O-Pump-1	32.58	-0.29	0.977	319.654	-2.872	15.49550	12.60955
R-1	2.10	2.10	0.000	20.601	20.601	0.02220	0.02220
O-Pump-1	1.00	1.00	0.000	9.808	9.808	0.02220	0.02220

Simulation Analysis Report




gals no head Elyhead


SUMMARY OF MAX/MIN LOWE PRESSURES:

START NODE	END NODE	MAX PRESS. psi or kPa	MIN PRESS. psi or kPa	Steady Press. at end nodes	Head/Depth at end nodes	Lowest/Hiest at end nodes	Evaporation Potential		
0-Empty-1	J-1	319.65	-68.70	195.84	129.64	190.71	190.44	-2.87	+69.05
J-2	J-3	251.17	-49.02	149.89	148.34	190.05	197.57	+8.16	+49.51
J-1	J-2	251.17	-68.70	179.66	149.89	190.88	188.95	-69.78	-48.55
J-4	J-5	232.58	-51.84	145.89	141.20	194.88	195.04	-50.55	-30.28
J-0	J-4	241.46	-58.25	148.34	145.89	197.57	194.88	-48.03	-51.68
J-6	J-7	227.52	-77.31	134.85	125.75	199.89	192.06	-59.84	-70.13
J-5	J-6	226.67	-59.84	143.20	134.85	195.04	193.88	-51.84	-60.20
J-8	J-9	286.65	-77.32	113.27	113.94	190.80	188.24	-77.32	+76.04
J-7	J-8	198.44	-77.32	113.75	113.27	190.04	190.80	-77.31	-75.79
J-10	K-1	199.02	-72.20	103.57	28.60	175.07	0.00	-78.30	-155.27
J-9	J-10	288.48	-74.28	113.96	103.57	188.24	175.87	-74.28	-84.77

***** END OF THIS SIMULATION *****

KMD RUN AT TIME 11:48:39






palt no need flywheel (1500rpm)

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	15.03	-6.72	102.702	147.463	-65.955	16.05050	12.58735
J-2	15.81	-4.75	81.166	155.076	-46.597	16.11709	12.52075
J-3	16.98	-3.18	40.848	166.586	-31.168	16.13929	12.49855
J-4	13.96	-5.00	85.851	136.967	-49.020	16.20589	12.43195
J-5	12.52	-5.31	91.446	122.869	-52.049	16.27249	11.07778
J-6	10.63	-5.26	92.955	104.328	-51.553	18.98085	10.98898
J-7	8.41	-4.73	90.713	82.548	-46.414	18.89205	10.90018
J-8	5.70	-3.85	92.089	55.906	-37.726	18.80325	10.81138
J-9	2.56	-2.24	104.633	25.159	-22.021	16.05050	10.72258
O-Pump-1	24.22	2.27	0.000	237.607	22.273	16.02830	12.60955
R-1	0.20	0.20	0.000	1.962	1.962	0.02220	0.02220
O-Pump-1	1.60	1.60	0.000	15.695	15.695	0.02220	0.02220

Design/10, Analysis Report




p017 no need flywheel (1500rpm)


SUMMARY OF MAX/MIN LINE PRESSURES:

START NODE	END NODE	MAX PRESS. poi or kPa	MIN PRESS. poi or kPa	Steady Press. at end nodes		MaxPrDrop at end nodes		LowestPress at end nodes	
0= Pump-1	J-1	237.61	-65.95	140.16	50.72	117.89	116.68	22.27	-67.17
J-1	J-2	155.08	-65.95	50.72	64.60	116.68	111.20	-65.95	-52.08
J-2	J-3	166.59	-46.60	64.60	78.00	111.20	109.17	-46.60	-33.20
J-3	J-4	166.59	-49.02	78.00	53.62	109.17	102.64	-31.17	-55.55
J-4	J-5	136.97	-52.05	53.62	43.95	102.64	96.00	-49.02	-58.69
J-5	J-6	122.87	-52.05	43.95	33.95	96.00	85.50	-52.05	-62.05
J-6	J-7	104.33	-51.55	33.95	24.93	85.50	71.34	-51.55	-60.57
J-7	J-8	82.55	-46.41	24.93	14.93	71.34	52.66	-46.41	-56.41
J-8	J-9	55.91	-37.73	14.93	4.93	52.66	26.95	-37.73	-47.73
J-9	R-1	25.16	-22.02	4.93	1.96	26.95	0.00	-22.02	-24.99

***** END OF THIS SIMULATION *****

END RUN AT TIME 11:52:40

PIPE2010 (KYPipe) 2010





psi? without flywheel (1000rpm)

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	15.18	-0.79	58.987	148.927	-86.190	15.47330	11.29977
J-2	14.82	-7.22	34.809	145.356	-70.850	15.53990	11.23317
J-3	15.73	-5.80	9.812	154.351	-56.914	15.58430	11.21097
J-4	12.22	-7.98	40.893	119.871	-78.260	15.65090	11.14438
J-5	10.50	-8.83	48.375	102.992	-83.650	15.71750	11.07778
J-6	8.80	-8.73	74.506	86.321	-85.631	15.80630	10.98898
J-7	7.44	-8.43	81.854	72.970	-82.709	15.89510	10.90018
J-8	6.46	-7.52	91.224	63.358	-73.739	15.96305	10.81138
J-9	4.39	-4.87	114.846	43.047	-47.794	16.01445	10.72258
O-Pump-1	24.56	0.30	0.000	240.949	2.910	15.47330	11.32197
R-1	0.20	0.20	0.000	1.962	1.962	0.02220	0.02220
O-Pump-1	1.60	1.60	0.000	15.695	15.695	0.02220	0.02220

Time 0 PS-17



psi7 with flywheel (1000rpm)

SUMMARY OF MAXIMUM AND MINIMUM HEADS:

Position no.	MaxHead (m)	MinHead (m)	Time Reverse Grad.	MaxPressure (kPa)	MinPressure (kPa)	MaxTime (sec)	MinTime (sec)
J-1	15.12	-7.00	105.699	148.298	-68.680	15.87290	11.29977
J-2	15.75	-5.16	69.866	154.543	-50.600	15.93950	11.23317
J-3	16.89	-3.63	30.613	165.677	-35.643	15.96170	11.21097
J-4	13.78	-5.59	84.119	135.141	-54.842	16.02830	11.14438
J-5	12.26	-5.95	88.826	120.315	-58.338	16.09489	11.07779
J-6	10.69	-5.92	85.451	104.875	-58.119	24.30876	10.98898
J-7	8.77	-5.41	79.879	86.032	-53.062	18.89205	10.90018
J-8	6.05	-4.44	85.962	59.369	-43.586	18.80325	10.81138
J-9	2.77	-2.62	107.963	27.192	-25.675	16.05050	10.72258
O-Pump-1	24.30	2.01	0.000	238.336	19.690	15.85070	11.32197
R-1	0.20	0.20	0.000	1.962	1.962	0.02220	0.02220
O-Pump-1	1.60	1.60	0.000	15.695	15.695	0.02220	0.02220

KYPipe
PIPE 2018

psit with Flywheel (1000rpm)

SUMMARY OF MAX/MIN LINE PRESSURES:

START NODE	END NODE	MAX PRESS. psi or kPa	MIN PRESS. psi or kPa	steady Press. at end nodes	MaxFrDrop at end nodes	LowestPress at end nodes
O-Pump-1	J-1	238.34	-68.68	140.16	50.72	120.47
J-1	J-2	154.54	-68.68	50.72	64.60	119.40
J-2	J-3	165.68	-50.69	64.60	78.00	115.20
J-3	J-4	165.68	-54.84	78.00	53.62	113.64
J-4	J-5	135.14	-58.34	53.62	43.95	108.46
J-5	J-6	120.32	-58.34	43.95	33.95	102.29
J-6	J-7	104.87	-58.12	33.95	24.93	92.07
J-7	J-8	86.03	-53.06	24.93	14.93	77.99
J-8	J-9	59.37	-43.59	14.93	4.93	58.52
J-9	R-1	27.19	-25.67	4.93	1.96	30.60

***** END OF THIS SIMULATION *****

END RUN AT TIME 11:55:24

KYPE PIPE
FIPROTS

SECTION C3: List of Mechanical Equipment**C3.1 List of Mechanical Equipment (Pumping Stations)**

Item No.	Equipment Name	Specification	kW	Qty		Remarks
				duty	standby	
M01	Pumping Stations					
M01-01-01/02	Lifting Pump 1	Submersible Sewage Pump (Non-clog type) Dia.100 mm × 6 L/S × 1.4 m	5.5	1	1	With Flywheel (WR2= more than 2.0Nm ²)
M01-01-03	Monorail Hoist Unit	Manual monorail hoist with trolley 0.5 t × 2 unit	-	1	0	With two I beams and Steel Columns Lift more than 3m
M01-02-01/02	Lifting Pump 2	Submersible Sewage Pump (Non-clog type) Dia.100 mm × 10.8 L/S × 40 m	22	1	1	With Flywheel (WR2= more than 15Nm ²)
M01-02-03	Monorail Hoist Unit	Manual monorail hoist with trolley 0.5 t × 1 unit, 1 t × 1 unit	-	1	0	With two I beams and Steel Columns Lift more than 3m
M01-03-01/02	Lifting Pump 3	Submersible Sewage Pump (Non-clog type) Dia.100 mm × 31.6 L/S × 25 m	22	1	1	With Flywheel (WR2= more than 6.2Nm ²)
M01-03-03	Monorail Hoist Unit	Manual monorail hoist with trolley 0.5 t × 1 unit, 1 t × 1 unit	-	1	0	With two I beams and Steel Columns Lift more than 3m
M01-04-01/02	Lifting Pump 4	Submersible Sewage Pump (Non-clog type) Dia.200 mm × 80.0 L/S × 17 m	22	1	1	With Flywheel (WR2= more than 20Nm ²)
M01-04-03	Monorail Hoist Unit	Manual monorail hoist with trolley 0.5 t × 1 unit, 2 t × 1 unit	-	1	0	With two I beams and Steel Columns Lift more than 3m
M01-05-01/04	Lifting Pump 5	Submersible Sewage Pump (Non-clog type) Dia.200 mm × 73.3 L/S × 42 m	55	2	1	With Flywheel (WR2= more than 37Nm ²)
M01-05-05/07	Delivery Valve	Motorized operated sluice valve φ200 mm	0.4	2	1	With 1 unit stock With control panel
M01-05-08	Monorail Hoist Unit	Manual monorail hoist with trolley 0.5 t × 1 unit, 2.5 t × 1 unit	-	1	0	With two I beam and Steel Columns Lift more than 3m

Item No.	Equipment Name	Specification	kW	Qty		Remarks
				duty	standby	
M01-06-01/02	Lifting Pump 6	Submersible Sewage Pump (Non-clog type) Dia.100 mm × 10.8 L/S × 17 m	5.5	1	1	
M01-06-03	Monorail Hoist Unit	Manual monorail hoist with trolley 0.5 t × 2 units	-	1	0	With two I beams and Steel Columns Lift more than 3m
M01-07-01/02	Lifting Pump 7	Submersible Sewage Pump (Non-clog type) Dia.100 mm × 23.3 L/S × 24 m	15	1	1	With Flywheel (WR2= more than 5Nm ²)
M01-07-03	Monorail Hoist Unit	Manual monorail hoist with trolley 1.0 t × 1 unit	-	1	0	With one I beam and Steel Columns Lift more than 3m
M01-08-01/02	Lifting Pump 8	Submersible Sewage Pump (Non-clog type) Dia.100 mm × 10.0 L/S × 24 m	7.5	1	1	With Flywheel (WR2= more than 4.5Nm ²)
M01-08-03	Monorail Hoist Unit	Manual monorail hoist with trolley 0.5 t × 1 unit	-	1	0	With one I beam Lift more than 3m
M01-09-01/04	Lifting Pump 9	Submersible Sewage Pump (Non-clog type) Dia.200 mm × 93.3 L/S × 11 m	15	2	1	With 1 unit stock
M01-09-05	Monorail Hoist Unit	Manual monorail hoist with trolley 1.0 t	-	1	0	With one I beam and Steel Columns Lift more than 3m
M01-10-01/04	Lifting Pump 10	Submersible Sewage Pump (Non-clog type) Dia.250 mm × 103.3 L/S × 42 m	75	2	1	With 20m ³ closed surge tank and necessary two compressors, With 1 unit stock
M01-10-05/07	Delivery Valve	Motorized operated sluice valve φ200 mm	0.4	2	1	With control panel
M01-10-08	Monorail Hoist Unit	Manual monorail hoist with trolley 0.5 t × 1 unit, 2.5 t × 1 unit	-	1	0	With I two beams and Steel Columns Lift more than 3m

Item No.	Equipment Name	Specification	kW	Qty		Remarks
				duty	standby	
M01 -11-01/02	Lifting Pump 11	Submersible Sewage Pump (Non-clog type) Dia.200 mm × 43.3 L/S × 31 m	37	1	1	
M01 -11-03	Monorail Hoist Unit	Manual monorail hoist with trolley 0.5 t × 1 unit, 1.5 t × 1 unit	-	1	0	With two I beams and Steel Columns Lift more than 3m
M01 -12-01/04	Lifting Pump 12	Submersible Sewage Pump (Non-clog type) Dia.200 mm × 58.3 L/S × 33 m	45	2	1	With Flywheel (WR2= more than 45Nm ²) With 1 unit stock
M01 -12-05	Monorail Hoist Unit	Manual monorail hoist with trolley 2.5 t	-	1	0	With one I beam and Steel Columns Lift more than 3m
M01 -13-01/02	Lifting Pump 13	Submersible Sewage Pump (Non-clog type) Dia.100 mm × 6 L/S × 20 m	5.5	1	1	
M01 -13-03	Monorail Hoist Unit	Manual monorail hoist with trolley 0.5 t × 2 units	-	1	0	With two I beams and Steel Columns Lift more than 3m
M01 -14-01/02	Lifting Pump 14	Submersible Sewage Pump (Non-clog type) Dia.100 mm × 7.5 L/S × 24 m	7.5	1	1	
M01 -14-03	Monorail Hoist Unit	Manual monorail hoist with trolley 0.5 t × 2 units	-	1	0	With two I beams and Steel Columns Lift more than 3m
M01 -15-01/02	Lifting Pump 15	Submersible Sewage Pump (Non-clog type) Dia.100 mm × 12.5 L/S × 43 m	22	1	1	With Flywheel (WR2= more than 25Nm ²)
M01 -15-03	Monorail Hoist Unit	Manual monorail hoist with trolley 0.5 t × 1 unit, 1.0 t × 1 unit	-	1	0	With two I beams and Steel Columns Lift more than 3m

Item No.	Equipment Name	Specification	kW	Qty		Remarks
				duty	standby	
M01 -16-01/02	Lifting Pump 16	Submersible Sewage Pump (Non-clog type) Dia.100 mm × 25 L/S × 21 m	11	1	1	
M01 -16-03	Monorail Hoist Unit	Manual monorail hoist with trolley 0.5 t × 2 units	-	1	0	With two I beams and Steel Columns Lift more than 3m
M01 -17-01/04	Lifting Pump 17	Submersible Sewage Pump (Non-clog type) Dia.350 mm × 208.3 L/S × 15 m	55	2	1	With Flywheel in case of 1000rpm WR2= more than 50Nm ² , Without Flywheel in case of 1500rpm, with 1 unit stock
M01 -17-05/07	Delivery Valve	Motorized oprated sluice valve ø300 mm	0.4	2	1	With control panel
M01 -17-08	Monorail Hoist Unit	Manual monorail hoist with trolley 0.5 t × 1 unit, 2.5 t × 1 unit	-	1	0	With two I beams and Steel Columns Lift more than 3m

C3.2 List of Mechanical Equipment (STP)

Item No.	Equipment Name	Specification	kW	Qty		Remarks
				duty	standby	
M02	Grit Chamber Facility					
M02-01-01/02	Grit Chamber Inlet Gate	Manual Operated Cast Iron Gate W 500 mm × H 750 mm	0	2	0	Design depth 2,450mm (Bottom to floor)
M02-02-01/02	Medium Screen	Automatic Drum Screen Dia. 1400 mm, openings 20 mm, with Container	2.2	2	0	Water channel depth 1,900mm
M02-03-01/02	Grit Collector	Vorte× type Dia. 1600mm With Pressure Nozzles	0.75	2	0	Water channel depth 2,200mm Sand Pit bottom depth 2,000mm
M02-04-01/02	Grit Pump	Centrifugal Sludge Pump (Non-clog type) Dia.80 mm × 0.5 m ³ /min × 7 m	2.2	2	0	
M02-05-01/02	Sump Drain Pump	Non-clog Submersible Sludge Pump Dia.80 mm × 0.3 m ³ /min × 6 m	1.5	1	1	
M02-06	Grit Separator	Screw Conveyor Type (Compact type) 0.5m ³ /min	0.75	1	0	Grit Container with caster (0.5m ³ /unit × 4 units)
M02-07	Oil skimmer	Dia.200 mm × 4200 mmL	0	1	0	Carbon steel with corrosion resistant paint.
M02-08-01/02	Oil Discharge Pump	Submersible Sludge Pump Dia.65 mm × 0.2 m ³ /min × 6 m	0.75	1	1	
M02-09	Scum Screen	Automatic Drum type (Wedge Wire) 0.5m ³ /min, Openings : Less than 2 mm, with Container	0.4	1	0	
M02-10	Screenings Conveyor	Screw conveyor, shaft less type Dia.200 mm × L5.5 m	2.2	1	0	Screenings Container with caster (0.5 m ³ /unit × 4 units)
M02-11-01/02	Coarse Screen	Manually Bar Screen W 1,600 mm × H 1,900 mm, Bar openings 100 mm, with Container	0	2	0	Screenings Container with Caster (0.1m ³ /unit × 2 units)
M02-12	Bypass Gate	Manual Operated Cast Iron Gate W 500 mm × H 500 mm	0	1	0	Design depth 2,450mm (Bottom to floor)
M02-13	Grit Chamber Outlet Weir	Fixed Weir Plate (FRP) W 1.5 m	0	1	0	
M03	Distribution Chamber Facility					
M03-01-01/04	Distribution Weir	Manual Operated Cast Iron Adjustable Weir W 800 mm × Stroke 400 mm	0	4	0	Design depth 1,300mm (Bottom to floor)

Item No.	Equipment Name	Specification	kW	Qty		Remarks
				duty	standby	
M04	Oxidation Ditch Facility					
M04 -01-01/03	Air Diffuser	Super fine bubble, Membrane type air diffuser, whole aeration system Air : approx. 42 m ³ /min/tank	0	3	0	Water depth 6.0 m
M04 -02-01/12	Reactor Tank Mixer	Submersible propeller type mixer Propeller dia.approx. 2.4 m	approx. 2.3	12	0	Water depth 6.0 m
M04 -03-01/03	Outlet Gate	Manual Operated Cast Iron Gate W 500 mm × H 500mm	0	3	0	Design depth 4,100mm (Bottom to floor)
M04 -04-01	Isolation Gate	Manual Operated Cast Iron Gate W 500 mm × H 500mm	0	1	0	Design depth 4,100mm (Bottom to floor)
M04 -05-01/06	Aeration Blower	Rotary piston (roots) type blower (Air cooling) Dia.200mm × 42 m ³ /min × 70 kPa	75	3	2	
M04 -06-01/02	Hoist Block for Blower	Manual Operated Geared Trolley Chain Block 2.0 Ton, Lift= 5 m	0	2	0	
M04 -07-01/02	Air Supply Valve	Motorized butterfly valve with control panel Dia. 300mm	0.2	2	1	2 units are motorized and 1 unit is manual, 1 unit will be motorized in the future
M04 -08-01/06	Waste Sludge Pump	Submersible Sewage Pump (Non-clog type) Dia. 100mm × 1.1 m ³ /min × 14 m	5.5	3	3	With one unit stock
M05	Clarifier Facility					
M05 -01-01/03	Clarifier	Center Driven Colum type Dia. 25 m × WH 3.5 m	0.75	3	0	
M05 -02-01/06	Return Sludge Pump	Centrifugal Pump (Screw type) Dia.150 mm × 3.2 m ³ /min × 9 m	11	3	3	
M05 -03-01/02	Hoist Block for Sludge Pump	Manual Operated Geared Trolley Chain Block 1.0Ton, Lift=5 m	0	2	0	
M05 -04-01/04	Sump Drain Pump	Non-clog Submersible Sludge Pump Dia.80 mm × 0.3 m ³ / min × 6 m	1.5	2	2	
M05 -05-01/04	Scum Pump	Submersible Sludge Pump Dia.80 mm × 0.5 m ³ / min × 14 m	3.7	2	2	

Item No.	Equipment Name	Specification	kW	Q'ty		Remarks
				duty	standby	
M06	Utility & Disinfection Facility					
M06-01	Chlorine Solution Tank	Cylindrical Tank 7m ³ (effective more than 4.6 m ³)	1.5	1	0	with Agitator
M06-02-01	Chlorine Solution Storage Tank	Cylindrical tank, polyethylene 0.1 m ³	0	1	0	
M06-03-01/02	Chlorine Solution Dosing Charger	Manual flow control and gravity flow type Measuring range : 0 - 0.26 m ³ /hr, PVC	0	1	1	Manually Control
M06-04	Utility TE Water Supply Unit	Submersible two pumps with pressure tank Dia. 50 mm × 0.6m ³ /min × 42 m	7.4	1	0	With Control Panel
M06-05-01/04	Auto Strainer	Automatic Washing System 0.6 m ³ /min × mesh.0.4 mm	0.1	2	2	With Control Panel
M06-06-01/02	Defoaming Pump	Submersible Turbine Pump 0.6 m ³ /min × 29 m	3.7	1	1	
M06-07-01/02	Ultra Violet Disinfection Unit	Low Pressure High Intensity Type Daily Average Flow 9,200 m ³ /day/unit, Hourly Maximum 18,400 m ³ /day/unit	15	2	0	With Control Panel
M06-08-01/03	Disinfection Inlet Gate	Manual Operated Cast Iron Gate W 400 mm × H 600 mm	0	2	1	Design depth 1,800mm (Bottom to floor)
M06-09	Hoist Block for UV Unit	Manual Operated Geared Trolley Chain Block 0.5 Ton, Lift= 5 m	0	1	0	
M06-10	Hoist Block for Utility Pump	Manual Operated Geared Trolley Chain Block 0.5 Ton, Lift= 5 m	0	1	0	
M06-11	Disinfection Outlet Weir	Fixed Weir Plate (FRP) W 1.5 m	0	1	0	

Item No.	Equipment Name	Specification	kW	Q'ty		Remarks
				duty	standby	
M07	Sludge Treatment Facility					
M07-01-01/02	Sludge Dewatering Unit	Multi-Diskplate Screw Press 180 kg-ds/ hr	approx. 6	1	1	With Control Panel
M07-02	Sludge Cake Conveyor	Shaftless Screw Conveyor Dia. 400 mm × L 10 m	5.5	1	0	
M07-03	Sludge Cake Hopper	Motor Driven Cutgate Type 15 m ³	4.4	1	0	
M07-04-01/02	Polymer Dissolving Tank	Cylindrical Steel Tank 17 m ³	11	1	1	With Agitator
M07-05-01/02	Polymer Feeder	Constant Chemical Feeder 2.3 kg/ min	0.4	1	1	
M07-06-01/02	Polymer Feed Pump for Dewatering	Progress Cavity Pump 0.7-2.0 m ³ /hr × 20m	1.5	1	1	
M07-07-01/02	Air Compressor	Pressure-switch Type 400 NL/ min × 0.83 Mpa	3.7	1	1	With Control Panel
M07-08-01/02	Air Dryer	Refrigerating type 400 NL/ min	0.2	1	1	
M07-09	Hoist Block for Dewatering Unit	Manual Operated Gearing Trolley Chain Block 2.0 Ton, Lift=5 m	0	2	0	
M07-10	Hoist Block for Sludge Treatment Building	Manual Operated Gearing Trolley Chain Block 2.0 Ton, Lift=5 m	2.8 0.4	2	0	one unit manual and one unit motorized
M07-11-01/02	Sump Drain Pump	Non-clog Submersible Sludge Pump Dia.80 mm × 0.3 m ³ /min × 6 m	1.5	1	1	
M07-12-01/02	Waste Water Mixer	Submersible Mixer	1.5	1	0	With one unit stock
M07-13-01/02	Waste Water Pump	Submersible Sludge Pump Dia.100 mm × 2.0 m ³ /min × 14 m	11	1	1	
M07-14	Biological Odor Control	40 m ³ / min	0	1	0	With Control Panel
M07-15-01/02	Deodorization Fan	Turbo fan 40 m ³ / min	5.5	1	1	
M07-16	Utility Potable Water Supply Unit	Submersible two pumps with pressure tank Dia. 50 mm × 0.45 m ³ / min × 25 m	4.4	1	0	With Control Panel
M07-17	Hoist Block for Utility Pump	Manual Operated Gearing Trolley Chain Block 0.5 Ton, Lift=5 m	0	1	0	