

A-7 Field Report


**PREPARATORY SURVEY
ON
THE PROJECT
FOR
RURAL ELECTRIFICATION PHASE III
IN
THE REPUBLIC OF UGANDA**

THE FIRST FIELD SURVEY


FIELD REPORT

April 21st, 2011

Presented and submitted by:


Mr. Masatsugu KOMIYA
Chief Consultant,
JICA Study Team,
Japan International Cooperation Agency
(JICA)

Confirmed by:


Mr. Godfrey R. Turyahikayo
Executive Director,
Rural Electrification Agency (REA),
Ministry of Energy and Mineral Development
(MEMD)

Witness



Mr. Fred Kabagambe Kallisa
Permanent Secretary,
Chairman of Rural Electrification Board,
Ministry of Energy and Mineral Development
(MEMD)

Table of Contents

1. Introduction	1
2. Information and Results of the Site Survey	4
2.1 Areas where the Site Survey was carried out	4
2.2 Beneficiary of the Project	5
2.2.1 Extension of 33 kV distribution line in Iganga, Bugiri and Busia District (Area-4)	5
2.2.2 Extension of 33 kV distribution line in Masaka and Rakai District (Area-2)	6
2.2.3 Extension of 33 kV distribution line in Bushenyi and Rukungiri District (Area-5)	7
2.3 Network Diagrams and Route Maps of the Project	8
2.3.1 Extension of 33 kV distribution line in Iganga, Bugiri and Busia District (Area-4)	8
2.3.2 Extension of 33 kV distribution line in Masaka and Rakai District (Area-2)	9
2.3.3 Extension of 33 kV distribution line in Bushenyi and Rukungiri District (Area-5)	10
2.4 Environmental and Social Considerations	11
2.4.1 Environmental and Social Aspects	11
2.4.2 Location of the 33kV Distribution Lines	11
2.4.3 Environmental Certificate (EC)	12
3. Priority of the Requested Sites	13
4. Design Conditions and Technical Specifications	14
4.1 Design Conditions	14
4.1.1 Climatic Conditions	14
4.1.2 Basic Electrical Design Conditions	14
4.1.3 Applicable Codes / Standards and Units	16
4.2 Basic Technical Specifications	16
5. Data Collection of connecting situations in the Previous JICA's Project Area	19
6. Questionnaire for the Second Field Survey	19
7. List of Parties Concerned in the Recipient Country	20

ANNEX

PART 1:

Extension of 33 kV distribution line in Iganga, Bugiri and Busia District (Area-4)

1. Socio-economic Data
2. Network Diagram
3. Route Map of Distribution Line

PART 2

Extension of 33 kV distribution line in Masaka and Rakai District (Area-2)

1. Socio-economic Data
2. Network Diagram
3. Route Map of Distribution Line

PART 3

Extension of 33 kV distribution line in Bushenyi and Rukungiri District (Area-5)

1. Socio-economic Data
2. Network Diagram
3. Route Map of Distribution Line

PART 4 Pole Assembly Drawing for Distribution Line

DWG No. T-01	Intermediate Pole (Line Angle 0 to 5 degrees)	TYPE A
DWG No. T-02	Light angle Pole (Line Angle 5 to 30 degrees)	TYPE B
DWG No. T-03	Heavy angle Pole (Line Angle 30 to 50 degrees)	TYPE C
DWG No. T-04	Heavy angle Pole (Line Angle 50 to 90 degrees)	TYPE D
DWG No. T-05	Section Pole	TYPE E
DWG No. T-06	Section Pole (VERTICAL)	TYPE F
DWG No. T-07	Terminal Pole	TYPE G
DWG No. T-08	Load Break Switch Pole	TYPE H
DWG No. T-09	T-off Pole	TYPE J
DWG No. T-10	Transformer Pole	TYPE K
DWG No. T-11	3 Member Pole	TYPE L
DWG No. T-12	Bulk Metering Unit Pole	TYPE M
DWG No. T-13	Connection Plan to the Existing Line (Extension Type)	TYPE N1
DWG No. T-14	Connection Plan to the Existing Line (Cross Type)	TYPE N2
DWG No. T-15	33kV Auto Recloser Pole	TYPE 3R

PART 5 Questionnaire for the Second Field Survey

1. Introduction

In June 2009, the Government of the Republic of Uganda made a request for Grant Aid for the Project for Rural Electrification Phase III (the Project) to the Government of Japan. The Japan International Cooperation Agency (JICA), the official agency implementing technical cooperation, ODA loans, and Grant Aid, has conducted Data Collection Survey on Rural Electrification (the Previous Survey) from June to July, 2010. As a result of the Previous Survey, JICA decided to conduct a Preparatory Survey (the Survey) to formulate Outline Design, project plan, cost estimation and sent the Survey team for the First Field Survey (the Team), headed by Dr. Akira NIWA, Senior Advisor, JICA.

In order to build mutual understanding between the Ugandan side and the Team (Both Parties) on the technical and engineering aspects, this Field Report has been prepared based on the results of the first field survey and discussions with the Ugandan side, i.e., Rural Electrification Agency (REA) and Ministry of Energy and Mineral Development (MEMD). However, the final components of the Project will be decided by the Government of Japan.

Both parties confirmed the necessity and urgency of the requested sites, and evaluated the priority of the sites in terms of contributions to rural development through electrification, technical features, and environmental & social considerations as shown in Minutes of Discussions (M/D) signed by both parties on 8th April, 2011. Contents of main components and priority ranking confirmed by Both Parties are shown in Table 1, which is also as described in M/D.

Based on the discussion and agreement between Both Parties, a site survey was carried on three sites which was rated as Priority Ranking A and Priority Ranking B in M/D. Some components requested by the Government of Uganda have been constructed by itself after the request, and these components are omitted from the Project and the site survey. Scope of the site survey is shown in Table 2.

Table 1 Contents of main components and priority ranking confirmed by Both Parties

Project Site	Area/Region	Priority Ranking ⁽¹⁾	Contents of main components ⁽²⁾	Project Features
1	Bale-Gallaya (Central) ⁽³⁾	C	- Supply and installation of 33kV distribution Lines (approx. 44.1km) and distribution transformers (33kV/415-230V)	- Need socio-economic justification for 44km extension of the existing Koyunga-Bale line (JICA I) - Length of line passing CFRs*: approx. 10km - Recommendable for strengthening private participation in rural electrification - Length of line passing CFRs*: approx. 8km
2	Bakira-Namirembe & Masaka-Nyahayajwe (Central)	B	- Supply and installation of 33kV distribution Lines (approx. 93.9km) and distribution transformers (33kV/415-230V)	- Power to Kiganda will be supplied from Muzazi (Miyana)-Kiganda line, which is on-going grant project by Norway. This reduces on number of connections and consequently project benefit. - Length of line passing CFRs*: approx. 4.5km
3	Kiganda-Mubende (Central)	C	- Supply and installation of 33kV distribution Lines (approx. 57.1km) and distribution transformers (33kV/415-230V)	- Highly recommendable for electrification of new district headquarters (Namatyango) and synergy with Interconnection of Electric Grids of Nile Equatorial Lakes Countries Project (NELSAP) - Length of line passing CFRs*: approx. 1.5km
4	Iganga-Nakabugu & Mayuge-Lumino (Eastern) ⁽⁴⁾	A	- Supply and installation of 33kV distribution Lines (approx. 160.8km) and distribution transformers (33kV/415-230V)	- Highly recommendable for synergy with OVOP and NELSAP. - Project scope has been reduced by various rural Electrification Projects funded by the Government of Uganda. The remaining project scope proposed to JICA
5	Kitagata-Kasana & Kitagata-Kabwohe (Western) ⁽⁵⁾	B	- Supply and installation of 33kV distribution Lines (approx. 58.7km) and distribution transformers (33kV/415-230V)	- Project scope has been reduced by various rural Electrification Projects funded by the Government of Uganda. The remaining project scope proposed to JICA

Table 2 Scope of the Site Survey

Priority A: Area-4

Extension of 33 kV distribution line in Iganga, Bugiri and Busia District

No.	Project Area	Length [km]
4.0	Iganga-Nakabugu, Mayuge-Lumino	137.7
4.1	Banda lugala	4.9
4.2	Haarembe	5.9
4.3	Matale Point	5.0
4.4	Busiro	7.3
Subtotal		160.8

Priority B: Area-2

Extension of 33 kV distribution line in Masaka and Rakai District

No.	Project Area	Length [km]
2.0	Bakira-Namirembe-Masaka-Nyahayajwe	80.9
2.2	Zzimwe	5.9
2.3	Nakanyaga	3.3
2.4	Buwunga	3.8
Subtotal		93.9

Area-5

Extension of 33 kV distribution line in Bushenyi and Rukungiri District

No.	Project Area	Length [km]
5.0	Kitagata-Kasana-Kagati, Rwanja-Karisizo, Kitagata-Mukibirizi, Rwobugimbi-Kitagata	56.3
5.1	Kotoma	2.4
Subtotal		58.7

Note: Grey-colored component are omitted from the Project in M/D.

2. Information and Results of the Site Survey

2.1 Areas where the Site Survey was carried out

Based on the discussion and agreement between Both Parties, the site survey was carried on three sites which was rated as Priority Ranking A and Priority Ranking B in M/D. The location of areas where the site survey was carried out is shown in Figure 1.

6	Hoima-Mbarara-Kinyara (Western)	C	- Supply and installation of 33kV distribution Lines (approx. 61.8km) and distribution transformers (33kV/415-230V)	- is now limited to Kitagata-Kasana-Kagati with spur to Rukondo, Rwanja-Karisizo, Kitagata-Mukibirizi and Rwobugimbi-Kitagata. - Length of line passing CFRs*: None - Need clarification of socio-economic benefit produced after connecting trading centers. - Project scope has been reduced by various rural Electrification Projects funded by the Government of Uganda. The remaining project scope proposed to JICA is now limited to Hoima-Mbarara-Kinyara with spur to Kityimbogi and Kyabegya. - Length of line passing CFRs*: approx. 7.5km
---	---------------------------------	---	---------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Notes:

- (1) Factors which are considered in evaluation of priority ranking are: impact to rural economy and development, access to electricity in the underserved area and environment.
- (2) Content of main components is based on the results of the previous survey and additional information provided by REA. Modification in the quantities and additional new items/equipments will be determined based on the site survey.
- (3) Length of the line originally requested was approx. 91.2km. However, project component of Koyunga-Busuma and associated costs is under implementation with financing from the Government of Uganda.
- (4) The line originally requested was Iganga-Nakabugu. However, it has been changed to Iganga-Kaciro because the project to supply the District headquarters at Lunda (Nakabugu) from Kaciro has been funded by the Government of Uganda.
- (5) CFR stands for Central Forest Reserve managed by NFA. The proposed alignments including those passing CFRs are along the existing roads.
- (6) "Project Features" for Project Site 5 and Project Site 6 were presented in Annex-4. Minutes of Discussion signed on 8th April, 2011, because one for Project Site 5 had been described in the column for Project Site 6. Accordingly, one for Project Site 6 were added in the column for Project Site 6 above.



Figure 1 Areas where the Site Survey was carried out

2.2 Beneficiary of the Project

2.2.1 Extension of 33 kV distribution line in Iganga, Bugiri and Busia District (Area-4)

(i) Primary beneficiaries

1) Potential Consumers

In the inland, main livelihoods of potential consumers are farming (cassava, maize, ground nut, beans, rice, millet, sugarcane), trading and they also have livestock (cattle, goat, chicken). All activities are in small scale. On the lake shore, the main livelihood is dominated by fishing of tilapia and Nile perch although they have farming. Approximate average monthly incomes are 50,000 - 100,000 UGX/household by farming, 150,000 - 200,000 UGX/household by fishing and

up to 950,000 UGX/household by trading.

Most trading centers have generators and solar panels for TV theaters, barber shops, lighting, charging for mobile phones and even distributing electricity for neighbor houses. Milling machines are also inevitable to process local food materials (maize, millet and cassava) for daily life. They also consume oils for kerosene lamp and tadoba as main lighting. They are willing the electricity for the activities done by the generators and solar panels, the lighting and to establish new businesses like food processing, cool storage, welding and carpentry.

The amounts of potential consumers are as follows.

- Trading center (TC): 37 TCs
- Household: 9,095 households
- Population: 69,990 persons

Table 1 Amounts of Potential Consumers in Area-4

No.	Size of TC	No. of TC	Household	Population	Remarks
1	Over 1,000 households	2	4,200	31,800	Namayingo TC is the district center of newly established district last year.
2	500 - 999 households	0	0	0	
3	100 - 499 households	24	4,340	34,080	
4	Under 100 households	11	555	4,110	
5	Total	37	9,095	69,990	

2) Public Facilities

(a) School

- Primary school: 101 schools
- Secondary school: 17 schools
- Tertiary school: 2 schools

(b) Health Center

- Health center IV: 2 centers
- Health center III: 5 centers
- Health center II: 8 centers

(2) Secondary beneficiaries

- Pulish population covered by schools and health centers

2.2.2 Extension of 33 kV distribution line in Masaka and Rakai District (Area-2)

(3) Primary beneficiaries

1) Potential Consumers

In the inland, main livelihoods of potential consumers are farming (pineapple, coffee, matooke, cassava, maize, beans, and sugarcane). Trading and they also have livestock (cattle, goat, and chicken). The pineries outstand in the farming activities. On the lake shore, the main livelihood is dominated by fishing of tilapia and Nile perch although they have farming. Approximate average

for cattle. Coffee is also outstanding in local agricultural crops. Approximate average monthly incomes are 50,000 - 100,000 UGX/household by farming.

Most trading centers have generators for TV theaters, barber shops, lighting, and charging for mobile phones. Milling machines are also inevitable to process local food materials (maize, millet and cassava) for daily life. They also consume oils for kerosene lamp and tadoba as main lighting. They are willing the electricity for the activities done by the generators, the lighting and to establish new businesses like coffee factory, cool storage, welding and carpentry.

The amounts of potential consumers are as follows.

- Trading center (TC): 10 TCs
- Household: 985 households
- Population: 6,860 persons

Table 3 Amounts of Potential Consumers in Area-5

No.	Size of TC	No. of TC	Household	Population	Remarks
1	Over 1,000 households	0	0	0	
2	500 - 999 households	0	0	0	
3	100 - 499 households	4	770	5,540	
4	Under 100 households	6	215	1,320	
5	Total	10	985	6,860	

2) Public Facilities

(a) School

- Primary school: 20 schools
- Secondary school: 4 schools
- Tertiary school: 2 schools

(b) Health Center

- Health center III: 2 centers
- Health center II: 2 centers

(6) Secondary beneficiaries

- Pulish population covered by schools and health centers

2.3 Network Diagrams and Route Maps of the Project

2.3.1 Extension of 33 kV distribution line in Iganga, Bugiri and Busia District (Area-4)

The requested component in Area-4 had been separated into two parts. A part had been a distribution line from Iganga to Nakabugu. The other had been distribution lines from Mayuge to Lumino. Through discussion between Both Parties, it had been confirmed that Nakabugu, which is the biggest demand area in the former part, has already been electrified by 33 kV distribution line from Kaliro. Therefore, the electrification between Kiyungi and Iganga had been requested in discussion before the site survey. However, it was confirmed through the site survey that the part is also under construction of 33 kV distribution lines by UEDCL. As the result, it is agreed between

monthly incomes are 50,000 - 150,000 UGX/household by farming, 50,000 - 100,000 UGX/household by fishing and 300,000 UGX/household by trading in a comparatively large trading center in the area.

Most trading centers have generators and solar panels for TV theaters, barber shops, lighting, charging for mobile phones and even distributing electricity for neighbor houses. Milling machines are also inevitable to process local food materials (maize, millet and cassava) for daily life. They also consume oils for kerosene lamp and tadoba as main lighting. They are willing the electricity for the activities done by the generators and solar panels, the lighting and to establish new businesses like food processing (coffee factory, juice factory), cool storage for fish and milk.

The amounts of potential consumers are as follows.

- Trading center (TC): 13 TCs
- Household: 1,980 households
- Population: 9,300 persons

Table 2 Amounts of Potential Consumers in Area-2

No.	Size of TC	No. of TC	Household	Population	Remarks
1	Over 1,000 households	1	1,000	3,000	
2	500 - 999 households	0	0	0	
3	100 - 499 households	7	790	5,250	
4	Under 100 households	5	190	1,050	
5	Total	13	1,980	9,300	

2) Public Facilities

(a) School

- Primary school: 25 schools
- Secondary school: 5 schools
- Tertiary school: 3 schools

(b) Health Center

- Health center III: 2 centers
- Health center II: 1 centers
- Health center I: 2 centers

(4) Secondary beneficiaries

- Pulish population covered by schools and health centers

2.2.3 Extension of 33 kV distribution line in Bushenyi and Rukungiri District (Area-5)

(5) Primary beneficiaries

1) Potential Consumers

Main livelihoods of potential consumers are farming (matooke, coffee, cassava, beans), trading and they also have livestock (cattle, goat, chicken). The land use of Area-5 is dominated by ranch

Both Parties that the part shall be omitted from the Project.

As the result of the site survey, it was also agreed between Both Parties that the other part is 33 kV distribution lines between Mayuge (Connection Point A) and Lumino (Connection Point B) including T-off lines to Busiro and Bumeru. Around Nankoma area, which is located in middle between Mayuge and Lumino, has been already electrified, and the requested distribution lines of the part are also separated into two parts. It is composed of construction of 33 kV distribution lines between Mayuge (Connection Point A) and Nankoma (Connection Point B), and ones between Nankoma (Connection Point C) to Lumino (Connection Point D) including T-off lines to Busiro and Bumeru. They are finally the components of the Project in Area-4.

Based on the results of the site survey, their network diagram and route maps of distribution lines are shown in "ANNEX" of this Field Report. And number of Tracing Centers where distribution transformers shall be installed was specified as 37, which is also shown in socio-economic data in "ANNEX" of this Field Report.

Based on the results of the site survey, Total Length of the distribution line is Approx. 130 km. And length of the distribution lines of the component of the Project in Area-4 is as follows;

- Line from Mayuge (Connection A) to Nankoma (Connection B): Approx. 22 km
- Line from Nankoma (Connection C) to Lumino (Connection D): Approx. 45 km
- T-off line to Busiro: Approx. 30 km
- T-off line to Bumeru: Approx. 33 km

And it was agreed by Both Parties that T-off Lines to Matala Point (4.2) and Haarembe (4.2) shall be omitted from the Project, because they are very small villages and appropriateness for the Japan's grant aid was not confirmed.

2.3.2 Extension of 33 kV distribution line in Masaka and Rakai District (Area-2)

The requested component in Area-2 had originally been construction of 33 kV distribution lines between Masaka and Kyotera. However, it was confirmed through the site survey that 33 kV distribution line between Kyambazi and Ndeeba-Lwaggle, which are located in middle between Masaka and Kyotera, including a T-off Line to Dimo Landing Site is under construction (However the line will be connected to existing 11 kV line and operated in 11 kV). The component of the Project in Area-5 is separated into two parts. A part is a distribution line from Nyendo (Connection Point A) to Kyambazi including a T-off line to Namirembe. The other is a distribution line from Ndeeba-Lwaggle to Kyotera (Connection Point B).

Based on the results of the site survey, their network diagram and route maps of distribution lines are shown in "ANNEX" of this Field Report. Number of Tracing Centers where distribution transformers shall be installed was specified as 13, which is also shown in socio-economic data in "ANNEX" of this Field Report.

Based on the results of the site survey, Total Length of the distribution line is Approx. 65 km. And length of the distribution lines of the component of the Project in Area-2 is as follows:

- Line from Nyendo (Connection A) to Kyambazi: Approx. 36 km
- Line from Nankoma (Connection C) to Ndeeba-Lwaggle: Approx. 29 km

Based on the results of the site survey, it was agreed by Both Parties that T-off Lines to Zimwe (2.2) shall be omitted from the Project, because it is a very small village and appropriateness for the Japan's grant aid was not confirmed.

2.3.3 Extension of 33 kV distribution line in Bushenyi and Rukungiri District (Area-5)

Concerning Area-5, construction of 33 kV distribution line in length of 86.0 km had been originally requested. It had been confirmed through discussion between Both Parties that some part of the requested component has been already constructed or under construction by the Ugandan side. Therefore, construction of 33 kV distribution line in length of 58.7 km had been specified in M/D as the components of the Project. However, it was confirmed through the site survey that most of the distribution lines in the length of 58.7 km specified in M/D has also been constructed or under construction. The rest of the requested lines were separated to four parts and the length of each part is less than 10 km.

Area between Kabwohe and Kitagata has already been electrified or under construction in 11 kV, and this area shall be omitted from the Project. While, area between Kitagata and Karisizo has already been electrified or under construction in 33 kV, and this area shall also be omitted from the Project.

Based on the results of the site survey, the component of the Project in Area-5 are composed of a line from Kitagata (Connection A) to Furuma including a T-off line to Katoma, a line from Kitagata (Connection B) to Katagi including Kassana, a line from Kitagata (Connection C) to Rukondo, and a T-off line to Kihanga which is a branch line from the line between Kitagata and Karisizo already under construction. They shall be in 33 kV.

Based on the results of the site survey, their network diagram and route maps of distribution lines are shown in "ANNEX" of this Field Report. Number of Tracing Centers where distribution transformers shall be installed was specified as 10, which is also shown in socio-economic data in "ANNEX" of this Field Report.

Based on the results of the site survey, Length of the distribution lines of the component of the Project in Area-5 is as follows:

- Line from Kitagata (Connection A) to Furuma including a T-off line to Katoma: Approx. 8 km
- Line from Kitagata (Connection B) to Katagi including Kassana: Approx. 10 km
- Line from Kitagata (Connection C) to Rukondo: Approx. 4 km
- T-off line to Kihanga: Approx. 8 km

16

- Area-4: The main requested route along the road between Mayuge TC and Lumino TC is managed by UNRA. It can be seen that the road reserve is secured even not certainly 15m from the road center in the TCs. LC I chairpersons or local council members interviewed in the field survey are aware of the road reserve along the main route.
- Area-2: The requested routes are located along rather wider district roads.
- Area-5: All roads are narrow passing in mountainous site.

On that basis, the road reserves of selected routes should be cleared according to road classification of national and district levels, if REA will use the road reserves for the Project. Even in case that REA will not use the road reserve, distances to be kept from them should be cleared.

Meanwhile, REA's policies and procedures how to secure the routes of 33kV distribution lines should be confirmed. REA will take the following steps for compensation on the routes.

- Community meeting
- Survey and Explanation to persons whose properties are affected
- Agreement with the wayleaves consent form
- Evaluation of properties on the routes with the wayleaves assessment form
- Preparation of evaluation report
- Submission of the evaluation report to a Chief Government Valuer in Ministry of Land
- Assessment and authorization by a Chief Government Valuer

Explanation of evaluation results to the affected owners and payment

2.4.3 Environmental Certificate (EC)

REA shall obtain an Environmental Certificate (EC) from NEMA to implement the Project. As the first step, REA shall submit NEMA a Project Brief which describes the outline of the project, likely impacts caused by the Project and the mitigation measures. NEMA will determine whether or not the Project is exempted from an EIA based on the Project Brief. For obtaining the EC with the Project Brief exempted from the EIA, one of important issue is negative impact on natural environment especially on the central forest reserves (CFR) and wetlands.

In the requested areas, most lands along the requested routes are cultivated already and the Environment Officers say the wetlands have common aspects in the country. In this context, the 33 kV distribution lines can minimally affect the natural environment. The major aspects of nature are as follows. Regarding these aspects, Area-4 will have the least negative impacts on the natural environment by the Project.

- Area-4: The Area has totally gently undulating hills in topography and the requested route passes a CFR named Irimbi CFR which is used for industrial and commercial plantation on rocky hill in the short length at approximately 500m. In the inland, there are seasonal wetlands that the local people have been cultivating, and few wetlands on the lakeshore area.
- Area-2: In Masaka District, the topography is hilly and the requested routes pass through

12

2.4 Environmental and Social Considerations

2.4.1 Environmental and Social Aspects

In the field survey, environmental and social aspects in the Areas are summarized as follows:

Table 4 Environmental and Social Aspects in the Areas

Area	Area-4	Area-2	Area-5
District	Mayuge, Bugiri, Namayingo, Busia	Masaka, Rakai	Bushenyi, Rukungiri
Topography	- Hilly site - Lake shore site	- Hilly site - Lake shore site	- Mountainous site - Both sides along the routes are rather steep slopes.
Land Use	- cultivated lands, Ranch - Woodlot (forestry)	- Ranch, cultivated lands (pinyon) - Woodlot (forestry)	- Ranch, cultivated lands - Woodlot (forestry)
Socio-economy	- Farming: cassava, maize, ground nut, beans, rice, millet, sugarcane - Fishing: tilapia, Nile perch - Livestock: cattle, goat, chicken - Approx. average monthly income: 50,000 - 100,000 (farming), 150,000 - 200,000 (fishing), up to 950,000 (trading) UGX/household	- Farming: pineapple, coffee, matooke, cassava, maize, beans, sugarcane - Fishing: tilapia, Nile perch - Livestock: cattle, goat, chicken - Trading: retailers - Approx. average monthly income: 50,000 - 150,000 (farming), 300,000 (trading) UGX/household	- Farming: matooke, coffee, cassava, beans - Livestock: cattle, goat, chicken - Trading: retailers - Approx. average monthly income: 50,000 - 100,000 (farming) UGX/household
Forest Reserve	- Irimbi CFR (Bugiri): Approx. 500m on the route	- Nabukongo CFR (Masaka): Approx. 500m on the route - Kineti CFR (Masaka): Approx. 500m on the route - Muzizi CFR (Masaka): Approx. 2km on the route	- None
Wetland	- Common wetlands - There are few wetlands and most them are seasonal ones. - Local people have been cultivating the wetlands	- Common wetlands - There are permanent wetlands - The route in Rakai passes a wetland at 2km	- Common wetlands - There are permanent wetlands
Suggestions from EOs*	<ul style="list-style-type: none"> - Water flow in the wetlands should not be obstructed by poles - Embankment for pole installation in the wetlands should be shorter from roads - No erosion from the embankment - Involvement of communities (local councils), district offices and sub-counties - Sensitization for workers and local peoples - Conserve cultural and valuable trees and re-plantation - Electricity is a step for improving livelihood leading to conserve environment - Prevent preservatives of poles being into the wetlands 		

Note: * EO (Environment Officer)

2.4.2 Location of the 33kV Distribution Lines

In three Areas, the structures along the requested routes are built set-back especially in the trading centers. However, the other lands along the routes are mostly used for cropland, ranch and woodlot except natural vegetation and wetlands. Some branch routes are located along very narrow roads. The major aspects of roads on the requested routes are as follows.

11

three CFRs and several permanent wetlands. One of them, Muzizi CFR, is located along the shore of Lake Victoria. In the route of Rakai District, there are gently undulating hills and no CFRs but the route passes a permanent wetland at approximately 2km.

- Area-5: There are no CFRs although several wetlands are located, and Area-5 has mountainous topography. Lands along the requested routes are rather steep slopes than the other Areas. Several trading centers are also built on the slopes.

3. Priority of the Requested Sites

Based on the discussion and agreement between Both Parties, the site survey was carried on three sites which was rated as Priority Ranking A and Priority Ranking B in M/D. The areas where the site survey was carried out were shown in following Table.

Table 5 Areas where Site Survey was carried out

Rate	Area	Components
Priority A	Area-4	Extension of 33 kV distribution line in Iganga, Bugiri and Busia District
Priority B	Area-2	Extension of 33 kV distribution line in Masaka and Rakai District
Priority B	Area-5	Extension of 33 kV distribution line in Bushenyi and Rukungiri District

Concerning Area-5, construction of 33 kV distribution line in length of 86.0 km had been originally requested. It had been confirmed through discussion between Both Parties that some part of the requested component has been already constructed by the Ugandan side, and construction of 33 kV distribution line in length of 58.7 km had been specified in M/D as the components of the Project. However, it was confirmed through the site survey that most of the distribution line in the length of 58.7 km specified in M/D has also been constructed or under construction. The rest of the requested lines were separated to four parts and the length of each part is less than 10 km. Therefore, the scale of the components is considered to be too small for the Japan's grant aid project, and the scale merit is not expected. It is strongly recommended that the component is constructed with budget of the Ugandan side.

Following Table shows the total number of Trading Centers, public facilities such as schools and health centers, and general households from the site survey. Comparing with Area-4 and Area-2, the number of those in Area-4 is extremely bigger than those in Area-2, even though difference of the length of the components is took into consideration.

Table 6 Areas where Site Survey was carried out

Area	Length (km)	Trading Center	Schools				Health Center				Household
			Primary	Secondary	Technical	Other	I	II	III	IV	
Area-4	136	27	149	17	2	3	5	5	5	5	995
Area-2	65	11	24	2	0	0	0	0	0	0	100
Area-5	59	4	2	0	0	0	0	0	0	0	20

Note: The numbers described above are specified based on the results of the site survey

Based on the results of the site survey, the Team prioritized the components of the Project as follows in consideration of contributions to activities of public facilities and general households, and project effectiveness.

13

Table 7 Priority Rankin of the Components

Priority Ranking	Area	Components	* Length (km)
1st	Area-4	Extension of 33 kV distribution line in Iganga, Bugiri and Jinja District	Approx. 130 km
2nd	Area-2	Extension of 33 kV distribution line in Masaka and Rakai District	Approx. 42 km
3rd	Area-5	Extension of 33 kV distribution line in Bushenyi and Rukungiri District	Approx. 30 km

Note: *The length is specified based on the results of the site survey

4. Design Conditions and Technical Specifications

4.1 Design Conditions

Design conditions to be applied to the Project are described as follows.

4.1.1 Climatic Conditions

Natural conditions for the equipments and facilities design are described as follows.

Table 8 Climatic Conditions for the equipments and facilities design

Item	The Project Area		
	Area-4 (Iganga, Bugiri and Busia District)	Area-2 (Masaka and Rakai District)	Area-5 (Bushenyi and Kukungiri District)
Altitude	Less than 1,000m	Less than 1,000m	Less than 1,500m
Ambient Temperature	Maximum	35°C	33°C
	Minimum	15°C	12°C
	Mean	25°C	22°C
Maximum Humidity	85%	80%	75%
Max. Wind Velocity	20m/sec.	15m/sec.	25m/sec.
Rainfall	2,200mm/year	2,500mm/year	2,700mm/year
Seismic Force	Horizontal 0.1G	Horizontal 0.1G	Horizontal 0.1G
Soil Bearing Capacity	5 ton/m ²	5 ton/m ²	10 ton/m ²

Source: UGANDA DISTRICTS Information Handbook (2007-2008)

4.1.2 Basic Electrical Design Conditions

(1) Electric System (Voltage and Wiring System)

Voltage, wiring, frequency and earthing system to be applied for the 33kV distribution line shall be the same as those of the existing facilities. The summary of the electrical system concerned with the Project is shown in the following Table

Table 9 Summary of Electricity System

Nominal Voltage	33 kV
Maximum Voltage	36 kV
Wiring Method	3 phase, 3 wires
Frequency	50 Hz
Earthing System	Effective Earth
Earth Fault Current	25kA
Lightning Impulse Withstand Voltage (LIWV)	170kV
Commercial Frequency Withstand Voltage	70kV
Creepage distance	16 mm / kV
Overhead Grounding Wire	Not Required

(2) Other Electrical Systems

1) Color coding

Applicable color coding shall be in accordance with IEC standard, Red, Yellow, Blue and Black (Neutral).

2) Safety Factor

Following Safety Factor shall be maintained in all design and construction works:

- Pole, Foundations: 2.0
- Conductor, Crossarms: 2.5
- Insulators: 2.0

3) Clearance for Conductors

Clearance on 33kV overhead line shall be as follows:

- Minimum Clearance
 - Phase to phase: 430 mm
 - Phase to ground: 380 mm
- Minimum Height from Ground Level
 - Road Crossing: 7.5 m
 - Roadside: 6.5 m

4) Electrical Pole Span Length

- Single and double pole: Maximum 100m
- Three member pole: Maximum 300m

5) Load Break Switch

Load Break Switch shall be installed at major branching point and at intervals of about 13km for inspection and maintenance of the 33kV distribution line.

6) Auto Recloser

Auto Recloser shall be installed at major connection point or branch point.

7) Metering Unit

Metering Unit shall be installed at connection point where the operator (UMEME, FERDSULT, others) is not yet decided.

4.1.3 Applicable Codes / Standards and Units

(1) Applicable Codes/Standards

The following Japanese and International standards/codes shall be generally applied to the Project as well as the Uganda National Primary Grid Code and other technical standards specified by REA.

- International Electrotechnical Commission (IEC)
- British Standard (BS)
- International Standardization Organization (ISO)
- Japanese Industrial Standard (JIS)
- Japanese Electrotechnical Commission (JEC)
- The Standard of Japan Electrical Manufacturer's Association (JEM)
- Japan Cable Maker's Association Standard (JCS)
- Other Japanese and International Standards concerned

(2) Units

Unit of length, area, volume, mass (weight), etc. used in the Project (such as Design, manufacturing, Installation, Testing and Reporting) shall be in accordance with the International System of Units (SI) unless otherwise specified.

4.2 Basic Technical Specifications

Basic technical specifications of major equipment and materials are described as follows.

Table 10 Basic technical specifications of major equipments

Equipment	Specifications
(1) Distribution Transformers	
1) Applicable Standard	IEC, JIS, JEC, JEM or Equivalent
2) Type	Oil immersed, Hermetically-sealed, Outdoor, Pole-mount type
3) Nominal Voltage	33,000/415-240 V
4) Impedance Voltage	4-5 %
5) Tapping Voltage (%) on HV Side	±2.5 %, ±5.0 % (no voltage tap changer)
6) Phase	HV: 3 phases, LV: 3 phase, 4-wire
7) Frequency	50 Hz
8) Vector Symbol	Dyn11
9) Capacity	50, 100, 200 kVA
10) Efficiency (%)	50 kVA: 97.2 < 100 kVA: 97.7 < 200 kVA: 98 <
11) Accessories	-Name Plate -Oil temperature indicator and breather
(2) Load Break Switch	
1) Applicable Standard	IEC, JIS, JEC, JEM or Equivalent
2) Type	Manual Operation
3) Rated Nominal Current	630 A
4) Rated Voltage	33 kV
5) Rated Frequency	50 Hz
6) LIWV	170 kV
7) Rated Breaking Capacity	630 A (at load current)
8) Rated Short-Time Current	16 kA (1 sec.)
9) Creepage Distance	min. 825 mm
10) Accessories	-Name Plate -Operation mechanism -Hot-dipped galvanized steel support with fixing material (Cross Arm Set, etc)
(3) Fused Cutout Switches	
1) Applicable Standard	IEC, JIS, JEC, JEM or Equivalent
2) Type	Outdoor Type
3) Rated Current of Unit	100 A
4) Rated Voltage	33 kV
5) Rated Frequency	50 Hz
6) LIWV	170 kV
7) Interrupting Current	8 kA
8) Fuse	6 A to 25 A (depending on the size of Tr.)
9) Operation	To be operated by rod from the ground
10) Accessories	-Hook 5 m -Hot-dipped galvanized steel support with fixing material

Equipment	Specifications
(4) Lightning Arrester 1) Applicable Standard 2) Type 3) Nominal System Voltage 4) Rated Voltage 5) Nominal Discharge Current 6) Protection Ratio 7) Accessories	IEC, JIS, JEC, JEM or Equivalent Outdoor, Zinc-oxide, Gapless Type 33 kV Minimum 30 kV (rms) 5 kA (8/20 μs) Minimum 1.2 Hot-dipped galvanized steel support with fixing material
(5) Metering Unit 1) Applicable Standard 2) Metering Unit 3) Electric Meter (Remarks: Electric Meter is to be provided two(2) (Main and Checking)) 4) Control Cable 5) Outdoor Metering Kiosk 6) Terminal Blocks 7) Cable Ties	IEC or Equivalent 33 kV STC 18kA-1sec 200 or 100 Amp, Outdoor oil filled, Pole mounted (CT-VT) Class:33,000:110 Volt/50 VA/Class 0.2 2xCT: 200-100-50:1 Amp/10 VA Class 0.2 KWhr & kVar Import/Export Measurement, KVAh Derivation 16 times of use 4V free out put relays, Load Profiling (450 days, 1 channel, 30 mins), 3-Phase, 3-Wire, 50 Hz, Voltage 110 V, Current/1 A, Class 0.2 Min. 2.5 mm ² 7C cu, 10m Waterproof type, with pad-lock (spare key: 3pcs) 13 way 1 lot
(6) Auto Recloser 1) Applicable Standard 2) Type 3) Continuous Current Capacity 4) Rated Short-Time Current 5) Control Cubicle 6) Accessories:	IEC or Equivalent Pole mounting, gas insulated auto circuit recloser 630A 16 kA (1 sec.) Simple programming is provided from the control panel. Closing and tripping is from high quality and long life batteries which charge capacitors. Control cubicle is stainless steel enclosure. - Voltage transformers (33kV/110V, Accuracy class 1.0, 50VA) - Surge arresters (10kA, 8/20 μs) - Control cables - Fixing materials for electrical pole - Relay software - Technical and installation manual
(7) Conductor for 33kV Distribution Line 1) Applicable standard 2) Type 3) Size 4) Length per a Drum	IEC or Equivalent All Aluminum Alloy Conductor (AAAC) 100 mm ² 2,000 m

18

Equipment	Specifications
(8) Wooden Pole with Pole Cap 1) Wooden Pole • Material • Length • Diameter at top Min. 2) Pole Cap • Material • Accessories	Creosoted wooden pole 11 m / 12 m / 15 m 11 m (190-210mm) / 12m (210-235mm) 15m (220-245mm) Steel Plates/Iron Sheets Nail (Q'ty 2 pcs/cap)

5. Data Collection of connecting situations in the Previous JICA's Project Area

The Ugandan side shall prepare answers for the questionnaire, which asks the record of the number of connected customers, customer category, and electricity consumption for the sites of the previous projects (JICA I and II) by April 26, 2011.

6. Questionnaire for the Second Field Survey

For basic design of the Project, the Ugandan side shall prepare answers for the questionnaire for the second field survey attached in this Field Report as Part 5 of "ANNEX" before the second field survey.

19

7. List of Parties Concerned in the Recipient Country

Name	Employment Position
Ministry of Energy and Mineral Development (MEMD)	
Eng. Moses Muregezi	Advisor to Chairman (EMSWG)
Mr. Sajiabi J. Fredrick	Senior Energy Officer
Emmanuel Sande Nsubuga	Energy Officer (Electrical)
Ministry of Finance, Planning and Economic Development (MFPED)	
Ms. Jennifer Muwuliza	AG. Commissioner Aid Liaison Department
Mr. Mugaga Denis	Economist – Aid Liaison Department
Mr. Tomohito Kanaizuka	ODA Loan Advisor Aid Liaison Department
Rural Electrification Agency (REA)	
Mr. Benon Bena	Manager Investment Planning & Promotion
Mr. Philip P.P. Ganyi	Senior Planning Engineer
Mr. Werike K. Godfrey	Manager Project Monitoring & Evaluation
Mr. Muguwa Andrew	Senior Planning Engineer
Ms. Deborah Nantume	Senior Construction Engineer
Ms. Flavia Uwayezu	Project Engineer Planning
Ms. Joan Kayunga Mutibwa	Project Engineer Construction
Mr. James Gideon Litta	Wayleaves Officer
Mr. Daniel Mugurura	Intern
Uganda Electricity Transmission Company Ltd. (UETCL)	
Mr. Erlasi Kiyenba	Managing Director/CEO
Uganda Electricity Generation Company Ltd. (UEGCL)	
Mr. Dan W. Mayanja	Technical Manager
Mr. Kitayimwa Godfrey	Electrical Engineer
Mr. Kanziro Milton	Procurement Financial Specialist
Mr. Jimmy. C. Oconel	Hedonic Engineer / Consultant
Mr. Otim Moses	Environmental Specialist
National Environment Management Authority (NEMA)	
Mr. Francis Ogwal	Natural Resource Management Specialist (Biodiversity & Rangelands)
Mr. Alex Winyi Kiiza	Environmental Impact Assessment Officer

20

Ministry of Water and Environment (MWE)	
Ms. Lucy Iyango	Assistant Commissioner Wetlands
Uganda National Road Authority (UNRA)	
Mr. Patrick Muleme	Project Engineer – Technical Services
National Forestry Authority (NFA)	
Mr. Paul Musamali Buyerali	Director Corporate Affairs
Electricity Regulatory Authority (ERA)	
Eng. Semitala Norbert	Director, Technical Regulation
Mr. Patrick J. Mwesige	Director Financial & Admin' Services
Ferdault Engineering Services Ltd.	
Mr. Simbwa Emeil	Projects Manager
Umeme Limited	
Mr. Ssonko Azuman	Supervisor of Hamanve s/s
Mr. Michael Oputo	District Manager Iganga and Kamuli
Mr. Sande John Baptist	Technical Officer
Hydromax Limited	
Mr. Maheshwara Reddy	Executive Director
Mr. Sentumbwe Godfrey	General Manager
Masaka District	
Ms. Rose Nakyejwe	Environment Officer
Mr. Behwera Wilson	Wetland Officer
Rakai District	
Mr. Kiyangi Jamil	Wetland Officer
Mayuge District	
Mr. Mr. Aramu Thomas	Environment Officer
Bugiri District	
Ms. Bennadet Kauma	Assistant Environmental Officer

21

Forest Officer
Municipality Environmental Officer

Energy Counsellor

Senior Financial Analyst
Sustainable Development Department Africa Region

Senior Project Manager
Division Chief Sub-Saharan Africa
Energy Transport Telecommunication

Director Albertine Rift
Staff

Chief Representative
Representative
Project Formulation Advisor
Consultant for Infrastructure Sector


ANNEX

PART 1


Extension of 33 kV distribution line in Iganga, Bugiri and Busia District (Area-4)

Rural Electrification Phase III Socio-economic Data in Area-4

Trading Center	Parish	Sub-county	Schools		Health Center				Households	Remarks
			Primary	Secondary	IV	III	II	I		
1 Mitau	Mafisa	Mpingwe	3	0	0	0	1	0	100	
2 Mpingwe	Maji	Mpingwe	5	1	0	0	0	0	420	
3 Namabanda	Kasori	Makutu	1	0	0	0	0	0	100	
4 Bwanga	Makutu	Makutu	1	0	0	0	0	0	120	
5 Makutu	Makutu	Makutu	2	2	0	1	0	0	150	
6 Notsave	Kasori	Makutu	1	0	0	0	0	0	200	
7 Bwacha	Ingero	Nankoma	2	1	0	0	0	0	300	
8 Matovu	Nankoma	Nankoma	2	0	0	0	0	0	200	
9 Nshigango	Hulileli	Hulileli	2	0	0	0	0	1	200	
10 Irishi	Kilamba	Mitazere	2	0	0	0	0	0	30	
11 Mavege-Bukobzi	Mavege	Bukaya	5	0	0	0	1	0	1200	
12 Bunde	Bwacha	Bwacha	0	0	0	0	0	0	100	
13 Nsongo	Kinyo	Botinja	7	1	0	0	1	0	300	
14 Nanyigo	Nanyigo T.C.	Nanyigo T.C.	21	7	1	1	0	0	3000	
15 Lwaganda	Botinja	Botinja	4	1	0	1	0	0	90	
16 Nivoli	Bwanga	Banda	1	0	0	0	0	0	40	
17 Lutoo	Lutolo	Banda	1	1	0	0	1	0	200	
18 Kilirefisi	Lutolo	Banda	2	0	0	0	0	0	15	
19 Lupa	Lugali	Banda	3	0	0	0	0	1	300	
20 Bwaca	Bwacha	Banda	1	0	0	0	0	0	100	
21 Bwiro	Bujwanga	Banda	2	0	0	0	0	1	100	
22 Bwiro Landing Site	Bujwanga	Banda	3	0	0	0	0	0	150	
23 Bwera A	Bwacha	Mitamba	5	0	0	0	0	0	50	
Bwera B	Mitamba	Mitamba	1	0	0	0	0	0	50	

Route Map for Extension of 33 kV Distribution Line in Iganga, Bugiri and Busia District (Area-4)

Extension of 33 kV distribution line in Masaka and Rakai District (Area-2)






Route Map for Extension of 33 kV Distribution Line in Masaka and Rakai District (Area-2)

Socio-economic Data in Area-2

Trading Center	Parish	Sub-community	Schools			Health Center				Households	Remarks
			Primary	Secondary	Tertiary	IV	III	II	I		
1 Buvunga	Buvunga	Buvunga	3	0	0	0	0	0	1	120	
2 Nkomo	Nkomo	Nkomo	1	0	0	0	0	0	1	100	
3 Nkomo	Nkomo	Nkomo	1	0	0	0	0	0	0	1000	
4 Buvunga	Buvunga	Buvunga	3	1	0	0	0	0	0	50	
5 Nkomo	Nkomo	Nkomo	3	0	0	0	0	0	0	100	
6 Nkomo	Nkomo	Nkomo	1	1	0	0	0	0	0	10	
7 Kyambizi	Kyambizi	Kyambizi	2	0	0	0	0	0	0	80	
8 Ndebea Lwagglwe	Ndebea Lwagglwe	Ndebea Lwagglwe	2	1	0	0	0	0	0	120	
9 Kibira	Kibira	Kibira	0	0	0	0	0	0	1	30	
10 Buvunga	Buvunga	Buvunga	2	0	0	0	0	0	0	20	
11 Kibira	Kibira	Kibira	2	0	0	0	0	0	0	100	
12 Kibira	Kibira	Kibira	2	1	0	0	0	0	0	120	
13 Kibira	Kibira	Kibira	3	1	1	0	0	0	0	130	
Total			25	3	0	0	0	0	2	1860	



NETWORK DIAGRAM
AREA-2 (MASAKA AND RAKAI DISTRICT)

PART 3


Extension of 33 kV distribution line in
Bushenyi and Rukungin District (Area-5)





Route Map for Extension of 33 kV Distribution Line in Bushenyi and Rukungiri District (Area-5)




PART 4

Pole Assembly Drawing for Distribution Line



NETWORK DIAGRAM
AREA-5 (BUSHENYI AND RUKUNGIRI DISTRICT)





PART 5

Questionnaire for the Second Field Survey

**PREPARATORY SURVEY
ON
THE PROJECT FOR
RURAL ELECTRIFICATION PHASE III
IN
THE REPUBLIC OF UGANDA**

QUESTIONNAIRE

for the Second Field Survey

April 2011

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)
YACHIYO ENGINEERING CO., LTD.

Table 1-1 Maximum demand of each 33 kV feeder in 132/33 kV Substation in the Owen Falls Power Plant (Area-4)

No.	Feeder Name	Rated	Recorded Data [A]			
		[A]	2007	2008	2009	2010

Table 1-2 Maximum demand of each 33 kV feeder in Tororo Substation

No.	Feeder Name	Rated	Recorded Data [A]			
		[A]	2007	2008	2009	2010

Table 1-3 Maximum demand of each 33 kV feeder in Masaka West Substation

No.	Feeder Name	Rated	Recorded Data [A]			
		[A]	2007	2008	2009	2010

Table 1-4 Maximum demand of each 33 kV feeder in Mbarara North Substation

No.	Feeder Name	Rated	Recorded Data [A]			
		[A]	2007	2008	2009	2010

Table 1-5 Maximum demand of each 33 kV feeder in Nkenda Substation

No.	Feeder Name	Rated	Recorded Data [A]			
		[A]	2007	2008	2009	2010

(2) Specifications and operational records of the existing conductors which the distribution lines of the Project will be connected to

For basic design of the Project, specifications and operational records of the existing conductors which the distribution lines of the Project will be connected to shall be described in the following tables.

1. Technical issues

1.1 Preparation of Network Diagrams related to the Project

Power source for some distribution lines currently under construction was not confirmed clearly. The Ugandan side shall prepare exact network diagrams for the existing distribution and transmission lines and ones under construction related to the Project. In the preparation of the network diagram, scope described in the network diagrams attached to this Field Report shall be referred.

1.2 Preparation of Route Maps of distribution and transmission lines related to the Project

It was confirmed in the site survey that actual location of some distribution lines was not in conformity with the information in the GIS data of REA. The Ugandan side shall prepare exact route maps of distribution and transmission lines for the existing ones and ones under construction related to the Project. The Ugandan side shall also specify voltage levels by color in the route maps for certain distinction. In the preparation of the route maps, scope described in the network diagrams and route maps attached to this Field Report shall be referred.

1.3 Preparation of Single Line Diagrams for 132/33kV Substations related to the Project including basic specifications of main transformers

For confirmation of protection system and capacity of the existing equipment, single line diagrams for 132/33 kV substations related to the Project including basic specifications of main transformers, i.e. capacity, vector group, percent impedance, installation year and etc., shall be prepared by the Ugandan side. The related 132/33 kV substations are as follows;

- 132/33 kV Substation in the Owen Falls Power Plant (Area-4)
- Tororo Substation (Area-4)
- Masaka West Substation (Area-2)
- Mbarara North Substation (Area-5)
- Nkenda Substation (Area-5)

1.4 Operational Data of each 33kV feeders in the 132/33kV Substations related to the Project

(1) Maximum Demand of the related 33 kV feeders

For confirmation of operational conditions of the existing equipment, maximum demand of all the 33 kV feeders in the 132/33 kV substations related to the Project for the recent four years shall be described in the following tables. Feeder number and feeder name shall be specified in the Table.

Table 2-1 Specifications and operational records of the existing conductors which the distribution lines from Mayuge (Connection A) to Nankoma (Connection B) of the Project will be connected to

No.	Feeder Name	Size [mm ²]	Allowable Current [A]	Maximum Current [A]			
				2007	2008	2009	2010

Table 2-2 Specifications and operational records of the existing conductors which the distribution lines from Nankoma (Connection C) to Lumino (Connection D) of the Project will be connected to

No.	Feeder Name	Size [mm ²]	Allowable Current [A]	Maximum Current [A]			
				2007	2008	2009	2010

Table 2-3 Specifications and operational records of the existing conductors which the distribution lines from Nyendo (Connection A) to Kyambazi of the Project will be connected to

No.	Feeder Name	Size [mm ²]	Allowable Current [A]	Maximum Current [A]			
				2007	2008	2009	2010

Table 2-4 Specifications and operational records of the existing conductors which the distribution lines from Nankoma (Connection C) to Ndeeba-Lwaggle of the Project will be connected to

No.	Feeder Name	Size [mm ²]	Allowable Current [A]	Maximum Current [A]			
				2007	2008	2009	2010

Table 2-5 Specifications and operational records of the existing conductors which the distribution lines from Mayuge (Connection A) to Nankoma (Connection B) of the Project will be connected to

No.	Feeder Name	Size [mm ²]	Allowable Current [A]	Maximum Current [A]			
				2007	2008	2009	2010

Table 2-6 Specifications and operational records of the existing conductors which the distribution lines from Kitagata (Connection B) to Katagi of the Project will be connected to

No.	Feeder Name	Size [mm ²]	Allowable Current [A]	Maximum Current [A]			
				2007	2008	2009	2010

(3) Failure Records of 33kV feeders which the distribution lines of the Project will be connected to

ATTACHMENT
JICA I

ATTACHMENT
JICA II

Estimated Power Demand in Project Site B

TC Name	Project Site B (Wabigaro-Migera)								Energy (kWh)	Demand (kW)
	Residential	Commercial	Schools		Health Center		Office	Small Factory		
			Primary	Secondary	Center	Clinic				
Wabigaro										
Sasira										
Namasa										
Migera										
Total										0

Estimated Power Demand in Project Site C

TC Name	Project Site C (Holima-Murtemo)								Energy (kWh)	Demand (kW)
	Residential	Commercial	Schools		Health Center		Office	Small Factory		
			Primary	Secondary	Center	Clinic				
Buawekera										
Buhimba										
Kikuba										
Murtemo										
Total										0

Estimated Power Demand in Project Site A

Project Site A (Nabitende/Itanda Area in Iganga District)											
Parish	Residential	Water Pump	Schools		Health Center		Maize & rice mill		Energy (kWh)	Demand (kW)	
			Primary	Secondary	Grade IV	Others					
Namungwalwe											
Nabitenda											
Naluliko											
Ituba											
Bugono											
Itanda											
Kwanyi											
Nawangaza											
Total										0	

Total in the Site		
Energy (kWh)	Demand (kW)	Customer Number
Domestic		
Commercial		
Manufacturing Industry		
Large Industry		
EX-Large Industry		
Total	0	0

Estimated Power Demand in Project Site D

Project Site D (Bukakata Area in Masaka District)									
Parish	Residential	Water Pump		Schools		Health Center Grade IV	Maize & rice mill	Energy (kWh)	Demand (kWh)
		Primary	Secondary	Primary	Secondary				
Kayugi									
Nabusaabu Camp									
Ssunga									
Kigo									
Bunaddu									
Kinoo									
Kinoo Landing site									
Bukakata									
Kachunga									
Total									0

	Total in the Site	
	Energy (kWh)	Demand (kW) Customer Number
Domestic		
Commercial		
Medium industry		
Large industry		
EX-large industry		
Total	0	0

Estimated Power Demand in Project Site B

[illegible]

	Total in the Site	
	Energy (kWh)	Customer Number
Domestic		
Commercial		
Medium Industry		
Large Industry		
EX-large Industry		
Total	0	0

Estimated Power Demand in Project Site C

[illegible]

	Total in the Site	
	Energy (kWh)	Demand (kW) Customer Number
Domestic		
Commercial		
Medium Industry		
Large Industry		
EX-large Industry		
Total	0	0

**PREPARATORY SURVEY
ON
THE PROJECT
FOR
RURAL ELECTRIFICATION PHASE III
IN
THE REPUBLIC OF UGANDA**

THE SECOND FIELD SURVEY

FIELD REPORT

July 18th, 2011

Presented and submitted by:

Kazunari Nogami
for **Kazunari NOGAMI**
Mr. Masatsugu KOMIYA
Chief Consultant,
JICA Study Team,
Japan International Cooperation Agency (JICA)

Confirmed by:

Chabachaling
Mr. Fred Kabagambwe-Kalissa
Permanent Secretary,
Chairman of Rural Electrification Board,
Ministry of Energy and Mineral Development (MEMD)

Witness:

Godfrey R. Turyahikayo
Mr. Godfrey R. Turyahikayo
Executive Director,
Rural Electrification Agency (REA),
Ministry of Energy and Mineral Development (MEMD)

Table of Contents

1. Introduction	1
2. Project Site Information	2
2.1 Project Site Locations	2
2.2 Beneficiary of the Project	3
2.3 Progress of Customer Connection in the Previous Project Sites (JICA I and II)	7
2.4 Power Demand Forecast in the Project Sites	10
3. Design Conditions and Technical Specifications	12
3.1 Design Conditions	12
3.2 Basic Plans of Components	15
3.3 Procurement and Installation Plan of Equipment and Materials	16
3.4 Procurement Plan of Spare Parts and Maintenance Tools	22
3.5 Upgrading of the Existing Distribution Lines (from Busia to Nankoma, around Nankoma)	22
3.6 Tentative Implementation Schedule of the Project	24
4. Environmental and Social Considerations	26
4.1 Location of 33 kV Distribution Line	26
4.2 Points of Environment and Social Considerations	26
4.3 Site Survey	28
4.4 Environmental and Social Impacts and Mitigation Measures	31
4.5 Preparation of Project Brief (PB)	36
5. Work Demarcations for Both Parties	36

ANNEX

- Members of the Team
- List of Parties Concerned in the Recipient Country
- Minutes of Discussion
- Results of socio-economic survey
- Estimation of loads of each consumer
- Fact finding sheets
Mayuge, Iganga, Busia, Namayingo and Bugiri districts

Drawings

- Single Line Diagrams of the Project
- Route Maps of the Project
- Pole Assembly Drawings for Distribution Lines

Contents of Drawings

- Single Line Diagram of the Project**
DWG No. UG3-E1: 33kV Distribution Network Diagram of the Project (Mayuge + Lamira)
- Route Map of the Project**
DWG No. R-01
DWG No. RD-01 ~ RD-38
Route Map of the Project
Detail Route Map of the Project
- Pole Assembly Drawings for Distribution Lines**

DWG No. T-01	Pole Type A	Intermediate Pole (Line Angle: 0 ~ 5 degree)
DWG No. T-02	Pole Type B	Light Angle Pole (Line Angle: 5 ~ 30 degree)
DWG No. T-03	Pole Type C	Heavy Angle Pole (Line Angle: 30 ~ 50 degree)
DWG No. T-04	Pole Type D	Heavy Angle Pole (Line Angle: 50 ~ 90 degree)
DWG No. T-05	Pole Type E	Section Pole (Horizontal Arrangement)
DWG No. T-07	Pole Type G	Terminal Pole
DWG No. T-08	Pole Type H	Land Break Switch (LBS) Pole
DWG No. T-09	Pole Type J	T-off Pole (Branch)
DWG No. T-10	Pole Type L	Transformer Pole (Line end)
DWG No. T-11	Pole Type K	Transformer Pole (on Line)
DWG No. T-12	Pole Type M	Bulk Metering Unit Pole
DWG No. T-13	Pole Type N	Connection Plan to the existing line (extension type)
DWG No. T-14	Pole Type Q	Sharp Angle Pole (Line Angle: 90 ~ 90 degree) (Horizontal)
DWG No. T-15	Pole Type R	Auto Re-closer Pole
DWG No. T-16	Pole Type W	Intermediate Pole (area to be flooded)

1. Introduction

In order to build common understanding between the Ugandan side and the Second Preparatory Survey Team (hereinafter referred to as "the Team") for the Project for Rural Electrification Phase III in the Republic of Uganda (hereinafter referred to as "the Project") on the technical and engineering aspects, this Field Report has been prepared based on the results of the second field survey and discussions with the Ugandan side, i.e., Rural Electrification Agency (REA) and Ministry of Energy and Mineral Development (MEMD).

The Ugandan side and the Team agreed that the proposed distribution line traversing through parts of five districts: Mayuge, Iganga, Bugiri, Namayingo and Busia as the most prioritized site in the Minutes of Discussions (M/D) signed on 16th June, 2011. Main reasons for the prioritization are (1) electrification of beneficiaries in terms of the number of consumers which include trading centers, households, schools and health centers, (2) the importance of electrification of new district headquarters in Namayingo, and (3) project impacts including synergy with the Interconnection of Electric Grids of Nile Basin Initiative Countries Interconnection Project.

The main component of the Project is shown in Table 1. However, the final components of the Project will be decided by the Government of Japan.

Table 1 Summary of the Project

Summary of the Project	
Procurement and Installation	Procurement and installation of the following equipment and materials for 33 kV distribution line:
	(1) 33 kV Distribution Line (Total Length: Approx. 134.4 km)
	➤ Trunk line from Mayuge Trading Centre (T/C) to Isukuma T/C through Mayuge T/C: Approx. 21.3 km
	➤ Branch line from Mayuge T/C to Makana T/C: Approx. 10.2 km
	➤ Trunk line from Nankoma T/C to Lamira T/C through Namayingo T/C and Lamira T/C: Approx. 57.5 km
Procurement	➤ Branch line from Namayingo T/C to Gwasa A T/C and Gwasa B T/C: Approx. 20.0 km
	➤ Branch line from Namayingo T/C to Gwasa Landing Site and Umpala: Approx. 14.8 km
	➤ Branch line from Fukuwa T/C to Masingi T/C and Masingi-Tupani T/C: Approx. 10.5 km
	(2) 33/10, 15/0.240 kV Distribution Transformer (Total Number: 40 units)
	➤ 250 kVA × 4 units, 160 kVA × 7 units, 90 kVA × 11 units, 25 kVA × 28 units
Procurement	(3) Metering Unit: 4 units
	(4) Auto Re-closer: 4 units
	(5) Load Break Switch: 14 units
	Spare parts and maintenance tools for 33 kV distribution line
Procurement	(1) Emergency Spare Parts
	(2) Replacement Spare Parts
	(3) Maintenance Tools

Source: JICA Study Team

2.1 Project Site Locations

The project site location is shown as Figure 1.



Figure.1 Project Site Location

- Total coverage populations: 461,600 population

- Table 2 Beneficiaries in the Project

Source: JICA Study Team

Note: Each aspect of change from first survey is bolded.

*1 Matrices: It is added, details are in main body.

*2 Luvuvigoria: Its I/C is changed from IV to III from the site survey.

*3 Living population: To specify the number of living populations out in the electrified area by the Project in consideration of coverage area of transformers installed. Interview in LCU households carried out in the first field survey.

^a4 Number of Milling machines is estimated by the results of socio-economic survey.

*5 Other marked cells. They are excluded or reduced the number from the site survey because they are located in out of TAC.

(1) General Information of beneficiaries in the Project Site

The results of the socio-economic survey are shown in Annex 4.

- (2) General households

- ### (3) Public Facilities

- 3

Table 3 Major Beneficiaries of R/C III/IV in the Project

Source: Computed by ICA Study Team using the data below.

Coverage population of Iskenderli – (adopt three year development plan for the period 2010/2011 – 2012/2013)

© 2019 American Society of Tropical Medicine and Hygiene. Published by Elsevier Inc. This is an open access article under the CC BY-NC-ND 4.0 International license.

Coverage population of Belgium, Luxembourg, (1994) Germany, 93
 Coverage population of Lower Austria, Austria, 1994

Coverage population: 11 149 997. Data 1997.

Note: † Total coverage population is defined as number of population of Livingston, Liberia and Monrovia, which are included in the coverage population of HIV-1.

2. Total beneficiaries: 62,000 population

- (a) **Primary school**

Table 4 Primary school beneficiaries by district

Sources: Compiled by IJCA Study Team using data below.

Uganda Districts Information Hotline: 12091-2092

Note: * Number of students and teachers are calculated as zone district average of students' and teachers' number times number of schools.

small offices does not show a clear trend.

Table 8 Outline of the survey results of the customer connection growth in the previous project sites

After commissioning	2 years after	11 years after
General households and shops	3%	66%
Milling machines	28%	90%

Source: IICA Study Team

2.3.2 Analysis of the Site Survey in the Previous Project Sites

In the project site, it is expected from the results of the socio-economic survey that the driving loads will be mainly composed of the demand of general households, shops and milling machines processing staple foods. Based on the results shown in Table 8, the period required for completion of connection in the previous project site are respectively estimated by Least Square Approximation and shown in Table 9. And increase rate of connection is also shown in Table 4, respectively.

The results are as follows:

- Connection of general households and shops will complete 16 years after from the commissioning of the Project.
- Connection of milling machines will complete 10 years after from the commissioning of the Project.

Table 9 Estimated terms required for completion of connection and increase rate of connection

After commissioning	Periods	Increase Rate of connection
General customer and shops	16 years	6.26 %/year
Milling machines	10 years	10.0 %/year

Source: IICA Study Team

Though public facilities such as health centres or schools are important as beneficiaries of the Project, their demand does not effect the total demand remarkably, as their respective number are not so large compared with one of general households and shops. Though number of milling Machines is not so large either, their respective demand are not small.

2.4 Power Demand Forecast in the Project Sites

The conditions for the demand forecast are shown below and the results shown in Table 10.

Conditions for the demand forecast

- Increased rate of customer connection in the project site is assumed as 1.5 times of the rate in the previous project sites in consideration of introduction of subsidy scheme for customer connection in the project site.
- General households and shops: 9.39 %/year

Table 10 Demand Forecast for the Project

Trading Center	District	2013	2014	2015	2016	2017	2018	Required Capacity	Total Capacity
		kVA	kVA	kVA	kVA	kVA	kVA	kVA	kVA
1. Mase	Mbarara	1,483	2,841	8,110	7,784	12,870	13,871	42	140-150
2. Mbarara	Mbarara	4,577	13,842	23,883	24,734	39,411	48,892	101	140-150
3. Mbarara	Mbarara	1,075	2,176	4,712	8,417	12,154	14,132	30	140-150
4. Mbarara	Mbarara	1,491	3,653	4,811	8,231	11,351	13,822	29	140-150
5. Mbarara	Mbarara	4,482	8,736	14,423	20,221	28,711	35,523	54	140-150
6. Mbarara	Mbarara	8,946	19,138	22,216	38,611	38,271	49,367	94	140-150
7. Mbarara	Mbarara	4,871	9,331	13,111	15,411	18,455	28,887	51	140-150
8. Mbarara	Mbarara	2,522	5,122	7,451	10,511	14,615	23,118	21	140-150
9. Mbarara	Mbarara	2,485	5,445	8,226	11,224	17,415	27,415	28	140-150
10. Mbarara	Mbarara	8,865	1,222	1,877	2,121	2,151	4,779	12	140-150
11. Mbarara	Mbarara	7,506	14,427	21,468	28,715	48,471	51,120	43	140-150
12. Mbarara	Mbarara	19,719	34,401	51,461	70,234	128,114	148,891	281	140-150
13. Mbarara	Mbarara	1,115	2,202	3,301	4,776	10,114	11,401	17	140-150
14. Mbarara	Mbarara	3,511	10,028	16,114	21,408	35,408	46,508	47	140-150
15. Mbarara	Mbarara	40,344	42,021	123,081	143,104	110,271	380,344	356	140-150
16. Mbarara	Mbarara	1,977	2,881	8,465	7,477	12,894	19,465	22	140-150
17. Mbarara	Mbarara	6,361	1,119	1,881	2,465	7,461	8,844	12	140-150
18. Mbarara	Mbarara	2,445	8,851	10,854	14,276	30,551	35,544	42	140-150
19. Mbarara	Mbarara	8,421	8,851	1,244	2,461	5,671	7,704	11	140-150
20. Mbarara	Mbarara	3,779	3,779	11,714	12,811	27,151	42,122	122	140-150
21. Mbarara	Mbarara	1,479	1,479	2,551	3,550	10,882	12,108	16	140-150
22. Mbarara	Mbarara	1,794	2,144	4,714	8,444	12,211	14,244	25	140-150
23. Mbarara	Mbarara	2,229	4,475	8,445	8,761	18,471	22,845	35	140-150
24. Mbarara	Mbarara	2,554	3,471	7,849	10,499	21,714	25,209	21	140-150
25. Mbarara	Mbarara	1,398	1,351	2,551	3,520	10,689	12,104	16	140-150
26. Mbarara	Mbarara	1,861	2,779	3,921	7,481	18,414	31,179	71	140-150
27. Mbarara	Mbarara	2,888	8,011	6,615	12,544	22,851	27,880	44	140-150
28. Mbarara	Mbarara	3,541	1,119	1,441	2,461	7,461	8,844	12	140-150
29. Mbarara	Mbarara	1,729	2,429	2,871	5,244	10,221	12,121	16	140-150
30. Mbarara	Mbarara	5,811	1,822	2,711	3,739	6,941	12,461	15	140-150
31. Mbarara	Mbarara	1,221	2,449	3,779	5,114	10,611	13,730	14	140-150
32. Mbarara	Mbarara	1,291	2,211	3,471	5,101	10,111	12,101	16	140-150
33. Mbarara	Mbarara	3,339	5,811	10,469	14,840	30,361	35,241	51	140-150
34. Mbarara	Mbarara	2,550	7,724	11,844	14,811	22,244	24,811	39	140-150
35. Mbarara	Mbarara	2,100	4,711	5,444	7,714	19,471	22,104	35	140-150
36. Mbarara	Mbarara	7,461	7,719	11,822	14,811	24,461	27,104	40	140-150
37. Mbarara	Mbarara	6,259	1,491	2,114	2,461	1,841	1,401	12	140-150
38. Mbarara	Mbarara	8,701	1,421	2,544	2,461	1,941	5,304	12	140-150
Total		151,424	307,162	499,418	606,762	1,221,711	1,502,494		

Source: IICA Study Team

Note: "Required capacity" is calculated in consideration of Power Factor 0.85 and Demand Factor 0.8

"Transformer capacity" is the minimum rated capacity to meet "Required Capacity".

3. Design Conditions and Technical Specifications

3.1 Design Conditions

Design conditions applied to the Project are described as follows.

3.1.1 Climatic Conditions

Natural conditions which need considerations for the equipment and facilities design are shown in Table 11.

- Milling Machine: 15.0 %/year

➤ It was mentioned by RLA that the subsidy scheme will be introduced only for customers who will connect to the grid within some years after commissioning of 33 kV distribution line of the Project. The period to subsidize customers is assumed as 5 to 5 years in the demand forecast.

- Subsidy period: 4 years

➤ Increase rate of demand is assumed 1.65 %/year in consideration of the growth trend of national demand of Uganda for the past ten years and the recent 5 years.

- Increase rate of demand: 1.65 %/year

➤ Demand of each public facility is assumed as follows based on information obtained from the socio-economic survey carried out in the site survey. Number of public facilities are shown in Table 2. The loads of each consumer are estimated in Annex 3. Based on the site survey.

- Primary School: 1,400 W
- Secondary School and Tertiary School: 1,900 W
- Health Center IV: 25,000 W
- Health Center III and Health Center II: 1,600 W

➤ In general, it takes a few years to elapse before a rapid connection of milling machines to the grid, as procurement of motor (Approx. 10kW to 25kW) require some cost to their owners. It is assumed that the first boost will occur 2 to 4 years after from the commissioning of the Project based on data in the previous project site.

- The time of first boost of connection of milling machines: four years after from the commissioning.

Table 11 Climatic Conditions for the Equipment and Facilities Design

Item	The Project Area Mbarara, Iganga, Bugiri, Namutoko and Bwamba Districts
Altitude	Less than 1,200 m
Ambient Temperature	35 °C
Minimum	15 °C
Mean	25 °C
Maximum Humidity	85 %
Maximum Wind Velocity	30 m/sec
Rainfall	2,200 mm/year
Seismic Force	Horizontal 0.1 G

Source: UGANDA DISTRICTS Information Handbook (2007-2008)

3.1.2 Basic Electrical Design Conditions

(1) Electric System (Voltage and Wiring System)

Voltage, wiring, frequency and earthing system applied to the 33kV distribution line and distribution transformer LV side shall be the same as those of the existing facilities. The summary of the electrical system concerned with the Project is shown in Table 12.

Table 12 Summary of Electric System

Nominal Voltage	33 kV	415-240 V
Maximum Voltage	36 kV	460 V
Wiring Method	3 phase, 3 wires	3 phase, 3 wires
Frequency	50 Hz	50 Hz
Earthing System	Effective Earth	Effective Earth
Short-circuit Current	Less than 25 kA (1 sec.) at 33 kV switchgear at distribution transformer LV side	Less than 10 kA (1sec.) at distribution transformer LV side
Lightning Impulse Withstand Voltage (LIWV)	170 kV	-
Power Frequency Withstand Voltage	70 kV	-
Overvoltage	16 mm / kV	-
Overhead Grounding Wire	Not Required	-

Source: IICA Study Team

(2) Other Electrical Systems

1) Color coding

Applicable color coding shall be applied to IEC standard that is red, yellow, blue and black.

2) Safety factor

The following safety factor shall be applied to design and installation works.

- (a) Pole and Foundation: 2.0
- (b) Conductor and cross-arms: 2.5
- (c) Insulators: 2.0

3) Clearance of conductors

The Clearance of 33kV overhead line shall be as follows.

- (A) Minimum Clearance
- Phase to phase: 330 mm
 - Phase to ground: 380 mm
- (B) Minimum Height from Ground Level
- Road Crossing: 7.5 m
 - Roadside: 6.5 m
- 4) Span length of electrical pole
- Single pole and double poles: Maximum 100m
- 5) Location of section pole
- Every 8 spans
- 6) Location of Load Break Switch
- Load Break Switch shall be installed at connection point with existing 33kV distribution line, major branching point and at intervals of about 13km for inspection and maintenance of the 33kV distribution line.
- 7) Location of Auto Recloser
- Auto Recloser shall be installed at connection point with existing 33kV distribution line.
- 8) Metering Unit
- Metering Unit shall be installed at connection point with existing 33kV distribution line.

3.1.3 Applicable Codes / Standards and Units

(1) Applicable Codes/Standards

The following Japanese and International standards/codes shall be generally applied to the Project.

- 1) International Electrotechnical Commission (IEC)
- 2) British Standard (BS)
- 3) International Standardization Organization (ISO)
- 4) Japanese Industrial Standard (JIS)
- 5) Japanese Electrotechnical Commission (JEC)
- 6) The Standard of Japan Electrical Manufacturer's Association (JEM)
- 7) Japan Cable Maker's Association Standard (JCS)
- 8) Other Japanese and International Standards concerned

(2) Units

Unit of length, area, volume, mass (weight), etc. used in the Project (such as Design, Manufacturing, Installation, Testing and Reporting) shall be in accordance with the International System of Units (SI).

3.2 Basic Plans of Components

The basic plan of the components is shown in Table 13.

Table 13 Basic Plan of Components

Basic plan of Components	
Procurement and Installation	Procurement and installation of the following equipment and materials for 33 kV distribution line
	<ol style="list-style-type: none"> (1) 33 kV Distribution Line (Total Length: Approx. 134.4 km) <ul style="list-style-type: none"> ➢ Trunk line from Mayuge Trading Center (T/C) to Nankoma T/C through Mpungwe T/C: Approx. 21.5 km ➢ Branch line from Mpungwe T/C to Makungu T/C: Approx. 10.2 km ➢ Trunk line from Nankoma T/C to Lumbwe T/C through Nanyungu T/C and Hukuma T/C: Approx. 37.5 km ➢ Branch line from Nanyungu T/C to Hukuma T/C and Hukuma B T/C: Approx. 29.9 km ➢ Branch line from Nanyungu T/C to Busiro Landing Site and Lugala: Approx. 24.8 km ➢ Branch line from Hukuma T/C to Mungu T/C and Mungu-Tayari T/C: Approx. 10.5 km (2) 33 (0.415-0.240 kV) Distribution Transformer (Total Number: 50 units) <ul style="list-style-type: none"> ➢ 250 kVA = 4 units, 100 kVA = 7 units, 50 kVA = 11 units, 25 kVA = 28 units (3) Metering Unit (Total: 4 units) <ul style="list-style-type: none"> ➢ Connection point at Mayuge: 1 unit ➢ Connection point at Nankoma: 2 units ➢ Connection point at Lumbwe: 1 unit (4) Auto Recloser (Total: 4 units) <ul style="list-style-type: none"> ➢ Connection point at Mayuge: 1 unit ➢ Connection point at Nankoma: 2 units ➢ Connection point at Lumbwe: 1 unit (5) Load Break Switch (Total: 16 units) <ul style="list-style-type: none"> ➢ Connection point at Mayuge: 1 unit, Connection point at Nankoma: 2 units, Connection point at Lumbwe: 1 unit and Major branch point: 4 units and intervals of 13 km: 8 units
Procurement	Space parts and maintenance tools for 33 kV distribution line
	<ol style="list-style-type: none"> (1) Emergency Spare parts (1 lot) <ul style="list-style-type: none"> ➢ Lightning Arrester, Fused Cut-out Switch and Distribution Transformer (2) Replacement Spare Parts (1 lot) <ul style="list-style-type: none"> ➢ Fuse elements for cut-out switch and contacts for load break switch (3) Maintenance Tools (1 lot) <ul style="list-style-type: none"> ➢ Digital-type multi meter, Clip-on meter, Phase rotation meter, etc.

Source: JICA Study Team

15

3.3 Procurement and Installation Plan of Equipment and Materials

(1) Procurement Plan of Equipment and Materials

1) Quantity of Major Equipment and Materials

(a) Distribution Transformer

Table 14 Quantity and Capacity of Distribution Transformers

Trading Center	Quantities of Transformers (unit)				Total	Additional Transformer
	25 kVA	50 kVA	100 kVA	200 kVA		
1. Matsa	1				1	
2. Mpungwe	1		1		2	25 kVA for secondary school
3. Nankoma	1		1		2	25 kVA for small town nearby
4. Bughula	1	1			2	25 kVA for primary school
5. Malova		1			1	
6. Nanyungu	1				1	
7. Busiro	1				1	
8. Makungu	1	1			2	25 kVA for schools
9. Nanyungu	1	1			2	
10. Irindi	1				1	
11. Mungu	1		1		2	25 kVA for schools
12. Mayuge-Bukheli	1			1	2	25 kVA for health center
13. Busiro	1				1	
14. Nanyungu			1		1	
15. Nanyungu		2	1	2	5	* District capital of Nanyungu
16. Lumbwe			1		1	
17. Busiro	2				2	25 kVA for Sub-county headquarter
18. Hukuma		1			1	
19. Lumbwe	1				1	
20. Mungu-Tayari	1				1	
21. Mungu	2				2	25 kVA for primary school
22. Lumbwe	1				1	
23. Nankoma	1				1	
24. Lumbwe			1		1	
25. Kilindi	1				1	
26. Lugala				1	1	
27. Busiro	1				1	
28. Busiro	1				1	
29. Busiro Landing Site		1			1	
30. Farm	1				1	
31. Nankoma	1				1	
32. Hukuma-Bassa		1			1	
33. Makungu		1			1	
34. Busiro-A	1				1	
35. Mungu-B	1				1	
36. Busiro	1				1	
37. Busiro-A	1				1	
38. Busiro-B	1				1	
Total	28	11	7	4	50	

Source: JICA Study Team

Note: * The District capital of Nanyungu District expands widely. Based on the demand forecast for the project, 5 transformers of total capacity of 600 kVA are located.

(B) Load Break Switch

Quantity and location of load break switch is as follows:

- a) Connection point at Lumbwe: 1 set
- b) Connection point at Nankoma: 2 sets
- c) Connection points at Mayuge: 2 sets
- d) Major branch point: 4 sets
- e) Intervals of 13 km: 5 sets

(C) Metering Unit

Quantity and location of metering unit is as follows:

- a) Connection point at Lumbwe: 1 set
- b) Connection point at Nankoma: 2 sets
- c) Connection points at Mayuge: 1 set

(D) Auto Recloser

Quantity and location of auto recloser is as follows:

- a) Connection point at Lumbwe: 1 set
- b) Connection point at Nankoma: 2 sets
- c) Connection points at Mayuge: 1 set

(E) Conductor

The procurement length of conductor for 33kV distribution lines is as follows:

- a) Design length of conductors: 134.4km x 3 phase = 403.2km
- b) Procurement length of conductor: 403.2 x 1.05 = 423.36km (1.05: margin)

(2) Specifications of Major Equipment and Materials

The specifications of major equipment and materials are shown in Table 15.

Table 15 Specifications of Major Equipment and Materials

Equipment	Specifications
(1) Distribution Transformer	
1) Applicable Standard	IEC, BS, JEC, JEM or Equivalent
2) Type	900 mm rated, ONAN, Thermally-protected, Outdoor, Pole-mount type
3) Nominal Voltage	25,000/415/250 V
4) Impedance Voltage	4-5 %
5) Tapping Voltage (%) on HV Side	±2.5 %, ±5.0 % (no voltage tap changer)
6) Phase	110/3 phase, LV 3 phase, 4-wire
7) Frequency	50 Hz
8) LRVV	170kV
9) Vector Symbol	Dyn11
10) Capacity	25, 50, 100, 200 kVA
11) Accessories	-Name Plate

17

Equipment	Specifications
(3) Load Break Switch	<ul style="list-style-type: none"> 1) Applicable Standard: IEC, BS, JEC, IEC or Equivalent 2) Type: Manual Operation 3) Rated Normal Current: 100 A 4) Rated Voltage: 33 kV 5) Rated Frequency: 50 Hz 6) Rated Voltage: 170 kV 7) Rated Interrupting Capacity: 650 A (at 100 A) 8) Rated Short-Time Current: 16 kA (1 sec.) 9) Creepage Distance: min. 825 mm 10) Accessories: <ul style="list-style-type: none"> ✓ Operation mechanism ✓ 100-dipped galvanized steel support with flange material
(3) Fixed Contact Switches	<ul style="list-style-type: none"> 1) Applicable Standard: IEC, BS, JEC, IEC or Equivalent 2) Type: (air type) 3) Rated Current of Pole: 100 A 4) Rated Voltage: 33 kV 5) Rated Frequency: 50 Hz 6) Rated Voltage: 170 kV 7) Rated Interrupting Capacity: 650 A (at 100 A) 8) Rated Short-Time Current: 16 kA (1 sec.) 9) Pole: 3 A to 25 A (depending on the capacity of distribution feedthrough) or to be specified by end user the ground 10) Accessories: <ul style="list-style-type: none"> ✓ Operation mechanism ✓ 100-dipped galvanized steel support with flange material
(4) Lightning Arrester	<ul style="list-style-type: none"> 1) Applicable Standard: IEC, BS, JEC, IEC or Equivalent 2) Type: (air type) 3) Rated Voltage: 33 kV 4) Rated Voltage: 170 kV 5) Nominal Discharge Current: 1 kA (10/100 μs) 6) Accessories: <ul style="list-style-type: none"> ✓ 100-dipped galvanized steel support with flange material
(5) Metering Unit	<ul style="list-style-type: none"> 1) Applicable Standard: IEC, BS, JEC, IEC or Equivalent 2) Type: (air type) 3) Rated Voltage: 33 kV, Class 100 kV, Pole mounted 4) Rated Current: 100 or 150 Amp, Short-time current: 10 kA (10/100 μs) 5) VT: 33,000/110 V, 50 VA, Accuracy class: 0.5 6) CT: 200/5 A, 10 VA, 20/5 A, Accuracy class: 0.5 7) SA: 100/5 A, 10 VA, 20/5 A, Accuracy class: 0.5 8) Accessories: <ul style="list-style-type: none"> ✓ 100-dipped galvanized steel support with flange material
(5) Auto Reclosers	<ul style="list-style-type: none"> 1) Applicable Standard: IEC, BS, JEC, IEC or Equivalent 2) Type: Pole mounted, gas insulated auto circuit recloser 3) Continuous Current Capacity: 100 A 4) Rated Short-Time Current: 16 kA (1 sec.) 5) Control Cable: (to be provided from the ground point)

18

In case important public facilities are far away from the location of transformer (over 500m), can not supplied from the transformer and additional transformers are requested by REA based on the survey.

Trading Centers where additional transformer are located: Mpungwe, Nondwe, Buwalala, Makuutu, Muterere, Mayuge-Bukholi, Namayingo, Buwanga and Mundindi.


(d) Method of Connecting Existing and New Distribution Lines

New 33kV distribution lines shall be connected to the existing 33kV distribution lines and be extended to project sites. The connection method is shown in Table 16 and typical drawings are shown in Figure 4.

Table 16 Connection Method between New 33kV Distribution Lines and Existing Distribution Lines

Project Site	Connection Method	No.
Mayuge	New line shall be extended from the existing line at dead end pole in Mayuge.	(1)
Nankoma (West)	New line shall be extended from the existing line at dead end pole in Nankoma (West).	(2)
Nankoma (East)	New line shall be branched (T-off) from the existing line at dead end pole in Nankoma (East).	(3)
Lumino	New line shall be extended from the existing line at dead end pole in Lumino.	(4)

Source: JICA Study Team



Source: JICA Study Team
Figure 4 Typical drawings of Connection method

Equipment	Specifications
8) Accessories	<ul style="list-style-type: none"> Clamping and tapping is from high quality tool long life barrier which change appearance. Control cable is stainless steel enclosure. ✓ Wiring transformers (33 kV/110 V, Accuracy class: 0.5, 50 VA) ✓ Control cables ✓ Wiring materials for electrical pole ✓ Jockey software ✓ Technical and installation manual
(7) Conductor for 33kV Distribution Line	<ul style="list-style-type: none"> 1) Applicable Standard: IEC or Equivalent 2) Type: All Aluminum Alloy Conductor (AAAC) 3) Size: 100 mm² 4) Length per a Drive: 2,000 m
(8) Wooden Pole with Pole Cap	<ul style="list-style-type: none"> 1) Wooden Pole <ul style="list-style-type: none"> • Material: Crossed wooden pole • Shape: Round pole • Length: 1) m (12 m) • Diameter of pole (at top): 1) m pole: 190-210 mm; 12 m pole: 210-235 mm 2) Pole Cap <ul style="list-style-type: none"> • Material: Steel Plate/Alum Sheet • Accessories: Min. 100 mm per one insulator
(9) Insulators	<ul style="list-style-type: none"> 1) Pin Insulator <ul style="list-style-type: none"> • Applicable standard: IEC or Equivalent • Type: Solid core • Material: Porcelain • Color of porcelain: Brown • Creepage distance: Min. 270mm 2) Disc Insulator <ul style="list-style-type: none"> • Applicable standard: IEC or Equivalent • Type: Half and socket • Material: Porcelain • Diameter of insulator: 254 mm • Number of insulator per string: 3 pieces • Creepage distance: Min. 100 mm per one insulator

(3) Installation Plan of Equipment and Materials

The route of 33kV distribution lines and location of distribution transformers shall be designed in accordance with the following measures.


1) Technical Aspects

- 33kV distribution lines are designed along existing road and location of electrical pole is basically designed within road reserve.
- 100m span is applied for pole interval of 33 distribution line basically in conformity with the Ugandan standard.
- Distribution transformers are located in land center of each trading Center.


19

2) Environmental and Social Aspects

- Based on the site survey, we could find the mitigation measures of all cases of wetland as described Figure 5: Position of electrical poles are designed in 100m span as standards.



Typical section at stream/wetland crossing



Typical Plan at stream/wetland crossing

Source: JICA Study Team

Figure 5 Typical Arrangement around Wetland/Stream

- 33kV distribution lines routes are designed to avoid play-grounds in schools, cultural sites (shrines) and valuable trees, where possible.
- In case of crossing seasonal flood plains, position of electrical pole is designed in maximum 100m span. Type of electrical pole is intermediate double poles (Type W) is applied.

2)

3.4 Procurement Plan of Spare Parts and Maintenance Tools

The spare parts and maintenance tools for the Project are shown in Table 17 and Table 18.

Table 17 Spare Parts List

Equipment	Qty	Description
(1) Emergency Spare Part		
1) Lighting Arrester	3 pcs	33kV, 3kA, single phase
2) Fused Cut-out switch	2 pcs	33kV, center phase
3) Distribution Transformer	1 set of each type	25, 50, 100, 200kVA
(2) Backhoe Loader		
1) Type loader for construction	2 nos. off each type	
2) Circuits for fault break switch	3 pcs	

Source: JICA Study Team

Table 18 Maintenance Tool List


Equipment	Qty	Description
(1) Digital-type multi meter	1 set	For general purpose
(2) Clip-on meter	1 set	For checking of short-circuit
(3) Phase rotation meter	1 set	For general purpose
(4) Voltage detector	1 set	For 50kV line
(5) Voltage detector	1 set	For low voltage
(6) Insulation resistance tester	1 set	For megger test, 375 V line
(7) Insulation resistance tester	1 set	For megger test, low voltage
(8) Earth resistance tester	1 set	For general purpose
(9) Operation end	1 set	For fused cut-out switch

Source: JICA Study Team

3.5 Upgrading of the Existing Distribution Lines (from Busia to Lumino, around Nankoma)

For stable and qualitative power supply to the project site, the capacity of power equipment in the back home supply level of the project site was established through a site survey and discussions with RGA, UMEME, and Uganda Electricity Transmission Company Limited (UETCL). The power system around the project site is shown in Figure 6.

- 33 kV distribution line of the Project will be connected to the existing distribution line from Jinja Industrial Substation to Iganga S/S in the Jinja side of the Project site.
- 33 kV distribution line of the Project will also be connected to the existing distribution line from Tororo S/S to Majunji through Busia and Lumino in the Lumino side.



Source: JICA Study Team

Figure 6 Project System around the project site

- Currently, the power system infrastructure from Jinja Industrial S/S to Iganga S/S is almost loaded at full capacity due to huge power consumption of big factories such as the steel rolling mills in the Iganga area.

- Conductor type: 150 mm² AAAC
- Normal Load of Line 15 MVA / Capacity of Power line 17 MVA

- It was confirmed through discussion with UETCL that they plan to install and commission a new Iganga S/S (132 / 33 kV, Capacity 80 MVA) in 2013 between Owen Falls S/S and Iganga S/S. Therefore, it is projected that the power source to the project site from the Jinja side will be relieved from over-load a few years after commissioning the Project.

- Currently, specifications of the existing 33 kV distribution line from Tororo S/S to Busia are partly 25 mm² AAAC or ACSR. It was confirmed through discussion with UMEME that the rehabilitation and urgent upgrading work for the line will be carried out starting in this year, 2011 in consideration of development of Busia.

- Rehabilitation work of supporting structures for the line: 220 poles
- Upgrading work of conductor size at the parts where the size of conductor is 25 mm² between Tororo and Busia: 50 mm² ACSR
(By the work, all the conductor between Tororo S/S and Busia will be 50 mm².)

The extension work of the distribution line shall be in conformity with the current conditions of the existing distribution system. In consideration of urgency of the Project, the Project is targeting five years after from the time of the Preparatory Survey, i.e. 2016. Above mentioned upgrading work will contribute to keep the voltage drop within 10 % at the load center (Nankoma T/C) of the project site until the target year based on the demand forecast for the Project shown in Table 10.

23

- The Ugandan side also plans to upgrade 33 kV distribution line from Tororo S/S to Majunji to 100 mm² AAAC to conformity with development of Busia and Lumino within a few years. The upgrading work will contribute to stable and qualitative power supply to the project site from viewpoint of medium term as well as construction of New Iganga S/S, in case that the Project is commissioned.

- The above mentioned upgrading work is planned to include upgrading of the existing 33 kV distribution line around Nankoma T/C, which is between Point B and C in Fig.6, from 25 mm² AAAC to 100 mm² AAAC.

The Team recommends the Ugandan side to include installation work of transformer for the pumping station to supply water to Nankoma T/C, which was confirmed in the site survey between Malovo T/C and Nankoma T/C. It is desirable 33 kV distribution line of the Project can be utilized effectively by installation of the transformer for the pumping station.

3.6 Tentative Implementation Schedule of the Project

Tentative Implementation schedule is shown as Table 19. In case that the Project is decided by the Japanese Government, the Project will proceed as follows in case of the earliest scenario, as shown as Table 19. Installation work of the Project starts in December, 2012.

- The Exchange of Notes between the Ugandan and Japanese Government will be signed in January, 2012.
 - The Tender Opening will be held in June, 2012.
 - Installation work of the Project will start in December, 2012.
 - Commissioning of the Project will be in November, 2013.
 - Design and preparation of tender for installation of low voltage distribution line borne by the Ugandan side shall be commenced immediately after the Exchange of Note.
- In conformity with the time of commissioning of the Project, the Ugandan side procure and install low voltage line in timely manner to escape stagnation of progress of customer connection.




Table 19 Tentative Implementation Schedule

Source: JICA Study Team

25

4.1 Location of 33 kV Distribution Line

Project Route	(km)	Districts	Sub-county
1) Mnyage – Nankoma	21.5	Mnyage, Iganga	Mnyage TC, Bukigile, Mnyunge, Kigululu, Makutu
2) Mnyagwe – Makutu	10.2	Mnyagwe, Iganga	Mnyagwe, Makutu
3) Nankoma – Limimo	37.5	Bopiri, Namayingo, Busia	Nankoma, Bulufika, Mugerere, Budhaya
4) Namayingo – Bumeri A	29.9	Namayingo, Busia	Namayingo TC, Buyinja, Luwe, Limimo
5) Namayingo – Lufala	23.8	Namayingo	Namayingo TC, Buhengha
6) Bukoma – Nwemile-Tayari (Mumuli)	10.5	Busia	Longo
Total	134.4		



The following sections summarize the results of 1st field survey of the Project Route. The following points are derived from those results for the works of environmental survey in 2nd field

- ### Key Findings:

- ### 4.3 Site Survey

Figure 8. Survey Area with Trading Centers

- 1) Socio-economic activities can be affected on the Project routes
- 2) Land use and structures can be affected on the Project routes
- 3) Nature areas can be affected on the Project routes (CFR, wetlands, rivers, vegetation especially roadside valuable trees)
- 4) Local people's involvement

The results of 18 field survey shows that most lands along the Project routes of Area-4 are cultivated already and many trade centers (TCs) are located on. The Project Site has totally gently undulating hills in topography and the requested route passes a Central Forest Reserve (CFR) named frimbi CFR which is used for industrial and commercial plantation on rocky hill (in the short length at approximately 1km. In the inland of Project Site, there are seasonal wetlands that the local people have been cultivating and few wetlands. Respective District Environment Officers say that the local wetlands have common aspects in the country. Table 2) summarizes the environmental and social aspects of Project Site from the 1st site survey and interviews to district environment officers and local representatives (Local Council Chairman).

Area	Description
District	Mayaguez, Igaranga, Baguio, Namanangco, Busia
Topography	- Gently hilly site - Lake shore site
Land Use	- Settlements (trading centers) - Cultivated lands, Cattle grazing land - Woodlot (forestry)
Socio-economy	- Farming: cassava, maize, ground nut, beans, rice, millet, sugarcane - Fishing: tilapia, Nile perch - Livestock: cattle, goat, chicken - Approx. average monthly income: 50,000 – 100,000 (farming), 150,000 – 200,000 (fishing), up to \$250,000 (trading), UGX/1month=sh4
Forest Reserve	- Irimbi CFR (Baguio District): Approx. 1km on the Project Route
Wetland:	- Common wetlands in vegetation - There are few permanent wetlands - Most wetlands are seasonal ones - Local people have been using the wetlands for the subsistence

In the 1st field survey, the Team visited district environment officers and forest officers, and obtained their suggestions on the specific points for the environmental and social considerations of Area-4 as follows.

27

The Team and R&A will avoid or minimize development projects' adverse impacts on the environment and local communities. Based on the policy, both of them conducted the site survey involving the District Environment Officers to identify the focal points of environmental and social impacts to reflect them on the route design.

Through the site survey, the Team, REA and the District Environment Officers found and concluded the following points should be considered most in the Project Site, which are described in the Fact Sheets attached in ANNEX 6.

- Wetlands (permanent and seasonal)
- Forest (Timber CFR)
- Cultural Site (shrine)
- Overcrowded building area at Nanavtiyan branch point

The Team, REA and respective District Environmental Officers observed wetlands (seasonal and permanent), seasonal streams, flood plains, water valley tanks along the Project Route. They are highly modified for cultivation mainly with maize and rice except the water valley tanks. The other crops, sugarcane, cassava, potatoes (tubers), were observed in the wetlands. Cattle grazing are also typical activities in the wetlands. Small water ponds around box culverts were observed as the lowest points in them with the common wetland vegetation mainly of reeds, sedges, alfalfa, *Phragmites*, elephant grass, acacia, and thorny bushes. In the south area of the Project Site, along the Project Route up to the lake shore, the water valley tanks are main domestic water sources as there are few bore holes.

- Wetlands: Seasonal (23 places), Permanent (5 places)
- Seasonal streams: 5 places
- Protected spring: 1 place
- Water valley tanks: 2 places
- Seasonal water pool: 1 place
- Seasonal flood plain: 1 place

Irimbi CFR managed by NFA is located at 250 meters from Irimbi TC. Main function of the Irimbi CFR is categorized in industrial and commercial forest plantations. The area is located on Nyeri river hill and it protect soil from erosion for the surrounding villages. The CFR has supplies fuel woods to Bugiri, Iyanga and the surrounding trading centers. There are three licensed persons in four parts of land along the road. The plantations at the south side are more than the north side along the road. Types of plantations

- North side aspects: Young Grevillias and Ring trees at about 1 meter tall are planted

20

apartely. Another type of plantation is Burtydaria trees which is also planted few. Most land is mixed with maize cultivation encroached by local peoples. Burtydaria trees about 5 years grown (about 5m tall) are planted sparsely. A cultural site (Kazimbis Kungula) is located on the road.

- South side aspects: Crevilla, Pine trees and Burtydaria trees about 5 years grown (about 5m tall) are planted in one homestead area. These trees can be used for timber. A part of land is used mixed with vegetable and maize cultivation encroached by local peoples. Few trees are planted at half part of land along the road. Most land is cultivated with maize.

(3) Cultural Site (shrine)

There are two shrines were identified along the Project Route. Baisemena is located on the north side of the road at the border of Iganga District and Mayuge District, which is taken care by Nalugodha (a cultural leader). There are several rocks surrounded by trees. The other shrine, called Kazimbis Kungula is located on the northern side of the road in Irindi CFR. The site is surrounded by tall trees.

(4) Overcrowded building area at Namanyingo branch point

Residential buildings are established close to the carriageway at the turn of the preliminary Project Route branch to Bunere A TC at Namanyingo TC. The preliminary Project Route will affect the residential buildings along the road at about 400 meters. The space is too narrow to pass the Project Route along the road.

4.3.3 Other Subjects to be Considered

In addition to the first findings, the Team and REA have concluded that the subjects to be considered as much as possible for the Route design as follows:

- Buildings and Structures should not be affected
- Loss of crops will be minimized
- School especially playground will be avoided
- Tall/large trees or massive trees will be avoided or those losses will be minimized

4.3.4 Findings from Environment Officers

The followings are findings for the Project Route from interviews to the District Environment Officers of five districts.

- Important ecosystems: wetlands, Irindi CFR, plantations
- Environment issues: deforestation, wetland degradation,
- Likely positive impacts: lighting, value added agricultural production, welding, produce processed materials, boost of economic activities, growth of trading centers, reduce use of fire wood (deforestation)

- Likely negative impacts: loss of crops and trees, stream flow interruption, destruction of property, people's health
- Mitigation measures: compensation, re-plantation, minimum excavation
- Specific land use: mostly cultivated land with maize, cassava, millet, potato, settlements (shops), schools, plantation along the road
- Threatened species: nesting sparrow, local trees (Mvule-Mulinda Escalpa)

4.3.5 Findings from Local Representatives

It is also important to involve local representatives in the process of the Project. The Team and REA visited 43 local representatives including sub-country headquarters and local representatives (LC) chairmen and mayors of TCs to explain the Project, collect information and ask corporation. The results are summarized as follows:

- Specific land use, ecosystems (forests, wetlands, etc.), trees, graveyards, structures, to be considered along the Project Route. Nothing special, some grave yards but not close
- Positive impacts: Milling (Maize, Rice, Coffee), Charging phone and battery, Sawmill, Refrigerator for cool drink, Welding (workshop), Carentry, Salon, Industrialization (processing factory), Video theater, Health center, School, Reduce use of fire wood (deforestation)
- Negative impacts and fines: Loss of crops, mango trees, Construction workers encroach on land, Accidents (lack of knowledge), Accidents on the facilities (poles and wires), Expense electricity charge/connection cost.
- Mitigation measures for the impacts: compensation, sensitization
- Others: Peoples are aware of road reserve (need sensitization); Peoples can allow the Project Route pass in front of behind buildings; Peoples are waiting power long time

4.4 Environmental and Social Impacts and Mitigation Measures

4.4.1 Anticipated Environmental and Social Impacts

Anticipated environmental and social impacts are summarized as shown in Table 22 incorporating the findings of the site survey and interviews with various stakeholders. Most lands are dominated by farmlands even in both seasonal/permanent wetlands and farmland/ranchland mixed lands along the Project Route. Total 38 TCs include residential/commercial area of larger TC and settlement of smaller TC. The focal points of environmental and social impacts found with the District Environment Officers are already mitigated and reflected on the route design as well as the other subjects mentioned in section 4.3. In this context, the installation of 33 kV distribution lines can minimally affect the natural environment. Loss of crops and trees is the most negative impacts on the cultivated lands along the Project Route, however, will be compensated by REA.

Meanwhile, the power supply to un-electrified households will possibly provide new means of

31

livelihood and extend night-time learning for children at home. At health centers and schools, their public services will be more accessible and reliable for people in a wider area.

Table 22 Anticipated Impacts

No.	Likely Impacts	Descriptions
(1) Positive Impacts		
1) Before/During Construction Phase		
[Social Environment]		
1	Create job opportunities at construction works	As the construction work will be mostly manually conducted, the worker's demand (especially unskilled) can provide a temporary boost for local employment
2	Facilitate business opportunities for local service sector	Local service sector can provide the construction workers accommodation, foods and beverages
2) Operation Phase		
[Social Environment]		
1	Create opportunities to establish new businesses (micro enterprises) to improve income sources for the local peoples	The power supply to households will create the scope of developing new livelihoods using electricity as, <ul style="list-style-type: none"> • Kiosk with refrigerator • Welding, Carpentry, Sawmill • Video theater, salon • Ice-producing to cool fish
2	Improvement of living environments	The electrification can improve the living environment like, <ul style="list-style-type: none"> • Reduce risk of fire and health damage from kerosene lamp • Facilitate access to social information and entertainment with TV, radio, electrical device • Facilitate charging mobile phone and communication • Improve home safety and awareness on sanitation with lighting • Provide a longer time of homework for children at night
3	Improvement of social services (school, health center, water supply)	Better and more reliable public services will be provided by the health centers and schools for people in a wider area. In areas where the local peoples hardly can access to domestic water supplied by bore hole or spring, electrification could induce a water pumping system in those areas. In the health centers, the following impacts can contribute for the health maintenance of local peoples <ul style="list-style-type: none"> • Enable them emergency care in the night • Enable them to introduce electrical medical equipment • Improved cold storage condition for medicine and vaccine can improve medical care services including immunization In the schools, students and teachers can obtain academic progress by <ul style="list-style-type: none"> • Introducing lighting equipment, PC, laboratory, practical equipment, etc. • Extending time of night learning
4	Improvement of agricultural industry	The most likely development is to improve agricultural industry in electrification of grinding mills especially for maize and rice. The electric grinding mills can produce better quality flour and more quantity with lower cost, and those ones can be sold with better prices. Additionally, availability of power can promote investment to establish agricultural processing factories
5	Improvement of social safety	Lighting in households, installation of street lamps and lighting at police stations can contribute to prevent crimes like theft and violence in the darkness. Moreover, the lighting can moderate mental fear to the darkness
(2) Negative Impacts		
1) Before/During Construction Phase		

No.	Likely Impacts	Descriptions
[Natural Environment]		
1	Obstruction of residential buildings	At Namanyingo branch point of the Project Route, there is an area where the space is too narrow to pass the Project Route along the road. The wider narrow space is seen along the Namanyingo-Bunere route at 'T-junction' trading center. The Project Route could affect the residential buildings in the areas.
2	Loss of crops and trees of the Project Route	Most lands along the Project Route are cultivated even in wetlands. The tall/large trees, plantations were also observed along the Route. Those crops and trees on the Project Route will be removed for the installing the poles and cables.
3	Construction workers encroaching on the land	External construction workers use induce fears of the local peoples. They might behave with bad manners, not respect local culture and traditions, or could harm the peoples' properties.
4	Obstruction of cultural sites (shrines)	There are two shrines were identified along the Project Route. The distribution line site pass in front of the shrines.
5	Obstruction of schools especially playground	Primary and secondary schools are located along the Project Route. The installation works and installed poles can hinder the students' activities on the playgrounds.
6	Exposure of HIV/AIDS	The external construction workers could induce illicit sexual relationships with local women and it would enlarge a risk to spread HIV/AIDS.
[Natural Environment]		
8	Obstruction of water flow in wetlands	The Project Route passes along wetlands (seasonal and permanent), seasonal streams, flood plains, water valley valley. Small water pools around the wetlands were observed on the road with some wetland vegetation. If the poles are installed in front of the box culvert, water flows can be obstructed.
7	Loss of trees in Irindi CFR	The Project Route is designed along the road passing through Irindi CFR at about 1 kilometer. The planted trees can be killed to install the distribution line.
8	Loss of vegetation and landscape	The loss of tall/large trees, plantations could deteriorate the vegetation and landscape along the Route although they are avoided as much as possible.
[Accidents]		
9	Accidents of construction workers and local residents	Although a contractor will use few heavy machinery, the manual laboring of the work means that there is one opportunity for accidents involving workers in labor. The works to install poles and wires can induce the accidents on the local peoples.
2) Operation Phase		
[Accidents]		
10	Accidents in households	Due to lack of knowledge of electricity, the households can have accidents like electric shock in their homes. The towns of Iganga in the local peoples' representatives, ICH/III children, sub-securely officials, also use the same lines.
11	Accidents on the facilities	Although rare, the overhead cables may be cut and damaged due to an accident or disaster. The other possible accidents on the facilities are theft, vandalism or burns in the field.

Source: IICA Study Team

4.4.2 Proposed Mitigation Measures

As the environmental items which may experience negative impacts of the Project based on the evaluation results, their common mitigation measures are proposed as shown in Table 33.

33

No.	Possible Negative Impacts	Mitigation Measures	Organization
1) Before/During Construction Phase			
1	Obstruction of buildings and other infrastructure	To avoid the obstructions on buildings, the Project Route will be designed to connect to the other branch line of Nanyang-Luqian Road as a bypass.	REA, Consultant
2	Loss of crops and trees on the Project Route	REA will conduct community meetings, survey, explain to the local people, make agreements, evaluate the subjects with district compensation rates and compensate the owners.	REA
3	Construction workers encroaching on the land	Contractor will instruct the construction workers about proper manner in the site and to learn the local traditions.	Contractor
4	Obstruction of cultural sites (shrines)	The cultural site will not be impacted with the Project Route will be designed passing the opposite side of the road.	REA, Consultant
5	Obstruction of the school specially the playground	The Project Route will be designed passing the opposite side of the road where schools are located.	REA, Consultant
6	Expansion of HIV/AIDS	Contractors will monitor workers and communication with cooperation of respective health centers.	Contractor, Health Centers
7	Obstruction of wetlands	The Project Route will be designed to avoid water pools and soft ground. The poles will be installed at approximately 10m span to avoid the box culverts and stream. To ease the poles are installed in the wetlands, the poles location will be away from the box culverts to avoid obstruction of the flow of water. Clearance of the vegetation and excavation will be avoided in the area where the electricity poles will be installed.	REA, Consultant, Supervising Consultant, Contractor
8	Loss of trees in critical CFR	The Project Route will be designed to pass the north side to avoid more massive forested plantations. The poles will be installed at approximately 10m span to minimize the numbers of poles in the site. REA will compensate NFA, the forested portions and other farmers for the forest trees, crops and animals including in other areas.	REA, Consultant
9	Loss of vegetation and landscape	The Project Route will be designed to avoid tall/large trees or massive trees along the road as much as possible. The trees felled by necessity will be compensated by REA as same as loss of crops and trees. Re-plantation program will be conducted to provide communities with seeds, tree seedlings for replanting.	REA, Community

No.	Possible Negative Impacts	Mitigation Measures	Organization
10	Accidents of construction workers and local residents	Personal Protective wear will be provided for all the workers during construction according to the labor laws of Uganda and ensure good and safe working conditions in accordance with contractor's construction manuals which are required in the contract.	Supervising Consultant, Contractor
2) Operation Phase			
11	Accidents in households	REA will sensitize the local people to educate about electricity and instruction how to use safely.	REA, District/ Sub-county offices
12	Accidents on the facilities	Operator is obligated to maintain the facilities complying with their maintenance regulation. Community development Officer will also sensitize the local people on the importance of maintaining the facilities, need protect them from theft, vandalism or burns in the field.	Operator, Community (LCI/II), Sub-county

4.4.3 Procedure of Compensation

On that basis, the road reserves of selected routes should be cleared according to road classification of national and district levels, if REA will use the road reserves for the Project. Even in case that REA will not use the road reserve, distances to be kept from them should be cleared.

Meanwhile, REA's policies and procedures how to secure the routes of 33kV distribution lines should be confirmed. REA will take the following steps for compensation on the routes. However, the survey will be started just before construction according to the REA's prior projects. Therefore, it is recommended that the first step of the process, the community meeting with related LCI Chairmen, will be conducted immediately after E/N and agreement are done. Besides, the local peoples will also be involved in the early meeting.

- Community meeting with LCI Chairmen
- Survey and Explanation to persons whose properties are affected
- Agreement with the wayleaves consent form
- Evaluation of properties on the routes with the wayleaves assessment form
- Preparation of evaluation report
- Submission of the evaluation report to a Chief Government Valuer in Ministry of Land
- Assessment and authorization by a Chief Government Valuer
- Explanation of evaluation results to the affected owners and payment

4.5 Preparation of Project Brief (PB)

REA should obtain an Environmental Certificate (EC) from NEMA to implement the Project. As the first step, REA shall submit NEMA a Project Brief which describes the outline of the project, likely impacts caused by the Project and the mitigation measures. NEMA will determine whether or not the Project is exempted from an EIA based on the Project Brief. To prepare the PB, an environment expert who belongs to MEMD joined the site survey. She will finalize the PB and submit NEMA it in the end of August.

5. Work Demarcations for Both Parties

In the implementation of the Grant-Aid Project, Japanese side and Ugandan side is required to undertake such necessary measures as shown in Table 24.

No.	Understandings	To be covered by Japan / Uganda	Remarks	Item No. on MOP
1	(1) Relinquish of lands of the Project site (points of 33kV distribution lines)			1
2	(2) Land leveling and preparation, bush clearing and removal of obstacles in the Project site			
3	To construct the following facilities		Not Applicable (Existing conditions work does not include)	3
	(1) The building			
	(2) The gates and fences in and around the site			
	(3) The parking lot			
	(4) The road within the site			
	(5) The road outside the site			
4	To provide facilities for distribution of electricity, water supply and drainage and other incidental facilities necessary for the implementation of the Project outside the Project site		Not Applicable (Existing installation work does not include)	4
	(1) Water supply			
	a. The distribution power line in the site			
	b. The drop wiring and internal wiring within the site			
	c. The main canal, trench and transmission			
	(2) Water supply			
	a. The city water distribution main to the site			
	b. The supply system within the site (reservoir and elevated tanks)			
	(3) Drainage			
	a. The city drainage main (for storm sewer and effluent in the site)			
	b. The drainage system (for solid sewer, common waste, storm drainage and others) within the site			
	(4) Gas supply			
	a. The city gas main to the site			
	b. The gas supply system within the site			
	(5) Telephone System			

No.	Understandings	To be covered by Japan / Uganda	Remarks	Item No. on MOP
	a. The telephone main line to the main distribution frame/pole (MD) of the building			
	b. The MD and the extension after the termination			
	(6) Furniture and Equipment			
	a. General furniture			
	b. Project equipment			
4	Transportation of the Equipment, customs procedures and tax procedures			4 and 5
	(1) Air cargo transportation to a port of disembarkation			
	(2) Procedures for tax exemption and customs clearance at the port of disembarkation			
	(3) Internal transportation from a port of disembarkation to the Project site		Delivery point: Storage Yard at Nakawa	
	(4) Exemption or payment of value-added tax (VAT) on locally procured items			
5	Procedures necessary to obtain the following permits for the Japanese Consultants and Contractor:		The permits shall be obtained before project implementation.	6
	- Permit required for installation works			
	- Permit to access restricted areas			
6	Proper operation and maintenance of facilities and the equipment after the Project		including bush clearing and removal of obstacles along 33kV distribution lines	7
7	To bear all the expenses, other than those covered by Grant, necessary for the implementation of the project.			8
8	Payment of the following fees based on the Banking Arrangement:			9
	(1) A/P advising commission		Approx. 10,000 Japanese Yen	
	(2) Payment commission		0.1% of the grant aid amount	
9	Giving due environmental and social considerations in the implementation of the Project.			10
10	Securing of land of temporary material storage yard with fence and gate		To be utilized Storage Yard at Nakawa	
11	Securing parking space during installation period		To be secured, beside the road during the installation work	
12	Site offices		See the Japanese Consultants and Contractor	
13	Proper storage and safety management of the equipment in temporary material storage yard			
14	Securing of working space along routes of 33kV distribution lines and traffic control		When necessary	
15	Relocation of existing overhead/underground cables or pipes of power, telephone, water supply/drainage, etc. and obtaining necessary permissions		When necessary	
16	Obtaining permissions on road crossing during 33kV distribution line work		When necessary	
17	Providing of disposal site of soil and discharged water caused by the installation work			
18	Manufacturing and procurement of the equipment		"The Equipment" is defined as the equipment and materials to be provided by the Japanese side under the Project.	

No.	Understandings	To be covered by Japan side	Remarks	Item No. in S4/D
19	Installation of the Equipment, adjust and setting	<input type="checkbox"/>	The Ugandan side is required to install equipment and tools to be provided on the Project to the Japanese Contractor during installation.	
20	Temporary shut down during installation	<input type="checkbox"/>		
21	Installation of a final back-sweep onto the existing pole at the connection point of 24kV distribution line to Nakulima	<input type="checkbox"/>		
22	Final connection to the existing 24kV distribution lines	<input type="checkbox"/>	By Mayuge, Nankomo and Lomwa connection points	
23	Provision of materials for the above mentioned final connection	<input type="checkbox"/>		
24	Provision of training for initial operation and maintenance of the Equipment	<input type="checkbox"/>		
25	Assessing security for personnel in the Project sites	<input type="checkbox"/>	On request	
26	Managing any dispute from consumers regarding temporary shut down for installation work including compensation for consumers	<input type="checkbox"/>	If necessary	
27	Public notice of scheduled shut down and implementation of the project during the implementation stage	<input type="checkbox"/>		
28	Design, procurement and installation of trunk line of low voltage distribution lines and operation to ensure transparency and public facilities in the Project area	<input type="checkbox"/>	The Ugandan side is required to implement the work in parallel with 24kV distribution line work done by Japanese side.	
29	Salary	<input type="checkbox"/>	The Ugandan side is required to implement the work in parallel with 24kV distribution line work done by Japanese side.	

Source: JICA Study Team

Note: * is Granted by the "Annex Test Minutes of Discussion" signed between the Ugandan and Japanese side.

ANNEX

1. Member of the Team

1 Member of the Team

Name	Assignment	Organization
Akira NIWA	Team Leader	Japan International Corporation Agency
Yoshikazu WADA	Planning and Management	Japan International Corporation Agency
Masatsugu KOMIYA	Chief Consultant / Power Supply Planning	Yachiyo Engineering Co., Ltd.
Kazumori NOGAMI	Deputy Chief Consultant/ Distribution Equipment Planning	Yachiyo Engineering Co., Ltd.
Masayuki TAMAI	Distribution System Planning	Yachiyo Engineering Co., Ltd.
Takeshi OMURA	Social and Environmental Considerations	Yachiyo Engineering Co., Ltd.
Atsuhito URUNO	Procurement and Installation Plan/ Cost Estimation	Yachiyo Engineering Co., Ltd.
Ayumi KOYAMA	Coordinator/ Assistance for Distribution System Planning	Yachiyo Engineering Co., Ltd.

2. List of Parties Concerned in the Recipient Country

2. List of Parties Concerned in the Recipient Country

Name **Employment Position**

Ministry of Finance, Planning and Economic Development (MoFPED)

Mr. Lawrence K. Kiles Director Economic Affairs
Mr. Muhumusa NTACYO Javani Senior Economist/ Finance Officer Aid (Lesse Department)

Ministry of Energy and Mineral Development (MEMD)

Mr. Irene Nalwira Mironi Minister of Energy and Minerals
Mr. Simon D'Janga, Minister of State for Energy
Mr. Ssegawa Ronald Gyagenda Undersecretary
Eng. Henry Bidassa-Igaga Assistant Commissioner (Electric Power)
Eng. Moses Murengesi Advisor to Chairman (EMSWG)
Mr. Sam Barasa Personal Assistant to Minister
Mr. James Bwanabe Isingoma Acting Commissioner Energy Resources Department
Mr. Sigiabi J. Fredrick Senior Energy Officer
Mr. Agni Caroline Senior Petroleum Officer/ Environment
Ms. Mary Mwegisa Civil Engineer
Mr. Nabagereka Hridget Electrical Engineer
Mr. Emmanuel Sindi Nsubuga Energy Officer (Electrical)

Rural Electrification Agency (REA)

Mr. Godfrey R. Turyahikayo Executive Director
Mr. Wexiku R. Godfrey Manager Project Monitoring & Evaluation
Mr. Mugwera Andrew Principal Planning Engineer
Mr. Philip E.P. Ggoyi Senior Planning Engineer
Mr. Thomas Amuku Senior Project Engineer
Ms. Joan Kayunga Mutibwa Project Engineer Construction
Mr. Daniel Muganza Intern

Uganda Electricity Transmission Company Ltd. (UETCL)

Mr. Eriasi Kiyenba CEO
Mr. Gerald Muganga Manager, Planning and Investments
Mr. Andrew Geno Omalla Technical Officer, Projects
Mr. Ziria Titalwa Principal Planning Engineer
Ms. Stephen Kyegamwa Senior Planning Engineer

Uganda Electricity Distribution Company Ltd. (UEDCL)

Mr. Laim Hamanya Project Manager

Mayuge District

Mr. Omar Brugo Dantoor District Chairman, Mayuge District
Mr. Kahakulya Samuel Assistant Chief Administrative Officer
Mr. Lubanga District Natural Resource Officer
Mr. Alan Thomas District Environment Officer

Iganga District

Ms. Epodot Pauline Orio Principal Assistant Secretary
Mr. Wamala Jotham Assistant Chief Administrative Officer
Mr. Samanya Abdul District Forest Officer
Mr. Dhikusooka Joseph District Agricultural Officer
Mr. Batmuka Samuel District Community Officer
Mr. Kayemba Jonan Fred District Planner
Mr. Kagere Reinhard Project Support Officer CAIP
Mr. Nelson Mwamul Chairman Nondwe Town Board
Mr. Muhikwa Sulayi Counsellor of Nondwe

Bugiri District

Ms. Margaret Mwanamulizi Resident District Commissioner
Mr. Luke L.L. Lukoda Chief Administrative Officer
Ms. Benishet Kauma Environmental Officer
Mr. Kyomulira Mwandazuly District Planner
Mr. Ngia Abeké Water pump Operator
Mr. Rogers Muzamvu Water pump Operator

Namayingo District

Mr. Richard Mugolo Chief Administrative Officer
Mr. Kaleeba Peter Assistant Chief Administrative Officer
Mr. Mayedo Ekwoni Accountant
Mr. Kaawo Kawere Naay District Educational Officer
Mr. Bwamiki Michael District Health Educator
Mr. Kaleeba Peter District Health Inspector

Busia District

Mr. Sentosa Yusuf Chief Administrative Officer
Mr. Adeya Vincent Deputy Chief Administrative Officer
Mr. Wabwire Patrick District Planner
Ms. Teopista Namajja Municipality Environmental Officer
Mr. Osiango Matola Julius Chief of Busime sub-county
Mr. Ondworo James Accountant of Busime sub-county
Ms. Kinye Murewa Intern

Uneme Limited

Mr. Charles Chapman Managing Director
Mr. Sam Zimbe General Manager Corporate & Regulatory Affairs
Mr. Robert Kisubi Support Services Manager
Mr. Zach Humani Network Manager Planning & Loss Reduction
Mr. Isaac Serwadda Project Manager
Mr. Robert Mubiru Area Manager Eastern
Mr. Fred Wandira Power Transformer Maintenance Manager
Mr. Charles Magonbe Switchgear Maintenance Manager
Ms. Patricia Ocan Planning & Design Manager

Embassy of Japan in Uganda

Kazuo Minagawa Ambassador Extraordinary and Plenipotentiary
Eri Ogawa Third Secretary
Shugo Shimodaira Coordinator for Economic Cooperation

JICA Uganda Office

Mr. Tetsuo Saki Chief Representative
Ms. Akiko Nanami Representative
Ms. Masae Iijima Project Formulation Advisor

3. Minutes of Discussion


Minutes of Discussions on the Preparatory Survey on the Project for Rural Electrification Phase III in the Republic of Uganda (Second Field Survey)

In response to the request from the Government of the Republic of Uganda (hereinafter referred to as "Uganda"), the Japan International Cooperation Agency (hereinafter referred to as "JICA"), in consultation with the Government of Japan, decided to conduct a Preparatory Survey (hereinafter referred to as "the Survey") on the Project for Rural Electrification Phase III (hereinafter referred to as "the Project").


JICA dispatched the 2nd Field Survey Team (hereinafter referred to as "the Team") to Uganda, headed by Dr. Akira NIWA, Senior Advisor, Department of Human Resources for International Cooperation, JICA. The Team is scheduled to stay in Uganda from June 10 to July 21, 2011.


The Team held discussions with the officials of authorities concerned of the Government of Uganda (hereinafter referred to as "the Ugandan side"), and conducted a series of field surveys. In the course of the discussions, both the Ugandan side and the Team (hereinafter referred to as "Both parties") have confirmed the main items described in the sheets attached hereto.


Kampala, June 16, 2011


Dr. Akira NIWA
Leader,
Preparatory Survey Team,
Japan International Cooperation Agency
(JICA)

Witness:


Ms. Jennifer Muwizi
Ag. Commissioner,
Aid Liaison Department,
Ministry of Finance Planning and
Economic Development (MoFPED)


Mr. Fred Kabugambe-Kalisa
Permanent Secretary,
Ministry of Energy and Mineral Development
(MEMD)
/ Chairman of Rural Electrification Board


Mr. Godfrey R. Turyahikayo
Executive Director,
Rural Electrification Agency (REA),
Ministry of Energy and Mineral Development
(MEMD)

ATTACHMENT

1. Objective of the Project

The objective of the Project is to extend the distribution system for reliable and stable supply of electricity to the rural communities within the Project sites.

2. The Project Site

The Ugandan side and the Team confirmed prioritization among six candidate project sites in the 1st Field Survey and agreed that the Area-4 as the most prioritized site in consideration of previous project scale. Main reasons for the prioritization are (1) electrification beneficiaries in terms of the number of consumers which include trading centers, households, schools and health centers, (2) an importance of electrification of new district headquarters in Namayingo, and (3) project impacts including synergy with the Interconnection of Electric Grids of Nile Equatorial Lakes Countries Project. Both parties reconfirmed needs and urgency of rural community electrification and agreed to take necessary action by conveying strong recommendation to decision makers for the smooth and timely implementation of the Project to both governments. The Project Sites are shown in Annex-1.

3. Responsible and Implementing Organizations

- (1) The responsible organization for the Project is the Ministry of Energy and Mineral Development (MEMD).
- (2) The implementing agency is the Rural Electrification Agency (REA).
- (3) The organization charts of MEMD and REA are shown in Annex-2 and Annex-3, respectively.

4. Components of the Project

JICA explained the result of analysis on the 1st Survey to Ugandan side and also explained following main components of the Area-4, the highest prioritized project site. The detailed contents of the components are described in Annex-4.

- (1) Supply and installation of 33kV distribution lines in Mayuge-Lumino.
- (2) Installation of distribution transformers (33kV/415-230V).

5. Japan's Grant Aid Scheme

- (1) The Ugandan side has understood the Japan's Grant Aid Scheme explained by the Team as described in Annex-5 and Annex-6.
- (2) The Ugandan side will take necessary measures, as described in Annex-7, for smooth implementation of the Project as prerequisites for the Japan's Grant Aid to be implemented.

6. Environmental and Social Considerations

- (1) The Ugandan side agreed to comply with the JICA Guidelines for Environmental and Social Considerations (April 2004) (hereinafter referred to as "JICA Guidelines") as well as Ugandan laws and regulations, and to prepare Environmental Checklist and Monitoring Form which are designated by JICA Guidelines for an outline design.

- (2) Both parties confirmed that a project brief document was required for the Project to obtain approval from the National Environment Management Authority (NEMA). The project brief document would duly include IEE level study and mitigation measures for the selected section of distribution line. The project brief document for the Project will be prepared and submitted to the NEMA by the end of August, 2011. An approval is to be expected by the end of October, 2011.
- (3) Both parties agreed followings in relation to environment and social considerations:
 - (a) REA assigned an environment officer during the 2nd Field Survey to coordinate the environmental activities, survey for environmental impacts and mitigation measures, and compile baseline data for preparation of the project brief.
 - (b) REA will conduct stakeholder meetings (SHM) on July 13 and 14 (tentative) at Namayingo and Mayuge district headquarters respectively, inviting district officials and community leaders from the Project areas. The proposed agenda of SHM will include:
 - (i) Explanation of government policy and plan in rural electrification.
 - (ii) Presentation of project features.
 - (iii) Presentation of the route map of 33kV distribution line, location map of transformers and load centers.
 - (iv) Characteristics of project impacts and mitigation measures at sites, and
 - (v) Enhance awareness in community.
 Records and findings of the SHM will be incorporated in the Project Brief.
 - (c) JICA is to monitor the progress of environmental activities in terms of the overall project schedule and review and advise on the outcomes in order to ensure conformity with JICA Environmental and Social Consideration Guidelines.
- (4) The Ugandan side agreed to secure funds necessary for implementation of the Project.
- (5) The Ugandan side agreed to secure funding for and execution of the above environmental matters in a schedule as required for smooth execution of the Project.

7. Technical Considerations

The Ugandan side will formulate the technical notes together with the Team during the 2nd Field Survey. The technical notes aims at clarifying works to be done by the Ugandan side for smooth implementation of the Project especially data and document collection for further analysis in the outline design and environmental and social consideration activities.

8. Schedule of the Survey

The Team will continue the Survey in Uganda until July 21, 2011. Based on the results of the Survey, JICA plans to send a mission to explain the Draft Final Report in October, 2011.

9. Other Relevant Issues

- (1) Status of the Survey

The Team explained that the purpose of the Survey is to collect necessary information and data for 1) the evaluation of the relevance, appropriateness and urgency of the Project, 2) the identification of the priorities of the components of the Project, and 3) the identification of the

issues to be cleared for implementation of the Project. Therefore the project site for the Survey and components confirmed by both parties may not necessarily be approved by the Government of Japan.

(2) Stable and reliable electricity supply in the Project Site.

Both parties have discussed and confirmed necessity for further analysis in the related transmission line and distribution lines for stable and reliable electricity supply in the Project site. In order to realize power supply stability in the region, both parties agreed that the Ugandan side will submit an additional proposal by the end of the 2nd Field Survey. The team will review and evaluate technical and economic viability of the proposal for the further consideration of Japanese government.

(3) Confirmation of information/ data submission

In the 1st field survey, MEMD/REA agreed on the following measures to minimize the constraints on realization of the electrification benefit of rural communities in the Project sites.

- Revision of policy, which was specifically the Rural Electrification Strategy and Plan (RESP)
- Social and economic data in the Area-4 were to be confirmed during the 2nd Field Survey of the Project
- To realize timely implementation of low voltage connection to the communities for the Project by making necessary arrangements including measures for avoiding a delay in the procurement procedures by initiating the contract as soon as the Outline Design completed

(4) Counterpart Personnel

The Team requested the Ugandan side that necessary number of counterpart personnel shall be assigned to the Team and necessary arrangements with related organizations shall be made during the Survey in Uganda. The Ugandan side agreed to support the Team based on the request.

(5) Questionnaires

The Team requested the Ugandan side that the answers to the questionnaires which the Team had already submitted to the Ugandan side shall be given to the Team by July 19, 2011.


(End)

- Annex-1 The Project Site
 Annex-2 Organization charts of MEMD
 Annex-3 Organization charts of REA
 Annex-4 Components of the Project confirmed by the Ugandan side and the Japanese side
 Annex-5 Japan's Grant Aid
 Annex-6 Flow Chart of Japan's Grant Aid Procedures
 Annex-7 Major Undertakings to be taken by Each Government

The Project Site




Annex-2



Organization charts of MEMD

Annex-3



Organization charts of REA

JAPAN'S GRANT AID

The Government of Japan (hereinafter referred to as "the GOJ") is implementing the organizational reforms to improve the quality of ODA operations, and as a part of this realignment, a new JICA law was entered into effect on October 1, 2008. Based on the law and the decision of the Government of Japan (hereinafter referred to as "the GOJ"), JICA has become the executing agency of the Grant Aid for General Projects, for Fisheries and for Cultural Cooperation, etc.

The Grant Aid is non-reimbursable fund to a recipient country to procure the facilities, equipment and services (engineering services and transportation of the products, etc.) for economic and social development of the country under principles in accordance with the relevant laws and regulations of Japan. The Grant Aid is not supplied through the donation of materials as such.

1. Grant Aid Procedures

The Japanese Grant Aid is conducted as follows:

- Preparatory Survey (hereinafter referred to as "the Survey")
 - The Survey conducted by JICA
- Appraisal & Approval
 - Appraisal by The GOJ and JICA, and Approval by the Japanese Cabinet
- Determination of Implementation
 - The Notes exchanged between the GOJ and a recipient country
- Grant Agreement (hereinafter referred to as "the G/A")
 - Agreement concluded between JICA and a recipient country
- Implementation
 - Implementation of the Project on the basis of the G/A

2. Preparatory Survey

(1) Contents of the Survey

The aim of the Survey is to provide a basic document necessary for the appraisal of the Project by JICA and the GOJ. The contents of the Survey are as follows:

- Confirmation of the background, objectives, and benefits of the Project and also institutional capacity of agencies concerned of the recipient country necessary for the implementation of the Project.
- Evaluation of the appropriateness of the Project to be implemented under the Grant Aid Scheme from a technical, financial, social and economic point of view.
- Confirmation of items agreed on by both parties concerning the basic concept of the Project.
- Preparation of a basic design of the Project.
- Estimation of costs of the Project.

The contents of the original request by the recipient country are not necessarily approved in their initial form as the contents of the Grant Aid project. The Basic Design of the Project is confirmed considering the guidelines of the Japan's Grant Aid scheme.

JICA requests the Government of the recipient country to take whatever measures are necessary

to ensure its self-reliance in the implementation of the Project. Such measures must be guaranteed even though they may fall outside of the jurisdiction of the organization in the recipient country actually implementing the Project. Therefore, the implementation of the Project is confirmed by all relevant organizations of the recipient country through the Minutes of Discussions.

(2) Selection of Consultants

For smooth implementation of the Survey, JICA uses (a) registered consulting firm(s), JICA selects (a) firm(s) based on proposals submitted by interested firms.

(3) Result of the Survey

The Report on the Survey is reviewed by JICA, and after the appropriateness of the Project is confirmed, JICA recommends the GOJ to appraise the implementation of the Project.

3. Japan's Grant Aid Scheme

(1) The E/N and the G/A

After the Project is approved by the Cabinet of Japan, the Exchange of Notes (hereinafter referred to as "the E/N") will be signed between the GOJ and the Government of the recipient country to make a plan for assistance, which is followed by the conclusion of the G/A between JICA and the Government of the recipient country to define the necessary articles to implement the Project, such as payment conditions, responsibilities of the Government of the recipient country, and procurement conditions.

(2) Selection of Consultants

The consultant firm(s) used for the Survey will be recommended by JICA to the recipient country or also work on the Project's implementation after the E/N and the G/A, in order to maintain technical consistency.

(3) Eligible source country

Under the Japanese Grant Aid, in principle, Japanese products and services including transport or those of the recipient country are to be purchased. When JICA and the Government of the recipient country or its designated authority deem it necessary, the Grant Aid may be used for the purchase of the products or services of a third country. However, the prime contractors, namely, constructing and procurement firms, and the prime consulting firm are limited to "Japanese nationals".

(4) Necessity of "Verification"

The Government of the recipient country or its designated authority will conclude contracts denominated in Japanese yen with Japanese nationals. Those contracts shall be verified by JICA. This "Verification" is deemed necessary to secure accountability to Japanese taxpayers.

(5) Major undertakings to be taken by the Government of the Recipient Country

In the implementation of the Grant Aid Project, the recipient country is required to undertake such necessary measures as Annex-7.

(6) "Proper Use"

The Government of the recipient country is required to maintain and use the facilities constructed and the equipment purchased under the Grant Aid properly and effectively and to assign staff necessary for this operation and maintenance as well as to bear all the expenses other than those covered by the Grant Aid.

(7) "Export and Re-export"

The products purchased under the Grant Aid should not be exported or re-exported from the recipient country.

(8) Banking Arrangements (B/A)

- a) The Government of the recipient country or its designated authority should open an account in the name of the Government of the recipient country in a bank in Japan (hereinafter referred to as "the Bank"). JICA will execute the Grant Aid by making payments in Japanese yen to cover the obligations incurred by the Government of the recipient country or its designated authority under the Verified Contracts.
- b) The payments will be made when payment requests are presented by the Bank to JICA under an Authorization to Pay (A/P) issued by the Government of the recipient country or its designated authority.


(9) Authorization to Pay (A/P)

The Government of the recipient country should bear an advising commission of an Authorization to Pay and payment commissions to the Bank.

(10) Environmental and Social Considerations

A recipient country must ensure the social and environmental considerations for the Project and must follow the environmental regulation of the recipient country and the JICA Guidelines for Environmental and Social Considerations (April 2004).

Flow Chart of Japan's Grant Aid Procedures



16

DL

Stage	Material	Hourly wage	Hourly material	Material cost	Hourly labor
1. Preparation of materials	1. Cement 100 kg	10	10	10	10
2. Mixing of concrete	2. Sand 100 kg	10	10	10	10
3. Laying of bricks	3. Bricks 1000	10	10	10	10
4. Finishing of walls	4. Plaster 100 kg	10	10	10	10
5. Painting of walls	5. Paint 100 kg	10	10	10	10
6. Laying of floor	6. Tiles 1000	10	10	10	10
7. Finishing of floor	7. Grout 100 kg	10	10	10	10
8. Laying of roof	8. Tiles 1000	10	10	10	10
9. Finishing of roof	9. Grout 100 kg	10	10	10	10
10. Laying of walls	10. Bricks 1000	10	10	10	10
11. Finishing of walls	11. Plaster 100 kg	10	10	10	10
12. Painting of walls	12. Paint 100 kg	10	10	10	10
13. Laying of floor	13. Tiles 1000	10	10	10	10
14. Finishing of floor	14. Grout 100 kg	10	10	10	10
15. Laying of roof	15. Tiles 1000	10	10	10	10
16. Finishing of roof	16. Grout 100 kg	10	10	10	10
17. Laying of walls	17. Bricks 1000	10	10	10	10
18. Finishing of walls	18. Plaster 100 kg	10	10	10	10
19. Painting of walls	19. Paint 100 kg	10	10	10	10
20. Laying of floor	20. Tiles 1000	10	10	10	10
21. Finishing of floor	21. Grout 100 kg	10	10	10	10
22. Laying of roof	22. Tiles 1000	10	10	10	10
23. Finishing of roof	23. Grout 100 kg	10	10	10	10
24. Laying of walls	24. Bricks 1000	10	10	10	10
25. Finishing of walls	25. Plaster 100 kg	10	10	10	10
26. Painting of walls	26. Paint 100 kg	10	10	10	10
27. Laying of floor	27. Tiles 1000	10	10	10	10
28. Finishing of floor	28. Grout 100 kg	10	10	10	10
29. Laying of roof	29. Tiles 1000	10	10	10	10
30. Finishing of roof	30. Grout 100 kg	10	10	10	10
31. Laying of walls	31. Bricks 1000	10	10	10	10
32. Finishing of walls	32. Plaster 100 kg	10	10	10	10
33. Painting of walls	33. Paint 100 kg	10	10	10	10
34. Laying of floor	34. Tiles 1000	10	10	10	10
35. Finishing of floor	35. Grout 100 kg	10	10	10	10
36. Laying of roof	36. Tiles 1000	10	10	10	10
37. Finishing of roof	37. Grout 100 kg	10	10	10	10
38. Laying of walls	38. Bricks 1000	10	10	10	10
39. Finishing of walls	39. Plaster 100 kg	10	10	10	10
40. Painting of walls	40. Paint 100 kg	10	10	10	10
41. Laying of floor	41. Tiles 1000	10	10	10	10
42. Finishing of floor	42. Grout 100 kg	10	10	10	10
43. Laying of roof	43. Tiles 1000	10	10	10	10
44. Finishing of roof	44. Grout 100 kg	10	10	10	10
45. Laying of walls	45. Bricks 1000	10	10	10	10
46. Finishing of walls	46. Plaster 100 kg	10	10	10	10
47. Painting of walls	47. Paint 100 kg	10	10	10	10
48. Laying of floor	48. Tiles 1000	10	10	10	10
49. Finishing of floor	49. Grout 100 kg	10	10	10	10
50. Laying of roof	50. Tiles 1000	10	10	10	10
51. Finishing of roof	51. Grout 100 kg	10	10	10	10
52. Laying of walls	52. Bricks 1000	10	10	10	10
53. Finishing of walls	53. Plaster 100 kg	10	10	10	10
54. Painting of walls	54. Paint 100 kg	10	10	10	10
55. Laying of floor	55. Tiles 1000	10	10	10	10
56. Finishing of floor	56. Grout 100 kg	10	10	10	10
57. Laying of roof	57. Tiles 1000	10	10	10	10
58. Finishing of roof	58. Grout 100 kg	10	10	10	10
59. Laying of walls	59. Bricks 1000	10	10	10	10
60. Finishing of walls	60. Plaster 100 kg	10	10	10	10
61. Painting of walls	61. Paint 100 kg	10	10	10	10
62. Laying of floor	62. Tiles 1000	10	10	10	10
63. Finishing of floor	63. Grout 100 kg	10	10	10	10
64. Laying of roof	64. Tiles 1000	10	10	10	10
65. Finishing of roof	65. Grout 100 kg	10	10	10	10
66. Laying of walls	66. Bricks 1000	10	10	10	10
67. Finishing of walls	67. Plaster 100 kg	10	10	10	10

Price of fuel
kerosene UGX2,800/L
diesel UGX3,200/L
gasoline UGX3,800/L
dry fuel UGX1,200/Pan
charcoal UGX3,500-Ton
oil UGX2,500,000/Cylinder

