No.

FINAL REPORT

ON

PREPARATORY SURVEY

ON

THE PHOTOVOLTAIC POWER PLANT PROJECT

IN

THE ARAB REPUBLIC OF EGYPT

APPENDIX 2/2

DECEMBER, 2012

JAPAN INTERNATIONAL COOPERATION AGENCY (JICA)

MEE
CR (10)
12-024

Appendix 2/2

Appendix 1/2

Appendix 2-1:	Grid Code (First Draft A of Egyptian Electric Power Transmission Code)
Appendix 2-2:	"Promoting Investments in Renewable Energy Projects"

Appendix 3-2-1: Measurement Data

Appendix 2/2

Appendix 3-2-2:	Method of Calculating monthly PV module temperature
Appendix 3-3-1:	Method of calculating solar radiation
Appendix 3-3-2:	Calculation of wind load and seismic load for PV foundation
Appendix 3-3-3:	Calculation of PV foundation
Appendix 3-4-1:	Cost breakdowns for Poly Crystalline, MLTF and CIS
Appendix 3-4-2:	Image of information center (layout and interior)
Appendix 3-4-3:	Terms of Reference for Consulting Services (Draft)
Appendix 3-5-1:	Cost Breakdown for the Project
Appendix 3-5-2:	Detailed Cost breakdown for the Project
Appendix 3-5-3:	Annual Fund Requirements (JP Yen basis)
Appendix 3-5-4:	Cost Breakdown for Consulting Services
Appendix 3-5-5:	Man-Months allocation for consultant
Appendix 6-1:	Screening Format of JICA's Guidelines for Environmental and Social
	Considerations and JICA's Environmental Checklist for Other Electric
	Generation
Appendix 6-2:	ESIA Report
Appendix 6-2: Appendix 6-3:	Generation ESIA Report Description of the results of the individual scoping meetings
Appendix 6-2: Appendix 6-3: Appendix 6-4:	Generation ESIA Report Description of the results of the individual scoping meetings Minutes of Meeting of the public consultation
Appendix 6-2: Appendix 6-3: Appendix 6-4: Appendix 7-1:	Generation ESIA Report Description of the results of the individual scoping meetings Minutes of Meeting of the public consultation Template Form for "Contribution of a Project in Sustainable
Appendix 6-2: Appendix 6-3: Appendix 6-4: Appendix 7-1:	Generation ESIA Report Description of the results of the individual scoping meetings Minutes of Meeting of the public consultation Template Form for "Contribution of a Project in Sustainable Development"
Appendix 6-2: Appendix 6-3: Appendix 6-4: Appendix 7-1: Appendix 7-2:	Generation ESIA Report Description of the results of the individual scoping meetings Minutes of Meeting of the public consultation Template Form for "Contribution of a Project in Sustainable Development" Template Form for "Confirmation of Voluntarily Participation in a
Appendix 6-2: Appendix 6-3: Appendix 6-4: Appendix 7-1: Appendix 7-2:	Generation ESIA Report Description of the results of the individual scoping meetings Minutes of Meeting of the public consultation Template Form for "Contribution of a Project in Sustainable Development" Template Form for "Confirmation of Voluntarily Participation in a Project"
Appendix 6-2: Appendix 6-3: Appendix 6-4: Appendix 7-1: Appendix 7-2: Appendix 7-3:	Generation ESIA Report Description of the results of the individual scoping meetings Minutes of Meeting of the public consultation Template Form for "Contribution of a Project in Sustainable Development" Template Form for "Confirmation of Voluntarily Participation in a Project" Template Form for "Confirmation of no Official Development Assistance
Appendix 6-2: Appendix 6-3: Appendix 6-4: Appendix 7-1: Appendix 7-2: Appendix 7-3:	Generation ESIA Report Description of the results of the individual scoping meetings Minutes of Meeting of the public consultation Template Form for "Contribution of a Project in Sustainable Development" Template Form for "Confirmation of Voluntarily Participation in a Project" Template Form for "Confirmation of no Official Development Assistance (ODA) will be diverted to the Project"
Appendix 6-2: Appendix 6-3: Appendix 6-4: Appendix 7-1: Appendix 7-2: Appendix 7-3: Appendix 7-4:	Generation ESIA Report Description of the results of the individual scoping meetings Minutes of Meeting of the public consultation Template Form for "Contribution of a Project in Sustainable Development" Template Form for "Confirmation of Voluntarily Participation in a Project" Template Form for "Confirmation of no Official Development Assistance (ODA) will be diverted to the Project" Draft Project Idea Note (PIN)
Appendix 6-2: Appendix 6-3: Appendix 6-4: Appendix 7-1: Appendix 7-2: Appendix 7-3: Appendix 7-4: Appendix 7-5:	 Generation ESIA Report Description of the results of the individual scoping meetings Minutes of Meeting of the public consultation Template Form for "Contribution of a Project in Sustainable Development" Template Form for "Confirmation of Voluntarily Participation in a Project" Template Form for "Confirmation of no Official Development Assistance (ODA) will be diverted to the Project" Draft Project Idea Note (PIN) Calculation of the Emission Factor for the Egyptian Unified Electric Grid
Appendix 6-2: Appendix 6-3: Appendix 6-4: Appendix 7-1: Appendix 7-2: Appendix 7-2: Appendix 7-3: Appendix 7-4: Appendix 7-5: Appendix 8-1:	 Generation ESIA Report Description of the results of the individual scoping meetings Minutes of Meeting of the public consultation Template Form for "Contribution of a Project in Sustainable Development" Template Form for "Confirmation of Voluntarily Participation in a Project" Template Form for "Confirmation of no Official Development Assistance (ODA) will be diverted to the Project" Draft Project Idea Note (PIN) Calculation of the Emission Factor for the Egyptian Unified Electric Grid

Appendix 3-2-2: Method of Calculating monthly PV module temperature

Appendix 3-2-2 Method of Calculating monthly PV module temperature

Monthly PV module temperature is calculated as weighted average temperature of PV module which is weighted by Global solar radiation. Monthly PV module temperature is as shown in the following formula:

$$\mathbf{T}_{CR} = \frac{\left(\mathbf{H}_{1} \times \mathbf{T}_{1} + \mathbf{H}_{2} \times \mathbf{T}_{2} + \dots + \mathbf{H}_{n} \times \mathbf{T}_{n}\right)}{\left(\mathbf{H}_{1} + \mathbf{H}_{2} + \dots + \mathbf{H}_{n}\right)}$$

T_{CR}: Monthly PV module temperature [Deg./month]

H: Global solar radiation (measured data from JICA measurement system) [kW/m2/min.]

T: PV module temperature (measured data from JICA measurement system) [Deg./min.]

Appendix 3-3-1: Method of calculating solar radiation

Appendix 3-3-1 Method of Calculating solar radiation

(1) Basic Idea for Fundamental Approach

- (a) The calculated amount of Total Solar Radiation at the lifted surface of the photovoltaic panels (the panels/modules) will be necessary for calculating the power energy output as the panels are usually installed in a lifted position.
- (b) The amount of Total Solar Radiation at the lifted surface of the panels is total of the following radiation amounts (refer to (2) (b) of this Appendix).
 - Amount of Direct Solar Radiation
 - Amount of Scattered Solar Radiation at the lifted surface of the panels (radiations from air)
 - Amount of Scattered Solar Radiation at the lifted surface of the panels (reflecting radiations from ground surface)
- (c) Although the Solar Radiation data to be used for this study is average of 2007 2010 data of the Global Solar Radiation provided from Egyptian Methodological Authority and the measured Global Solar radiation data (2011-2012) from the installed measurement system by JICA as shown in Table 3-3-2-1, the Global Solar Radiation is necessary to separate to the 2 components, i.e., Direct Solar Radiation and Scattered Solar Radiation. The Formula of Page (Page, J.K. 1964, refer to the (2) (a) of this Appendix) has been adapted for the separation since it has been used from a long time ago with actual achievements.

(2) Calculation of daily average solar radiation at the lifted surface of the panels

(a) Separation of Direct Solar Radiation and Scattered Solar Radiation from Global Solar Radiation (by using Page Formula).

Calculate horizontal Scattered Solar Radiation (Hd) and horizontal Direct Solar Radiation (Hb) from Global Solar Radiation (H) in Table 3-3-2-1, by using the next formula of Page (Page, J.K. 1964).

Formula of separation: (Hd / H) = 1.00 - 1.13 (H / Ho)

Hd: Scattered Solar Radiation of horizontal surface

H: Global Solar Radiation

Ho: Solar Radiation of horizontal surface outside the atmosphere

Here, Ho is derived from the next formula.

FR on Preparatory Survey on the Photovoltaic Power Plant Project in A.R.E

 $Ho = (24/\pi) \cdot Isc \cdot \{1 + 0.033 \cdot \cos\{2\pi(n-2)/365\}\} \cdot (\cos\phi \cdot \cos\delta \cdot \sin\omega s + \omega s \cdot \sin\phi \cdot \sin\delta)$ Isc : solar constants; 1.382kWm⁻²

- *n* : day serial number of setting January 1^{st} as '1' ending in "365" which is December 31^{st} .
- ø : latitude of location (deg.)

 δ : celestial declination (deg.)

 ωs : solar sunset hour angle against the horizon line

 $\omega s = \cos^{-1}(-\tan \phi \tan \delta)$

As for the relational formula of H = Hb + Hd, direct solar radiation Hb is as follows.

Hb = H - Hd

(b) Based on the above, Daily Average Solar Radiation at the lifted surface of the panel (H_{β}) can be calculated by the following formula:



(c) The Calculation of lifted surface conversion coefficient (Rb) with each angles are as shown in the following formula:

 $Rb = \cos\theta / \sinh(\theta)$ (θ : incidence angle of solar radiation incoming into lifted surface, h: height angle of sun)

 $\cos\theta$ is derived from the next formula.

 $\cos \theta = (\sin \delta \sin \phi \cos \beta - \sin \delta \cos \phi \sin \beta \cos \gamma) + (\cos \delta \cos \phi \cos \beta \cos \sigma) + (\cos \delta \sin \phi \sin \beta \cos \gamma \cos \omega) + (\cos \delta \sin \beta \sin \gamma \sin \omega)$ Here, δ is celestial declination (deg.), ϕ : latitude (deg.), ω : hour angle (deg.)

sinh is derived from the next formula.

 $\sinh = \sin \delta \sin \phi + \cos \delta \cos \phi \cos \omega$



 β : lifted angle

horizontal surface

Appendix 3-3-2: Calculation of wind load and seismic load for PV foundation

Appendix 3-3-2 Calculation of wind load and seismic load for PV foundation

1. Wind load for PV foundation

```
Wind Speed (m/s) = 26
```

Air Density (kg/m³) = 1.25

Anala(desusa)	C	Wind Pressure (N/m ²)		
Angle(degrees)	Ue	Egyptian code	Japanese JIS code	
5	0.80	338		
10	0.80	338	1239	
15	0.80	338	1352	
20	0.80	338	1466	
25	0.98	415	1581	
30	1.17	495		
35	1.39	588		
-40	1.60	676		
45	1.60	676		
50	1.60	676		



<u>Wind Pressure Equation from Egyptian Code #201 (General code for loads and forces</u> <u>calculation in civil works and buildings construction)</u>

Pe =
$$C_e \times K_e \times q$$
 (1)
q = 0.5 x p x V² x C_t x C_s (2)

Where:

- P_e = Wind external pressure acting statically on unit area of an external surface of a building
- q = basic wind pressure, relevant to geographical location

 $\mathbf{k}_{\,\mathrm{e}}\text{=}\mathsf{Exposure}$ Coefficient. Changes according to elevation

 C_e = Wind pressure Coefficient, depends on building geometry

V = Wind Speed (36 for Hurghada)

 ρ = Air Density (1.25 Kg/m³)

Ct = Topography Coefficient

 C_s = Construction Coefficient (=1 for buildings of height <60 m)

	Open Exposure	Suburban Exposure	City Centre Exposure	
Elevation (m)	К			
0-10	1	1	1	
10-20	1.15	1	1	
20-30	1.4	1	1	
30-50	1.6	1.05	1	
50-80	1.85	1.3	1	
80-120	2.1	1.5	1.15	
120-160	2.3	1.7	1.36	
160-240	2.5	1.85	1.55	

Surface condition of land surrounding the building	Ct
Slope rate less than 5% for an area with a minimum of 1 Km diameter	1
Surrounding land is relatively un-flat with a	
slope rate equals:	
5-10%	1.2
10-15%	1.4
15-20%	1.6
20-25%	1.8
>25%	1.8
Mountains, hills and similar types	1
Mountains' summits	1.8





Wind Speed:

Wind speed's values can be found in the table below. For regions and areas not covered by this table, the value of the closest location from the locations below should be used. Wind speeds represent gust of 3 seconds at a height of 10 m above ground with a probability of occurrence that does not exceed 2% over a 50 year interval.

Location	Wind Speed (m/s)
Marsa Matrouh/Dab'aa / Zaafarana	42
Saloom	39
Alexandria / Hurghada / Abu Soweir / and other coastal regions	36
Cairo / Assiut / Dakhla / Aswan / Siwa / Luxor	33
Menia / Fayoum / Tanta / Modeereyet El Tahrir / Mansoura	30

2. Seismic load for PV foundation in Egypt

Horizontal seismic load for foundation

K=k×G

where K :Seismic load(N)

k :Horizontal seismic coefficient

G :Total weight of mounting foundation (N)

The Hurghada is located along the Gulf of Suez seismic belt, which is known as one of the active seismic zones in Egypt. According to Seismic Activity Zones, Egypt is divided in terms of seismic impact into five zones. Hurghada is in zone 5a and value of k (Horizontal seismic coefficient) is 0.25g.

Egyptian Building Code Section 8 - Earthquake loads

8.4. Earthquake Actions

8.4.1. Earth Quake Zones

1- Egypt is divided in terms of seismic impact into five zones according to Design Basis Earthquake Ground Motion (DBEGM), or Peak Ground Acceleration (PGA) values are shown in table (8.2). Zones are shown in Figure 8.1

Zone	DBEGM (ag)
Zone 1	0.1 g
Zone 2	0.125 g
Zone 3	0.15 g
Zone 4	0.20 g
Zone 5a	0.25 g
Zone 5b	0.3 g

Table (8.2)	Zones i	n Egypt	in terms	of seismic impact
-------------	---------	---------	----------	-------------------

*Hurghada is in Zone 5a

2- Seismic impact is determined for most of the code applications according to the quantity of the coefficient (ag) which represents the acceleration of the ground motion in a rock layer or hard soil, and is known as "design basis earthquake ground motion", or "Peak Ground Acceleration (PGA)". There are other important coefficients that affect the determination of earthquake load for example, the importance of the building.

3- Refer to the earthquake map in Figure (8.1) which is specified considering that the assumed return time for earth quakes is assumed to be 475 years. $g=9.81 \text{ m/s}^2$.

4- Buildings should be designed taking into account the peak ground acceleration for each zone.



Figure(8.1) Seismic Active Zones

FR on Preparatory Survey on the Photovoltaic Power Plant Project in A.R.E

Type of Module		Poly Crystallize	CIS	Tandem Thin Film
Tilted Angle	Weight of PV Panel and Mounting Structure (kN)	2.466	3.103	3.531
	Seismic Coefficient (k)	0.25	0.25	0.25
25°	Seismic Load (kN)	0.617	0.776	0.883
	Weight of PV Panel and Mounting Structure (kN)	2.447	3.084	3.512
20°	Seismic Coefficient (k)	0.25	0.25	0.25
	Seismic Load (kN)	0.612	0.771	0.878
	Weight of PV Panel and Mounting Structure (kN)	2.426	3.063	3.491
15°	Seismic Coefficient (k)	0.25	0.25	0.25
	Seismic Load (kN)	0.607	0.766	0.873
10°	Weight of PV Panel and Mounting Structure (kN)	2.410	3.047	3.475
	Seismic Coefficient (k)	0.25	0.25	0.25
	Seismic Load (kN)	0.607	0.766	0.873

Table	Calculation	for Seis	mic Load	ls of PV	foundation
rubic	Culculation	IOI DUIL	mile Loue		roundation

K=k×G

where

Κ

:Seismic load(N)

k :Horizontal seismic coefficient

G :Total weight of mounting foundation (N)

Appendix 3-3-3: Calculation of PV foundation

Appendix 3-3-3 Calculation of PV foundation

Туре о	of Module		Poly Cr	ystallize	
Founda	tion Shape	1000 t t			
					m - ·
Tilted	Angle (°)	25	20	15	10
	а	0.25	0.25	0.25	0.25
	h	0.8	0.8	0.8	0.8
Size (m)	В	1.5	1.5 1.5		1.5
	B'	0.4	0.4	0.4	0.4
	t 0.3 0.3 0.3		0.3		
	Uplift	Nil	Nil	Nil	Nil
Result of Study	Compression	1.63 ≧ 1.20	1.94 ≧ 1.20	2.10 ≧ 1.20	2.27 ≧ 1.20
	Overturning	$0.247 \leqq 0.500$	$0.146 \leqq 0.500$	$0.105 \leq 0.500$	0.066 ≦ 0.500
	Sliding	12.65 ≧ 1.20	19.21 ≧ 1.20	25.38 ≧ 1.20	37.78 ≧ 1.20
Concrete Volume	e of One Foundation (m ³)	0.280	0.280	0.280	0.280

Calculation	result o	f Found	dation for	Poly	crystallize
				5	5

Design of the foundaiton for PV





Stability against compression lo	ad Inc.			
wind >	CH CV	-		
	1	1		
ل	Vc			
	Mc B			
Supporting area (A = 1.66?	2 × 0.995 ×	-4	-	6.615 m ²
Compression force (Tw)	÷		÷	2.746 kN
Vertical(GV) = Cw	× cos25°		-	2.489 kN
Horizontal(CH) = Cw	× sin25°		=	1.161 kN
Overturning Morment(Mc)	= CH ×	ĥ	-	1.650 kN • m
	(h= 1.421	m)		
Vertical loads(Vc) = CV	+ WC +	WG	-	11.675 kN
Eccentric distance(e)	= Mc /	Vc	=	0.142 m
α = 1 +	6e / B		e	1.568
Ground reaction(σ cmax)	= a/ x Vc	/(B × B')	÷	30.511 kN/m ²
O Allowable bearing capacity(pa	a) : loose sand		-	50 kN/m ²
◎ Factor of safety(F)= qa	/ J cmax	= 1.63	≧	12 ···[OK]

4)



```
6) Sliding
```

O Horizontal load(Q) = (Uplift or Compression, whichever is greater)	= 1.161 kN
Wind load(TH) = 1.161 kN Uplift = 1.161 kN	Compression
O Passive earth pressure(Pp) = Kp $\times \gamma \times h \times B$	= 14.698 kN
Coefficient of passive earth pressure(Kp) = $\tan^2 (\frac{45^{\circ}}{45^{\circ}} + \phi)$	/ 2) = 2.882 kN
Unit weight(γ) = loose sand	= 17.0 kN/m ³
Embedded length(h) =	= 200 mm
Footing Width(B) =	= 1500 mm
Internal friction angle(ϕ) = 15 + $\sqrt{(20 \times N)}$	= 29 °
◎ Factor of safety(F)= Pp / Q = 12.65	≥ <u>12</u> …[OK]

Design of the foundaiton for PV





	⇒ ,	CH V		-	T	-					
	_	-						1			
		1	vc		ή			ч			
	2.00.00	MC)					-			
4		В					1	Ξ.			
Supporting area (A =	1.662 ×	0.99	5 ×	-4					-	-	6.615 m ²
Compression force (Tw)	1.2								-		2.236 kN
Vertical(CV) =	Cw ×	cos20)°						-		2.102 kN
Horizontal(CH) =	Gw x	sin20	0								0.765 kN
Overturning Morment(Mo	s) =	СН	×	ĥ					i de		1.026 kN•m
	3	(h=	1.34	m)							
Vertical loads(Vc) =	CV +	wc	+	WG							11.269 kN
Eccentric distance(e)	Ŧ	Mc	1	Vc							0.092 m
α = 1	+ 6e	1	в								1.368
Ground reaction(σ cmax) =	æ	× Vc	10	в	×	В'	э	-	2	25.694 kN/m ²
) Allowable bearing capaci	ty(pa) :	loose	sand						-		50 kN/m ²


```
6) Sliding
```

O Horizontal load(Q) = (Uplift or Compression, whichever is greater)	= 0.765 kN
Wind load(TH) = 0.765 kN Uplift = 0.765 kN	Compression
O Passive earth pressure(Pp) = Kp $\times \gamma \times h \times B$	= 14.698 kN
Coefficient of passive earth pressure(Kp) = $\tan^2 (\frac{45^{\circ}}{45^{\circ}} + \phi)$	/ 2) = 2.882 kN
Unit weight(γ) = loose sand	= 17.0 kN/m ³
Embedded length(h) =	= 200 mm
Footing Width(B) =	= 1500 mm
Internal friction angle(ϕ) = 15 + $\sqrt{(20 \times N)}$	= 29 °
© Factor of safety(F) = Pp / Q = 19.21 ₽	≥ <u>12</u> …[ok]





													l.,	oad	sion	pres	nst com	Stability again
						-	-	-			ĨV	C	2#		ind .	W		
				-	1					-	-	2	CH_	-	_			
				4	4			ή			/c	Iv			ĥ		-	
				-						-j	}	Ð	Mc		والعربية			-
							+		_	_		Б		_	_		12	
12	6.615	=							4		×	995	0.9	2 ×	1.6	(=	area (A	Supporting
N	2.236	=												=	W)	• (T)	on force	Compressio
N	2.160	-									y.	15°	cos	×	Cw	-	ŝ	Vertical(CV
N	0.579	=										15°	sin 1	×	Gw		(CH)	Horizontal(
N•m	0.729	-							h	h	×	e.	CH	-	Mc)	ent(g Morm	Overturnin
									n)	3 m	.258	1	(h=					
N	11.306	e l							/G	w	+	0	wo	+	cv	- 10	ads(Vc)	Vertical loa
1	0.065	=							/c	v	1	c	Mc	×		e(e)	distance	Eccentric o
	1.260	=									в		1	6e	1 +	÷		CX
N/m ²	23.743	÷)	e d	в	×	в	10	c /	Ve	×	α		ax)	Tom	action(c	Ground rea
N/m ²	50	-								d	sand	se	loos) :	acity(cap	pearing) Allowable b
	23.743 50 1.2	-	NI.)	r 10	B 2-1	×	B =	15.	a / d	Vo sano	se : nax	a loos o cn	=)a) : /	ax) acity(qa	capa)=	action(c bearing safety(F	Ground rea O Allowable b D Factor of s



```
6) Sliding
```

O Horizontal load(Q) = (Uplift or Compression, whichever is greater)	= 0.579 kN
Wind load(TH) = 0.579 kN Uplift = 0.579 kN	Compression
O Passive earth pressure(Pp) = Kp $\times \gamma \times h \times B$	= 14.698 kN
Coefficient of passive earth pressure(Kp) = $\tan^2 (\frac{45^{*}}{45^{*}} + \phi)$	/ 2) = 2.882 kN
Unit weight(γ) = loose sand	= 17.0 kN/m ³
Embedded length(h) =	= 200 mm
Footing Width(B) =	= 1500 mm
Internal friction angle(ϕ) = 15 + $\sqrt{(20 \times N)}$	= 29 °
◎ Factor of safety(F) = Pp / Q = 25.38	≧ <u>12</u> …[ok]





tability against co	mpre	ssion I	oad	C . 1	120							
	W	ind	>		C.Y		-		-			
		_	(LH _	-					-		
-	-	T		- 1	Vc		Ч			-		
		ما الم ماتينية		-	2	(analysis)		7.		_		
	5			E				1		-*		
Supporting area	(A =	1.60	32 ×	0.99	5 ×	4					=	6.615 m ²
Compression for	rce (T	(w)	=								Ŧ	2.236 kN
Vertical(GV)	-	Cw	×	cos1()°							2.203 kN
Horizontal(CH)	-	Gw	×	sin10	°						=	0.389 kN
Overturning Mo	rment	(Mc)	-	CH	×	h					-	0.457 kN•m
			1	(h=	1.173	m)						
Vertical loads(V	c) =	cv	+	wc	+	WG					-	11.333 kN
Eccentric distar	nce(e)	i.	×	Mc	1	Vc					=	0.041 m
ce	÷	1+	6e	1	в						æ	1.164
Ground reaction	i(σcr	nax)	я	æ	x Vc	10	в	×	В,)	ę	21.987 kN/m ²
			na) :	loose	sand						-	50 kN/m ²



```
6) Sliding
```

O Horizontal load(Q) = (Uplift or Compression, whichever is greater)	= 0.389 kN
Wind load(TH) = 0.389 kN Uplift = 0.389 kN	Compression
O Passive earth pressure(Pp) = Kp $\times \gamma \times h \times B$	= 14.698 kN
Coefficient of passive earth pressure(Kp) = $\tan^2 (\frac{45^{\circ}}{45^{\circ}} + \phi)$	/ 2) = 2.882 kN
Unit weight(γ) = loose sand	= 17.0 kN/m ³
Embedded length(h) =	= 200 mm
Footing Width(B) =	= 1500 mm
Internal friction angle(ϕ) = 15 + $\sqrt{(20 \times N)}$	= 29 °
◎ Factor of safety(F) = Pp / Q = 37.78	≧ <u>12</u> …[ok]

Туре с	of Module	CIS								
Founda	tion Shape	1000 t +			GL ±0					
					<u>ča</u> - ·					
Tilted	Angle (°)	25	20	15	10					
	a	0.25	0.25	0.25	0.25					
	h	0.8	0.8	0.8	0.8					
Size (m)	В	1.5	1.5	1.5	1.5					
	B'	0.4	0.4	0.4	0.4					
	t	0.3	0.3	0.3	0.3					
	Uplift	Nil	Nil	Nil	Nil					
Decult of Chr. 1-	Compression	$1.50 \ge 1.20$	1.78 ≧ 1.20	1.93 ≧ 1.20	2.09 ≧ 1.20					
Result of Study	Overturning	$0.262 \le 0.500$	$0.154 \le 0.500$	0.111 ≦ 0.500	$0.070 \le 0.500$					
	Sliding	11.30 ≧ 1.20	17.15 ≧ 1.20	22.64 ≧ 1.20	33.78 ≧ 1.20					
Concrete Volume	e of One Foundation (m ³)	0.280	0.280	0.280	0.280					

Calculation result of Foundation for CIS

1 CIS type : Tilted angle 25°





7.406 m ² 3.074 kN 2.786 kN
7.406 m ² 3.074 kN 2.786 kN
3.074 kN 2.786 kN
2.786 kN
1.300 kN
1.840 kN•m
12.609 kN
0.146 m
1.584
33.288 kN/m ²
50 kN/m ²



6) Sliding

O Horizontal load(Q) = (Uplift or Compression, whichever is greater)	= 1.300 kN
Wind load(TH) = 1.300 kN Uplift = 1.300 kN	Compression
O Passive earth pressure(Pp) = Kp $\times \gamma \times h \times B$	= 14.698 kN
Coefficient of passive earth pressure(Kp) = $\tan^2 (\frac{45^{\circ}}{45^{\circ}} + \phi)$	/ 2) = 2.882 kN
Unit weight(γ) = loose sand	= 17.0 kN/m ³
Embedded length(h) =	= 200 mm
Footing Width(B) =	= 1500 mm
Internal friction angle(ϕ) = 15 + $\sqrt{(20 \times N)}$	= 29 °
◎ Factor of safety(F) = Pp / Q = 11.30	≥ <u>12</u> …[ok]

1 CIS type : Tilted angle 20°





	ssion ic	bad									
W	ind		2#	C1			_	-			
	~	ς	CH_	-	-	T			-		
-	T					L			Ĩ		
-		_	1	VC	_		4		ч		
	de celeo		Mc	}	(e/				-+		
4	_	_	E		_		-				
(A =	1.25	7 ×	0.98	2 ×	6					=	7.406 m ²
ce (T	w)	=								÷	2.504 kN
a.	Cw	×	cos20	0°						-	2.353 kN
	Cw	×	sin20	°						=	0.857 kN
ment((Mc)	-	CH	×	ĥ						1.145 kN•m
		((h≓	1.336	m)						
c) =	cv	+	wc	+	WG					Ģ	12.157 kN
ice(e)			Mc	1	Vc					-	0.095 m
÷	1 +	6e	1	в						æ	1.380
(σcm	nax)		α	x Vc	10	в	×	В,	Э	ę	27.962 kN/m ²
	acituín	a) :	loose	sand							50 kN/m ²
	(A = (A = = = c) = nce(e) = i(σ cn	Wind (A = 1.25 rce (Tw) = Cw = Cw rment(Mc) c) = CV rce(e) = 1 + i(σ cmax)	$(A = 1.257 \times (A $	$\frac{Wind}{CH} = \frac{CW}{CH}$ $\frac{Wind}{CH} = \frac{Wind}{CH}$ $\frac{Wind}{CH} = \frac{Wind}{CH}$ $\frac{Wind}{CH}$ $$	$Wind \qquad CW \qquad CV \\ CV \\ CH \qquad VC \\ VC \\ MC \\ H \\ H \\ CH \\ H \\ CH \\ CH \\ CH \\$	$\begin{array}{c} Wind \\ \hline \\ & \\ \hline \\ \\ & \\ \hline \\ \\ & \\ \hline \\ \\ \hline \\ \\ & \\ \hline \\ \hline \\ \hline \\ \hline \\ \hline \\ \hline \hline \\ \hline \\ \hline \\ \hline \hline \\ \hline \hline \\ \hline \\ \hline \hline \hline \\ \hline \hline \\ \hline \hline \\ \hline \hline \hline \hline \hline \hline \hline \\ \hline \hline$	$Wind \qquad C \times C$	$Wind \qquad VC \qquad VC \qquad VC \qquad WC \qquad WC \qquad WC \qquad WC \qquad WC$	$\begin{array}{c} \text{Wind} & \text{CV} & \text{CV} \\ & \text{CH} & \text{CV} \\ & \text{C} \\ & \text{C}$	$\frac{\forall ind}{C_{H}} \xrightarrow{C_{V}} \underbrace{\nabla c} \\ \xrightarrow{Vc} \underbrace{Wind}_{C_{H}} \underbrace{\nabla c} \\ \xrightarrow{Vc} \underbrace{Wind}_{C_{H}} \underbrace{\nabla c} \\ \xrightarrow{Vc} \underbrace{Wind}_{C_{H}} \underbrace{Wc}_{C_{H}} \underbrace{Wc}_{C$	$\begin{array}{c} \begin{array}{c} W \\ \hline \hline \hline W \\ \hline \hline \hline \hline$



```
6) Sliding
```

O Horizontal load(Q) = (Uplift or Compression, whichever is greater)	= 0.857 kN
Wind load(TH) = 0.857 kN Uplift = 0.857 kN	Compression
O Passive earth pressure(Pp) = Kp $\times \gamma \times h \times B$	= 14.698 kN
Coefficient of passive earth pressure(Kp) = $\tan^2 (\frac{45^{\circ}}{45^{\circ}} + \phi)$	/ 2) = 2.882 kN
Unit weight(γ) = loose sand	= 17.0 kN/m ³
Embedded length(h) =	= 200 mm
Footing Width(B) =	= 1500 mm
Internal friction angle(ϕ) = 15 + $\sqrt{(20 \times N)}$	= 29 °
◎ Factor of safety(F)= Pp / Q = 17.15	≧ 12 …[ок]

1 CIS type : Tilted angle 15°





ires	sion lo	ad										
Wi				SV.	_	-		-				
-	-	-	ill and a second	-	-				7			
			1	V¢		Π	_		ч			
	ومالي		Mc	}	<u></u>		-		<u> </u>			
•	-	_	В		_	_	-					
8	1.257	7 ×	0.982	×	e	1					8	7.406 m ²
(Tv	v)	=									=	2.504 kN
e,	Cw	×	cos15	°								2.419 kN
	Gw	×	sin15	•							=	0.649 kN
ant()	Mc)	-	СН	×	h						=	0.814 kN-m
		((h≓	1.254	m)							
÷	cv	+	wo	+	WG						•	12.202 kN
(e)		=	Мс	1	Vc							0.067 m
÷	1+	6e	1	в							-	1.268
cm	ax)	ñ.	a x	e Vo	15	в	×	В,	5		÷	25.787 kN/m ²
apa	icity(p	a) :	loose	sand							=	50 kN/m ²
-		T			-		-	1.02		>	-	12[OK]
	win win	<pre>vression lo wind wind and wind and and and and wind and and and and and and and and and a</pre>	wind C wind C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C c C	pression load $\begin{array}{c} \hline W \text{ ind} \\ \hline W \text{ ind} \\ \hline C \# \hline C $	pression load Wind CW CW CW CW CW CW CW CW CW CW	pression load Wind CW CH CW CH CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CV MC CH MC MC CH MC MC CH MC MC CH MC MC CH MC MC CH MC MC CH MC MC CV MC CV MC MC CV MC CV MC CV MC CV MC CV MC CV CC CV MC CV MC CV CC CV CC CV CC CC CC CC C	pression load $\begin{array}{c} \hline Wind \\ \hline Wind \\ \hline Uc \\ \hline Uc \\ \hline Wind \\ \hline Uc \\ \hline Uc \\ \hline Wind \\ \hline Uc \\ \hline W \\ \hline H \hline \hline H \\ \hline H \\ \hline H \\ \hline H \hline \hline H \hline \hline H \\ \hline \hline H \hline \hline H \hline \hline$	pression load $\begin{array}{c} \hline Wind \\ \hline C \# \hline C \#$	pression load $\begin{array}{c} \hline Wind \\ \hline W \\ \hline \hline W \\ \hline W \\ \hline \hline \hline W \\ \hline \hline \hline W \\ \hline \hline \hline \hline$	pression load $\frac{\forall \text{ ind } \qquad C \forall \qquad C \forall \qquad C \forall \qquad C \forall \qquad d \neq $	pression load $\frac{\text{Wind}}{\text{CH}} \xrightarrow{\text{CW}} \text{$	pression load $\begin{array}{c} \hline Wind \\ \hline Wind \\ \hline Wind \\ \hline W \\ \hline W \\ \hline CH \\ \hline W \\ \hline CH \\ \hline W \\ \hline CH \\ \hline W \\ \hline H \\ \hline CH \\ \hline W \\ \hline H \\ \hline H \\ \hline CH \\ \hline H \\ \hline H \\ \hline CH \\ \hline H \\ \hline H \\ \hline CH \\ \hline H \hline \hline H \\ \hline H \\ \hline H \\ \hline H \\ \hline H \hline \hline H \\ \hline H \hline \hline H \hline \hline H \\ \hline H \hline \hline H \hline \hline H \\ \hline \hline H \hline \hline H \hline \hline H \hline \hline $



6) Sliding

O Horizontal load(Q) = (Uplift or Compression, whichever is greater)	= 0.649 kN
Wind load(TH) = 0.649 kN Uplift = 0.649 kN	Compression
O Passive earth pressure(Pp) = Kp $\times \gamma \times h \times B$	= 14.698 kN
Coefficient of passive earth pressure(Kp) = $\tan^2 (\frac{45^{\circ}}{45^{\circ}} + \phi)$	/ 2) = 2.882 kN
Unit weight(γ) = loose sand	= 17.0 kN/m ³
Embedded length(h) =	= 200 mm
Footing Width(B) =	= 1500 mm
Internal friction angle(ϕ) = 15 + $\sqrt{(20 \times N)}$	= 29 °
◎ Factor of safety(F)= Pp / Q = 22.64	≧ <u>12</u> …[OK]

1 CIS type : Tilted angle 10°





mpressio	on load	al L								
Wind	->	-"\\	2.1		-	-	-			
	0	H	-		1			-		
-					Ч					
	1		VC		IL	٦.		ч		
		Mc	¥			1		-		
4		В	_	-	-	•				
(A =	1.257 ×	0.982	×	6					-	7.406 m ²
rce (Tw)	2								Ŧ	2.504 kN
÷	Cw ×	cos10	o						-	2.466 kN
	Gw ×	sin10°	Þ						=	0.435 kN
rment(Mo	c) =	СН	×	h					-	0.510 kN•m
	(lh=	1.171	m)						
c) =	CV +	wo	+	WG					Ģ	12.233 kN
ice(e)	Ŧ	Mc	1	Vc						0.042 m
= 1	+ 6e	1	в						=	1.168
(σcmax) =	a ×	Vc	10	в	×	В,)	÷	23.814 kN/m ²
	tu(na) :	loose	sand						-	50 kN/m ²
	<pre>wind Wind (A = (A = rce (Tw)) = = crment(Mo c) = nce(e) = 1 s(0 cmax</pre>	$\frac{\text{Wind}}{(A = 1.257 \times \text{rce}(\text{TW}) = 0}$ $= CW \times \text{rment}(\text{Mc}) = 0$ $= CV + 1$ $= 1 + 6e$ $= 1 + 6e$	$\frac{Wind}{CH} = \frac{CW}{CH}$ $\frac{Wind}{CH} = \frac{CW}{CH}$ $\frac{Wind}{CH} = \frac{Wind}{CH}$ $\frac{Wind}{CH}$ Wi	$\frac{Wind}{CH} = \frac{C}{C} + $	$\frac{Wind}{CH} = \frac{C}{CV} + \frac{Vc}{CH} + V$	$\frac{Wind}{CH} = \frac{C}{C} \frac{Vc}{H} + \frac{Vc}{H} $	$\frac{Wind}{CH} \xrightarrow{VC} CV$ $\frac{VC}{H} \xrightarrow{VC} CV$ $\frac{VC}{H} \xrightarrow{VC} CH$ $\frac{VC}{H} \xrightarrow{VC} CV$ $\frac{VC}{H} \xrightarrow{VC} CV$ $\frac{VC}{H} \xrightarrow{VC} CV$ $\frac{VC}{H} \xrightarrow{VC} CH$	$\frac{Wind}{CH} \xrightarrow{CW} \xrightarrow{CV} \xrightarrow{CV} \xrightarrow{VC} \xrightarrow{VC} \xrightarrow{Wind} \xrightarrow{VC} \xrightarrow{Wind} \xrightarrow{VC} \xrightarrow{VC} \xrightarrow{VC} \xrightarrow{VC} \xrightarrow{Wind} \xrightarrow{VC} VC$	$\frac{Wind}{CH} \xrightarrow{CW} \xrightarrow{CW} \xrightarrow{CV} \xrightarrow{C} \xrightarrow{W} \xrightarrow{C} \xrightarrow{C} \xrightarrow{W} \xrightarrow{W} \xrightarrow{C} \xrightarrow{C} \xrightarrow{W} \xrightarrow{C} \xrightarrow{C} \xrightarrow{C} \xrightarrow{C} \xrightarrow{C} \xrightarrow{C} \xrightarrow{C} C$	$\begin{array}{rcl} \text{mpression load} \\ \hline & & & & \\ \hline \hline & & \\ \hline & & \\ \hline & & \\ \hline & & \\ \hline \hline & & \\ \hline \hline & & \\ \hline \hline & & \\ \hline \hline & & \\ \hline \hline \hline & & \\ \hline \hline \hline & & \\ \hline \hline \hline \\ \hline \hline \hline \hline$



```
6) Sliding
```

O Horizontal load(Q) = (Uplift or Compression, whichever is greater)	= 0.435 kN
Wind load(TH) = 0.435 kN Uplift = 0.435 kN	Compression
O Passive earth pressure(Pp) = Kp $\times \gamma \times h \times B$	= 14.698 kN
Coefficient of passive earth pressure(Kp) = $\tan^2 \left(\frac{45^{\circ}}{45^{\circ}} + \phi \right)$	/ 2) = 2.882 kN
Unit weight(γ) = loose sand	= 17.0 kN/m ³
Embedded length(h) =	= 200 mm
Footing Width(B) =	= 1500 mm
Internal friction angle(ϕ) = 15 + $\sqrt{(20 \times N)}$	= 29 °
◎ Factor of safety(F) = Pp / Q = 33.78	≧ <u>12</u> …[OK]

Туре с	of Module]	Multi layer Tar	dem Thin Filn	ı
Founda	tion Shape	1000 t			GL ±0
					m
Tilted	Angle (°)	25	20	15	10
	a	0.25	0.25	0.25	0.25
	h	0.8	0.8	0.8	0.8
Size (m)	В	1.5	1.5	1.5	1.5
	B′	0.4	0.4	0.4	0.4
	t	0.3	0.3	0.3	0.3
	Uplift	Nil	Nil	Nil	Nil
Result of Study	Compression	1.36 ≧ 1.20	1.64 ≧ 1.20	1.79 ≧ 1.20	1.95 ≧ 1.20
	Overturning	$0.300 \le 0.500$	$0.175 \leq 0.500$	$0.126 \leq 0.500$	$0.080 \le 0.500$
	Sliding	9.89 ≧ 1.20	15.01 ≧ 1.20	19.83 ≧ 1.20	29.57 ≧ 1.20
Concrete Volume	e of One Foundation (m ³)	0.280	0.280	0.280	0.280

Calculation result of Foundation for Multi Layer Tandem Thin Film

1 Tandem thin film type : Tilted angle 25°



Design of the foundaiton for PV 1 Tandem thin film type : Tilted angle 25° 1) Dead load (PV panels & mounting steel structures) 8.462 m² Supporting area (A) 1_402 × 1.006 × 3.531 kN Weight for one foundation (WG) = 2) Foundation weight Size of post part Width (a) 250 mm Height(h) 800 mm Size of footing part Long side (B) 1500 mm 400 mm Height(t) 300 mm Short side(B' = Foundation weight(WC) $= (a^2 \times H \times 2 + B \times B' \times t)$ 6.720 kN xr Unit weight of reinforced concrete (γ) 24.0 kN/m



	\Rightarrow	r	- V		-	T	-					
	_	-	-	-					-			
	5		b	ГC		Ч			-			
			The second	}		1 L	7		-			
			B	, 					-			
Supporting area (A =	1.402	×	1.006	×	6	i.					8.462 m ²	
Compression force (Tw	ŋ	=								÷	3.512 kN	
Vertical(GV) =	Cw	×	cos25	0							3.183 kN	
Horizontal(CH) =	Cw	×	sin25°							=	1.485 kN	
Overturning Morment(M	Ac)	=	СН	×	h					=	2.117 kN•m	
		(h=	1.425	m)							
Vertical loads(Vc) =	cv	+	wc	+	WG					-	13.434 kN	
Eccentric distance(e)			Мс	1	Vc						0.158 m	
<i>ce</i> =	1 +	6e	1	в						=	1.632	
Ground reaction(σ cma	ex)	a,	a ×	Vc	10	в	×	В,	Э	÷	36.541 kN/m ²	ł
O Allowable bearing capa	city(pa	ð :	loose	sand						=	50 kN/m ²	i



```
6) Sliding
```

O Horizontal load(Q) = (Uplift or Compression, whichever is greater)	= 1.485 kN
Wind load(TH) = 1.485 kN Uplift = 1.485 kN	Compression
O Passive earth pressure(Pp) = Kp $\times \gamma \times h \times B$	= 14.698 kN
Coefficient of passive earth pressure(Kp) = $\tan^2 (\frac{45^*}{45^*} + \phi)$	/ 2) = 2.882 kN
Unit weight(γ) = loose sand	= 17.0 kN/m ³
Embedded length(h) =	= 200 mm
Footing Width(B) =	= 1500 mm
Internal friction angle(ϕ) = 15 + $\sqrt{(20 \times N)}$	= 29 °
◎ Factor of safety(F)= Pp / Q = 9.89	≥ <u>12</u> …[ok]







	⇒ ,	TH Y	-	-	T	-				
	-	-						1		
		Iv	°c		h.			ч		
	2	The second	·	(i)		7.				
		B	-			1		-		
Supporting area (A =	.402 ×	1.006	×	6					-	8.462 m ²
Compression force (Tw)	-								÷	2.861 kN
Vertical(CV) = 0	Cw ×	cos20°	6							2.689 kN
Horizontal(CH) = (Ow ×	sin20°							=	0.979 kN
Overturning Morment(Mo	;) =	СН	×	ĥ					-	1.316 kN-m
	((h≓ 1	.344	m)						
Vertical loads(Vc) =	OV +	wc	+	WG					÷	12.921 kN
Eccentric distance(e)	=	Mc	1	Vc.					=	0.102 m
α = 1	+ 6e	1	в						æ	1.408
Ground reaction(σ cmax) =	α×	Vc	10	в	×	В,)	÷	30.322 kN/m ²
O Allowable bearing capacit	ty(pa) :	loose	sand						=	50 kN/m ²



```
6) Sliding
```

O Horizontal load(Q) = (Uplift or Compression, whichever is greater)	= 0.979 kN
Wind load(TH) = 0.979 kN Uplift = 0.979 kN	Compression
O Passive earth pressure(Pp) = Kp $\times \gamma \times h \times B$	= 14.698 kN
Coefficient of passive earth pressure(Kp) = $\tan^2 (\frac{45^{\circ}}{45^{\circ}} + \phi)$	/ 2) = 2.882 kN
Unit weight(γ) = loose sand	= 17.0 kN/m ³
Embedded length(h) =	= 200 mm
Footing Width(B) =	= 1500 mm
Internal friction angle(ϕ) = 15 + $\sqrt{(20 \times N)}$	= 29 °
	≧ <u>12</u> …[OK]
Design of the foundaiton for PV



1) Dead load (PV panels & mounting steel structures)





Stability against compression lo	ad I a			
Wind	CW CV			
	CH_		-	
	hte	Н	-	
6-	B		-*	
Supporting area (A = 1.40	2 × 1.006 ×	6		8.462 m ²
Compression force (Tw)	2		-	2.861 KN
Vertical(CV) = Cw	× cos15°			2.764 kN
Horizontal(CH) = Cw	× sin15°		0.5	0.741 KN
Overturning Morment(Mc)	= CH ×	ĥ	-	0.934 kN-m
	(h= 1.26	m)		
Vertical loads(Vc) = CV	+ WC +	WG	ę	12.975 kN
Eccentric distance(e)	= Mc /	Vc	-	0.072 m
α = 1 +	6e / B		-	1.288
Ground reaction(σcmax)	= a × Vo	/(B × B) =	27.853 kN/m ²
O Allowable bearing capacity(p	a) : loose sand	i	-	50 kN/m ²
◎ Factor of safety(F)= qa	/ Ocmax	= 1.7	9 ≧	12 ···[OK]



```
6) Sliding
```

O Horizontal load(Q) = (Uplift or Compression, whichever is greater)	= 0.741 kN
Wind load(TH) = 0.741 kN Uplift = 0.741 kN	Compression
O Passive earth pressure(Pp) = Kp $\times \gamma \times h \times B$	= 14.698 kN
Coefficient of passive earth pressure(Kp) = tan ⁻² (45° + ϕ	/ 2) = 2.882 kN
Unit weight(γ) = loose sand	= 17.0 kN/m ³
Embedded length(h) =	= 200 mm
Footing Width(B) =	= 1500 mm
Internal friction angle(ϕ) = 15 + $\sqrt{(20 \times N)}$	= 29 °
◎ Factor of safety(F) = Pp / Q = 19.83	≧ <u>12</u> …[OK]

Design of the foundaiton for PV

1 Tandem thin film type : Tilted angle 10°

1) Dead load (PV panels & mounting steel structures)





Stability against compression lo	bad			
wind >		-	-	
-			1	
	V¢		-	
	B	•	-*	
Supporting area (A = 1.40	2 × 1.006 ×	6	-	8.462 m ²
Compression force (Tw)	=		æ.	2.861 KN
Vertical(CV) = Cw	× cos10°		÷.	2.818 kN
Horizontal(CH) = Cw	× sin10°			0.497 kN
Overturning Morment(Mc)	= CH ×	h	14	0.584 kN•m
	(h= 1.175	5 m)		
Vertical loads(Vc) = CV	+ WC +	WG	e	13,013 kN
Eccentric distance(e)	= Mc /	Vc	=	0.045 m
α = 1 +	6e / B		-	1.180
Ground reaction(σ cmax)	$= \alpha \times V \alpha$	s /(B ×	B') =	25.593 kN/m ²
O Allowable bearing capacity(p	a) : loose sand	d	.=	50 kN/m ²
③ Factor of safety(F) = qa	/ J cmax		1.95 ≧	12 ···[OK]

4)



```
6) Sliding
```

O Horizontal load(Q) = (Uplift or Compression, whichever is greater)	= 0.497 kN
Wind load(TH) = 0.497 kN Uplift = 0.497 kN	Compression
O Passive earth pressure(Pp) = Kp $\times \gamma \times h \times B$	= 14.698 kN
Coefficient of passive earth pressure(Kp) = $\tan^2 (\frac{45^{\circ}}{45^{\circ}} + \phi)$	/ 2) = 2.882 kN
Unit weight(γ) = loose sand	= 17.0 kN/m ³
Embedded length(h) =	= 200 mm
Footing Width(B) =	= 1500 mm
Internal friction angle(ϕ) = 15 + $\sqrt{(20 \times N)}$	= 29 °
◎ Factor of safety(F)= Pp / Q = 29.57	≥ <u>12</u> …[ok]

Appendix 3-4-1: Cost breakdowns for Poly Crystalline, MLTF and CIS

Appendix 3-4-1 Cost breakdowns for Poly Crystalline, MLTF and CIS

The following cost breakdown is attached here for reference.

- ✓ Poly Crystalline
- ✓ MLTF
- ✓ CIS

*For MLTF, refer to Appendix 3-5-1 "Cost Breakdown for the Project".

Cost breakdown for the Project (Poly Crystalline)

No. Itame to be requested	Nos. of	CIF to I	Port Saied	ost (Thousand do Inland	ollar) Site Works (Installation		Notes
no. nells to be requested	Required	unit (Foreign	amount Currency)	Transportation (Local (replacement etc.)	Total	ivotes
1 Construction of 20MW PV Power Plant including necessary		(Foreign	44,751.9	451.9	16,896.1	62,100.0	62,100.0
1) PV module							
1-1 PV Module (Poly-Crystalline)	LS		32,648.0	84.5	3,487.1	36,219.6	
1-2 Terminal Box	LS		728.0	2.0	105.3	835.3	
1-3 DC cable	LS		1,564.8	35.8	397.7 8 840 4	9 773 4	
Sub-Total			35,836.8	159.3	12,830.5	48,826.6	
2) Inverter					,	-,	
2-1 Inverter	LS		3,600.0	3.4	363.6	3,967.0	
2-2 Step-up Transformer	LS		260.0	1.7	3.7	265.4	
2-3 LV, MV switchgear	LS		300.0	6.7	17.9	324.6	
2-4 LV/MV cable for inverter 2-5 Monitoring System terminal unit	0		5.0	0.0	17.1	22.1	
Sub-Total			4,252.0	11.8	439.9	4,703.7	
3) MV switchgear	•						
3-1 Switchgear Box	LS		320.0	0.8	36.3	357.1	
3-2 Monitoring System terminal unit	LS		4.5	0.0	8.9	13.4	
Sub-Total 4) Distribution line connection			324.5	0.8	45.2	370.5	
4-1 Feeder Box	LS	[80.0	0.8	1.2	82.0	
4-2 Monitoring System terminal unit	LS		1.0	0.0	0.9	1.9	
Sub-Total			81.0	0.8	2.1	83.9	
5) Monitoring System							
5-1 Monitoring System	LS		281.5	0.0	10.1	291.6	
6) Internal cable connection	l		281.5	0.0	10.1	291.6	I
6-1 MV Cable Connection	LS		1,320.0	5.5	278.1	1,603.6	
6-2 LV Cable Connection	LS		600.0	0.5	105.3	705.8	
6-3 Optic fiber cable connection	LS		176.0	0.5	48.7	225.2	
Sub-Total			2,096.0	6.6	432.1	2,534.7	
7) Grounding system	16		200.0	0.5	27.2	227.9	
Sub-Total	1.5		200.0	0.5	37.3	237.8	
8) Civil works							
8-1 PV and transformer foundation	LS		0.0	262.1	2,071.1	2,333.2	
8-2 land leveling	LS		0.0	0.0	111.8	111.8	
8-3 road and drain work	LS		0.0	0.0	152.2	152.2	
Sub-1otal 9) House construction			0.0	262.1	2,335.1	2,597.2	
9-1 Inverter house construction	LS		0.0	2.5	252.0	254.5	
9-2 MV Switchgear house construction	LS		0.0	2.5	248.0	250.5	
Sub-Total			0.0	5.0	500.0	505.0	
10) Guard Fence							
10-1 Guard Fence	LS		0.0	1.9	190.8	192.7	
Sub-Total 11) Information Center			0.0	1.9	190.8	192.7	
11-1 Exhibition System	LS		300.0	3.0	0.0	303.0	
11-2 Construction of house	LS		0.0	0.0	70.0	70.0	
Sub-Total			300.0	3.0	70.0	373.0	
12) Central Hurghada Substation Modifications	.						
12-1 Central Hurghada S/S modifications	LS		20.0	0.2	3.0	23.2	
13) Training to Owner's engineers			20.0	0.2	3.0	23.2	
13-1 Training	LS	[70.0			70.0	
Sub-Total			70.0			70.0	
14) Maintenance contract for PV power plant							
14-1 Maintenance Contract Cost for 2 years	LS		861.4			861.4	1% of the above 1) -/ Jper year * 2 years
Sub-Total 15) Spare parts			861.4			861.4	
15-1 Spare parts for PV, Inverter, etc.	LS		428.7			428.7	1% of above 1)-6)
Sub-Total			428.7			428.7	
2 Installation of 2MW High Performance Battery including			11,220.8	29.3	645.6	11,895.7	11.895.7
necessary equipment			,			,	,
1-1 High Performance Battery	IS		9.086.0	24.7	162.6	9.273.3	
1-2 Power conditioning system for battery	LS		1,600.0	0.7	91.3	1,692.0	
1-3 MV Switchgear for Battery	LS		80.0	0.2	4.0	84.2	
1-4 MV Cable Connection	LS		60.0	0.2	23.7	83.9	
1-5 Room for Battery and PCS	LS		0.0	3.6	364.0	367.6	
Sub-Total			10,826.0	29.3	645.6	11,500.9	
2) Training to Owner's engineers	10		=~ -			=^ · ·	
2-1 Iraning Sub-Total	LS		70.0			70.0	
3) Maintenance contract for Battery System	I	l	70.0			70.0	<u> </u>
3-1 Maintenance Contract Cost for 2 years	LS		216.5			216.5	1% of the above 1) per year * 2 years
Sub-Total			216.5			216.5	
4) Spare parts							
13-1 Spare parts for Battery,PCS, etc.	LS		108.3			108.3	1% of above 1)
Sub-Total			108.3			108.3	
3 Dispute Board for 3 persons			963.0	0.0	0.0	963.0	
Total			56,935.7	481.2	17,541.7	74,958.6	74,958.6

JICA

Appendix 3-4-1-2

	1	No.	Item	Specification	Unit Price (US\$)	Unit Price (EGP)	Total Quantity	units	Total Price (US\$)	Total Price (EGP)	Remarks
		1	PV module (Poly-Crystalline) 1MW	240W (1.6\$/W)	385	2,330	84,800		32,648,000	197,584,000	
		2	Terminal Box		1,300	7,840	560)	728,000	4,390,400	
	PV module	3	From PV module to Terminal box		2	20	782,400	m	1,564,800	15,648,000	
		4	DC cable connection From Terminal box to Inverter		8	50	112,000	m	896,000	5,600,000	
		5	Frame for PV		2,000.0	12,060	2,786	t	5,572,000	33,599,160	
		6 7	Sub Total (1+2+3+4+5) Inverter	500kVA					41,408,800	256,821,560	
		8	Step-up Transformer	400V/22kV	90,000	542,700	40		3,600,000	21,708,000	
		9	LV Switchboard	2000kVA 400V	26,000	156,780	10		260,000	1,567,800	
		10	MV Switchgear	22kV	10,000	60,300	10		100,000	603,000	·
	Inverter	11	I.V. cable Connection		20,000	120,600	10		200,000	1,206,000	
	liverter	12	From Inverter to LV Switchboard		50	310	1,200	m	60,000	372,000	
		12	From LV Switchboard to Step-up transformer		50	310	180	m	9,000	55,800	
		13	From Step-up transformer to MV Switchgear		100	610	180	m	18,000	109,800	
		14	Monitoring system terminal unit		500	3,020	10		5,000	30,200	
		15 16	Sub Total (7+8+9+10+11+12+13+14) Feeder box						4,252,000	25,652,600	
		17	VT Box		40,000	241,200	6		240,000	1,447,200	
	MV Switchgear	18	Bus coupler Box		20,000	120,600	2		40,000	241,200	
	_	19	Monitoring system terminal unit		40,000	241,200	1		40,000	241,200	
		20	Sub Total (16+17+18+19)		500	3,020	9		4,500	27,180	
		20	Feeder Box (Extension)		40.000	241 200			52 4, 500	482.400	
	Distribution line connection	22	Monitoring system terminal unit		40,000	241,200			1,000	482,400	
		23	Sub Total (21+22)		500	3,020	2		1,000 81,000	6,040 488,440	
		24	M/M computer system		80,000	482,400	1		80,000	482,400	
1.PV	Monitoring	25	server system		200,000	1,206,000	1		200,000	1,206,000	
	System	26	Communication interface		1,000	6,030	1		1,000	6,030	
		27	UPS		500	3.020	1		500	3.020	
		28	Sub Total (24+25+26+27) MV Cable Connection			0,020	-		281,500	1,697,450	
		20	MV cube connection from unit substation to 22kV bus unit		100	610	13,200	m	1,320,000	8,052,000	
	Internal cable connection	29	to Hurghada Wind Distribution Point		100	610	6,000	m	600,000	3,660,000	
		30			20	130	8,800	m	176,000	1,144,000	
	Grounding	31 32	Sub Total (28+29+30) Grounding conductor						2,096,000	12,856,000	
	system	33	Sub Total (32)		20	130	10,000	m	200,000 200,000	1,300,000 1,300,000	
		34	PV foundation		335	2,030	6,182		2,071,104	12,550,272	27730 x 0.28m3
	Civil works	35	Ground leveling		3	20	33,880	m3	111,804	677,600	
		36	road construction		2	20	63.420	m	152.208	1,268,400	
		37	Sub Total (34+35+36) Inverter house						2,335,116	14,496,272	
	Inverter house	20	Interior work		350	2,120	360	m2	126,000	763,200	36m2 / 1room x 10 rooms
	construction		Cali Tatal (29.120)		350	2,120	360	m2	126,000	763,200	
		40	MV switch gear house						252,000	1,526,400	
	MV switch gear house	42	Interior work		400	2,420	310		124,000	750,200	
		43	Sub Total (41+42)		400	2,420	310		124,000 248,000	750,200 1,500,400	
	Guard Fence	44	Guard Fence		58	350	3,290	m	190,820	1,151,500	
	WOIK	45 46	Sub Total (44) Exhibition System						190,820	1,151,500	
	T () (47	Construction of house		300,000	1,809,000	1	LS	300,000	1,809,000	
	Center	48	Interior work		350	2,120	100	m2	35,000	212,000	
		10	Sub Total (46+47+48)		350	2,120	100	m2	35,000	212,000	
	Central Hurghada	50	S/S modifications		20.000	120.000			20,000	120 (00	
	S/S modifications	51	Sub Total	1.0001147	20,000	120,600	1	LS	20,000 20,000	120,600 120,600	
		1	riign Pertormance Battery	1,000kW	4,543,000	27,394,290	2	unit	9,086,000	54,788,580	
		2	rower conditioning system(PCS) for Battery	500KW	400,000	2,412,000	4	unit	1,600,000	9,648,000	
	High	3	MV Switchgear		40,000	241,200	2	unit	80,000	482,400	
2.Battery	Performance Battery	4	MV Cable connection		100	610	600	m	60,000	366,000	
	-	5	Room for battery and PCS		350	2.120	520	m2	182.000	1,102.400	
		6	Room Interior work including air conditioner		350	2 120	520	m?	182 000	1.102.400	
		7	Sub Total (1+2+3+4+5+6) Dispute Board			2,120	520		11,190,000	67,489,780	
3. DB	Dispute Board	2	Sub Total		963,000	5,806,890	1	LS	963,000	5,806,890	
		. 4							CAN ANNI	0,000,020	

JICA

Appendix 3-4-1-3

Cost breakdown for the Project (CIS)

	Nos. of	CIF to 1	Co Port Saied	ost (Thousand do	ollar) Site Works (Installation		
No. Items to be requested	Required	unit	amount	Transportation	replacement etc.)	Total	Notes
		(Foreign	Currency)	(Local G	Currency)		
equipment			35,434.3	452.1	17,206.8	53,093.1	53,093.1
1) PV module							
1-1 PV Module (CIS)	LS		23,601.6	84.5	3,487.1	27,173.2	
1-2 Terminal Box	LS		728.0	2.0	105.3	835.3	
1-3 DC cable	LS		1,564.8	35.8	397.7	1,998.3	
1-4 Frame for PV	LS		896.0	37.0	8,840.4	9,773.4	
Sub-Total			26,790.4	159.3	12,830.5	39,780.2	
2) Inverter							
2-1 Inverter	LS		3,600.0	3.4	363.6	3,967.0	
2-2 Step-up Transformer	LS		260.0	1.7	3.7	265.4	
2-3 LV, MV switchgear	LS		300.0	6.7	17.9	324.6	
2-4 LV,MV cable for inverter			87.0	0.0	37.6	124.6	
2-5 Monitoring System terminal unit	0		5.0	11.0	17.1	4 702 7	
Sub-Total			4,252.0	11.8	439.9	4,703.7	
3.1 Switchgear Boy	IS		320.0	0.8	36.3	357.1	
3-2 Monitoring System terminal unit	IS		4 5	0.0	8.9	13.4	
Sub-Total			324.5	0.0	45.2	370.5	
4) Distribution line connection			524.5	0.0	40.2	570.5	
4-1 Feeder Box	IS		80.0	0.8	12	82.0	
4-2 Monitoring System terminal unit	IS		1.0	0.0	0.9	1.9	
Sub-Total			81.0	0.8	2.1	83.9	
5) Monitoring System	I	l	51.0	0.0			I
5-1 Monitoring System	LS		281.5	0.0	10.1	291.6	
Sub-Total		L	281.5	0.0	10.1	291.6	
6) Internal cable connection	1	l					1
6-1 MV Cable Connection	LS		1,320.0	5.5	278.1	1,603.6	
6-2 LV Cable Connection	LS		600.0	0.5	105.3	705.8	
6-3 Optic fiber cable connection	LS		176.0	0.5	48.7	225.2	
Sub-Total	1		2,096.0	6.6	432.1	2,534.7	
7) Grounding system							
7-1 Grounding conductor	LS		200.0	0.5	37.3	237.8	
Sub-Total			200.0	0.5	37.3	237.8	
8) Civil works							
8-1 PV and transformer foundation	LS		0.0	262.1	2,363.8	2,625.8	
8-2 land leveling	LS		0.0	0.0	111.8	111.8	
8-3 road and drain work	LS		0.0	0.0	152.2	152.2	
Sub-Total			0.0	262.1	2,627.8	2,889.9	
9) House construction			11				
9-1 Inverter house construction	LS		0.0	2.5	252.0	254.5	
9-2 MV Switchgear house construction	LS		0.0	2.5	248.0	250.5	
Sub-Total			0.0	5.0	500.0	505.0	
10) Guard Fence							•
10-1 Guard Fence	LS		0.0	2.1	208.8	210.9	
Sub-Total			0.0	2.1	208.8	210.9	
11) Information Center							
11-1 Exhibition System	LS		300.0	3.0	0.0	303.0	
11-2 Construction of house	LS		0.0	0.0	70.0	70.0	
Sub-Total			300.0	3.0	70.0	373.0	
12) Central Hurghada Substation Modifications							
12-1 Central Hurghada S/S modifications	LS		20.0	0.2	3.0	23.2	
Sub-Total			20.0	0.2	3.0	23.2	
13) Training to Owner's engineers							
13-1 Training	LS		70.0			70.0	
Sub-Total			70.0			70.0	
14) Maintenance contract for PV power plant	1						1% of the above 1) -7)mor upon 12
14-1 Maintenance Contract Cost for 2 years	LS		680.6			680.6	years
Sub-Total			680.6			680.6	
15) Spare parts							
15-1 Spare parts for PV, Inverter, etc.	LS		338.3			338.3	1 % of above 1)-6)
Sub-Lotal			338.3			338.3	
2 Installation of 2MW High Performance Battery including necessary equipment			11,220.8	29.3	645.6	11,895.7	11,895.7
1) High Performance Battery							
1-1 High Performance Battery	IS		9.086.0	24 7	162.6	9 273 3	
1-2 Power conditioning system for hattery	19		1 600 0	0.7	Q1 2	1 602 0	
1-3 MV Switcheear for Battery			1,000.0	0.7	91.3	1,072.0 	
1-4 MV Cable Connection	ΤC		811.17			04.2	1
1-TIM Cubic Connection	LS		60.0	0.2	4.0	82.0	
1-5 Room for Battery and PCC	LS LS		60.0	0.2	23.7	83.9	
1-5 Room for Battery and PCS	LS LS LS		60.0 0.0	0.2	23.7 364.0	83.9 367.6	
1-5 Room for Battery and PCS Sub-Total	LS LS LS		60.0 0.0 10,826.0	0.2 0.2 3.6 29.3	23.7 364.0 645.6	83.9 367.6 11,500.9	
1-5 Room for Battery and PCS Sub-Total 2) Training to Owner's engineers			80.0 60.0 0.0 10,826.0	0.2 0.2 3.6 29.3	4.0 23.7 364.0 645.6	83.9 367.6 11,500.9	
1-5 Room for Battery and PCS Sub-Total 2) Training to Owner's engineers 2-1 Training	LS LS LS LS		80.0 60.0 0.0 10,826.0 70.0	0.2 0.2 3.6 29.3	4.0 23.7 364.0 645.6	83.9 367.6 11,500.9 70.0	
1-5 Room for Battery and PCS Sub-Total 2) Training to Owner's engineers 2-1 Training Sub-Total	LS LS LS LS		80.0 60.0 0.0 10,826.0 70.0 70.0	0.2 0.2 3.6 29.3	4.0 23.7 364.0 645.6	83.9 367.6 11,500.9 70.0 70.0	
1-5 Room for Battery and PCS Sub-Total 2) 2) Training to Owner's engineers 2-1 Training Sub-Total 3) Maintenance contract for Battery System	LS LS LS LS		80.0 60.0 10,826.0 70.0 70.0	0.2 0.2 3.6 29.3	4.0 23.7 364.0 645.6	83.9 367.6 11,500.9 70.0 70.0	1% of the above 11 ner year * 2
1-5 Room for Battery and PCS Sub-Total 2) 2) Training to Owner's engineers 2-1 2-1 Training Sub-Total 3) 3) Maintenance contract for Battery System 3-1 Maintenance Contract Cost for 2 years	LS LS LS LS LS		80.0 60.0 10,826.0 70.0 70.0 216.5	0.2 0.2 3.6 29.3	4.0 23.7 364.0 645.6	83.9 367.6 11,500.9 70.0 70.0 216.5	1% of the above 1) per year * 2 years
1-5 Room for Battery and PCS Sub-Total 2) 2) Training to Owner's engineers 2-1 2-1 Training Sub-Total 3) 3) Maintenance contract for Battery System 3-1 Maintenance Contract Cost for 2 years Sub-Total	IS IS IS		80.0 60.0 10.826.0 70.0 70.0 216.5 216.5	0.2 0.2 3.6 29.3	4.0 23.7 364.0 645.6	83.9 367.6 11,500.9 70.0 70.0 216.5 216.5	1% of the above 1) per year*2 years
1-5 Room for Battery and PCS Sub-Total 2) 2) Training to Owner's engineers 2-1 2-1 Training Sub-Total 3) 3) Maintenance contract for Battery System 3-1 Maintenance Contract Cost for 2 years Sub-Total 4) 4) Spare parts	IS IS IS		80.0 60.0 10,826.0 70.0 70.0 216.5 216.5	0.2 0.2 3.6 29.3	4.0 23.7 364.0 645.6	83.9 367.6 11,500.9 70.0 70.0 216.5 216.5	1% of the above 1) per year * 2 years
1-5 Room for Battery and PCS Sub-Total 2) Training to Owner's engineers 2-1 Training Sub-Total 3) Maintenance contract for Battery System 3-1 Maintenance Contract Cost for 2 years Sub-Total 4) Spare parts 13-1 Spare parts for Battery,PCS, etc.	1.5 1.5 1.5 1.5 1.5 1.5 1.5 1.5		80.0 60.0 10,826.0 70.0 70.0 216.5 216.5 216.5	0.2 0.2 3.6 29.3	4.0 23.7 364.0 645.6	83.9 367.6 11,500.9 70.0 70.0 216.5 216.5 108.3	1% of the above 1) per year * 2 years 1% of above 1)
1-5 Room for Battery and PCS Sub-Total 2) 2) Training to Owner's engineers 2-1 Training Sub-Total 3) 3) Maintenance contract for Battery System 3-1 Maintenance Contract Cost for 2 years Sub-Total 4) 4) Spare parts 13-1 Spare parts for Battery, PCS, etc. Sub-Total	1.5 1.5 1.5 1.5 1.5 1.5 1.5 1.5		80.0 60.0 0.0 10,826.0 70.0 70.0 216.5 216.5 216.5 108.3	0.2 0.2 3.6 29.3	4.0 23.7 364.0 645.6	83.9 367.6 11,500.9 70.0 70.0 216.5 216.5 216.5 108.3 108.3	1% of the above 1) per year *2 years 1% of above 1)
1-5 Room for Battery and PCS Sub-Total 2) 2) Training to Owner's engineers 2-1 Training Sub-Total 3) 3) Maintenance contract for Battery System 3-1 Maintenance Contract Cost for 2 years Sub-Total 4) 4) Spare parts 13-1 Spare parts for Battery,PCS, etc. Sub-Total 3 Dispute Board for 3 persons	1.5 1.5 1.5 1.5 1.5 1.5		80.0 60.0 0.0 10,826.0 70.0 70.0 70.0 216.5 216.5 216.5 216.5 963.0	0.2 0.2 3.6 29.3 0.0	4.0 23.7 364.0 645.6	83.9 367.6 11,500.9 70.0 70.0 216.5 216.5 216.5 108.3 108.3 963.0	1% of the above 1) per year * 2 years 1% of above 1)
1-5 Room for Battery and PCS Sub-Total 2) 2-1 Training Sub-Total 3) 3) Maintenance contract for Battery System 3-1 Maintenance Contract Cost for 2 years Sub-Total 4) 4) Spare parts 13-1 Spare parts for Battery,PCS, etc. Sub-Total 3 Dispute Board for 3 persons Total	IS IS IS IS IS IS IS		80.0 60.0 0.0 10,826.0 70.0 70.0 70.0 216.5 216.5 216.5 216.5 216.5 216.5 216.5 216.5 216.5 216.5	0.2 0.2 3.6 29.3 0.0 0.0 401.4	0.0 0.0	83.9 367.6 11,500.9 70.0 70.0 216.5 216.5 216.5 108.3 108.3 963.0	1% of the above 1) per year *2 years 1% of above 1)

JICA

Appendix 3-4-1-4

Detailed Cost breakdown for the Project (CIS)

		No.	Item	Specification	Unit Price (US\$)	Unit Price (EGP)	Total Quantity	units	Total Price (US\$)	Total Price (EGP)	Remarks
		1	PV module (CIS) 1MW	140W (1.18\$/W)	165	1,000	143,040		23,601,600	143,040,000	
		2	Terminal Box		1 200	7.840	540		728.000	4 390 400	
		3	DC cable connection		1,500	7,040	500		720,000	4,570,400	
	PV module	4	From PV module to Terminal box DC cable connection		2	20	782,400	m	1,564,800	15,648,000	
		5	From Terminal box to Inverter		8	50	112,000	m	896,000	5,600,000	
					2,000.0	12,060	3,854	t	7,708,000	46,479,240	
		6 7	Sub Lotal (1+2+3+4+5) Inverter	500kVA					34,498,400	215,157,640	
		8	Step-up Transformer	400V/22kV	90,000	542,700	40		3,600,000	21,708,000	
				2000kVA	26,000	156,780	10		260,000	1,567,800	
		9		400 V	10,000	60,300	10		100,000	603,000	
		10	MV Switchgear	22kV	20,000	120,600	10		200,000	1,206,000	
	Inverter	11	LV cable Connection From Inverter to LV Switchboard		50	310	1 200	m	60.000	372.000	
		12	LV cable Connection	 	50	010	100		0.000	55.000	
		13	MV Cable Connection		50	310	180	m	9,000	55,800	
		14	From Step-up transformer to MV Switchgear Monitoring system terminal unit		100	610	180	m	18,000	109,800	
		15	Sub Total $(7+8+0+10+11+12+13+14)$		500	3,020	10		5,000	30,200	
		16	Feeder box						4,232,000	23,032,000	
		17	VT Box		40,000	241,200	6		240,000	1,447,200	
	MV Switchgear	18	Bus coupler Box		20,000	120,600	2		40,000	241,200	
	0	10	Monitoring system terminal unit		40,000	241,200	1		40,000	241,200	
		19			500	3,020	9		4,500	27,180	
		20 21	Sub Total (16+17+18+19) Feeder Box (Extension)						324,500	1,956,780	
	Distribution line	22	Monitoring system terminal unit		40,000	241,200	2		80,000	482,400	
	connection		Cub Tata 1 (21 22)		500	3,020	2		1,000	6,040	
		23	M/M computer system						81,000	400,440	
		25	server system		80,000	482,400	1		80,000	482,400	
1.PV	Monitoring	26	Communication interface		200,000	1,206,000	1		200,000	1,206,000	
	System		LIDC		1,000	6,030	1		1,000	6,030	
		27			500	3,020	1		500	3,020	
		28 28	Sub Total (24+25+26+27) MV Cable Connection						281,500	1,697,450	
	· · · · ·	29	from unit substation to 22kV bus unit MV cable Connection from 22kV bus unit		100	610	13,200	m	1,320,000	8,052,000	
	connection	20	to Hurghada Wind Distribution Point		100	610	6,000	m	600,000	3,660,000	
		30			20	130	8,800	m	176,000	1,144,000	
	Grounding	31 32	Grounding conductor						2,096,000	12,856,000	
	system	33	Sub Total (32)		20	130	10,000	m	200,000 200.000	1,300,000 1.300.000	
		34	PV foundation		335	2 030	7.056		2 363 760	14 323 680	$27730 \times 0.28m3$
		35	Ground leveling		333	2,030	7,030		2,303,700	14,323,000	27750 x 0.20115
	Civil works	36	road construction		3	20	33,880	m3	111,804	677,600	
		37	Sub Total (34+35+36)		2	20	63,420	m	152,208 2.627.772	1,268,400 16.269.680	
		38	Inverter house		350	2 120	360	m2	126 000	763 200	$36m^2/1rcom \times 10$ rooms
	Inverter house construction	39	Interior work		350	2,120	300	1112	128,000	783,200	50112 / 110011 x 10 100115
		40	Sub Total (38+39)		350	2,120	360	m2	126,000 252,000	763,200 1,526,400	
	MV and -1	41	MV switch gear house		400	2,420	310		124,000	750,200	
	house	42	Interior work		400	2 420	310		124 000	750 200	
		43	Sub Total (41+42)		400	2,420	510		248,000	1,500,400	
	Guard Fence	44	Guard Fence		58	350	3,600	m	208,800	1,260,000	
	WOIK	45 46	Sub Total (44) Exhibition System						208,800	1,260,000	
		47	Construction of house		300,000	1,809,000	1	LS	300,000	1,809,000	
	Information Center	4/			350	2,120	100	m2	35,000	212,000	
		48	Interior work		350	2,120	100	m2	35,000	212,000	
		49 50	Sub Total (46+47+48) S/S modifications						370,000	2,233,000	
	Central Hurghada S/S modifications	51	Sub Total		20,000	120,600	1	LS	20,000	120,600	
		1	High Performance Battery	1,000kW							
		2	Power conditioning system(PCS) for Battery	500kW	4,543,000	27,394,290	2	unit	9,086,000	54,788,580	
		3	MV Switchgear		400,000	2,412,000	4	unit	1,600,000	9,648,000	
2.Battery	High Performance	4	MV Cable connection		40,000	241,200	2	unit	80,000	482,400	
	Battery	-	Doom for battom and DCC		100	610	600	m	60,000	366,000	
		5			350	2,120	520	m2	182,000	1,102,400	
		6	Room Interior work including air conditioner		350	2,120	520	m2	182,000	1,102,400	
		7	Sub Total (1+2+3+4+5+6) Dispute Board						11,190,000	67,489,780	
3. DB	Dispute Board	2	Sub Total		963,000	5,806,890	1	LS	963,000	5,806,890	

Appendix 3-4-2: Image of information center (layout and interior)

Appendix 3-4-2 Image of Information Center (layout and interior)

Since the detailed requirements and conditions are not decided yet, details shall be decided during the detailed design stage.

This Appendix is describing only image of the information center.

The following schematic diagram is just reference for layout of the information center based on visitor center of Komekura-yama PV power plant in Japan where NREA . Photos are exhibitions of the PV power plant for reference where NREA engineers visited during training in Japan.



You may refer to the followings web site as reference (but this is Japanese only). http://www.pref.yamanashi.jp/kg-denki/komekurayama_prshisetsu.html

According to NREA, this information center will be used for mainly person related to energy sector with following purposes:

- Learning solar energy in general
- Learning PV technology including how to generate
- Exhibition for solar conditions in Egypt
- Background of this information center (why created and who support), etc.

Appendix 3-4-3: Terms of Reference for Consulting Services (Draft)

Appendix 3-4-3 Terms of Reference for Consulting Services (Draft)

Photovoltaic Power Plant Project in Hurghada Terms Of Reference For Consulting Services (Draft)

1- General

- (1) Power demand in Egypt has been growing rapidly, e.g., 7% in last fifteen years.
- (2) Power generation needs to be developed in line with the demand. According to 6th five year development plan (2007/8-2011/12), the generation will be increased by 9.1% p.a.
- (3) In consideration to the above, GoE (Government of Egypt) established "Supreme Council of Energy" in 2006 and has adopted a resolution to cover 12% of the generation capacity development plan of up to 2011, and by 2020 to cover 20% of the total generation capacity with renewable energy.
- (4) Climate in Egypt has an excellent condition of strong solar radiation for solar power generation. GoE intends to request to GoJ (Government of Japan) to provide Japanese ODA (Official Development Assistance) Yen Loan for photovoltaic power plant in Egypt.

2- Scope of the Project

(1) Objectives

To develop 20MW photovoltaic power plant in Hurghada with 2MW battery at NREA's wind power plant.

(2) Scope of the Project

Engineering, procurement & construction of the photovoltaic power plant facilities on turn key basis including the following:

- 20MW Photovoltaic modules with related equipment
- 2MW battery with related equipment
- Remote monitoring and control system
- Electrical works including renovation/expansion of Hurghada wind farm distribution point
- Civil works including access roads, gate, fence, drainage, houses, etc.
- Social and environmental considerations (mitigation measures & monitoring)

3- Objectives of the Consulting Service

The services to be rendered by the Consultant will cover preparation of draft pre-qualification (P/Q) and draft bid documents, the assistance for P/Q and bid evaluation, contract negotiation, construction supervision and contract management of the

project as well as warranty verification including data measuring. Expected consulting services period is approximately 68 months.

During the project implementation stage, the Consultant is requested to be "Engineer" which will be defined in the contract conditions to be developed later. JICA recommends using FIDIC (Federation International Des Ingenieurs Conseils) as contract condition under Japanese ODA Loan project.

4- Scope of Services to be performed by Consultant

4.1 Pre Award Stage

a) Design Stage

The Consultant shall carry out the followings:

- To review previous study reports conducted by NREA or other agencies, with respect to the requirements of the photovoltaic power plant
- To carry out site reconnaissance to grasp situation of the site and existing distribution point, especially space availability, situation of existing facilities, topography, soil condition and environmental circumstances, etc.
- To carry out basic and detailed design in consideration of site conditions, design criteria, applicable photovoltaic power plant specifications, practice, etc. in order to prepare technical specifications
- To estimate bill of quantities and costs
- To develop integrated implementation schedule
- b) Pre-Qualification Stage

The Consultant shall carry out the followings:

- To prepare draft Pre-Qualification (P/Q) documents including evaluation criteria in accordance with JICA's rule, guidelines and sample documents for the project.
- To make draft reply to questions from applicants.
- To make draft evaluation report of P/Q for the projects in consultation with NREA.
- c) Tendering Stage

The Consultant shall carry out the followings:

- To prepare draft tender documents for the project including evaluation criteria in accordance with JICA's rule, guidelines and sample documents as well as considering NREA's practices.
- To make draft reply to questions from tenderers.
- To attend pre-tender meeting.
- To carry out evaluations and make draft technical and financial evaluation report

for the projects in consultation with NREA.

 To attend contract negotiation with a successful tenderer and prepare the draft contract documents.

4.2 Project Implementation Stage

The Consultant is request to be (behave) "Engineer" under FIDIC contract condition or equivalent.

In addition to roles of "Engineer" above, the Consultant shall also carry out the followings:

- To assist in kick-off meeting for the project.
- To assist in progress meetings.
- To assist in review of the detailed overall work schedule prepared by the contractor.
- To assist in carrying out construction supervision in view of quality control, scheduling control and disbursement control.
- To assist in monitoring and evaluating of the work progress.
- To assist in inspection of manufacturing and fabrications at the site.
- To assist in witnessing of manufacturing and fabrications at factories.
- To assist in review and approval for testing procedure prepared by contractor.
- To witness the testing and commissioning at site as well as factory acceptance tests.
- To check the as-built drawings and operation & maintenance manual prepared by the Contractor.
- To assist in the evaluation of potential contractual claims.
- To assist in punch list preparation and preparation of Taking Over and Acceptance Certificate

4.3 Warranty Stage

The Consultant shall carry out the followings:

- To assist in the photovoltaic power plant performance verification.
- To assist the verification of deterioration ratio of the installed PV modules.
- Carry out end of warranty inspection.
- To assist in preparation of Final Acceptance Certificate

4.4 Environmental aspects

The Consultant shall carry out the followings:

- To assist setting up environmental monitoring system during construction.
- To monitor environmental measures and resettlement situations, if any, under the Project.

4.5 Co-ordination

The Consultant will assist NREA to maintain proper co-ordination and communication between NREA/JICA and NREA/Contractor.

4.6 Training

The Consultant will carry out/coordinate trainings to NREA's staffs based on description in Chapter 4 of this report.

■ This should be defined later

4.7 Measuring

The Consultant shall measure and record of measured data such as solar radiation, output current of modules, temperature of modules, air temperature which can be obtained from measuring system provided by JICA. The Consultant shall maintain the measuring system provided by JICA properly during the services period.

The Consultant shall also measure and record of measured data of newly installed measuring system by the Contractor.

Then the Consultant will analyze such measuring data.

5- Duties of the Owner

The followings are assumed to be provided from the Owner for the consulting services:

- To provide to the Consultants in an expeditious manner access to and copies of studies, plans, specifications, maps, drawings, criteria, and other information related to the Project, if available to the Owner and necessary for the Consultants to perform the Services, at no expense to the Consultants.
- To assist the Consultants in obtaining customs clearance for materials or equipment brought into Egypt for performance of the Services by the Consultants. The Owner shall directly pay the customs duties associated with materials or equipment reimbursable hereunder brought for the jobsite office only, which at completion of the Project will be delivered to the Owner as Owner's property.
- To assist the Consultants, if required, in obtaining clearances, visas, and extensions; resident work permits; and any other documents relating to Expatriates of the Consultant, their accompanying dependents, and their personal effects assigned to perform the Services and shall use its best efforts to assist the Consultant, its Sub-consultants, and employees to obtain the benefit of all privileges, exemptions, and other favorable treatment, which are or may become lawfully available under any decisions, laws, regulations, or rules of Egypt.

- To provide overall management, direction, and control of the Project. In addition, the Owner intends to provide a dedicated Owner's team for the Project to coordinate with the Consultants' project team.
- To facilitate and expedite the Services, the Owner shall approve or object to the Consultants' replies and/or recommendations within two weeks after receipt of such replies/recommendations made during the Project's implementation period and in accordance with the Project's milestone schedule. For the purposes of assuring continuity in the performance of the Consultants' Services, in the event approval or objection is not made within such two weeks period, the replies/recommendations shall be deemed approved unless otherwise agreed for a longer period.

6- Reports to be prepared by the Consultant

The Consultant shall prepare and submit to the Owner for the following reports:

- Quarterly Progress Report including Project Status Report which JICA request Executing Agency
- Draft PQ Evaluation report
- Draft Technical Evaluation Report
- Draft Financial Evaluation Report
- Project Completion Report
- Warranty Inspection Report
- Final Report

- Appendix 3-5-1: Cost Breakdown for the Project
- Appendix 3-5-2: Detailed Cost breakdown for the Project
- Appendix 3-5-3: Annual Fund Requirements (JP Yen basis)
- Appendix 3-5-4: Cost Breakdown for Consulting Services
- Appendix 3-5-5: Man-Months allocation for consultant

Appendix 3-5-1 Cost breakdown for the Project

The cost breakdown is attached as follows.

				Co	ost (Thousand do	ollar)		
No.	Items to be requested	Nos. of	CIF to I	Port Saied	Inland	Site Works (Installation		Notes
	.	Required	unit	amount	Transportation	replacement etc.)	Total	
1 Constru	action of 20MW PV Power Plant including necessary		(Foreign	Currency)	(Local C	Currency)		50 (00.0
equipme	nt			34,494.7	452.5	17,485.7	52,432.9	52,432.9
1) PV mo	dule							
1-1	PV Module (MLTF)	LS		22,689.6	84.5	3,487.1	26,261.2	
1-2	Terminal Box	LS		728.0	2.0	105.3	835.3	
1-3	DC cable	LS		1,564.8	35.8	397.7	1,998.3	
1-4	Frame for PV	LS		896.0	37.0	8,840.4	9,773.4	
Sub-Total				25,878.4	159.3	12,830.5	38,868.2	
2) Inverte	r							
2-1	Inverter	LS		3,600.0	3.4	363.6	3,967.0	
2-2	Step-up Transformer	LS		260.0	1.7	3.7	265.4	
2-3	LV, MV switchgear	LS		300.0	6.7	17.9	324.6	
2-4	LV,MV cable for inverter	LS		87.0	0.0	37.6	124.6	
2-5	Monitoring System terminal unit	0		5.0	0.0	17.1	22.1	
Sub-Total				4,252.0	11.8	439.9	4,703.7	
3) MV sw	ritchgear							
3-1	Switchgear Box	LS		320.0	0.8	36.3	357.1	
3-2	Monitoring System terminal unit	IS		4.5	0.0	8.9	13.4	
Sub-Total				324.5	0.8	45.2	370.5	
4) Distrib	ution line connection			524.5	0.0	40.2	570.5	
4) Distrib		IC		80.0	0.0	10	82.0	
4-1	reeder box	1.5		80.0	0.8	1.2		
4-2	wontoring system terminal unit	LS		1.0	0.0	0.9	1.9	
Sub-Tota				81.0	0.8	2.1	83.9	
5) Monito	pring System							
5-1	Monitoring System	LS		281.5	0.0	10.1	291.6	
Sub-Total				281.5	0.0	10.1	291.6	
6) Interna	al cable connection							
6-1	MV Cable Connection	LS		1,320.0	5.5	278.1	1,603.6	
6-2	LV Cable Connection	LS		600.0	0.5	105.3	705.8	
6-3	Optic fiber cable connection	LS		176.0	0.5	48.7	225.2	
Sub-Total				2,096.0	6.6	432.1	2,534.7	
7) Ground	ding system							
7-1	Grounding conductor	LS		200.0	0.5	37.3	237.8	
Sub-Total				200.0	0.5	37.3	237.8	
8) Civil w	vorks							
8-1	PV and transformer foundation	LS		0.0	262.1	2,600.9	2,863.0	
8-2	land leveling	LS		0.0	0.0	111.8	111.8	
8-3	road and drain work	IS		0.0	0.0	152.2	152.2	
Sub-Total				0.0	262.1	2 865 0	3 127 0	
0) House	construction			0.0	202.1	2,000.0	5,127.0	
9)11043C	Inverter house construction	IS		0.0	2.5	252.0	254.5	
9-1		1.5		0.0	2.5	252.0	254.5	
9-2	MV Switchgear house construction	LS		0.0	2.5	248.0	250.5	
Sub-Tota				0.0	5.0	500.0	505.0	
10) Guaro	d Fence							
10-1	Guard Fence	LS		0.0	2.5	250.6	253.1	
Sub-Total				0.0	2.5	250.6	253.1	
11) Inform	nation Center							
11-1	Exhibition System	LS		300.0	3.0	0.0	303.0	
11-2	Construction of house	LS		0.0	0.0	70.0	70.0	
Sub-Total				300.0	3.0	70.0	373.0	
12) Centr	al Hurghada Substation Modifications							
12-1	Central Hurghada S/S modifications	LS		20.0	0.2	3.0	23.2	
Sub-Total				20.0	0.2	3.0	23.2	
13) Train	ing to Owner's engineers							
13-1	Training	LS		70.0			70.0	
Sub-Tota				70.0			70.0	
14) Maint	tenance contract for PV power plant							
14-1	Maintenance Contract Cost for 2 years	LS		662.2			662.2	1% of the above 1) -7)per year * 2
Sub-Total				662.2			662.2	years
15) Spare	parts			002.2			50212	
15_1	Spare parts for PV. Inverter. etc.	IS		320.1			320.1	1% of above 1)-6)
10-1 Sub T-+ 1				329.1			327.1	
Sub-Total				329.1			329.1	
2 Installa	tion of 2MW High Performance Battery including			11,220.8	29.3	645.6	11,895.7	11,895.7
1) High P	erformance Battery							
1)116111	High Portormance Battery	IC		0.086.0	24.7	162.6	0 272 2	
1-1	Down conditioning writers for bottom	1.5		9,086.0	24./	102.6	7,2/3.3	
1-2	rower conditioning system for battery			1,600.0	0.7	91.3	1,692.0	
1-3	MV Switchgear for Battery	LS		80.0	0.2	4.0	84.2	
1-4	MV Cable Connection	LS		60.0	0.2	23.7	83.9	
1-5	Room for Battery and PCS	LS		0.0	3.6	364.0	367.6	
Sub-Total				10,826.0	29.3	645.6	11,500.9	
2) Trainir	ng to Owner's engineers							
2-1	Training	LS		70.0			70.0	
Sub-Tota				70.0			70.0	
3) Mainte	nance contract for Battery System	1	1	. 0.0	i		. 0.0	
2.1	Maintenance Contract Cost for 2 years	IS		214 5			214 5	1% of the above 1) per year * 2
Sub Teta	tendice contact cost for 2 years			210.3			210.3	years
A) C				216.5			216.5	
4) Spare j								
13-1	Spare parts for Battery,PCS, etc.	LS		108.3			108.3	1% of above 1)
Sub-Total	l			108.3			108.3	
3 Disput	e Board for 3 persons			963.0	0.0	0.0	963.0	
T · ·								
Total				46,678.5	481.8	18,131.3	65,291.6	65,291.6

Cost for PV project (Reference only)

JICA

Appendix 3-5-2

Appendix 3-5-2 Detailed Cost breakdown for the Project

		No.	Item	Specification	Unit Price (US\$)	Unit Price (EGP)	Total Quantity	units	Total Price (US\$)	Total Price (EGP)	Remarks
		1	PV module (MLTF) 1MW	128W (1.1\$/W)	145	880	156,480		22,689,600	137,702,400	
		2	Terminal Box		1,300	7,840	560		728,000	4,390,400	
	PV module	3	DC cable connection From PV module to Terminal box		2	20	782,400	m	1,564,800	15,648,000	
		4	DC cable connection From Terminal box to Inverter		8	50	112,000	m	896,000	5,600,000	
		5	Frame for PV		2,000.0	12,060	4,420	t	8,840,000	53,305,200	
		6 7	Sub Total (1+2+3+4+5) Inverter	500kVA					34,718,400	216,646,000	
		8	Step-up Transformer	400V/22kV	90,000	542,700	40		3,600,000	21,708,000	
		9	LV Switchboard	2000kVA 400V	26,000	156,780	10		260,000	1,567,800	
		10	MV Switchgear	22kV	10,000	60,300	10		100,000	603,000	
	Inverter	11	LV cable Connection		20,000	120,600	10		200,000	1,206,000	
		12	From Inverter to LV Switchboard LV cable Connection		50	310	1,200	m	60,000	372,000	
		13	From LV Switchboard to Step-up transformer MV Cable Connection		50	310	180	m	9,000	55,800	
		14	From Step-up transformer to MV Switchgear Monitoring system terminal unit		100	610	180	m	18,000	109,800	
		15	Sub Total (7+8+9+10+11+12+13+14)		500	3,020	10		5,000 4,252,000	30,200 25,652,600	
		16	Feeder box		40,000	241,200	6		240,000	1,447,200	
		17	VT Box		20,000	120,600	2		40,000	241,200	
	MV Switchgear	18	Bus coupler Box		40,000	241,200	1		40,000	241,200	
		19	Monitoring system terminal unit		500	3,020	9		4,500	27,180	
		20 21	Sub Total (16+17+18+19) Feeder Box (Extension)			,			324,500	1,956,780	
	Distribution line	22	Monitoring system terminal unit		40,000	241,200	2		80,000	482,400	
	connection	23	Sub Total (21+22)		500	3,020	2		1,000	6,040	
		23	M/M computer system		80.000	482 400	1		80.000	482 400	
1 PV		25	server system		200.000	1 206 000	1		200.000	1 206 000	
1.1 V	Monitoring System	26	Communication interface		1 000	(020	1		1.000	(020	
		27	UPS		1,000	6,030	1		1,000	6,030	
		28	Sub Total (24+25+26+27)		500	5,020	1		281,500	3,020 1,697,450	
		28	from unit substation to 22kV bus unit		100	610	13,200	m	1,320,000	8,052,000	
	Internal cable connection	29	to Hurghada Wind Distribution Point		100	610	6,000	m	600,000	3,660,000	
		30			20	130	8,800	m	176,000	1,144,000	
	Grounding	31 32	Grounding conductor			100	10.000		2,096,000	12,856,000	
	system	33	Sub Total (32)		20	130	10,000	m	200,000 200,000	1,300,000 1,300,000	
		34	PV foundation		335	2,030	7,764		2,600,940	15,760,920	27730 x 0.28m3
	Civil works	35	Ground leveling		3	20	33,880	m3	111,804	677,600	
		36	road construction		2	20	63,420	m	152,208	1,268,400	
		37 38	Sub Total (34+35+36) Inverter house						2,864,952	17,706,920	
	Inverter house	39	Interior work		350	2,120	360	m2	126,000	763,200	36m2 / 1room x 10 rooms
	construction	40	Sub Total (38+39)		350	2,120	360	m2	126,000 252,000	763,200 1,526,400	
	MV switch gear	41	MV switch gear house		400	2,420	310		124,000	750,200	
	house	42	Interior work		400	2,420	310		124,000	750,200	
	Guard Fence	43 44	Sub Total (41+42) Guard Fence						248,000	1,500,400	
	work	45	Sub Total (44)		58	350	4,320	m	250,560 250,560	1,512,000 1,512,000	
		46	Exhibition System		300,000	1,809,000	1	LS	300,000	1,809,000	
	Information	47	Construction of house		350	2,120	100	m2	35,000	212,000	
	Center	48	Interior work		350	2,120	100	m2	35,000	212,000	
		49 50	Sub Total (46+47+48) S/S modifications						370,000	2,233,000	
	Central Hurghada S/S modifications	51	Sub Total		20,000	120,600	1	LS	20,000 20,000	120,600 120,600	
		1	High Performance Battery	1,000kW	4,543.000	27,394.290	2	unit	9,086.000	54,788.580	
		2	Power conditioning system(PCS) for Battery	500kW	400.000	2.412.000	4	unit	1.600.000	9.648.000	
	High	3	MV Switchgear		40.000	241 200		unit	80.000	482 400	
2.Battery	Performance	4	MV Cable connection		10,000	610	600	m	60,000	366 000	
	Dattery	5	Room for battery and PCS		250	2 120	520		192.000	1 102 400	
		6	Room Interior work including air conditioner			2,120	520		102,000	1,102,400	
		7	Sub Total (1+2+3+4+5+6) Dignute Board		350	2,120	520	m2	182,000 11,190,000	67,489,780	
3. DB	Dispute Board	1	Sub Total		963,000	5,806,890	1	LS	963,000	5,806,890	

	\mathbf{A}_{j}	pp	er	ndix 3	8-5-3	Ann	ual F	un	ıd	R	eq	lni	ire	m	er	ıts	(J	P	Ye	en	ba	as	is)																	
	Total	10101		269				269	76	17	362	24	9	31	303						0	101	2	32	13	23	68	461	36	503	al to Mouch	THE IO IMPRICIL								
2018	2018	2/2		77				77	51	6	134	ю	en N	x	142	-					0	1 10	2	32	13	23	68	210		210	an Decem A se	dv 1101.1 . 18								
	E/C	2/1		192				192	25	11	228	19	τ -	33	251	4												251	36	о 293	Elecel Vo	L'ECAL LC						251.0	5,520.0	36.0
	Total	10101		269				269	61	17	347	36	r 4	0 46	303	2					1	T O	- 1	77	12	22	61	454	34	0 494										
2017	1 /C	2		77				77	40	6	123	7	4 -	17	135						17	T O	¢ [22	12	22	61	196		196										
	<u></u> 1/1	~/		192				192	21	11	224	29	ς, η	34	258													258	34	о 298								258.0	5,235.0	34.0
	Total	TOTAL		2,691				2,691	474	159	3,324	302	45	364	3,688	00010					166	00T	12	245	113	220	578	4,266	30	4,302										
2016	2016	2		767				767	308	54	1,129	61	24	4 89	1.218	214					126	00T	12	245	113	220	578	1,796		1,796										
	E/C	~/.7		1,924				1,924	166	105	2,195	241	21	275 275	2 470	0.11												2,470	30	9 2,506								2.470.0	4,947.0	30.0
	Total	TOTAL		2,153				2,153	277	122	2,552	302	34	353	2,905	20.717					120	120) «	173	83	172	428	3,333	14	3,353										
2015	2015	2		614				614	177	40	831	61	18	* 83	914						120	120	ς α	173	83	172	428	1,342		1,342			Ē	(I.V						
	E/C	~/		1,539				1,539	100	82	1,721	241	16	270 270	1 991													1,991	14	0 2,011			on 	rtion (mcl. v				1,991.0	2,463.0	14.0
	Total	1 0101										302	21	340	340													340	1	о 347			Eligible porti	he Eligible po						Π
1011	2014	2										61	11	4	76	2												76		76			rency of the	currency of t						
	E/C	~/										241	13	264	264													264	, 1	0 271		portion	e in local cur	e in toreign e				264.0	471.0	1.0
	Total	TOTAL										242	8 5	CT 263	263	2												263	`	о 269		of the Eligible	of expenditu	of expenditui	dura	year				Π
2013	2013	2/2										49	4 0	с <u>9</u> 5	200	8												56		56		5%	10%	10%	0.1%	Þ		0.01%		
	E/C	~/										193	4	201 201	202	6												207	`	0 213	-	ation Cost=	=TAV	- D	Charge ratio=	sbursement		for Consul= 207.0	207.0	
	Total	10141		5,382				5,382	888	315	6,585	1,208	121	1.397	7 987	-0/1.					000	100	23	477	221	437	1,135	9,117	115	9,265	9,268	Administr			Commitment (Duration of		Interest rate f		
Loto1	T /C	2		1,535				1,535	576	106	2,217	244	16	324	2.541	1.0/-					000	100	23	477	221	437	1,135	3,676		3,676	3,676				m/LE cs /Van	1121 / 60				
	E/C	~/		3,847				3,847	312	209	4,368	964	57	1.073	5 441													5,441	115	5,589	5,592	2.1 %	8.8 %	5.0 %	1.0 Yi 82.43 Ui	87.4%	60.3 %	0.650 %		
Iteres	Item		ILIGIBLE PORTION	Construction of 20MW PV Power Plant including necessary equipment incl. 2MW battery				Total (1-4)	Price Escalation	Physical Contingency	Total (5+6+7)	Consulting Service	Price Escalation	Triy steat Colutingency Total (9+10+11)	A. Total (8+12)		VON ELIGIBLE PORTION	Land acquisition & Compensation	Price Escalation	Physical Contingency	Total (14+15+16)	Duise Econosi	Physical Contingency	Total (18+19+20)	VAT	Ð	B. Total (21+22+23)	TOTAL (A+B)	IDC :	Grand Total (25+26+27)		Price Escalation (F/C):	Price Escalation (L/C):	Physical Contingency :(construction) Physical Contingency (others) :	Exchange Rate : $1.0 =$	Eligible ratio	Financing rate (Foreign/Total)	Interest rate Actual Disbursement/Temporally allocation	Debt at the end of term	Interest during const
NI.	No.		A.E	1	2	3	4	5	9	4	×	6	10	11	13.1	ì	B.N	14	15	16	17	1 10	20	21	22	23	24	25	26	77]								t	1

JICA

Appendix 3-5-4

Actual Disbursement = Total cost except for Interest during construction * Financing rate Debt at the end of term = Actual Disbursement of same year + Dekt at the end of last year + Interest during const of last year Interest during const = Debt at the end of term * Interest rate

Appendix 3-5-4 Cost Breakdown for Consulting Services

<Monthly/Daily Unit Rate>

1. ENGINEERING FEE							
1.1 Outside of Egypt	MM	RATE		Paid in LE		Paid in JP Yen	
Foreign Consultant (FC)	6.0	2,562,000	Yen/MM			15,372,000	Yen
Foreign Consultant for Training	20.0	2,562,000	Yen/MM			51,240,000	Yen
1.2 In Egypt (incl. Factory Test)							
Foreign Consultant (FC)	201.0	2,712,000	Yen/MM			545,112,000	Yen
Local Consultant (LC)	303.0	55,000	LE/MM	16,665,000	LE		
1.3 Subtotal for Engineering Fee				16,665,000	LE	611,724,000	Yen
2. Direct Cost							
2.1 Airfare	Trips						
Air Fare from Japan to Egypt	61	450,000	Yen/trip			27,450,000	Yen
Air Fare for FC for factory test	3	450,000	Yen/trip			1,350,000	Yen
2.2 Accommodation	person-night						
Accommodation for FC in Egypt	6,030	18,000	Yen/Person-Night			108,540,000	Yen
Accommodation for FC for factory test	75	23,000	Yen/Person-Night			1,725,000	Yen
2.3Local Transportation	car-months/days						
for FC in Egypt	101	230,000	Yen/Car-Months			23,230,000	Yen
for LC in Egypt	152	5,000	LE/Car-Months	760,000	LE		
for factory test for FC	38	8,000	Yen/days			300,000	Yen
for factory test for LC	0	400	LE/days	0	LE		
2.4 Offices and Equipment/Facilities	months						
Rental fee for Egypt Office for FC	64	300,000	Yen/Months			19,200,000	Yen
Office equipment/furniture for Egypt FC office	LS	-	Yen/Months			30,000,000	Yen
PC, printers, faxes, copiers for Egypt FC office	LS	-	Yen/Months			20,000,000	Yen
Office staff for Egypt FC office	64	300,000	Yen/Months			19,200,000	Yen
Office equipment/furniture etc. for site office	20.0	20,000	LE/Months	400,000	LE	0	Yen
2.5 Communication and Document Delivery							
Any communication and document delivery for FC	64	500,000	Yen/Months			32,000,000	Yen
2.6 Any Direct Costs related Training to NREA							
Air Fare to Japan from Egypt	40	320,000	Yen/trip			12,800,000	Yen
Accommodation for NREA in Japan	1,200	23,000	Yen/Person-Night			27,600,000	Yen
Transportation in Japan	40	100,000	Yen/Person-Trip			4,000,000	Yen
Allowances for NREA staffs	1,200	4,000	Yen/Person-Night			4,800,000	Yen
Any facilities and documents required for Training	LS					20,000,000	Yen
2.6 Subtotal for Direct Cost				1,160,000	LE	352,195,000	Yen
3. Total Amount (1+2)				17,825,000	LE	963,919,000	Yen

Appendix 3-5-5 Man-Months allocation for consultant

Man-Months allocation table for Consulting Services for 20MW PV power plant project in Hurghada

year									2								3 4 5 6 _														1																	
month	1	2 3	4	5 6	7 8	3 9	10 11	12	13 14	15 16	17 1	8 19	20 2	1 22	23 2	4 25	26 27	28 2	9 30	31 3	2 33	34 3	35 36 3	7 38	39 4	0 41 4	42 43	3 44	45 46	47 48	49 5	0 51	52 53	54	55 56	57 5	58 59	9 60	61 62	63	64 6	5 66	67 6	68 69	70 7	71 72	Total	
Pre-Construction stage					-																																+									+++		
Basic Design Preparation of PO and Tender Docs	8 1	1 1	1	1 1	1 1		-		_					+					+						-		_	+				+		+	_		+			+		+		-	++	++		
Tendering stage (incl. prep. for tender docs	0 1								-								-		_						-		_					+ +	_		_		+		_	+		-		-	\vdash	++		
evaluations upto contract sign)	12					1	1 1	1	1 1	1 1	1	1 1	1																																		, P	
Construction Stage	20				_								_	1 1	1	1 1	1 1	1	1 1	1	1 1	1	1 1	1 1	1	1	_			_					_		+		_			_		_		++		
Detailed Design incl_site investigations	4		+						-					1 1	1	1	1 1	1	1 1	1	1 1	-	1 1	1 1	-	1	_	+ +				+ +		+	-		+			+	-	-		-	+	++		
Manufacturing and transportation	13		+		_			+			+			<u>+</u> +	-	1 1	1 1	1	1 1	1	1 1	1	1 1	+	+	++	_	+	-+-+	+	\vdash	++		+	_	++	+			+		+		-	\vdash	++		
Factory test of PV	15								-								1 1		1 1	-	1 1	1	1 1	+						-							+					+		-		++		
Factory test of Investor	0		++		_		_		_		++				_	×	_		_		+	_			_	+	_	+		_		+		+	_		+		_	+		+		_	\vdash	++		1
Factory test of MV equipment	0		+		_				_						_				_			_			_		_				\vdash				_		+		_	++	_	_		_	\vdash	++	!	1
Civil Works	14		+						_					-	1	1 1	1 1	1	1 1	1	1 1	1	1 1		_		_	+ +				+ +			_		+			+	_	_		_		++	'	
Civil Works	14		+		_		_		_		+				1		1 1	1	1 1 1 1	1	1 1 1 1	1	1 1	1 1	_	+	_	+	+	_	\vdash	+		+	_		+		_	+	_	_		_	\vdash	++	!	4
Site installation works	13		+		_		_		_		+				_		1 1	. 1	1 1	1		1	1 1	1 1	1		_	+		_		+		$\left \right $	_		—		_	+		_		_	\square	++	'	1
Commissioning test	2						_		_								1 1		_						1										_		+				_	_		_		++	'	1
Iraining	5		++														1 1		_							1							1 1		1 1						-	_		_	\square	++		4
Warranty period	24		+		_		_		_							+	_		_						_				1 1								44		1 1		1	_		_		_	'	4
Verification and acceptance test	0																															*	*							* 1	*							1
Consultant MM allocation																																																
vear				1								2							,	3							4							5									6			<u> </u>		Nee of
month							12	12 13 14 15 16 17 18 19 20 21 22 23							24 25 26 27 28 29 20 21 22 22						24 25 26 27 28 20 40 4					12 13	3 11	15 16	47 48	10	50 51	52 53	54	55 50	57	58 50	9 60	60 61 62 63 64 65 66 67 68					68 60	70	71 72	Total Trip		
International Congultant	1	2 .	/ -	5 0			10 11	12	15 1	10 10	, 1/ .	10 17	20 2	.1 22	2.5 2	4 25	20 27	20	27 30	51 5	52 55	54	35 30 3	, 30	37 3	10 41	72 70	J 11	45 40	4/ 40		0 51	52 55	54	35 50	57		00	01 02	- 05	0 T	00	07	00 0.	70	/1 /2	'	r
			+					\vdash	_							+								+	_		_					+					+					_		_		++	'	
Inside Egypt																					-							_									\rightarrow					_				\rightarrow		
Project Manager	1.0	1.0 1.0	1.0	1.0 1.0	0.5 1.0	0.5	1.0 0.5	1.0	1.0 0.3	5 1.0 1.0	0.5 1	.0 1.0	0.5 1.	.0 1.0	1.0 1.	0 1.0	1.0 1.0	1.0	.0 1.0	1.0 1.	.0 1.0	1.0 1	1.0 1.0 1.	.0 1.0	1.0 1.	0 1.0 1	1.0 1.0	0			\vdash	1.0	1.0				+			1.0	1.0	_			\vdash	++	44.0	6
PV Specialist	1.0	1.0 1.0	1.0	1.0 1.0	0.5 1.0) 0.5	1.0 0.5	1.0	1.0 0.5	5 1.0 1.0	0.5 1	.0 1.0	0.5 1.	.0 1.0	1.0 1.	0 1.0	1.0 1.0	1.0	.0 1.0	1.0 1.	.0 1.0	1.0 1	1.0 1.0 1.	.0 1.0	1.0 1.	.0 1.0 1	1.0 1.0	0				1.0	1.0				\perp			1.0	1.0	_				\rightarrow	44.0	6
Civil Engineer	1.0	1.0 1.0	1.0	1.0 1.0				1.0	1.0	1.0	1	.0 1.0	1.	.0	1.	0 1.0	1.0 1.0	1.0		1.	.0 1.0	1.0 1	1.0 1.0									+					+					_				$\rightarrow \rightarrow$	22.0	9
Eclectic Engineer for LV	1.0	1.0 1.0	1.0	1.0				1.0		1.0				1.0			1.0 1.0	0 1.0		1.	.0 1.0			1.0	1.0 1.	.0											\perp					_				\square	16.0	7
Eclectic Engineer for MV	1.0	1.0 1.0	0 1.0	1.0 1.0	1.0)		1.0	1.0	1.0 1.0) 1	.0 1.0	1.	.0 1.0	1.0 1.	0 1.0	1.0	1.0	.0 1.0	1.0 1.	.0	1.0 1	1.0 1.0 1.	.0 1.0	1.0 1.	.0 1.0 1	1.0 1.0	0									\perp									\square	34.0	8
Control System Engineer	1.0	1.0 1.0	0 1.0	1.0 1.0				\square						1.0		+		\square					1.0	+	1.	.0						++					\perp					_				\square	9.0	4
Environmental Specialist	1.0	1.0 1.0	0 1.0					\vdash						1.0		+				1.	.0		1.0	+	1.	.0						+					\perp					_				\square	8.0	5
Commercial Expert		1.0	0 1.0	1.0 1.0			1.0		1.0	1.0		1.0		1.0						1.	.0		1.0		1.	.0						$ \rightarrow $					\perp					_				\square	12.0	9
Legal Expert		1.0	1.0	1.0 1.0								1.0								1.	.0				1	.0																					7.0	4
Safety Expert	1.0	1.0 1.0)											1.0						1.	.0																										5.0	3
Sub-Total																																															201.0	61
Outside Egypt																																																
PV Specialist																																															0.0	1
Eclectic Engineer																																															0.0	2
Engineers for Training																	4.0	4.0								4.0 4	4.0 4.0	0																			20.0	
Home Office Support								1.0							1.	0							1.0							1.0								1.0			1.0						6.0	
Sub-Total			\square																																		—									++	26.0	
Total for International Consultant																																					+									++		<u> </u>
Local Consultant																		+								++											+-									++		
Leader of Local Consultant	1.0	1.0 1.0) 1.0	1.0 1.0			1.0	1.0	1.0 1.0) 1.0 1.0	1.0 1	.0 1.0	1.0 1	.0 1.0	1.0 1.	0 1.0	1.0 1.0	1.0	.0 1.0	1.0 1	.0 1.0	1.0 1	L0 1.0 1.	.0 1.0	1.0 1	0 1.0 1	1.0 1.0	D							1.0 1.0		+-									++	41.0	
Civil Engineer	1.0	10 10	10	10 10			10	1.0	10 10	1010	101	0 1 0	10 1	0 1 0	10 1	0 1 0		1.0	0 1 0	10 1	0 1 0	10 1		0				-				+					+		_			_				+++	33.0	
Eclectic Engineer for LV	1.0	10 10	1.0	10 10			1.0	1.0	10 10	1010	1.0 1	0 1.0	1.0 1	0 1.0	10 1	0 1.0		1.0	0 10	1.0 1	0 1.0	1.0 1		0 10	101	0 1 0 1	10 10	n							10 10		+					_				++	41.0	
Eclectic Engineer for MV	1.0	1.0 1.0	1.0	1.0 1.0			1.0	1.0	1.0 1.0	1.0 1.0	1.0 1	0 1.0	1.0 1	0 1.0	1.0 1	0 1.0		1.0	0 1.0	1.0 1	0 1.0	1.0 1		0 1.0	1.0 1	0 1 0 1	1.0 1.0	n				+			1.0 1.0		—		_			_		_		++	41.0	<u> </u>
Control System Engineer	1.0	1.0 1.0	1.0	1.0 1.0			1.0	1.0	1.0 1.0	1.0 1.0	1.01	0 1.0	1.0 1	0 1.0	1.0 1.	0 1.0		1.0	0 1.0	1.0 1	0 1.0	1.0 1		0 1.0	1.0 1	0 1.0 1	1.0 1.0	0				+			1.0 1.0		+		_			_				++	41.0	
Moscuring device maintenance and data accuricitien	1.0	1.0 1.0	1.0	0.5 0.5	0.5 0.7	5 0 5	05.05	1.0	0.5 0.1	, 1.0 1.0	1.0 1	5 05	1.0 1.	5 0 5	1.0 1.	5 0 5	1.0 1.0		.0 1.0	1.0 1.	5 05	1.0 1	1.0 1.0 1.	5 0 5	1.0 1.	5 0 5 0	05.07	5 0 5	05.05	05.07	0.5 0	5 0 5	05.05	0.5	0.5 0.7	050	0.5.07	5 0 5	0.5 0.7		0.5	_	+		\vdash	++	37.0	<u> </u>
Environmental Specialist	1.0	0.5 0.5	0.5	1.0 1.0	0.5 0.5	0.5	0.5 0.5	0.5	0.5 0.8	0.5 0.5	0.5 0	.5 0.5	0.5 0.	0.0	0.5 0.	5 0.5	.5 0.5	0.5 0	1.0	0.5 0.	.5 0.5	0.5 (1.0	.5 0.5	0.5 0.	.5 0.5 (0.5 0.5	5 0.5	0.5 0.5	0.5 0.5	0.5 0	.5 0.5	0.5 0.5	0.5	0.5 0.5	0.5 (,.5 0.5	5 0.5	0.5 0.5	, 0.5	0.0	+	++	_	\vdash	++	32.0	<u> </u>
Environmental Specialist	1.0	\vdash		1.0 1.0		+	+	┢┼┤	1.0			0 1 0	1.	0 1 0	1.0	+		+	1.0	\vdash	+	+	1.0	┽╉						+	\vdash	+		\vdash	_	$\left - \right $	+	+		+	+	+	\vdash	_	\vdash	++	7.0	<u> </u>
Legal and Contractual Expert	1.0	\vdash	+	1.0 1.0		+		++	1.0	1.0	1.0 1	.0 1.0		0 1.0	1.0 1	0 1 0	1.0 1.0	1.0	1.0	10-	0 1 0	10 -	1.0	0 1 0	101						\vdash	+		\vdash	_	\vdash	+	+		++		—	\vdash	-	\vdash	++	15.0	<u> </u>
Procurement Materials Control Experts		\vdash	++	+			1012		101			.0 1.0	1.0	0 1.0	1.0 1.	0 1.0	1.0 1.0	1.0	.0 1.0	1.0 1	.0 1.0	1.0 1		.0 1.0	1.0 1.	0 1 0 1	1012		\rightarrow	+	\vdash	+		\vdash	_	\vdash	+	+		+		_	\vdash	_	\vdash	++	22.0	<u> </u>
Document Control and Administration			\square	+		+	1.0 1.0	1.0	1.0 1.0	1.0 1.0	1.0 1	.0 1.0	1.0 1.	.0 1.0	1.0 1.	0 1.0	1.0	1.0	.0 1.0	1.0 1.	.0 1.0	1.0 1	1.0 1.0 1.	.0 1.0	1.0 1.	.0 1.0 1	1.0 1.0	U	+		\vdash	+		\vdash		\square	+	+		++		_	\square		\vdash	++	34.0	—
Supervisors			Ц					\square						\square		$\downarrow \downarrow$		\square								++					Ц	+		\square		\square	\perp			\square			Ц		Щ	\dashv	0.0	
Total																																															303.0	1

Appendix 3-5-1 to 5
Appendix 6-1:Screening Format of JICA's Guidelines for
Environmental and Social Considerations and
JICA's Environmental Checklist for Other Electric
Generation

FR on Preparatory Survey on the Photovoltaic Power Plant Project in A.R.E

Appendix 6-1Screening Format of JICA's Guidelines for Environmental and SocialConsiderations and JICA's Environmental Checklist for Other Electric Generation

JICA's Environmental Checklist for Other Electric Generation (1 of 2)

Category	Environmental Item	Main Check Items	Yes: Y No: N	Confirmation of Environmental Considerations (Reasons, Mitigation Measures)
1 Permits and Explanation	(1) ESIA and Environmental Permits	 (a) Have ESIA reports been already prepared in official process? (b) Have ESIA reports been approved by authorities of the host country's government? (c) Have ESIA reports been unconditionally approved? If conditions are imposed on the approval of ESIA reports, are the conditions satisfied? (d) In addition to the above approvals, have other required environmental permits been obtained from the appropriate regulatory authorities of the host country's government? 	(a)Y (b)N (c)- (d)-	 (a) ESIA (Environmental and Social Impact Assessment) report will be finalized in December 2012. It will be submitted to EEAA (Egyptian Environmental Affairs Agency) soon. (b) It has not been approved yet. (c) Not Applicable (N/A) (d) N/A
	(2) Explanation to the Local Stakeholders	 (a) Have contents of the project and the potential impacts been adequately explained to the Local stakeholders based on appropriate procedures, including information disclosure? Is understanding obtained from the Local stakeholders? (b) Have the comment from the stakeholders (such as local residents) been reflected to the project design? 	(a)Y (b)Y	 (a) Public hearings were held two times. Outline of the project and possible impacts were explained to the local stakeholders. (b) Impact of flood and impact on water resources were anticipated by the local people at the scoping meeting. Then additional topographical survey and detail impact assessments were made. Based on the impact assessment, suitable mitigation measures were taken in cooperated to the project design.
	(3) Examination of Alternatives	(a) Have alternative plans of the project been examined with social and environmental considerations?	(a)Y	(a) Alternatives of module types, cleaning methods, and alternative locations were considered. Environmental and social issues were considered in the alternative comparison.
	(1) Air Quality	 (a) In the case that electric power is generated by combustion, such as biomass energy projects, do air pollutants, such as sulfur oxides (SOx), nitrogen oxides (NOx), and soot and dust emitted by power plant operations comply with the country's emission standards and ambient air quality standards? Are any mitigating measures taken? (b) Do air pollutants emitted from other facilities comply with the country's emission standards? 	(a) - (b) Y	(a) This project is not thermal power system. (b)Gas emission from construction vehicles during construction and gas emission from water pump during operation. But the amount of the gas is expected to be very limited and it will be minimized by periodical check and maintenance plan described in the EMP (Environmental Management Plan, a part of ESIA).
2 Pollution Control	(2) Water Quality	 (a) Do effluents (including thermal effluent) from various facilities, such as power generation facilities comply with the country's effluent standards? Is there a possibility that the effluents from the project will cause areas that do not comply with the country's ambient water quality standards? (b) Do leachates from the waste disposal sites comply with the country's effluent standards and ambient water quality standards? Are adequate measures taken to prevent contamination of soil, groundwater, and seawater by leachates? 	(a) Y (b) -	 (a) The waste water will only be domestic water by workers. The high polluted waste water will not be discharged. (b) Inverters and batteries might contain hazardous substances. Then adequate check will be done for the effluence to prevent soil contamination. EMP suggests suitable treatment, if unusual conditions are confirmed.
	(3) Wastes	(a) Are wastes generated by the plant operations properly treated and disposed of in accordance with the country's regulations (especially biomass energy projects)?	(a) Y	(a) Possible industrial waste is expected to be used PV modules and used batteries. The adequate treatment policies are written in the EMP.
	(4) Soil Contamination	(a) Has the soil in the project site been contaminated in the past? Are adequate measures taken to prevent soil contamination?	(a) Y	(a) No soil contaminations are recorded in the past. The monitoring and inspections are planned in the EMP to prevent soil pollution.
2	(5) Noise and Vibration	 (a) Do noise and vibrations comply with the country's standards? (b) In case of Wind Power Station, does low frequency noise comply with the environmental standard? 	(a) Y (b) -	 (a) The assessed impact noise level fulfill the Environmental standard in Egypt. (b)It is not a wind farm project.
	(6) Subsidence	(a) In the case of extraction of a large volume of groundwater, is there a possibility that the extraction of groundwater will cause subsidence?	(a) N	(a) Water pumping from underground is not planned.
	(7) Odor	(a) Are there any odor sources? Are adequate odor control measures taken?	(a) N	(a) There is no source of odor in the project.
3 Natural Environment	(1) Protected Areas	(a) Is the project site located in protected areas designated by the country's laws or international treaties and conventions? Is there a possibility that the project will affect the protected areas?	(a) N	(a) The project site is outside of the protected area. Although migration birds are moving above the project site, no adverse impact are anticipated because no high facilities are planned.
	(2) Ecosystem	 (a) Does the project site encompass primeval forests, tropical rain forests, ecologically valuable habitats (e.g., coral reefs, mangroves, or tidal flats)? (b) Does the project site encompass the protected habitats of endangered species designated by the country's laws or international treaties and conventions? (c) If significant ecological impacts are anticipated, are adequate protection measures taken to reduce the impacts on the ecosystem? (d) Is there a possibility that localized micro-meteorological changes due to wind power generation will affect valuable vegetation in the surrounding areas (Is there valuable vegetation in the vicinity of the wind power generation facilities)? If impacts on vegetation are anticipated, are adequate measures considered? (e) Are the wind power generation facilities (wind turbines) sited by considering the habitat and migration routes of sensitive or potentially affected bird species? 	(a) N (b) N (c) N (d) - (e) -	 (a) No (b) No (c) No serious ecological impact are anticipated. (d) This project is not a wind farm project. (e) This project is not a wind farm project.
	(3) Hydrology	(a) Is there a possibility that hydrologic changes due to installation of the structures, such as weirs will adversely affect the water flows, waves and tides?	(a) N	(a) The project facilities will not block the water flow might be considered by potential flood from wadies. Then the water system will not be changed.
	(4) Topography and Geology	(a) Is there a possibility that the project will cause a large-scale alteration of the topographic features and geologic structures in the surrounding areas?	(a) N	(a) No

100 - 3 C 2 1 0 f 2

JICA's Environmental Checklist for Other Electric Generation (2 of 2)

Category	Environmental Item	Main Check Items	Yes: Y No: N	Confirmation of Environmental Considerations (Reasons, Mitigation Measures)
4 Social Environment	(1) Resettlement	 (a) Is involuntary resettlement caused by project implementation? If involuntary resettlement is caused, are efforts made to minimize the impacts caused by the resettlement? (b) Is adequate explanation on compensation and resettlement assistance given to affected people prior to resettlement? (c) Is the resettlement plan, including compensation with full replacement costs, restoration of livelihoods and living standards developed based on socioeconomic studies on resettlement? (d) Are the compensations going to be paid prior to the resettlement? (e) Are the compensation policies prepared in document? (f) Does the resettlement plan pay particular attention to vulnerable groups or people, including women, children, the elderly, people below the poverty line, ethnic minorities, and indigenous peoples? (g) Are agreements with the affected people obtained prior to resettlement? (h) Is the organizational framework established to properly implement resettlement? Are the capacity and budget secured to implement the plan? (i) Are any plan developed to monitor the impacts of resettlement? 	(a) N (b) - (c) - (d) - (e) - (f) - (g) - (h) - (i) - (j) -	 (a) No resettlement is required under this project. (b) N/A (c) N/A (d) N/A (e) N/A (f) N/A (g) N/A (h) N/A (i) N/A (j) N/A
	(2) Living and Livelihood	 (a) Is there a possibility that the project will adversely affect the living conditions of inhabitants? Are adequate measures considered to reduce the impacts, if necessary? (b) Is there a possibility that the amount of water (e.g., surface water, groundwater) used and discharge of effluents by the project will adversely affect the existing water uses and water area uses? 	(a) N (b) N	 (a) Dust pollution will temporally be happened during construction stage because of the construction vehicles. But some mitigation measures such as speed limitations are suggested in the ESIA. (b) Impact on water resources are assessed because the fresh water will be used for module cleaning during operation. But the amount of the water is no so much. Then no serious impacts are anticipated.
	(3) Heritage	(a) Is there a possibility that the project will damage the local archeological, historical, cultural, and religious heritage? Are adequate measures considered to protect these sites in accordance with the country's laws?	(a) N	(a) No
	(4) Landscape	(a) Is there a possibility that the project will adversely affect the local landscape? Are necessary measures taken?	(a) N	(a) There is no special view and/or landscape around the project site.
	(5) Ethnic Minorities and Indigenous Peoples	 (a) Are considerations given to reduce impacts on the culture and lifestyle of ethnic minorities and indigenous peoples? (b) Are all of the rights of ethnic minorities and indigenous peoples in relation to land and resources respected? 	(a) - (b) -	 (a) There is no impact on the lifestyle of the ethnic minorities and indigenous people. (b) There is no impact on the natural resources of the ethnic minorities and indigenous people.
	(6) Working Conditions	 (a) Is the project proponent not violating any laws and ordinances associated with the working conditions of the country which the project proponent should observe in the project? (b) Are tangible safety considerations in place for individuals involved in the project, such as the installation of safety equipment which prevents industrial accidents, and management of hazardous materials? (c) Are intangible measures being planned and implemented for individuals involved in the project, such as the establishment of a safety and health program, and safety training (including traffic safety and public health) for workers etc.? (d) Are appropriate measures taken to ensure that security guards involved in the project not to violate safety of other individuals involved, or local residents? 	(a) Y (b) Y (c) Y (d) Y	 (a) Minimizing impact on workers are proposed in the ESIA. (b) Electrical facilities are designed based on Japanese safety standard. Then precautions for industrial accidents are fully considered. (c) Training for the workers are planned in the EMP. (d) Security guards are currently working on the site and there is no confliction between surrounding area.
	(1) Impacts during Construction	 (a) Are adequate measures considered to reduce impacts during construction (e.g., noise, vibrations, turbid water, dust, exhaust gases, and wastes)? (b) If construction activities adversely affect the natural environment (ecosystem), are adequate measures considered to reduce impacts? (c) If construction activities adversely affect the social environment, are adequate measures considered to reduce impacts? 	(a) Y (b) - (c) -	 (a) Mitigation measures for noise, dust, exhaust gases during construction are suggested in the ESIA. (b) There is no serious adverse impact on ecology during construction. (c) There is no serious adverse impact on social aspects during construction
5 Others	(2) Monitoring	 (a) Does the proponent develop and implement monitoring program for the environmental items that are considered to have potential impacts? (b) What are the items, methods and frequencies of the monitoring program? (c) Does the proponent establish an adequate monitoring framework (organization, personnel, equipment, and adequate budget to sustain the monitoring framework)? (d) Are any regulatory requirements pertaining to the monitoring report system identified, such as the format and frequency of reports from the proponent to the regulatory authorities? 	(a) Y (b) - (c) Y (d) N	 (a) Monitoring plan is mentioned in the EMP. (b) Monitoring items, methods, and frequencies are adequately defined in the EMP. (c) Monitoring cost is estimated in the EMP. (d)Not yet developed. Reporting frequencies are not mentioned in the EMP.

	Reference to Checklist of Other Sectors	(a) Where necessary, pertinent items described in the Power Transmission and Distribution Lines checklist should also be checked (e.g., projects including installation of electric transmission lines and/or electric distribution facilities).	(a) -	(a) Transmission and Distribution lines are not included in the project.
6 Note				
5 NOLE	Note on Using Environmental Checklist	(a) If necessary, the impacts to transboundary or global issues should be confirmed (e.g., the project includes factors that may cause problems, such as transboundary waste treatment, acid rain, destruction of the ozone layer, or global warming).	(a) -	(a) N/A

1) Regarding the term "Country's Standards" mentioned in the above table, in the event that environmental standards in the country where the project is located diverge significantly from international standards, appropriate environmental considerations are required to be made.

In cases where local environmental regulations are yet to be established in some areas, considerations should be made based on comparisons with appropriate standards of other countries (including Japan's experience).

2) Environmental checklist provides general environmental items to be checked. It may be necessary to add or delete an item taking into account the characteristics of the project and the particular circumstances of the country and locality in which the project is located.

Mede Sa 2 of 2

Screening Format of JICA'S GUIDELINES FOR ENVIRONMENTAL AND SOCIAL CONSIDERATIONS

Name of Proposed Project:

. .

.

THE PHOTOVOLTAIC POWER PLANT PROJECT IN THE ARAB REPUBLIC OF EGYPT

Project Executing Organization, Project Proponent or Investment Company:

New & Renewable Energy Authority (NREA)

Name, Address, Organization, and Contact Point of a Responsible Officer:

Name: Eng. Afaf Meakhail Tawfic Address: Dr. Ibrahim Abu El-Naga St., Ext. Abbass El-Akkas St., Nasr City, Cairo, Egypt. Organization: New & Renewable Energy Authority (NREA) Tel: (202) 22710081 Fax: (02) 227 122 67 E-Mail: afaftawfic@hotmail.com

Date: $\frac{2}{10} \frac{20}{20} \frac{2}{2}$ Signature: $\frac{1}{10} \frac{10}{10} \frac{20}{10} \frac{2}{20}$

Check Items

Please write "to be advised (TBA)" when the details of a project are yet to be determined.

Question 1: Address of project site

The project is planned to be located in the northern part of Hurghada city, along Hurghada –Ras_Garib road, on the site of Hurghada wind farm owned by NREA.

Question 2: Scale and contents of the project (approximate area, facilities area, production, electricity generated, etc.)

2-1. Project profile (scale and contents)

This is a 20MW Photovoltaic (PV) power plant. The materials and equipment are as follows.

- 20 MW PV modules (as temporary solution the following mixture arrangement is anticipated; 18 MW to be selected from Polycrystalline type, 1MW to be selected from Multi-Layer Thin Film type and 1 MW to be selected from CIS type) with accessories such as terminal boxes, DC power cables, optic fiber cables, supporting structures for PV modules, etc.
- Electrical equipment for PV power plant including Inverters (500kVA * 40 units), step-up transformers (400V/22kV, 2MVA, 10 units), switchgears, cables, etc.
- Electrical equipment for existing Distribution Point including MV switchgears, buscouplers, terminal units, etc.
- High performance battery (Sodium Sulfur or Lead battery, 2MW, 12MWh)
- Monitoring systems including server, communication interface, UPS, etc.
- Exhibition system including sophisticated 3 D and/or 2D screens, etc.

2-2. How was the necessity of the project confirmed?

Is the project consistent with the higher program/policy?
☑YES: Please describe the higher program/policy.
(The strategy for the electricity generation (February 2008))

□NO

2-3. Did the proponent consider alternatives before this request?

☑YES: Please describe outline of the alternatives (No Development Alternative, Alternative Site Location, Alternative Electricity Generating Renewable Energy Technologies, Alternative PV Types, Alternative panel cleaning, and Energy Storage batteries are considered.)

□NO

2

pr- 1A

2-4. Did the proponent implement meetings with the related stakeholders before this request?

☑Implemented □Not implemented

If implemented, please mark the following stakeholders.

☑ Administrative body
☑ Local residents
☑ NGO
□ Others ()

2-5 Does the project include any of the following items?

🗆 Yes 🛛 No

If yes, please mark the items included in the project.

□Involuntary resettlement (scale: households persons)

□Groundwater pumping (scale: m3/year)

□Land reclamation, land development, and/or land-clearing (scale:

hectors)

□Logging (scale: hectors)

Question 3:

Is the project a new one or an ongoing one? In the case of an ongoing project, have you received strong complaints or other comments from local residents?

New

□Ongoing (with complaints)

□Ongoing (without complaints)

□Other

Question 4:

Is an Environmental Impact Assessment (EIA), including an Initial Environmental Examination (IEE) Is, required for the project according to a law or guidelines of a host country? If yes, is EIA implemented or planned? If necessary, please fill in the reason why EIA is required.

☑Necessity (□Implemented ☑Ongoing/planning)

(Reason why EIA is required: Egyptian Environmental Affairs Agency (EEAA) requirments.

□Not necessary

 \Box Other (please explain)

N. 14 MP

Question 5:

. .

In the case that steps were taken for an EIA, was the EIA approved by the relevant laws of the host country? If yes, please note the date of approval and the competent authority.

)

□ Approved without a supplementary condition

Approved with a supplementary condition

□Under appraisal

(Date of approval: Competent authority:

Under implementation

□Appraisal process not yet started

)

□Other (

Question 6:

If the project requires a certificate regarding the environment and society other than an EIA, please indicate the title of said certificate. Was it approved?

 \Box Already certified

Title of the certificate: ()

Requires a certificate but not yet approved

☑Not required

□Other

Question 7:

Are any of the following areas present either inside or surrounding the project site?

□Yes **②**No

If yes, please mark the corresponding items.

□National parks, protection areas designated by the government (coastline, wetlands, reserved area for ethnic or indigenous people, cultural heritage) □Primeval forests, tropical natural forests

Ecologically important habitats (coral reefs, mangrove wetlands, tidal flats, etc.)

□Habitats of endangered species for which protection is required under local laws and/or international treaties

□ Areas that run the risk of a large scale increase in soil salinity or soil erosion

□Remarkable desertification areas

□Areas with special values from an archaeological, historical, and/or cultural points of view

□Habitats of minorities, indigenous people, or nomadic people with a traditional lifestyle, or areas with special social value

N-H

Question 8:

× 9

Does the project include any of the following items?

□Yes ☑No

If yes, please mark the appropriate items.

□Involuntary resettlement (scale: households persons)

□Groundwater pumping (scale: m3/year)

□Land reclamation, land development, and/or land-clearing (scale: hectors)

□Logging (scale: hectors)

Question 9:

Please mark related environmental and social impacts, and describe their outlines.

□Involuntary resettlement

 \Box Air pollution

Local economies, such as employment, livelihood, etc.

□Water pollution

□Soil pollution

□Land use and utilization of local resources

☑Waste

 \Box Noise and vibrations

 \Box Social institutions such as social infrastructure and local decision-making

institutions

□Ground subsidence

 \Box Offensive odors

□Geographical features

Existing social infrastructures and services

□ Bottom sediment

□Biota and ecosystems

Poor, indigenous, or ethnic people

☑ Water usage

□Misdistribution of benefits and damages

Accidents

□Local conflicts of interest

□Global warming

□Limitation of accessibility to information, meetings, etc. on a specific person or group

□Gender

N.H.

□Children's rights □Cultural heritage □Infectious diseases such as HIV/AIDS □Other () Outline of related impact:

Question 10:

In the case of a loan project such as a two-step loan or a sector loan, can sub-projects be specified at the present time?

□Yes **☑**No

Question 11:

Regarding information disclosure and meetings with stakeholders, if JICA's environmental and social considerations are required, does the proponent agree to information disclosure and meetings with stakeholders through these guidelines?

☑Yes □No

m whet