



Annex:

- Annex-1 Project Sites
- Annex-2 Components of the Project
- Annex-3 Selected Sites
- Annex-4 Organization Chart of the Responsible Organization
- Annex-5 Project Cost Estimation



[Handwritten signatures]





Location Map of the Target Sites
 The Preparatory Survey for the Project for Small Town Water Supply in Southern Part of the Amhara Regional State

Japan International Cooperation Agency
 3

Ministry of Finance and Economic Development
 Republic of Ethiopia

Amhara Regional Water Resources Development Bureau

Components of the Project

1. Construction of Water Supply Facilities: 9 towns as listed below

No.	Town	Population (2016)	Water supply amount (2016)
9	Mertule Maryam	17,829	328.97 m ³ /day
10	Yetimen	3,877	74.33 m ³ /day
12	Lumame	13,451	255.17 m ³ /day
14	Wojel	3,758	121.22 m ³ /day
15	Sedie	3,947	87.99 m ³ /day
16	Dibo	2,510	89.22 m ³ /day
	Amanuel	12,694	86.40 m ³ /day
27	Gobeze Maryam	6,908	114.00 m ³ /day
	Bikolo	5,811	181.43 m ³ /day
	Total	70,786	1,338.73 m ³ /day

2. Technical Assistance consisting of:


- To facilitate AWRDB and Woreda water office on the effective support system in proper management of Water Management Organization (WMO)
- To institutionalize the operation and maintenance structures of WMO
- To secure general understanding among the stakeholders on the operation and maintenance structures
- To conduct technical trainings on the maintenance and repair of the facilities (implemented by EWTEC)
- To conduct technical trainings on administrative tasks such as accountancy, book keeping and reporting
- To assist WMO conducting monitoring and evaluation, modification of the plan



Annex-3




Selected Target Sites

No.	Zone	Woreda	Town
9	East Gojam	Enebsie Sar Midir	Mertule Maryam
10	East Gojam	Enemay	Yetimen
12	East Gojam	Awabel	Lumame
14	East Gojam	Awabel	Wojel
15	East Gojam	Hulet Egu Enesie	Sedie
16	East Gojam	Enebsie Sar Midir	Dibo
	East Gojam	Machakel	Amanuel
27	West Gojam	Quarit	Gobeze Maryam
	West Gojam	Macha	Bikolo



[Handwritten signatures and initials]

Organization Chart of the Responsible Organization



Handwritten signatures and initials.

Appendix 5
Soft Component
(Technical Cooperation) Plan

The Project for Small Town Water Supply in Southern Part of the Amhara Regional State Soft Component (Technical Assistance) Plan

(1) Background of Planning the Soft Component

1) Present Situation and the Problem

In the target sites, the structure of operation and maintenance (O&M) for water supply facilities by existing Water Management Organization (WMO). However, the capability of planning to reserve O&M fee, collecting and managing water fee, and operating the water supply facilities are poor. The water supply facilities are left unrepaired and unattended, causing minor accidents. In the meantime, the role of Woreda water office of regular maintenance in order to avoid the accidents before they happen is not clear, and the budget and manpower are also insufficient. Therefore, the current problems of O&M by WMO are as follows:

- The structure of O&M is not secured.
- WMO cannot correspond to equipment operation and minor repairs.
- The capability of collecting and managing water fee (O&M cost) is poor by WMO.

2) Necessity of Soft Component

As mentioned above, there is the structure of O&M by existing WMO, however the capability of planning to reserve O&M fee, collecting and managing water fee, and operating the water supply facilities are poor. And the capability of minor repairs is also poor. The water supply facilities in the Project are planned as the composition and scale in order to conduct O&M by WMO, however, the structure of O&M and technique of existing WMO are poor. Therefore, in order to secure the commencement of the Project smoothly, technical assistance is given in the soft component, and supports to strengthen of the capability of O&M of WMO and Woreda water office. In the target sites, water supply facilities exist, hygiene philosophy is already made in the habitants; therefore hygiene education is not conducted in the soft component. The contents of technical support is placed priority on strengthening the capability of O&M (soft side); however, technical support of equipment operation and minor repairs (hard side) is also conducted in cooperation with the Ethiopian Water Technology Centre (EWTEC).

(2) Objective of Soft Component

1) Objective

The objective of soft component is for O&M to be properly conducted by WMO. Moreover, the overall goal is defined as: long-term utilization of the constructed facilities after completion of the Project. In other words, the target is that the facilities will be utilized sustainably by O&M of the WMO after the completion of the Project. Project Design Matrix (PDM) of soft component is shown below.

PDM (Soft component)

Summary of the Project	Indicator	Measurement	External condition
<u>Overall goal</u> Long-term utilization of facilities after completion of the Project.	Decline of percentage of the water-born disease rate of residents.	* Statistical report about health hygiene. * Result of the questionnaire to residents	
<u>Target of the Soft Component</u> Operation and maintenance are properly conducted by WMO	* All facilities in Project area work throughout the year * Increase safe water supply population in Project area.	* Operation records of the facilities * Log of facility users	AWRDB does not change the policy of O&M by WMO
<u>Output</u> 1. Executive system of the operation and maintenance of the facilities will be established.	1.1 The consciousness of the implementing agency of the need for citizen participation in O&M is increased and a concrete support system for the VWC is developed. 1.2 The VWC of residents is formed or reorganized in each village. 1.3 Each organization and all residents concerned have a clear understanding of their roles.	* Questionnaire to persons concerned * Workshop Report * Chart of support system for O&M * User rules * Organization Chart for WMO * O&M plan * Questionnaire to persons concerned * Organization Chart for all concerned	Organization concerned have no objection against the fact facilities are operated by residents.
2. The concerned organizations acquire the necessary skills and knowledge for operation and maintenance.	2.1 The period of breakdown is shortened and the frequency of breakdown is reduced. 2.2 The records of administration containing the fee collection are prepared in the WMO. 2.3 The monitoring and evaluation for the activities are carried out and reflected in the activities of the soft component	* Records of the activities of the organization concerned * Operation records of the facilities * Report of the technical training * Maintenance and repair regulations * Log of fee collection * Log of facility users * Implement report of soft component	
Activities			Precondition
1.1 Formulate a support system of AWRDB and Woreda 1.2 Formulate the O&M activities 1.3 Obtain an understanding of the O&M activities 2.1 Conduct the technical training (hard side) for the maintenance and repair of the facilities 2.2 Conduct the technical training (soft side) of administrative tasks such as accountancy, record keeping and reporting 2.3 Conduct monitoring, evaluation and modification of the plan			All organizations concerned take an active part in the Project.

2) Considerations for the Support System

In the Project, O&M by the WMOs will be conducted for each site in two (2) phases: “Phase 1: Establishment of executive system,” which is to be undertaken before the construction of facilities”, and “Phase 2: Acquisition of O&M skills” during the construction. Concerning the technical O&M of the facilities, two (2) instructors from the Ethiopian Water Technology Centre (EWTEC) conducted the technical training for all persons concerned.

(3) Output of Soft Component

The expected outputs of the Soft Component are summarized as follows:

Output 1: Executive system of the O&M of the facilities will be established

The existing facilities are operated by the WMO of each site. But they cannot cope with various problems like repairs of malfunctions or inability of users to pay water rates. Other organizations such as AWRDB and Woreda water offices are in a position to fulfill this role, but their concrete support system also has not functioned smoothly.

With the soft component, the concrete support system will be established after reviewing the function of each organization with regard to WMO. In addition, concrete outcomes of the soft component will be ensured by establishing a plan of O&M which includes specific rules for the use of facilities.

Output 2: The concerned organizations acquire the necessary skills and knowledge for O&M

In order to conduct O&M by the WMO, it is necessary to compensate for the current lack of technical skills. After establishing a support system by administrative agency, the technical training (on hard and soft sides) for the persons in charge at the WMO and Woreda is executed to ensure they acquire the capacity to cope with concrete problems. With the technical training on hard side, the WMO will have the ability to repair slight troubles and if WMO is unable to handle a repair, the Woreda will be given the capacity to repair complicated problems. Consequently, the role of each organization will be clearly defined under the executive system of O&M. In addition, for O&M to be truly sustainable, it is paramount that the facility utilization fees are collected and managed properly. Therefore the chairman and accountants of WMO and Woreda will receive technical training on methods of accounting management (soft side).

Furthermore, in order to keep records of facilities usage and work done, the persons in charge at WMO and Woreda are given training on this and how to produce the records. The records made by WMO are presented to AWRDB through Woreda. With this joint information, the problems of fee collection or leaving facilities broken down will decrease.

(4) Indicator of Output Achievement

The indicator and measurement used to confirm the achievement of the two (2) output items are given in the table below.

Indicator of output achievement

Output	Indicator	Measurement
Executive system of the O&M of the facilities will be established.	1. The consciousness of the implementing agency of the need for citizen participation in O&M is increased and a concrete support system for the WMO is developed.	<ul style="list-style-type: none"> ● Questionnaire to person concerned ● Workshop Report ● Organization Chart for O&M ● User rules
	2. The WMO of residents is formed or reorganized in each village.	<ul style="list-style-type: none"> ● Organization Chart for WMO ● O&M plan
	3. Each organization and all residents concerned have a clear understanding of their roles.	<ul style="list-style-type: none"> ● Questionnaire to person concerned ● Organization Chart of all concerned
The concerned organizations acquire the necessary skills and knowledge for O&M.	1. The period of breakdown is shortened and the frequency of breakdowns is reduced.	<ul style="list-style-type: none"> ● Records of the agency concerned ● Operation records of the facilities ● Technical training report ● Maintenance and repair regulations
	2. The records of administration containing the fee collection are prepared by the WMO.	<ul style="list-style-type: none"> ● Log of fee collection ● Log of utilization
	3. The monitoring and evaluation for the activities are carried out and reflected in the activities of the soft component	<ul style="list-style-type: none"> ● Monitoring/evaluation records ● Soft component report

(5) Plan of Soft Component Activities (Input Plan)

1) Division of the Activities

The Soft Component activities are categorized into two (2) phases: 1-Before construction and 2-During construction and after completion of main facilities. The activities will be carried out by the Japanese consultant with the cooperation of regional government staff such as AWRDB and Woreda. As to the technical training like inspection and repair of the facilities, it will be implemented with the cooperation of EWTEC.

2) Division of Roles

The role of the Japanese consultant and Woreda staff and EWTEC instructors are summarized as follows:

Japanese Consultant

Overall responsibility for the Soft Component, and is in charge of:

- Supervision and implementation of this Project.
- Activities for commencing a workshop and a seminar.
- Meetings with AWRDB and implementation of workshops for Woreda staff.
- Cooperating and communicating with other donors and NGOs.
- Preparation of the support system for WMO of AWRDB and Woreda.

- Conduct a technical training (hard side) for the maintenance and repair of the facilities by EWTEC instructors.
- Technical training (soft side) for the administration.
- Preparation of O&M manual.
- Assistance for the drafting of all rules.
- Assistance for a preparation of all records.
- Monitoring of the activities and review of the evaluation.
- Review and the feedback of the results of each activity in each phase.
- Report to the AWRDB and JICA.

Woreda Staff

Woreda staff will take part continuously in the entire Project, taking charge of activities to execute the work plan. During the Japanese consultant's absence, Woreda staff will keep a constant check on the progress of each activity. And also when the Japanese consultant is on site, they will arrange with the organization concerned and assist the activities.

- Support the establishment of WMOs by citizens in villages with water facilities.
- Organize resident meetings in each village.
- Confirm the situation of O&M in each site and report to the Japanese consultant.
- Organize the technical training (hard side) by EWTEC instructors.
- Cooperative support and regular inspection for the O&M of WMO.
- Assist the monitoring to the persons concerned.
- Adjustment with the organization concerned in absence of the Japanese consultant.

EWTEC instructors

EWTEC instructors, as part of technical training (hard side) for the Woreda staff and WMO staff, are to teach:

- Basic knowledge about the new facilities.
- Method of the daily inspection.
- Method in case of failure (in case of slight damage and serious damage).
- Purchase of spare parts of the facilities.
- Rules of the facilities user.
- Cleaning of the facilities.

(6) Plan of the activities

The concrete content of the activities is as follows.

<Before the construction of main facilities - Establishment of executive system>

Activity 1-1: Formulate a Support System of AWRDB and Woreda for the WMO

At the beginning of the Project, discussions will be held with the implementing agency, AWRDB concerning the objective, necessity and content of the Project, as well as the implementation plan.

Then a workshop will be held targeting the Woreda staff directly responsible for O&M activities in order to understand the condition of usage for the existing facilities, and the necessity and importance of O&M by the residents.

Through this workshop, Woreda staff will acquire the techniques needed to encourage resident participation by staff of WMO and the residents. Japanese consultants produce the organization chart after considering the relation with the WMO and the clarification of the problem at the hearing for Woreda staff. Additionally, the concrete plan for the management system including the membership which is selected in Activity 1-2, their role, the method of member selection, the management resources, and the user regulation will be formulated by the Japanese consultant and Woreda staff.

Target participants:	AWRDB staff and Woreda staff
Implementer:	Japanese consultant (10 days), Vehicle
Output:	Organization chart for the support system

Activity 1-2: Formulate the O&M activities of WMO

A workshop will be held in order to make sure of the function and clarify the problems of the nine (9) sites in which the new facilities will be constructed. Considering the results, under the leadership of Woreda staff, the appropriate membership for the future O&M, its role, and the method of member selection should be presented to get the understanding for the current staff.

With regard to the implementation of O&M, the relation between WMO and residents will be reconsidered, and a plan that is appropriate to the level of cooperation and capacity of each WMO will be drafted prior to the next resident committee meeting. Especially regarding the remuneration of organization staff and the resources of management, the appropriate water fee, the method of collection, should be determined at this Stage 1-2 to submit to the resident committee at the Activity 1-3.

Target participants:	WMO Staff
Implementer:	Japanese consultant (9 days), Woreda staff (9 days), Vehicle
Outputs:	Organization chart for WMO, Draft of O&M activities

Activities 1-3: Obtain an understanding of the O&M activities

A workshop will be held targeting the residents based on the results of 1-1, 1-2 activities after explaining the short summary of O&M by Woreda staff who control each site. Through this workshop, it is necessary for the residents to understand the environmental management of the facilities for the sustainable water supply services, the importance of the participation in O&M for facilities according to the user rules, especially the necessity for the collection of the water fee. WMO staff will provide the draft of O&M that they compiled in Activity 1-2, and ask the residents for their cooperation.

Target participants:	Residents, Village council
Implementer:	Japanese consultant (9 days), Woreda staff (9 days), WMO staff (9 days), Vehicle

<During construction to after completion of main facilities - Acquirement of skills of the O&M>

Activity 2-1: Conduct technical training for the maintenance and repair of the facilities

EWTEC instructors are to teach through on-the-job training (OJT) the Woreda staff and the WMO member in charge of management of the facilities: basic knowledge for technical training, the method of O&M, the method of daily maintenance, how to deal with breakdowns and techniques for minor repairs. This technical training will be conducted three (3) times, after construction is completed at the third, sixth and ninth (and final) site.

At the end of training, the repair manual for the malfunctions and operation record produced by the consultants shall be distributed to the related personnel so that they can practice the regular O&M measures by using the techniques and knowledge of O&M.

Target participants:	Woreda staff, WMO staff
Implementer:	EWTEC instructors (21 days x 2 persons), Japanese consultant (15 days), Vehicle
Outputs:	Repair manual for the malfunctions, Activity record, Facility's operation record, Technical training report

Activity 2-2: Conduct technical training of administrative tasks such as accountancy, record keeping and reporting

In order to acquire the techniques of O&M for facilities, Woreda staff, WMO staff and accountants receive OJT from consultants who are expert in the abovementioned fields. In the OJT, technical training concerning the administrative task as described below will be conducted.

- Setting a water facility utilization fee
- Fee collection management methods
- Expense of facility management
- Remuneration for staff

- Cost of spare parts in case of repair
- Method of calculation for repair fee
- Operation of facility, and
- Method of recording for operation.

Same as the Activity 2-1, manual concerning the administrative task, financial records for the collection fee would be formulated beforehand by the consultants. In case of any changes in the manual, modification should be done and distributed to the related persons.

Target participants:	Woreda staff, WMO staff, Residents
Implementer:	Japanese consultant (12 days), Vehicle
Outputs:	Manual for O&M, Financial records for the collection fee, Log of utilization

Activity 2-3: Conduct monitoring and evaluation, modification of the plan

Monitoring and evaluation will be conducted by the related persons in order to confirm if the result of technical training regarding O&M facilities and administrative tasks is reflected in the activity faithfully. Japanese consultant provides the related person some guidance so that they can use the result for the activity of next site. Additionally after the completion of the Project, the related persons themselves will continue the monitoring and evaluation, and modify the plan of O&M on each occasion, as necessary.

Target participants:	Woreda staff, WMO staff, Residents
Implementer:	Japanese consultant (10 days), Vehicle
Outputs:	Monitoring plan

Contents of soft component activity

	Activity Items	Feature	Target Audience	Implementer
Preparation of Executive system	1.1 Formulate a support system of AWRDB and Woreda for the WMO	Meeting Workshop	AWRDB Woreda	Japanese consultant
	1.2 Formulate the O&M activities of WMO	Workshop	WMO	Japanese consultant Woreda staff
	1.3 Obtain an understanding of the O&M activities.	Resident meeting OJT	Inhabitants	Japanese consultant Woreda staff WMO staff
Acquisition of the skills for O&M	2.1 Conduct technical training for the maintenance and repair of the facilities	Seminar OJT	Woreda WMO	Japanese consultant EWTEC staff
	2.2 Conduct technical training of administrative tasks such as accountancy, record keeping and reporting	Seminar OJT	Woreda WMO	Japanese consultant
	2.3 Conduct monitoring, evaluation, and modification of the plan	Monitoring/ Evaluation	Woreda WMO	Japanese consultant

(7) Supply a human resources for the Soft Component


The Project will be under the supervision of the Japanese consultant, however the technical training (on-the-job training) on various O&M and repair tasks will be conducted with the cooperation of EWTEC; meanwhile the persons in charge at Woreda and WMO will support training in each activity.

(8) Implementation Schedule

1) Implementation Content

It is proper that some activities shall be implemented before commencement of construction, therefore the activities to be implemented in the soft component are divided into the following two (2) phases: “Phase 1: Before construction (28 days)” and “Phase 2: During construction (37 days)”. The period of activity of the Japanese consultant will be assumed 65 days. Either the persons in charge at the WMO or in the Woreda office will accompany the Japanese consultants to participate in each activity at the various sites.

The technical training by EWTEC will be implemented over five days, and the Japanese consultant will accompany all this period to prepare a manual of technical maintenance. In addition, the monitoring and evaluation will be implemented by the persons concerned under the supervision of the Woreda staff.



- The percentage of the activities that the Japanese consultant is involved
- The percentage of the activities that the implementation agency is involved
- The percentage of the activities that the EWTEC is involved

Conceptual plan for the implementation of O&M

Basis for calculating the necessary number of days for the soft component

Phase 1 (before construction)	Phase 2 (During construction - after completion of main facilities)	Phase 3 (towns)	Activities No.	Activity items	Target Audience	Implementer	Numbers of days for the works		Number of days to transfer		Total	
							Japanese consultant (1)	Local staff (EWTEC×2)	Japanese consultant (1)	Local staff (EWTEC×2)	Japanese consultant (1)	Local staff (EWTEC×2)
1. Establishment of executive system			1-1	Formulate a support system of A WRDB and Woreda for the WMO	AWRDB staff Woreda staff	Japanese consultant	10					
			1-2	Formulate the O&M activities of WMO	WMO staff	Japanese consultant Woreda staff	9		4		32	
			1-3	Obtain an understanding of the O&M activities.	Residents Village council	Woreda staff WMO staff Japanese consultant	9					
2. Acquisition of skills of the operation and maintenance	1st Term (3 towns)		2-1	Conduct the technical training (hard side) for the maintenance and repair of the facilities		EWTEC instructors Japanese consultant	5	5	2			14
			2-2	Conduct the technical training of administrative tasks such as accountancy, record keeping and reporting	WMO staff Woreda staff	Japanese consultant	4		4		18	
			2-3	Conduct monitoring and evaluation, modification of the plan.		Japanese consultant	5					
	2nd Term (3 towns)		2-1	Conduct the technical training (hard side) for the maintenance and repair for the facilities		EWTEC instructors Japanese consultant	5	5	2			14
			2-2	Conduct the technical training of accountant, record, report concerning administration.	WMO staff Woreda staff	Japanese consultant	4		4		18	
			2-3	Conduct monitoring and evaluation, modification of the plan.		Japanese consultant	5					
	3rd Term (3 towns)		2-1	Conduct the technical training (hard side) for the maintenance and repair for the facilities		EWTEC instructor Japanese consultant	5	5	2			14
			2-2	Conduct the technical training of administrative tasks such as accountancy, record keeping and reporting	WMO staff Woreda staff	Japanese consultant	4		4		13	
			2-3	Conduct monitoring and evaluation, modification of the plan.		Woreda staff						
						65	30	16	12	81	42	

2) Examination of validity of the number of and term of dispatches of the Japanese consultant

Japanese consultants will be dispatched four times into the field for O&M activities, and after considering the contents and the timing of execution, the activities will be conducted in two (2) phases; “Preparation of executive system” and “Acquisition of the skills for O&M”.

The Japanese consultant will participate in all of the activities intended for the implementation organization. In the first phase, it is important to make an agreement with the persons concerned, and so it is necessary to confirm the activities in each period by the Japanese consultant. Similarly in phase 2, the Japanese consultant should stay at the site for the entire time during each activity to prepare a manual and records, and to give advice on the running of the OJT. Therefore, the dispatch term and the number of times of dispatches of the Japanese consultant are considered appropriate for the Project.

(9) Outputs of the soft component activities

The documents as outputs of the Project are as follows:

- Organizational framework of support system (Activity 1-1)
- User rules (Activity 1-1)
- Organizational framework of WMO (Activity 1-2)
- O&M plan (Activity 1-2)
- Repairing manual (Activity 2-1)
- Activity records (Activity 2-1)
- Operating records of facilities (Activity 2-1)
- Technical training report (Activity 2-1)
- O&M manual (Activity 2-2)
- Account book of water rates (Activity 2-2)
- Log of utilization (Activity 2-2)
- Monitoring plan (Activity 2-3)
- Implementation report of soft component (for each dispatch period of Japanese consultants)
- Final report (to be submitted to Ethiopian and Japanese sides after Project completion)

(10) Obligation of Recipient Country

In the implementation of the soft component, the concerned organization of recipient country is required to undertake certain measures, as follows:

- Supervision during the entire program in cooperation with the Japanese consultant.
- Reports to the upper level organizations concerned.
- Request for cooperation to other organizations concerned in carrying out the soft component.
- Provide staff of the organization concerned and cover their expense for the activities in the field, transportation, their daily allowance and accommodation charge.
- Coordination of lectures of technical training by the instructor of EWTEC.
- Burden of the working expenses for the preparation of the workshop space and for the joint committee meeting.

Appendix 6 Other Relevant Data

6-1 Collected Data List

No.	Item	Configuration	Original / Copy	Issuing Institution	Year	
1	Hydrogeological Map of Northern Ethiopia, S=1/1,000,000	Hydrogeological Map	Drawing / Electronic File	Copy	GSE	2002
2	Regional Hydrogeological Investigation of Northern Ethiopia	Instruction Manual	Electronic File	Copy	GSE	2003
3	Geological Map of the Bahir Dar Area (NC37-1), S=1/250,000	Geological Map	Drawing / Electronic File	Copy	GSE	2010
4	Geology Geochemistry and Gravity Survey of the Bahir Dar Area	Instruction Manual	Electronic File	Copy	GSE	2010
5	Geological Map of the Debre Tabor Area (NC37-2), S=1/250,000	Geological Map	Drawing / Electronic File	Copy	GSE	2010
6	Geology Geochemistry and Gravity Survey of the Debre Tabor Area	Instruction Manual	Electronic File	Copy	GSE	2010
7	Geological Map of the Bure (NC37-5), S=1/250,000	Geological Map	Drawing / Electronic File	Copy	GSE	2007
8	Geology of Bure map Sheet (NC37-5)	Instruction Manual	Electronic File	Copy	GSE	2007
9	Geological Map of Debre Marcos Sheet (NC37-6), S=1/250,000	Geological Map	Drawing / Electronic File	Copy	GSE	2009
10	Topographic Map, S=1/250,000, EMA3, NC37-1, Bahir Dar	Topographical Map	Drawing	Copy	EMA	1996
11	Topographic Map, S=1/250,000, 1502, NC37-2, Debre Tabor	Topographical Map	Drawing	Copy	EMA	1972
12	Topographic Map, S=1/250,000, EMA3, NC37-5, Bure	Topographical Map	Drawing	Copy	EMA	1995
13	Topographic Map, S=1/250,000, EMA3, NC37-6, Debre Mark'os	Topographical Map	Drawing	Copy	EMA	1995
14	Topographic Map, S=1/50,000, ETH4, , Debre Mark'os	Topographical Map	Drawing	Copy	EMA	1995
15	Topographic Map S=1/50,000, ETH 4 1037 A2 DABI (Gebez Maryam)	Topographical Map	Drawing	Copy	EMA	1987
16	Topographic Map S=1/50,000, ETH 4 1037 A3 BURE (Mankusa, Kuchie)	Topographical Map	Drawing	Copy	EMA	1987
17	Topographic Map S=1/50,000, ETH 4 1037 B2 KERANIYO (Keranyo, Sedie)	Topographical Map	Drawing	Copy	EMA	1984
18	Topographic Map S=1/50,000, ETH 4 1037 C1 KUCH (Kuchie)	Topographical Map	Drawing	Copy	EMA	1987
19	Topographic Map S=1/50,000, ETH 4 1037 D2 AMBER (Amberi, Lumamie)	Topographical Map	Drawing	Copy	EMA	1984
20	Topographic Map S=1/50,000, ETH 4 1037 D4 LUMAME (Amberi, Lumamie)	Topographical Map	Drawing	Copy	EMA	1984
21	Topographic Map S=1/50,000, ETH 4 1038 A2 MERTO LEMARYAM (Mertle Maryam, Dibo)	Topographical Map	Drawing	Copy	EMA	1998
22	Topographic Map S=1/50,000, ETH 4 1038 C1 BICHENA (Bichena, Yetimen)	Topographical Map	Drawing	Copy	EMA	1984
23	Topographic Map S=1/50,000, ETH 4 1038 C3 DEJEN (Wejele)	Topographical Map	Drawing	Copy	EMA	1984
24	Topographic Map S=1/50,000, ETH 4 1137 A1 KUNZLA (Kunzila)	Topographical Map	Drawing	Copy	EMA	1987
25	Topographic Map S=1/50,000, ETH 4 1137 C1 MER AWI (Mer-Awi)	Topographical Map	Drawing	Copy	EMA	1987
26	Topographic Map S=1/50,000, ETH 4 1137 C4 ADAMA TERARA (Gebez Maryam)	Topographical Map	Drawing	Copy	EMA	1987
27	Topographic Map S=1/50,000, ETH 4 1137 D3 GONJ (Gonji Kollala)	Topographical Map	Drawing	Copy	EMA	1984

GSE: Geological Survey of Ethiopia
EMA: Ethiopian Mapping Agency

Appendix 7 References

7-1 Hydraulic Calculation

Hydraulic Calculation

1. Mertule Maryam

1.1. Basal Condition

Since the checked quantity of water intake is 424.01m³/day, and it is less than maximum daily supply and average daily supply, water facilities of Mertule Maryam are planned by total quantity of water intake.

1.2. Water Intake

There are two existing water sources in Mertule Maryam, both of two water sources are spring. One is transmitted to reservoir by gravity flow (139.35m³/day), and another is transmitted to the collection chamber by gravity flow (91.96m³/day) and then pumped up to reservoir.

The volume of existing collection chamber is 28.65m³ and another 28.83m³ of new collection chamber is designed, so totally 57.48m³ of volume of collection chambers are secured. Total volume of collection chamber is calculated 15 hours of volume of water intake (i.e. 91.96m³ x 15 hours / 24 hours = 57.48m³).

It was confirmed that another three springs are existing in Mertule Maryam. One is 42.59m³/day of volume, second one is 92.70m³/day and third one is 57.41m³/day. These three springs are transmitted by gravity flow, so at the end of this project, total 424.01m³/day of volume of water intake is secured.

The specification of pump at collection chamber is calculated by 9 hours running per day (4 hours in the morning, 4 hours in the afternoon and 1 hour recess). Total head from collection chamber to reservoir tank is 40m and flow volume is 3.19L/sec (91.96m³/day / 8 hours), so it is needed 3.7kw of capacity of pump.

1.3. Transmission Line

The specification of transmission lines is calculated by the conditions of each water intake. Diameter is decided by the calculation with Hazen-Williams formula. Each distance of each water intake to reservoir tank is from 440m to 3015m. Diameters of transmission line are almost 3", only one transmission line's diameter is 1"1/2.

1.4. Reservoir Tank

There are three existing reservoir tanks in Mertule Maryam. The volume is, first: 82.98m³, second: 50.36m³, third: 50.36m³. All the three reservoir tanks are not leaking water and it is useful, it is planned the new reservoir tank as additional. Required total capacity of reservoir tanks is 212.01m³, so short capacity is 28.31m³, it is planned 30m³ of reservoir tank by reinforced concrete.

1.5. Distribution Line

Distribution lines are calculated by Hazen-Williams formula with peak hourly supply. Now distribution lines are already set in Mertule Maryam, but some lines are not in the ground, those lines crop out. So basically lines are replaced by the necessity of changing diameter, but also are changed at the lines that pipes are cropping out.

1.6. Water Faucet

Every existing water faucets are replaced and additional new water faucets are constructed.

2. Yetimen

2.1. Basal Condition

In Yetimen, average daily supply is 102.98m³/day, maximum daily supply is 123.58m³/day and checked quantity of water intake is 250.56m³/day. Quantity of water intake is sufficient, so water facilities of Yetimen are planned by average and maximum daily supply.

2.2. Water Intake

There is one existing borehole as water sources in Yetimen, but new borehole was drilled and there is no problem about quality and quantity of that borehole, it is planned to use new borehole for this project.

From the borehole to reservoir tank, the water is pumped up, the specification of pump at borehole is calculated by 9 hours running per day (4 hours in the morning, 4 hours in the afternoon and 1 hour recess). Total head from borehole to reservoir tank is 70m and flow volume is 4.29L/sec (123.58m³/day / 8 hours), so it is needed 5.5kw of capacity of pump.

2.3. Transmission Line

The specification of transmission lines is calculated by the conditions of water intake. Diameter is decided by the calculation with Hazen-Williams formula. Distance from borehole to reservoir tank is 1250m. Diameter of transmission line is 3".

2.4. Reservoir Tank

There is an existing reservoir tank in Yetimen. The volume of reservoir tank is 60m³. Existing reservoir tank is now leaking, there is an option only to repair the existing reservoir tank, but preventing water leakage can not be guaranteed for the future because of the technical difficulty, new reservoir tank is planned in Yetimen.

Required capacity of reservoir tank is 64.36m³, so it is planned 70m³ of reservoir tank by reinforced concrete.

2.5. Distribution Line

Distribution lines are calculated by Hazen-Williams formula with peak hourly supply. Now distribution lines are already set in Yetimen, but some lines are not in the ground, those lines crop out. So basically lines are replaced by the necessity of changing diameter, but also are changed at the lines that pipes are cropping out.

2.6. Water Faucet

Every existing water faucets are replaced and additional new water faucets are constructed.

3. Lumame

3.1. Basal Condition

In Lumame, average daily supply is 342.64m³/day, maximum daily supply is 411.17m³/day and checked quantity of water intake is 399.17m³/day. Quantity of water intake is enough for average daily supply, so water facilities of Lumame are planned by average daily supply and quantity of water intake.

3.2. Water Intake

There are two existing boreholes as water sources in Lumame, but total quantity of those two boreholes is not enough for new water facilities (first: 57.60m³/day, second: 86.40m³/day, total: 144.00m³/day), so new borehole was drilled and it was confirmed the quantity of new borehole is 255.17m³/day. It is not enough for maximum daily supply but satisfied average daily supply, so it is planned to use all of three boreholes for this project.

From each borehole to reservoir tank, the water is pumped up, the specification of pump at borehole is calculated by 9 hours running per day (4 hours in the morning, 4 hours in the afternoon and 1 hour recess). Each total head from borehole to reservoir tank is 90m (first), 100m (second) and 110m (third). Flow volume is 2.00L/sec (57.60m³/day / 8 hours), 3.00L/sec (86.40m³/day / 8 hours) and 8.86L/sec (255.17m³/day / 8 hours), so each borehole need 5.5kw, 5.5kw and 15kw of capacity of pump.

3.3. Transmission Line

The specification of transmission lines is calculated by the conditions of water intake. Diameter is decided by the calculation with Hazen-Williams formula. Existing transmission lines of existing two boreholes are combined on the line to reservoir tank. So, existing pumps do not function at the same time because of interfering with each other. It is planned to replace new transmission lines independently for existing transmission lines, and also planned to set new transmission line for new borehole.

Distance and diameter of each transmission line is 1927.22m (first: existing, 3"), 1475.14m (second: existing, 3"), 1208.09m (third: new, 4").

3.4. Reservoir Tank

There is an existing reservoir tank (elevated tank) in Lumame. The volume of existing reservoir tank is 50m³. Existing reservoir tank is functioning and new reservoir tank is planned to satisfy the total capacity of reservoir tank.

Required capacity of reservoir tank is 121.30m³, so it is planned 123m³ of reservoir tank by elevated type.

3.5. Distribution Line

Distribution lines are calculated by Hazen-Williams formula with peak hourly supply. Now distribution lines are already set in Lumame, but some lines are not in the ground, those lines crop out. So basically lines are replaced by the necessity of changing diameter, but also are changed at the lines that pipes are cropping out.

3.6. Water Faucet

Every existing water faucets are replaced and additional new water faucets are constructed.

4. Wojel

4.1. Basal Condition

In Wojel, average daily supply is 101.02m³/day, maximum daily supply is 121.22m³/day and checked quantity of water intake is 224.64m³/day. Quantity of water intake is sufficient, so water facilities of Wojel are planned by average and maximum daily supply.

4.2. Water Intake

There is one existing borehole as water sources in Wojel, but that borehole was abandoned and new borehole was drilled. There is no problem about quality and quantity of new borehole, it is planned to use new borehole for this project.

From the new borehole to reservoir tank, the water is pumped up, the specification of pump at borehole is calculated by 9 hours running per day (4 hours in the morning, 4 hours in the afternoon and 1 hour recess). Total head from borehole to reservoir tank is 90m and flow volume is 4.21L/sec (121.22m³/day / 8 hours), so it is needed 7.5kw of capacity of pump.

4.3. Transmission Line

The specification of transmission lines is calculated by the conditions of water intake. Diameter of transmission line is decided by the calculation with Hazen-Williams formula. Distance from borehole to reservoir tank is 1000m. Diameter of transmission line is 3".

4.4. Reservoir Tank

There is an existing reservoir tank in Wojel. The volume of existing reservoir tank is 60m³ but that reservoir tank was deserted, so new reservoir tank is planned in Wojel.

Required capacity of reservoir tank is 63.14m³, so it is planned 70m³ of reservoir tank by reinforced concrete.

4.5. Distribution Line

Distribution lines are calculated by Hazen-Williams formula with peak hourly supply. Now distribution lines are already set in Lumame, but every water facilities were abandoned in wojel and it is difficult to confirm the condition of existing distribution line, so new distribution line is planned.

4.6. Water Faucet

Every existing water faucets are replaced new and additional new water faucets are constructed.

5. Sedie

5.1. Basal Condition

In Sedie, average daily supply is 106.66m³/day, maximum daily supply is 127.99m³/day and checked quantity of water intake is 256.32m³/day. Quantity of water intake is sufficient, so water facilities of Yetimen are planed by average and maximum daily supply.

5.2. Water Intake

There is one existing borehole as water sources in Sedie, but new borehole was drilled and there is no problem about quality and quantity of that borehole, it is planed to use new borehole for this project.

From the borehole to reservoir tank, the water is pumped up, the specification of pump at borehole is calculated by 9 hours running per day (4 hours in the morning, 4 hours in the afternoon and 1 hour recess). Total head from borehole to reservoir tank is 110m and flow volume is 4.44L/sec (127.99m³/day / 8 hours), so it is needed 7.5kw of capacity of pump.

5.3. Transmission Line

The specification of transmission lines is calculated by the conditions of water intake. Diameter is decided by the calculation with Hazen-Williams formula. Distance from borehole to reservoir tank is 1455m. Diameter of transmission line is 3".

5.4. Reservoir Tank

There is an existing reservoir tank in Sedie. The volume of existing reservoir tank is 60m³. Existing reservoir tank is located low elevation, so new reservoir tank is planed in Sedie.

Required capacity of reservoir tank is 66.66m³, so it is planed 70m³ of reservoir tank by reinforced concrete.

5.5. Distribution Line

Distribution lines are calculated by Hazen-Williams formula with peak hourly supply. Now distribution lines are already set in Sedie, but some lines are not in the ground, those lines crop out. So basically lines are replaced by the necessity of changing diameter, but also are changed at the lines that pipes are cropping out.

5.6. Water Faucet

Every existing water faucets are replaced and additional new water faucets are constructed.

6. Dibo

6.1. Basal Condition

In Dibo, average daily supply is 74.35m³/day, maximum daily supply is 89.22m³/day and checked quantity of water intake is 256.32m³/day. Quantity of water intake is sufficient, so water facilities of Dibo are planed by average and maximum daily supply.

6.2. Water Intake

There is no existing borehole and any other water facility in Dibo except hand pump, so new borehole was drilled and there is no problem about quality and quantity of that borehole, it is planed to use new borehole for this project.

From the borehole to reservoir tank, the water is pumped up, the specification of pump at borehole is calculated by 9 hours running per day (4 hours in the morning, 4 hours in the afternoon and 1 hour recess). Total head from borehole to reservoir tank is 90m and flow volume is 3.10L/sec (89.22m³/day / 8 hours), so it is needed 5.5kw of capacity of pump.

6.3. Transmission Line

The specification of transmission lines is calculated by the conditions of water intake. Diameter is decided by the calculation with Hazen-Williams formula. Distance from borehole to reservoir tank is 2070m. Diameter of transmission line is 3".

6.4. Reservoir Tank

There is no existing reservoir tank in Dibo. Required capacity of reservoir tank is 46.47m³, so it is planed 50m³ of reservoir tank by elevated type.

6.5. Distribution Line

Distribution lines are calculated by Hazen-Williams formula with peak hourly supply. Now there are no distribution lines in Dibo, so every pipeline for distribution is set as new.

6.6. Water Faucet

Every existing water faucets are replaced and additional new water faucets are constructed.

7. Amanuel

7.1. Basal Condition

In Amanuel, average daily supply is 326.76m³/day, maximum daily supply is 392.11m³/day and checked quantity of water intake is 230.40m³/day. Quantity of water intake is not enough for average and maximum daily supply, so water facilities of Amanuel are planned by quantity of water intake.

7.2. Water Intake

There are two existing boreholes as water sources in Amanuel, but one of existing boreholes is abandoned and quantity of another existing borehole is not enough (144.00m³/day) for new water facilities, so new borehole was drilled and it was confirmed the quantity of new borehole is 86.40m³/day. Total amount of water intake is not enough for average and maximum daily supply but it was not found another water intake as drilling, so it is planned to use two boreholes (existing and new) for this project.

From each borehole to reservoir tank, the water is pumped up, existing borehole and pump is functioning well, so at this project, only the pump for new borehole is set. The specification of pump at new borehole is calculated by 9 hours running per day (4 hours in the morning, 4 hours in the afternoon and 1 hour recess). Total head from new borehole to reservoir tank is 100m. Flow volume is 3.00L/sec (86.40m³/day / 8 hours), so new borehole needs 5.5kw of capacity of pump.

7.3. Transmission Line

The specification of transmission lines is calculated by the conditions of water intake. Diameter is decided by the calculation with Hazen-Williams formula. Existing transmission line is functioning, so only new transmission line from new borehole to reservoir tank.

Distance and diameter of new transmission line is 2386m. Diameter of transmission line is 3".

7.4. Reservoir Tank

There is two existing reservoir tanks (elevated tank) in Amanuel. Although the volume of existing reservoir tanks are 60m³ and 30m³, both reservoir tanks are leaking. So it is planned to construct new reservoir tank, required capacity of reservoir tank is 115.2m³, so it is planned 120m³ of reservoir tank by elevated type.

7.5. Distribution Line

Distribution lines are calculated by Hazen-Williams formula with peak hourly supply. Now distribution lines are already set in Amanuel, but some lines are not in the ground, those lines crop out. So basically lines are replaced by the necessity of changing diameter, but also are changed at the lines that pipes are cropping out.

7.6. Water Faucet

Every existing water faucets are replaced and additional new water faucets are constructed.

8. Gobeze Maryam

8.1. Basal Condition

Since the checked quantity of water intake is 164.00m³/day as a spring, and it is less than maximum daily supply and average daily supply, water facilities of Gobeze Maryam are planned by total quantity of water intake.

8.2. Water Intake

There is an existing water source in Gobeze Maryam as a spring. The water is transmitted to the collection chamber by gravity flow and then pumped up to the reservoir.

The volume of the existing collection chamber is 19.87m³ and another 82.63m³ of new collection chamber is designed, so a total of 102.50m³ of volume of collection chambers are secured. Total volume of collection chamber is calculated as 15 hours of volume of water intake (i.e. 164.00m³ x 15 hours / 24 hours = 102.50m³).

The specification of the pump at the collection chamber is calculated by 9 hours running per day (4 hours in the morning, 4 hours in the afternoon and 1 hour recess). Total head from the collection chamber to the reservoir tank is 100m and flow volume is 5.69L/sec (164.00m³/day / 8 hours), so it is needed 11kw of capacity of pump.

8.3. Transmission Line

The specification of transmission lines is calculated by the conditions of water intake. Diameter is decided by the calculation with Hazen-Williams formula. Distance from water intake to reservoir tank is 1300m. Diameters of transmission line are 3".

8.4. Reservoir Tank

There is an existing reservoir tank in Gobeze Maryam. The volume of the existing reservoir tank is 50m³. But the elevation of the existing reservoir tank is not enough to distribute a high area, so the existing reservoir tank will be abandoned and a new reservoir tank is planned instead. Required capacity of reservoir tank is 102.50m³, so it is planned 105m³ of reservoir tank by reinforced concrete.

8.5. Distribution Line

Distribution lines are calculated by Hazen-Williams formula with peak hourly supply. Now distribution lines are already set in Gobeze Maryam, but some lines are not in the ground, those lines crop out. So basically lines are replaced by the necessity of changing diameter, but also are changed at the lines that pipes are cropping out.

8.6. Water Faucet

Every existing water faucets are replaced and additional new water faucets are constructed.

9. Bikolo

9.1. Basal Condition

In Bikolo, average daily supply is 151.19m³/day, maximum daily supply is 181.43m³/day and checked quantity of water intake is 403.20m³/day. Quantity of water intake is sufficient, so water facilities of Bikolo are planed by average and maximum daily supply.

9.2. Water Intake

There is one existing borehole as water sources in Bikolo, but new borehole was drilled and there is no problem about quality and quantity of that borehole, it is planed to use new borehole for this project.

From the borehole to reservoir tank, the water is pumped up, the specification of pump at borehole is calculated by 9 hours running per day (4 hours in the morning, 4 hours in the afternoon and 1 hour recess). Total head from borehole to reservoir tank is 110m and flow volume is 6.30L/sec (181.43m³/day / 8 hours), so it is needed 11kw of capacity of pump.

9.3. Transmission Line

The specification of transmission lines is calculated by the conditions of water intake. Diameter is decided by the calculation with Hazen-Williams formula. Distance from water intake to reservoir tank is 5533m. Diameters of transmission line are 4".

9.4. Reservoir Tank

There is an existing reservoir tank in Bikolo. The volume of existing reservoir tank is only 25m³. Moreover, the location of existing reservoir tank is centering of Bikolo town, water pressure for distribution is not enough. That is why existing reservoir tank will be abandoned and new reservoir tank is planed instead at high area of Bikolo town. Required capacity of reservoir tank is 94.49m³, so it is planed 105m³ of reservoir tank by reinforced concrete.

9.5. Distribution Line

Distribution lines are calculated by Hazen-Williams formula with peak hourly supply. Now distribution lines are already set in Bikolo, but new reservoir tank is designed to construct at high area, it is needed to extend the distribution line. And some lines are not in the ground, those lines crop out. So basically lines are replaced by the necessity of changing diameter, but also are changed at the lines that pipes are cropping out.

9.6. Water Faucet

Every existing water faucets are replaced and additional new water faucets are constructed.

Hydrologic Calculation

1. Basic Number

No.	Towns	Zone	Woreda	Existing Population 2012	Projection of pop. 2016	School number of students	Hospital, Clinic
9	Mertule Maryam	East Gojam	Enebsie Sar Mdir	15,124	17,829	7,180	10
10	Yetimen	East Gojam	Enemay	3,289	3,877	2,346	11
12	Lumame	East Gojam	Awabel	11,410	13,451	5,735	10
14	Wojel	East Gojam	Awabel	3,188	3,758	2,486	10
15	Sedie	East Gojam	Hulet Egu Enesie	3,348	3,947	2,712	10
16	Dibo	East Gojam	Enebsie Sar Mdir	2,129	2,510	2,839	10
---	Amanuel	East Gojam	Machakel	10,768	12,694	6,002	10
27	Gobeze Maryam	West Gojam	Quarit	5,860	6,908	4,938	10
---	Bikolo(Wetet Abay)	West Gojam	Mecha	4,929	5,811	3,000	10
Total				60,045	70,785	37,238	91

--- Annual Growth Rate of Population ---
Growth Rate : 4.2 %

--- Number of students and beds ---
It is based on the result of field study.

2. Water Demand

(AD : 2012)

Unit: m3/day

No.	Towns	Daily Water Demand(m3/day)				Ineffective water 15 %	Average Daily Supply	Maximum Daily Supply factor : 1.2	Peak Hourly Supply factor : 2.0
		General 20 l/c/day	School 5 l/c/day	Hospital, Clinic 25 l/c/day	Total				
9	Mertule Maryam	302.48	35.90	0.25	338.63	50.79	389.42	467.30	778.84
10	Yetimen	65.78	11.73	0.28	77.79	11.67	89.46	107.35	178.92
12	Lumame	228.20	28.68	0.25	257.13	38.57	295.70	354.84	591.40
14	Wojel	63.76	12.43	0.25	76.44	11.47	87.91	105.49	175.82
15	Sedie	66.96	13.56	0.25	80.77	12.12	92.89	111.47	185.78
16	Dibo	42.58	14.20	0.25	57.03	8.55	65.58	78.70	131.16
---	Amanuel	215.36	30.01	0.25	245.62	36.84	282.46	338.95	564.92
27	Gobeze Maryam	117.20	24.69	0.25	142.14	21.32	163.46	196.15	326.92
---	Bikolo(Wetet Abay)	98.58	15.00	0.25	113.83	17.07	130.90	157.08	261.80
Total		1,200.90	186.20	2.28	1,389.38	208.40	1,597.78	1,917.33	3,195.56

Unit of Water Demand : 20 l/c/day (Average Daily Demand)
5 l/c/day (School)
25 l/c/day (Hospital)

Ineffective Water : 15 %

Factor of Water Supply : 1.2 (Maximum Daily Supply)
2.0 (Peak Hourly Supply)

(AD : 2016)

Unit: m3/day

No.	Towns	Daily Water Demand(m3/day)				Ineffective water 15 %	Average Daily Supply	Maximum Daily Supply factor : 1.2	Peak Hourly Supply factor : 2.0
		General 20 l/c/day	School 5 l/c/day	Hospital, Clinic 25 l/c/day	Total				
9	Mertule Maryam	356.58	35.90	0.25	392.73	58.91	451.64	541.97	903.28
10	Yetimen	77.54	11.73	0.28	89.55	13.43	102.98	123.58	205.96
12	Lumame	269.02	28.68	0.25	297.95	44.69	342.64	411.17	685.28
14	Wojel	75.16	12.43	0.25	87.84	13.18	101.02	121.22	202.04
15	Sedie	78.94	13.56	0.25	92.75	13.91	106.66	127.99	213.32
16	Dibo	50.20	14.20	0.25	64.65	9.70	74.35	89.22	148.70
---	Amanuel	253.88	30.01	0.25	284.14	42.62	326.76	392.11	653.52
27	Gobeze Maryam	138.16	24.69	0.25	163.10	24.47	187.57	225.08	375.14
---	Bikolo(Wetet Abay)	116.22	15.00	0.25	131.47	19.72	151.19	181.43	302.38
Total		1,415.70	186.20	2.28	1,604.18	240.63	1,844.81	2,213.77	3,689.62

3. Volume of Water Intake

Unit: m3/day

No.	Towns	Maximum Daily Supply m3/day	Volume of Water Intake(Existing)			Volume of Water Intake(New)			Volume of Water Intake(Total)			Design Volume		Remarks
			Borehole	Spring	Total	Borehole	Spring	Total	Borehole	Spring	Total	Water Intake	Water Coverage	
9	Mertule Maryam	541.97	0.00	139.35	139.35	0.00	0.00	0.00	0.00	424.01	424.01	424.01	78.23%	Existing use
			0.00	91.96	91.96	0.00	0.00	0.00						Existing use
			0.00	0.00	0.00	0.00	42.59	42.59						New
			0.00	0.00	0.00	0.00	92.70	92.70						New
			0.00	0.00	0.00	0.00	57.41	57.41						New
10	Yetimen	123.58	0.00	0.00	0.00	0.00	0.00	0.00	250.56	0.00	250.56	123.58	100.00%	Abolishment
			0.00	0.00	0.00	250.56	0.00	250.56						New
12	Lumame	411.17	57.60	0.00	57.60	0.00	0.00	0.00	399.17	0.00	399.17	399.17	97.08%	Existing use
			86.40	0.00	86.40	0.00	0.00	0.00						Existing use
			0.00	0.00	0.00	255.17	0.00	255.17						New
14	Wojel	121.22	0.00	0.00	0.00	0.00	0.00	0.00	224.64	0.00	224.64	121.22	100.00%	Abolishment
			0.00	0.00	0.00	224.64	0.00	224.64						New
15	Sedie	127.99	0.00	0.00	0.00	0.00	0.00	0.00	256.32	0.00	256.32	127.99	100.00%	Abolishment
			0.00	0.00	0.00	256.32	0.00	256.32						New
16	Dibo	89.22	0.00	0.00	0.00	256.32	0.00	256.32	256.32	0.00	256.32	89.22	100.00%	New
			144.00	0.00	144.00	0.00	0.00	0.00						Existing use
---	Amanuel	392.11	0.00	0.00	0.00	0.00	0.00	0.00	230.40	0.00	230.40	230.40	58.76%	Abolishment
			0.00	0.00	0.00	86.40	0.00	86.40						New
			0.00	0.00	0.00	0.00	0.00	0.00						Existing use
27	Gobeze Maryam	225.08	0.00	164.00	164.00	0.00	0.00	0.00	0.00	164.00	164.00	164.00	72.86%	Existing use
---	Bikolo(Wetet Abay)	181.43	0.00	0.00	0.00	0.00	0.00	0.00	403.20	0.00	403.20	181.43	100.00%	Abolishment
			0.00	0.00	0.00	403.20	0.00	403.20						New
Total		2,213.77	288.00	395.31	683.31	1,732.61	192.70	1,925.31	2,020.61	588.01	2,608.62	1,861.02	84.07%	---

4. Intake, Transmission Facilities

No.	Towns	Volume of Water Intake (m ³ /day)			Elevation(m)				Transmission Pipe, Intake to the ground, the ground to Tank					Pump Plan(8h/day)		
		Spring		Borehole	Intake Facilities		Tank	Vertical Drop	Length (m)	Diameter (mm)	Velocity (m/s)	Hydraulic Grade (%)	Head loss (m)	Lifting Range (m)	Flow Volume (l/s)	Spec (kw)
		Gravity	Pump		Intake Point	Ground										
9	Mertule Maryam	139.35	0.00	0.00	2,737.94	2,737.94	2,711.09	26.85	800.00	75	0.37	3.66	2.93	---	---	---
		0.00	91.96	0.00	2,630.69	2,630.69	2,667.92	-37.23	440.00	75	0.72	1.70	0.75	40.00	3.19	3.7
		42.59	0.00	0.00	2,848.73	2,848.73	2,711.09	137.64	3,015.40	40	0.39	8.73	26.33	---	---	---
		92.70	0.00	0.00	2,790.81	2,790.81	2,711.09	79.72	790.00	75	0.24	1.72	1.36	---	---	---
		57.41	0.00	0.00	2,678.33	2,678.33	2,664.87	13.46	1,444.86	75	0.15	0.71	1.03	---	---	---
10	Yetimen	0.00	0.00	123.58	2,382.83	2,405.63	2,445.78	-62.95	60.00	50	2.19	21.13	1.27	70.00	4.29	5.5
12	Lumame	0.00	0.00	57.60	2,418.84	2,464.13	2,505.77	-86.93	55.00	50	1.02	5.15	0.28	90.00	2.00	5.5
		0.00	0.00	86.40	2,412.34	2,462.95	2,505.77	-93.43	1,475.14	75	0.68	1.51	2.23	100.00	3.00	5.5
		0.00	0.00	255.17	2,407.00	2,424.95	2,505.77	-98.77	40.00	65	2.67	22.52	0.90	110.00	8.86	15.0
14	Wojel	0.00	0.00	121.22	2,403.96	2,442.88	2,488.58	-84.62	1,208.09	100	1.13	2.76	3.34	---	---	---
		0.00	0.00	121.22	2,403.96	2,442.88	2,488.58	-84.62	55.00	50	2.14	20.39	1.12	90.00	4.21	7.5
15	Sedie	0.00	0.00	127.99	2,446.25	2,468.29	2,547.55	-101.30	1,000.00	75	0.95	2.83	2.83	---	---	---
16	Dibo	0.00	0.00	89.22	2,374.98	2,420.18	2,452.64	-77.66	60.00	50	2.26	22.55	1.35	110.00	4.44	7.5
		0.00	0.00	89.22	2,374.98	2,420.18	2,452.64	-77.66	1,455.27	75	1.01	3.13	4.56	---	---	---
---	Amanuel	0.00	0.00	144.00	2,147.20	2,197.20	2,302.89	-155.69	55.00	50	1.58	11.57	0.64	90.00	3.10	5.5
		0.00	0.00	144.00	2,302.89	2,302.89	2,397.78	-94.89	2,071.06	75	0.70	1.61	3.33	---	---	---
		0.00	0.00	144.00	2,302.89	2,302.89	2,397.78	-94.89	100.00	50	2.55	28.05	2.80	170.00	5.00	13.0
27	Gobeze Maryam	0.00	164.00	0.00	2,156.40	2,156.40	2,243.37	-86.97	32.00	50	1.53	10.90	0.35	100.00	3.00	5.5
		0.00	164.00	0.00	2,156.40	2,156.40	2,243.37	-86.97	2,800.00	75	1.13	3.89	10.90	---	---	---
---	Bikolo(Wetet Abay)	0.00	0.00	181.43	1,855.63	1,905.63	1,953.02	-97.39	2,386.25	75	0.68	1.51	3.61	---	---	---
Total		332.05	255.96	1,417.01	---	---	---	---	---	---	---	---	---	---	---	---

5. Transmission Facilities (Relay Tank)

No.	Towns	Water Intake m ³ /day	Required Capacity of Tank (m ³)	Vol. of Existing Tank (m ³)	Additional capacity (m ³)
9	Mertule Maryam	91.96	57.48	28.65	28.83
27	Gobeze Maryam	164.00	102.50	19.87	82.63


6. Distribution Facilities (Reservoir Tank)

No.	Towns	Average Daily Supply (m ³ /day)	Volume of Intake Water (m ³ /day)	Required Capacity Reservoirs (m ³)		Existing Reservoir (m ³)	Existing Use (m ³)	Short Capacity (m ³)	Plan of Reservoir Tank					Remarks				
				12 hour	15 hour				Width (m)	Length (m)	Net Depth (m)	Number of Tank	Volume (m ³)		Category			
9	Mertule Maryam	451.64	424.01	212.01	---	82.98	82.98	28.31	φ 6.20	---	2.75	1	82.98	RC	Existing use			
						50.36	50.36		φ 5.40	---	2.20	1	50.36	Stone Masonry	Existing use			
						50.36	50.36		φ 5.40	---	2.20	1	50.36	Stone Masonry	Existing use			
10	Yetimen	102.98	123.58	---	64.36	60.00	0.00	64.36	3.00	4.00	2.50	1	30.00	RC	New			
						---	---		---	---	---	---	---	---	---	---	---	---
12	Lumame	342.64	399.17	171.32	---	50.02	50.02	121.30	---	---	---	---	---	---	---	---		
						---	---		---	---	---	---	---	---	---	---	---	---
14	Wojel	101.02	121.22	---	63.14	60.00	0.00	63.14	4.50	6.00	2.50	1	67.50	RC	New			
						---	---		---	---	---	---	---	---	---	---	---	---
15	Sedie	106.66	127.99	---	66.66	60.00	0.00	66.66	---	---	---	---	---	---	---	---		
						---	---		---	---	---	---	---	---	---	---	---	---
16	Dibo	74.35	89.22	---	46.47	0.00	0.00	46.47	4.50	6.00	2.50	1	67.50	RC	New			
						---	---		---	---	---	---	---	---	---	---	---	---
---	Amanuel	326.76	230.40	115.20	---	60.00	0.00	115.20	5.00	5.00	2.05	1	51.25	Elevated Tank	New			
						---	---		---	---	---	---	---	---	---	---	---	---
						---	---		---	---	---	---	---	---	---	---	---	---
27	Gobeze Maryam	187.57	164.00	---	102.50	50.00	0.00	102.50	4.00	7.50	2.05	2	123.00	Elevated Tank	New			
						---	---		---	---	---	---	---	---	---	---	---	---
---	Bikolo(Wetet Abay)	151.19	181.43	---	94.49	25.00	0.00	94.49	---	---	---	---	---	---	---	---		
						---	---		---	---	---	---	---	---	---	---	---	---
Total		1,844.81	1,861.02	498.53	437.62	578.72	233.72	702.43	---	---	---	---	868.47	---	---	---		

7. Distribution Facilities (Pipeline)

Distribution pipelines of each site are determined by the hydraulic calculation.

Mertule Maryam Pipe Networks



-----Mertule Maryam <<Case.1 : Hazen-Williams Formula>>-----

<< Explanatory Notes >>

Tank 3 Maximum EHP 69.227 (m)
 Node 109 Minimum EHP 0.000 (m)
 Line 113 Maximum I 0.000 (%)
 Pump.Decom 9 Maximum V 0.000 (m/s)

- Line -
 D: Diameter
 L: Length of Pipe
 Coef: Friction Coefficient
 Q: Quantity of Flow
 V: Velocity of Flow
 I: Hydraulic Gradient
 HL: Head Loss
 P: Add Pressure

- Node -
 HP: Head Pressure
 GL: Ground Level
 EHP: Effectual Head Pressure
 Qc: Consumption of Water

Convergence Gap 0.00 (cm)
 Calculation 2 (times)

----- NodeData -----

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	Node ST	Node EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
1	2711.092	2.711.092		0.000	0.000	Reservoir Tank	1	4	100.0	738.592	110	0.000	0.000	0.000	0.000	0.000
2	2667.920	2.667.920		0.000	0.000	Reservoir Tank	2	83	75.0	177.672	110	++++	++++	++++	++++	++++
3	2678.330	2.678.330		0.000	0.000	Protect Spring	3	17	75.0	586.845	110	0.000	0.000	0.000	0.000	0.000
4	2711.092	2.678.563		32.528	0.000		4	2	37.5	532.902	110	++++	++++	++++	++++	++++
5	2711.092	2.683.449		27.643	0.000		4	5	50.0	315.819	110	0.000	0.000	0.000	0.000	0.000
6	2711.092	2.676.987		34.104	0.000		4	111	75.0	5.000	110	0.000	0.000	0.000	0.000	-32.528
7	2711.092	2.666.009		45.082	0.000		5	6	37.5	173.162	110	0.000	0.000	0.000	0.000	0.000
8	2711.092	2.669.977		41.114	0.000		5	8	37.5	356.867	110	0.000	0.000	0.000	0.000	0.000
9	2711.092	2.670.943		40.148	0.000		6	7	37.5	210.687	110	0.000	0.000	0.000	0.000	0.000
10	2711.092	2.667.801		43.290	0.000		8	9	37.5	38.912	110	0.000	0.000	0.000	0.000	0.000
11	2711.092	2.647.574		63.517	0.000		8	18	37.5	28.446	110	0.000	0.000	0.000	0.000	0.000
12	2711.092	2.661.335		49.756	0.000		9	10	37.5	167.427	110	0.000	0.000	0.000	0.000	0.000
13	2711.092	2.661.633		49.459	0.000		10	11	37.5	375.927	110	0.000	0.000	0.000	0.000	0.000
14	2711.092	2.663.275		47.817	0.000		10	12	37.5	152.470	110	0.000	0.000	0.000	0.000	0.000
15	2711.092	2.652.036		59.056	0.000		12	13	37.5	276.997	110	0.000	0.000	0.000	0.000	0.000
16	2711.092	2.650.905		60.187	0.000		13	14	37.5	47.669	110	0.000	0.000	0.000	0.000	0.000
17	2678.330	2.610.000		68.330	0.000		14	15	37.5	366.847	110	0.000	0.000	0.000	0.000	0.000
18	2711.092	2.669.435		41.657	0.000		15	16	37.5	203.839	110	0.000	0.000	0.000	0.000	0.000
19	2711.092	2.665.041		46.051	0.000		16	17	50.0	858.018	110	++++	++++	++++	++++	++++
20	2711.092	2.660.441		50.651	0.000		18	19	37.5	228.057	110	0.000	0.000	0.000	0.000	0.000
21	2678.563	2.646.951		31.612	0.000		19	20	37.5	333.917	110	0.000	0.000	0.000	0.000	0.000
22	2678.563	2.650.877		27.686	0.000		21	22	75.0	254.447	110	0.000	0.000	0.000	0.000	0.000
23	2678.563	2.649.199		29.364	0.000		21	30	75.0	98.839	110	0.000	0.000	0.000	0.000	0.000
24	2678.563	2.639.156		39.407	0.000		22	23	75.0	144.166	110	0.000	0.000	0.000	0.000	0.000

----- NodeData -----

----- NodeData -----

----- LineData -----

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	ST	EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
25	2678.563	2.648.840		29.723	0.000		23	24	37.5	76.626	110	0.000	0.000	0.000	0.000	0.000
26	2678.563	2.639.255		39.309	0.000		23	25	37.5	193.779	110	0.000	0.000	0.000	0.000	0.000
27	2678.563	2.638.286		40.277	0.000		23	26	75.0	78.843	110	0.000	0.000	0.000	0.000	0.000
28	2678.563	2.640.412		38.151	0.000		26	27	37.5	63.445	110	0.000	0.000	0.000	0.000	0.000
29	2678.563	2.633.869		44.694	0.000		26	28	37.5	165.855	110	0.000	0.000	0.000	0.000	0.000
30	2678.563	2.638.502		40.061	0.000		26	29	75.0	94.027	110	0.000	0.000	0.000	0.000	0.000
31	2678.563	2.635.328		43.235	0.000		30	31	37.5	163.997	110	0.000	0.000	0.000	0.000	0.000
32	2678.563	2.633.840		44.723	0.000		30	32	75.0	135.739	110	0.000	0.000	0.000	0.000	0.000
33	2633.840	2.606.060		27.781	0.000		32	38	75.0	306.663	110	0.000	0.000	0.000	0.000	0.000
34	2633.840	2.594.605		39.235	0.000		32	112	37.5	0.100	110	0.000	0.000	0.000	0.000	-44.723
35	2633.840	2.602.746		31.094	0.000		33	34	37.5	131.019	110	0.000	0.000	0.000	0.000	0.000
36	2633.840	2.607.019		26.821	0.000		33	35	37.5	135.480	110	0.000	0.000	0.000	0.000	0.000
37	2633.840	2.587.186		46.654	0.000		35	36	37.5	96.947	110	0.000	0.000	0.000	0.000	0.000
38	2678.563	2.628.299		50.264	0.000		35	37	37.5	155.253	110	0.000	0.000	0.000	0.000	0.000
39	2678.563	2.623.546		55.017	0.000		38	39	75.0	149.759	110	0.000	0.000	0.000	0.000	0.000
40	2623.546	2.605.298		18.249	0.000		38	97	50.0	124.408	110	0.000	0.000	0.000	0.000	0.000
41	2623.546	2.606.458		17.089	0.000		39	113	75.0	0.100	110	0.000	0.000	0.000	0.000	-55.017
42	2623.546	2.602.136		21.411	0.000		39	118	75.0	227.583	110	0.000	0.000	0.000	0.000	0.000
43	2623.546	2.617.831		5.715	0.000		40	41	37.5	22.791	110	0.000	0.000	0.000	0.000	0.000
44	2623.546	2.594.942		28.604	0.000		40	42	37.5	117.963	110	0.000	0.000	0.000	0.000	0.000
45	2623.546	2.589.029		34.518	0.000		43	44	37.5	264.336	110	0.000	0.000	0.000	0.000	0.000
46	2623.546	2.610.616		12.931	0.000		43	46	65.0	105.762	110	0.000	0.000	0.000	0.000	0.000
47	2623.546	2.598.849		24.697	0.000		44	45	37.5	47.986	110	0.000	0.000	0.000	0.000	0.000
48	2623.546	2.595.483		28.063	0.000		46	47	37.5	192.998	110	0.000	0.000	0.000	0.000	0.000
49	2598.849	2.575.018		23.831	0.000		46	52	65.0	23.052	110	0.000	0.000	0.000	0.000	0.000
50	2598.849	2.566.153		32.696	0.000		47	48	37.5	46.357	110	0.000	0.000	0.000	0.000	0.000
51	2598.849	2.549.208		49.641	0.000		47	114	37.5	0.100	110	0.000	0.000	0.000	0.000	-24.697
52	2623.546	2.611.045		12.501	0.000		49	50	37.5	162.117	110	0.000	0.000	0.000	0.000	0.000
53	2623.546	2.608.679		14.867	0.000		50	51	37.5	280.793	110	0.000	0.000	0.000	0.000	0.000
54	2623.546	2.598.152		25.395	0.000		52	53	50.0	105.543	110	0.000	0.000	0.000	0.000	0.000
55	2678.563	2.610.185		68.378	0.000		53	54	38	185.127	110	0.000	0.000	0.000	0.000	0.000
56	2610.185	2.600.317		9.868	0.000		55	63	50	145.769	110	0.000	0.000	0.000	0.000	0.000
57	2610.185	2.590.637		19.548	0.000		55	117	38	0.100	110	0.000	0.000	0.000	0.000	0.000
58	2610.185	2.573.553		36.632	0.000		56	57	38	79.436	110	0.000	0.000	0.000	0.000	0.000
59	2610.185	2.586.678		23.508	0.000		57	58	38	280.099	110	0.000	0.000	0.000	0.000	0.000
60	2610.185	2.572.897		37.288	0.000		57	59	38	60.044	110	0.000	0.000	0.000	0.000	0.000
61	2610.185	2.560.109		50.076	0.000		59	60	38	78.645	110	0.000	0.000	0.000	0.000	0.000
62	2610.185	2.555.223		54.962	0.000		60	61	38	142.935	110	0.000	0.000	0.000	0.000	0.000
63	2678.563	2.613.779		64.784	0.000		60	62	38	197.215	110	0.000	0.000	0.000	0.000	0.000
64	2613.779	2.597.077		16.703	0.000		63	72	50	37.566	110	0.000	0.000	0.000	0.000	0.000

----- NodeData -----

----- LineData -----

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	ST	EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
65	2613.779	2,576.356		37.423	0.000		63	115	38	0.100	110	0.000	0.000	0.000	0.000	-64.784
66	2613.779	2,573.891		39.888	0.000		64	65	38	113.377	110	0.000	0.000	0.000	0.000	0.000
67	2613.779	2,553.076		60.703	0.000		65	66	38	172.393	110	0.000	0.000	0.000	0.000	0.000
68	2613.779	2,570.643		43.136	0.000		65	69	38	14.938	110	0.000	0.000	0.000	0.000	0.000
69	2613.779	2,574.186		39.593	0.000		66	67	38	226.436	110	0.000	0.000	0.000	0.000	0.000
70	2613.779	2,563.787		49.993	0.000		66	68	38	131.300	110	0.000	0.000	0.000	0.000	0.000
71	2613.779	2,567.443		46.336	0.000		69	70	38	102.389	110	0.000	0.000	0.000	0.000	0.000
72	2678.563	2,616.146		62.417	0.000		69	71	38	143.007	110	0.000	0.000	0.000	0.000	0.000
73	2678.563	2,641.121		37.442	0.000		72	73	50	195.905	110	0.000	0.000	0.000	0.000	0.000
74	2678.563	2,619.902		58.662	0.000		72	74	38	157.571	110	0.000	0.000	0.000	0.000	0.000
75	2619.902	2,597.497		22.405	0.000		74	116	38	0.100	110	0.000	0.000	0.000	0.000	-58.661
76	2619.902	2,601.146		18.755	0.000		75	76	38	97.487	110	0.000	0.000	0.000	0.000	0.000
77	2619.902	2,552.038		67.864	0.000		76	77	38	335.366	110	0.000	0.000	0.000	0.000	0.000
78	2574.476	2,544.476	75.426	30.000	0.000	reak Pressure Val	76	79	38	37.283	110	0.000	0.000	0.000	0.000	0.000
79	2619.902	2,599.225		20.677	0.000		77	78	38	221.917	110	0.000	0.000	0.000	0.000	-45.426
80	2619.902	2,585.933		33.969	0.000		79	80	38	145.320	110	0.000	0.000	0.000	0.000	0.000
81	2619.902	2,572.614		47.288	0.000		80	81	38	117.716	110	0.000	0.000	0.000	0.000	0.000
82	2619.902	2,586.446		33.455	0.000		80	82	38	79.963	110	0.000	0.000	0.000	0.000	0.000
83	2678.563	2,653.412		25.151	0.000		83	84	38	128.469	110	0.000	0.000	0.000	0.000	0.000
84	2678.563	2,646.151		32.413	0.000		83	92	75	42.444	110	0.000	0.000	0.000	0.000	0.000
85	2678.563	2,614.118		64.445	0.000		84	85	38	320.993	110	0.000	0.000	0.000	0.000	0.000
86	2678.563	2,609.337		69.227	0.000		84	87	38	49.509	110	0.000	0.000	0.000	0.000	0.000
87	2678.563	2,642.879		35.685	0.000		85	86	38	25.157	110	0.000	0.000	0.000	0.000	0.000
88	2678.563	2,643.004		35.560	0.000		87	88	38	26.182	110	0.000	0.000	0.000	0.000	0.000
89	2678.563	2,615.695		62.868	0.000		87	89	38	221.991	110	0.000	0.000	0.000	0.000	0.000
90	2678.563	2,613.128		65.436	0.000		89	90	38	91.771	110	0.000	0.000	0.000	0.000	0.000
91	2678.563	2,609.365		69.198	0.000		89	91	38	103.369	110	0.000	0.000	0.000	0.000	0.000
92	2678.563	2,649.415		29.148	0.000		92	93	75	117.501	110	0.000	0.000	0.000	0.000	0.000
93	2678.563	2,635.990		42.573	0.000		93	94	38	51.545	110	0.000	0.000	0.000	0.000	0.000
94	2678.563	2,630.675		47.888	0.000		93	95	75	365.347	110	0.000	0.000	0.000	0.000	0.000
95	2678.563	2,627.783		50.780	0.000		95	96	38	81.890	110	0.000	0.000	0.000	0.000	0.000
96	2678.563	2,619.503		59.060	0.000		95	97	75	59.027	110	0.000	0.000	0.000	0.000	0.000
97	2678.563	2,626.850		51.714	0.000		97	98	38	90.806	110	0.000	0.000	0.000	0.000	0.000
98	2678.563	2,613.347		65.216	0.000		97	99	75	334.654	110	0.000	0.000	0.000	0.000	0.000
99	2678.563	2,612.993		65.570	0.000		99	100	38	120.771	110	0.000	0.000	0.000	0.000	0.000
100	2678.563	2,610.654		67.910	0.000		99	101	50	18.706	110	0.000	0.000	0.000	0.000	0.000
101	2678.563	2,611.913		66.650	0.000		101	102	38	160.098	110	0.000	0.000	0.000	0.000	0.000
102	2607.572	2,607.572	70.991	0.000	0.000	reak Pressure Tan	102	103	38	86.388	110	0.000	0.000	0.000	0.000	-70.991
103	2607.572	2,598.508		9.064	0.000		102	104	38	418.211	110	0.000	0.000	0.000	0.000	0.000
104	2607.572	2,572.544		35.028	0.000		111	22	75	293.703	110	0.000	0.000	0.000	0.000	0.000

--- NodeData ---

--- LineData ---

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (1/s)	Remarks	Node ST EN	D (mm)	L (m)	Coef C	Q (1/s)	V (m/s)	I (%)	HL (m)	P (m)
111	2678.563	2.678.563	32.528	0.000	0.000	reak Pressure Tan	112 33	38	522.930	110	0.000	0.000	0.000	0.000	0.000
112	2633.840	2.633.840	44.723	0.000	0.000	reak Pressure Tan	113 40	38	174.553	110	0.000	0.000	0.000	0.000	0.000
113	2623.546	2.623.546	55.017	0.000	0.000	reak Pressure Tan	113 43	75	98.768	110	0.000	0.000	0.000	0.000	0.000
114	2598.849	2.598.849	24.697	0.000	0.000	reak Pressure Tan	114 49	38	278.995	110	0.000	0.000	0.000	0.000	0.000
115	2613.779	2.613.779	64.784	0.000	0.000	reak Pressure Tan	115 64	38	269.183	110	0.000	0.000	0.000	0.000	0.000
116	2619.902	2.619.902	58.662	0.000	0.000	reak Pressure Tan	116 75	38	286.580	110	0.000	0.000	0.000	0.000	0.000
117	2610.185	2.610.185	68.378	0.000	0.000	reak Pressure Tan	117 56	38	210.779	110	0.000	0.000	0.000	0.000	0.000
118	2678.563	2.611.045		67.518	0.000		118 55	75	261.653	110	0.000	0.000	0.000	0.000	0.000
							118 101	38	92.744	110	0.000	0.000	0.000	0.000	0.000

-----Mertule Maryam <<Case.2 : Hazen-Williams Formula>>-----

<< Explanatory Notes >>

- Line -
 D: Diameter
 L: Length of Pipe
 Coef: Friction Coefficient
 Q: Quantity of Flow
 V: Velocity of Flow
 I: Hydraulic Gradient
 HL: Head Loss
 P: Add Pressure

- Node -
 HP: Head Pressure
 GL: Ground Level
 EHP: Effectual Head Pressure
 Qc: Consumption of Water

Tank 3 Maximum EHP 67.985 (m)
 Node 109 Minimum EHP 0.000 (m)
 Line 113 Maximum I 64.767 (%)
 Pump, Decom 9 Maximum V 1.125 (m/s)

Convergence Gap 0.88 (cm)
 Calculation 16 (times)

----- NodeData -----

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	ST	Node EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
1	2711.092	2.711.092		0.000	-6.509	Reservoir Tank	1	4	100.0	738.592	110	6.509	0.829	11.721	8.657	0.000
2	2667.920	2.667.920		0.000	-1.898	Reservoir Tank	2	83	75.0	177.672	110	3.140	0.711	12.339	2.192	0.000
3	2678.330	2.678.330		0.000	-0.607	Protect Spring	3	17	75.0	586.845	110	0.607	0.138	0.588	0.345	0.000
4	2702.434	2.678.563		23.871	0.000		4	2	37.5	532.902	110	1.242	1.125	64.767	34.515	0.000
5	2697.738	2.683.449		14.289	0.000		4	5	50.0	315.819	110	1.196	0.609	14.872	4.697	0.000
6	2697.738	2.676.987		20.750	0.000		4	111	75.0	5.000	110	4.071	0.922	19.957	0.100	-23.771
7	2697.738	2.666.009		31.728	0.000		5	6	37.5	173.162	110	0.000	0.000	0.000	0.000	0.000
8	2676.192	2.669.977		6.214	0.000		5	8	37.5	356.867	110	1.196	1.083	60.375	21.546	0.000
9	2675.214	2.670.943		4.270	0.225		6	7	37.5	210.687	110	0.000	0.000	0.000	0.000	0.000
10	2673.054	2.667.801		5.252	0.000		8	9	37.5	38.912	110	0.745	0.675	25.139	0.978	0.000
11	2672.021	2.647.574		24.447	0.225		8	18	37.5	28.446	110	0.451	0.408	9.912	0.282	0.000
12	2672.367	2.661.335		11.032	0.225		9	10	37.5	167.427	110	0.520	0.471	12.901	2.160	0.000
13	2672.282	2.661.633		10.650	0.225		10	11	37.5	375.927	110	0.225	0.204	2.746	1.032	0.000
14	2672.349	2.663.275		9.074	0.000		10	12	37.5	152.470	110	0.294	0.267	4.501	0.686	0.000
15	2672.861	2.652.036		20.826	0.225		12	13	37.5	276.997	110	0.069	0.062	0.306	0.085	0.000
16	2674.347	2.650.905		23.443	0.225		13	14	37.5	47.669	110	-0.156	-0.142	-1.397	-0.067	0.000
17	2677.985	2.610.000		67.985	0.000		14	15	37.5	366.847	110	-0.156	-0.142	-1.397	-0.512	0.000
18	2675.910	2.669.435		6.475	0.225		15	16	37.5	203.839	110	-0.382	-0.346	-7.290	-1.486	0.000
19	2675.283	2.665.041		10.243	0.000		16	17	50.0	858.018	110	-0.607	-0.309	-4.239	-3.637	0.000
20	2674.367	2.660.441		13.926	0.225		18	19	37.5	228.057	110	0.225	0.204	2.746	0.626	0.000
21	2669.074	2.646.951		22.123	0.000		19	20	37.5	333.917	110	0.225	0.204	2.746	0.917	0.000
22	2672.702	2.650.877		21.825	0.000		21	22	75.0	254.447	110	-3.395	-0.769	-14.258	-3.628	0.000
23	2672.598	2.649.199		23.400	0.000		21	30	75.0	98.839	110	3.395	0.769	14.258	1.409	0.000
24	2672.388	2.639.156		33.232	0.225		22	23	75.0	144.166	110	0.676	0.153	0.718	0.104	0.000

----- NodeData -----

----- LineData -----

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (1/s)	Remarks	ST	Node EN	D (mm)	L (m)	Coef C	Q (1/s)	V (m/s)	I (%)	HL (m)	P (m)
25	2672.066	2.648.840		23.226	0.225		23	24	37.5	76.626	110	0.225	0.204	2.746	0.210	0.000
26	2672.591	2.639.255	33.336	33.336	0.000		23	25	37.5	193.779	110	0.225	0.204	2.746	0.532	0.000
27	2672.591	2.638.286	34.305	34.305	0.000		23	26	75.0	78.843	110	0.225	0.051	0.094	0.007	0.000
28	2672.136	2.640.412	31.724	31.724	0.225		26	27	37.5	63.445	110	0.000	0.000	0.000	0.000	0.000
29	2672.591	2.633.869	38.722	38.722	0.000		26	28	37.5	165.855	110	0.225	0.204	2.746	0.455	0.000
30	2667.665	2.638.502	29.163	29.163	0.000		26	29	75.0	94.027	110	0.000	0.000	0.000	0.000	0.000
31	2667.665	2.635.328	32.337	32.337	0.000		30	31	37.5	163.997	110	0.000	0.000	0.000	0.000	0.000
32	2665.730	2.633.840	31.889	31.889	0.000		30	32	75.0	135.739	110	3.395	0.769	14.258	1.935	0.000
33	2628.657	2.606.060	22.597	22.597	0.000		32	38	75.0	306.663	110	2.944	0.667	10.952	3.359	0.000
34	2628.297	2.594.605	33.692	33.692	0.225		32	112	37.5	0.100	110	0.451	0.408	9.913	0.001	-31.888
35	2628.285	2.602.746	25.539	25.539	0.000		33	34	37.5	131.019	110	0.225	0.204	2.746	0.360	0.000
36	2628.019	2.607.019	20.999	20.999	0.225		33	35	37.5	135.480	110	0.225	0.204	2.746	0.372	0.000
37	2628.285	2.587.186	41.098	41.098	0.000		35	36	37.5	96.947	110	0.225	0.204	2.746	0.266	0.000
38	2662.371	2.628.299	34.072	34.072	0.000		35	37	37.5	155.253	110	0.000	0.000	0.000	0.000	0.000
39	2660.651	2.623.546	37.105	37.105	0.000		38	39	75.0	149.759	110	3.021	0.684	11.482	1.720	0.000
40	2623.546	2.605.298	18.249	18.249	0.000		38	97	50.0	124.408	110	-0.076	-0.039	-0.091	-0.011	0.000
41	2623.546	2.606.458	17.089	17.089	0.000		39	113	75.0	0.100	110	1.127	0.255	1.849	0.000	-37.105
42	2623.546	2.602.136	21.411	21.411	0.000		39	118	75.0	227.583	110	1.894	0.429	4.837	1.101	0.000
43	2623.364	2.617.831	5.533	5.533	0.000		40	41	37.5	22.791	110	0.000	0.000	0.000	0.000	0.000
44	2622.638	2.594.942	27.696	27.696	0.225		40	42	37.5	117.963	110	0.000	0.000	0.000	0.000	0.000
45	2622.638	2.589.029	33.609	33.609	0.000		43	44	37.5	264.336	110	0.225	0.204	2.746	0.726	0.000
46	2623.104	2.610.616	12.488	12.488	0.000		43	46	65.0	105.762	110	0.901	0.272	2.456	0.260	0.000
47	2616.199	2.598.849	17.349	17.349	0.000		44	45	37.5	47.986	110	0.000	0.000	0.000	0.000	0.000
48	2616.071	2.595.483	20.588	20.588	0.225		46	47	37.5	192.998	110	0.901	0.817	35.780	6.906	0.000
49	2592.996	2.575.018	17.978	17.978	0.225		46	52	65.0	23.052	110	0.000	0.000	0.000	0.000	0.000
50	2591.389	2.566.153	25.236	25.236	0.225		47	48	37.5	46.357	110	0.225	0.204	2.746	0.127	0.000
51	2590.618	2.549.208	41.410	41.410	0.225		47	114	37.5	0.100	110	0.676	0.612	21.003	0.002	-17.347
52	2623.104	2.611.045	12.059	12.059	0.000		49	50	37.5	162.117	110	0.451	0.408	9.913	1.607	0.000
53	2623.104	2.608.679	14.425	14.425	0.000		50	51	37.5	280.793	110	0.225	0.204	2.746	0.771	0.000
54	2623.104	2.598.152	24.952	24.952	0.000		52	53	50.0	105.543	110	0.000	0.000	0.000	0.000	0.000
55	2657.467	2.610.185	47.282	47.282	0.000		53	54	38	185.127	110	0.000	0.000	0.000	0.000	0.000
56	2608.096	2.600.317	7.779	7.779	0.225		55	63	50	145.769	110	2.028	1.033	39.567	5.768	0.000
57	2607.878	2.590.637	17.240	17.240	0.000		55	117	38	0.100	110	0.451	0.408	9.913	0.001	-47.281
58	2607.878	2.573.553	34.324	34.324	0.000		56	57	38	79.436	110	0.225	0.204	2.746	0.218	0.000
59	2607.713	2.586.678	21.035	21.035	0.225		57	58	38	280.099	110	0.000	0.000	0.000	0.000	0.000
60	2607.713	2.572.897	34.816	34.816	0.000		57	59	38	60.044	110	0.225	0.204	2.746	0.165	0.000
61	2607.713	2.560.109	47.603	47.603	0.000		59	60	38	78.645	110	0.000	0.000	0.000	0.000	0.000
62	2607.713	2.555.223	52.490	52.490	0.000		60	61	38	142.935	110	0.000	0.000	0.000	0.000	0.000
63	2651.699	2.613.779	37.920	37.920	0.225		60	62	38	197.215	110	0.000	0.000	0.000	0.000	0.000
64	2604.148	2.597.077	7.071	7.071	0.225		63	72	50	37.566	110	0.901	0.459	8.814	0.331	0.000

--- NodeData ---

--- LineData ---


Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	ST	EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
65	2601.767	2.576.356		25.411	0.000		63	115	38	0.100	110	0.901	0.817	35.782	0.004	-37.917
66	2600.058	2.573.891		26.166	0.225		64	65	38	113.377	110	0.676	0.612	21.003	2.381	0.000
67	2599.436	2.553.076		46.360	0.225		65	66	38	172.393	110	0.451	0.408	9.912	1.709	0.000
68	2600.058	2.570.643		29.414	0.000		65	69	38	14.938	110	0.225	0.204	2.746	0.041	0.000
69	2601.725	2.574.186		27.539	0.000		66	67	38	226.436	110	0.225	0.204	2.746	0.622	0.000
70	2601.725	2.563.787		37.939	0.000		66	68	38	131.300	110	0.000	0.000	0.000	0.000	0.000
71	2601.333	2.567.443		33.890	0.225		69	70	38	102.389	110	0.000	0.000	0.000	0.000	0.000
72	2651.368	2.616.146		35.222	0.000		69	71	38	143.007	110	0.225	0.204	2.746	0.393	0.000
73	2651.236	2.641.121		10.115	0.225		72	73	50	195.905	110	0.225	0.115	0.676	0.133	0.000
74	2648.059	2.619.902		28.157	0.225		72	74	38	157.571	110	0.676	0.612	21.003	3.309	0.000
75	2617.061	2.597.497		19.564	0.000		74	116	38	0.100	110	0.451	0.408	9.913	0.001	-28.156
76	2616.095	2.601.146		14.948	0.000		75	76	38	97.487	110	0.451	0.408	9.912	0.966	0.000
77	2615.174	2.552.038		63.136	0.000		76	77	38	335.866	110	0.225	0.204	2.746	0.921	0.000
78	2574.476	2.544.476	70.088	30.000	0.225	reak Pressure Valv	76	79	38	37.283	110	0.225	0.204	2.746	0.102	0.000
79	2615.992	2.599.225		16.768	0.000		77	78	38	221.917	110	0.225	0.204	2.746	0.609	-40.088
80	2615.593	2.585.933		29.660	0.000		79	80	38	145.320	110	0.225	0.204	2.746	0.399	0.000
81	2615.270	2.572.614		42.656	0.225		80	81	38	117.716	110	0.225	0.204	2.746	0.323	0.000
82	2615.593	2.586.446		29.147	0.000		80	82	38	79.963	110	0.000	0.000	21.003	0.000	0.000
83	2665.727	2.653.412		12.315	0.000		83	84	38	128.469	110	0.676	0.612	21.003	2.698	0.000
84	2663.029	2.646.151		16.879	0.000		83	92	75	42.444	110	2.464	0.558	7.876	0.334	0.000
85	2662.148	2.614.118		48.030	0.000		84	85	38	320.993	110	0.225	0.204	2.746	0.881	0.000
86	2662.079	2.609.337		52.742	0.225		84	87	38	49.509	110	0.451	0.408	9.913	0.491	0.000
87	2662.538	2.642.879		19.660	0.000		85	86	38	25.157	110	0.225	0.204	2.746	0.069	0.000
88	2662.467	2.643.004		19.463	0.225		87	88	38	26.182	110	0.225	0.204	2.746	0.072	0.000
89	2661.929	2.615.695		46.234	0.000		87	89	38	221.991	110	0.225	0.204	2.746	0.610	0.000
90	2661.677	2.613.128		48.549	0.225		89	90	38	91.771	110	0.225	0.204	2.746	0.252	0.000
91	2661.929	2.609.365		52.564	0.000		89	91	38	103.869	110	0.000	0.000	0.000	0.000	0.000
92	2665.393	2.649.415		15.978	0.225		92	93	75	117.501	110	2.239	0.507	6.594	0.775	0.000
93	2664.618	2.635.990		28.628	0.000		93	94	38	51.545	110	0.225	0.204	2.746	0.142	0.000
94	2664.477	2.630.675		33.802	0.225		93	95	75	365.347	110	2.013	0.456	5.418	1.979	0.000
95	2662.639	2.627.783		34.856	0.000		95	96	38	81.890	110	0.225	0.204	2.746	0.225	0.000
96	2662.414	2.619.503		42.911	0.225		95	97	75	59.027	110	1.788	0.405	4.349	0.257	0.000
97	2662.382	2.626.850		35.533	0.000		97	98	38	90.806	110	0.225	0.204	2.746	0.249	0.000
98	2662.133	2.613.347		48.786	0.225		97	99	75	334.654	110	1.487	0.337	3.089	1.034	0.000
99	2661.348	2.612.993		48.356	0.000		99	100	38	120.771	110	0.225	0.204	2.746	0.332	0.000
100	2661.017	2.610.654		50.363	0.225		99	101	50	18.706	110	1.261	0.643	16.416	0.307	0.000
101	2661.041	2.611.913		49.128	0.225		101	102	38	160.098	110	0.451	0.408	9.913	1.587	-51.883
102	2607.572	2.607.572	51.883	-0.000	0.000	reak Pressure Tan	102	103	38	86.388	110	0.225	0.204	2.746	0.237	0.000
103	2607.335	2.598.508		8.827	0.225		102	104	38	418.211	110	0.225	0.204	2.746	1.148	0.000
104	2606.423	2.572.544		33.879	0.225		111	22	75	293.703	110	4.071	0.922	19.957	5.861	0.000

---- NodeData ----

---- LineData ----

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	Node ST EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
111	2678.563	2.678.563	23.771	0.000	0.000	reak Pressure Tan	112 33	38	522.930	110	0.451	0.408	9.913	5.184	0.000
112	2633.840	2.633.840	31.888	-0.000	0.000	reak Pressure Tan	113 40	38	174.553	110	0.000	0.000	0.000	0.000	0.000
113	2623.546	2.623.546	37.105	-0.000	0.000	reak Pressure Tan	113 43	75	98.768	110	1.127	0.255	1.849	0.183	0.000
114	2598.849	2.598.849	17.347	0.000	0.000	reak Pressure Tan	114 49	38	278.695	110	0.676	0.612	21.003	5.853	0.000
115	2613.779	2.613.779	37.917	-0.000	0.000	reak Pressure Tan	115 64	38	269.183	110	0.901	0.817	35.780	9.631	0.000
116	2619.902	2.619.902	28.156	-0.000	0.000	reak Pressure Tan	116 75	38	286.580	110	0.451	0.408	9.913	2.841	0.000
117	2610.185	2.610.185	47.281	-0.000	0.000	reak Pressure Tan	117 56	38	210.779	110	0.451	0.408	9.913	2.089	0.000
118	2659.551	2.611.045		48.506	0.000		118 55	75	261.653	110	2.479	0.561	7.963	2.084	0.000
							118 101	38	92.744	110	-0.585	-0.530	-16.074	-1.491	0.000

Yetimen Pipe Networks



Legend

New: 100mm	—
New: 75mm	—
New: 50mm	—
New: 40mm	—
Exist: 100mm	- - -
Exist: 75mm	- - -
Exist: 50mm	- - -
Exist: 40mm	- - -

-----Yetimen <<Case.1 : Hazen-Williams Formula>>-----

Tank 1 Maximum EHP 37.204 (m) << Explanatory Notes >>
 Node 25 Minimum EHP 13.863 (m) - Line -
 Line 25 Maximum I 0.000 (%) D: Diameter
 Maximum V 0.000 (m/s) L: Length of Pipe
 Pump Decom 0 Coef: Friction Coefficient
 Convergence Gap 0.00 (cm) Q: Quantity of Flow
 Calculation 2 (times) V: Velocity of Flow
 I: Hydraulic Gradient
 HL: Head Loss
 P: Add Pressure

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	Node ST	Node EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
1	2445.775	2.445.775		0.000	-0.000	Reservoir Tank	1	2	75.0	122.593	110	0.000	0.000	0.000	0.000	0.000
2	2445.775	2.430.247		15.528	0.000		2	3	37.5	233.440	110	0.000	0.000	0.000	0.000	0.000
3	2445.775	2.427.969		17.806	0.000		2	9	37.5	181.823	110	0.000	0.000	0.000	0.000	0.000
4	2445.775	2.427.235		18.540	0.000		2	13	75.0	218.028	110	0.000	0.000	0.000	0.000	0.000
5	2445.775	2.427.269		18.506	0.000		3	4	37.5	211.438	110	0.000	0.000	0.000	0.000	0.000
6	2445.775	2.418.940		26.835	0.000		4	5	37.5	29.691	110	0.000	0.000	0.000	0.000	0.000
7	2445.775	2.430.110		15.665	0.000		5	6	37.5	186.444	110	0.000	0.000	0.000	0.000	0.000
8	2445.775	2.420.266		25.509	0.000		5	7	37.5	168.369	110	0.000	0.000	0.000	0.000	0.000
9	2445.775	2.431.912		13.863	0.000		5	8	37.5	314.448	110	0.000	0.000	0.000	0.000	0.000
10	2445.775	2.424.229		21.546	0.000		9	10	37.5	338.976	110	0.000	0.000	0.000	0.000	0.000
11	2445.775	2.418.920		26.855	0.000		10	11	37.5	227.765	110	0.000	0.000	0.000	0.000	0.000
12	2445.775	2.413.235		32.540	0.000		10	12	37.5	172.222	110	0.000	0.000	0.000	0.000	0.000
13	2445.775	2.419.148		26.627	0.000		13	14	37.5	105.331	110	0.000	0.000	0.000	0.000	0.000
14	2445.775	2.421.306		24.469	0.000		13	21	75.0	16.799	110	0.000	0.000	0.000	0.000	0.000
15	2445.775	2.424.991		20.784	0.000		14	15	37.5	256.414	110	0.000	0.000	0.000	0.000	0.000
16	2445.775	2.416.621		29.154	0.000		15	16	37.5	286.635	110	0.000	0.000	0.000	0.000	0.000
17	2445.775	2.424.153		21.622	0.000		15	17	37.5	54.082	110	0.000	0.000	0.000	0.000	0.000
18	2445.775	2.423.421		22.354	0.000		17	18	37.5	63.991	110	0.000	0.000	0.000	0.000	0.000
19	2445.775	2.421.428		24.347	0.000		17	19	37.5	79.942	110	0.000	0.000	0.000	0.000	0.000
20	2445.775	2.408.571		37.204	0.000		19	20	37.5	349.857	110	0.000	0.000	0.000	0.000	0.000
21	2445.775	2.419.148		26.627	0.000		21	22	75.0	96.666	110	0.000	0.000	0.000	0.000	0.000
22	2445.775	2.416.366		29.409	0.000		21	24	37.5	287.787	110	0.000	0.000	0.000	0.000	0.000
23	2445.775	2.411.422		34.353	0.000		22	23	75.0	224.852	110	0.000	0.000	0.000	0.000	0.000
24	2445.775	2.416.708		29.067	0.000		24	25	37.5	214.222	110	0.000	0.000	0.000	0.000	0.000

----- NodeData ----- LineData -----

-----Yetimen <<Case.2 : Hazen-Williams Formula>>-----

<< Explanatory Notes >>

- Line -
 D: Diameter
 L: Length of Pipe
 Coef: Friction Coefficient
 Q: Quantity of Flow
 V: Velocity of Flow
 I: Hydraulic Gradient
 HL: Head Loss
 P: Add Pressure

- Node -
 HP: Head Pressure
 GL: Ground Level
 EHP: Effectual Head Pressure
 Qc: Consumption of Water


Tank I Maximum EHP 33.260 (m)
 Node 25 Minimum EHP 8.156 (m)
 Line 25 Maximum I 17.312 (%)
 Pump.Decom 0 Maximum V 0.552 (m/s)

Convergence Gap 0.99 (cm)
 Calculation 12 (times)

----- NodeData -----

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	Node ST	Node EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
1	2445.775	2.445.775		0.000	-2.071	Reservoir Tank	1	2	75.0	122.593	110	2.071	0.469	5.709	0.700	0.000
2	2445.075	2.430.247		14.828	0.000		2	3	37.5	233.440	110	0.609	0.552	17.311	4.041	0.000
3	2441.034	2.427.969		13.065	0.122		2	9	37.5	181.823	110	0.365	0.331	6.722	1.222	0.000
4	2438.613	2.427.235		11.378	0.122		2	13	75.0	218.028	110	1.096	0.248	1.758	0.383	0.000
5	2438.414	2.427.269		11.145	0.000		3	4	37.5	211.438	110	0.487	0.441	11.450	2.421	0.000
6	2438.250	2.418.940		19.310	0.122		4	5	37.5	29.691	110	0.365	0.331	6.721	0.200	0.000
7	2438.266	2.430.110		8.156	0.122		5	6	37.5	186.444	110	0.122	0.110	0.879	0.164	0.000
8	2438.137	2.420.266		17.871	0.122		5	7	37.5	168.369	110	0.122	0.110	0.879	0.148	0.000
9	2443.853	2.431.912		11.941	0.122		5	8	37.5	314.448	110	0.122	0.110	0.879	0.276	0.000
10	2442.777	2.424.229		18.548	0.000		9	10	37.5	338.976	110	0.244	0.221	3.173	1.076	0.000
11	2442.577	2.418.920		23.657	0.122		10	11	37.5	227.765	110	0.122	0.110	0.879	0.200	0.000
12	2442.626	2.413.235		29.391	0.122		10	12	37.5	172.222	110	0.122	0.110	0.879	0.151	0.000
13	2444.692	2.419.148		25.544	0.000		13	14	37.5	105.331	110	0.609	0.552	17.312	1.823	0.000
14	2442.868	2.421.306		21.562	0.122		13	21	75.0	16.799	110	0.487	0.110	0.391	0.007	0.000
15	2439.932	2.424.991		14.941	0.000		14	15	37.5	256.414	110	0.487	0.441	11.452	2.936	0.000
16	2439.680	2.416.621		23.059	0.122		15	16	37.5	286.635	110	0.122	0.110	0.879	0.252	0.000
17	2439.568	2.424.153		15.415	0.000		15	17	37.5	54.082	110	0.365	0.331	6.723	0.364	0.000
18	2439.512	2.423.421		16.091	0.122		17	18	37.5	63.991	110	0.122	0.110	0.879	0.056	0.000
19	2439.315	2.421.428		17.887	0.122		17	19	37.5	79.942	110	0.244	0.221	3.173	0.254	0.000
20	2439.007	2.408.571		30.436	0.122		19	20	37.5	349.857	110	0.122	0.110	0.879	0.308	0.000
21	2444.685	2.419.148		25.537	0.000		21	22	75.0	96.666	110	0.122	0.028	0.030	0.003	0.000
22	2444.682	2.416.366		28.316	0.122		21	24	37.5	287.787	110	0.365	0.331	6.722	1.935	0.000
23	2444.682	2.411.422		33.260	0.000		22	23	75.0	224.852	110	0.000	0.000	0.000	0.000	0.000
24	2442.751	2.416.708		26.043	0.122		24	25	37.5	214.222	110	0.244	0.221	3.172	0.680	0.000

Lumame Pipe Networks



Legend

—	New : 100mm
—	New : 75mm
—	New : 50mm
—	New : 40mm
- - -	Exist : 100mm
- - -	Exist : 75mm
- - -	Exist : 50mm
- - -	Exist : 40mm

-----Luname <<Case. 1 : Hazen-Williams Formula>>-----

<< Explanatory Notes >>

- Line -
 D: Diameter
 L: Length of Pipe
 Coef: Friction Coefficient
 Q: Quantity of Flow
 V: Velocity of Flow
 I: Hydraulic Gradient
 HL: Head Loss
 P: Add Pressure

- Node -
 HP: Head Pressure
 GL: Ground Level
 EHP: Effectual Head Pressure
 Qc: Consumption of Water

Tank 1 Maximum EHP 52.343 (m)
 Node 48 Minimum EHP 12.929 (m)
 Line 50 Maximum I 0.000 (%)
 Pump.Decom 0 Maximum V 0.000 (m/s)

Convergence Gap 0.00 (cm)
 Calculation 2 (times)

----- NodeData -----

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	Node ST	Node EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
1	2505.819	2.497.769		8.050	0.000	Reservoir Tank	1	2	75.0	240.166	110	0.000	0.000	0.000	0.000	0.000
2	2505.819	2.485.570		20.249	0.000		1	21	37.5	124.844	110	0.000	0.000	0.000	0.000	0.000
3	2505.819	2.478.002		27.817	0.000		1	49	100.0	186.712	110	0.000	0.000	0.000	0.000	0.000
4	2505.819	2.483.278		22.541	0.000		2	3	37.5	75.572	110	0.000	0.000	0.000	0.000	0.000
5	2505.819	2.475.730		30.089	0.000		2	4	75.0	58.442	110	0.000	0.000	0.000	0.000	0.000
6	2505.819	2.479.872		25.947	0.000		4	5	37.5	116.212	110	0.000	0.000	0.000	0.000	0.000
7	2505.819	2.471.057		34.762	0.000		4	6	75.0	123.637	110	0.000	0.000	0.000	0.000	0.000
8	2505.819	2.479.479		26.340	0.000		6	7	37.5	158.415	110	0.000	0.000	0.000	0.000	0.000
9	2505.819	2.476.115		29.704	0.000		6	8	37.5	39.525	110	0.000	0.000	0.000	0.000	0.000
10	2505.819	2.476.975		28.844	0.000		7	14	37.5	361.055	110	0.000	0.000	0.000	0.000	0.000
11	2505.819	2.476.515		29.304	0.000		8	9	37.5	156.505	110	0.000	0.000	0.000	0.000	0.000
12	2505.819	2.490.686		15.133	0.000		9	10	37.5	270.158	110	0.000	0.000	0.000	0.000	0.000
13	2505.819	2.480.695		25.124	0.000		10	11	37.5	27.311	110	0.000	0.000	0.000	0.000	0.000
14	2505.819	2.467.909		37.910	0.000		10	13	37.5	64.905	110	0.000	0.000	0.000	0.000	0.000
15	2505.819	2.466.395		39.424	0.000		12	13	75.0	211.914	110	0.000	0.000	0.000	0.000	0.000
16	2505.819	2.462.879		42.940	0.000		12	18	37.5	120.098	110	0.000	0.000	0.000	0.000	0.000
17	2505.819	2.469.119		36.700	0.000		13	17	75.0	157.353	110	0.000	0.000	0.000	0.000	0.000
18	2505.819	2.484.223		21.596	0.000		14	15	37.5	154.475	110	0.000	0.000	0.000	0.000	0.000
19	2505.819	2.466.960		38.859	0.000		15	16	37.5	229.472	110	0.000	0.000	0.000	0.000	0.000
20	2505.819	2.482.798		23.021	0.000		15	17	37.5	162.406	110	0.000	0.000	0.000	0.000	0.000
21	2505.819	2.488.260		17.559	0.000		16	48	37.5	330.309	110	0.000	0.000	0.000	0.000	0.000
22	2505.819	2.487.557		18.262	0.000		17	24	37.5	214.586	110	0.000	0.000	0.000	0.000	0.000
23	2505.819	2.487.846		17.973	0.000		17	30	75.0	23.287	110	0.000	0.000	0.000	0.000	0.000
24	2505.819	2.465.203		40.616	0.000		18	19	37.5	149.669	110	0.000	0.000	0.000	0.000	0.000

----- NodeData -----

----- NodeData -----

----- LineData -----

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (1/s)	Remarks	Node ST EN	D (mm)	L (m)	Coef C	Q (1/s)	V (m/s)	I (%)	HL (m)	P (m)
25	2505.819	2.462.249		43.570	0.000		18 20	37.5	133.816	110	0.000	0.000	0.000	0.000	0.000
26	2505.819	2.467.756		38.063	0.000		21 22	37.5	23.435	110	0.000	0.000	0.000	0.000	0.000
27	2505.819	2.468.042		37.777	0.000		21 23	37.5	120.584	110	0.000	0.000	0.000	0.000	0.000
28	2505.819	2.482.775		23.044	0.000		24 25	37.5	97.004	110	0.000	0.000	0.000	0.000	0.000
29	2505.819	2.462.028		43.791	0.000		24 26	37.5	16.021	110	0.000	0.000	0.000	0.000	0.000
30	2505.819	2.469.119		36.700	0.000		26 27	37.5	12.562	110	0.000	0.000	0.000	0.000	0.000
31	2505.819	2.466.103		39.716	0.000		26 28	37.5	238.879	110	0.000	0.000	0.000	0.000	0.000
32	2505.819	2.463.965		41.854	0.000		28 29	37.5	174.023	110	0.000	0.000	0.000	0.000	0.000
33	2505.819	2.463.243		42.576	0.000		30 31	37.5	169.219	110	0.000	0.000	0.000	0.000	0.000
34	2505.819	2.462.506		43.313	0.000		30 36	37.5	349.479	110	0.000	0.000	0.000	0.000	0.000
35	2505.819	2.465.147		40.672	0.000		30 38	75.0	14.847	110	0.000	0.000	0.000	0.000	0.000
36	2505.819	2.465.892		39.927	0.000		31 32	37.5	129.307	110	0.000	0.000	0.000	0.000	0.000
37	2505.819	2.466.766		39.053	0.000		31 35	37.5	237.093	110	0.000	0.000	0.000	0.000	0.000
38	2505.819	2.469.773		36.046	0.000		32 33	37.5	61.048	110	0.000	0.000	0.000	0.000	0.000
39	2505.819	2.467.287		38.532	0.000		32 34	37.5	54.019	110	0.000	0.000	0.000	0.000	0.000
40	2505.819	2.473.213		32.606	0.000		36 37	37.5	253.273	110	0.000	0.000	0.000	0.000	0.000
41	2505.819	2.472.929		32.890	0.000		38 39	75.0	136.194	110	0.000	0.000	0.000	0.000	0.000
42	2505.819	2.481.970		23.849	0.000		39 40	50.0	440.235	110	0.000	0.000	0.000	0.000	0.000
43	2505.819	2.487.080		18.739	0.000		39 44	37.5	124.093	110	0.000	0.000	0.000	0.000	0.000
44	2505.819	2.463.032		42.787	0.000		40 41	37.5	24.327	110	0.000	0.000	0.000	0.000	0.000
45	2505.819	2.461.905		43.914	0.000		40 42	50.0	114.120	110	0.000	0.000	0.000	0.000	0.000
46	2505.819	2.453.476		52.343	0.000		42 43	37.5	88.219	110	0.000	0.000	0.000	0.000	0.000
47	2505.819	2.463.283		42.536	0.000		44 45	37.5	55.325	110	0.000	0.000	0.000	0.000	0.000
48	2505.819	2.466.677		39.142	0.000		44 46	37.5	405.357	110	0.000	0.000	0.000	0.000	0.000
49	2505.819	2.492.890		12.929	0.000		46 47	37.5	558.375	110	0.000	0.000	0.000	0.000	0.000
							49 12	75.0	240.335	110	0.000	0.000	0.000	0.000	0.000

-----Lumame <<Case.2 : Hazen-Williams Formula>>-----

<< Explanatory Notes >>

Tank 1	Maximum EHP	31.480 (m)
Node 48	Minimum EHP	4.408 (m)
Line 50	Maximum I	35.149 (%)
Pump, Decom 0	Maximum V	0.913 (m/s)

Convergence Gap 0.97 (cm)

Calculation 13 (times)

- Line -
 D: Diameter
 L: Length of Pipe
 Coef: Friction Coefficient
 Q: Quantity of Flow
 V: Velocity of Flow
 I: Hydraulic Gradient
 HL: Head Loss
 P: Add Pressure

- Node -
 HP: Head Pressure
 GL: Ground Level
 EHP: Effectual Head Pressure
 Qc: Consumption of Water

--- NodeData ---

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	Node ST	Node EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
1	2505.819	2.497.769		8.050	-6.845	Reservoir Tank	1	2	75.0	240.166	110	2.218	0.502	6.483	1.557	0.000
2	2504.262	2.485.570		18.692	0.000		1	21	37.5	124.844	110	0.595	0.539	16.590	2.071	0.000
3	2503.915	2.478.002		25.913	0.298		1	49	100.0	186.712	110	4.031	0.514	4.828	0.901	0.000
4	2503.972	2.483.278		20.694	0.000		2	3	37.5	75.572	110	0.298	0.270	4.596	0.347	0.000
5	2503.438	2.475.730		27.708	0.298		2	4	75.0	58.442	110	1.921	0.435	4.965	0.290	0.000
6	2503.522	2.479.872		23.650	0.000		4	5	37.5	116.212	110	0.298	0.270	4.596	0.534	0.000
7	2498.709	2.471.057		27.652	0.298		4	6	75.0	123.637	110	1.623	0.368	3.635	0.449	0.000
8	2502.394	2.479.479		22.915	0.298		6	7	37.5	158.415	110	0.825	0.748	30.383	4.813	0.000
9	2500.513	2.476.115		24.398	0.000		6	8	37.5	39.525	110	0.798	0.723	28.539	1.128	0.000
10	2497.265	2.476.975		20.290	0.000		7	14	37.5	361.055	110	0.528	0.478	13.271	4.791	0.000
11	2497.139	2.476.515		20.624	0.298		8	9	37.5	156.505	110	0.500	0.453	12.023	1.882	0.000
12	2500.208	2.490.686		9.522	0.000		9	10	37.5	270.158	110	0.500	0.453	12.022	3.248	0.000
13	2497.118	2.480.695		16.423	0.000		10	11	37.5	27.311	110	0.298	0.270	4.596	0.126	0.000
14	2493.918	2.467.909		26.009	0.298		10	13	37.5	64.905	110	0.203	0.184	2.256	0.146	0.000
15	2493.477	2.466.395		27.082	0.000		12	13	75.0	211.914	110	3.436	0.778	14.579	3.090	0.000
16	2489.671	2.462.879		26.792	0.298		12	18	37.5	120.098	110	0.595	0.539	16.590	1.992	0.000
17	2494.568	2.469.119		25.449	0.000		13	17	75.0	157.353	110	3.639	0.824	16.211	2.551	0.000
18	2498.216	2.484.223		13.993	0.000		14	15	37.5	154.475	110	0.230	0.208	2.853	0.441	0.000
19	2497.528	2.466.960		30.568	0.298		15	16	37.5	229.472	110	0.595	0.539	16.589	3.807	0.000
20	2497.601	2.482.798		14.803	0.298		15	17	37.5	162.406	110	-0.365	-0.331	-6.713	-1.090	0.000
21	2503.748	2.488.260		15.488	0.000		16	48	37.5	330.309	110	0.298	0.270	4.596	1.518	0.000
22	2503.640	2.487.557		16.083	0.298		17	24	37.5	214.586	110	0.298	0.270	4.596	0.986	0.000
23	2503.194	2.487.846		15.348	0.298		17	30	75.0	23.287	110	2.976	0.674	11.161	0.260	0.000
24	2493.581	2.465.203		28.378	0.000		18	19	37.5	149.669	110	0.298	0.270	4.596	0.688	0.000


--- NodeData ---

--- NodeData ---

--- LineData ---

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	Node ST EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
25	2493.581	2.462.249		31.332	0.000		18 20	37.5	133.816	110	0.298	0.270	4.596	0.615	0.000
26	2493.508	2.467.756		25.752	0.000		21 22	37.5	23.435	110	0.298	0.270	4.596	0.108	0.000
27	2493.450	2.468.042		25.408	0.298		21 23	37.5	120.584	110	0.298	0.270	4.596	0.554	0.000
28	2493.508	2.482.775		10.733	0.000		24 25	37.5	97.004	110	0.000	0.000	0.000	0.000	0.000
29	2493.508	2.462.028		31.480	0.000		24 26	37.5	16.021	110	0.298	0.270	4.596	0.074	0.000
30	2494.308	2.469.119		25.189	0.000		26 27	37.5	12.562	110	0.298	0.270	4.596	0.058	0.000
31	2491.500	2.466.103		25.397	0.000		26 28	37.5	238.879	110	0.000	0.000	0.000	0.000	0.000
32	2490.906	2.463.965		26.941	0.000		28 29	37.5	174.023	110	0.000	0.000	0.000	0.000	0.000
33	2490.906	2.463.243		27.663	0.000		30 31	37.5	169.219	110	0.595	0.539	16.589	2.807	0.000
34	2490.658	2.462.506		28.152	0.298		30 36	37.5	349.479	110	0.595	0.539	16.589	5.797	0.000
35	2490.411	2.465.147		25.264	0.298		30 38	75.0	14.847	110	1.786	0.404	4.338	0.064	0.000
36	2488.510	2.465.892		22.618	0.298		31 32	37.5	129.307	110	0.298	0.270	4.596	0.594	0.000
37	2487.346	2.466.766		20.580	0.298		31 35	37.5	237.093	110	0.298	0.270	4.596	1.090	0.000
38	2494.243	2.469.773		24.470	0.298		32 33	37.5	61.048	110	0.000	0.000	0.000	0.000	0.000
39	2493.822	2.467.287		26.535	0.000		32 34	37.5	54.019	110	0.298	0.270	4.596	0.248	0.000
40	2492.023	2.473.213		18.810	0.000		36 37	37.5	253.273	110	0.298	0.270	4.596	1.164	0.000
41	2491.911	2.472.929		18.982	0.298		38 39	75.0	136.194	110	1.488	0.337	3.095	0.422	0.000
42	2491.894	2.481.970		9.924	0.000		39 40	50.0	440.235	110	0.595	0.303	4.086	1.799	0.000
43	2491.488	2.487.080		4.408	0.298		39 44	37.5	124.093	110	0.893	0.809	35.149	4.362	0.000
44	2489.460	2.463.032		26.428	0.000		40 41	37.5	24.327	110	0.298	0.270	4.596	0.112	0.000
45	2489.206	2.461.905		27.301	0.298		40 42	50.0	114.120	110	0.298	0.152	1.132	0.129	0.000
46	2482.735	2.453.476		29.259	0.298		42 43	37.5	88.219	110	0.298	0.270	4.596	0.405	0.000
47	2480.169	2.463.283		16.886	0.298		44 45	37.5	55.325	110	0.298	0.270	4.596	0.254	0.000
48	2488.152	2.466.677		21.475	0.298		44 46	37.5	405.857	110	0.595	0.539	16.589	6.725	0.000
49	2504.918	2.492.890		12.028	0.000		46 47	37.5	558.375	110	0.298	0.270	4.596	2.566	0.000
							49 12	75.0	240.335	110	4.031	0.913	19.596	4.710	0.000

Wojel Pipe Networks



Legend

New: 100mm
New: 75mm
New: 50mm
New: 40mm
Exist: 100mm
Exist: 75mm
Exist: 50mm
Exist: 40mm

-----Wojel <<Case.1 : Hazen-Williams Formula>>-----

<< Explanatory Notes >>

Tank 1 Maximum EHP 61.324 (m)
 Node 29 Minimum EHP 3.995 (m)
 Line 29 Maximum I 0.000 (%)
 Pump Decom 0 Maximum V 0.000 (m/s)

Convergence Gap 0.00 (cm)
 Calculation 2 (times)

- Line -
 D: Diameter
 L: Length of Pipe
 Coef: Friction Coefficient
 Q: Quantity of Flow
 V: Velocity of Flow
 I: Hydraulic Gradient
 HL: Head Loss
 P: Add Pressure

- Node -
 HP: Head Pressure
 GL: Ground Level
 EHP: Effectual Head Pressure
 Qc: Consumption of Water

----- LineData -----

----- NodeData -----

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	Node ST	Node EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
1	2488.580	2.488.580		0.000	-0.000	Reservoir Tank	1	2	75.0	281.892	110	0.000	0.000	0.000	0.000	0.000
2	2488.580	2.468.554		20.026	0.000		1	29	37.5	169.070	110	0.000	0.000	0.000	0.000	0.000
3	2488.580	2.457.691		30.889	0.000		2	3	75.0	215.938	110	0.000	0.000	0.000	0.000	0.000
4	2488.580	2.459.356		29.224	0.000		3	4	37.5	224.731	110	0.000	0.000	0.000	0.000	0.000
5	2488.580	2.454.353		34.227	0.000		3	9	50.0	126.041	110	0.000	0.000	0.000	0.000	0.000
6	2488.580	2.453.681		34.899	0.000		4	5	37.5	121.741	110	0.000	0.000	0.000	0.000	0.000
7	2488.580	2.449.408		39.172	0.000		4	8	37.5	221.458	110	0.000	0.000	0.000	0.000	0.000
8	2488.580	2.453.958		34.622	0.000		5	6	37.5	37.460	110	0.000	0.000	0.000	0.000	0.000
9	2488.580	2.452.918		35.662	0.000		5	7	37.5	177.094	110	0.000	0.000	0.000	0.000	0.000
10	2488.580	2.450.606		37.974	0.000		9	10	50.0	60.825	110	0.000	0.000	0.000	0.000	0.000
11	2488.580	2.445.876		42.704	0.000		10	11	37.5	120.052	110	0.000	0.000	0.000	0.000	0.000
12	2488.580	2.448.677		39.903	0.000		10	12	50.0	84.910	110	0.000	0.000	0.000	0.000	0.000
13	2488.580	2.447.566		41.014	0.000		12	13	37.5	50.613	110	0.000	0.000	0.000	0.000	0.000
14	2488.580	2.446.475		42.105	0.000		12	17	37.5	20.865	110	0.000	0.000	0.000	0.000	0.000
15	2488.580	2.438.025		50.555	0.000		12	24	37.5	143.358	110	0.000	0.000	0.000	0.000	0.000
16	2488.580	2.429.792		58.788	0.000		13	14	37.5	47.965	110	0.000	0.000	0.000	0.000	0.000
17	2488.580	2.448.557		40.023	0.000		13	15	37.5	285.724	110	0.000	0.000	0.000	0.000	0.000
18	2488.580	2.448.522		40.058	0.000		15	16	37.5	267.710	110	0.000	0.000	0.000	0.000	0.000
19	2488.580	2.449.100		39.480	0.000		17	18	37.5	428.253	110	0.000	0.000	0.000	0.000	0.000
20	2488.580	2.444.628		43.952	0.000		17	19	37.5	142.781	110	0.000	0.000	0.000	0.000	0.000
21	2488.580	2.444.988		43.592	0.000		19	20	37.5	143.976	110	0.000	0.000	0.000	0.000	0.000
22	2488.580	2.443.362		45.218	0.000		19	21	37.5	175.749	110	0.000	0.000	0.000	0.000	0.000
23	2488.580	2.449.607		38.973	0.000		21	22	37.5	102.786	110	0.000	0.000	0.000	0.000	0.000
24	2488.580	2.449.100		39.480	0.000		21	23	37.5	446.829	110	0.000	0.000	0.000	0.000	0.000

-----Wojel <<Case. 2 : Hazen-Williams Formula>>-----

<< Explanatory Notes >>

Tank 1	Maximum EHP	50.405 (m)
Node 29	Minimum EHP	3.610 (m)
Line 29	Maximum I	22.615 (%)
Pump.Decom 0	Maximum V	0.764 (m/s)

Convergence Gap 0.50 (cm)
 Calculation 14 (times)

- Line -
 D: Diameter
 L: Length of Pipe
 Coef: Friction Coefficient
 Q: Quantity of Flow
 V: Velocity of Flow
 I: Hydraulic Gradient
 HL: Head Loss
 P: Add Pressure


- Node -
 HP: Head Pressure
 GL: Ground Level
 EHP: Effectual Head Pressure
 Qc: Consumption of Water

----- LineData -----

----- NodeData -----

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	Node ST	Node EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
1	2488.580	2.488.580		0.000	-2.035	Reservoir Tank	1	2	75.0	281.892	110	1.928	0.437	4.999	1.409	0.000
2	2487.171	2.468.554		18.617	0.107		1	29	37.5	169.070	110	0.107	0.097	0.693	0.117	0.000
3	2486.200	2.457.691		28.509	0.000		2	3	75.0	215.938	110	1.821	0.412	4.497	0.971	0.000
4	2485.009	2.459.356		25.653	0.000		3	4	37.5	224.731	110	0.321	0.291	5.297	1.190	0.000
5	2484.705	2.454.353		30.352	0.000		3	9	50.0	126.041	110	1.499	0.764	22.615	2.850	0.000
6	2484.679	2.453.681		30.998	0.107		4	5	37.5	121.741	110	0.214	0.194	2.500	0.304	0.000
7	2484.582	2.449.408		35.174	0.107		4	8	37.5	221.458	110	0.107	0.097	0.693	0.153	0.000
8	2484.856	2.453.958		30.898	0.107		5	6	37.5	37.460	110	0.107	0.097	0.693	0.026	0.000
9	2483.349	2.452.918		30.431	0.107		5	7	37.5	177.094	110	0.107	0.097	0.693	0.123	0.000
10	2482.150	2.450.606		31.544	0.000		9	10	50.0	60.825	110	1.392	0.709	19.715	1.199	0.000
11	2482.067	2.445.876		36.191	0.107		10	11	37.5	120.052	110	0.107	0.097	0.693	0.083	0.000
12	2480.707	2.448.677		32.030	0.000		10	12	50.0	84.910	110	1.285	0.655	16.999	1.443	0.000
13	2480.580	2.447.566		33.014	0.000		12	13	37.5	50.613	110	0.214	0.194	2.500	0.127	0.000
14	2480.547	2.446.475		34.072	0.107		12	17	37.5	20.865	110	0.536	0.485	13.640	0.285	0.000
15	2480.382	2.438.025		42.357	0.000		12	24	37.5	143.358	110	0.536	0.485	13.640	1.955	0.000
16	2480.197	2.429.792		50.405	0.107		13	14	37.5	47.965	110	0.107	0.097	0.693	0.033	0.000
17	2480.422	2.448.557		31.865	0.107		13	15	37.5	285.724	110	0.107	0.097	0.693	0.198	0.000
18	2480.126	2.448.522		31.604	0.107		15	16	37.5	267.710	110	0.107	0.097	0.693	0.185	0.000
19	2479.666	2.449.100		30.566	0.000		17	18	37.5	428.253	110	0.107	0.097	0.692	0.297	0.000
20	2479.566	2.444.628		34.938	0.107		17	19	37.5	142.781	110	0.321	0.291	5.296	0.756	0.000
21	2479.226	2.444.988		34.238	0.000		19	20	37.5	143.976	110	0.107	0.097	0.693	0.100	0.000
22	2479.155	2.443.362		35.793	0.107		19	21	37.5	175.749	110	0.214	0.194	2.500	0.439	0.000
23	2478.917	2.449.607		29.310	0.107		21	22	37.5	102.786	110	0.107	0.097	0.693	0.071	0.000
24	2478.751	2.449.100		29.651	0.107		21	23	37.5	446.829	110	0.107	0.097	0.693	0.309	0.000

Sedie Pipe Networks



Legend

—	New : 100mm
—	New : 75mm
—	New : 50mm
—	New : 40mm
- - -	Exist : 100mm
- - -	Exist : 75mm
- - -	Exist : 50mm
- - -	Exist : 40mm

-----Sedie <<Case.1 : Hazen-Williams Formula>>-----

<< Explanatory Notes >>

Tank 1 Maximum EHP 53.574 (m)
 Node 22 Minimum EHP 2.501 (m)
 Line 22 Maximum I 0.000 (%)
 Pump.Decom 0 Maximum V 0.000 (m/s)

Convergence Gap 0.00 (cm)

Calculation 2 (times)

- Line -
 D: Diameter
 L: Length of Pipe
 Coef: Friction Coefficient
 Q: Quantity of Flow
 V: Velocity of Flow
 I: Hydraulic Gradient
 HL: Head Loss
 P: Add Pressure

- Node -
 HP: Head Pressure
 GL: Ground Level
 EHP: Effectual Head Pressure
 Qc: Consumption of Water

----- NodeData -----

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	Node ST	Node EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
1	2549.547	2.547.547		2.000	-0.000	Reservoir Tank	1	2	75.0	82.469	110	0.000	0.000	0.000	0.000	0.000
2	2549.547	2.547.046		2.501	0.000		2	3	37.5	164.065	110	0.000	0.000	0.000	0.000	0.000
3	2549.547	2.536.065		13.482	0.000		2	4	75.0	326.205	110	0.000	0.000	0.000	0.000	0.000
4	2549.547	2.523.827		25.720	0.000		4	5	37.5	109.160	110	0.000	0.000	0.000	0.000	0.000
5	2549.547	2.526.481		23.066	0.000		4	7	50.0	107.358	110	0.000	0.000	0.000	0.000	0.000
6	2549.547	2.514.206		35.341	0.000		5	6	37.5	231.116	110	0.000	0.000	0.000	0.000	0.000
7	2549.547	2.513.260		36.287	0.000		7	8	50.0	175.117	110	0.000	0.000	0.000	0.000	0.000
8	2549.547	2.507.277		42.270	0.000		8	9	37.5	29.102	110	0.000	0.000	0.000	0.000	0.000
9	2549.547	2.507.277		42.270	0.000		8	10	50.0	56.618	110	0.000	0.000	0.000	0.000	0.000
10	2549.547	2.507.060		42.487	0.000		10	11	50.0	8.812	110	0.000	0.000	0.000	0.000	0.000
11	2549.547	2.507.083		42.464	0.000		11	12	37.5	353.802	110	0.000	0.000	0.000	0.000	0.000
12	2549.547	2.505.031		44.516	0.000		11	13	50.0	45.623	110	0.000	0.000	0.000	0.000	0.000
13	2549.547	2.506.727		42.820	0.000		13	14	37.5	39.152	110	0.000	0.000	0.000	0.000	0.000
14	2549.547	2.508.331		41.216	0.000		13	15	37.5	78.806	110	0.000	0.000	0.000	0.000	0.000
15	2549.547	2.504.935		44.612	0.000		15	16	37.5	55.669	110	0.000	0.000	0.000	0.000	0.000
16	2549.547	2.505.625		43.922	0.000		15	19	37.5	141.599	110	0.000	0.000	0.000	0.000	0.000
17	2549.547	2.504.639		44.908	0.000		16	17	37.5	19.174	110	0.000	0.000	0.000	0.000	0.000
18	2549.547	2.495.973		53.574	0.000		16	18	37.5	214.400	110	0.000	0.000	0.000	0.000	0.000
19	2549.547	2.502.041		47.506	0.000		19	20	37.5	26.235	110	0.000	0.000	0.000	0.000	0.000
20	2549.547	2.502.041		47.506	0.000		19	21	37.5	23.255	110	0.000	0.000	0.000	0.000	0.000
21	2549.547	2.501.727		47.820	0.000		21	22	37.5	96.237	110	0.000	0.000	0.000	0.000	0.000
22	2549.547	2.498.880		50.667	0.000		21	22	37.5	96.237	110	0.000	0.000	0.000	0.000	0.000
23	2549.547	2.500.127		49.420	0.000		21	23	37.5	267.699	110	0.000	0.000	0.000	0.000	0.000

----- NodeData -----

-----Sedie <<Case.2 : Hazen-Williams Formula>>-----

<< Explanatory Notes >>

Tank	I	Maximum EHP	39.862 (m)
Node	22	Minimum EHP	1.996 (m)
Line	22	Maximum I	30.503 (%)
Pump, Decom	0	Maximum V	0.843 (m/s)

Convergence Gap 0.85 (cm)

Calculation 13 (times)

- Line -
 D: Diameter
 L: Length of Pipe
 Coef: Friction Coefficient
 Q: Quantity of Flow
 V: Velocity of Flow
 I: Hydraulic Gradient
 HL: Head Loss
 P: Add Pressure


- Node -
 HP: Head Pressure
 GL: Ground Level
 EHP: Effectual Head Pressure
 QC: Consumption of Water

----- NodeData -----

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	QC (l/s)	Remarks	Node ST	Node BN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
1	2549.547	2.547.547		2.000	-2.150	Reservoir Tank	1	2	75.0	82.469	110	2.150	0.487	6.119	0.505	0.000
2	2549.042	2.547.046		1.996	0.000		2	3	37.5	164.065	110	0.165	0.150	1.549	0.254	0.000
3	2548.788	2.536.065		12.723	0.165		2	4	75.0	326.205	110	1.985	0.450	5.277	1.721	0.000
4	2547.321	2.523.827		23.494	0.000		4	5	37.5	109.160	110	0.331	0.300	5.590	0.610	0.000
5	2546.711	2.526.481		20.230	0.165		4	7	50.0	107.358	110	1.654	0.843	27.123	2.912	0.000
6	2546.353	2.514.206		32.147	0.165		5	6	37.5	231.116	110	0.165	0.150	1.549	0.358	0.000
7	2544.409	2.513.260		31.149	0.165		7	8	50.0	175.117	110	1.489	0.759	22.314	3.908	0.000
8	2540.457	2.507.277		33.225	0.000		8	9	37.5	29.102	110	0.165	0.150	1.547	0.045	0.000
9	2540.457	2.507.277		33.180	0.165		8	10	50.0	56.618	110	1.323	0.674	17.940	1.016	0.000
10	2539.486	2.507.060		32.426	0.165		10	11	50.0	8.812	110	1.158	0.590	14.009	0.123	0.000
11	2539.363	2.507.083		32.280	0.000		11	12	37.5	353.802	110	0.165	0.150	1.549	-0.548	0.000
12	2538.815	2.505.031		33.784	0.165		11	13	50.0	45.623	110	0.992	0.506	10.531	0.480	0.000
13	2538.882	2.506.727		32.155	0.000		13	14	37.5	39.152	110	0.165	0.150	1.549	0.061	0.000
14	2538.821	2.508.331		30.490	0.165		13	15	37.5	78.806	110	0.827	0.749	30.503	2.404	0.000
15	2536.478	2.504.935		31.543	0.000		15	16	37.5	55.669	110	0.331	0.300	5.590	0.311	0.000
16	2536.167	2.505.625		30.542	0.000		15	19	37.5	141.599	110	0.496	0.450	11.845	1.677	0.000
17	2536.137	2.504.639		31.498	0.165		16	17	37.5	19.174	110	0.165	0.150	1.549	0.030	0.000
18	2535.835	2.495.973		39.862	0.165		16	18	37.5	214.400	110	0.165	0.150	1.549	0.332	0.000
19	2534.801	2.502.041		32.760	0.000		19	20	37.5	26.235	110	0.165	0.150	1.547	0.041	0.000
20	2534.760	2.502.041		32.719	0.165		19	21	37.5	23.255	110	0.331	0.300	5.590	0.130	0.000
21	2534.671	2.501.727		32.944	0.000		21	22	37.5	96.237	110	0.165	0.150	1.549	0.149	0.000
22	2534.522	2.498.880		35.642	0.165		21	23	37.5	267.699	110	0.165	0.150	1.549	0.415	0.000
23	2534.256	2.500.127		34.129	0.165		21	23	37.5	267.699	110	0.165	0.150	1.549	0.415	0.000

----- NodeData -----

Dibo Pipe Networks



-----Dibo <<Case.1 : Hazen-Williams Formula>>-----

<< Explanatory Notes >>

- Line -
 D: Diameter
 L: Length of Pipe
 Coef: Friction Coefficient
 Q: Quantity of Flow
 V: Velocity of Flow
 I: Hydraulic Gradient
 HL: Head Loss
 P: Add Pressure

- Node -
 HP: Head Pressure
 GL: Ground Level
 EHP: Effectual Head Pressure
 Qc: Consumption of Water

Tank 1 Maximum EHP 52.609 (m)
 Node 25 Minimum EHP 5.945 (m)
 Line 25 Maximum I 0.000 (%)
 Pump,Decom 0 Maximum V 0.000 (m/s)

Convergence Gap 0.00 (cm)
 Calculation 2 (times)

----- NodeData -----

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	Node ST	Node EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
1	2460.637	2.452.637		8.000	-0.000	Reservoir Tank	1	2	50.0	17.292	110	0.000	0.000	0.000	0.000	0.000
2	2460.637	2.452.637		8.000	0.000		1	4	37.5	59.380	110	0.000	0.000	0.000	0.000	0.000
3	2460.637	2.454.692		5.945	0.000		2	3	37.5	149.799	110	0.000	0.000	0.000	0.000	0.000
4	2460.637	2.452.637		8.000	0.000		2	5	50.0	247.922	110	0.000	0.000	0.000	0.000	0.000
5	2460.637	2.449.122		11.515	0.000		5	6	50.0	861.812	110	0.000	0.000	0.000	0.000	0.000
6	2460.637	2.427.184		33.453	0.000		6	7	50.0	104.195	110	0.000	0.000	0.000	0.000	0.000
7	2460.637	2.425.528		35.109	0.000		7	8	37.5	108.556	110	0.000	0.000	0.000	0.000	0.000
8	2460.637	2.426.495		34.142	0.000		7	9	50.0	70.404	110	0.000	0.000	0.000	0.000	0.000
9	2460.637	2.423.994		36.643	0.000		9	10	50.0	75.833	110	0.000	0.000	0.000	0.000	0.000
10	2460.637	2.422.498		38.139	0.000		10	11	50.0	80.550	110	0.000	0.000	0.000	0.000	0.000
11	2460.637	2.419.690		40.947	0.000		11	12	37.5	51.921	110	0.000	0.000	0.000	0.000	0.000
12	2460.637	2.419.665		40.972	0.000		11	14	37.5	101.410	110	0.000	0.000	0.000	0.000	0.000
13	2460.637	2.420.837		39.800	0.000		11	22	37.5	143.415	110	0.000	0.000	0.000	0.000	0.000
14	2460.637	2.416.953		43.684	0.000		12	13	37.5	235.909	110	0.000	0.000	0.000	0.000	0.000
15	2460.637	2.417.560		43.077	0.000		14	15	37.5	81.991	110	0.000	0.000	0.000	0.000	0.000
16	2460.637	2.418.852		41.785	0.000		14	17	37.5	120.299	110	0.000	0.000	0.000	0.000	0.000
17	2460.637	2.413.151		47.486	0.000		14	19	37.5	42.612	110	0.000	0.000	0.000	0.000	0.000
18	2460.637	2.410.035		50.602	0.000		15	16	37.5	141.846	110	0.000	0.000	0.000	0.000	0.000
19	2460.637	2.416.928		43.709	0.000		17	18	37.5	127.783	110	0.000	0.000	0.000	0.000	0.000
20	2460.637	2.411.380		49.257	0.000		19	20	37.5	140.266	110	0.000	0.000	0.000	0.000	0.000
21	2460.637	2.408.028		52.609	0.000		20	21	37.5	179.378	110	0.000	0.000	0.000	0.000	0.000
22	2460.637	2.415.263		45.374	0.000		22	23	37.5	171.836	110	0.000	0.000	0.000	0.000	0.000
23	2460.637	2.424.553		36.085	0.000		23	24	37.5	131.438	110	0.000	0.000	0.000	0.000	0.000
24	2460.637	2.410.020		50.617	0.000		23	25	37.5	255.236	110	0.000	0.000	0.000	0.000	0.000

----- NodeData -----

-----Dibo <<Case.2 : Hazen-Williams Formula>>-----

<< Explanatory Notes >>

Tank 1 Maximum EHP 32.658 (m)
 Node 25 Minimum EHP 5.463 (m)
 Line 25 Maximum I 19.695 (%)
 Pump.Decom 0 Maximum V 0.709 (m/s)

Convergence Gap 0.53 (cm)
 Calculation 14 (times)

- Line -
 D: Diameter
 L: Length of Pipe
 Coef: Friction Coefficient
 Q: Quantity of Flow
 V: Velocity of Flow
 I: Hydraulic Gradient
 HL: Head Loss
 P: Add Pressure









- Node -
 HP: Head Pressure
 GL: Ground Level
 EHP: Effectual Head Pressure
 Qc: Consumption of Water


----- NodeData -----

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	Node ST	Node EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
1	2460.637	2.452.637		8.000	-1.518	Reservoir Tank	1	2	50.0	17.292	110	1.392	0.709	19.695	0.341	0.000
2	2460.296	2.452.637		7.659	0.000		1	4	37.5	59.380	110	0.127	0.115	0.943	0.056	0.000
3	2460.155	2.454.692		5.463	0.127		2	3	37.5	149.799	110	0.127	0.115	0.943	0.141	0.000
4	2460.581	2.452.637		7.944	0.127		2	5	50.0	247.922	110	1.265	0.645	16.508	4.093	0.000
5	2456.204	2.449.122		7.082	0.127		5	6	50.0	861.812	110	1.139	0.580	13.582	11.705	0.000
6	2444.499	2.427.184		17.315	0.127		6	7	50.0	104.195	110	1.012	0.516	10.920	1.138	0.000
7	2443.361	2.425.528		17.833	0.000		7	8	37.5	108.556	110	0.127	0.115	0.943	0.102	0.000
8	2443.259	2.426.495		16.764	0.127		7	9	50.0	70.404	110	0.886	0.451	8.528	0.600	0.000
9	2442.761	2.423.994		18.767	0.127		9	10	50.0	75.833	110	0.759	0.387	6.410	0.486	0.000
10	2442.275	2.422.498		19.777	0.000		10	11	50.0	80.550	110	0.759	0.387	6.410	0.516	0.000
11	2441.758	2.419.690		22.068	0.000		11	12	37.5	51.921	110	0.000	0.000	0.000	0.000	0.000
12	2441.758	2.419.665		22.093	0.000		11	14	37.5	101.410	110	0.380	0.344	7.209	0.731	0.000
13	2441.758	2.420.837		20.921	0.000		11	22	37.5	143.415	110	0.380	0.344	7.209	1.034	0.000
14	2441.027	2.416.953		24.074	0.000		12	13	37.5	235.909	110	0.000	0.000	0.000	0.000	0.000
15	2440.950	2.417.560		23.390	0.000		14	15	37.5	81.991	110	0.127	0.115	0.943	0.077	0.000
16	2440.816	2.418.852		21.964	0.127		14	17	37.5	120.299	110	0.127	0.115	0.943	0.113	0.000
17	2440.914	2.413.151		27.763	0.000		14	19	37.5	42.612	110	0.127	0.115	0.943	0.040	0.000
18	2440.793	2.410.035		30.758	0.127		15	16	37.5	141.846	110	0.127	0.115	0.943	0.134	0.000
19	2440.987	2.416.928		24.059	0.000		17	18	37.5	127.783	110	0.127	0.115	0.943	0.120	0.000
20	2440.855	2.411.380		29.475	0.000		19	20	37.5	140.266	110	0.127	0.115	0.943	0.132	0.000
21	2440.686	2.408.028		32.658	0.127		20	21	37.5	179.378	110	0.127	0.115	0.943	0.169	0.000
22	2440.724	2.415.263		25.461	0.127		22	23	37.5	171.836	110	0.253	0.229	3.403	0.585	0.000
23	2440.140	2.424.553		15.587	0.000		23	24	37.5	131.438	110	0.127	0.115	0.943	0.124	0.000
24	2440.016	2.410.020		29.996	0.127		23	25	37.5	255.236	110	0.127	0.115	0.943	0.241	0.000

Amanuel Pipe Networks

Legend

	New: 100mm
	New: 75mm
	New: 50mm
	New: 40mm
	Exist: 100mm
	Exist: 75mm
	Exist: 50mm
	Exist: 40mm



-----Amanuel <<Case. 1 : Hazen-Williams Formula>>-----

<< Explanatory Notes >>

Tank 1 Maximum EHP 36.735 (m)
 Node 44 Minimum EHP 7.360 (m)
 Line 44 Maximum I 0.000 (%)
 Pump, Decom 0 Maximum V 0.000 (m/s)

Convergence Gap 0.00 (cm)
 Calculation 2 (times)

- Line -
 D: Diameter
 L: Length of Pipe
 Coef: Friction Coefficient
 Q: Quantity of Flow
 V: Velocity of Flow
 I: Hydraulic Gradient
 HL: Head Loss
 P: Add Pressure

- Node -
 HP: Head Pressure
 GL: Ground Level
 EHP: Effectual Head Pressure
 Qc: Consumption of Water

----- LineData -----

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	Node ST	Node EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
1	2395.780	2.387.780		8.000	0.000	Reservoir Tank	1	2	100.0	28.598	110	0.000	0.000	0.000	0.000	0.000
2	2395.780	2.388.420		7.360	0.000		2	3	37.5	43.799	110	0.000	0.000	0.000	0.000	0.000
3	2395.780	2.383.858		11.922	0.000		2	8	100.0	64.943	110	0.000	0.000	0.000	0.000	0.000
4	2395.780	2.383.308		12.472	0.000		3	4	37.5	207.736	110	0.000	0.000	0.000	0.000	0.000
5	2395.780	2.363.538		32.242	0.000		3	5	37.5	167.220	110	0.000	0.000	0.000	0.000	0.000
6	2395.780	2.361.485		34.295	0.000		5	6	37.5	282.031	110	0.000	0.000	0.000	0.000	0.000
7	2395.780	2.359.045		36.735	0.000		5	7	37.5	158.173	110	0.000	0.000	0.000	0.000	0.000
8	2395.780	2.386.000		9.780	0.000		8	9	75.0	14.197	110	0.000	0.000	0.000	0.000	0.000
9	2395.780	2.385.123		10.657	0.000		8	18	75.0	223.946	110	0.000	0.000	0.000	0.000	0.000
10	2395.780	2.375.800		19.980	0.000		9	10	37.5	156.993	110	0.000	0.000	0.000	0.000	0.000
11	2395.780	2.374.125		21.655	0.000		9	13	37.5	136.127	110	0.000	0.000	0.000	0.000	0.000
12	2395.780	2.365.257		30.523	0.000		9	33	75.0	225.047	110	0.000	0.000	0.000	0.000	0.000
13	2395.780	2.385.955		9.825	0.000		10	11	37.5	71.098	110	0.000	0.000	0.000	0.000	0.000
14	2395.780	2.381.832		13.949	0.000		10	12	37.5	219.644	110	0.000	0.000	0.000	0.000	0.000
15	2395.780	2.378.646		17.134	0.000		13	14	37.5	49.610	110	0.000	0.000	0.000	0.000	0.000
16	2395.780	2.371.777		24.003	0.000		13	15	37.5	378.050	110	0.000	0.000	0.000	0.000	0.000
17	2395.780	2.368.373		27.407	0.000		15	16	37.5	148.405	110	0.000	0.000	0.000	0.000	0.000
18	2395.780	2.381.915		13.865	0.000		15	17	37.5	568.506	110	0.000	0.000	0.000	0.000	0.000
19	2395.780	2.379.442		16.338	0.000		18	19	37.5	50.906	110	0.000	0.000	0.000	0.000	0.000
20	2395.780	2.379.859		15.921	0.000		18	22	75.0	238.624	110	0.000	0.000	0.000	0.000	0.000
21	2395.780	2.376.847		18.933	0.000		19	20	37.5	19.150	110	0.000	0.000	0.000	0.000	0.000
22	2395.780	2.382.000		13.780	0.000		19	21	37.5	43.526	110	0.000	0.000	0.000	0.000	0.000
23	2395.780	2.377.818		17.962	0.000		22	23	37.5	302.739	110	0.000	0.000	0.000	0.000	0.000
24	2395.780	2.382.532		13.248	0.000		22	24	75.0	139.919	110	0.000	0.000	0.000	0.000	0.000

--- NodeData ---

--- LineData ---

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	Node ST EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
25	2395.780	2,382.519		13.261	0.000		24 25	37.5	105.811	110	0.000	0.000	0.000	0.000	0.000
26	2395.780	2,379.000		16.780	0.000		24 26	50.0	246.807	110	0.000	0.000	0.000	0.000	0.000
27	2395.780	2,381.417		14.363	0.000		26 27	37.5	240.833	110	0.000	0.000	0.000	0.000	0.000
28	2395.780	2,378.714		17.066	0.000		26 28	50.0	288.251	110	0.000	0.000	0.000	0.000	0.000
29	2395.780	2,381.880		13.900	0.000		28 29	37.5	71.523	110	0.000	0.000	0.000	0.000	0.000
30	2395.780	2,382.016		13.764	0.000		28 31	37.5	216.192	110	0.000	0.000	0.000	0.000	0.000
31	2395.780	2,380.916		14.864	0.000		29 30	37.5	203.061	110	0.000	0.000	0.000	0.000	0.000
32	2395.780	2,380.916		14.864	0.000		31 32	37.5	164.821	110	0.000	0.000	0.000	0.000	0.000
33	2395.780	2,382.057		13.723	0.000		33 34	37.5	75.399	110	0.000	0.000	0.000	0.000	0.000
34	2395.780	2,383.000		12.780	0.000		33 39	75.0	192.406	110	0.000	0.000	0.000	0.000	0.000
35	2395.780	2,383.000		12.780	0.000		34 35	37.5	79.446	110	0.000	0.000	0.000	0.000	0.000
36	2395.780	2,381.798		13.982	0.000		34 36	37.5	137.879	110	0.000	0.000	0.000	0.000	0.000
37	2395.780	2,381.705		14.075	0.000		36 37	37.5	10.247	110	0.000	0.000	0.000	0.000	0.000
38	2395.780	2,365.052		30.728	0.000		36 38	37.5	199.456	110	0.000	0.000	0.000	0.000	0.000
39	2395.780	2,382.106		13.675	0.000		39 40	37.5	76.087	110	0.000	0.000	0.000	0.000	0.000
40	2395.780	2,383.000		12.780	0.000		39 41	50.0	45.179	110	0.000	0.000	0.000	0.000	0.000
41	2395.780	2,382.500		13.280	0.000		41 42	37.5	291.533	110	0.000	0.000	0.000	0.000	0.000
42	2395.780	2,366.080		29.700	0.000		41 43	50.0	499.885	110	0.000	0.000	0.000	0.000	0.000
43	2395.780	2,382.500		13.280	0.000		43 44	37.5	164.865	110	0.000	0.000	0.000	0.000	0.000
44	2395.780	2,365.239		30.541	0.000		43 45	37.5	772.496	110	0.000	0.000	0.000	0.000	0.000
45	2395.780	2,375.118		20.662	0.000		43 45	37.5	772.496	110	0.000	0.000	0.000	0.000	0.000

-----Amanuel <<Case. 2 : Hazen-Williams Formula>>-----

<< Explanatory Notes >>

Tank 1 Maximum EHP 32.118 (m)
 Node 44 Minimum EHP 3.166 (m)
 Line 44 Maximum I 29.844 (%)
 Pump.Decom 0 Maximum V 0.833 (m/s)

Convergence Gap 0.89 (cm)
 Calculation 14 (times)

- Line -
 D: Diameter
 L: Length of Pipe
 Coef: Friction Coefficient
 Q: Quantity of Flow
 V: Velocity of Flow
 I: Hydraulic Gradient
 HL: Head Loss
 P: Add Pressure

- Node -
 HP: Head Pressure
 GL: Ground Level
 EHP: Effectual Head Pressure
 Qc: Consumption of Water

----- LineData -----

----- NodeData -----


Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	Node ST	Node EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
1	2395.780	2.387.780		8.000	-6.538	Reservoir Tank	1	2	100.0	28.598	110	6.538	0.833	11.820	0.338	0.000
2	2395.442	2.388.420		7.022	0.000		2	3	37.5	43.799	110	0.817	0.740	29.844	1.307	0.000
3	2394.135	2.383.858		10.277	0.000		2	8	100.0	64.943	110	5.721	0.729	9.231	0.599	0.000
4	2393.324	2.383.308		10.016	0.272		3	4	37.5	207.736	110	0.272	0.247	3.902	0.811	0.000
5	2391.779	2.363.538		28.241	0.000		3	5	37.5	167.220	110	0.545	0.494	14.085	2.355	0.000
6	2390.679	2.361.485		29.194	0.272		5	6	37.5	282.031	110	0.272	0.247	3.902	1.100	0.000
7	2391.162	2.359.045		32.118	0.272		5	7	37.5	158.173	110	0.272	0.247	3.902	0.617	0.000
8	2394.842	2.386.000		8.842	0.000		8	9	75.0	14.197	110	3.542	0.802	15.418	0.219	0.000
9	2394.624	2.385.123		9.501	0.000		8	18	75.0	223.946	110	2.179	0.494	6.274	1.405	0.000
10	2392.412	2.375.800		16.612	0.000		9	10	37.5	156.993	110	0.545	0.494	14.085	2.211	0.000
11	2392.135	2.374.125		18.010	0.272		9	13	37.5	136.127	110	0.817	0.740	29.842	4.062	0.000
12	2391.555	2.365.257		26.298	0.272		9	33	75.0	225.047	110	2.179	0.494	6.274	1.412	0.000
13	2390.561	2.385.955		4.606	0.000		10	11	37.5	71.098	110	0.272	0.247	3.902	0.277	0.000
14	2390.368	2.381.832		8.536	0.272		10	12	37.5	219.644	110	0.272	0.247	3.902	0.857	0.000
15	2385.236	2.378.646		6.591	0.000		13	14	37.5	49.610	110	0.272	0.247	3.902	0.194	0.000
16	2384.657	2.371.777		12.880	0.272		13	15	37.5	378.050	110	0.545	0.494	14.085	5.325	0.000
17	2383.018	2.368.373		14.645	0.272		15	16	37.5	148.405	110	0.272	0.247	3.902	0.579	0.000
18	2393.437	2.381.915		11.522	0.000		15	17	37.5	568.506	110	0.545	0.494	14.085	2.218	0.000
19	2392.720	2.379.442		13.279	0.000		18	19	37.5	50.906	110	0.272	0.247	3.902	0.717	0.000
20	2392.646	2.379.859		12.787	0.272		18	22	75.0	238.624	110	1.635	0.370	3.683	0.879	0.000
21	2392.551	2.376.847		15.704	0.272		19	20	37.5	19.150	110	0.272	0.247	3.902	0.075	0.000
22	2392.559	2.382.000		10.559	0.000		19	21	37.5	43.526	110	0.272	0.247	3.902	0.170	0.000
23	2391.377	2.377.818		13.560	0.272		22	23	37.5	302.739	110	0.272	0.247	3.902	1.181	0.000
24	2392.191	2.382.532		9.659	0.000		22	24	75.0	139.919	110	1.362	0.308	2.628	0.368	0.000

---- NodeData ----

---- LineData ----

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	Node ST EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
25	2391.778	2,382.519		9.260	0.272		24	25	105.811	110	0.272	0.247	3.902	0.413	0.000
26	2389.100	2,379.000		10.100	0.000		24	26	246.807	110	1.090	0.555	12.523	3.091	0.000
27	2388.160	2,381.417		6.744	0.272		26	27	240.833	110	0.272	0.247	3.902	0.940	0.000
28	2386.981	2,378.714		8.267	0.000		26	28	288.251	110	0.817	0.416	7.351	2.119	0.000
29	2385.974	2,381.880		4.094	0.272		28	29	71.523	110	0.545	0.494	14.085	1.007	0.000
30	2385.182	2,382.016		3.166	0.272		28	31	216.192	110	0.272	0.247	3.902	0.844	0.000
31	2386.138	2,380.916		5.222	0.000		29	30	203.061	110	0.272	0.247	3.902	0.792	0.000
32	2385.495	2,380.916		4.579	0.272		31	32	164.821	110	0.272	0.247	3.900	0.643	0.000
33	2393.212	2,382.057		11.155	0.000		33	34	75.399	110	0.817	0.740	29.843	2.250	0.000
34	2390.962	2,383.000		7.962	0.000		33	39	192.406	110	1.362	0.308	2.627	0.506	0.000
35	2390.652	2,383.000		7.652	0.272		34	35	79.446	110	0.272	0.247	3.900	0.310	0.000
36	2389.020	2,381.798		7.221	0.000		34	36	137.879	110	0.545	0.494	14.085	1.942	0.000
37	2388.980	2,381.705		7.274	0.272		36	37	10.247	110	0.272	0.247	3.902	0.040	0.000
38	2388.241	2,365.052		23.189	0.272		36	38	199.456	110	0.272	0.247	3.902	0.778	0.000
39	2392.706	2,382.106		10.601	0.000		39	40	76.087	110	0.272	0.247	3.902	0.297	0.000
40	2392.409	2,383.000		9.409	0.272		39	41	45.179	110	1.090	0.555	12.523	0.566	0.000
41	2392.140	2,382.500		9.640	0.000		41	42	291.533	110	0.272	0.247	3.902	1.138	0.000
42	2391.003	2,366.080		24.923	0.272		41	43	499.885	110	0.817	0.416	7.348	3.673	0.000
43	2388.467	2,382.500		5.967	0.272		43	44	164.865	110	0.272	0.247	3.902	0.643	0.000
44	2387.824	2,365.239		22.585	0.272		43	45	772.496	110	0.272	0.247	3.902	3.014	0.000
45	2385.453	2,375.118		10.335	0.272		43	45							

Gobeze Maryam Pipe Networks



Legend

New : 100mm	Blue
New : 75mm	Red
New : 50mm	Orange
New : 40mm	Green
Exist : 100mm	Purple
Exist : 75mm	Brown
Exist : 50mm	Yellow
Exist : 40mm	Light Green

-----Gobeze Maryam <<Case.1 : Hazen-Williams Formula>>-----

<< Explanatory Notes >>

- Line -

- Node -

D: Diameter
 L: Length of Pipe
 Coef: Friction Coefficient
 Q: Quantity of Flow
 V: Velocity of Flow
 I: Hydraulic Gradient
 HL: Head Loss
 P: Add Pressure

HP: Head Pressure
 GL: Ground Level
 EHP: Effectual Head Pressure
 Qc: Consumption of Water

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	Node ST	Node EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
1	2243.367	2,243.367	0.000	0.000	0.000	Reservoir Tank	1	2	75.0	485.203	110	0.000	0.000	0.000	0.000	0.000
2	2243.367	2,205.414	37.953	37.953	0.000		2	3	37.5	128.621	110	0.000	0.000	0.000	0.000	0.000
3	2243.367	2,203.382	39.985	39.985	0.000		2	6	75.0	84.885	110	0.000	0.000	0.000	0.000	0.000
4	2243.367	2,195.882	47.485	47.485	0.000		3	4	37.5	43.447	110	0.000	0.000	0.000	0.000	0.000
5	2243.367	2,193.937	49.430	49.430	0.000		3	5	37.5	109.350	110	0.000	0.000	0.000	0.000	0.000
6	2243.367	2,201.626	41.741	41.741	0.000		6	7	38.0	178.748	110	0.000	0.000	0.000	0.000	0.000
7	2243.367	2,197.127	46.240	46.240	0.000		6	11	75.0	33.324	110	0.000	0.000	0.000	0.000	0.000
8	2243.367	2,200.871	42.496	42.496	0.000		7	8	37.5	94.200	110	0.000	0.000	0.000	0.000	0.000
9	2243.367	2,190.450	52.917	52.917	0.000		8	9	37.5	229.402	110	0.000	0.000	0.000	0.000	0.000
10	2243.367	2,185.540	57.827	57.827	0.000		9	10	37.5	139.146	110	0.000	0.000	0.000	0.000	0.000
11	2243.367	2,198.264	45.103	45.103	0.000		11	12	37.5	337.327	110	0.000	0.000	0.000	0.000	0.000
12	2243.367	2,191.000	52.367	52.367	0.000		11	13	75.0	16.411	110	0.000	0.000	0.000	0.000	0.000
13	2196.874	2,196.874	-0.000	-0.000	0.000		13	14	75.0	260.129	110	0.000	0.000	0.000	0.000	0.000
14	2196.874	2,178.282	18.592	18.592	0.000		14	15	37.5	247.263	110	0.000	0.000	0.000	0.000	0.000
15	2196.874	2,170.411	26.463	26.463	0.000		14	22	75.0	26.377	110	0.000	0.000	0.000	0.000	0.000
16	2196.874	2,178.906	17.968	17.968	0.000		15	16	37.5	79.796	110	0.000	0.000	0.000	0.000	0.000
17	2196.874	2,170.043	26.831	26.831	0.000		15	17	37.5	11.960	110	0.000	0.000	0.000	0.000	0.000
18	2196.874	2,172.335	24.539	24.539	0.000		17	18	37.5	233.157	110	0.000	0.000	0.000	0.000	0.000
19	2243.367	2,184.670	58.697	58.697	0.000		5	20	37.5	360.300	110	0.000	0.000	0.000	0.000	0.000
20	2243.367	2,185.870	57.497	57.497	0.000		19	20	37.5	44.563	110	0.000	0.000	0.000	0.000	0.000
21	2243.367	2,192.550	50.817	50.817	0.000		19	21	37.5	140.791	110	0.000	0.000	0.000	0.000	0.000
22	2196.874	2,176.768	20.106	20.106	0.000		22	23	50.0	240.840	110	0.000	0.000	0.000	0.000	0.000
23	2196.874	2,178.517	18.357	18.357	0.000		22	33	50.0	88.436	110	0.000	0.000	0.000	0.000	0.000
24	2196.874	2,179.953	16.921	16.921	0.000		23	24	37.5	62.282	110	0.000	0.000	0.000	0.000	0.000

----- NodeData ----- LineData -----

Convergence Gap 0.00 (cm)
 Calculation 2 (times)

-----Gobeze Maryam <<Case.2 : Hazen-Williams Formula>>-----

<< Explanatory Notes >>

- Line -

- Node -

- Tank 1 Maximum EHP 44.776 (m)

- Node 53 Minimum EHP 0.000 (m)

- Line 53 Maximum I 27.911 (%)

- Pump, Decom 1 Maximum V 0.857 (m/s)

HP: Head Pressure
 GL: Ground Level
 EHP: Effectual Head Pressure
 Qc: Consumption of Water

D: Diameter
 L: Length of Pipe
 Coef: Friction Coefficient
 Q: Quantity of Flow
 V: Velocity of Flow
 I: Hydraulic Gradient
 HL: Head Loss
 P: Add Pressure

Convergence Gap 0.55 (cm)
 Calculation 16 (times)

----- NodeData -----


Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	ST	EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
1	2243.367	2,243.367		0.000	-3.784	Reservoir Tank	1	2	75.0	485.203	110	3.784	0.857	17.426	8.455	0.000
2	2234.912	2,205.414		29.498	0.000		2	3	37.5	128.621	110	0.631	0.571	18.463	2.375	0.000
3	2232.537	2,203.382		29.155	0.000		2	6	75.0	84.885	110	3.153	0.714	12.433	1.055	0.000
4	2232.475	2,195.882		36.593	0.158		3	4	37.5	43.447	110	0.158	0.143	1.417	0.062	0.000
5	2231.352	2,193.937		37.415	0.158		3	5	37.5	109.350	110	0.473	0.428	10.838	1.185	0.000
6	2233.856	2,201.626		32.230	0.000		6	7	38.0	178.748	110	0.473	0.417	10.161	1.816	0.000
7	2232.040	2,197.127		34.913	0.000		6	11	75.0	33.324	110	2.680	0.607	9.202	0.307	0.000
8	2231.019	2,200.871		30.148	0.158		7	8	37.5	94.200	110	0.473	0.428	10.838	1.021	0.000
9	2229.846	2,190.450		39.396	0.158		8	9	37.5	229.402	110	0.315	0.286	5.115	1.173	0.000
10	2229.648	2,185.540		44.108	0.158		9	10	37.5	139.146	110	0.158	0.143	1.417	0.197	0.000
11	2233.550	2,198.264		35.286	0.158		11	12	37.5	337.327	110	0.158	0.143	1.417	0.478	0.000
12	2233.072	2,191.000		42.072	0.158		11	13	75.0	16.411	110	2.365	0.536	7.298	0.120	-36.556
13	2196.874	2,196.874	36.556	0.000	0.000		13	14	75.0	260.129	110	2.365	0.536	7.298	1.898	0.000
14	2194.976	2,178.282		16.694	0.000		14	15	37.5	247.263	110	0.315	0.286	5.115	1.265	0.000
15	2193.711	2,170.411		23.300	0.000		14	22	75.0	26.377	110	2.050	0.464	5.599	0.148	0.000
16	2193.598	2,178.906		14.692	0.158		15	16	37.5	79.796	110	0.158	0.143	1.417	0.113	0.000
17	2193.694	2,170.043		23.651	0.000		15	17	37.5	11.960	110	0.158	0.143	1.417	0.017	0.000
18	2193.364	2,172.335		21.029	0.158		17	18	37.5	233.157	110	0.158	0.143	1.417	0.330	0.000
19	2229.446	2,184.670		44.776	0.000		5	20	37.5	360.300	110	0.315	0.286	5.115	1.843	0.000
20	2229.509	2,185.870		43.639	0.158		19	20	37.5	44.563	110	-0.158	-0.143	-1.417	-0.063	0.000
21	2229.246	2,192.550		36.696	0.158		19	21	37.5	140.791	110	0.158	0.143	1.417	0.200	0.000
22	2194.828	2,176.768		18.060	0.000		22	23	50.0	240.840	110	0.946	0.482	9.636	2.321	0.000
23	2192.507	2,178.517		13.990	0.158		22	33	50.0	88.436	110	1.104	0.562	12.820	1.134	0.000
24	2190.769	2,179.953		10.816	0.000		23	24	37.5	62.282	110	0.788	0.714	27.911	1.738	0.000

--- NodeData ---

--- LineData ---

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	ST	Node EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
25	2189.917	2,173.053		16.864	0.000		24	25	37.5	78.635	110	0.473	0.428	10.838	0.852	0.000
26	2189.917	2,162.313		27.604	0.000		24	30	37.5	345.446	110	0.315	0.286	5.115	1.767	0.000
27	2188.092	2,163.321		24.771	0.158		25	26	37.5	95.922	110	0.000	0.000	0.000	0.000	0.000
28	2187.635	2,165.310		22.325	0.158		25	27	37.5	168.380	110	0.473	0.428	10.838	1.825	0.000
29	2187.329	2,158.000		29.329	0.158		27	28	37.5	89.267	110	0.315	0.286	5.115	0.457	0.000
30	2189.002	2,179.502		9.500	0.000		28	29	37.5	216.025	110	0.158	0.143	1.417	0.306	0.000
31	2188.957	2,177.642		11.315	0.158		30	31	37.5	32.041	110	0.158	0.143	1.417	0.045	0.000
32	2188.766	2,182.000		6.766	0.158		30	32	37.5	166.798	110	0.158	0.143	1.417	0.236	0.000
33	2193.694	2,173.196		20.498	0.000		33	34	37.5	171.888	110	0.000	0.000	0.000	0.000	0.000
34	2193.694	2,166.947		26.747	0.000		33	35	50.0	60.878	110	1.104	0.562	12.820	0.780	0.000
35	2192.914	2,169.885		23.029	0.158		35	36	37.5	174.858	110	0.158	0.143	1.417	0.248	0.000
36	2192.666	2,166.942		25.724	0.158		35	37	37.5	188.330	110	0.788	0.714	27.911	5.257	0.000
37	2187.657	2,160.921		26.736	0.000		37	38	37.5	88.012	110	0.158	0.143	1.417	0.125	0.000
38	2187.533	2,160.284		27.249	0.158		37	39	37.5	116.222	110	0.631	0.571	18.464	2.146	0.000
39	2185.512	2,155.720		29.792	0.158		39	40	37.5	234.981	110	0.158	0.143	1.417	0.333	0.000
40	2185.179	2,147.523		37.656	0.158		39	41	37.5	104.456	110	0.000	0.000	0.000	0.000	0.000
41	2185.512	2,152.124		33.388	0.000		39	46	37.5	7.486	110	0.315	0.286	5.115	0.038	0.000
42	2185.512	2,142.124		43.388	0.000		41	42	37.5	162.353	110	0.000	0.000	0.000	0.000	0.000
43	2185.512	2,150.124		35.388	0.000		41	43	37.5	25.812	110	0.000	0.000	0.000	0.000	0.000
44	2185.512	2,148.124		37.388	0.000		43	44	37.5	24.796	110	0.000	0.000	0.000	0.000	0.000
45	2185.512	2,148.124		37.388	0.000		43	45	37.5	75.651	110	0.000	0.000	0.000	0.000	0.000
46	2185.473	2,155.720		29.753	0.000		46	47	37.5	194.022	110	0.158	0.143	1.417	0.275	0.000
47	2185.198	2,147.690		37.508	0.158		46	48	37.5	115.720	110	0.158	0.143	1.417	0.164	0.000
48	2185.309	2,150.480		34.829	0.000		48	49	37.5	157.380	110	0.000	0.000	0.000	0.000	0.000
49	2185.309	2,144.480		40.829	0.000		48	50	37.5	133.185	110	0.158	0.143	1.417	0.189	0.000
50	2185.121	2,146.289		38.832	0.000		48	51	37.5	325.258	110	0.000	0.000	0.000	0.000	0.000
51	2185.121	2,143.564		41.557	0.000		50	52	37.5	23.343	110	0.158	0.143	1.417	0.033	0.000
52	2185.088	2,145.649		39.439	0.000		52	53	37.5	96.490	110	0.000	0.000	0.000	0.000	0.000
53	2185.088	2,140.760		44.328	0.000		52	54	37.5	116.267	110	0.158	0.143	1.417	0.000	0.000
54	2184.923	2,142.502		42.421	0.158		52								0.165	0.000

Bikolo Pipe Networks



-----Bikolo <<Case.1 : Hazen-Williams Formula>>-----

<< Explanatory Notes >>

Tank 1 Maximum EHP 51.220 (m)
 Node 17 Minimum EHP 16.200 (m)
 Line 17 Maximum I 0.000 (%)
 Pump, Decom 0 Maximum V 0.000 (m/s)

- Line -
 D: Diameter
 L: Length of Pipe
 Coef: Friction Coefficient
 Q: Quantity of Flow
 V: Velocity of Flow
 I: Hydraulic Gradient
 HL: Head Loss
 P: Add Pressure

- Node -
 HP: Head Pressure
 GL: Ground Level
 EHP: Effectual Head Pressure
 Qc: Consumption of Water

Convergence Gap 0.00 (cm)

Calculation 2 (times)

----- NodeData -----

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	Node ST	Node EN	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
1	1953.020	1,953.020		0.000	-0.000	Reservoir Tank	1	2	100.0	823.886	110	0.000	0.000	0.000	0.000	0.000
2	1953.020	1,936.820		16.200	0.000		2	3	37.5	257.828	110	0.000	0.000	0.000	0.000	0.000
3	1953.020	1,932.430		20.590	0.000		2	4	75.0	296.953	110	0.000	0.000	0.000	0.000	0.000
4	1953.020	1,929.430		23.590	0.000		4	5	37.5	44.415	110	0.000	0.000	0.000	0.000	0.000
5	1953.020	1,929.940		23.080	0.000		4	9	37.5	186.736	110	0.000	0.000	0.000	0.000	0.000
6	1953.020	1,932.130		20.890	0.000		5	6	37.5	186.654	110	0.000	0.000	0.000	0.000	0.000
7	1953.020	1,932.910		20.110	0.000		6	7	37.5	96.106	110	0.000	0.000	0.000	0.000	0.000
8	1953.020	1,932.120		20.900	0.000		6	8	37.5	117.885	110	0.000	0.000	0.000	0.000	0.000
9	1953.020	1,927.710		25.310	0.000		4	10	75.0	346.203	110	0.000	0.000	0.000	0.000	0.000
10	1953.020	1,922.350		30.670	0.000		10	11	75.0	226.819	110	0.000	0.000	0.000	0.000	0.000
11	1953.020	1,917.240		35.780	0.000		11	12	37.5	104.219	110	0.000	0.000	0.000	0.000	0.000
12	1953.020	1,915.370		37.650	0.000		11	15	37.5	189.681	110	0.000	0.000	0.000	0.000	0.000
13	1953.020	1,917.290		35.730	0.000		12	13	37.5	62.816	110	0.000	0.000	0.000	0.000	0.000
14	1953.020	1,901.800		51.220	0.000		12	14	37.5	547.964	110	0.000	0.000	0.000	0.000	0.000
15	1953.020	1,913.790		39.230	0.000		11	16	37.5	14.956	110	0.000	0.000	0.000	0.000	0.000
16	1953.020	1,916.120		36.900	0.000		16	17	37.5	195.039	110	0.000	0.000	0.000	0.000	0.000
17	1953.020	1,912.560		40.460	0.000		16	18	37.5	202.555	110	0.000	0.000	0.000	0.000	0.000
18	1953.020	1,915.450		37.570	0.000		16	18	37.5							

-----Bikolo <<Case.2 : Hazen-Williams Formula>>-----

<< Explanatory Notes >>

- Line -
 D: Diameter
 L: Length of Pipe
 Coef: Friction Coefficient
 Q: Quantity of Flow
 V: Velocity of Flow
 I: Hydraulic Gradient
 HL: Head Loss
 P: Add Pressure

- Node -
 HP: Head Pressure
 GL: Ground Level
 EHP: Effectual Head Pressure
 Qc: Consumption of Water

Tank	1	Maximum EHP	40.444 (m)
Node	17	Minimum EHP	10.502 (m)
Line	17	Maximum I	30.364 (%)
Pump, Decom	0	Maximum V	0.747 (m/s)

Convergence Gap 0.72 (cm)

Calculation 13 (times)


----- NodeData ----- LineData -----

Node	HP (m)	GL (m)	EHP 1st (m)	EHP 2nd (m)	Qc (l/s)	Remarks	ST	EN	Node	D (mm)	L (m)	Coef C	Q (l/s)	V (m/s)	I (%)	HL (m)	P (m)
1	1953.020	1,953.020		0.000	-3.025	Reservoir Tank	1	2	2	100.0	823.886	110	3.025	0.385	2.836	2.337	0.000
2	1950.683	1,936.820		13.863	0.000		2	3	3	37.5	257.828	110	0.275	0.249	3.971	1.024	0.000
3	1949.660	1,932.430		17.230	0.275		2	4	4	75.0	296.953	110	2.750	0.623	9.651	2.866	0.000
4	1947.817	1,929.430		18.387	0.000		4	5	5	37.5	44.415	110	0.825	0.747	30.364	1.349	0.000
5	1946.469	1,929.940		16.529	0.275		4	9	9	37.5	186.736	110	0.275	0.249	3.970	0.741	0.000
6	1943.794	1,932.130		11.664	0.000		5	6	6	37.5	186.654	110	0.550	0.498	14.331	2.675	0.000
7	1943.412	1,932.910		10.502	0.275		6	7	7	37.5	96.106	110	0.275	0.249	3.970	0.382	0.000
8	1943.326	1,932.120		11.206	0.275		6	8	8	37.5	117.885	110	0.275	0.249	3.970	0.468	0.000
9	1947.076	1,927.710		19.366	0.275		4	10	10	75.0	346.203	110	1.650	0.374	3.748	1.297	0.000
10	1946.520	1,922.350		24.170	0.275		10	11	11	75.0	226.819	110	1.375	0.311	2.674	0.606	0.000
11	1945.914	1,917.240		28.674	0.275		11	12	12	37.5	104.219	110	0.550	0.498	14.332	1.494	0.000
12	1944.420	1,915.370		29.050	0.000		11	15	15	37.5	189.681	110	0.000	0.000	0.000	0.000	0.000
13	1944.171	1,917.290		26.881	0.275		12	13	13	37.5	62.816	110	0.275	0.249	3.971	0.249	0.000
14	1942.244	1,901.800		40.444	0.275		12	14	14	37.5	547.964	110	0.275	0.249	3.971	2.176	0.000
15	1945.914	1,913.790		32.124	0.000		11	16	16	37.5	14.956	110	0.550	0.498	14.332	0.214	0.000
16	1945.699	1,916.120		29.579	0.000		16	17	17	37.5	195.039	110	0.275	0.249	3.971	0.774	0.000
17	1944.925	1,912.560		32.365	0.275		16	18	18	37.5	202.555	110	0.275	0.249	3.970	0.804	0.000
18	1944.895	1,915.450		29.445	0.275		16	18	18	37.5	202.555	110	0.275	0.249	3.970	0.804	0.000


Appendix 7 References

7-2 Result of Test Well Drilling (Well Column Diagram)


Test well drilling and existing water source survey for the second preparatory survey of the project for small towns water supply in southern part of the Amhara regional state




Test well drilling and existing water source survey for the second preparatory survey of the project for small towns water supply in southern part of the Amhara regional state




Test well drilling and existing water source survey for the second preparatory survey of the project for small towns water supply in southern part of the Amhara regional state




Test well drilling and existing water source survey for the second preparatory survey of the project for small towns water supply in southern part of the Amhara regional state




Test well drilling and existing water source survey for the second preparatory survey of the project for small towns water supply in southern part of the Amhara regional state




Test well drilling and existing water source survey for the second preparatory survey of the project for small towns water supply in southern part of the Amhara regional state




Test well drilling and existing water source survey for the second preparatory survey of the project for small towns water supply in southern part of the Amhara regional state



Test well drilling and existing water source survey for the second preparatory survey of the project for small towns water supply in southern part of the Amhara regional state



Test well drilling and existing water source survey for the second preparatory survey of the project for small towns water supply in southern part of the Amhara regional state



Test well drilling and existing water source survey for the second preparatory survey of the project for small towns water supply in southern part of the Amhara regional state

