

第8章 添付資料

- 添付資料 1 : Project Design Matrix
- 添付資料 2 : 専門家派遣の実績 (1/2)
- 添付資料 3 : 専門家派遣の実績 (2/2)
- 添付資料 4 : 本邦カウンターパートトレーニング研修員受け入れ実績
- 添付資料 5 : 機材供与実績
- 添付資料 6 : Minutes of Meetings (1st mission to 9th mission)
- 添付資料 7 : Workshop 資料

Appendix 1

Project Design Matrix

事業名：フィリピン国 電力協同組合のためのシステムロスの低減プロジェクト
 執行機関：国家電化庁
 受益者層：NEA や特定 EC のフィリピン人の技術者、エンジニア
 対象地域：フィリピン
 事業期間：2011.3－2013.3 (2年)

| プロジェクト要旨 | 客観的指標 | 指標データ入手手段 | 外部条件 |
|---|---|---|--|
| <p>上位目標： ECの配電システムロスを低減し、電力供給能力を効率的かつ経済的に向上させる</p> <p>プロジェクト目標： ECやNEAによる配電システムロスを低減するためのエンジニアリング及び計画立案能力を向上させる</p> | <ul style="list-style-type: none"> • (2008年度)13.87%の合計システムロスを2015年までに一桁台まで低減する • 特定のECは独自でノンテクニカルロスとテクニカルロスの分別を効率的に行なうことができる • 配電システム計画がEC独自の能力で作られる • 電力システムを分析し、その問題点をECが解決する | <ul style="list-style-type: none"> • 調査すべき NEA、EC の公的 年報 • DOE や NEA による統計的報告書 • 年間運営報告書 • 調査すべき NEA、EC の公的 年報 | <ul style="list-style-type: none"> • (電力セクター政策など)フィリピンの発展計画に大きな変化はない • 施設設備の向上に必要な資金が分配される • 地域工学、マクロエンジニアリング援助、資産管理などの NEA のシステムロス低減プログラムが上手く実施されている |
| <p>成果：</p> <ol style="list-style-type: none"> 1. システムロス低減のための事業運営マニュアルを用意し、適切に実施する 2. システムロスの量的評価に対するサポートシステムを確立する 3. 中圧配電線の昇圧 (23kV化) を行うための支援を実施し、技術基準を確立する | <ol style="list-style-type: none"> 1.1 システムロス低減マニュアルを用意する。 1.2 NEA および各 EC がワークショップへ参加する 1.3 ワークショップで各 EC が課題解決活動を報告する 2.1 システムロス定量評価手法マニュアルを用意する 2.2 NEA および各 EC がシステムロス定量評価訓練に参加する 3.1 設備基準・技術基準ガイドラインを用意する | <ol style="list-style-type: none"> 1.1.1 プロジェクトで吟味作成されたシステムロス低減マニュアル 1.2.1 報告されたベストプラクティス事例集 1.2.2 ワークショップの記録 2.1 プロジェクトで吟味作成されたシステムロス定量評価手法マニュアル 1.2.2 システムロス定量評価訓練の記録 3.1 プロジェクトで吟味作成された設備基準・技術基準ガイドライン | <ul style="list-style-type: none"> • フィリピンの電力セクター政策に大きな変化はない • NEA や EC の経営に必要な予算が継続的に配分される |

| 活動： | 投入(方法とコスト) | 事前状況 |
|--|---|--|
| <p>1. システムロス低減のための事業運営マニュアルを用意し、適切に実施する</p> <p>1-1. 主要 EC のシステムロス低減に対する現在のベーストプラクティスを調査</p> <p>1-2. 日本の経験に基づいた、システムロス低減のためのマニュアルやチェックリストを準備</p> <p>1-2-1. 電力施設の O&M の基準を準備</p> <p>1-2-2. 将来の投資計画の作成方法を準備 (需要予測、電力フロー分析など)</p> <p>1-2-3. 財務と経済面での評価方法を準備</p> <p>1-3. 特定の EC にマニュアルを適用するためのケーススタディの実施</p> <p>1-3-1. 現状調査(問題の調査)</p> <p>1-3-2. 特定 EC において、問題を解決するための状況にあつた解決策を導入</p> <p>1-3-3. 将来の計画作成(中期的計画、特定 EC への投資計画)</p> <p>1-3-4. 特定 EC についてマニュアル草案の有効性を検証</p> <p>1-4. NEA と共同による EC の非技術的ベーストプラクティスの統合を含む上記の活動に基づくマニュアルの完成</p> <p>1-5. NEA と共同による他の EC にマニュアルの水平展開のための適切な仕組みの提案</p> <p>2. システムロスの量的評価のためのサポートシステムの確立</p> <p>2-1. 特定 EC について電力フロー分析のためのソフトウェアの現在の使用状況を調査</p> <p>2-2. 特定 EC についてシステムロス低減を評価する適切な方法を検討・提案</p> <p>2-2-1. 技術的損失の把握方法</p> <p>2-2-2. ロス低減分の価値評価方法</p> <p>2-3. 特定 EC について 2-1 と 2-2 に基づいた適切な手法を開発</p> <p>2-4. 上記で確立された方法で、EC の職員を訓練</p> | <p>日本側</p> <p>日本側に以下の専門家が配置される</p> <p>A. 以下に挙げられているようなパースナネルが提供される</p> <p><技術専門家チーム></p> <ul style="list-style-type: none"> ● 総括／電力系統計画 ● 経済財政分析 ● 系統解析(ソフトウェア) ● 配電計画／ロス低減 ● 配電管理／維持管理手法 ● 能力強化／業務調整 <p>B. 日本での訓練</p> <ul style="list-style-type: none"> ● 日本でのカウンタート研修 (2 回) <p>C. 設備など</p> <p>(必要であれば)シミュレーションソフトウェア</p> <p>詳細は事業期間内に検討される</p> <p>フリピン側：</p> <p>タスクメンバーはプロジェクト・デザイン・マトリックスに要約された関連活動を引き受け、協調的に働くために、それぞれの専門を任せられる。メンバーは NEA と EC から選抜される。タスクメンバーは JICA の専門家から技術を継承することを主要目標とする</p> <p>以下に挙げられているようなパースナネルが提供される</p> <p>A. カウンタート</p> <ul style="list-style-type: none"> ● 事業指揮者(Deputy Administrator for Electric Distribution Utilities Services(NEA)) ● 事業管理者(Director for Corporate Planning Office(NEA)) ● コーディネーター(インダストリアルエンジニアリング) (Manager for Strategic Planning Division(NEA)) ● 技術者(Technical Loss(NEA)) <ul style="list-style-type: none"> ・ 主任技術者(1) ・ 担当職員(2) | <p>● タスクメンバーが任命され、ワーキンググループが結成される</p> <p>● プロジェクトのために必要な予算とオフィススペースや施設がわりあてられる</p> |

| | | |
|--|---|--|
| <p>3. 中圧配電線の昇圧（23kV化）を行うための支援を実施し、技術基準を確立する</p> <p>3-1. 特定 EC の既設設備形態・計画の調査</p> <p>3-2. NEA と共同による 23kV 配電線の標準デザインとガイドラインを検討・確立</p> <p>3-3. NEA と共同による 23kV 配電線の設備基準・技術基準ガイドラインを作成</p> <p>3-4. フルスケールの F/S のための作業準備(配電開発計画の地域の確認分析)</p> <p>3-4-1. 候補地点確認</p> <p>3-4-2. F/S における検討項目の確認</p> | <ul style="list-style-type: none"> ● 技術者(Non-Technical Loss(NEA)) <ul style="list-style-type: none"> ・ 主任技術者(1) ・ 担当職員(1) B. 管理部門職員 <ul style="list-style-type: none"> ● 秘書(NEA) ● サポート職員(NEA) ● 能力強化/業務調整 C. 各 EC 職員 <ul style="list-style-type: none"> ● 技術者(Technical Loss) <ul style="list-style-type: none"> ・ 主任技術者(1) ・ 担当職員(2) ● 技術者(Non-Technical Loss) <ul style="list-style-type: none"> ・ 主任技術者(1) ・ 担当職員(1) D. 土地、建設物、その他 <ul style="list-style-type: none"> ● オフィススペース（電力、エアコン、水、通信手段含） ● その他必要な機材 E. 事業に必要な予算の分配 | |
|--|---|--|

Appendix 2
専門家派遣の実績 (1/2)

Expert Dispatch Records (1/2)

| Field | Expert | FY 2011 | | | | | | | | | | | | | | |
|---|------------------|---------|---|---|---|---|---|---|----|----|----|---|---|---|---|---|
| | | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 1 | 2 | 3 | | |
| Team Leader/ Power System Planning | Masaharu YOGO | | ■ | | | | ■ | | | ■ | | | | | ■ | |
| Distribution Planning / System Loss Reduction | Toshiya MINEJIMA | | ■ | | | | ■ | | | ■ | | | | | ■ | ■ |
| | Masahiro MYOGA | | | | | | | | | | | | | | | |
| Distribution Management / Maintenance management | Kenichi KUWAHARA | | ■ | | | | ■ | | | ■ | | | | | | ■ |
| Economic / Financial Analysis | Teru MIYAZAKI | | ■ | | | | ■ | | | ■ | | | | | | ■ |
| | Takayuki SHIBATA | | | | | | | | | | | | | | | |
| Power System Analysis (Software) | Masaki KUROIWA | | ■ | | | | | | | | | | | | | |
| | Junichi OHISHI | | | | | | ■ | | | ■ | | | | | ■ | |
| Capacity Building/ Coordinator | Keiichi FUJITANI | | ■ | | | | ■ | | | ■ | | | | | ■ | |

| Field | Expert | FY 2012 | | | | | | | | | | | | | | |
|---|------------------|---------|---|---|---|---|---|---|----|----|----|---|---|---|---|---|
| | | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 1 | 2 | 3 | | |
| Team Leader/ Power System Planning | Masaharu YOGO | | ■ | | | | ■ | | | | ■ | | | ■ | | ■ |
| Distribution Planning / System Loss Reduction | Toshiya MINEJIMA | | ■ | | | | ■ | | | | | | | | | |
| | Masahiro MYOGA | | | | | | | | | | ■ | | ■ | | ■ | |
| Distribution Management / Maintenance management | Kenichi KUWAHARA | | ■ | | | | ■ | | | | ■ | | ■ | | ■ | |
| Economic / Financial Analysis | Teru MIYAZAKI | | ■ | | | | ■ | | | | | | | | | |
| | Takayuki SHIBATA | | | | | | | | | | ■ | | ■ | | ■ | |
| Power System Analysis (Software) | Masaki KUROIWA | | ■ | | | | | | | | | | | | | |
| | Junichi OHISHI | | | | | | ■ | | | | ■ | | ■ | | ■ | |
| Capacity Building/ Coordinator | Keiichi FUJITANI | | ■ | | | | ■ | | | | | ■ | ■ | | ■ | |

Appendix 3
専門家派遣の実績 (2/2)

Expert Dispatch Records (2/2)

| Field | Expert | Dispatched Period |
|---|---------------------|--|
| Team Leader/ Power System Planning | Masaharu YOGO | Apr. 3 - Apr. 16, 2011 |
| | | Jul 19 - Aug. 5, 2011 |
| | | Oct. 16 - Oct. 28, 2011 |
| | | Jan. 30 - Feb. 11, 2012 |
| | | May. 22 - Jan. 6, 2012 |
| | | Aug. 15 - Aug. 31, 2012 |
| | | Nov. 13 - Nov. 30, 2012 |
| | | Jan. 6 - Jan. 19, 2013 |
| | | Feb. 27 - May 5, 2013 |
| Distribution Planning / System Loss Reduction | Toshiya MINEJIMA | Apr. 10 - Apr. 16, 2011 |
| | | Jul 17 - Aug. 5, 2011 |
| | | Oct. 13 - Oct. 28, 2011 |
| | | Jan. 29 - Jan. 31, Feb. 6 - Feb. 17, 2012 |
| | | May. 22 - Jan. 6, 2012 |
| | | Aug. 15 - Aug. 31, 2012 |
| | Masahiro MYOGA | Nov. 13 - Nov. 30, 2012 |
| | | Jan. 6 - Jan. 19, 2013 |
| | | Feb. 27 - May 5, 2013 |
| Distribution Management / Maintenance management method | Kenichi KUWAHARA | Apr. 3 - Apr. 16, 2011 |
| | | Jul 19 - Aug. 3, 2011 |
| | | Oct. 13 - Oct. 27, 2011 |
| | | Feb. 5 - Feb. 17, 2012 |
| | | May. 22 - Jan. 6, 2012 |
| | | Aug. 20 - Aug. 31, 2012 |
| | | Nov. 18 - Dec. 5, 2012 |
| | | Jan. 6 - Jan. 18, 2013 |
| | | Feb. 18 - May 1, 2013 |
| Economic / Financial Analysis | Teru MIYAZAKI | Apr. 3 - Apr. 16, 2011 |
| | | Jul 19 - Aug. 5, 2011 |
| | | Oct. 16 - Oct. 28, 2011 |
| | | Feb. 5 - Feb. 17, 2012 |
| | | May. 22 - Jan. 2, 2012 |
| | | Aug. 15 - Aug. 31, 2012 |
| | Takayuki SHIBATA | Nov. 13 - Nov. 30, 2012 |
| | | Jan. 6 - Jan. 19, 2013 |
| | | Feb. 27 - May 5, 2013 |

| Field | Expert | Dispatched Period |
|-------------------------------------|---------------------|-------------------------|
| Power System Analysis (Software) | Masaki KUROIWA | Apr. 3 - Apr. 16, 2011 |
| | Junichi OHISHI | Jul 19 - Aug. 5, 2011 |
| | | Oct. 16 - Oct. 28, 2011 |
| | | Jan. 29 - Feb. 10, 2012 |
| | | May. 22 - Jan. 2, 2012 |
| | | Aug. 15 - Aug. 31, 2012 |
| | | Dec. 4 - Dec. 21, 2012 |
| | | Jan. 6 - Jan. 19, 2013 |
| | | Feb. 27 - May 5, 2013 |
| Capacity Building/Coordinator | Keiichi FUJITANI | Apr. 3 - Apr. 16, 2011 |
| | | Jul 17 - Aug. 1, 2011 |
| | | Oct. 13 - Oct. 28, 2011 |
| | | Jan. 29 - Feb. 9, 2012 |
| | | May. 22 - Jan. 2, 2012 |
| | | Aug. 20 - Aug. 31, 2012 |
| | | Dec. 3 - Dec. 21, 2012 |
| | | Jan. 8 - Jan. 19, 2013 |
| | | Feb. 26 - May 5, 2013 |

Appendix 4

本邦カウンターパート

トレーニング研修員受け入れ実績

The trainees' lists of counterpart training in Japan

| FY | Period | Name of Participants | Designation | Office address | Organization |
|------|----------------------------------|--------------------------------|-------------------------|---|-------------------------------|
| 2011 | 2012/3/6 | MONTANO Virgilio Labuguen | General Manager | Office of the General Manager | ISELCO I |
| | | GAMBOA Enrique Yumang | Manager | Technical Operation Department | PELCO II |
| | | MALENIZA Carmille Sabio | Section Head | Technical Planning Section-Corporate Planning Department | CASURECO II |
| | | OLEA Alfred Dela Cruz | Section Head | System Loss Reduction & Special Equipment-Technical Services Department | CASURECO IV |
| | - | HERNANDEZ Jane Gabionza | Division Chief | Planning, Monitoring and Evaluation-Technical Services Department | SORECO I |
| | 2012/3/16 | FORSUELO Richard Abroso | Section Head | Planning Design & Evaluation-Engineering Services Division | LEYECO III |
| | | DE VEAS Claro Gutierrez | Principal Engineer | Engineering Department, Technical Operations Division | NEA |
| | | CORTES Antonio Dizon | Principal Engineer | Engineering Department, Technical Operations Division | NEA |
| | | DAVID Bonifacio Tolentino | Senior Engineer | Engineering Department, Technical Operations Division | NEA |
| | | EVALE Exequiel Jr Tidalgo | Senior Engineer | Engineering Department, Technical Operations Division | NEA |
| 2012 | | 2012/9/24 | BALINGUE Abraham Corpuz | Area Engineer | Technical Services Department |
| | DEL FIN Marvin Alimurung | | Section Head | Technical Cooperation Department | PELCO II |
| | MACALALAG Jan Michael Lagradilla | | Division Chief | Technical Services Department | FLECO |
| | NAPAY Joanaiyn Candilosas | | Section Head | Engineering Department, Line Operation Division | CASURECO II |
| | - | FORTES Roberto Fortes | General Manager | Office of the General Manager | SORECO I |
| | 2012/10/5 | VILLAREAL Ferdinand Purugganan | Acting Director | Engineering Department, Technical Operations Division | NEA |
| | | SILVANO Ernesto Jr. Oledan | Principal Engineer | Engineering Department, Technical Operations Division | NEA |
| | | VELGADO Enrico Golla | Senior Engineer | Engineering Department, Technical Operations Division | NEA |
| | | FAJARDO Manolito Santiago | Senior Officer | Electric Cooperative Audit Department, Accelerated Total Electrification Division | NEA |
| | | GALARPE Arnel Pascubillo | Officer in Charge | Institutional Development Department, Consumer Development Protection Division | NEA |

Appendix 5

機材供与実績

Equipment Administration for the Survey

| Date of Registration (Day-Month-Year) | Name of Equipment | Specification | QTY | Unit Price (US\$, PHP) | User | Condition |
|--|---|---------------|-----|---|--|-----------|
| 08-Feb-12 | SynerGEE Electric Core Load Flow Module and SynerGEE Middlelink Electric | Version 3.8 | 8 | US\$110,000 | NEA, ISELCO I, PELCO II, FLECO, CASURECO II, CASURECO IV, SORECO I, LEYCO III | Transfer |
| 08-Feb-12 | Clamp on Power Hitester | HIOKI 3169-21 | 14 | Procurement by JICA Philippines office | NEA, ISELCO I, PELCO II, FLECO, CASURECO II, CASURECO IV, SORECO I, LEYCO III | Transfer |
| 31-Oct-12 | Amorphous Distribution Transformer | 10kVA | 6 | Procurement by JICA Philippines office | ISELCO I, PELCO II, FLECO | Transfer |
| 31-Oct-12 | Amorphous Distribution Transformer | 15kVA | 6 | Procurement by JICA Philippines office | ISELCO I, PELCO II, FLECO | Transfer |
| 31-Oct-12 | Amorphous Distribution Transformer | 25kVA | 6 | Procurement by JICA Philippines office | ISELCO I, PELCO II, FLECO | Transfer |
| 31-Oct-12 | Amorphous Distribution Transformer | 37.5kVA | 6 | Procurement by JICA Philippines office | ISELCO I, PELCO II, FLECO | Transfer |
| 31-Oct-12 | Amorphous Distribution Transformer | 50kVA | 3 | Procurement by JICA Philippines office | ISELCO I, PELCO II, FLECO | Transfer |

Appendix 6
Minutes of Meetings
(1st mission to 9th mission)

(1st Mission)

Minutes of Meetings
of
the 1st Mission
on
The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's)
between
National Electrification Administration
and the
JICA Technical Assistance Team

The JICA Technical Assistance Team (hereafter referred to as "the TA Team") conducted the 1st Mission for The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's) (hereafter referred to as "the Project") from April 4th, 2011 to April 15th, 2011.

During this mission, discussions and confirmation were conducted in a friendly and cordial atmosphere between National Electrification Administration (hereafter referred to as "NEA") and the TA Team.

The main items that were discussed and confirmed are summarized below.

Kick-off Meeting

Date: April 4th, 2011

Time: 13:30 – 15:30

Venue: NEA Meeting room

Attendee: See Kick-off Meeting of the 1st Mission on "The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's)" Attendee List (Appendix-1)

The TA Team submitted eight (8) copies of "Implementation plan" to NEA and explained the contents based on the supplemental materials (Appendix-2). NEA and The TA Team exchanged opinions of both sides based on the supplemental materials and agreed on the ways of the Project proposed by the TA Team.

Data Collection Status

The TA Team submitted Questionnaires (Appendix-3) to NEA. During the 1st Mission, some of the available data and information were collected and the rest of the data and information will

submitted from NEA to the TA Team by the end of June through the e-mail.

Assignment of the representative persons of the joint coordination committee meeting (JCC)

The TA Team requested NEA to assign the representative persons of the joint coordination committee meeting from relevant authorities by the time of 2nd mission and NEA agreed on the cooperation.


Assignment of the representative persons of the work shop (WS)

The TA Team requested NEA to assign the representative 2 or 3 persons of the work shop from selected seven (7) ECs by the time of 2nd mission and NEA agreed on the cooperation.

The schedule of next mission


The schedule of next mission (from July 17th to August 5th) and the Agenda of JCC and Work Shop referred to the documents attached hereto (Appendix 4,5,6) was confirmed by both the counterparts of NEA and the TA Team.

April 15, 2011
Manila, Philippines



Mr. Masaharu YOGO
Team Leader

JICA TA Team



Mr. Edgardo R. Piamonte
Deputy Administrator for Electric
Distribution Utilities Services
National Electrification Administration

(2nd Mission)

**Minutes of Meetings of
the 2nd Mission on
The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's)
between
National Electrification Administration
and the
JICA Technical Assistance Team**

The JICA Technical Assistance Team (hereafter referred to as "the TA Team") conducted the 2nd Mission for The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's) (hereafter referred to as "the Project") from July 17th, 2011 to August 5th, 2011.

During this mission, discussions and confirmation were conducted in a friendly and cordial atmosphere between National Electrification Administration (hereafter referred to as "NEA") and the TA Team. The main items that were discussed and confirmed are summarized below.

Joint Coordination Committee Meeting (JCC)

Date: July 28th, 2011

Time: 9:30 – 11:00

Venue: NEA Meeting room

Attendee: Attendee List (Appendix-1)

The TA Team reported the outline of Current Situation of this Project to NEA and explained the contents based on the supplemental materials (Appendix-2). NEA and The TA Team exchanged opinions of both sides based on the supplemental materials and agreed on the ways of the Project proposed by the TA Team. Main topics discussed are as follows.

- ✓ Schedule of the TA
- ✓ Proposal of the pilot project
- ✓ Needs for installation of software to ECs

1st Work Shop on "The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's)"

Date: July 29th, 2011

Time: 8:50 – 16:00

Venue: Dusit Thani Manila Hotel, 2nd floor Boardroom 2

Attendee: Attendee List (Appendix-3)

The TA Team made following presentation.

- ✓ Outline of Current Situation of this Project
- ✓ Distribution Management method in Japan
- ✓ Technical Loss Reduction using Amorphous Core transformer
- ✓ Distribution Planning in Japan

The NEA made following presentation.

- ✓ Distribution Planning and management method and Current Situation of System Loss Reduction in Philippines

The seven ECs made following presentation.

- ✓ Good practices for system loss reduction Outline of Current Situation of this Project

Pilot Site for Project on System Loss Reduction

The TA Team proposed the pilot sites to be CASURECO II or CASURECO IV according to their current status of loss ratios. However, after evaluation of the selected ECs and observation on the presentation of CASURECO II in 1st Workshop at Dusit Thani Hotel, instead of CASURECO II, other ECs, such as FLECO, ISELCO I or PELCO II seemed suitable for pilot sites from the viewpoints of their data arrangement and the management situations.

The NEA and the TA team agreed on the candidate sites and agreed to cooperate on the pilot site survey.

Counterpart Training in JAPAN

The TA Team proposed the rescheduling counterpart training in JAPAN from the former November, 2011 to March, 2012. The NEA agreed on the proposal.

The schedule of next mission

The schedule of next mission (from October 18th to October 28th) referred to the documents attached hereto (Appendix 4) was confirmed by both the counterparts of NEA and the TA Team.

August 4, 2011
Manila, Philippines

餘 語 正 晴

Mr. Masaharu YOGO
Team Leader
JICA TA Team



EDGARD R. PIAMONTE
Deputy Administrator for Electric
Distribution Utilities Services
National Electrification Administration

(3rd Mission)

**Minutes of Meetings of
the 3rd Mission on
The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's)
between
National Electrification Administration
and the
JICA Technical Assistance Team**

The JICA Technical Assistance Team (hereafter referred to as "the TA Team") conducted the 3rd Mission for The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's) (hereafter referred to as "the Project") from October 13th, 2011 to October 28th, 2011.

During this mission, discussions and confirmation were conducted in a friendly and cordial atmosphere between National Electrification Administration (hereafter referred to as "NEA") and the TA Team. The main items that were discussed and confirmed are summarized below.

Assignment of the representative persons of the Joint Coordination Committee meeting (JCC)

The TA Team requested NEA to assign the representative persons of the joint coordination committee meeting from relevant authorities by the time of 4th mission (February 7) and NEA agreed on the cooperation and the agenda of JCC referred to the documents attached hereto (Appendix 1) was confirmed by both the counterparts of NEA and the TA Team.

Assignment of the representative persons of the work shop (WS)

The TA Team requested NEA to assign the representative 2 or 3 persons include engineer of the work shop from selected seven (7) ECs by the time of 4th mission (February 8) and NEA agreed on the cooperation and the agenda of JCC referred to the documents attached hereto (Appendix 2) was confirmed by both the counterparts of NEA and the TA Team.

Pilot Site for Project on System Loss Reduction

The TA Team proposed the pilot sites to be ISELCO I and PELCO II from the viewpoints of their data arrangement and the management situations.

The TA Team will continue the study of upgrading of medium voltage.

The NEA and the TA team agreed on the candidate sites and agreed to cooperate on the pilot site survey.

Counterpart Training in JAPAN

The TA Team proposed the schedule of counterpart training in JAPAN (from March 5th to March 17th). The NEA agreed on the proposal and the schedule referred to the documents attached hereto (Appendix 3) was confirmed by both the counterparts of NEA and the TA Team..


Assignment of the representative persons of Counterpart Training in JAPAN

The TA Team requested NEA to assign the representative one person from selected seven (7) ECs and more three persons (Total ten person), and submit the list to JICA Philippines Office. NEA agreed on the cooperation.

The schedule of next mission

The schedule of next mission (from January 29th to February 17th) referred to the documents attached hereto (Appendix 4) was confirmed by both the counterparts of NEA and the TA Team.


October 27, 2011
Manila, Philippines



Mr. Masaharu YOGO

Team Leader

JICA TA Team



EDGARDO R. PIAMONTE

Deputy Administrator for
Electric Distribution Utilities Services
National Electrification Administration

(4th Mission)

**Minutes of Meetings of
the 4th Mission on
The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's)
between
National Electrification Administration
and the
JICA Technical Assistance Team**

The JICA Technical Assistance Team (hereafter referred to as “the TA Team”) conducted the 4th Mission for The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's) (hereafter referred to as “the Project”) from January 29th, 2012 to February 17th, 2012.

During this mission, discussions and confirmation were conducted in a friendly and cordial atmosphere between National Electrification Administration (hereafter referred to as “NEA”) and the TA Team. The main items that were discussed and confirmed are summarized below.

Joint Coordination Committee Meeting (JCC)

Date: February 7th, 2012

Time: 10:00 – 11:10

Venue: NEA 6F Meeting room

Attendee: Attendee List (Appendix-1)

The TA Team reported the overall progress and activities carried out of this Project to NEA and explained the outline of the Draft Contents of System Loss Reduction Manual (Appendix-2). NEA and The TA Team exchanged opinions of both sides based on the supplemental materials and agreed on the Draft Contents of System Loss Reduction Manual and next year schedule proposed by the TA Team. Main topics discussed are as follows.

- ✓ Draft Contents of System Loss Reduction Manual
- ✓ Upgrading the distribution line voltage
- ✓ Next fiscal year schedule of the TA
- ✓ Modeling of EC distribution line

2nd Work Shop on “The Project on System Loss Reduction for Philippine Electric Cooperatives (EC’s)”

Date: February 8th, 2011

Time: 9:30 – 16:00

Venue: Dusit Thani Manila Hotel, 2nd floor Boardroom 2

Attendee: Attendee List (Appendix-3)

The TA Team made following presentation.

- ✓ Overall progress and activities carried out of this Project and the outline of the Draft Contents of System Loss Reduction Manual
- ✓ Methods for evaluating system loss reduction using SynerGEE
- ✓ Economical evaluating for system loss reduction project
- ✓ Effects for introduction of AMDT
- ✓ Useful information of Loss reduction in Slum area in Brazil

The Philec made the following presentation.

- ✓ Current situation of utilization of AMDT in Philippine

The seven ECs made the following presentation.

- ✓ Good practices for system loss reduction

Pilot Site for Project on System Loss Reduction

The TA Team proposed the pilot sites to be ISELCO I and PELCO II from the viewpoints of their data arrangement and the management situations.

The TA Team will continue the study of upgrading of medium voltage.

The NEA and the TA team agreed on the candidate sites and agreed to cooperate on the pilot site survey.

The contents of System Loss Reduction Manual

The TA Team explained the contents of System Loss Reduction Manual. The NEA and the TA team agreed on the contents referred to the documents attached hereto. (Appendix 2)


The schedule of next mission

The schedule of next mission (from May 22nd to June 6th) referred to the documents attached hereto (Appendix 4) was confirmed by both the counterparts of NEA and the TA Team.

The schedule of next year

The schedule of next year referred to the documents attached hereto (Appendix 5) was confirmed by both the counterparts of NEA and the TA Team.


February 10, 2012
Manila, Philippines



Mr. Masaharu YOGO

Team Leader

JICA TA Team



EDGARD R. PIAMONTE

Deputy Administrator for Electric
Distribution Utilities Services
National Electrification Administration

(5th Mission)

**Minutes of Meetings of
the 5th Mission on
The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's)
between
National Electrification Administration
and the
JICA Technical Assistance Team**

The JICA Technical Assistance Team (hereafter referred to as “the TA Team”) conducted the 5th Mission for The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's) (hereafter referred to as “the Project”) from May 22nd, 2012 to June 6th, 2012.

During this mission, discussions and confirmation were conducted in a friendly and cordial atmosphere between National Electrification Administration (hereafter referred to as “NEA”) and the TA Team. The main items that were discussed and confirmed are summarized below.

3rd Work Shop on “The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's)”

Date: May 31st, 2012

Time: 9:30 – 16:30

Venue: Dusit Thani Manila Hotel, 2nd floor Boardroom 2

Attendee: Attendee List (Appendix-1)

The TA Team made following presentation.

- ✓ Overall progress and activities carried out of this Project
- ✓ Sample Analysis of Medium Voltage Line Loss Reduction Measures and Proposed on appropriate mechanism to transfer loss reduction method to all ECs

The NEA made the following presentation.

- ✓ System loss reduction using SynerGEE

The BENECO made the following presentation.

- ✓ Experience of upgrading distribution voltages

The seven ECs made the following presentation.

- ✓ Activities for system loss reduction using software

Pilot Site Project for System Loss Reduction by installing AMDT

The TA Team proposed the pilot site for System Loss Reduction by installing AMDT to be ISELCO I, PELCO II and FLECO from the viewpoints of their data arrangement and the management situations.

The NEA and the TA team agreed on the candidate sites and agreed to cooperate on the pilot site survey.

The schedule of next mission

The schedule of next mission (from August 15th to September 5th) referred to the documents attached hereto (Appendix 2) was confirmed by both the counterparts of NEA and the TA Team.

Counterpart Training in JAPAN

The TA Team proposed the schedule of counterpart training in JAPAN (from September 24th to October 6th). The NEA agreed on the proposal and the schedule referred to the documents attached hereto (Appendix 3) was confirmed by both the counterparts of NEA and the TA Team.

Assignment of the representative persons of Counterpart Training in JAPAN

The TA Team requested NEA to assign the representative one person from selected seven (7) ECs and more three persons (Total ten person), and submit the list to JICA Philippines Office. NEA agreed on the cooperation.


June 5, 2012
Manila, Philippines

餘語正晴

Mr. Masaharu YOGO

Team Leader

JICA TA Team



EDGARD R. PIAMONTE

Deputy Administrator for Electric
Distribution Utilities Services
National Electrification Administration

(6th Mission)

**Minutes of Meetings of
the 6th Mission on
The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's)
between
National Electrification Administration
and the
JICA Technical Assistance Team**

The JICA Technical Assistance Team (hereafter referred to as “the TA Team”) conducted the 6th Mission for The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's) (hereafter referred to as “the Project”) from August 15th, 2012 to August 31st, 2012.

During this mission, discussions and confirmation were conducted in a friendly and cordial atmosphere between National Electrification Administration (hereafter referred to as “NEA”) and the TA Team. The main items that were discussed and confirmed are summarized below.

The confirmation of System Loss Reduction Manual

The TA Team explained the System Loss Reduction Manual (Draft) (hereafter referred to as “the Manual”). The TA Team requested NEA to write the “Foreword” and “Chapter 8”. NEA agreed on taking charge of writing of the “Foreword” and “Chapter 8”. The TA Team requested NEA to check the Manual and distribute the Manual to selected ECs and submit the comments of Manual include selected ECs comments by 24th of September. NEA agreed on the submission of the comments of the Manual. The latest Manual is attached hereto. (Appendix 1)

Pilot Site Project for System Loss Reduction by installing AMDT

The TA Team explained the pilot site for System Loss Reduction by installing AMDT to be ISELCO I, PELCO II and FLECO. The NEA agreed to cooperate on the pilot site survey.

Assignment of the representative persons of the Joint Coordination Committee meeting (hereafter referred to as “JCC”)

The TA Team requested NEA to assign the representative persons of the joint coordination committee meeting from relevant authorities by the time of 7th mission (27th of November) and NEA agreed on the cooperation and the agenda of JCC referred to the documents attached hereto (Appendix 2) was confirmed by both the counterparts of NEA and the TA Team.


Assignment of the representative persons of the work shop (hereafter referred to as “WS”)

The TA Team requested NEA to assign the representative 2 or 3 persons include engineer of the work shop from selected seven (7) ECs by the time of 7th mission (28th of November) and NEA agreed on the cooperation and the agenda of WS referred to the documents attached hereto (Appendix 3) was confirmed by both the counterparts of NEA and the TA Team.

The schedule of next mission

The schedule of next mission (from November 13th to December 21st) referred to the documents attached hereto (Appendix 4) was confirmed by both the counterparts of NEA and the TA Team.


August 30, 2012
Manila, Philippines



Mr. Masaharu YOGO

Team Leader

JICA TA Team



EDGARD R. PIAMONTE

Deputy Administrator for Electric

Distribution Utilities Services

National Electrification Administration

(7th Mission)

**Minutes of Meetings of
The 7th Mission on
The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's)
between
The National Electrification Administration
and
The JICA Technical Assistance Team**

The JICA Technical Assistance Team (hereafter referred to as the "TA Team") conducted the first half of 7th Mission for The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's) (hereafter referred to as "the Project") from November 13th, 2012 to November 27th, 2012.

During this mission, discussions and confirmation were conducted in a friendly and cordial atmosphere between National Electrification Administration (hereafter referred to as "NEA") and the TA Team. The main items that were discussed and confirmed are summarized below.

Joint Coordination Committee Meeting (JCC)

Date: November 27th, 2012

Time: 10:15 – 11:40

Venue: NEA 6F Meeting room

Attendee: Attendee List (Appendix-1)

The TA Team reported the overall progress and activities carried out of this Project to NEA and explained the outline of the Draft System Loss Reduction Manual (Appendix-2). NEA and the TA Team commented and exchanged opinions based on the supplemental materials and agreed on the Draft System Loss Reduction Manual and the next mission schedule proposed by the TA Team. Main topics discussed are as follows.

- ✓ Draft System Loss Reduction Manual
- ✓ Upgrading the distribution line voltage
- ✓ AMDT pilot project

The confirmation of Draft System Loss Reduction Manual

The TA Team explained the outline of the Draft System Loss Reduction Manual (hereafter referred to as "the Manual"). The TA Team requested NEA to write the "Foreword". NEA agreed on taking charge of writing of the "Foreword". The Preface, which is written by conductor of this mission, is requested by JICA. The TA Team requested NEA to check the Manual and distribute the Manual to selected ECs and submit the comments on the Manual by the 19th of December. NEA agreed on the submission of the comments of the Manual. The latest Manual is attached hereto. (Appendix-2) The manual will be finalized in early January 2013. The finalized Manual will be explained in the workshop (hereafter referred to as "WS").

The recommendation of Voltage Upgrading

The TA Team explained the concept and construction procedure of voltage upgrading from 13.2kV to 23kV. NEA will inform the TA Team's recommendations about the voltage upgrading to the selected ECs and to ask them to give their comments in advance prior to the WS, which would be held next January 2013. NEA mentioned other candidate sites that can be considered to have a 23kV distribution system project introduced. The result of study of actual candidate sites will be reflected in the completion report of this project.

Pilot Site Project for AMDT installation

The TA Team explained that the pilot site for AMDT installation will be ISELCO I, PELCO II and FLECO. The NEA agreed to cooperate on the additional pilot site survey, if necessary.

Assignment of the representative persons of the WS

The TA Team requested NEA to invite 6 or 7 representatives, to include engineers, from selected seven (7) ECs on the 8th mission (16th of January). NEA agreed on the agenda of the WS referred to the documents attached hereto (Appendix 3) as confirmed by the NEA/TA Team.

The schedule of next mission

The schedule of next mission (from January 6th to January 19th) referred to the documents attached hereto (Appendix 4) was also confirmed by the NEA/TA Team.

Other items

NEA proposed to provide a meeting room at NEA for the WS, which will be held on January 16, 2013. The Foreword of the manual was provided by NEA.

November 29, 2012
Manila, Philippines

for 餘語正晴

Mr. Masaharu YOGO

Team Leader

JICA TA Team

Edgardo R. Piamonte

EDGARDO R. PIAMONTE

Deputy Administrator for Electric

Distribution Utilities Services

National Electrification Administration

(8th Mission)

**Minutes of Meetings of
The 8th Mission on
The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's)
between
The National Electrification Administration
and
The JICA Technical Assistance Team**

The JICA Technical Assistance Team (hereafter referred to as the "TA Team") conducted the 8th Mission for The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's) (hereafter referred to as "the Project") from January 6th, 2013 to January 19th, 2013.

During this mission, discussions and confirmation were conducted in a friendly and cordial atmosphere between National Electrification Administration (hereafter referred to as "NEA") and the TA Team. The main items that were discussed and confirmed are summarized below.

The confirmation of System Loss Reduction Manual

The TA Team submitted the sample of System Loss Reduction Manual (hereafter referred to as "the Manual"). NEA received the Manual and the manual have been finalized. The latest Manual is attached hereto. (Appendix 1) The three hundred copies of the Manual will be distributed in the 4th workshop (hereafter referred to as "WS").

The necessary assistance for work shop on 28th of February

The TA Team requested NEA the necessary assistance for work shop. NEA agreed on providing the necessary assistance for work shop. (Appendix 2)

Assignment of the representative persons of the WS

The TA Team requested NEA to invite 2 representatives of the work shop from all ECs. NEA agreed on the cooperation and the agenda of WS referred to the documents attached hereto (Appendix 3) was confirmed by both the counterparts of NEA and the TA Team.

The recommendation of System Voltage Upgrading

The TA Team recommended the system voltage upgrading from 13.2kV to 23kV. NEA agreed the concept of system voltage upgrading and will promote the system voltage upgrading in all ECs area. NEA wishes the grant or the soft loan by JICA as the international aid.


The recommendation of establishment of material center

The TA Team proposed the establishment of material center. NEA operated 9 material center in Philippine. However, all material centers were abolished in 1990th. NEA can not force the establishment of regional material center on ECs because of the respect for EC's autonomy. Therefore NEA recommended that the TA Team should discuss the proposal with ECs.

The schedule of next mission

The schedule of next mission (from February 18th to March 5th) referred to the documents attached hereto (Appendix 4) was also confirmed by the NEA/TA Team.


January 18, 2013
Manila, Philippines



Mr. Masaharu YOGO

Team Leader

JICA TA Team



EDGARDO R. PIAMONTE

Deputy Administrator for Electric
Distribution Utilities Services

National Electrification Administration

(9th Mission)

The recommendation of System Voltage Upgrading

The TA Team recommended the system voltage upgrading from 13.2kV to 23kV. NEA agreed the concept of system voltage upgrading and will promote the system voltage upgrading in all ECs area. NEA wishes the grant or the soft loan by JICA as the international aid.

The recommendation of establishment of material center

The TA Team proposed the establishment of material center. NEA operated 9 material center in Philippine. However, all material centers were abolished in 1990th. NEA can not force the establishment of regional material center on ECs because of the respect for EC's autonomy. Therefore NEA recommended that the TA Team should discuss the proposal with ECs.

The schedule of next mission

The schedule of next mission (from February 18th to March 5th) referred to the documents attached hereto (Appendix 4) was also confirmed by the NEA/TA Team.


January 18, 2013
Manila, Philippines



Mr. Masaharu YOGO

Team Leader

JICA TA Team



EDGARDO R. PIAMONTE

Deputy Administrator for Electric
Distribution Utilities Services
National Electrification Administration

The recommendation of System Voltage Upgrading

The TA Team recommended the system voltage upgrading from 13.2kV to 23kV. NEA agreed the concept of system voltage upgrading and will promote the system voltage upgrading in all ECs area. NEA wishes the grant or the soft loan by JICA as the international aid.


The recommendation of establishment of material center

The TA Team proposed the establishment of material center. NEA operated 9 material center in Philippine. However, all material centers were abolished in 1990th. NEA can not force the establishment of regional material center on ECs because of the respect for EC's autonomy. Therefore NEA recommended that the TA Team should discuss the proposal with ECs.

The schedule of next mission

The schedule of next mission (from February 18th to March 5th) referred to the documents attached hereto (Appendix 4) was also confirmed by the NEA/TA Team.


January 18, 2013
Manila, Philippines



Mr. Masaharu YOGO

Team Leader

JICA TA Team



EDGARDO R. PIAMONTE

Deputy Administrator for Electric

Distribution Utilities Services

National Electrification Administration

Appendix 7
Presentation Materials
(1st workshop to final workshop)

Presentation Materials of 1st Workshop

| <p>JICA The Project on System Loss Reduction for Philippine Electric Cooperatives</p> <p>The 1st Joint Coordination Committee Meeting / The 1st Workshop</p> <p>MAYOGO TEPCO/JICA TA Team Manila July 28th and 29th 2011</p> | <p>JICA TA Team</p> <ul style="list-style-type: none"> Masaharu YOGO: Team leader/ Power system Planning Toshiya MINEJIMA: Distribution Planning/System Loss Reduction Kenichi KUWAHARA: Distribution Management / Maintenance Management Method Teru MIYAZAKI: Economic/ Financial Analysis JUNICHI OHISHI: Power System Analysis (Software) Keiichi FUJITANI: Capacity Building/Coordinator Saichiro HIROSE: Support Staff <p>— Mr. YOGO, Mr. MINEJIMA, Mr. MIYAZAKI, Mr. OHISHI and Mr. FUJITANI belong to TEPCO and Mr. KUWAHARA and Mr. HIROSE belonging to SHIKOKU EPCO support TEPCO.</p> | <p>Japanese Power Utilities</p> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|--|---|--|-------------------|--------------------------------|---|-------------------|----------------------|---|------|----------|----------|------|--|--|------|---|------|------|-------|-------|------|---|------|------|-------|--------|------|---|------|------|-------|-------|------|---|------|------|-------|--------|------|---|------|------|-------|--------|------|---|------|------|-------|-------|------|---|------|------|-------|--------|------|----|------|------|-------|-------|------|----|------|------|-------|--------|---|---|---|---|---|---------|
| <p>TEPCO's Service Area</p> <table border="1"> <thead> <tr> <th></th> <th>TEPCO</th> <th>All Japan</th> <th>TEPCO's share</th> </tr> </thead> <tbody> <tr> <td>Peak Demand</td> <td>84,350W</td> <td>182,400W</td> <td>35%</td> </tr> <tr> <td>Loss</td> <td>22877kWh</td> <td>29774kWh</td> <td>35%</td> </tr> </tbody> </table> | | TEPCO | All Japan | TEPCO's share | Peak Demand | 84,350W | 182,400W | 35% | Loss | 22877kWh | 29774kWh | 35% | <p>Purposes of the Technical Assistance</p> <ul style="list-style-type: none"> To provide necessary support to improve the management and technology of NEA and selected ECs (7 ECs) Output 1: Total management manuals for system loss reduction Output 2: Support system for quantitative evaluation of system loss Output 3: Support system for upgrading the present mid-voltage to 23kV (or 34.5 kV) and technical design standards Hopefully, we may identify the projects for loss reductions via those activities. | <p>7 ECs</p> <ul style="list-style-type: none"> ISELCO I (Isabela 1) PELCO II (Pampanga 2) FLECO (First Laguna) CASURECO II (Camarines Sur 2) CASURECO IV (Camarines Sur 4) SORECO I (Sorsogon 1) LEVECO III (Leyte 3) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | TEPCO | All Japan | TEPCO's share | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Peak Demand | 84,350W | 182,400W | 35% | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Loss | 22877kWh | 29774kWh | 35% | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <p>Outputs 1 and 2</p> <ul style="list-style-type: none"> Output 1: Total management manuals for system loss reduction <ul style="list-style-type: none"> To investigate causes of technical losses To find out causes and their measures from the viewpoints of O&M <ul style="list-style-type: none"> Daily management of load data (distribution transformers and their feeders) Distribution system map/ diagrams and distribution facilities data Management of customer data (relation between LV feeders and customers) Selection of optimum conductor, transformer To do issue-solving activities with the counterpart To review and reflect the current measurements and existing manual <ul style="list-style-type: none"> The core solutions depend on system configurations and regional characteristics and their priority To carry out EPC studies for each EC To formulate total management manuals for technical loss reduction Output 2: Support system for quantitative evaluation of system loss <ul style="list-style-type: none"> To make quantitative evaluation of system losses <ul style="list-style-type: none"> Load data, distribution facilities data and necessity of introducing analysis software To grasp the effects on reduction in technical losses Make trial runs the merit of countermeasures against technical loss and their effects To make distribution plans to consider loss reduction Selection of capacity, Establishment of consideration methodology of economic value of loss reduction | <p>Output 3</p> <ul style="list-style-type: none"> Output 3: Support system for upgrading the present mid-voltage to 23kV (34.5 kV) and establishment of technical design standards. Effects of upgrading system voltages: <ul style="list-style-type: none"> Adequate maintenance of system voltage Enhancement of power supply reliability Investment cost for construction of upgrading voltage: <ul style="list-style-type: none"> When upgrading system MV voltage, the capacity expansion of existing distribution network facilities and their power sources (distribution sub stations) would be required Expenses for operation/maintenance business after upgrading voltage (O&M) must be larger and heavier Activities for keeping the system (disaster, dark, clearance, relocate the lean-by buildings or vegetation management) Comments: Technical justification for new raising voltage, or replacement of the transformer (substations) should be established Making criteria of selecting the candidate area for upgrading voltage, and schedule on each project <ul style="list-style-type: none"> Evaluation of financial merit gained by upgrading voltage and its cost <ul style="list-style-type: none"> Establishment of criteria for assessing on sites and when upgrading voltage Study and establishment of rational criteria and item-checklist for upgrading Issuing manuals regarding upgrading voltage <ul style="list-style-type: none"> Concerning upgrading voltage considering the complicated situation in which the old facilities (substations) have voltage and the new installed are existing simultaneously Manuals or guidelines on planning, construction, operation or maintenance business for 23kV (or 34.5 kV) raised distribution networks <ul style="list-style-type: none"> Manuals on 23kV (or 34.5 kV) voltage area to be suited for support of seven ECs. | <p>Schedule</p> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <p>Fact findings - Roles of Software</p> <ul style="list-style-type: none"> ERC Guidelines, ARTICLE II Segregation of Distribution System Losses <ul style="list-style-type: none"> Most of ECs is carrying out quantitative evaluation of system loss with utilizing "PowerSolver Software" that is considered suitable for calculating total system loss. PowerSolve Suitable for Segregation of Distribution System Losses SynerGEE Suitable for identifying causes of technical loss and their countermeasures (mapping image, detailed results of loss causing locations) | <p>Fact findings - Existing Manuals</p> <ul style="list-style-type: none"> Electric Cooperatives Distribution Utility Planning Manual Distribution Code <ul style="list-style-type: none"> Objective, Criteria, Goals and General procedure clearly described Issues for efficient planning for technical loss reduction <ul style="list-style-type: none"> Methodology of economic evaluation for loss reduction projects should be established Loading levels of distribution transformers/lines should be examined in terms of loss reduction Loss reduction by power factor correction seems to be secured if following Distribution Code. Methodology of identifying loss reduction measures should be established Others <ul style="list-style-type: none"> Setting out resistance temperature non technical portion of burden in system for technical loss estimation | <p>Fact findings - Status of metering system confirmed</p> <ul style="list-style-type: none"> Current Status <ul style="list-style-type: none"> No significant problems in system with meter quality management, meter reading and calibration Estimated causes for large non-technical losses <ul style="list-style-type: none"> Meter reading <ul style="list-style-type: none"> A possibility of not doing once a month Reading error (lower when using handy terminal?) Calibration <ul style="list-style-type: none"> How many sampling every two years? ±0.5% be kept? (considered no problems because of acceptance deal by EC) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <p>Proposal for Pilot Projects</p> <ul style="list-style-type: none"> Purpose <ul style="list-style-type: none"> To try to simulate the distribution system for establishing Manuals To identify candidates of the loss reduction projects 3rd mission <ul style="list-style-type: none"> Making Draft Manuals via Pilot Projects with using Software, SynerGEE SynerGEE modeling Preparation for case studies 4th mission <ul style="list-style-type: none"> Establishing Manuals Identifying candidates of the projects with using Software, SynerGEE Initial pilot project sites will be selected during this mission hopefully mediated by SynerGEE <ul style="list-style-type: none"> High loss ratio SynerGEE | <p>Manuals to be established</p> <ul style="list-style-type: none"> Purpose <ul style="list-style-type: none"> To make quick and rational judgments about the countermeasures against loss to identify their candidates Criteria for taking measures <ul style="list-style-type: none"> Loss reduction by installation of pole transformers, leveling the operation loads of transformers Selection of adequate capacity of a transformer and conductors of low voltage lines Re-conducting and increase in the number of lines Load switching optimization Establishment of methodology of cost comparison between loss reduction (kW) and cost of loss reduction Describing process of loss reduction plans <ul style="list-style-type: none"> Utilize the data for making effective loss reduction Establish methodology of economic evaluation for loss reduction projects Seek the candidates of effective loss reduction methodology Identify the validation of the selected loss reduction projects etc. | <p>Process of Loss Reduction Plans</p> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <p>Quick Evaluation for Cost-benefit Analysis</p> <p>A cost saving achieved by loss reduction = benefit by loss reduction</p> <p>Construction cost + labor cost</p> | <p>Loss Reduction Value</p> <p>At peak load 1 kW loss reduction at peak (kW)</p> <p>Yearly Energy loss reduction (kWh/year/kW) or (Php/year/kW)</p> <p>Multiple years Loss Reduction Value (present value) (Php/kW)</p> | <p>An Image of Calculation of Loss Reduction Value (for example, for 10 years)</p> <table border="1"> <thead> <tr> <th>Year</th> <th>Reduced cost loss at peak (kW)</th> <th>Reduced loss load at peak (kW)</th> <th>Real Energy (kWh)</th> <th>Present Worth Factor</th> <th>Present Worth of loss reduction value (Php)</th> </tr> </thead> <tbody> <tr> <td>2011</td> <td>1</td> <td>0.00</td> <td>1.00</td> <td>2.617</td> <td>1,000</td> </tr> <tr> <td>2012</td> <td>2</td> <td>0.00</td> <td>1.00</td> <td>2.395</td> <td>6,917</td> </tr> <tr> <td>2013</td> <td>3</td> <td>0.00</td> <td>1.00</td> <td>2.181</td> <td>13,060</td> </tr> <tr> <td>2014</td> <td>4</td> <td>0.00</td> <td>1.12</td> <td>1.974</td> <td>6,915</td> </tr> <tr> <td>2015</td> <td>5</td> <td>0.00</td> <td>1.27</td> <td>1.784</td> <td>13,060</td> </tr> <tr> <td>2016</td> <td>6</td> <td>0.00</td> <td>1.32</td> <td>1.607</td> <td>13,790</td> </tr> <tr> <td>2017</td> <td>7</td> <td>0.00</td> <td>1.47</td> <td>1.451</td> <td>6,917</td> </tr> <tr> <td>2018</td> <td>8</td> <td>0.00</td> <td>1.62</td> <td>1.308</td> <td>13,060</td> </tr> <tr> <td>2019</td> <td>10</td> <td>0.00</td> <td>1.87</td> <td>1.077</td> <td>6,915</td> </tr> <tr> <td>2020</td> <td>10</td> <td>0.02</td> <td>2.02</td> <td>0.956</td> <td>13,060</td> </tr> <tr> <td>Total loss reduction value (per 10 at peak)</td> <td>-</td> <td>-</td> <td>-</td> <td>-</td> <td>137,292</td> </tr> </tbody> </table> | Year | Reduced cost loss at peak (kW) | Reduced loss load at peak (kW) | Real Energy (kWh) | Present Worth Factor | Present Worth of loss reduction value (Php) | 2011 | 1 | 0.00 | 1.00 | 2.617 | 1,000 | 2012 | 2 | 0.00 | 1.00 | 2.395 | 6,917 | 2013 | 3 | 0.00 | 1.00 | 2.181 | 13,060 | 2014 | 4 | 0.00 | 1.12 | 1.974 | 6,915 | 2015 | 5 | 0.00 | 1.27 | 1.784 | 13,060 | 2016 | 6 | 0.00 | 1.32 | 1.607 | 13,790 | 2017 | 7 | 0.00 | 1.47 | 1.451 | 6,917 | 2018 | 8 | 0.00 | 1.62 | 1.308 | 13,060 | 2019 | 10 | 0.00 | 1.87 | 1.077 | 6,915 | 2020 | 10 | 0.02 | 2.02 | 0.956 | 13,060 | Total loss reduction value (per 10 at peak) | - | - | - | - | 137,292 |
| Year | Reduced cost loss at peak (kW) | Reduced loss load at peak (kW) | Real Energy (kWh) | Present Worth Factor | Present Worth of loss reduction value (Php) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2011 | 1 | 0.00 | 1.00 | 2.617 | 1,000 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2012 | 2 | 0.00 | 1.00 | 2.395 | 6,917 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2013 | 3 | 0.00 | 1.00 | 2.181 | 13,060 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2014 | 4 | 0.00 | 1.12 | 1.974 | 6,915 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2015 | 5 | 0.00 | 1.27 | 1.784 | 13,060 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2016 | 6 | 0.00 | 1.32 | 1.607 | 13,790 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2017 | 7 | 0.00 | 1.47 | 1.451 | 6,917 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2018 | 8 | 0.00 | 1.62 | 1.308 | 13,060 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2019 | 10 | 0.00 | 1.87 | 1.077 | 6,915 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2020 | 10 | 0.02 | 2.02 | 0.956 | 13,060 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Total loss reduction value (per 10 at peak) | - | - | - | - | 137,292 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Example 1: Loss Reduction for LV lines by adding transformers

(Sample: PELCO II, MABALACAT SS, F25212 by Powersolve Data)

Relocation of transformers

(Sample: PELCO II, MABALACAT SS, F25212 by Powersolve Data)

Example 2: Switching optimization for Low Voltage Line

(Sample: PELCO II, MABALACAT SS, F25212 by SynerGEE data tentatively modeled from PowerSolve Data by Study Team)

Loss reduction = 450kW - 442kW = 8kW
 If BW 4 Loss reduction value [per kW at peak] > Construction Cost, its OK.

Example 3: Switching optimization for medium voltage lines by constructing a new line

(Sample: PELCO II, MABALACAT SS, F25212 by SynerGEE data tentatively modeled from PowerSolve Data by Study Team)

Loss reduction = 438kW - 388kW = 55kW
 55kW x Loss reduction value [per kW at peak] > Construction Cost, its OK.

Example 4: Switching optimization for medium voltage lines by constructing a new interconnections and a substation

(Sample: Laos 22 kV system modeled by CYMEE software)

| Case | Power from SPS | MV network losses | Loss ratio |
|--------|----------------|-------------------|------------|
| Before | 74,210.2 kW | 4,943.6 kW | 6.66% |
| After | 72,253.1 kW | 2,977.5 kW | 3.99% |

Next Step

- Starting initial Pilot Project at 3rd site survey
- Analyzing Data (expected done by ECs until next W/S)
 - Operation rate of pole transformers (at peak load time and average)
 - Lengths, sending currents, their using conductors and operation rates of LV lines/MV lines.
- Examining finance applications.

Distribution Management Method in Japan

29/07/2011

Contents

- Current Situation of Japanese Distribution Facilities
 - Segregation of Distribution Loss
 - Measurements of Distribution Loss Reduction
- Design Concept of Distribution Facilities in Japanese
 - Outline of Distribution Line
 - Planning for strengthen of HV Line
 - HV-Line Installation Method
 - LV-Line Installation Method
 - Distribution Facilities Management Method

Result of analysis

1. Current Situation of Japanese Distribution Facilities

1. Current Situation of Japanese Distribution Facilities

○ Distribution Line in Japan (Results in fiscal year 2008)



| Unit | All Japan | Urban Area Ex. Tokyo | Rural Area Ex. Shikoku | Philippines (all NEA area) |
|-----------------------------------|-------------|----------------------|------------------------|----------------------------|
| HV-Line km | 893,541 | 143,119 | 72,226 | 100,000 |
| LV-Line km | 362,913 | 191,293 | 169,261 | 62,412 |
| Transformer unit | 9,816,730 | 7,142,544 | 436,951 | 379,363 |
| Total Capacity of Transformer kVA | 599,444,747 | 73,378,074 | 8,520,074 | 8,963,717 |
| Pole | 20,852,347 | 3,170,733 | 817,221 | 1,314,573 |
| Substation point | 5,099 | 1,412 | 179 | 302 |
| HV-Line per Substation km/point | 135.3 | 101.4 | 183.8 | 211.2 |
| LV-Line per Transformer km/unit | 0.087 | 0.087 | 0.042 | 0.43 |
| TR capacity average kVA/unit | 30.8 | 34.3 | 17.9 | 29.88 |
| Transformer per Pole unit/pole | 0.47 | 0.37 | 0.28 | 0.15 |

* Source: Electric power statistical information by Federation of Electric Power Companies.

○ Comparison of Transmission and Distribution Loss (Results in fiscal year 2008)

| Unit | All Japan | Urban Area Ex. Tokyo | Rural Area Ex. Shikoku | Philippines (all NEA area) |
|--------------------------------------|-----------|----------------------|------------------------|----------------------------|
| Transmission and Distribution Loss % | 5.1 | 4.9 | 6.1 | 10.27 |
| (Transmission Loss) % | 2.3 | 2.8 | 2.4 | 3.1 |
| (Distribution Loss) % | 2.8 | 2.0 | 4.8 | 7.2 |

○ Transmission and Distribution Loss = (electric energy of Transmission end - net system energy demand - electric energy in Substation (loss)) / (electric energy of Transmission end)



(1) Segregation of Distribution Loss

○ Segregate distribution loss in three parts as follows

- High Voltage Line Loss
- Transformer Loss
- Low Voltage Line Loss

HV-Line Loss is the largest part and second is Transformer Loss.

(2) Measurements of Distribution Loss Reduction

| Items | Concrete Measurements | No. |
|-------------------------------|--|-----|
| Reduce load current | • Develop new substation | ① |
| | • Develop new distribution feeder | |
| | • Load allocation | |
| Reduce wire resistance | • Improving unbalanced current | ② |
| | • Improving Power Factor | |
| Reduce transformer resistance | • High Voltage line conductor size upgrade | ④ |
| | • Shortening Low Voltage line (Split load of one Transformer) | |
| Reduce transformer resistance | • Transformer replacement to low loss type (For example: Introduce Amorphous core transformer) | ⑥ |
| | | |

(2) Measurements of Distribution Loss Reduction

① New Substation development or New Feeder installation

Basic case: Line A, Loss₀ = 3r/1

Case ①: Loss₁ = (3r/2) + (1/2) = 3r/2 + 1/2

(Case 1 - Basic) / Basic * 100 = ▲ 75%

Case ②: Loss₂ = 3r + (1/2) = 3r + 1/2

(Case 2 - Basic) / Basic * 100 = ▲ 63%

- Decrease High Voltage line loss in order to
 - New Substation building (SS)
 - New Feeder building (Line B)

(2) Measurements of Distribution Loss Reduction

② Improve unbalance current

Basic case: Loss₀ = r * (0.91)^2 + r * (1.1)^2 = 3.0r/11

Case ①: Loss₁ = 3.0r/11

(Case 1 - Basic) / Basic * 100 = ▲ 0.2%

- Improve unbalance of High Voltage current among three phases. (Example)
- It is effective to conduct this measurements especially for long single phase line. After this measurements of each phase current, power company should change the phase connection on HV line and allocate the load in appropriate manner.

(2) Measurements of Distribution Loss Reduction

③ Phase change to improve balanced current

When power company find the unbalance, they change the connection.

In usual HV installation, the single phase connection are ruled as follows.

- Beginning (1-10) of month
- Middle (11-20) of month
- End (21-31) of month

(2) Measurements of Distribution Loss Reduction

(4) Benefits for Improving Power Factor

Basic case: $P = E \cdot I \cdot \cos \theta_1$
 Case ①: $P = E \cdot I_1 \cdot \cos \theta_1$
 Case ②: $P = E \cdot I_2 \cdot \cos \theta_2$

Legend: [R] = Wire resistance, [Tr] = Transformer, [I] = Feeder current, [SS] = Substation, [M] = Demand

Comparison Power is G (Var) $= P \cdot (\tan \theta_1 - \tan \theta_2)$

(Case 1 - Basic) / Basic * 100 = $(\cos \theta_2 / \cos \theta_1) - 1$ * 100%

• Reduce reactive power to improve Power Factor.

(2) Measurements of Distribution Loss Reduction

(4) Benefits for Improving Power Factor

Case study: Improving Power Factor from 0.85 to 0.90

Basic case: $P = E \cdot I_1 \cdot \cos \theta_1$
 Case ①: $P = E \cdot I_2 \cdot \cos \theta_2$

Ex.) Improving Power Factor from 0.85 to 0.90
Expected Loss Reduction = $(0.85)^2 / (0.90)^2 - 1 \times 100 = \mathbf{\Delta 10.8\%}$

(2) Measurements of Distribution Loss Reduction

(5) High-Voltage Line size up

Line A (resistance is R) $Loss = R \cdot I^2$
 Line A (resistance is R') $Loss = R' \cdot I^2$

Legend: [R] = Wire resistance, [Tr] = Transformer, [I] = Feeder current, [SS] = Substation

(Case 1 - Basic) / Basic * 100 = $(R - R') / R \times 100\%$

• Size up of High-Voltage line result to reduce line resistance.

(2) Measurements of Distribution Loss Reduction

(5) High-Voltage line size up

Case study: Change line from OC-AL120 to OC-Cu150

Line A (resistance is R) $Loss = R \cdot I^2$
 Line A (resistance is R') $Loss = R' \cdot I^2$

Ex.) Change line from OC-AL120 to OC-Cu150

| Line type | Equivalent resistant (PF 0.95) | Permissible current |
|-----------------------|--------------------------------|---------------------|
| AL-120mm ² | 0.3546 [R.km] | 310 [A] |
| Cu-150mm ² | 0.2385 [R.km] | 510 [A] |

Expected Loss Reduction = $(0.2283 - 0.3546) / 0.3546 \times 100 = \mathbf{\Delta 35.6\%}$

(2) Measurements of Distribution Loss Reduction

(6) Shorten low Voltage line (Split load to Transformer)

Basic case: $Loss_{total} = R_L \cdot I^2 + R_T \cdot I^2$
 Case ①: $Loss_{total} = R_L \cdot I_1^2 + R_L \cdot I_2^2 + R_T \cdot I_1^2 + R_T \cdot I_2^2$

Legend: [R] = LV wire resistance, [Tr] = Transformer, [I] = LV current, [SS] = Substation

Case ① - Basic = $R_L (I_1^2 + I_2^2) + R_T (I_1^2 + I_2^2)$
< If $R_L = R_T = R_0$ case >
(Case ① - Basic) / Basic * 100 = $(I_1^2 + I_2^2) / (I^2) \times 100\%$

• Split load to Transformer result to reduce LV-line current

(2) Measurements of Distribution Loss Reduction

(6) Shorten low-Voltage line (Split load to Transformer)

Case study: Ratio loss is when demand is 5A per one customer

Basic case: $Loss_{total} = R_L \cdot I^2 + R_T \cdot I^2$
 Case ①: $Loss_{total} = R_L \cdot I_1^2 + R_L \cdot I_2^2 + R_T \cdot I_1^2 + R_T \cdot I_2^2$

Ex.) If demand is 5A per one customer, expected loss reduction is...

Expected Loss Reduction
Case ① - Basic = $R_L (I_1^2 + I_2^2) + R_T (I_1^2 + I_2^2)$
< If $R_L = R_T = R_0$ case >
(Case ① - Basic) / Basic * 100 = $(5^2 + 10^2) / (15^2) \times 100 = \mathbf{\Delta 61.5\%}$

(2) Measurements of Distribution Loss Reduction

(7) Transformer replacement to reduce no load loss

○ Tech advance of pole-transformer (Ex. Pole transformer 20kVA)

Old type (1982) 100%
 SIF (1982-1999) 77%
 SIF (2000-2009) 58%
 Amorphous 23%

Replacement to new TRs when they become old

• When pole transformer will replace because of its aged, TR's load loss can be decreased by adopting no load loss type transformer.

(2) Measurements of Distribution Loss Reduction

(7) Transformer replacement to reduce no load loss

(Supplement 1: The rule of Transformer replacement)

- The standard of Transformer replacement according to rusting steel
- Rank 1: The rust color is Reddish-brown in part of surface.
- Rank 2: The rust color is Reddish-brown on a consecutive and it seem a painting has come off in places.
- Rank 3: The rust color is Black brown and the base is exposed metal part.

(Supplement 2: The remove idle TR's (No customer connections 1))

- The idle transformers are managed in the system, and when no connection continues for three years, it shall be removed

(2) Measurements of Distribution Loss Reduction

○ Decrease measures of Loss for peak cut of demand

Peak current is decreased by peak cut of demand
 Because Distribution Loss influenced by the square of current value.
 ($Loss = R \cdot I^2$)

○ Decrease measures of Loss for peak cut of demand in Japanese Electric Power company.

- Night-time power price is more cheap than day time power price. (The power contract is prepared diversified)
- Recommending the electronic equipment that used at night-time power (Electric water heater, Timer-control laundry machine, Thermal storage heater etc.)

2. Design Concept of Distribution Facilities in Japanese

2. Design Concept of Distribution Facilities in Japanese

○ Institutional manuals of Power company (Ex. Shikoku Electric Power)

| Basic policy (a) | Manual (b) | Guideline (c) |
|---------------------------------------|---|-------------------------------------|
| Concept for Distribution construction | Series of Distribution task Manual for Distribution facilities Manual for Distribution planning Manual for Distribution construction | Guideline for Distribution planning |

(a) Basic policy is the general method of distribution construction.
 (b) Manual is determined to show the detail rule (Example: Safety, Economy, Electric supply reliability).
 (c) Guideline describe interpretation and special instruction (Example: Planning point, caution and requirement for the work).

- All the measurements of distribution construction or maintenance is described in these Basic policy, Manual and Guideline.
- Distribution design for connection and criteria of the equipments shall conduct according to these rules.

(1) Outline of Distribution Line

○ Japanese distribution feeders are connected each other as loop or mesh system. And distribution line is divided by automatic switch on the poles.

- Feeder is divided into sections by automatic switches, and each section can be energized by another feeders.
- So that section can supply power in case of power interruption.

○ Distribution Automation Systems (D A S)

• Dispatcher can monitor I & V in each SW in the feeder and manipulate (ON / OFF) SW from control center

(2) Planning for strengthening of HV Line

OHV Line

Index for HV Line management

- Substation load factor [%]
- Allowable feeder current [A]
- HV Customer demand [A]
- Conductor type and its capacity [A]

○ Strengthening of HV-Line

- 1) Feeder section switching (load allocation to other section) - low cost
- 2) Conductor size upgrade
- 3) New Feeder installation - high cost
- 4) New Substation development

○ Measurements of planning for strengthening of HV-line shall consider both

- Cost and merit
- Future demand forecast

At the result of consideration, the most appropriate measurement shall be adopted.

(2) Planning for strengthening of LV Line

○ LV Line

Index for LV-Line management

- Pole Transformer load factor [%]
- Allowable current of service wire [A]
- LV-customer demand [A]
- Conductor type and its capacity [A]

○ Strengthening of LV-Line

- 1) LV-Line size upgrade - low cost
- 2) Pole Transformer size up
- 3) New Transformer installation (load allocation to other TR) - high cost

○ Measurements of planning for strengthening LV-line shall consider these elements.

(a) Base load current: $I = 0.2 \times (X)^{0.782}$ [A]

(b) LV-wire size selection - Consider in 10 years

(c) Transformer size selection - Consider in 16 years

(3) HV-Line Installation Method

○ Case ① : 60A new connection

Bank capacity : 20MVA
 Load factor : 90% → 95%

○ Planning Method

| Demand Forecast | Allowance General? | NO | Planning measures | Improvement work |
|-------------------|------------------------|--------------------------|----------------------|-------------------|
| Planning contents | Substation load factor | Feeder section switching | Feeder current limit | Wire size upgrade |
| | Feeder current limit | Feeder section switching | Feeder current limit | Wire size upgrade |
| | Voltage Drop limit | Feeder section switching | Feeder current limit | Wire size upgrade |

Choose the most economical method
 Considering futura demand

(3) HV-Line Installation Method

○ Case ① : 60A new connection

Bank capacity : 20MVA
 Load factor : 90% → 95%

○ Planning Method

| Demand Forecast | Allowance General? | NO | Planning measures | Improvement work |
|-------------------|------------------------|--------------------------|----------------------|-------------------|
| Planning contents | Substation load factor | Feeder section switching | Feeder current limit | Wire size upgrade |
| | Feeder current limit | Feeder section switching | Feeder current limit | Wire size upgrade |
| | Voltage Drop limit | Feeder section switching | Feeder current limit | Wire size upgrade |

Choose the most economical method
 SW load current
 SW closed
 SW opened

(4) LV-Line Installation Method

Ex.) Planning for LV-new customer

Bank capacity : 20MVA
 Load factor : 90% → 95%

○ Planning Method

| Demand Forecast | Allowance General? | NO | Planning measures | Improvement work |
|-------------------|-------------------------|-------------------|---------------------|---------------------|
| Planning contents | Transformer load factor | Wire size upgrade | Transformer size up | Transformer size up |
| | LV wire current limit | Wire size upgrade | Transformer size up | Transformer size up |
| | Voltage Drop limit | Wire size upgrade | Transformer size up | Transformer size up |

Choose the most economical method
 Install other transformer to supply to new customer

Power Distribution Geographical Information System

(Characteristic)

- When operator click the symbol on the screen, Distribution facilities information can be shown
- It is possible to check a pole picture, a date of manufacture, etc.

(Expected Effect for Distribution work)

- No need to visit site (get information without site visit)
- No need to design the installation drawing (easy design and modified by GIS system)
- Efficient management (easy ordering work , approving work by online)

(5) Distribution facilities management method

○ Facilities data base (Outline)

① Check ② Planning ③ Work site ④ Update ⑤ Update ⑥ Update

- Check a Distribution facilities.
- Input planning date on DB
- Ordering work and Working site
- After completion of work, update planning date on DB
- Update distribution facilities DB
- Update latest GIS date & DAS system

(5) Distribution facilities management method

○ Distribution facilities data base network (Outline)

Group Companies NW Share information

(5) Distribution facilities management method

○ Distribution facilities data base item (excerpts)

| Item | Detail of Item |
|--------------|---|
| Pole | owner, material, length, year of manufacture and construction, result of inspection |
| HV-wire | type, distance, year of manufacture and construction, result of inspection |
| LV-wire | type, distance, year of manufacture and construction, result of inspection |
| Service wire | type, distance, year of manufacture and construction, enclosed fuse information, result of inspection |
| Transformer | capacity, type, year of manufacture and construction, application, connecting phase, result of inspection |
| Switch | capacity, type, switch position, year of manufacture and construction, result of inspection |
| Arrestor | connecting phase, year of manufacture and construction, result of inspection |
| Booster | capacity, year of manufacture and construction, operation time, result of inspection, repair history |
| Earthing | operate of determination, result of inspection |

Preliminary Result of analysis

| No. | Concrete measures | Effectiveness | Potential | Easiness (incl. cost) |
|-----|---|---------------|-----------|-----------------------|
| ① | Load allocation (New Feeder construction, etc.) | ◎ | ○ | △ |
| ② | Improve unbalanced current | △ | △ | △ |
| ③ | Improving Power Factor | ○ | △ | ○ |
| ④ | HV line size upgrade | ◎ | ○ | ○ |
| ⑤ | Shorten LV line (Split load to another transformer) | ○ | ○ | ○ |
| ⑥ | Introduction Low load Transformer | ◎ | ○ | ○ |

Thank you for your kind attention

Japanese Experience on Upgrading Distribution Voltage in 1960s

Toshiya MINEJIMA / TEPCO

29 July, 2011

Today's Agenda

Upgrading System Voltage brings plenty of advantages

- Loss Reduction
- Voltage Management
- Enhancement of Supplying Power
- Others

Experience of Japanese Power Utilities would be introduced and shared

10 Utility Companies in Japan

TEPCO's Service Area


| | TEPCO | All Japan | TEPCO's share |
|-------------|--------|-----------|---------------|
| Peak Demand | 84.3GW | 182.4GW | 35% |
| Sales | 289TWh | 889TWh | 33% |

TEPCO's Distribution Network [OH]

TEPCO's Distribution Network [UG]

Assets for TEPCO's Distribution Network

| Facilities | Numbers/Length |
|---------------|----------------|
| Utility Poles | 6 MIL. |
| DTs | 2 MIL. |
| LBS | 0.5 MIL. |
| Wires | 1 MIL. km |
| Service Lines | 20 MIL. |



Our Features

- High Reliability**
SAIDI=2minutes/customer/year
SAIFI=0.05times/customer/year
- Low Network Losses**
less than 5% : T&D
as low as 2.2% : Distribution Sector
- Efficient Workforce Management**


TEPCO's Distribution Network Losses

Loss Estimation from Distribution System about 6TWh (loss rate 2.2%)

MV Network of Japanese Utilities

After 2nd World War
Destroyed facilities were rehabilitated with **3kV system voltage** as before

Japanese Post-war Economic Miracle (early 1950s - 1973)
GDP had grown up so fast
Furthermore the demand for electricity incredible fast



| | | |
|--|--|--|
| <p>Needs for Upgrading System Voltage</p> <ul style="list-style-type: none"> 3kV was poor for MV system voltage - Congested Feeders - High Costs due to many feeding cables - Losses from low system voltage - Poor Voltage Management <p style="text-align: center;">↓</p> <p>Upgrading MV system voltage (3kV to 6kV) had been planned</p> <p style="text-align: right;"><small>©2011 The Tokyo Electric Power Company, Inc. All Rights Reserved. 12</small></p> | <p>Roles of Each Sector</p> <div style="text-align: center;"> <p>Regulator (MITI) Establish rules and regulations on upgrading business (1959)</p> <p>↓</p> <div style="display: flex; justify-content: space-around;"> <div style="border: 1px solid black; padding: 5px; text-align: center;"> <p>Utilities Plan and conduct upgrading voltage</p> </div> <div style="border: 1px solid black; padding: 5px; text-align: center;"> <p>MV Customers Cooperate for utilities in outage when upgrade</p> </div> </div> </div> <p style="text-align: right;"><small>©2011 The Tokyo Electric Power Company, Inc. All Rights Reserved. 13</small></p> | <p>Rules for Upgrading Biz</p> <ul style="list-style-type: none"> Upgrade the whole 3kV Network to 6kV within 15years <p style="text-align: center;"><i>(TEPCO's distribution feeders : 5,020 peak demand : 4.8GW) as of when upgrading started</i></p> <p style="text-align: right;"><small>©2011 The Tokyo Electric Power Company, Inc. All Rights Reserved. 14</small></p> |
| <p>Rules for Upgrading Biz</p> <ul style="list-style-type: none"> Upgrade the whole 3kV Network to 6kV within 15years Electric Switchboard Equipments <Cubicles> of MV Customers should be modified or renewed by Utilities' payment <p style="text-align: right;"><small>©2011 The Tokyo Electric Power Company, Inc. All Rights Reserved. 15</small></p> | <p>Chronology of TEPCO's Activities</p> <ul style="list-style-type: none"> 1957 Pre-Upgrading 1959 Main Upgrading Business Start 1973 Almost Finished 1981 Wholly Finished <p style="text-align: right;"><small>©2011 The Tokyo Electric Power Company, Inc. All Rights Reserved. 16</small></p> | <p>Concept of Upgrading System Voltage</p> <p style="background-color: #e0ffe0; padding: 5px; text-align: center;">Electricity is essential to daily life of people and economical activities of modernized society</p> <ul style="list-style-type: none"> Outage time needed for upgrading should be minimized <p style="text-align: center;">↓</p> <p style="background-color: #fff9c4; padding: 5px;">Distribution facilities were upgraded to 6kV-class in advance - LBS, Cables, Insulators et al Distribution Transformers were replaced by 3kV/6kV Dual Primary Voltage DTs</p> <p style="text-align: right;"><small>©2011 The Tokyo Electric Power Company, Inc. All Rights Reserved. 17</small></p> |
| <p>Upgrading Procedure</p> <p style="text-align: right;"><small>©2011 The Tokyo Electric Power Company, Inc. All Rights Reserved. 18</small></p> | <p>1st : Replacement of DTs & CUBs</p> <p style="text-align: right;"><small>©2011 The Tokyo Electric Power Company, Inc. All Rights Reserved. 19</small></p> | <p>2nd : Replacement of Equipments</p> <p style="text-align: right;"><small>©2011 The Tokyo Electric Power Company, Inc. All Rights Reserved. 20</small></p> |
| <p>3rd : Installation of 6kV Feeding Cables</p> <p style="text-align: right;"><small>©2011 The Tokyo Electric Power Company, Inc. All Rights Reserved. 21</small></p> | <p>4th : Upgrading Work in Outage</p> <p style="text-align: right;"><small>©2011 The Tokyo Electric Power Company, Inc. All Rights Reserved. 22</small></p> | <p>5th : Energizing Network by 6kV</p> <p style="text-align: right;"><small>©2011 The Tokyo Electric Power Company, Inc. All Rights Reserved. 23</small></p> |
| <p>6th : Removal of 3kV Cables</p> <p style="text-align: right;"><small>©2011 The Tokyo Electric Power Company, Inc. All Rights Reserved. 24</small></p> | <p>Upgraded Distribution System</p> <p style="text-align: right;"><small>©2011 The Tokyo Electric Power Company, Inc. All Rights Reserved. 25</small></p> | <p>Effects of Upgrading System Voltage</p> <ul style="list-style-type: none"> Supplying Power enough System Loss Rate down Voltage Management improved <p style="text-align: right;"><small>©2011 The Tokyo Electric Power Company, Inc. All Rights Reserved. 26</small></p> |
| <p>Effect for Supplying Power</p> <ul style="list-style-type: none"> Supplying Power enough to meet increasing demand <p style="text-align: center;"><i>Peak Demand from 4.8GW to 15.7GW while Feeders from 5,020 to 8,042ctt</i></p> <p style="text-align: right;"><small>©2011 The Tokyo Electric Power Company, Inc. All Rights Reserved. 27</small></p> | <p>Effect for Loss Reduction</p> <ul style="list-style-type: none"> System Loss Rate down <p style="text-align: center;"><i>Rate of Distribution Sector 8% or higher</i></p> <p style="text-align: center;">↓</p> <p style="text-align: center;"><i>Half Reduction to 4%</i></p> <p style="text-align: right;"><small>©2011 The Tokyo Electric Power Company, Inc. All Rights Reserved. 28</small></p> | <p>Effect for Voltage Management</p> <p style="text-align: center;">Average Voltage of 100V LV Network</p> <p style="text-align: center;"><i>Before Upgrading 88V at evening peak</i></p> <p style="text-align: center;">↓</p> <p style="text-align: center;"><i>After Upgrading improved nearly 10%</i></p> <p style="text-align: right;"><small>©2011 The Tokyo Electric Power Company, Inc. All Rights Reserved. 29</small></p> |

Summary of TEPCO's Experience

We could meet the rising demand by upgraded network successfully, while loss rate was half reduced to 4%, voltage drop had been improved.

Main Points for Upgrading Business

- **Decision on Proper System Voltage**
Upgrading to 23kV / 34.5kV
Considering Benefit & Additional Cost

Salamat !!

Presentation Materials of 2nd Workshop

| <h2>Progress & Activities Outline of Contents of System Loss Reduction Manual</h2> <p>The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's)</p> <p>M. Yogo JICA TA Team/TEPCO Manila 8-9 Feb. 2012</p> | <h3>Current Activities of ECs</h3> <table border="1"> <tr> <td>Line Loss Reduction</td> <td>Consolidation of 25 KV system, Upgrading of primary/secondary lines, Power factor improvement, Rehabilitation of pole transformers</td> </tr> <tr> <td>Transformer Loss Reduction</td> <td>Replacement/upgrading of pole transformers</td> </tr> <tr> <td>Facility Maintenance</td> <td>Thermal scanning, Comparison connection, Rehigh-voltage bushing, Replacement of transformer coil, Replacement of defective street lights, Right of way clearing</td> </tr> <tr> <td>Meters</td> <td>Tuning of measurement meters, Replacement of defective or broken meters, Switch from electro-mechanical to electronic 50% meter, Meter reading training, Regular assessment of meter reader</td> </tr> <tr> <td>Against Pilferage</td> <td>Upgrading unskilled customers and incorrect reading and billing, Pole 50W meters, clamping, Installation of meter feeder warning</td> </tr> <tr> <td>Distributed Facility Management</td> <td>Area Engineering concept, Facility maintenance using database, Load management of pole transformers, Overloaded/under loaded transformers, Balance three currents from transformers, Precise detail of pole transformers</td> </tr> <tr> <td>Training</td> <td>Personal training, Strict use of right materials, etc.</td> </tr> </table> | Line Loss Reduction | Consolidation of 25 KV system, Upgrading of primary/secondary lines, Power factor improvement, Rehabilitation of pole transformers | Transformer Loss Reduction | Replacement/upgrading of pole transformers | Facility Maintenance | Thermal scanning, Comparison connection, Rehigh-voltage bushing, Replacement of transformer coil, Replacement of defective street lights, Right of way clearing | Meters | Tuning of measurement meters, Replacement of defective or broken meters, Switch from electro-mechanical to electronic 50% meter, Meter reading training, Regular assessment of meter reader | Against Pilferage | Upgrading unskilled customers and incorrect reading and billing, Pole 50W meters, clamping, Installation of meter feeder warning | Distributed Facility Management | Area Engineering concept, Facility maintenance using database, Load management of pole transformers, Overloaded/under loaded transformers, Balance three currents from transformers, Precise detail of pole transformers | Training | Personal training, Strict use of right materials, etc. | <h2>Technical Situations</h2> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|--|--|--|--|----------------------------|--|----------------------|---|-------------------------|---|---|--|---------------------------------|--|----------|--|-------------------------------|----------|-------|-------|---------|-------|--|-------|------|------|--|----------|------|------|-------|--|----------|-------|------|-------|--|-----|----|------|----------|-------|-----|------|--|----------|-------|------|-------|--|----------|-------|------|-------|--|---------|---|------|----------|-------|------|-------|--|-----------|------|------|--------|--|---------|----|------|-----------|------|---|-------|--|--|---------|---------|----------------|--------|-------|--------|---------|---------|---------|---|------------|-------|-------|-----------------|--|-----------|---------------|-----------------------------------|----|--------|--------|-----|---------------------------------------|----|-------|-------|-----|-------------------------------------|----|--------|--------|-------|--|----|--|--|-----|
| Line Loss Reduction | Consolidation of 25 KV system, Upgrading of primary/secondary lines, Power factor improvement, Rehabilitation of pole transformers | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Transformer Loss Reduction | Replacement/upgrading of pole transformers | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Facility Maintenance | Thermal scanning, Comparison connection, Rehigh-voltage bushing, Replacement of transformer coil, Replacement of defective street lights, Right of way clearing | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Meters | Tuning of measurement meters, Replacement of defective or broken meters, Switch from electro-mechanical to electronic 50% meter, Meter reading training, Regular assessment of meter reader | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Against Pilferage | Upgrading unskilled customers and incorrect reading and billing, Pole 50W meters, clamping, Installation of meter feeder warning | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Distributed Facility Management | Area Engineering concept, Facility maintenance using database, Load management of pole transformers, Overloaded/under loaded transformers, Balance three currents from transformers, Precise detail of pole transformers | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Training | Personal training, Strict use of right materials, etc. | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <h3>CASURECO II</h3> <p>Profile of the 10 Feeders of CASURECO II</p> <table border="1"> <thead> <tr> <th>Substation</th> <th>Capacity (MVA)</th> <th>Peak Load (MVA)</th> <th>Feeder</th> <th>Length (km)</th> <th>3-Phase Loss (%)</th> <th>1-Phase Loss (%)</th> <th>Open Secondary Loss (%)</th> </tr> </thead> <tbody> <tr> <td rowspan="5">Mega</td> <td rowspan="5">40</td> <td rowspan="5">14.5</td> <td>Feeder 1</td> <td>9.28</td> <td>1.5</td> <td>15.1</td> <td></td> </tr> <tr> <td>Feeder 2</td> <td>7.5</td> <td>0.08</td> <td>2.03</td> <td></td> </tr> <tr> <td>Feeder 3</td> <td>11.31</td> <td>3.04</td> <td>5.02</td> <td></td> </tr> <tr> <td>Feeder 4</td> <td>11.9</td> <td>3.06</td> <td>10.28</td> <td></td> </tr> <tr> <td>Feeder 5</td> <td>13.85</td> <td>4.02</td> <td>13.37</td> <td></td> </tr> <tr> <td rowspan="3">PIL</td> <td rowspan="3">30</td> <td rowspan="3">7.62</td> <td>Feeder 6</td> <td>34.92</td> <td>8.2</td> <td>18.4</td> <td></td> </tr> <tr> <td>Feeder 7</td> <td>16.36</td> <td>1.54</td> <td>44.81</td> <td></td> </tr> <tr> <td>Feeder 8</td> <td>17.80</td> <td>0.38</td> <td>45.01</td> <td></td> </tr> <tr> <td rowspan="2">Caldent</td> <td rowspan="2">5</td> <td rowspan="2">1.47</td> <td>Feeder 9</td> <td>10.11</td> <td>8.15</td> <td>65.24</td> <td></td> </tr> <tr> <td>Feeder 10</td> <td>1.18</td> <td>0.48</td> <td>184.32</td> <td></td> </tr> <tr> <td>Stankon</td> <td>30</td> <td>1.45</td> <td>Feeder 11</td> <td>12.1</td> <td>0</td> <td>11.14</td> <td></td> </tr> </tbody> </table> <p>System Loss: 16.18% (2010) Target of Transformer Operating Ratio: (80%)</p> | Substation | Capacity (MVA) | Peak Load (MVA) | Feeder | Length (km) | 3-Phase Loss (%) | 1-Phase Loss (%) | Open Secondary Loss (%) | Mega | 40 | 14.5 | Feeder 1 | 9.28 | 1.5 | 15.1 | | Feeder 2 | 7.5 | 0.08 | 2.03 | | Feeder 3 | 11.31 | 3.04 | 5.02 | | Feeder 4 | 11.9 | 3.06 | 10.28 | | Feeder 5 | 13.85 | 4.02 | 13.37 | | PIL | 30 | 7.62 | Feeder 6 | 34.92 | 8.2 | 18.4 | | Feeder 7 | 16.36 | 1.54 | 44.81 | | Feeder 8 | 17.80 | 0.38 | 45.01 | | Caldent | 5 | 1.47 | Feeder 9 | 10.11 | 8.15 | 65.24 | | Feeder 10 | 1.18 | 0.48 | 184.32 | | Stankon | 30 | 1.45 | Feeder 11 | 12.1 | 0 | 11.14 | | <h3>CASURECO II SYSTEM MAP</h3> <p>System Loss: 16.47% (2010)</p> <p>A feeder with large length (97km) Plan of installation of 69kV with 47.94km</p> <table border="1"> <thead> <tr> <th>3-Phase</th> <th>1-Phase</th> <th>Open Secondary</th> </tr> </thead> <tbody> <tr> <td>160.15</td> <td>70.47</td> <td>109.48</td> </tr> <tr> <td>201.248</td> <td>201.248</td> <td>201.248</td> </tr> </tbody> </table> <p>Source: Presentation on CAMARINES SUR TV ELECTRIC COOPERATIVE INC</p> | 3-Phase | 1-Phase | Open Secondary | 160.15 | 70.47 | 109.48 | 201.248 | 201.248 | 201.248 | <h3>SORECO I</h3> <table border="1"> <thead> <tr> <th rowspan="2">Substation</th> <th rowspan="2">Input</th> <th rowspan="2">Sales</th> <th colspan="2">Calculated Loss</th> </tr> <tr> <th>Technical</th> <th>Non-Technical</th> </tr> </thead> <tbody> <tr> <td>Sta. Terevita (T1) 69 kV Metering</td> <td>PI</td> <td>16,417</td> <td>15,844</td> <td>574</td> </tr> <tr> <td>Sta. Terevita (T1) (13.2 kV Metering)</td> <td>PI</td> <td>7,822</td> <td>7,682</td> <td>395</td> </tr> <tr> <td>Quang-gwang (Mobile) 69 kV Metering</td> <td>PI</td> <td>11,548</td> <td>10,223</td> <td>1,309</td> </tr> <tr> <td></td> <td>PI</td> <td></td> <td></td> <td>228</td> </tr> </tbody> </table> <p>Source: Data from SORECO I</p> <p>Loss: 12.92% Technical: 8.57% Non-technical: 4.35%</p> | Substation | Input | Sales | Calculated Loss | | Technical | Non-Technical | Sta. Terevita (T1) 69 kV Metering | PI | 16,417 | 15,844 | 574 | Sta. Terevita (T1) (13.2 kV Metering) | PI | 7,822 | 7,682 | 395 | Quang-gwang (Mobile) 69 kV Metering | PI | 11,548 | 10,223 | 1,309 | | PI | | | 228 |
| Substation | Capacity (MVA) | Peak Load (MVA) | Feeder | Length (km) | 3-Phase Loss (%) | 1-Phase Loss (%) | Open Secondary Loss (%) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Mega | 40 | 14.5 | Feeder 1 | 9.28 | 1.5 | 15.1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | Feeder 2 | 7.5 | 0.08 | 2.03 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | Feeder 3 | 11.31 | 3.04 | 5.02 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | Feeder 4 | 11.9 | 3.06 | 10.28 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | Feeder 5 | 13.85 | 4.02 | 13.37 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| PIL | 30 | 7.62 | Feeder 6 | 34.92 | 8.2 | 18.4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | Feeder 7 | 16.36 | 1.54 | 44.81 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | Feeder 8 | 17.80 | 0.38 | 45.01 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Caldent | 5 | 1.47 | Feeder 9 | 10.11 | 8.15 | 65.24 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | Feeder 10 | 1.18 | 0.48 | 184.32 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Stankon | 30 | 1.45 | Feeder 11 | 12.1 | 0 | 11.14 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3-Phase | 1-Phase | Open Secondary | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 160.15 | 70.47 | 109.48 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 201.248 | 201.248 | 201.248 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Substation | Input | Sales | Calculated Loss | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | | | Technical | Non-Technical | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Sta. Terevita (T1) 69 kV Metering | PI | 16,417 | 15,844 | 574 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Sta. Terevita (T1) (13.2 kV Metering) | PI | 7,822 | 7,682 | 395 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Quang-gwang (Mobile) 69 kV Metering | PI | 11,548 | 10,223 | 1,309 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | PI | | | 228 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <h3>PELCO II</h3> <p>Many low operation level transformers and several high operation level transformers.</p> <p>System loss: 13.85% Primary: 3.22% Copper loss: 0.33% Core Loss: 1.27% Secondary: 0.81% Capacitor: 0.014% Service Wire: 0.056% Substation: 0.94%</p> | <h3>FLECO</h3> <table border="1"> <thead> <tr> <th>Substation</th> <th>MVA</th> <th>Peak Capacity</th> <th>% Loading</th> </tr> </thead> <tbody> <tr> <td>IM-05 No. 1</td> <td>2 MVA</td> <td>0.919 W</td> <td>45.9%</td> </tr> <tr> <td>IM-05 No. 2</td> <td>3 MVA</td> <td>1.964 W</td> <td>65.5%</td> </tr> <tr> <td>PAJIC</td> <td>3 MVA</td> <td>2.004 W</td> <td>66.8%</td> </tr> <tr> <td>FAJAY</td> <td>6 MVA</td> <td>4.342 W</td> <td>72.4%</td> </tr> </tbody> </table> <p>System Loss: 14.76%</p> <p>Source: Data from FLECO</p> | Substation | MVA | Peak Capacity | % Loading | IM-05 No. 1 | 2 MVA | 0.919 W | 45.9% | IM-05 No. 2 | 3 MVA | 1.964 W | 65.5% | PAJIC | 3 MVA | 2.004 W | 66.8% | FAJAY | 6 MVA | 4.342 W | 72.4% | <h3>System MAP</h3> <p>Total no. of customers served = 141,401</p> <p>Source: Presentation by ISELCO I</p> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Substation | MVA | Peak Capacity | % Loading | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| IM-05 No. 1 | 2 MVA | 0.919 W | 45.9% | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| IM-05 No. 2 | 3 MVA | 1.964 W | 65.5% | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| PAJIC | 3 MVA | 2.004 W | 66.8% | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| FAJAY | 6 MVA | 4.342 W | 72.4% | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <h3>LEVECO III</h3> <p>Source: Data from LEVECO III</p> | <h2>Purposes of Establishing System Loss Reduction Manual</h2> <ul style="list-style-type: none"> To identify appropriate locations for technical loss reduction To make quick and rational judgments To transfer the knowledge about loss reduction to EC's staff <p>With using software</p> | <h2>Draft Contents of Manual</h2> <ol style="list-style-type: none"> Introduction Economic Values of Technical Loss Reduction Methodology of O&M for Data Arrangement of Loss Analysis Identifying Countermeasures against Technical Losses for Low Voltage System Identifying Countermeasures against Technical Losses for Medium Voltage System Installation of Substations / Upgrading Voltage of Medium Voltage System Non-technical Loss Reduction | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <ol style="list-style-type: none"> Introduction <ol style="list-style-type: none"> Purpose of this manual Types of distribution losses and their countermeasures Planning procedures of technical loss reduction Appropriate methods to manual prevailing Economic Values of Technical Loss Reduction <ol style="list-style-type: none"> Methodology of calculating loss reduction values Costs of countermeasures Methodology of O&M for Data Arrangement of Loss Analysis <ol style="list-style-type: none"> Technical data Load data <p>Clamp on Meter SynerGEE Software</p> | <ol style="list-style-type: none"> Identifying Countermeasures against Technical Losses for Low Voltage system <ol style="list-style-type: none"> Methodology of calculation of operating status of low voltage system <ol style="list-style-type: none"> Methodology of calculation of loads of transformers Methodology of calculation of operating status of low voltage lines Methodology of listing up transformers categorized by their capacities Options of countermeasures against technical losses caused in low voltage system Criteria for taking countermeasures <table border="1"> <tr> <td>4.3.1</td> <td>Refring / relocation of pole transformers</td> </tr> <tr> <td>4.3.2</td> <td>Dividing system by installation of pole transformers</td> </tr> <tr> <td>4.3.3</td> <td>Adding or replacing low voltage feeders</td> </tr> <tr> <td>4.3.4</td> <td>Capacitor placement</td> </tr> </table> Appropriate capacities of pole transformers and sizes of conductors Installation of amorphous using transformers | 4.3.1 | Refring / relocation of pole transformers | 4.3.2 | Dividing system by installation of pole transformers | 4.3.3 | Adding or replacing low voltage feeders | 4.3.4 | Capacitor placement | <h3>4.3.1 Replacing/relocation of pole transformers (Example of Image)</h3> <p>Number of transformers by each operating rate during peak load period</p> <p>Low operating rate (Low Loss) High operating rate (High Loss)</p> <p>None transformer is moved from existing low operating rate to install in on LV system with high operating rate.</p> <p>Sample: PELCO II, MABALACAT SV, (2012 by PowerSolve Data)</p> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4.3.1 | Refring / relocation of pole transformers | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4.3.2 | Dividing system by installation of pole transformers | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4.3.3 | Adding or replacing low voltage feeders | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4.3.4 | Capacitor placement | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <h3>4.3.2 Dividing system by installation of pole transformers (Example of Image)</h3> <p>Sample: PELCO II, MABALACAT SV, (2012 by PowerSolve Data)</p> | <ol style="list-style-type: none"> Identifying Countermeasures against Technical Losses for Medium Voltage System <ol style="list-style-type: none"> Methodology of calculation of operating status of Medium Voltage system Options of countermeasures against technical losses caused in medium voltage system Criteria for taking countermeasures against technical loss reduction <ol style="list-style-type: none"> Adding or replacing medium voltage feeders Switching optimization Capacitor placement Correcting imbalance of phase currents Appropriate capacities of pole transformers and sizes of conductors | <h3>5.3.2 Switching optimization</h3> <p>To reduce the high current, a part of load is fed by another feeder / substation</p> <p>Substation or Feeder</p> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

- 6 Adding Transformers to Substations / Installation of Substations / Upgrading Voltage of Medium Voltage Feeders
 - 6.1 Methodology of system development
 - 6.2 Cases of installation of transformers
 - 6.3 Cases of upgrading medium voltage feeders 1
 - 6.4 Cases of upgrading medium voltage feeders 2
- 7 Non-technical Loss Reduction
 - 7.1 Tree touching
 - Meters, Etc.

Pilot Project

- Purpose
 - To create useful and efficient manuals on system loss reduction.
 - Business of analysis on chosen distribution network owned by selected ECs would be conducted. Results of the analysis should be fully reflected in the manual.

- Using SynerGEE simulation tool
- Application of amorphous transformer

Pilot Project Sites

So far, we select PELCOI and ISELCOI for the following Pilot Projects:

| | |
|---------------------------|---------------------------|
| PELCOI | ISELCOI |
| SynerGEE (Focusing on LV) | SynerGEE (Focusing on MV) |
| Amorphous | |

Because, PELCOI seems to have enough data to study pole transformers and LV system. ISELCOI's substations have high operating ratios. It seems to have much room to be improved.

Pilot Project Procedures Using SynerGEE simulation

- TA Team will prepare rough sketch of criteria or methodology.
- ECs will continue to model system with SynerGEE
- Confirming the adequacy of rough sketch of criteria or methodology by SynerGEE
- Establishing manuals.

Pilot Project Procedures Testing Installation of Amorphous Transformers

Evaluation of loss reduction value

- Measure the existing transformers (by PELCOI-owned power tester)
- Measure new amorphous transformers
- Calculate differences between existing transformers and amorphous transformers.
- Evaluate the quantity of loss reduction



*Capacity of transformer : 5, 10, 15, 25, 37.5, 50, 75, 100kVA
 *Number of transformer : 8 (one per each capacity)

Qualitative effect

- Qualitative loss reduction effect
- Experience of construction and maintenance of amorphous transformer
- Showcase effect for other EC's

Progress Schedule of ISEA Project on System Loss Reduction for Philippines (Electric) - Cebu Division

| Project No. | Project Name | Start | End | Phase | Progress (%) |
|-------------|--------------|---------|---------|--------------|--------------|
| 1 | PELCOI | 2012/02 | 2012/08 | Analysis | 100 |
| 2 | ISELCOI | 2012/02 | 2012/08 | Analysis | 100 |
| 3 | PELCOI | 2012/09 | 2012/12 | Installation | 100 |
| 4 | ISELCOI | 2012/09 | 2012/12 | Installation | 100 |





Economical Evaluation for System Loss Reduction Project

Teru MIYAZAKI / TEPCO
8 February, 2012

Main topic

- Show an example of economical evaluation for technical loss reduction



Rough benefit estimation for loss reduction

Quick benefit estimation

- Cost saving (=loss reduction value) is estimated by loss reduction (kW) at peak.

Output (cost saving)
Loss reduction value for multiple years (Php)

Rough benefit estimation for loss reduction

Input

kWh loss reduction per year

$$\text{kWh loss reduction at peak (kWh)} \times \text{Loss factor} \times \text{hours} \times \text{Unit price (Php/kWh)}$$

Yearly Loss reduction value (Php/year)

Output
Loss reduction value for multiple years (Php)

Rough benefit estimation for loss reduction

Loss reduction value can be obtained using 1 kW loss reduction value (Php/kWh) easily

Benefit (Net Present Value etc.)
Loss reduction value for multiple years (Php)

Cost
Countermeasure cost for loss reduction (Php)

1 kW Loss reduction value for multiple years (Php) x Loss reduction at peak (kW)

Calculation Software calculation

Example of economical analysis

| | |
|-------------------|-------------------|
| Line Type : 1/0 | Line Type : 4/0 |
| Length : 200m | Length : 200m |
| O.R. : 90% (207A) | O.R. : 61% (207A) |
| Loss : 3.59kW | Loss : 2.10kW |

Cost for Measure

| | | |
|--------------------|------------|------------|
| Construction Fee : | 4/0 * 200m | 44,087 PHP |
| Removal Fee : | 1/0 * 200m | 1,860 PHP |

Amount of Money for Loss Reduction

Loss Reduction : 19% (=209PHP) x 1.85kW = 368,735 PHP
 (1kW loss reduction value) (Loss reduction at peak)

Total Effect : 322,778 PHP

Economical analysis (Payback Period)

<Example> highly operated line 1/0 (90%) to 4/0 (61%)

CF₀ = 27,437 [Php] < 45,947 [Php]
 CF₁ + CF₂ = 58,093 [Php] > 45,947 [Php]

Determining how many years are necessary for the operating cash flow after implementation to exceed the initial investment
 - In this example, the project's payback period is "2 years"

Economical analysis (Net Present Value)

<Example> highly operated line 1/0 (90%) to 4/0 (61%)

Presented at 10% as discount rate

$$CF_0 / (1,1)^0 = -45,947 + 27,437 / 1.1 + 30,566 / (1,1)^2 + \dots + 77,730 / (1,1)^{10}$$

= +322,778 [Php] > 0

Taking into account the value of time, the expected cash flow in the future is discounted into "present value" with "discount rate"
 - In this example, the sum of present value is positive (+322,778)
 - The return of this project will satisfy investors' expectation

Economical analysis (IRR)

<Example> highly operated line 1/0 (90%) to 4/0 (61%)

| Year | 0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|-------------------|--------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Construction Fee | 44,057 | | | | | | | | | | |
| Removal Fee | | | | | | | | | | | |
| Loss | | 3,980 | 3,980 | 3,980 | 3,980 | 3,980 | 3,980 | 3,980 | 3,980 | 3,980 | 3,980 |
| Loss Reduction | | | | | | | | | | | |
| Net Present Value | | | | | | | | | | | |

Discounted at "r" as discount rate

$$NPV = \sum_{t=0}^{10} \frac{CF_t}{(1+r)^t} = -45,947 + 27,437/(1+r) + 30,566/(1+r)^2 + \dots + 77,730/(1+r)^{10} = 0$$

r = 70.8%

IRR (Internal Rate of Return) is a discount rate that results in net present value of zero for a series of cash flow

Project is attractive to investors when IRR is greater than the discount rate

Thank you for listening!

A Simple Table of Loss Reduction Measures for SynerGEE Calculation

JICA TA Team
Loss Reduction Project in the Philippines

TOKYO ELECTRIC POWER COMPANY

1. Purpose

Capable of finding the facilities which need loss reduction and measures by using SynerGEE and a simple table for loss reduction measures and effect

| Category | Countermeasure | Target Facilities | Remarks |
|-----------------------|-------------------|-------------------|---|
| Line | Line Thickening | High Operation | Capable of displaying by color on SynerGEE |
| | Parallel Circuit | High Operation | |
| | Line Thinning | High Operation | |
| Transformer & LV Line | Capacity Changing | Small → Big | Transformer: incapable of displaying by color on SynerGEE Only numerical results |
| | | Big → Small | |
| | Load Dividing | High Operation | |
| | Load Centering | High Operation | |

2. Effectiveness of SynerGEE 1

Comparison between PowerSolve and SynerGEE

| Item | PowerSolve | SynerGEE |
|---|------------|------------|
| Mapping function | △ | ○ |
| Specification of loss generating source | △ | ○ |
| Planning for loss reduction measures | △ | ○ |
| Data input | △ | △ |
| Price | 9,800 USD | 14,800 USD |

2. Effectiveness of SynerGEE 2

Mapping Function of SynerGEE

3. Explanation for a Simple Table 1

How do we conduct loss reduction by SynerGEE?

3. Explanation for a Simple Table 3

A Simple Table for Loss Reduction

| Category | Countermeasure | Target Facilities | Remarks |
|-----------------------|-------------------|-------------------|---|
| Line | Line Thickening | High Operation | Capable of displaying by color on SynerGEE |
| | Parallel Circuit | High Operation | |
| | Line Thinning | High Operation | |
| Transformer & LV Line | Capacity Changing | Small → Big | Transformer: incapable of displaying by color on SynerGEE Only numerical results |
| | | Big → Small | |
| | Load Dividing | High Operation | |
| | Load Centering | High Operation | |

Summarize measures for loss reduction

3. Explanation for a Simple Table 4

Example: Line Thickening

Input line length and operation ratio
Capable of checking total effect of loss reduction

4. Illustration of Loss Reduction Measures 1

Illustrate each loss reduction measure

Show sample cases of each measure

In the sample case, use unit price of loss

Load Loss: 196,729 (PHP/kW)
No Load Loss: 405,115 (PHP/kW)

4. Illustration of Loss Reduction Measures 2

4-1. Line Thickening for MV Line and LV Line

Thicken MV and LV line to upper size
Use high operation ratio MV line
Lower operation ratio of LV line

4. Illustration of Loss Reduction Measures 2

| Line Type | 1/0 | 4/0 |
|-----------|------------|------------|
| Length | 200m | 200m |
| O.R. | 90% (207A) | 61% (207A) |
| Loss | 3,980W | 2,100W |

Cost for Measure

| | | |
|------------------|------------|-------------------|
| Construction Fee | 4/0 → 200m | 44,057 PHP |
| Removal Fee | 1/0 → 200m | 1,985 PHP |
| Subtotal | | 45,947 PHP |

Amount of Money for Loss Reduction

| | |
|-----------------|--------------------|
| Loss Reduction | 368,729 PHP |
| Subtotal | 322,778 PHP |

Total Effect: 322,778 PHP

4. Illustration of Loss Reduction Measures 3

4. Illustration of Loss Reduction Measures 4

| Line Type | 1/0 | 4/0 |
|-----------|------------|------------|
| Length | 200m | 200m |
| O.R. | 90% (207A) | 61% (207A) |
| Loss | 3,980W | 2,100W |

Before

| | | |
|-----------------|------------|---------------|
| MV 1/0 | 90% (207A) | 3,980W |
| Subtotal | | 3,980W |

After

| | | |
|-----------------------|------------|---------------|
| MV 4/0 | 61% (207A) | 2,100W |
| Subtotal | | 2,100W |
| Loss Reduction | | 1,880W |

4. Illustration of Loss Reduction Measures 5

4-2. Load Dividing


Divide load of Tr and LV line, add a spare capacity Tr
Use high operation ratio Tr and/or LV line
Lower operation ratio of Tr and LV line

4. Illustration of Loss Reduction Measures 6


Model case of Load Dividing

4. Illustration of Loss Reduction Measures 7

4. Illustration of Loss Reduction Measures 8



4. Illustration of Loss Reduction Measures 9



4. Illustration of Loss Reduction Measures 10

| | | | |
|----------------|---------|--------------|---------|
| Before | | | |
| Tr | 37.5kVA | 120% (45kVA) | 627.3W |
| LV1 | 2 | 70% (125A) | 1085.6W |
| LV2 | 2 | 35% (63A) | 271.3W |
| Subtotal | | | 1984.2W |
| After | | | |
| Tr1 | 37.5kVA | 40% (15kVA) | 142.5W |
| Tr2 | 37.5kVA | 80% (30kVA) | 323.5W |
| LV1 | 2 | 0% (0A) | 0W |
| LV2 | 2 | 35% (63A) | 272.0W |
| Subtotal | | | 738.0W |
| Loss Reduction | | | 1246.2W |

5. Summary

- ✓ SynerGEE is a very effective tool for conducting loss reduction
- ✓ Simple table for loss reduction is helpful for conducting loss reduction by SynerGEE

Thank you for your attention !!

The Effects to Introducing Amorphous Transformer in Philippine

2012/02/08

Contents


1. The Comparison of the Transformer Losses
2. The Current Situation of the AMDT in Japan
3. Cost/Benefit estimation of AMDT in Philippine
4. How to introducing AMDT [Image]
5. Model Project in PELCO 2

1. The Comparison of the Transformer Losses


| Loss | Location | Main cause | Feature | Improvement |
|--------------------------|---------------|---------------------|--|---|
| No-load Loss (Iron Loss) | Magnetic Core | Magnetic reluctance | Constant, Independent of the load | -Magnetic Materials -Core structure -Thin strip |
| Load Loss (Copper Loss) | Copper Wire | Electric resistance | Proportional to the square of the load current | -Al → Cu -Shorten the wire. -Thin insulation |

- Use of better magnetic core material
 - Thin ribbon and high resistivity
- Amorphous Transformer**


1. The Comparison of the Transformer Losses




1. The Comparison of the Transformer Losses




1. The Comparison of the Transformer Losses




2. The Current Situation of the AMDT in Japan




3. Cost/Benefit estimation of AMDT in Philippine




3. Cost/Benefit estimation of AMDT in Philippine




3. Cost/Benefit estimation of AMDT in Philippine



4. How to introducing AMDT [Image]



4. How to introducing AMDT [Image]



4. How to introducing AMDT | Image 1

- Rule for replace the old TR
- Decide the index to replace the old TR
- Manage replacement schedule from the result of the site inspection
- Plan for proper replacement according to the ages

| Rank | Replacement Rule |
|--------|----------------------|
| Rank 1 | Replace in our year. |
| Rank 2 | Black listed |
| Rank 3 | Need to replace asap |

Source: JICA

5. Model Project in PELCO 2

Site survey in PELCO 2 Oct. 2011
 Pilot feeder: MABIGA S/S F252T1
 Feeder length: about 2km
 Feeder capacity: 750kVA
 Target transformer replacement: 2 units (T)
 VGT: 1 unit at feeding point
 Measurement device: 21 units at 2" TR

JICA estimated the project cost and study the benefit of this replacement.

Substation

5. Model Project in PELCO 2

Result of the Study in PELCO 2
 Feeder capacity about 1 MW
 Expected Loss Reduction 2-8 kW
 Too small loss reduction to measure by meter with CT & PT on the feed line.

Alternative Proposal
 1. Loss evaluation in the model measurement
 2. Measure loss reduction of TRs itself after remove from the line
 3. Measure loss reduction of new AMDTs for replacement
 4. Evaluate the difference of the loss on the model feeder

JICA will prepare the new AMDT for the replacement of this evolution

Necessary items for the pilot project
 * AMDT at 10,15,25,37,50,75,100kVA
 * Bus
 * Loss reduction are expected in the model feeder even if it is not capable to measure on the one feeder.
 * To leave the Unit AMDT in place on the site.
 * To use Energy-Flow Monitoring AMDT.
 * Expect in the response to introduce AMDT in other EC.

The lessons of Loss reduction in Slum area in Brazil

Favela - Slum

2012/02/08

Non-Technical Losses

- Non-Technical Losses in Brazil are 7.0%
- Equivalent to 27,000 GWh/year
- It costs US\$ 1.5 billion/year

Non Technical Losses Diversity

10-20% theft each hour

Energy Theft Evolution - Residential Clients

Direct connection to the low voltage grid

Meter tampering V1.0

Meter tampering V2.0

"Clique do Solda" theft

Free electricity through a clandestine cable

Energy Theft Evolution - Residential Clients

Direct connection to the low voltage grid

Meter tampering V1.0

Meter tampering V2.0

"Clique do Solda" theft

Free electricity by skipping the meter wheel

or by getting the meter in sleep

Energy Theft Evolution - Residential Clients

Direct connection to the low voltage grid

Meter tampering V1.0

Meter tampering V2.0

"Clique do Solda" theft

Feeding all the energy by changing meter gears

or just part of it by smoothing gears over

Energy Theft Evolution - Residential Clients

Direct connection to the low voltage grid

Meter tampering V1.0

Meter tampering V2.0

"Clique do Solda" theft

More Energy Theft - Corporate Clients

Disconnected wires

Electronic Fraud

Cost to:

- High tariffs
- Inadequate instruments to inspect the clients
- Employees corruption (steals vs. bribe value)
- Clients corruption (overage billed value vs. bribe value)
- Difficult access to the clients facilities
- Access time vs. time to disseminate the fraud
- Metering system cabin is built by 2nd parties
- Fraud arranged by the constructor

More Energy Theft - Corporate Clients

Disconnected wires

Electronic Fraud

Changing resistance polarity

Measurements using smart meters

concentrator

Monitor in house

Single Phase meter

Power Company

SYSTRAFO

CP

Landis+Gyr - Metering Solutions

Total of supplied Measurement Modules on field (Volumes from 2005 to end of Sep.2011)

| Country | N° MMs |
|--------------|----------------------|
| Brazil | >1.000.000 |
| Colombia | 1.525 |
| Jamaica | 2.000 |
| Mexico | 175 |
| Panama | 6.368 |
| Paraguay | 100 |
| Total | >1.000.000 |

Installation under low voltage distribution grid

Low voltage

Secondary Concentrator (CS)

Landis+Gyr - Metering Solutions

Ampla's Solution (Rio de Janeiro) for losses combat

Medium voltage

Low voltage

Secondary Concentrator (CS)

Landis+Gyr - Metering Solutions

Installation under middle voltage customers (Before)

The problem: high commercial losses in medium-sized enterprises

Why: our metering system used to be placed inside the clients' facilities, where we usually encountered plenty of difficulties to determine the consumption and to execute fraud inspections.

Landis+Gyr - Metering Solutions

Installation under middle voltage customers (After)

CT

PI

Meter

Landis+Gyr - Metering Solutions

- The solution: externalization of the metering system (3 power transformers, 3 current transformers, telemetry, motion sensor detector, and metering module)
- Telemetry: improves energy metering, optimizes the operations, and minimizes the energy losses

Success Cases: AMPLA PROJECT

Low-voltage network - common/coupler cable

Secondary concentrator

Medium-voltage network

Distribution transformer

Landis+Gyr - 100% of EC, Project Report for Brazil

Presentation Materials of 3rd Workshop

The 3rd Workshop on The JICA Project on System Loss Reduction for Philippine Electric Cooperatives (EC's)

Overall Progress and Activities

JICA TA Team
Manila
The Philippines
May 31, 2011

THE TOKYO ELECTRIC POWER CO., INC.

Schedule from May 2012

| Task | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 |
|--|-------------------|------|----------|------|------|------|------|------|------|
| Progress Bar chart of JICA Project on System Loss Reduction for Philippine Electric Cooperatives | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 |
| Mission | JCC, W/S, Meeting | W/S | JCC, W/S | JCC | | | | | |

Contents in the Schedule

| Tasks | Contents/Status |
|---|---|
| Making Draft Manuals and Checklist | (Starting) |
| Software /System Modeling | *SynerGEE modeling *Investigation of methodologies of data arrangement |
| Execution Case Study to Apply Manual to Problem Solving | *SynerGEE modeling *Amorphous transformer pilot project |
| 23 kV (33 kV) Distribution Lines | *Investigation of cost and specifications |

Goals
*Proposal of Appropriate Method of Evaluating System Loss Reduction
*Completion Manuals

Modeling Peak Load Situation with SynerGEE

Peak Load Allocation
↓
Peak loss calculation for each feeder
↓
Peak loss (kW)

How to obtain the peak load data and maintain its data?

Peak Load Data Correction and its Modeling

- Some options
 - Clamp-on meters measurement of peak current of pole transformers
 - Power solve data (ERC Data Templates) with customer data
 - MV feeders load measurement or purchasing amount of power -> load allocation

<Ref: TEPCO's Example> Computation of Load Current & Voltage Drop

$I_e = A \times \sum \pi_i + b$

Maximum load current I_e is calculated based on $\sum \pi_i$ by using multiplier A & constant b determined from the regional demand character. Voltage drop is also calculated.

<Ref: TEPCO's Example> Relationship between Maximum Measured Current & Sales Energy

$I_e = A \times \sum \pi_i + b$

Actual maximum current vs $\sum \pi_i$ (kW/h) (Summation of energy sales)

Establish the Methodology of Peak Loss Estimation of Pole Transformers

- Clamp-on meters measurement of peak current of pole transformers
- Power solve data (ERC Data Templates) with customer data
- Customer billing data

Finding out their relations

Estimating peak loads at pole transformers

Establish the methodology of loss evaluation values

| | |
|---------------------|-----------|
| Peak Loss reduction | 1 kW |
| Unit value | 5 PHP/kWh |
| Loss factor | 0.3 |

Resistance and Capacities of MV(13.2 kV) Line Conductors

| Line Type | Resistance Three-phase ohms per phase per km. of line (source: DX3430.48) | Capacity (A) |
|-----------|---|--------------|
| 336.4 | 0.173 | 530 |
| 266.8 | 0.217 | 460 |
| 4/0 | 0.274 | 340 |
| 3/0 | 0.345 | 300 |
| 2/0 | 0.436 | 270 |
| 1/0 | 0.55 | 230 |
| 2 | 0.876 | 180 |
| 4 | 1.391 | 140 |

Peak Loss in MV(13.2 kV) Lines (KW/km & million PHP/15years) (3 phase)

| Line Type | Peak Current (A) | 20 | 30 | 40 | 50 | 60 | 70 | 80 | 90 | 100 | 110 | 120 | 130 | 140 | 150 | 200 |
|-----------|------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
| 336.4 | 0.32 | 0.47 | 0.61 | 0.76 | 0.91 | 1.06 | 1.21 | 1.36 | 1.51 | 1.66 | 1.81 | 1.96 | 2.11 | 2.26 | 2.41 | 2.56 |
| 4/0 | 0.38 | 0.51 | 0.64 | 0.78 | 0.91 | 1.04 | 1.17 | 1.30 | 1.43 | 1.56 | 1.69 | 1.82 | 1.95 | 2.08 | 2.21 | 2.34 |
| 3/0 | 0.43 | 0.56 | 0.69 | 0.82 | 0.95 | 1.08 | 1.21 | 1.34 | 1.47 | 1.60 | 1.73 | 1.86 | 1.99 | 2.12 | 2.25 | 2.38 |
| 2/0 | 0.52 | 0.68 | 0.84 | 1.00 | 1.16 | 1.32 | 1.48 | 1.64 | 1.80 | 1.96 | 2.12 | 2.28 | 2.44 | 2.60 | 2.76 | 2.92 |
| 1/0 | 0.66 | 0.84 | 1.02 | 1.20 | 1.38 | 1.56 | 1.74 | 1.92 | 2.10 | 2.28 | 2.46 | 2.64 | 2.82 | 3.00 | 3.18 | 3.36 |
| 2 | 1.05 | 1.37 | 1.70 | 2.02 | 2.34 | 2.66 | 2.98 | 3.30 | 3.62 | 3.94 | 4.26 | 4.58 | 4.90 | 5.22 | 5.54 | 5.86 |
| 4 | 1.63 | 2.18 | 2.73 | 3.28 | 3.83 | 4.38 | 4.93 | 5.48 | 6.03 | 6.58 | 7.13 | 7.68 | 8.23 | 8.78 | 9.33 | 9.88 |

Establish the Methodology of Peak Loss Evaluation Values

Method 1
Considering load growth, interest rate and inflation rate

| | |
|--------------------------|------------------------|
| Load growth | 4 %/year |
| Interest rate | 10 %/year |
| Inflation rate | 3 %/year |
| Cost saving for 15 years | 196,729 PHP/KW/15 year |

* Assuming LF=0.3 5php/kWh

Method 2
Justs considering one-year cost saving multiplied by certain years

| | |
|--------------------------|------------------------|
| Cost saving for 5 year | 13,140 PHP/year |
| Cost saving for 5 years | 65,700 PHP/KW/5 year |
| Cost saving for 10 years | 131,400 PHP/KW/10 year |
| Cost saving for 15 years | 197,100 PHP/KW/15 year |

*Other factors affecting: evaluation period, using PHP/KW
*Methodology to be formulated for evaluation

Total Cost including Construction for 15 years in Case of New MV(13.2 kV) Lines (3 Phase)

| Line Type | Peak Current (A) | 20 | 30 | 40 | 50 | 60 | 70 | 80 | 90 | 100 | 110 | 120 | 130 | 140 | 150 | 200 |
|-----------|------------------|------|------|------|------|------|------|------|------|------|------|-------|-------|-------|-------|-------|
| 336.4 | 0.80 | 0.85 | 0.92 | 1.01 | 1.10 | 1.20 | 1.31 | 1.42 | 1.53 | 1.64 | 1.75 | 1.86 | 1.97 | 2.08 | 2.19 | 2.30 |
| 4/0 | 0.52 | 0.60 | 0.71 | 0.83 | 0.96 | 1.09 | 1.23 | 1.37 | 1.51 | 1.65 | 1.79 | 1.93 | 2.07 | 2.21 | 2.35 | 2.49 |
| 3/0 | 0.40 | 0.46 | 0.54 | 0.63 | 0.73 | 0.84 | 0.95 | 1.06 | 1.17 | 1.28 | 1.39 | 1.50 | 1.61 | 1.72 | 1.83 | 1.94 |
| 2/0 | 0.40 | 0.53 | 0.71 | 0.94 | 1.23 | 1.58 | 1.91 | 2.23 | 2.55 | 2.87 | 3.19 | 3.51 | 3.83 | 4.15 | 4.47 | 4.79 |
| 1/0 | 0.59 | 0.78 | 1.05 | 1.41 | 1.83 | 2.30 | 2.80 | 3.31 | 3.82 | 4.33 | 4.84 | 5.35 | 5.86 | 6.37 | 6.88 | 7.39 |
| 2 | 0.91 | 1.23 | 1.67 | 2.24 | 2.94 | 3.74 | 4.54 | 5.34 | 6.14 | 6.94 | 7.74 | 8.54 | 9.34 | 10.14 | 10.94 | 11.74 |
| 4 | 0.46 | 0.87 | 1.43 | 2.19 | 3.09 | 4.10 | 5.10 | 6.10 | 7.10 | 8.10 | 9.10 | 10.10 | 11.10 | 12.10 | 13.10 | 14.10 |




Suitable Size for Construction

Total Cost including Construction for 5 years in Case of New MV(13.2 kV) Lines (3 Phase)

| Line Type | Peak Current (A) | 20 | 30 | 40 | 50 | 60 | 70 | 80 | 90 | 100 | 110 | 120 | 130 | 140 | 150 | 200 |
|-----------|------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
| 336.4 | 0.72 | 0.76 | 0.83 | 0.92 | 1.01 | 1.10 | 1.20 | 1.30 | 1.40 | 1.50 | 1.60 | 1.70 | 1.80 | 1.90 | 2.00 | 2.10 |
| 4/0 | 0.47 | 0.55 | 0.66 | 0.79 | 0.92 | 1.05 | 1.18 | 1.31 | 1.44 | 1.57 | 1.70 | 1.83 | 1.96 | 2.09 | 2.22 | 2.35 |
| 3/0 | 0.35 | 0.41 | 0.49 | 0.58 | 0.67 | 0.76 | 0.85 | 0.94 | 1.03 | 1.12 | 1.21 | 1.30 | 1.39 | 1.48 | 1.57 | 1.66 |
| 2/0 | 0.33 | 0.43 | 0.55 | 0.71 | 0.93 | 1.20 | 1.52 | 1.84 | 2.16 | 2.48 | 2.80 | 3.12 | 3.44 | 3.76 | 4.08 | 4.40 |
| 1/0 | 0.29 | 0.39 | 0.53 | 0.71 | 0.93 | 1.17 | 1.41 | 1.65 | 1.89 | 2.13 | 2.37 | 2.61 | 2.85 | 3.09 | 3.33 | 3.57 |
| 2 | 0.70 | 0.93 | 1.21 | 1.61 | 2.01 | 2.41 | 2.81 | 3.21 | 3.61 | 4.01 | 4.41 | 4.81 | 5.21 | 5.61 | 6.01 | 6.41 |
| 4 | 0.24 | 0.46 | 0.77 | 1.17 | 1.67 | 2.17 | 2.67 | 3.17 | 3.67 | 4.17 | 4.67 | 5.17 | 5.67 | 6.17 | 6.67 | 7.17 |

Suitable Size for Construction

Standardized conductor size for bulk MV lines and MV system configuration for loss reduction and enhancement of power supply reliability to be established.



- Comparing 22 kV and 13.2 kV
 - Cost benefit analysis
 - Other factors
- Studying 22 kV System


Amorphous Transformer Pilot Project

(A) Replacement Project (Measurement conventional and amorphous transformer)

- Load Data Measurement (with clamp-on meters for peak and off-peak)
- Amorphous Transformers Measurement / Installation
- Existing Pole-transformers Measurement with a Power Tester
- Estimate Loss Reduction with Amorphous Transformers

(B) Splitting LV Loads Project

- Identifying locations with large voltage drops and heavy loads
- Installation of Amorphous Transformers
- Confirm its effects on loss reduction with using SynerGEE




- ### <Ref> TEPCO's Distribution System
- Transmission system
 - 500 kV, 275 kV, 154 kV, 66 kV
 - Distribution system
 - 22 kV : Three phase-four wires (Neutral point grounding)
 - 6.6 kV : Three phase-three wires (No-grounding)
 - LV

<Ref> 66/6.6kV Substation of TEPCO

| Area | Scale |
|--------------------------------------|----------------|
| High demand density area | 30 MVA x 3 |
| Tokyo/ Urban areas surrounding Tokyo | 20 MVA x 3 |
| Other areas | 10MVA x 3 or 2 |

| Capacity of a transformer | Standard number of feeders |
|---------------------------|----------------------------|
| 30 MVA | 8 |
| 20 MVA | 7 |
| 15 MVA | 4 |
| 10 MVA | 4 |

* 1 feeder: around 2-3MW at peak load



<Ref> Capacity of Bulk Lines of 6.6 kV


| | | Capacity of Bulk lines | |
|-------------|----------------|------------------------|-------------------------|
| | | Capacity (A) | Short time capacity (A) |
| Overhead | Large Capacity | 450-530* | 600 |
| | General | 230-270* | 300-360* |
| Underground | Large Capacity | 400 | 600 |
| | General | 260 | 400 |

* Depending on the types of automatic control scheme or conductors

<Ref> Typical Conductors used for 22 kV and 6.6 kV system

| | Type name | Size | | Application |
|--------|-----------|---------------------|--|-------------|
| | | Copper | Aluminum | |
| 22 kV | HCVT-SS | 200 mm ² | - | Large Cap. |
| | CVT-SS | 100 mm ² | - | General |
| 6.6 kV | SN-OC | - | HAL 240 mm ² (0.122 Ω/km) | Large Cap. |
| | SN-OE | - | ACSR 120 mm ² (0.25 Ω/km) ACSR 32 mm ² (0.928 Ω/km) | General |

* Other types are used for salty areas etc.



Sample Analysis of Medium Voltage Line Loss Reduction Measures and Propose for appropriate mechanism to transfer loss reduction method to all ECs

May 2012
Tokyo Electric Power Company, Inc.

Legal Notice
This document includes technical knowledge and secret information that belong to our company and our partners. Therefore, it shall neither be disclosed to any third parties, be copied, nor be used for any purpose other than that authorized by our company. THE TOKYO ELECTRIC POWER COMPANY, INC.

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved


- Method of Loss Reduction for Medium Voltage Line
 - Sample Analysis of Loss Reduction for MV Line using SynerGEE
 - Propose for appropriate mechanism to transfer loss reduction method to all ECs
 - Incentive system (Introduction of Front-line Workplaces Activities in TEPCO)
- ©2012 The Tokyo Electric Power Company, INC. All Rights Reserved

Method of Loss Reduction for Medium Voltage Line

1.1 Method of Loss Reduction for Medium Voltage Line

| Category | Countermeasure | Target Facilities | Remarks |
|-----------------------|---------------------------------|------------------------------|---|
| Line | Line Thickening | High Operation | Capable of displaying by color on SynerGEE |
| | Parallel Circuit | High Operation | Capable of displaying by color on SynerGEE |
| | Load Balancing | Stabilize line | Only numerical results |
| | Capacitor placement/replacement | Low Power Factor loss | Only numerical results |
| LV Line | Switching optimization | Multi-interconnection system | Method for multi-interconnection system |
| | Line Thickening | High Operation | Capable of displaying by color on SynerGEE |
| Transformer / LV Line | Capacity Changing | Small -> Big | High Operation |
| | | Big -> Small | Line Operation |
| | Load Shifting | High Operation | Transformer: incapable of displaying by color on SynerGEE |
| | Load Centering | High Operation | Only numerical results |

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved



Method of Loss Reduction for Medium Voltage Line


1.2 Method of Loss Reduction for MV Line (1)

Line Type : 1/0 → Line Type : 4/0
Length : 200m → Length : 200m
O.R. : 90% (207A) → O.R. : 61% (207A)
Loss : 4.71kW → Loss : 2.35kW

O.R. : Operation Ratio

- Cost for Measure
 - Construction Fee : 4/0 * 200m 44,087 PHP
 - Removal Fee : 1/0 * 200m 1,860 PHP
 - Subtotal : 45,947 PHP**
- Amount of Money for Loss Reduction
 - Loss Reduction : 2.36kW 464,278 PHP
 - Total loss reduction value: 196,729PHP-KW
 - Subtotal : 464,278 PHP**
 - Total Effect : 418,331 PHP**

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved



Method of Loss Reduction for Medium Voltage Line

1.2 Method of Loss Reduction for MV Line (1)

Review of 2nd work shop

| | | | | |
|--------|----|-----|----------------|--------|
| Before | MV | 1/0 | 90% (207A) | 3.98kW |
| | | | Subtotal | 3.98kW |
| After | MV | 4/0 | 61% (207A) | 2.10kW |
| | | | Subtotal | 2.10kW |
| | | | Loss Reduction | 1.88kW |

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 6

Method of Loss Reduction for Medium Voltage Line

1.3 Method of Loss Reduction for MV Line (2)

<Parallel Circuit>

- Install new MV line
- For high operation ratio MV line
- Lower operation ratio of MV line

✓ High operation ratio → ✓ Lower operation ratio

Reduction of line loss

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 7

Method of Loss Reduction for Medium Voltage Line

1.3 Method of Loss Reduction for MV Line (2)

| | |
|-------------------|----------------------|
| Line Type : 4/0 | Line Type : 4/0 * 2 |
| Length : 200m | Length : 200m |
| O.R. : 90% (306A) | O.R. : 45% (153A) |
| Loss : 5.13kW | Loss : 1.28*2=2.57kW |

Cost for Measure Construction Fee : 4/0 * 200m 44,087 PHP
Subtotal : 44,087 PHP

Amount of Money for Loss Reduction
 Loss Reduction : 2.56kW 503,623 PHP
 *Total loss reduction value: 196,728PHP/kW
Subtotal : 503,623 PHP

Total Effect : 459,536 PHP

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 8

Method of Loss Reduction for Medium Voltage Line

1.3 Method of Loss Reduction for MV Line (2)

Before: MV 4/0 ACSR 200m
 After: MV 4/0 * 2 ACSR 200m

Loss Reduction: 1.88kW

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 9

Method of Loss Reduction for Medium Voltage Line

1.3 Method of Loss Reduction for MV Line (2)

| | | | | |
|--------|----|-----|----------------|--------|
| Before | MV | 4/0 | 90% (306A) | 4.59kW |
| | | | Subtotal | 4.59kW |
| After | MV | 4/0 | 50% (153A) | 1.15kW |
| | MV | 4/0 | 50% (153A) | 1.15kW |
| | | | Subtotal | 2.30kW |
| | | | Loss Reduction | 2.29kW |

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 10

Method of Loss Reduction for Medium Voltage Line

1.4 Evaluation of suitable size for MV line (1)

Review of 2nd work shop

< Line Thickening >

Input line length and operation ratio
 Capable of checking total effect of loss reduction

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 11

Method of Loss Reduction for Medium Voltage Line

1.5 Evaluation of suitable size for MV line (2)

<Parallel Circuit>

Input line length and operation ratio
 Capable of checking total effect of loss reduction

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 12

Method of Loss Reduction for Medium Voltage Line

1.6 Matrix for suitable size for MV line

Operation rate

| Line | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
|------|--|---|---|---|---|---|---|---|---|----|
| 1 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 |
| 2 | 2 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 |
| 3 | 3 <td>3</td> <td>4</td> <td>4</td> <td>4</td> <td>4</td> <td>4</td> <td>4</td> <td>4</td> <td>4</td> | 3 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 |
| 4 | 4 <td>4</td> <td>4</td> <td>4</td> <td>4</td> <td>4</td> <td>4</td> <td>4</td> <td>4</td> <td>4</td> | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 |
| 5 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 |
| 6 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 |
| 7 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 |
| 8 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 |
| 9 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 |
| 10 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 |

Current size vs Suitable size

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 13

Method of Loss Reduction for Medium Voltage Line

1.7 Image of ideal MV line system based on loss reduction evaluation

Center
 Suitable size
 3/0
 4/0
 3/0
 Suitable size

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 14

1. Method of Loss Reduction for Medium Voltage Line
 2. Sample Analysis of Loss Reduction for MV Line using SynerGEE
 3. Propose for appropriate mechanism to transfer loss reduction method to all ECs
 4. Incentive system (Introduction of Front-line Workplaces Activities in TEPCO)
- ©2012 The Tokyo Electric Power Company, INC. All Rights Reserved

Sample Analysis of Loss Reduction for MV Line using SynerGEE

2.1 Model of Sample Analysis

Substation: GUAGUA S/S
 Feeder: F25112
 Demand: 3,455kW
 Power factor: 98%
 Connected customer: 9,605
 Connected kWh: 1,893,549

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 15

Sample Analysis of Loss Reduction for MV Line using SynerGEE

2.2 Result of Sample Analysis before countermeasure(A)

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 17

Sample Analysis of Loss Reduction for MV Line using SynerGEE

2.2 Result of Sample Analysis before countermeasure(B)

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 18

Sample Analysis of Loss Reduction for MV Line using SynerGEE

2.2 Result of Sample Analysis before countermeasure(C)

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 19

Sample Analysis of Loss Reduction for MV Line using SynerGEE

2.3 Necessary countermeasure for loss reduction

| | |
|---------------------------|---------------------------|
| Line Type : 2 (3-phase) | Line Type : 4/0 (3-phase) |
| Length : 767m | Length : 767m |
| Line Type : 1/0 (3-phase) | Line Type : 4/0 (3-phase) |
| Length : 2,212m | Length : 2,212m |
| Line Type : 2/0 (3-phase) | Line Type : 4/0 (3-phase) |
| Length : 1,187m | Length : 1,187m |

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 20

Sample Analysis of Loss Reduction for MV Line using SynerGEE

2.4 Result of Sample Analysis before countermeasure

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 21

Sample Analysis of Loss Reduction for MV Line using SynerGEE

2.4 Result of Sample Analysis before countermeasure (A)

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 22

Sample Analysis of Loss Reduction for MV Line using SynerGEE

2.4 Result of Sample Analysis before countermeasure (B)

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 23

Sample Analysis of Loss Reduction for MV Line using SynerGEE

2.4 Result of Sample Analysis before countermeasure (C)

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 24

Sample Analysis of Loss Reduction for MV Line using SynerGEE

2.5 Effect of countermeasure

- Cost for Measure
 - Construction Fee : 4/0 * 4,166m 1,884,940 PHP
 - Removal Fee : 2 * 767m 11,190 PHP
 - 1/0 * 2,212m 43,165 PHP
 - 2/0 * 1,187m 28,792 PHP
- Subtotal : 1,968,087 PHP
- Amount of Money for Loss Reduction (result from SynerGEE)
 - Loss Reduction : 64.5kW 12,688,956 PHP
 - Total loss reduction value: 136,728 PHP/kW
 - Subtotal : 12,722,526 PHP

Before: 308.2kW
After: 243.7kW

Total Effect : 10,720,869 PHP

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 25

- Method of Loss Reduction for Medium Voltage Line
- Sample Analysis of Loss Reduction for MV Line using SynerGEE
- Propose for appropriate mechanism to transfer loss reduction method to all ECs
- Incentive system (Introduction of Front-line Workplaces Activities in TEPCO)

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved

Propose for appropriate mechanism to transfer loss reduction method to all ECs

3.1 Image of establishment of Loss Reduction Manual

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 27

Propose for appropriate mechanism to transfer loss reduction method to all ECs

3.2 Draft Contents of Manual

- Introduction
- Economic Values of Technical Loss Reduction
- Methodology of O&M for Data Arrangement of Loss Analysis
- Identifying Countermeasures against Technical Losses for Low Voltage System
- Identifying Countermeasures against Technical Losses for Medium Voltage System
- Installation of Substations / Upgrading Voltage of Medium Voltage System
- Non-technical Loss Reduction

Important to revise periodically for reflecting new techniques and good practices

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 28

Propose for appropriate mechanism to transfer loss reduction method to all ECs

3.3 Revision method of Loss Reduction Manual

Revision of Loss Reduction Manual reflecting new techniques and good practices

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 29

Propose for appropriate mechanism to transfer loss reduction method to all ECs

3.4 Sample of Loss Reduction Sheet

Good Practices for System Loss Reduction

| Item | Implementation |
|-------------------------|--|
| EC Name | NEA/EC |
| Request | Technical Loss Reduction |
| Outline of Project | Find out the distribution pattern of MV line by analyzing MV distribution line using SynerGEE Transfer the technology from 2 ACSSR (10 ACSSR, 20 ACSSR to 40 ACSSR) |
| Picture | |
| Project Period | From May 2012 to October 2012 |
| Expected Loss Reduction | Transfer of Loss Reduction Technology from SynerGEE Loss Reduction: 44.5kW |
| Real Loss Reduction | 50% increase the actual loss after completion of work |
| Project Cost | Construction Fee : 2 * 767m * 11,190 PHP / 2,212m * 43,165 PHP / 1,187m * 28,792 PHP Total : 1,968,087 PHP |
| Remark | Loss Reduction: 44.5kW (Before: 243.7kW After: 243.7kW) Total loss reduction value: 136,728 PHP/kW Distribution Line Subtotal : 12,722,526 PHP |
| Reviewer's Name | |

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 30

- Method of Loss Reduction for Medium Voltage Line
- Sample Analysis of Loss Reduction for MV Line using SynerGEE
- Propose for appropriate mechanism to transfer loss reduction method to all ECs
- Incentive system (Introduction of Front-line Workplaces Activities in TEPCO)

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved

Incentive system (Introduction of Front-line Workplaces Activities in TEPCO)

4.1 Quality Control (QC) Circle Activity (not only loss reduction activities but all activities)

Background

- High demand for the quality of electric power and services
- Necessity of the cost reduction
- Necessity of the company system reform

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 32

Incentive system (Introduction of Front-line Workplaces Activities in TEPCO)

4.2 Priority Issue (PI) Solving Activity

Change from QC circle activity to PI solving activity

- To associate the name of circle activity with extra activity from work and compulsory work
- No means for requesting reforms to other section and management division
- To assume that it must be completed within own section

Point of review

- Change in name to PI solving activity
- Assessment of tackling to other section
- Establishment of means for requesting reforms to other section and management division through changing of manual

PI solving activity Start !
FY 1995

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 33

Incentive system (Introduction of Front-line Workplaces Activities in TEPCO)

4.3 Business Improvement Activity

- Accessible and Immediate Improvement, which Employees voluntarily think, devise and do by themselves (since 1956)
- ex) Reuse of blank backside of Printed Papers, Creation of Guide for exceptional billing treatment, Creation of Administration table for taking out mobile PCs
- Target is to pursue mobility and a number of proposals
- Rewarded with 500 to 15,000 PHP according to estimation at their office
- "Petit Improvement" * is acceptable since 2003

*This Proposal level is not so high but estimated any "improvement" in any way
ex) Reuse of Post-it (Sticky note), Posting of Reminders on car doors for ensuring parking-break

©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 34

Incentive system (Introduction of Front-line Workplaces Activities in TEPCO)

























4.4 President Award System

- TEPCO incorporate "Business Improvement Activity" and "PI solving activity" into President Award System

- Remarkable Cases can be rewarded as the President Award
- Maximum Reward Incentive is 250,000 PHP



©2012 The Tokyo Electric Power Company, INC. All Rights Reserved 35

Presentation Materials of Final (4th) Workshop

| <p align="center">The Final Workshop on “The Project on System Loss Reduction for Philippine Electric Cooperatives (EC’s)”</p> <p align="center">Manila, February 28, 2013 National Electrification Administration (NEA) Japan International Cooperation Agency (JICA) assisted by Tokyo Electric Power Company (TEPCO)</p>  | <p align="center">Overall Project Activities and Outline of System Loss Reduction Manual</p> <p align="center">The Final Workshop on “The Project on System Loss Reduction for Philippine Electric Cooperatives (EC’s)” Feb. 28, 2013 Masaharu Yogo JICA Technical Assistance Team/TEPCO</p>  | <p align="center">Background</p> <ul style="list-style-type: none"> The rate of self-sufficient of energy in the Philippines is low compared with other Asian countries. Energy policies state the enhancement of energy efficiency in the Philippines. For years both NEA and ECs have come up with strategic initiatives that will reduce power distribution loss levels. NEA sought the assistance of JICA which sent the Technical Assistance Team to provide necessary support to develop technical capacity and planning abilities of ECs to reduce distribution system losses.  | | | | | | |
|--|--|--|---------------------|------------------------------|---------------------|-----------------------------|--|---|
| <p align="center">Self Sufficient Energy Ratios of Asian Countries</p>  <p align="center">Source: Energy Balances of OECD / non-OECD Countries 2009</p>  | <p align="center">Purposes</p> <ul style="list-style-type: none"> The main purpose of this Project is to provide necessary support to improve the skills for loss reduction planning and its technology of NEA and ECs. <p>7 targeted ECs</p> <ul style="list-style-type: none"> ISELCO I (Isabela 1) PELCO II (Pampanga 2) FLECO (First Laguna) CASURECO II (Camarines Sur 2) CASURECO IV (Camarines Sur 4) SORECO I (Sorsogon 1) LEVECO III (Leyte 3)  | <p align="center">Goals</p> <ul style="list-style-type: none"> Output 1: Total management manuals for system loss reduction <ul style="list-style-type: none"> To support NEA and EC staff in the smooth implementation of the power distribution loss reduction plans by summarizing their procedures. Output 2: Support for quantitative evaluation of system loss <ul style="list-style-type: none"> To introduce Software with mapping functions Amorphous Distribution Transformer Pilot Project Output 3: Support for upgrading the present mid-voltage to 23kV and its technical design standards   | | | | | | |
| <p align="center">Workflow carried out since Mar.2011</p>   | <p align="center">ECs' Distribution Loss Ratios</p> <p>ECs loss ratio</p>  <p>Averaged ECs loss ratio</p> <p>Some ECs could achieve single digit loss ratio. But more could be reduced.</p>  | <p align="center">TEPCO's Transmission & Distribution Loss Ratio</p>  <table border="1"> <thead> <tr> <th></th> <th>TEPCO</th> </tr> </thead> <tbody> <tr> <td>Maximum Peak Demand</td> <td>64.3GW (recorded Jul. 2001)</td> </tr> <tr> <td>Sales</td> <td>293.4TWh (2010)</td> </tr> </tbody> </table>  | | TEPCO | Maximum Peak Demand | 64.3GW (recorded Jul. 2001) | Sales | 293.4TWh (2010) |
| | TEPCO | | | | | | | |
| Maximum Peak Demand | 64.3GW (recorded Jul. 2001) | | | | | | | |
| Sales | 293.4TWh (2010) | | | | | | | |
| <p align="center">Japanese Utilities' Transmission & Distribution Loss Ratios</p>  <table border="1"> <thead> <tr> <th></th> <th>Japanese 9 Utilities</th> </tr> </thead> <tbody> <tr> <td>Maximum Peak Demand</td> <td>181.3GW (recorded Jul. 2001)</td> </tr> <tr> <td>Sales</td> <td>912.1TWh (2007)</td> </tr> </tbody> </table>  | | Japanese 9 Utilities | Maximum Peak Demand | 181.3GW (recorded Jul. 2001) | Sales | 912.1TWh (2007) | <p align="center">Counterpart Training in Japan Mar.2012 & Sep.-Dec.2012</p>  <ul style="list-style-type: none"> Participants visited the Japanese Major Manufacturers. Various distribution facilities in Tokyo and Shikoku were good reference to understand urban distribution system of Japan.  | <p align="center">Technical Situations of Some ECs - From the Results of Site Surveys in 2011</p> <ul style="list-style-type: none"> There are some; <ul style="list-style-type: none"> substations with its heavy load <ul style="list-style-type: none"> CASURECOI, ISELCOI, FLECO, etc. large length medium voltage lines and their single phase lines <ul style="list-style-type: none"> CASURECOI, CASURECOIV, etc. pole transformers with too much capacities or insufficient capacities <ul style="list-style-type: none"> most ECs too much technical loss <ul style="list-style-type: none"> SORECOI, etc. <p>JICA provided Clamp-on Meters targeted ECs and NEA.</p>  |
| | Japanese 9 Utilities | | | | | | | |
| Maximum Peak Demand | 181.3GW (recorded Jul. 2001) | | | | | | | |
| Sales | 912.1TWh (2007) | | | | | | | |
| <p align="center">AMDT Project</p> <ul style="list-style-type: none"> On mid of Nov. 2012 JICA and three ECs (FLECO, ISELCO1 and PELCO2) conducted Factory Test of Amorphous Distribution Transformers at Philec factory and they received 9 AMDTs each from JICA. EC staff could measure the effects of amorphous with their own measurement equipments and confirm the superiority of the amorphous transformers.   | <p align="center">Distribution Analysis Software</p> <ul style="list-style-type: none"> PowerSolve Suitable for Segregation of Distribution System Losses SynerGEE Mapping image, detailed results of loss causing locations and easy to find out loss reduction options <p>JICA provided targeted ECs and NEA with SynerGEE and its training course.</p>   | <p align="center">Contents of Loss Reduction Manual</p> <ul style="list-style-type: none"> Introduction Economic Evaluation for Technical Loss Reduction Methodology of O&M for Data Arrangement of Loss Analysis Identifying Countermeasures against Technical Losses for the LV System Identifying Countermeasures against Technical Losses for MV System New Installation of Distribution Substation and Upgrading MV Network Using SynerGEE Non-Technical Loss Reduction Activities <p>Summarizing NEA&ECs know-how.</p>  | | | | | | |



Description of Manual

- Economical Evaluation
- Utilizing Distribution Software
- Adoption of larger size conductors
- Recommendation to the selection of the appropriate sizes of transformers
- Loss reduction effects of the amorphous transformers
- Criteria for application of 23 kV
- Summary of the activities for non-technical loss reduction by NEA and ECs.

16


Concept of Seeking Appropriate Measures for Loss Reduction


17

Conductor Losses

| Current | Capacity [A] |
|---------|--------------|
| 350 # | 350 |
| 400 | 364 |
| 500 | 380 |
| 600 | 397 |
| 700 | 414 |
| 800 | 432 |
| 900 | 450 |
| 1000 | 468 |




Conductor 1 km loss sometimes reaches an amount of load of a pole transformer!



18

Summary and Recommendation


- Utilization of Manual and Distribution Analysis Software
- Upgrading Medium Voltage to 23kV
- Application of Amorphous Transformers



19

Utilization of Manual and Distribution Analysis Software


- The System Loss Reduction Manual has been prepared and quantitative evaluation of system loss using the distribution analysis software would be supported.
- The institutional promotion system of Manual should be established by NEA and ECs to become able to implement its recommendation and revise them in case of change in the situations.
- Database should be maintained to promote to making system models on the distribution analysis software.
- We recommend that many loss reduction plans should be looked into that are able to yield benefits far exceeding costs for its measures by utilization of this Manual.



20



Upgrading Medium Voltage to 23kV

- The voltage upgrading of medium voltage systems was preliminary studied and its technical guideline was recommended in the Manual.
- It can be found out that in some cases the application of 23 kV may be superior to 13.2 kV from the economic point of view.
- We recommend that the detailed studies should be implemented for the evaluation of the candidate sites of 23 kV upgrading regarding their feasibility, costs and benefits brought by loss reduction.



21


An Example of 23kV Upgrading

22



Effects of 23kV Upgrading

- We can expect,
 - The Technical Loss Reduction
 - Max. 60% down for MV System (20% for Whole System)
 - The Extension of Power Supply Area
 - Max. 70% up (Improvement of Voltage Drop)
 - The Capacity Reinforcement
 - Max. 70% up per feeder (In terms of Supply Power)



23


23kV Upgrading

24

Application of Amorphous Transformers

- The amorphous transformer pilot project has been executed. Its effects on loss reduction could be confirmed.
- We recommend that the installation of amorphous transformers should be promoted in all the ECs with their adequate economic evaluation.



25

Thank you!




26

Final Work Shop on "The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's)"

Economical Evaluation for Technical Loss Reduction

Takayuki Shibata / JICA TA TEAM
28th February, 2013




27

Interactive Four Step Management

Objectives of economical analysis


- Ascertain whether the investment in a planned project is valid from financial aspects.
- Ascertain whether an ongoing project is operating as effectively as planned.



©2013 The JICA TA TEAM. All Rights Reserved.

28

Project Assessment





©2013 The JICA TA TEAM. All Rights Reserved.

29

Rough Benefit Estimation for Loss Reduction

Quick benefit estimation

Cost saving (=loss reduction value) is estimated by loss reduction (kW) at peak.

©2013 The JICA TA TEAM. All Rights Reserved.



30

Rough Benefit Estimation for Loss Reduction

Loss reduction value can be obtained using 1 kW loss reduction value (Php/kW) easily

Benefit (Net Present Value etc.) = Loss reduction value for multiple years (Php) - Countermeasure cost for loss reduction (Php)

1 kW Loss reduction value for multiple years (Php/kW) × Loss reduction at peak (kW)

©2013 The JICA TA TEAM. All Rights Reserved.

31

Rough Benefit Estimation for Loss Reduction

Input

kWh loss reduction per year

kW loss reduction at peak (kW) × Loss factor × 8760 hours × Unit price (Php/kWh)

Loss Factor = 0.15 × Load Factor + 0.85 × (Load Factor)²


Load Factor = Average Load (kW) / Peak Load (kW)

Output

Yearly Loss reduction value (Php/year)

Loss reduction value for multiple years (Php)

*NEA Engineering Bulletin IX23480



©2013 The JICA TA TEAM. All Rights Reserved.

32

Example of Economical Analysis

| | |
|------------------------|-------------------|
| Line Type : 1/0 | Line Type : 4/0 |
| Length : 200m | Length : 200m |
| O.R. : 90% (207A) | O.R. : 61% (207A) |
| Loss : 3.98kW | Loss : 2.10kW |
| O.R. : Operation Ratio | |

Cost for Measure

| | |
|-------------------------------|------------|
| Construction Fee : 4/0 * 200m | 44,087 Php |
| Removal Fee : 1/0 * 200m | 1,860 Php |
| Subtotal : 45,947 Php | |

Benefit for Loss Reduction

| | |
|--|-------------|
| Benefit : 1.88kW | 368,725 Php |
| Subtotal of 16y NPV : 868,725 Php | |
| Total Effect : 822,778 Php | |

Unit Price/kWh : 5,000/kWh
Interest Rate : 10%
Inflation Rate : 3%
Annual Load Growth : 4%

Economical Analysis (Payback Period)

<Example> Line reinforcement from 1/0 (90%) to 4/0 (61%)

| Year | 0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 |
|----------------------------------|---|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|----------|----------|----------|----------|
| Line reinforcement value (P) | 0 | 27,437 | 30,566 | 34,052 | 37,936 | 42,262 | 47,082 | 52,445 | 58,414 | 65,069 | 72,491 | 80,782 | 89,942 | 100,000 | 111,000 | 123,000 | 136,000 |
| Construction fee (P) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Benefit (B) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Net Cash Flow (C) | 0 | -27,437 | -30,566 | -34,052 | -37,936 | -42,262 | -47,082 | -52,445 | -58,414 | -65,069 | -72,491 | -80,782 | -89,942 | -100,000 | -111,000 | -123,000 | -136,000 |
| Discounted Cash Flow (C/(1+r)^t) | 0 | -25,947 | -28,947 | -32,052 | -35,262 | -38,662 | -42,362 | -46,414 | -50,882 | -55,742 | -60,982 | -66,602 | -72,612 | -79,012 | -85,812 | -93,012 | -100,612 |
| NPV (C/(1+r)^t) | 0 | -25,947 | -28,947 | -32,052 | -35,262 | -38,662 | -42,362 | -46,414 | -50,882 | -55,742 | -60,982 | -66,602 | -72,612 | -79,012 | -85,812 | -93,012 | -100,612 |

CF₁ = 27,437 [Php] < 45,947 [Php]
CF₁+P₁ = **58,008 [Php]** > 45,947 [Php]

The expected payback period is "2 years"

Economical Analysis (Net Present Value)

<Example> Line reinforcement from 1/0 (90%) to 4/0 (61%)

Discounted at 10% as discount rate

$$\sum_{t=0}^{16} C_t / (1+r)^t = -45,947 + 27,437/(1.1) + 30,566/(1.1)^2 + \dots + 77,730/(1.1)^{16} = \mathbf{+822,778 [Php]} > 0$$

Taking into account the value of time, the expected cash flow in the future is discounted into "present value" with "discount rate"

The sum of present value is positive (+822,778)
The return of this project will satisfy investors' expectation

Economical Analysis (IRR)

<Example> Line reinforcement from 1/0 (90%) to 4/0 (61%)

| Year | 0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 |
|----------------------------------|---|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|----------|----------|----------|----------|
| Line reinforcement value (P) | 0 | 27,437 | 30,566 | 34,052 | 37,936 | 42,262 | 47,082 | 52,445 | 58,414 | 65,069 | 72,491 | 80,782 | 89,942 | 100,000 | 111,000 | 123,000 | 136,000 |
| Construction fee (P) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Benefit (B) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Net Cash Flow (C) | 0 | -27,437 | -30,566 | -34,052 | -37,936 | -42,262 | -47,082 | -52,445 | -58,414 | -65,069 | -72,491 | -80,782 | -89,942 | -100,000 | -111,000 | -123,000 | -136,000 |
| Discounted Cash Flow (C/(1+r)^t) | 0 | -25,947 | -28,947 | -32,052 | -35,262 | -38,662 | -42,362 | -46,414 | -50,882 | -55,742 | -60,982 | -66,602 | -72,612 | -79,012 | -85,812 | -93,012 | -100,612 |
| NPV (C/(1+r)^t) | 0 | -25,947 | -28,947 | -32,052 | -35,262 | -38,662 | -42,362 | -46,414 | -50,882 | -55,742 | -60,982 | -66,602 | -72,612 | -79,012 | -85,812 | -93,012 | -100,612 |

Discounted at "r" as discount rate

$$\sum_{t=0}^{16} C_t / (1+r)^t = -45,947 + 27,437/(1+r) + 30,566/(1+r)^2 + \dots + 77,730/(1+r)^{16} = 0$$

r = 70.8%

IRR (Internal Rate of Return) is a discount rate that results in net present value of zero for a series of cash flow

IRR is greater than the discount rate (10%)
The Project is attractive to investors

Thank you for your attention!

1. Contents of Chapter 3

Chapter 3

- Title
- Methodology of O&M for Data Arrangement of Loss Analysis
- Composition of this chapter
 - 3.1. Network data
 - 3.2. Load data

Final Work Shop on "The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's)"

Methodology of O&M for Data Arrangement of Loss Analysis
Identifying Countermeasures against Technical Losses for the Low Voltage System

Junichi OHISHI / JICA TA Team
28th February, 2013

Contents of This Presentation

- Contents of Chapter 3
- Outline of Chapter 3
- Brief Explanation of Ch.3
- Contents of Chapter 4
- Outline of Chapter 4
- Brief Explanation of Ch.4
- Contents of Chapter 7
- Brief Explanation of Ch.7

2. Outline of Chapter 3

- Outline
- Methodology about O&M of data for loss analysis is explained in this chapter.
- Image of Technical Loss Calculation

3. Brief Explanation of Ch. 3

Section 3.1 Network Data

- Examples of Network Data
 - DSL data
 - GIS Mapping data
 - AutoCAD data
 - SynerGEE data

Model of Actual System

The actual system will be changed by daily construction works
New connections, Repair works etc.

Properly Update

3. Brief Explanation of Ch. 3

General Work Flow of Data O&M Work

```

graph TD
    A[Construction Division] --> B[New Connection / Repair Work / Data Difference]
    B --> C[Addition / Modification]
    C --> D[Revision Requiring Data]
    D --> E[Data Collection]
    E --> F[Data Addition / Modification]
    F --> G[Update Confirmation]
    G --> H[Revision Completion]
    H --> I[Design / Construction / Division Maintenance]
    I --> A
  
```

Periodic Work: Daily or Weekly or Monthly

3. Brief Explanation of Ch. 3

Section 3.2 Load Data

- Examples of Load Data
 - Customer's Energy Consumption Data
 - Feeder Current Data of Distribution Lines
 - Distribution Transformer Load Data
- Measured by Measurement Devices Recorded by Engineering Staff

Two Important Items

- Proper Data Record and Storage
- Time Consistency of Facilities and Data

3. Brief Explanation of Ch. 3

Section 4.1

Methodology of calculation of operating status of low voltage system

Methodology based on the DSL data

- How to calculate operating status of low voltage system
- This section is based on the DSL data

Possible to obtain necessary information

- Operation ratio of facilities
- Composition of facilities, etc.

4. Contents of Chapter 4

Chapter 4

- Title
- Identifying Countermeasures against Technical Losses for Low Voltage System
- Composition of this chapter
 - 4.1. Methodology of calculation of operating status of low voltage system
 - 4.2. Options of countermeasures against technical losses caused in low voltage system
 - 4.3. Criteria of countermeasures against technical loss reduction
 - 4.4. Recommended capacity of transformer and size of electric wire
 - 4.5. Installation of amorphous using transformer

5. Outline of Chapter 4

Image of composition image of DSL data

```

graph TD
    A[MV Bus ID] --> B[Source distribution transformer]
    B --> C[Source secondary line]
    C --> D[Customer ID]
    D --> E[Service Drop]
    E --> F[LV Bus ID]
    F --> G[LV Bus ID]
    G --> H[LV Bus ID]
    H --> I[LV Bus ID]
  
```

Service drop line data

Confirm the connecting secondary line

Secondary line data

Connecting the secondary line -> Distribution transformer

5. Outline of Chapter 4

Outline

Countermeasures against technical losses for low voltage system is explained in this chapter.

Section 1

It is important to grasp operating status of low voltage system.

- Possible to find out facilities which need loss reduction

Two(2) methodologies are explained in this section.

- Methodology based on DSL data
- Methodology based on SynerGEE data -> Chapter 7

Section 2

General countermeasures are explained in this section.

- Explanation of each countermeasure

6. Brief Explanation of Ch. 4

Section 4.1

Methodology of calculation of operating status of low voltage system

Methodology based on the DSL data

- How to calculate operating status of low voltage system
- This section is based on the DSL data

Possible to obtain necessary information

- Operation ratio of facilities
- Composition of facilities, etc.

6. Brief Explanation of Ch. 4

Section 4.1

Methodology of calculation of operating status of low voltage system


Methodology based on the DSL data

- How to calculate operating status of low voltage system
- This section is based on the DSL data

Possible to obtain necessary information

- Operation ratio of facilities
- Composition of facilities, etc.

6. Brief Explanation of Ch. 4



6. Brief Explanation of Ch. 4

◆ Section 4.2
Options of countermeasures against technical losses caused in the low voltage system


● Table of Countermeasures

| Category | Countermeasure | Target Facilities |
|--------------------------|-------------------|--------------------------------|
| LV Line | Line Thickening | High Operation |
| Combination DT & LV Line | Capacity Changing | Small -> Big High Operation |
| | Load Dividing | Big -> Small Low Operation |
| | Load Centering | High Operation |
| | Load Centering | High Operation |

6. Brief Explanation of Ch. 4

Example : Load Dividing

- Divide load of Tr and LV line (add a same capacity Tr)
- For High operation ratio Tr and/or LV line
- Lower operation ratio of Tr and LV line



7. Contents of Chapter 7

Chapter 7

- ◆ Title Using SynerGEE
- ◆ Composition of this chapter

- 7.1. Confirming the operating status of the distribution system **My part**
- 7.2. Procedure of load allocation
- 7.3. Power flow analysis
- 7.4. Method of capacitor placement using SynerGEE **Mr. Fujitani's part**
- 7.5. Method of switching optimization using SynerGEE
- 7.6. Load balancing improvement using SynerGEE
- 7.7. Phase balancing improvement using SynerGEE

8. Brief Explanation of Ch. 7

◆ Section 7.1
Options of countermeasures against technical losses caused in the low voltage system


● Composition of this section

1. Implementation of load flow by SynerGEE
2. Confirmation of operating status of distribution transformer
3. Confirmation of operating status of low voltage line

↓
Possible to obtain same information of Sec. 4.1. by using SynerGEE

- Operation ratio of facilities
- Composition of facilities etc.

8. Brief Explanation of Ch. 7



Final Work Shop on "The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's)"

Economical Sizing of the Transformer and the Electric Wire of the Low Voltage System - Introduction of AMDT Pilot Project-

KEN Kuwahara / JICA TA Team

28th February, 2013



Loss Reduction of Low Voltage Facilities


Contents

1. The study of economical sizing for transformer
2. The study of economical sizing for Low voltage line
3. The Pilot Study of Introduction AMDT

Concept to have Effective Low Voltage Facilities

- 1) Minimize the failures caused by overloaded conditions
- 2) Reduced core losses (Non-load losses) from inappropriate size
- 3) Reduced Copper losses (load losses) from inappropriate size
- 4) Minimize voltage fluctuation
- 5) Reduced voltage drop

Aged Power Transformer Condition



Permissible Overload of Transformer

| Hours of Peak Load | Ambient in Degrees C | | | | | |
|--------------------|----------------------|------|------|------|------|------|
| | 0°C | 10°C | 20°C | 30°C | 40°C | 50°C |
| 1/2 | 200% | 200% | 200% | 200% | 194% | 178% |
| 1 | 200% | 200% | 195% | 183% | 169% | 155% |
| 2 | 189% | 179% | 169% | 157% | 145% | 131% |
| 4 | 162% | 154% | 145% | 134% | 123% | 111% |
| 8 | 145% | 136% | 127% | 118% | 108% | 97% |
| 24 | 128% | 122% | 111% | 102% | 92% | 81% |



Economical Sizing for Pole Transformer


| Transformer Capacity Size (kVA) | Actual Copper Loss (kW) (1) | Energy Loss (kWh) (2) | Annual Cost of Energy Loss (PHP) (3) | PW Cost of Energy Loss (PHP) (4) |
|---------------------------------|-----------------------------|-----------------------|--------------------------------------|----------------------------------|
| 10kVA | 0.83 | 3,013 | 15,065 | 142,016 |
| 15 kVA | 0.42 | 1,560 | 7,843 | 77,192 |
| 25 kVA | 0.21 | 1,381 | 6,905 | 67,097 |
| 37.5 kVA | 0.13 | 1,363 | 6,815 | 64,245 |

(1) Annual Copper Loss (kW) = (Peak Load)² / Transformer Capacity (kVA)² × Rated Copper Loss (W)
 (2) Energy Loss (kWh) = Actual Copper Loss (kW) × Loss Factor (%) × Core Loss (W) × 8760hrs
 (3) Annual Cost of Energy Loss (PHP) = Energy Loss (kWh) × Unit price (PHP/kWh)
 (4) PW Cost of Energy Loss (PHP) for 30 years = Annual Cost of Energy Loss (PHP) × (1+10%)³⁰ / (1+10%)³⁰ - 1

| Transformer Size (kVA) | Initial Cost (PHP) (1) | PW O&M Cost (PHP) (2) | PW Cost of Energy Loss (PHP) (3) | PW Cost (PHP) (4) |
|------------------------|------------------------|-----------------------|----------------------------------|-------------------|
| 10kVA | 13,688 | 50,517 | 142,016 | 206,221 |
| 15 kVA | 19,598 | 34,804 | 77,192 | 175,494 |
| 25 kVA | 25,515 | 20,123 | 65,097 | 150,737 |
| 37.5 kVA | 104,310 | 88,218 | 64,245 | 256,773 |


(1) PW O&M cost = (Initial Cost × 10%) × ((1+10%)³⁰ - 1) / (1+10%)³⁰ - 1

Result of the Case Study of TR Sizing



Summary : Economical Transformer Sizing

Summary : Economical Transformer Sizing



Low Voltage Wire Selection Method

Precondition

| | |
|----------------------|----------|
| Existing line size | ACSR 110 |
| Existing line length | 100m |
| Operation ratio | 35% |
| Evaluation period | 5 years |

Loss of ACSR 110 Wire at 100m = 0.250 D/km × (230A × 0.33)² / 0.1km = 317 W
 Loss of ACSR 210 Wire at 100m = 0.248 D/km × (230A × 0.33)² / 0.1km = 251 W
 Loss of ACSR 310 Wire at 100m = 0.246 D/km × (230A × 0.33)² / 0.1km = 199 W
 Loss of ACSR 410 Wire at 100m = 0.274 D/km × (230A × 0.33)² / 0.1km = 158 W

Result of the case study

| Change | Loss reduction value (PHP) | Construction fee (PHP) | Benefit (PHP) |
|----------------------------------|----------------------------|------------------------|---------------|
| Changing from ACSR110 to ACSR210 | 5,454 | 8,028 | -3,224 |
| Changing from ACSR110 to ACSR310 | 9,718 | 9,227 | 451 |
| Changing from ACSR110 to ACSR410 | 13,084 | 12,891 | 95 |

Summary : Economical LV Wire Sizing

Methodology of DT Valuation

TOC : Total Owning Cost

$$TOC = \text{Price of DT} + \text{Loss Valuation}^* \text{ of DT}$$

Initial Cost Running Cost

Loss Valuation (LV) of DT = LV of Iron Core + LV of Winding

LV of Iron Core = A* × No Load Loss
 LV of Winding = B* × Load Loss

*A and B are factors which reflect investment plan, fuel cost, etc.

Composition of DT Price






DT is valued by not only the price of DT but also the amount of DT loss

Evaluation of AMDT Model Project

REPLACEMENT AMDT from existing SiFe DT

About 20% loss reductions are expected

| Item | Existing | AMDT | Reduction |
|--------------|----------|------|-----------|
| Core Loss | 1500 | 1200 | 20% |
| Copper Loss | 3000 | 2400 | 20% |
| Winding Loss | 1000 | 800 | 20% |
| Total Loss | 5500 | 4400 | 20% |



Final Work Shop on "The Project on System Loss Reduction for Philippine Electric Cooperatives (EC's)"

Identifying Countermeasures against Technical Losses for Medium Voltage System








Keiichi Fujitani / JICA TA TEAM
28th February, 2013

1. Method of Loss Reduction for Medium Voltage Line
2. Criteria for Taking Countermeasures against Technical Loss Reduction in the Medium Voltage System
3. Result of Study on Loss Reduction Project
4. Sample Analysis of Loss Reduction for MV Line using SynerGEE at FLECO

Method of Loss Reduction for Medium Voltage Line

1.1 Method of Loss Reduction for Medium Voltage Line

| Category | Countermeasure | Target Facilities | Remarks | |
|----------|----------------|---------------------------------|------------------------------|--|
| Line | MV Line | Line Thickening | High Operation | |
| | | Parallel Circuit | High Operation | |
| | | Upgrading Voltage | High Operation | Requiring some amount of investment on facilities to reduce power losses |
| | | Capacitor Placement/Replacement | Low Power Factor line | |
| | | Phase Increasing | High Operation | |
| | | Load Balancing | Unbalance line | Carrying out with small amount expenses through shilly work |
| | | Switching Optimization | Multi-interconnection system | Effective method for multi-interconnection system |



1. Method of Loss Reduction for Medium Voltage Line
2. Criteria for Taking Countermeasures against Technical Loss Reduction in the Medium Voltage System
3. Result of Study on Loss Reduction Project
4. Sample Analysis of Loss Reduction for MV Line using SynerGEE at FLECO

Criteria for Taking Countermeasures against Technical Loss Reduction in the Medium Voltage System

2.1 Conditions of study on medium voltage system

| | |
|---------------------------|--|
| Economic Evaluation Study | 5 years / 15 years |
| Load Factor | 0.57 |
| Unit Price per kWh | 5 PHP/kWh |
| Inflation Rate | 3% |
| Annual Growth Rate | 4% |
| Discount Rate | 10% |
| kW Value of load loss | 82,291 PHP(5 years) / 237,166 PHP(15 years) |
| kW Value of core loss | 180,573 PHP(5 years) / 404,115 PHP(15 years) |

The construction costs are calculated via the MATDX (FY2010)

Criteria for Taking Countermeasures against Technical Loss Reduction in the Medium Voltage System

2.2 Study example (Line Thickening)

Line Type : ACSR 2/0
Length : 1 km
Operation Ratio : 40%

Line Type : ACSR 4/0 or 3/36
Length : 1 km

* The loss reduction value and the construction fee, which include removable fee and OM cost for 15 years

| | Loss reduction value (PHP) | Construction fee (PHP) | Benefit (PHP) |
|-----------------------------------|----------------------------|------------------------|---------------|
| Not change | 0 | 0 | 0 |
| Changing from ACSR2/0 to ACSR4/0 | 448,171 | 293,107 | 155,064 |
| Changing from ACSR2/0 to ACSR3/36 | 727,838 | 485,724 | 241,814 |

The line thickening from the ACSR2/0 size line to ACSR3/36 size line is most effective in this case.



©2013 The JICA TA TEAM. All Rights Reserved.


1. Method of Loss Reduction for Medium Voltage Line
2. Criteria for Taking Countermeasures against Technical Loss Reduction in the Medium Voltage System
3. Result of Study on Loss Reduction Project
4. Sample Analysis of Loss Reduction for MV Line using SynerGEE at FLECO



©2013 The JICA TA TEAM. All Rights Reserved.

Result of Study on Loss Reduction Project

3.1 Appropriate Line Thickening conductor sizes




* The loss reduction value and the construction fee, which include removable fee and OM cost for 15 years



©2013 The JICA TA TEAM. All Rights Reserved.

Result of Study on Loss Reduction Project

3.2 Appropriate conductor sizes of parallel circuit




* The loss reduction value and the construction fee, which include removable fee and OM cost for 15 years



©2013 The JICA TA TEAM. All Rights Reserved.

Result of Study on Loss Reduction Project

3.3 Appropriate phase number




* The loss reduction value and the construction fee, which include removable fee and OM cost for 15 years



©2013 The JICA TA TEAM. All Rights Reserved.

Result of Study on Loss Reduction Project

3.4 Appropriate voltage for newly installed transformer



* The loss reduction value and the construction fee, which include removable fee and OM cost for 5 and 15 years




©2013 The JICA TA TEAM. All Rights Reserved.

1. Method of Loss Reduction for Medium Voltage Line
2. Criteria for Taking Countermeasures against Technical Loss Reduction in the Medium Voltage System
3. Result of Study on Loss Reduction Project
4. Sample Analysis of Loss Reduction for MV Line using SynerGEE at FLECO



Sample Analysis of Loss Reduction for MV Line using SynerGEE at FLECO

4.1 Model of Sample Analysis (1)



©2013 The JICA TA TEAM. All Rights Reserved.

Sample Analysis of Loss Reduction for MV Line using SynerGEE at FLECO

4.1 Model of Sample Analysis (2)



©2013 The JICA TA TEAM. All Rights Reserved.

Sample Analysis of Loss Reduction for MV Line using SynerGEE at FLECO

4.2 Result of Sample Analysis before countermeasure (Using SynerGEE Load Flow analysis)

| Feeder | Feeder Name | Substation | Demand | Impedance | Loss | Loss/W | Loss/W (Total) | | |
|--------|-------------|------------|--------|-----------|--------|--------|----------------|-------|-----|
| F1 | Papaganan | Lumban2 | 1,270 | 1,480 | 2,784 | 119 | 145 | 119 | 45 |
| F2 | Lumban | Lumban2 | 1,001 | 620 | 1,178 | 53 | 23 | 139 | 7 |
| F3 | Kalayan | Lumban2 | 770 | 477 | 858 | 48 | 35 | 457 | 24 |
| F4 | Cairan | Lumban2 | 786 | 485 | 629 | 41 | 40 | 7,655 | 42 |
| F5 | PasirPasar | Paki | 1,579 | 877 | 1,857 | 83 | 57 | 3,633 | 28 |
| F6 | Pangal | Paki | 727 | 460 | 656 | 37 | 18 | 2,445 | 11 |
| F7 | SindayPany | Mabatoc | 1,234 | 1,250 | 2,392 | 104 | 77 | 3,800 | 41 |
| F8 | MabatocMain | Mabatoc | 1,689 | 1,044 | 1,993 | 88 | 77 | 4,514 | 34 |
| Total | | | 10,353 | 6,772 | 12,978 | 489 | 489 | 289 | 201 |



©2013 The JICA TA TEAM. All Rights Reserved.

Sample Analysis of Loss Reduction for MV Line using SynerGEE at FLECO

4.3 Necessary countermeasure for loss reduction (Line Thickening base on manual)

| Feeder | Feeder Name | Existing Line Size | Percentage Load/Impedance | Phase | New Line Size | Percentage Load/Impedance | Length |
|--------|-------------|--------------------|---------------------------|--------|---------------|---------------------------|--------|
| F1 | Papaganan | 2/0 ACSR | about 40% | three | 3/36 ACSR | about 19.3% | 4,534 |
| F2 | Lumban | 2/0 ACSR | about 20 | three | - | - | - |
| F3 | Kalayan | 1/0 ACSR | about 20 | single | - | - | - |
| F4 | Cairan | 2/0 ACSR | about 15 | three | - | - | - |
| F5 | PasirPasar | 2/0 ACSR | about 23 | three | - | - | - |
| F6 | Pangal | 2/0 ACSR | about 15 | three | - | - | - |
| F7 | SindayPany | 2/0 ACSR | about 34.37 | three | 3/36 ACSR | about 17.29 | 1,425 |
| F8 | MabatocMain | 2 ACSR | about 43.45 | three | 4/0 ACSR | about 23.24 | 189 |



©2013 The JICA TA TEAM. All Rights Reserved.

Sample Analysis of Loss Reduction for MV Line using SynerGEE at FLECO

4.4 Result of Sample Analysis after countermeasure (Line Thickening base on manual)

| Feeder | Feeder Name | Substation | Demand | Impedance | Loss | Loss/W | Loss/W (Total) | | |
|--------|-------------|------------|--------|-----------|--------|--------|----------------|------|-----|
| F1 | Papaganan | Lumban2 | 2,363 | 1,470 | 2,783 | 119 | 90 | 3,73 | 43 |
| F2 | Lumban | Lumban2 | 2,001 | 620 | 1,178 | 53 | 23 | 1,99 | 7 |
| F3 | Kalayan | Lumban2 | 770 | 477 | 905 | 40 | 35 | 4,57 | 24 |
| F4 | Cairan | Lumban2 | 786 | 485 | 823 | 41 | 40 | 7,65 | 42 |
| F5 | PasirPasar | Paki | 879 | 877 | 1,857 | 40 | 47 | 3,63 | 28 |
| F6 | Pangal | Paki | 727 | 460 | 855 | 37 | 18 | 2,45 | 11 |
| F7 | SindayPany | Mabatoc | 2,030 | 1,251 | 2,390 | 104 | 45 | 2,94 | 23 |
| F8 | MabatocMain | Mabatoc | 1,688 | 1,045 | 1,989 | 86 | 47 | 4,46 | 40 |
| Total | | | 10,941 | 6,764 | 12,874 | 414 | 414 | 212 | 203 |



©2013 The JICA TA TEAM. All Rights Reserved.

Sample Analysis of Loss Reduction for MV Line using SynerGEE at FLECO

4.5 Effect of countermeasure for loss reduction (Line Thickening)

● Cost for Measure
Construction Fee : 4/0 * 189m = 85,515 PHP
3/36 * 4,959m = 3,789,974 PHP
Removal Fee : 2 * 189m = 2,758 PHP
2/0 * 4,959m = 120,285 PHP
Subtotal : 3,948,632 PHP

(Construction Fee: 4/0(3-phase) 452,458 PHP/km
3/36(3-phase) 754,179 PHP/km
2/0(3-phase) 14,500 PHP/km
2/0(3-phase) 24,256 PHP/km)

● Amount of Money for Loss Reduction (result from SynerGEE)
Loss Reduction : 75kW = 17,787,450 PHP
*Total loss reduction value: 237,169 PHP/kW
(Before: 489kW After: 414kW) Subtotal : 17,787,450 PHP
Total Effect : 13,838,918 PHP



©2013 The JICA TA TEAM. All Rights Reserved.

Sample Analysis of Loss Reduction for MV Line using SynerGEE at FLECO

4.6 Necessary countermeasure for loss reduction (Capacitor Setting using SynerGEE Capacitor Placement)

| Feeder | Feeder Name | Substation | PF before | Capacitor Size | PF after | PF after |
|--------|-------------|------------|-----------|----------------|----------|----------|
| F1 | Papaganan | Lumban2 | 85 | 850 | 86 | 86 |
| F2 | Lumban | Lumban2 | 85 | 850 | 130 | 86 |
| F3 | Kalayan | Lumban2 | 87 | 850 | 145 | 87 |
| F4 | Cairan | Lumban2 | 85 | 850 | 84 | 85 |
| F5 | PasirPasar | Paki | 85 | 850 | 84 | 85 |
| F6 | Pangal | Paki | 85 | 850 | 142 | 86 |
| F7 | SindayPany | Mabatoc | 87 | 850 | 80 | 87 |
| F8 | MabatocMain | Mabatoc | 84 | 850 | 81 | 84 |



©2013 The JICA TA TEAM. All Rights Reserved.

Sample Analysis of Loss Reduction for MV Line using SynerGEE at FLECO

4.7 Result of Sample Analysis after setting Capacitor

| Feeder | Feeder Name | Substation | Demand | Impedance | Loss | Loss/W | Loss/W (Total) | | |
|--------|-------------|------------|--------|-----------|--------|--------|----------------|------|-----|
| F1 | Papaganan | Lumban2 | 2,363 | 1,028 | 2,285 | 110 | 14.4 | 3,46 | 11 |
| F2 | Lumban | Lumban2 | 1,991 | 1,019 | 1,178 | 45 | 19 | 1,97 | 7 |
| F3 | Kalayan | Lumban2 | 770 | 476 | 854 | 36 | 31 | 3,39 | 15 |
| F4 | Cairan | Lumban2 | 786 | 484 | 823 | 35 | 35 | 3,39 | 15 |
| F5 | PasirPasar | Paki | 1,699 | 831 | 1,869 | 72 | 51 | 3,25 | 21 |
| F6 | Pangal | Paki | 727 | 463 | 811 | 32 | 17 | 2,33 | 11 |
| F7 | SindayPany | Mabatoc | 2,033 | 823 | 2,134 | 96 | 41 | 3,49 | 34 |
| F8 | MabatocMain | Mabatoc | 1,689 | 1,019 | 1,989 | 86 | 47 | 4,45 | 40 |
| Total | | | 10,955 | 5,752 | 11,833 | 430 | 430 | 257 | 203 |



©2013 The JICA TA TEAM. All Rights Reserved.

Sample Analysis of Loss Reduction for MV Line using SynerGEE at FLECO

4.8 Effect of setting Capacitor

● Cost for Measure
Construction Fee : 150var * 1 = 60,083 PHP
300var * 1 = 72,601 PHP
450var * 6 = 483,480 PHP
Subtotal : 616,164 PHP

(Construction Fee: 150var(3-phase) 60,083 PHP/set
300var(3-phase) 72,601 PHP/set
450var(3-phase) 80,580 PHP/set)

● Amount of Money for Loss Reduction (result from SynerGEE)
Loss Reduction : 49kW = 11,621,134 PHP
*Total loss reduction value: 237,169 PHP/kW
(Before: 489kW After: 440kW) Subtotal : 11,621,134 PHP
Total Effect : 11,004,970 PHP



©2013 The JICA TA TEAM. All Rights Reserved.

Thank you for your attention!