

A- 8 Soils Investigation Report and Topographic Survey

REPORT

Yachiyo Engineering Co Ltd. and West Japan Engineering Consultants, Inc. JV

Preparation Survey on the Project for Introduction of a Micro-Grid System with Renewable Energy for the Tonga Energy Road Map in the Kingdom of Tonga

Soils Investigation Report

Table of contents

1	Introduction	1
1.1	General	1
1.2	Project Description	1
2	Site Description	1
3	Summary of Site Survey	1
4	Summary of Soils Investigation	2
4.1	General	2
4.2	Handauger and Scala Penetrometer Investigations	2
4.2.1	Site A - Popua power station	2
4.2.2	Site B - Vaini	2
4.3	Geotechnical Laboratory Schedule	3
5	Subsurface Conditions	3
5.1	Geological Setting	3
5.2	Ground and Groundwater Conditions	4
5.2.1	Site A - Popua Power Station	4
5.2.2	Site B - Vaini	5
6	Geotechnical Laboratory Testing Results	6
7	Discussion and Engineering Properties	6
7.1	Solid Density Range	6
7.1.1	Site A - Popua Power Station	6
7.1.2	Site B - Vaini	7
7.2	Effective Cohesion (c')	7
7.2.1	Site A - Popua Power Station	7
7.2.2	Site B - Vaini	7
7.3	Effective Internal Friction Angle (ϕ)	7
7.3.1	Site A - Popua Power Station	7
7.3.2	Site B - Vaini	7
7.4	Young's Modulus Range (E)	8
7.4.1	Site A - Popua Power Station	8
7.4.2	Site B - Vaini	8
7.5	Foundation Design	8
7.5.1	General	8
7.5.2	Site A - Popua Power Station	9
7.5.3	Site B - Vaini	9
7.6	Settlement	9
8	Applicability	10
Appendix A:	Contract of Soils Explorations	
Appendix B:	Topographical Survey and Geotechnical Investigation Location Plans	
Appendix C:	Site A - Investigation Logs and Geotechnical Laboratory Testing	
Appendix D:	Site B - Investigation Logs and Geotechnical Laboratory Testing	
Appendix E:	Scala Penetrometer /SPT 'N' Value Conversion Chart	

Report prepared for:

Yachiyo Engineering Co Ltd. and West Japan Engineering Consultants, Inc. JV

Report prepared by:

Tonkin & Taylor International Ltd

Distribution:

Yachiyo Engineering Co Ltd/ West Japan Engineering Consultants, Inc. JV 3 copies

Tonkin & Taylor International Ltd (FILE) 1 copy

October 2012.

T&T Ref: 750932

4 Summary of Soils Investigation

4.1 General

The soils investigations were carried out in September 2012 and the scope of work was completed in accordance with the "Contract Soil Explorations" attached in Appendix A.

The following tasks were completed for the soils investigation:

- Site A - Popua power station
 - 6 No. Hand auger boreholes (BH1A – BH6A) to 1.9m below existing ground level
 - 6 No. Scala penetrometer tests (SC1A – SC6A) to 3m below existing ground level
- Site B - Vaini
 - 8 No. Hand auger boreholes (BH1B – BH6B) to 3m below existing ground level
 - 12 No. Scala penetrometer tests (SC1B – SC6B) to 3m below existing ground level

The subsections below present a summary of the investigation work and laboratory testing results. Site investigation logs are presented in Appendix C and laboratory testing results are presented in Appendix D.

4.2 Handauger and Scala Penetrometer Investigations

The soil investigation testing, including hand augered boreholes and Scala penetrometer tests, was undertaken over three days (26-28 September 2012) at Popua power station and at the new solar power station site in Vaini. In the hand auger boreholes in-situ shear strength testing was carried out in cohesive materials using a calibrated Pilcon shear vane and samples were taken for geotechnical laboratory testing. The subsurface soils were described and shear strengths are recorded on the borehole logs presented in Appendix C. The Scala penetrometer provides continuous soil strength data until hard ground/refusal is achieved (8 to 10 blows per 50mm penetration). The results of the Scala penetrometer tests are included in Appendix C.

4.2.1 Site A - Popua power station

Six hand auger boreholes and six Scala penetrometer tests were completed at this site on 26 September 2012. The hand auger boreholes could only be drilled to a depth of up to 2m below existing ground level due to dense gravely sands that were encountered. Groundwater was encountered at 1m below existing ground surface in each of the hand augers. The Scala penetrometer tests were terminated at depths of up to 3m below ground level.

4.2.2 Site B - Vaini

Eight hand auger boreholes and twelve scala penetrometer tests were completed at this site on 27 and 28 September 2012. The hand auger boreholes were drilled to a depth of up to 3.6m below existing ground level. No ground water was encountered in any of the boreholes. The Scala penetrometer tests were terminated at depths of up to 3m below ground level.

The precise test locations and co-ordinates are presented in the Survey report in Appendix B. The investigations were completed over a period of three days and were undertaken by an Engineering Geologist from T&T, Mr Conor Morrison.

1 Introduction

1.1 General

Yachyo Engineering Co., Ltd (YEC) engaged Tonkin & Taylor International Ltd (T&T) to carry out the soils investigations for a Power storage devices building at Popua and a Photovoltaic array area at Vaini in the Kingdom of Tonga. The investigations were carried out at Popua Power Stations and in Vaini, Tongatapu, Tonga. A topographical survey of the site at Vaini was undertaken by local surveyors, ITS Pacific Ltd.

The investigations have been carried out in accordance with the "Contract of Soil Explorations" provided to T&T by YEC (ref: Appendix A). The soils investigation consisted of 8 hand auger boreholes and 12 Scala penetrometer tests at Popua Power Station and 6 hand auger bore holes along with 6 Scala penetrometer tests at Vaini. Laboratory testing of recovered soil samples from the two sites was also undertaken. This work scope was agreed with YEC. This report summarises the results of the soils investigation carried out at these two sites.

1.2 Project Description

The Kingdom of Tonga consists of 176 islands scattered over 700,000 square kilometres of the southern Pacific Ocean. The capital is Nuku'alofa located on the main island of Tongatapu.

The project involves construction at two separate sites on the island; Power storage devices building for the existing Popua power station and a Photovoltaic array in Vaini. This work is part of a Tonga Energy Road Map for Tongatapu island.

The construction of the new solar power station in Vaini involves constructing a battery building and a series of solar panels covering approximately 23,791 m² of the site.

2 Site Description

The two sites are located on Tongatapu island, Tonga. The existing Popua power station (Site A) is located 3km east of Nuku'alofa on the edge of the lagoon and the new solar power station (Site B) is located in Vaini 6km south of Nuku'alofa.

The existing Popua power station is a diesel power station, situated on relatively flat land on the edge of the lagoon approximately 1.2m above sea level. Solar panels have recently been erected surrounding the power station as part of a renewable energy scheme.

The proposed new solar power station is situated on the outskirts of Vaini on relatively flat land approximately 13m above sea level. At the time of the investigations the site was vegetated with long grass, coconut palms and some large trees.

A site plan and topographic survey is attached in Appendix B.

3 Summary of Site Survey

The topographic survey of both sites were carried out by local surveying company ITS Pacific Ltd in September and October 2012. Each site investigation location was surveyed and the co-ordinates and reduced levels (RL'S) are presented in Appendix B. The topographic survey plans are also presented in Appendix B.

5.2 Ground and Groundwater Conditions

5.2.1 Site A - Popua Power Station

The six hand auger boreholes across the building platform encountered very similar ground conditions and these are summarised in Table 1 below:

Table 1 – Summary of ground conditions

Depth (Below ground level)	Geological unit	Soil description
0.0m – 0.2m	Topsoil	SILT with some clay and minor sand, trace gravel, dark brown, stiff, low plasticity
0.2m – 0.6m	Fill	Gravely SAND with some silt, yellowish white, fine to coarse, angular crushed limestone gravel
0.6m – 1.0m	Estuarine Sediments	Silty fine SAND, dark brown, loose to medium dense, some organics
1.0m - >2.0m	Coral Sand	Coarse SAND with some gravel and minor silt, blue/grey, loose to medium dense, saturated

Groundwater was encountered in all the boreholes at a depth of 1.0m below existing ground level.

The six Scala penetrometer tests SC1A – SC6A were terminated at depths of up to 3m below ground level. From this in-situ testing, we can assess the soil strengths at specific depths below the site. The Scala results and inferred soil strength are summarised in Table 2 below:

Table 2 – Summary of Scala penetrometer results

Depth (Below ground level)	Average Scala Blows per 50mm	Soil Type	Inferred Strength
0.5m	10*	Granular	Very dense*
1.0m	1	Granular	Very loose
1.5m	3	Granular	Medium dense
2.0m	4	Granular	Dense
2.5m	6	Granular	Dense
3.0m	8	Granular	Dense

*Compacted hardfill across majority of site to 0.5m below ground

From the table above, it can be noted that the soil strength increases with depth at the site.

4.3 Geotechnical Laboratory Schedule

The recovered samples were brought back to Auckland and geotechnical laboratory testing was carried out by Geotechnics Ltd. The laboratory tests have been completed in full accordance with the relevant New Zealand standards, identified in the subsections below, and the laboratory is fully accredited with International Accreditation New Zealand (IANZ) registration.

The soil testing consisted of the following:

- Site A - Popua power station
 - Specific Gravity tests (3 No.)
 - Grain size analysis (3 No.)
 - Moisture content test (3 No.)
- Site B - Vaini
 - Specific Gravity tests (2 No.)
 - Grain size analysis (2 No.)
 - Moisture content test (2 No.)

5 Subsurface Conditions

5.1 Geological Setting

The island of Tongatapu is composed of emerged and tilted coral limestones of Pliocene and Quaternary age with a volcanic soil mantle. The geology of the island consists of volcanic soils, coral sand, estuarine deposits and coral limestone (Roy 1990¹).

¹ Peter S. Roy 1990: The morphology and surface Geology of the Islands of Tongatapu and Vava'u, Kingdom of Tonga. Department of Mineral Resources New South Wales Government.

6 Geotechnical Laboratory Testing Results

A summary of the geotechnical laboratory testing results is presented in table 5 below. A full set of the geotechnical testing data sheets is presented in Appendix D.

Table 5 – Summary of geotechnical testing

Sample Identification	Specific Gravity	Grain Size Analysis	Moisture Content
HA3A – 1.2m	2.84 t/m ³	SAND with some shell fragments, minor gravel, minor silt and trace clay	34.3%
HA4A – 1.0m	2.81 t/m ³	SAND with some shell fragments, minor gravel, minor silt and trace clay	56.3%
HA5A – 0.5m	2.75 t/m ³	SAND with some shell fragments, minor gravel, minor silt, trace clay and trace organics	41.1%
HA1B – 1.1m	3.00 t/m ³	Silty CLAY with minor sand, stiff, high plasticity	71.4%
HA3B – 0.6m	2.94 t/m ³	Clayey SILT with some sand, stiff, high plasticity	81.5%

7 Discussion and Engineering Properties

Recommendations and opinions contained in this report are based upon data from:

- 6 No. hand auger boreholes and 6 No. Scala penetrometer tests at Popua power station
- 8 No. hand auger boreholes and 12 No. Scala penetrometer tests at Vaini

The nature and continuity of the subsoil away from the test locations is inferred, but it must be appreciated that actual conditions could vary from the assumed model.

From the results of the soils investigation, geotechnical laboratory testing and also using published empirical relationships, we have assessed the engineering properties for the underlying soils at the two sites for the designer's consideration in the following subsections.

Actual ground conditions should be confirmed by a person competent to judge whether the soils exposed in the foundation excavations are compatible with those described within this report.

7.1 Solid Density Range

7.1.1 Site A - Popua Power Station

The estuarine sediments (0.6m-1m) can be assumed to have the following solid densities:

$$\text{Solid Density} = 2.75 \text{ t/m}^3$$

The coral sand (1m-2m) can be assumed to have the following solid densities:

$$\text{Solid Density range} = 2.81 \text{ to } 2.84 \text{ t/m}^3$$

Preparation Survey on the Project for Introduction of a Micro-Grid System with Renewable Energy for the Tonga Energy Read Map in the Kingdom of Tonga, Soils Investigation Report
Yachiyo Engineering Co Ltd. and West Japan Engineering Consultants, Inc. JV.

T&T Ref. 750932
October 2012

5.2.2 Site B - Vaini

The 8 No. hand auger boreholes across the site encountered very similar ground conditions and these are summarised in Table 3 below.

Table 3 – Summary of ground conditions.

Depth (Below ground level)	Geological unit	Soil description	Soil shear strength (kPa)
0.0m – 0.5m	Topsoil	Clayey SILT, dark brown, stiff to very stiff, moderate plasticity	71 kPa to 186 kPa
0.5m – 2.5m	Volcanic Tuff	Clayey SILT, orange/red brown, very stiff to hard, moist, highly plastic	101 kPa to 223 kPa
2.3m – 2.5m	Coral Sand	Gravelly SAND, yellowish white	N/A
>2.5m	Coral Limestone	No description	N/A

N/A – not applicable

Groundwater was not encountered in any of the boreholes at the site.

The twelve Scala penetrometer tests SC1B – SC12B were terminated at depths of up to 3.1m below ground level. From this in-situ testing, we can assess the soil strengths at specific depths below the site. The Scala results and inferred soil strength are summarised in Table 4 below:

Table 4 – Summary of Scala penetrometer results

Depth (Below ground level)	Average Scala Blows per 50mm	Soil Type	Inferred Strength
0.5m	1	Cohesive	Stiff to Very Stiff
1.0m	2	Cohesive	Very Stiff
1.5m	2	Cohesive	Very Stiff
2.0m	2	Cohesive	Very Stiff
2.5m	20	Cohesive	Very Dense

From the table above, it can be noted that the soil strength increases with depth at the site.

Rather than using the conservative Scala results in the upper 2.5m, it would be beneficial to use the shear strengths recorded in the hand auger boreholes for detailed foundation design. These shear strengths are summarised in Table 4 above.

Preparation Survey on the Project for Introduction of a Micro-Grid System with Renewable Energy for the Tonga Energy Read Map in the Kingdom of Tonga, Soils Investigation Report
Yachiyo Engineering Co Ltd. and West Japan Engineering Consultants, Inc. JV.

T&T Ref. 750932
October 2012

7.1.2 Site B - Vaini

The volcanic tuff (0.5m-2.5m) can be assumed to have the following solid densities:

$$\text{Solid Density range} = 2.94 \text{ to } 3.0 \text{ t/m}^3$$

7.2 Effective Cohesion (c')

7.2.1 Site A - Popua Power Station

The near surface material are granular and therefore have an effective cohesion of 0 kPa.

$$c' \text{ (Effective Cohesion)} = 0 \text{ kPa}$$

7.2.2 Site B - Vaini

The near surface material provides some effective cohesion due to the cohesive nature of the soil. A value of 5 kPa should be used for design.

$$c' \text{ (Effective Cohesion)} = 5 \text{ kPa}$$

7.3 Effective Internal Friction Angle (φ)

7.3.1 Site A - Popua Power Station

The effective internal friction angle for the near surface material (sand) has been estimated using a correlation from the Scaia penetrometer results. A value of 30° should be used as the effective internal friction angle for design.

$$\phi \text{ (Effective internal friction angle)} = 30^\circ$$

7.3.2 Site B - Vaini

The effective internal friction angle for the near surface alluvium (clayey silt) has been estimated using a correlation from the Scaia penetrometer and shear strength results. A value of 30° should be used as the effective internal friction angle for design.

$$\phi \text{ (Effective internal friction angle)} = 30^\circ$$

7.4 Young's Modulus Range (E)

The soil stiffness or Youngs Modulus, E has been calculated from a correlation with SPT N values (Bowles et al) derived from the available shear strength and Scaia penetrometer readings. The table below gives the range of Youngs Modulus values for varying depths.

7.4.1 Site A - Popua Power Station

Table 6 – Summary of Youngs Modulus (E) with depth (granular soils only)

Depth (Below Ground level)	Scaia blows/300mm	Corresponding SPT "N" values	Estimated Young's Modulus, E (MPa)
0.5 m	3	2	6
1.0 m	3	2	6
1.5 m	9	6	18
2.0 m	12	7	22
2.5 m	18	13	38
3.0 m	24	17	50

7.4.2 Site B - Vaini

Table 7 – Summary of Youngs Modulus (E) with depth (cohesive soils only)

Depth (Below Ground level)	Shear strength (kPa)	Estimated Young's Modulus, E (MPa)
0.5 m	120	18
1.0 m	150	25
1.5 m	150	25
2.0 m	170	28

7.5 Foundation Design

7.5.1 General

Following discussions with YEC, it is understood that either strip or pad foundations will be constructed for the two proposed buildings at sites A and B and for the solar panels at Vini, providing the ground conditions are suitable.


The site investigation data has indicated that shallow foundations may be utilised at the two sites depending on actual loadings. We have provided bearing pressures at different depths in the upper 3m.


Preparation Survey on the Project for Introduction of a Micro-Grid System with Renewable Energy for the Tonga Energy Road Map in the Kingdom of Tonga, Soils Investigation Report
Yachiyo Engineering Co Ltd. and West Japan Engineering Consultants, Inc. JV.

Preparation Survey on the Project for Introduction of a Micro-Grid System with Renewable Energy for the Tonga Energy Road Map in the Kingdom of Tonga, Soils Investigation Report
Yachiyo Engineering Co Ltd. and West Japan Engineering Consultants, Inc. JV.

8 Applicability

This report has been prepared for the benefit of YEC with respect to the particular brief given to us and it may not be relied upon in other contexts or for any other purpose without our prior review and agreement.

Tonkin & Taylor International Ltd
 Environmental and Engineering Consultants
 Report prepared by:  Authorised for Tonkin & Taylor International Ltd by:

 Connor Morrison
 Engineering Geologist

 Chris Freer
 Project Director

own

p:\750932\workingmaterial\report\tpstated.docx

We recommend using a strength reduction factor of 0.5 ($\phi_c = 0.5$) to give an ultimate limit state (ULS) bearing capacity, in accordance with New Zealand Design Standards (ref: NZS 1170). For serviceability limit state design we recommend a strength reduction factor of 0.33 ($\phi_s = 0.3$) to give an allowable bearing capacity.

7.5.2 Site A - Popua Power Station

We recommend that all foundations should be embedded at least 0.5m below finished floor level. Strip or pad foundations would be constructed in the near surface alluvial material. Bearing capacities for this material based on the in situ testing undertaken are shown in table 8 below.

Table 8 – Bearing pressures within the loose to dense granular sediments

Depth	Bearing Pressures			
	Shallow strip footings up to 1 m wide		Shallow isolated pad footings up to 2.5 m wide	
	Allowable	ULS ⁽¹⁾	Ultimate	ULS ⁽¹⁾
0.5m	50kPa	85kPa	160kPa	210kPa
			70kPa	105kPa
				210kPa

⁽¹⁾ ULS = Ultimate Limit State (ref: NZS1170)

We recommend that all foundation excavations are inspected and tested by a competent person to ensure the ground conditions and bearing capacities are similar to those encountered during this investigation.

7.5.3 Site B - Vaini

We recommend that due to the high plasticity exhibited by the near surface soil, all foundations should be embedded a minimum of 600mm below finished ground level to allow for seasonal water content changes (shrink and swell effects).

The strip or pad foundations would be constructed in the near surface volcanic clay material. Bearing capacities for this material based on the in situ testing undertaken are shown in table 9 below.

Table 9 – Bearing pressures within the stiff and very stiff alluvial clay

Depth	Bearing Pressures			
	Shallow strip footings up to 1 m wide		Shallow isolated pad footings up to 2.5 m wide	
	Allowable	ULS	Ultimate	ULS
0.6m	165kPa	248kPa	496kPa	310kPa
			210kPa	620kPa

We recommend that all foundation excavations are inspected and tested by a competent person to ensure the ground conditions and bearing capacities are similar to those encountered during this investigation.

7.6 Settlement

T&T have not been provided with any vertical loads for the proposed structures. It is recommended that settlement analysis is carried out following completion of the detailed design two buildings.

Appendix A: Contract of Soils Explorations

PREPARATION SURVEY
ON
THE PROJECT
FOR
INTRUCTION OF A MICRO-GRID SYSTEM WITH RENEWABLE ENERGY
FOR THE TONGA ENERGY LOAD MAP
IN
THE KINGDOM OF TONGA
CONTRACT
OF
SOIL EXPLORATIONS

THIS CONTRACT is entered into on this 19th day of September, 2012 by and between **Yachiyo Engineering Co., Ltd.** (hereinafter referred to as "YEC") and **Tonkin & Taylor International**, duly organized and existing under the laws of New Zealand, (hereinafter referred to as "the Contractor").

WHEREAS, YEC requested the Contractor to perform the Soil Explorations work which is outlined in Annex-1 (hereinafter referred to as "the Work").

WHEREAS, the quotation for the Work submitted by the Contractor dated 4th of September, 2012 has been accepted by YEC.

WHEREAS, the Contractor has accepted to perform the Work in accordance with the specifications and conditions set forth in this Contract and Annex hereto.

THEREFORE, based on and in consideration of the foregoing promises and of the terms and conditions hereinafter provided, both parties hereto agree as follows:

Clause 1 : WORK

The Contractor shall implement the Work as hereinafter defined under the terms and conditions of this Contract.

Clause 2 : YEC's REPRESENTATIVE

YEC shall assign a representative (hereinafter referred to as "the Representative") at the site. The Representative shall have the right to supervise, inspect and give approval for the Work.

  -1-

Clause 3 : SPECIFICATIONS

The Work shall be performed in accordance with specifications in Annex-1.

Clause 4 : SITE LOCATION

The site location is shown in ATTACHMENT-1.

Clause 5 : WORK ITEMS

The Work shall cover the followings;

Soil Exploration

- (a) Preparation for field test
- (b) Seala penetrometer test (dynamic cone) and sampling
- (c) Soil laboratory test
- (d) Reporting

Clause 6 : PREPARATION FOR THE WORK

The Contractor shall prepare all the necessary highly-skilled personnel and all of the required materials, facilities and equipment for the performance of the Work at the site and laboratory. The Representative shall have the right to check and review such materials, facilities and equipment at any time during the execution of the Work.

Clause 7 : REPORTING

The Contractor shall submit a written daily report of the Work in English to YEC.

Clause 8 : INSPECTIONS OF RESULTS

The Contractor shall request YEC for an inspection of results immediately after the completion of each item of the Work, if such results are not accepted by YEC, the Contractor shall redeem those works as soon as possible to the satisfaction of YEC, the Contractor shall once more submit the results to YEC for inspection.

Clause 9 : TIME FOR COMPLETION

The Contractor shall complete all the Work by 21st day of October, 2012.

Clause 10 : CONTRACT AMOUNT

The Contract amount shall be Sixteen Thousand (16,000) US Dollars.

Clause 11 : METHOD OF PAYMENT

- (a) Advance payment
YEC shall pay an advance payment of thirty (30) percent of the Contract amount to the Contractor upon signing of the Contract.

- (b) Final payment
Payment of the remaining balance of the Contract amount shall be remitted to the Contractor's bank account within seven (7) days after the Work has been finished and approved by YEC.

Clause 12 : PENALTY

A penalty of one/one hundred (1/100) of the Contract amount shall be imposed upon the Contractor per day by YEC, with maximum of ten (10) percent of the total Contract amount for a delay in the performance of the Work for which the Contractor is responsible to complete within the period as set forth in Clause 9.

The penalty amount shall be deducted from the final payment amount to be made to the Contractor.

Clause 13 : FORCE MAJEURE

The Contractor shall not be responsible for any delay caused by Force Majeure such as change in laws and regulations of the Kingdom of Tonga, strikes and sabotage, natural disasters, declared or undeclared war, blockades, revolutions, and natural calamities beyond the control of the Contractor. If it appears that such Force Majeure continues to the end of the Contract period mentioned in Clause 9, YEC shall have the right to terminate this Contract at any time.

Clause 14 : LIABILITY

YEC shall be exempted from or kept harmless against any damage, loss and/or accident incurred by or arising from a third party in connection with any activity of the Contractor during the period of the Work.

Clause 15 : TERMINATION OF CONTRACT

YEC has the right to terminate the Contract by giving a written prior notice to the Contractor, in case of any of the following cases;

- (a) Due to causes attributable to the Contractor, if YEC judges that completion of the Work cannot be expected within the time set forth in Clause 9, and in accordance with

NS/KW

47


AS/KW

47


set out in this Contract. If no applicable rates or prices are set out in this Contract, then suitable rates or prices shall be agreed upon between YEC and the Contractor. In the event of disagreement, YEC shall determine such rates or prices as shall, in his opinion, be reasonable and proper.

IN WITNESS WHEREOF, the parties hereto have executed this Contract by their duly authorized representatives as of the date first above written.

For and On Behalf of
The YEC


Mitsuhiro Nishikawa
Chief Consultant
JICA Preparation Survey Team

For and On Behalf of
The Contractor


Chris Preet
Project Director
Tonkin & Taylor International

the detailed time schedule submitted by the Contractor and approved by YEC.

(b) If the Work is not fully performed by the Contractor in accordance with the Contract and specifications without (at YEC's discretion) justified reasons.

(c) If the Contractor does not commence the Work or if the Contractor suspends the Work for a certain period without (at YEC's discretion) justified reasons after the effective date of this Contract.

(d) If the Contractor violates any provision of this Contract and does not rectify it within ten (10) days after the Contractor has received notice of breach of contract from YEC.

Clause 16 : ASSIGNMENT AND/OR SUBCONTRACT

Without prior written consent of YEC, the Contractor shall not assign any or this entire Contract to a third party.

Clause 17 : EFFECTIVE DATE OF THIS CONTRACT

This Contract shall become effective on the date first above written.

Clause 18 : CHANGES IN WORKING PROGRAM

YEC has the right to change the contents of the Work, if modifications are necessary. In case of such change, the time for completion and the Contract amount may be modified by mutual agreement in writing of both parties hereto. However, if extension of Contract period or increase in contract amount is required due to reasons attributable to the improper execution of the Work by the Contractor, such request from the Contractor shall not be approved by YEC. Should the YEC order additional works, an additional fee shall be paid to the Contractor, however, the Contractor shall not refuse to carry out the additional works without satisfactory reasons.

Clause 19 : DOUBTS OR UNSPECIFIED ITEMS

Any doubts in connection with this Contract or anything not specified in this Contract shall be determined amicably by mutual agreement between both parties.

Clause 20 : MAINTENANCE OF SECRECY

Without obtaining YEC's prior written approval, the Contractor shall not disclose, not only during the effective period of this Contract but also after the termination or completion of the Contract, any information and/or data etc., which has been made known to the Contractor in executing the Work.

Clause 21 : EVALUATION OF ADDITIONAL AND OMITTED WORK

All work added or omitted under the instructions of YEC shall be evaluated at rates and prices









**ANNEX-1
SPECIFICATION**

1. Site Locations

Site location shall be shown to *ATTACHMENT-1*.
Work sites for investigation shall locate in Tongatapu.

- 1) Project site in Vaini (Site B)
- 2) Project site at Popua Power Station (Site A)

2. Site plan

Site plan for project site in Vaini (Site B) shall be shown to *ATTACHMENT-2*.
Site area is approx. 24,000m².

Site plan for project site at Popua Power Station (Site A) shall be shown to *ATTACHMENT-3*

3. Soil Explorations

3-1 Application

The soil exploration survey shall be implemented in accordance with the Contract, the instructions of the Representative and the technical specifications described hereafter.

3-2 Scope of works

The scope of works shall be as follows;

- Preparation of work implementation schedule
- Transportation, assembling and disassembling of all the survey equipment
- Installation of scaffold and other safety measures during the execution of the works
- Implementation of miscellaneous works related to penetrating and sampling, field test and laboratory test
- Execution of field test
- Sampling and transportation of sampled soil
- Report on geological aspect based on laboratory test and field test
- Submission of geological samples for inspection
- Presentation of test results and necessary calculations in report form
- Backfilling of sampled hole

3-3 Quantities of the Soil Explorations

The soil explorations shall be executed according to the following quantities. The depth of perforation and quantity of samples mentioned table may be modified according to the conditions of the soil stratum, however, such modifications must be approved by the Representative.

AF

ASCU

CAF

A-1

Items	Quantity	Remarks
Scala Penetrometer Test	Max.5 m (if possible)	6 places at Site A 12 places at Site B
Specific Gravity	5 samples	BS1377 or equivalent International Standard
Grain-Size Analysis	5 samples	
Moisture Content Test	5 samples	

3-4 Location of the Scala Penetrometer Tests (Dynamic Cone)

The penetrating shall be executed at the locations of the intersections under study as shown in **ATTACHMENT-4** and 4 points in the PV unit area at Väini Site.

The Contractor shall confirm the location of the penetrometer test on site before commencement in the presence of the Representative.

3-5 Preparation of Implementation Schedule

The implementation schedule to be prepared by the Contractor and submitted to the Representative shall cover the following items;

- (1) Study execution program
- (2) List of necessary machines and equipment
- (3) Work method and measures to maintain security
- (4) Relevant remarks
- (5) Contractor's staff organized for the Work

3-6 Securing of Geological Samples

The Contractor shall prepare the geological samples and submit them to the Representative with indications of the geological name, position and date of sampling and any other necessary information. The samples and their plastic containers shall be approved by the Representative.

3-7 Sampling Work

- (1) Preparation
Prior to the execution of sampling, the Contractor shall survey the sampling points and their heights above mean sea level.
- (2) Groundwater level measurement

The Contractor shall measure the groundwater level in the hole.

- (3) Completion of sampling
Upon completion of the sampling work, at the instructions of the Representative, the Contractor shall measure the exact perforation depth.
- (4) Daily progress report
The Contractor shall provide daily progress reports containing the results of the standard penetration tests, conditions of samples, penetration speed, and any problems or observations encountered.
- (5) Transport of machinery and samples
The Contractor shall be responsible for the safe transport of his equipment to and from the soil investigation site. The Contractor shall also be careful in the transport of soil samples to avoid excessive vibrations or changes in volume and composition.

3-8 Sampling for Laboratory Testing

- (1) Disturbed samples
 - Disturbed samples shall be taken from representative soil layers
 - The sampling points shall be decided in consultations with the Representative
 - Disturbed samples shall be sealed with wax immediately after the sampling
 - On the sealed samples shall be clearly indicated depth, soil classification and type of soil test

3-9 Soil Tests in the Laboratory

- (1) The soil tests in the laboratory shall be carried out based on the following standards or their equivalent;

Test	Standard
Specific Gravity	BS1377 or equivalent International Standard
Grain-Size Analysis	
Moisture Content Test	

- (2) Samples to be tested shall be chosen by the Representative.
- (3) The Contractor shall present to the Representative examples of the information sheets and data input used in his laboratory and both sides shall agree on the suitable presentation of the test results.

ATTACHMENT-1
SITE MAP



3-10 Results of the Soil Investigation Study

The Contractor shall submit to the Representative the results of the soil investigation study, in one (1) original and three (3) copies as follows;

(1) Field test and sampling logs

The field test and sampling log shall contain the following information;

- Depth below ground level
- Graphical symbol of the soil type
- Description of the soil
- Position where soil sample was taken, whether disturbed or undisturbed
- Sample number
- Analysis for result of penetrating
- Groundwater table position
- Other as necessary

(2) Soil laboratory test results

Results of the tests shall include the numerical values and graphs derived, standards applied and formula used.

(3) Language

Document and all data shall be written in English.

Handwritten signature

Handwritten signature


Handwritten signature

Handwritten signature

ASKILL

tlp

SITE PLAN




ATTACHMENT-3
Project Site at Popua Power Station

ATTACHMENT-2
Project Site in Vaini




CANDIDATE PHOTOVOLTAIC SITE

ATTACHMENT-4
SCALE PENETROMETER TEST POINTS



PCS & BATTERIES BUILDING at Project Site in VAINI

PCS & BATTERIES BUILDING IN VAINI



PCS & BATTERIES BUILDING at POPUA Power Station

PCS & BATTERIES BUILDING AT POPUA POWER STATION

○ PT-X LOCATION OF PENETROMETER TEST

ASSTD *[Signature]*

Appendix B:
Topographical Survey and Geotechnical
Investigation Location Plans

PREPARATION SURVEY
ON
THE PROJECT
FOR
INTRODUCTION OF A MICRO-GRID SYSTEM RENEWABLE ENERGY
FOR THE TONGA ENERGY ROAD MAP



SCHEDULE OF DRAWINGS	SHEET NO.	SHEET TITLE
	VA11	CADASTRAL MAP
	VA12	TOPOGRAPHICAL SURVEY
	VA13	CONTOUR MAP
	VA14	SPOT LEVELS
	VA15	YAVINI SPT COORDINATES AND LEVELS
	POP1	POPLUA SPT COORDINATES

05 OCTOBER 2012

ITS CIVIL, STRUCTURAL AND WATER
ENGINEERING CONSULTANTS
COMPANY LTD.
WIFI 1, 10 TONGALAVA PLAZA, BUKITANBARU KINOH, NUKUNONO
P.O. BOX 494 NUKUNONO, NUKUNONO, NUKUNONO, NUKUNONO, NUKUNONO

PREPARATION SURVEY
ON
THE PROJECT
FOR
INTRODUCTION OF A MICRO-GRID SYSTEM WITH RENEWABLE ENERGY
FOR THE TONGA ENERGY ROAD MAP
IN
THE KINGDOM OF TONGA

TOPOGRAPHICAL SURVEY

CLIENT

YACHIYO ENGINEERING CO., LTD. AND
WEST JAPAN ENGINEERING CONSULTANTS, INC. JV

SCHEDULE OF DRAWINGS	SHEET NO.	SHEET TITLE
	VA11	CADASTRAL MAP
	VA12	TOPOGRAPHICAL SURVEY
	VA13	CONTOUR MAP
	VA14	SPOT LEVELS
	VA15	YAVINI SPT COORDINATES AND LEVELS
	POP1	POPLUA SPT COORDINATES

05 OCTOBER 2012

ITS CIVIL, STRUCTURAL AND WATER
ENGINEERING CONSULTANTS
COMPANY LTD.
WIFI 1, 10 TONGALAVA PLAZA, BUKITANBARU KINOH, NUKUNONO
P.O. BOX 494 NUKUNONO, NUKUNONO, NUKUNONO, NUKUNONO, NUKUNONO



TOPOGRAPHICAL SURVEY MAP
SCALE = 1:1000M

STATIONS AND COODINATES


STATION	EASTING	NORTHING	REDUCED LEVEL [M]	REFERENCE NAME
STA. 1	1687617.440	2655883.447	13.237	BM1
STA. 2	1687617.460	2655009.393	13.299	BM2
STA. 3	1687559.775	2655920.504	13.298	BM3
STA. 4	1687703.045	2655763.756	12.751	BM4
STA. 5	1687764.359	2655840.927	13.201	BM5
STA. 6	1687857.757	2655861.258	12.331	BM6
STA. 7	1687730.211	2655917.884	13.337	BM7
STA. 8	1687863.072	2655852.849	12.171	BM8
REF. LEVEL	1687857.769	2655869.750	11.682	RL

LEGEND

- STATION POINT
- SPT POINT
- POWER POLE
- TREE
- BANANA PLANT
- COCONUT PALM
- FENCE




<p>DISCLAIMER:</p> <p>This drawing is a property of ITS Consulting Engineers. No part of this drawing may be reproduced or copied without the written permission of ITS Consulting Engineers.</p>	<p>DATE: 03/10/2024</p> <p>REVISION / ISSUE</p>	<p>ITS COMPANY LTD.</p> <p>CIVIL, STRUCTURAL AND WATER ENGINEERING CONSULTANTS</p> <p>UNIT 1-10 TONGGLAVA PLAZA, TAHAFAU ROAD, NANGA P.O. BOX 114 NUKUNOA, P.O. Box 1272 2007, 2012, 2018 (1/1) 43478</p>	<p>DESIGNED BY: F. FABRIZIO L. RAFFAELI T. KANGA-MIRUKU</p> <p>DRAWN BY: L. KANGULI T. KANGA-MIRUKU A. SANDOZ</p> <p>CHECKED BY: M. VABABEELA</p>	<p>PROJECT:</p> <p>THE PROJECT FOR INTRODUCTION OF A MICRO-GRID SYSTEM WITH RENEWABLE ENERGY FOR THE TONGA ENERGY ROAD MAP</p> <p>CLIENT:</p> <p>YACHIYO ENGINEERING CO., LTD. AND WEST JEC JV</p>	<p>SHEET CONTENT:</p> <p>TOPOGRAPHICAL SURVEY</p>	<p>SHEET NUMBER:</p> <p>VAI2</p> <p>DATE: 03/OCT/2024</p>
	<p>DATE: 03/10/2024</p> <p>REVISION / ISSUE</p>		<p>DATE: 03/10/2024</p> <p>REVISION / ISSUE</p>	<p>DATE: 03/10/2024</p> <p>REVISION / ISSUE</p>	<p>DATE: 03/10/2024</p> <p>REVISION / ISSUE</p>	




CADASTRAL MAP
SCALE = 1:1000M




<p>DISCLAIMER:</p> <p>This drawing is a property of ITS Consulting Engineers. No part of this drawing may be reproduced or copied without the written permission of ITS Consulting Engineers.</p>	<p>DATE: 03/10/2024</p> <p>REVISION / ISSUE</p>	<p>ITS COMPANY LTD.</p> <p>CIVIL, STRUCTURAL AND WATER ENGINEERING CONSULTANTS</p> <p>UNIT 1-10 TONGGLAVA PLAZA, TAHAFAU ROAD, NANGA P.O. BOX 114 NUKUNOA, P.O. Box 1272 2007, 2012, 2018 (1/1) 43478</p>	<p>DESIGNED BY: F. FABRIZIO L. RAFFAELI T. KANGA-MIRUKU</p> <p>DRAWN BY: L. KANGULI T. KANGA-MIRUKU A. SANDOZ</p> <p>CHECKED BY: M. VABABEELA</p>	<p>PROJECT:</p> <p>THE PROJECT FOR INTRODUCTION OF A MICRO-GRID SYSTEM WITH RENEWABLE ENERGY FOR THE TONGA ENERGY ROAD MAP</p> <p>CLIENT:</p> <p>YACHIYO ENGINEERING CO., LTD. AND WEST JEC JV</p>	<p>SHEET CONTENT:</p> <p>CADASTRAL MAP</p>	<p>SHEET NUMBER:</p> <p>VAI1</p> <p>DATE: 03/OCT/2024</p>
	<p>DATE: 03/10/2024</p> <p>REVISION / ISSUE</p>		<p>DATE: 03/10/2024</p> <p>REVISION / ISSUE</p>	<p>DATE: 03/10/2024</p> <p>REVISION / ISSUE</p>	<p>DATE: 03/10/2024</p> <p>REVISION / ISSUE</p>	




DISCLAIMER: This drawing is a property of ITS Consulting Engineers, Inc. (2011) All rights reserved. This drawing is not to be reproduced or copied without the written permission of ITS Consulting Engineers, Inc.	 CIVIL, STRUCTURAL AND WATER ENGINEERING CONSULTANTS UNIT 1-10 TONGGAVA PLAZA, TAMPAKSIJANG, PANGKA P.O. BOX 194 BUKITKALIA, PANGKA (611) 2887, 28412, MOB (811) 43478	SURVEYOR: F. RAJIBACHO, L. KAMRUS, F. KANGKANGRUS DRAWN BY: L. RAJIBACHO, F. KANGKANGRUS, A. SAUNDRES CHECKED BY: M. YANABONGSA	PROJECT: THE PROJECT FOR INTRODUCTION OF A MICRO GRID SYSTEM WITH RENEWABLE ENERGY FOR THE TONGKA ENERGY ROAD MAP CLIENT: YACHIMO ENGINEERING CO., LTD. AND WEST JFC JV	SHEET CONTENTS: SPOT LEVELS	SHEET NUMBER: VAI4 DATE: 02 OCT 2013
		REVISION / ISSUE	DATE: 02 OCT 2013		



DISCLAIMER: This drawing is a property of ITS Consulting Engineers, Inc. (2011) All rights reserved. This drawing is not to be reproduced or copied without the written permission of ITS Consulting Engineers, Inc.	 CIVIL, STRUCTURAL AND WATER ENGINEERING CONSULTANTS UNIT 1-10 TONGGAVA PLAZA, TAMPAKSIJANG, PANGKA P.O. BOX 194 BUKITKALIA, PANGKA (611) 2887, 28412, MOB (811) 43478	SURVEYOR: F. RAJIBACHO, L. KAMRUS, F. KANGKANGRUS DRAWN BY: L. RAJIBACHO, F. KANGKANGRUS, A. SAUNDRES CHECKED BY: M. YANABONGSA	PROJECT: THE PROJECT FOR INTRODUCTION OF A MICRO GRID SYSTEM WITH RENEWABLE ENERGY FOR THE TONGKA ENERGY ROAD MAP CLIENT: YACHIMO ENGINEERING CO., LTD. AND WEST JFC JV	SHEET CONTENTS: CONTOUR MAP	SHEET NUMBER: VAI3 DATE: 02 OCT 2013
		REVISION / ISSUE	DATE: 02 OCT 2013		



DISCLAIMER:	REVISION / ISSUE	<p>CIVIL, STRUCTURAL AND WATER ENGINEERING CONSULTANTS</p> <p>UNIT 1-10 TONGILAVA FLAZA, TAUFASHAHI ROAD, NANGA P.O. BOX 15480, NUKUNOA, PUNUFI 1541 2007, 20472, NUKUNOA (875) 43076</p>	<p>SURVEYOR:</p> <p>F. FALEANGA, L. LAUTISI, F. FANGAMENI</p> <p>DESIGNED BY:</p> <p>L. LAUTISI, F. FANGAMENI, A. SANOHE</p> <p>CHECKED BY:</p> <p>M. VAKANGILA</p>	<p>PROJECT:</p> <p>THE PROJECT FOR INTRODUCTION OF A MICRO-GRID SYSTEM WITH RENEWABLE ENERGY FOR THE TONGA ENERGY ROAD MAP</p> <p>CLIENT:</p> <p>YACHTHO ENGINEERING CO., LTD. AND WEST JFC JV</p>	<p>DATE:</p> <p>15 OCT 2022</p>	<p>PROJECT NAME:</p> <p>SPT COORDINATES AND LEVELS</p> <p>POP1</p>



DISCLAIMER:	REVISION / ISSUE	<p>CIVIL, STRUCTURAL AND WATER ENGINEERING CONSULTANTS</p> <p>UNIT 1-10 TONGILAVA FLAZA, TAUFASHAHI ROAD, NANGA P.O. BOX 15480, NUKUNOA, PUNUFI 1541 2007, 20472, NUKUNOA (875) 43076</p>	<p>SURVEYOR:</p> <p>F. FALEANGA, L. LAUTISI, F. FANGAMENI</p> <p>DESIGNED BY:</p> <p>L. LAUTISI, F. FANGAMENI, A. SANOHE</p> <p>CHECKED BY:</p> <p>M. VAKANGILA</p>	<p>PROJECT:</p> <p>THE PROJECT FOR INTRODUCTION OF A MICRO-GRID SYSTEM WITH RENEWABLE ENERGY FOR THE TONGA ENERGY ROAD MAP</p> <p>CLIENT:</p> <p>YACHTHO ENGINEERING CO., LTD. AND WEST JFC JV</p>	<p>DATE:</p> <p>15 OCT 2022</p>	<p>PROJECT NAME:</p> <p>SPT COORDINATES AND LEVELS</p> <p>VAI5</p>



TONKIN & TAYLOR LTD
BOREHOLE LOG

BOREHOLE No: HA1A
Hole Location: Site A Popua
power station, refer site plan.
SHEET 1 OF 1

PROJECT: Micro-Grid System in Tonga
LOCATION: Tongatapu, Tonga
JOB No: 760932
CO-ORDINATES 2689515.28 mN
1681245.96 mE
DRILL TYPE: 50mm Hand Auger
HOLE STARTED: 26/9/12
HOLE FINISHED: 26/9/12
R.L. 1.36 m
DRILL METHOD: Hand Auger
LOGGED BY: CWM
CHECKED: SRS
DATE: 10/03/05
DRILL FLUID: Nil

GEOLOGICAL		ENGINEERING DESCRIPTION	
DEPTH (m)	R.L. (m)	CLASSIFICATION SYMBOL	MOISTURE CONDITION
0.0 - 0.5	1.36 - 1.0	SP	U
0.5 - 1.0	1.0 - 0.5	SM	U
1.0 - 1.5	0.5 - 0.0	ML	U
1.5 - 2.0	0.0 - -0.5	SP	D
2.0 - 2.5	-0.5 - -1.0		
2.5 - 3.0	-1.0 - -1.5		
3.0 - 3.5	-1.5 - -2.0		
3.5 - 4.0	-2.0 - -2.5		
END OF BOREHOLE AT 1.9m. Hand to auger.			

Appendix C: Site A - Investigation Logs and Geotechnical Laboratory Testing

- Hand auger borehole logs
- Scala Penetrometer results
- Geotechnical Laboratory Testing



TONKIN & TAYLOR LTD BOREHOLE LOG

BOREHOLE No: HA2A
Hole Location: Site A Popua
power station, refer site plan,
SHEET 1 OF 1

PROJECT: Micro-Grid System in Tonga		LOCATION: Tongatapu, Tonga		JOB No: 750932	
CO-ORDINATES: 2859503.37 mN 1691247.25 mE		DRILL TYPE: 50mm Hand Auger		HOLE STARTED: 26/9/12	
R.L. 1.30 m		DRILL METHOD: Hand Auger		HOLE FINISHED: 26/9/12	
DATUM TGD2005		DRILL FLUID: Nil		LOGGED BY: CWM	
				CHECKED: SR\$	
GEOLOGICAL		ENGINEERING DESCRIPTION			
GEOLOGICAL UNIT GENERIC NAME ORIGIN MINERAL COMPOSITION	FLUID LOSS WATER METHOD CORRE RECOVERY (%) CASING TESTS SAMPLES R.L. (m) DEPTH (m)	CLASSIFICATION SYMBOL MOISTURE CONDITION WEATHERING CLASSIFICATION SHEAR STRENGTH COMPRESSION STRENGTH DEFLECT SPACING (mm)	SOIL DESCRIPTION Soil type, minor components, plasticity or particle size, color. ROCK DESCRIPTION Description: Rock type, particle size, color, mineral composition. Dip/slope: Type, location, direction, magnitude, etc.	GRAPHIC LOG	DEPTH (m)
TOPSOIL		ML	SILT, with some clay and minor sand, trace gravel, dark brown with light brown sand and gravel, firm, low plasticity, moist, many rootlets.		0.5
			Generally coarse to medium SAND, with some silt, dark brown with some light angular coral sand and gravel, very dense, dry.		0.5
CORAL SAND			END OF BOREHOLE AT 0.55m. Hard to auger (gravel).		1.0
					1.5
					2.0
					2.5
					3.0
					3.5
					4.0



TONKIN & TAYLOR LTD BOREHOLE LOG

BOREHOLE No: HA3A
Hole Location: Site A Popua
power station, refer site plan,
SHEET 1 OF 1

PROJECT: Micro-Grid System in Tonga		LOCATION: Tongatapu, Tonga		JOB No: 750932	
CO-ORDINATES: 2859504.32 mN 1691253.27 mE		DRILL TYPE: 50mm Hand Auger		HOLE STARTED: 26/9/12	
R.L. 1.30 m		DRILL METHOD: Hand Auger		HOLE FINISHED: 26/9/12	
DATUM TGD2005		DRILL FLUID: Nil		LOGGED BY: CWM	
				CHECKED: SR\$	
GEOLOGICAL		ENGINEERING DESCRIPTION			
GEOLOGICAL UNIT GENERIC NAME ORIGIN MINERAL COMPOSITION	FLUID LOSS WATER METHOD CORRE RECOVERY (%) CASING TESTS SAMPLES R.L. (m) DEPTH (m)	CLASSIFICATION SYMBOL MOISTURE CONDITION WEATHERING CLASSIFICATION SHEAR STRENGTH COMPRESSION STRENGTH DEFLECT SPACING (mm)	SOIL DESCRIPTION Soil type, minor components, plasticity or particle size, color. ROCK DESCRIPTION Description: Rock type, particle size, color, mineral composition. Dip/slope: Type, location, direction, magnitude, etc.	GRAPHIC LOG	DEPTH (m)
TOPSOIL		SM	SILTY SAND, with some clay, dark brown, loose, many rootlets.		0.5
FILL		SP	Coarse SAND, with some gravel, light yellow brown, very coarse, angular coral limestone sand (fill)		0.5
BURIED TOPSOIL			SILTY, fine SAND, dark brown, medium dense, moist, massive		1.0
ESTUARINE SEDIMENTS		S	Coarse SAND, with some gravel and minor silt, light blue grey, loose to medium dense, saturated, angular coral sand		1.5
CORAL SAND			NO RECOVERY		1.5
					2.0
					2.5
					3.0
					3.5
					4.0

**TONKIN & TAYLOR LTD
BOREHOLE LOG**

BOREHOLE No: HA4A
Hole Location: Site A Popua
power station, refer site plan
SHEET 1 OF 1



**TONKIN & TAYLOR LTD
BOREHOLE LOG**

BOREHOLE No: HA5A
Hole Location: Site A Popua
power station, refer site plan
SHEET 1 OF 1

PROJECT: Micro-Grid System in Tonga		LOCATION: Tongatapu, Tonga		JOB No: 750632	
CO-ORDINATES: 2889516.31 mN 1691254.61 mE		DRILL TYPE: 50mm Hand Auger		HOLE STARTED: 28/9/12	
R.L. DATUM: 1.20 m TCD2005		DRILL METHOD: Hand Auger		HOLE FINISHED: 28/9/12	
LOGGED BY: CWM		DRILL FLUID: NI		CHECKED: SRS	
GEOLOGICAL					
FLUID LOSS	WATER	CORE RECOVERY (%)	METHOD	CASING	TESTS
			HAND AUGER		
ENGINEERING DESCRIPTION					
DEPTH (m)	R.L. (m)	CLASSIFICATION SYMBOL	MOISTURE CONDITION	STRENGTH CLASSIFICATION	SHEAR STRENGTH
0.0 - 0.5	0.5	SP		S	
TOPSOIL SOIL DESCRIPTION: Silt type, three components, plasticity in particles size, color. ROCK DESCRIPTION: Substratum: Rock type, particle size, color, mineral components. Textures: nodules, fibrous, irregular, flake.					
Chazy SILT, with some sand and minor gravel, dark brown with some light brown sand and gravel, stiff, moist, low plasticity, many rootlets					
0.5 - 1.0	0.0	SP		S	
FILL Silty SILT, with some clay, dark brown/black, firm, moist, low plasticity					
1.0 - 1.5	-0.5	SP		S	
ESTUARINE SEDIMENTS Coarse SAND, with some fine gravel and minor silt, light grey, medium dense, saturated, poorly sorted					
1.5 - 2.0	-1.0	SP		S	
CORAL SAND NO RECOVERY					
2.0 - 2.5	-1.5	SP		S	
END OF BOREHOLE AT 1.9m. Hard to auger.					
2.5 - 3.0	-2.0	SP		S	
3.0 - 3.5	-2.5	SP		S	

Log Scale 1:20

1-T DATUM\PLATE\GDT.mxd

PROJECT: Micro-Grid System in Tonga		LOCATION: Tongatapu, Tonga		JOB No: 750632	
CO-ORDINATES: 2889509.87 mN 1691250.13 mE		DRILL TYPE: 50mm Hand Auger		HOLE STARTED: 26/9/12	
R.L. DATUM: 1.20 m TCD2005		DRILL METHOD: Hand Auger		HOLE FINISHED: 26/9/12	
LOGGED BY: CWM		DRILL FLUID: NI		CHECKED: SRS	
GEOLOGICAL					
FLUID LOSS	WATER	CORE RECOVERY (%)	METHOD	CASING	TESTS
			HAND AUGER		
ENGINEERING DESCRIPTION					
DEPTH (m)	R.L. (m)	CLASSIFICATION SYMBOL	MOISTURE CONDITION	STRENGTH CLASSIFICATION	SHEAR STRENGTH
0.0 - 0.5	0.5	SP		S	
TOPSOIL SOIL DESCRIPTION: Silt type, three components, plasticity in particles size, color. ROCK DESCRIPTION: Substratum: Rock type, particle size, color, mineral components. Textures: fibrous, irregular, flake, nodules.					
Sandy SILT, with some gravel, dark brown, moist, many rootlets					
0.5 - 1.0	0.0	SP		S	
FILL Gravelly coarse SAND, light brown/white, very dense, angular coral sand					
1.0 - 1.5	-0.5	SP		S	
CORAL SAND Silty, fine SAND, with some gravel, dark brown, loose, moist, some rootlets					
1.5 - 2.0	-1.0	SP		S	
END OF BOREHOLE AT 1.7m. Hard to auger.					
2.0 - 2.5	-1.5	SP		S	
2.5 - 3.0	-2.0	SP		S	
3.0 - 3.5	-2.5	SP		S	

Log Scale 1:20

1-T DATUM\PLATE\GDT.mxd



TONKIN & TAYLOR LTD
BOREHOLE LOG

BOREHOLE NO: HA8A
Hole Location: Site A Popua power station, Peller site plan.
SHEET 1 OF 1

PROJECT: Micro-Grid System in Tonga		LOCATION: Tongatapu, Tonga		JOB No: 750932									
CO-ORDINATES: 2859509.91 mN 1691232.12 mE		DRILL TYPE: 50mm Hand Auger		HOLE STARTED: 26/9/12									
R.L. 1.20 m		DRILL METHOD: Hand Auger		HOLE FINISHED: 26/9/12									
DATUM: TGD2003		DRILL FLUID: Nil		LOGGED BY: CWM									
GEOLOGICAL		ENGINEERING DESCRIPTION		CHECKED: SRS									
GENERAL	TESTS	SAMPLES	DEPTH (m)	CLASSIFICATION SYMBOL	MOISTURE WEATHERING	CONDITION	EXTENSIONITY	SHEAR STRENGTH	COMPRESSIVE STRENGTH	UNIFORMITY	OBJECT SYMBOL	DEPTH (mm)	SOIL DESCRIPTION
GENERIC NAME	UNIT				%			MPa	MPa				
ORIGEN.	NO.												
MINERAL COMPOSITION													
TORNSOIL		● 6S/20RPa	1.0	SL								50	Standy SILT, with minor clay, dirt brown, stiff, moist
ESTUARINE SEDIMENTS			0.5	SL								100	Silty SAND, with minor clay, dark brown, medium dense, poorly sorted, massive
			1.0	SP								150	Course SAND, with some fine gravel and minor silt, light grey blue, saturated, NO RECOVERY
CORAL SAND			1.5	SP								200	
			2.0									250	
			2.5									300	
			3.0									350	
			3.5									400	
			4.0									450	
			4.5									500	
			5.0									550	
			5.5									600	
			6.0									650	
			6.5									700	
			7.0									750	
			7.5									800	
			8.0									850	
			8.5									900	
			9.0									950	
			9.5									1000	
			10.0									1050	
			11.0									1150	
			12.0									1250	
			13.0									1350	
			14.0									1400	
			14.5									1450	
			15.0									1500	
			15.5									1550	
			16.0									1600	
			16.5									1650	
			17.0									1700	
			17.5									1750	
			18.0									1800	
			18.5									1850	
			19.0									1900	
			19.5									1950	
			20.0									2000	
			20.5									2050	
			21.0									2100	
			21.5									2150	
			22.0									2200	
			22.5									2250	
			23.0									2300	
			23.5									2350	
			24.0									2400	
			24.5									2450	
			25.0									2500	

1:1 DATA/SCALE/REF QDT 3mm




TONKIN & TAYLOR
SCALA PENETROMETER LOG

Job No: 750932
Project: Micro-Grid System in Tonga
Location: Site A
R.L. 1.27m

Date: 27/09/2012
Operated by: CWM
Logged by: CWM
Checked by: ADP

Test No. SC1A
Sheet 1 of 1

mm Driven	No. of Blows	mm Driven	No. of Blows
50	10	2550	6
100	15	2600	6
150	12	2650	4
200	16	2700	3
250	6	2750	5
300	3	2800	6
350	2	2850	5
400	1	2900	6
450	1		
500	1		
550	1		
600	1		
650	2		
700	2		
750	1		
800	1		
850	2		
900	0		
950	1		
1000	0		
1050	1		
1100	1		
1150	0		
1200	1		
1250	0		
1300	1		
1350	1		
1400	0		
1450	2		
1500	4		
1550	5		
1600	6		
1650	3		
1700	3		
1750	4		
1800	6		
1850	7		
1900	6		
1950	7		
2000	4		
2050	4		
2100	3		
2150	3		
2200	2		
2250	3		
2300	4		
2350	3		
2400	4		
2450	5		
2500	6		



Test Method Used: NZS 4402:1988 Test 6.5.2 Dynamic Cone Penetrometer

CLIENT: Yehshin Engineering
TITLE: Scala Penetrometer Test
REFERENCE No: 750932

September 2012

(1)

SC2.xlsx




TONKIN & TAYLOR
SCALA PENETROMETER LOG

Job No: 750932
Project: Micro-Grid System in Tonga
Location: Site A
RL: 1.26m

Date: 27/09/2012
Operated by: CWM
Logged by: CWM
Checked by: ADP

Test No. SC2A
Sheet 1 of 1



Test Method Used: NZS 4402:1988 Test 6.5.2 Dynamic Cone Penetrometer

CLIENT: Yachyo Engineering
TITLE: Scala Penetrometer Test
REFERENCE No: 750932

September, 2012

(1)

SC3.xlsx




TONKIN & TAYLOR
SCALA PENETROMETER LOG

Job No: 750932
Project: Micro-Grid System in Tonga
Location: Site A
RL: 1.26m

Date: 27/09/2012
Operated by: CWM
Logged by: CWM
Checked by: ADP

Test No. SC3A
Sheet 1 of 1



Test Method Used: NZS 4402:1988 Test 6.5.2 Dynamic Cone Penetrometer

CLIENT: Yachyo Engineering
TITLE: Scala Penetrometer Test
REFERENCE No: 750932

September, 2012

(1)

SC4.xlsx




TONKIN & TAYLOR

SCALA PENETROMETER LOG

Job No: 750932
 Project: Micro-Grid System in Tonga
 Location: Site A
 RL: 1.25m

Date: 27/09/2012
 Operated by: CWM
 Logged by: CWM
 Checked by: ADP

Test No. SC4A
 Sheet 1 of 1



Test Method Used: NZS 4402:1988 Test 6.5.2 Dynamic Cone Penetrometer

CLIENT: Yachyo Engineering
 TITLE: Scala Penetrometer Test
 REFERENCE No: 750932

September 2012

(1)

SC5.xlsx




TONKIN & TAYLOR

SCALA PENETROMETER LOG

Job No: 750932
 Project: Micro-Grid System in Tonga
 Location: Site A
 RL: 1.20m

Date: 27/09/2012
 Operated by: CWM
 Logged by: CWM
 Checked by: ADP

Test No. SC5A
 Sheet 1 of 1



Test Method Used: NZS 4402:1988 Test 6.5.2 Dynamic Cone Penetrometer

CLIENT: Yachyo Engineering
 TITLE: Scala Penetrometer Test
 REFERENCE No: 750932

September 2012

(1)




TONKIN & TAYLOR
SCALA PENETROMETER LOG

Job No: 750932
 Project: Micro-Grid System in Tonga
 Location: Site A
 RL: 1.24m

Date: 27/09/2012
 Operated by: CWM
 Logged by: CWM
 Checked by: ADP

Test No. SC6A
 Sheet 1 of 1



Test Method Used: NZS 4402:1988 Test 6.5.2 Dynamic Cone Penetrometer

September 2012

CLIENT: Yeohio Engineering
 TITLE: Scala Penetrometer Test
 REFERENCE No.: 750932

23 Morgan Street, Newmarket
 Auckland 1023, New Zealand
 P. +64 9 356 3510
 W. WWW.GEOTECHNICS.CO.NZ

Page of

Your Job No.: 750932
 Our Job No.: 615931,000

Site: Popua, Tongatapu, Tonga - Site A
 Test Method Used: NZS 4402:1988 Test 2.1 Determination of the water content

WATER CONTENT TEST RESULTS

Table 1: Water Content

HA No.:	3	4	5
Depth (m)	1.2	1.0	0.5
Water Content (%)	34.3	56.3	41.1

Tested by: ST
 Date: 10/10/12
 Checked by: ASG
 Date: 10/10/12

23 Morgan Street, Newmarket
Auckland 1023, New Zealand
P. +64 9 356 3570
W. www.geotechnics.co.nz

Form No. 35
Issue Date: January 2004
By: Practice Committee Approved Use Only

Page of
Your Job No.: 750932
Our Job No.: 615931.000
Site: Popua, Tongatapu, Tonga - Site A
HA No.: 3
Depth (m): 1.2
Test Method Used: NZS 4402:1986 Test 2.7.2 Determination of Solid Density of Soil Particles - Vacuum Method

SOLID DENSITY TEST RESULTS

HA No.:	*Single Specimen tested	*Single Specimen tested	*Single Specimen tested
3	4	5	5
Depth (m)	1.2	1.0	0.5
Solid Density (t/m ³)	2.84	2.81	2.75

Remarks :
Solid density was performed on whole material.
*As per the standard, two specimens required to perform a solid density, but due to insufficient sample mass obtained, it was performed on a single specimen as directed by the engineer. Therefore the test results are not IANZ endorsed.

Tested by: ST

Date: 10/10/12

Checked by: ASFC

Date: 10/10/12

23 Morgan Street, Newmarket
Auckland 1023, New Zealand
P. +64 9 356 3570
W. www.geotechnics.co.nz

Form No. 35
Issue Date: January 2004
By: Practice Committee Approved Use Only

Page of
Your Job No.: 750932
Our Job No.: 615931.000
Site: Popua, Tongatapu, Tonga - Site A
HA No.: 3
Depth (m): 1.2
Test Method Used: NZS 4402:1986 Test 2.8.1 Wet Sieve

PARTICLE SIZE ANALYSIS

Sieve (mm)	Total % Passing
63.0	94
53.0	86
37.5	65
26.5	53
19.0	40
13.2	28
9.50	21
6.70	16
4.75	99
3.35	97



Entered by: ST

Date: 10/10/12

Checked by: ASFC

Date: 10/10/12

Sample history : As received.
Description : Coral SAND mixed with shell fragments, minor gravel, minor silt and trace of clay, loose/soft lumps, light brownish grey with white.
Remarks : The minimum mass of sample required for sieving is 0.2 kg, but due to insufficient sample mass the sieving was carried out on ~ 0.10 kg.
The classification of sand and gravel was described on the basis of particle size analysis.
Percentage passing the finest sieve was obtained by difference.
Sample description and test results are not IANZ endorsed.





TONKIN & TAYLOR LTD
BOREHOLE LOG

BOREHOLE NO: HA1B
Hole Location: Site B Vaini, refer site plan.
SHEET 1 OF 1

PROJECT: Micro-Grid System In Tonga		LOCATION: Tongatapu, Tonga		JOB No: 769622												
CO-ORDINATES: 2656918.83 mN 1697653.55 mE		DRILL TYPE: 50mm Hand Auger		HOLE STARTED: 28/8/12												
R.L. 13.10 m		DRILL METHOD: Hand Auger		HOLE FINISHED: 28/8/12												
DATUM TGD2005		DRILL FLUID: NI		LOGGED BY: CWM												
GEOLOGICAL		ENGINEERING DESCRIPTION		CHECKED: SRS												
FLUID LOSS	WATER	CORE RECOVERY (%)	METHOD	CASING	TESTS	DEPTH (m)	DEPTH (ft)	CLASSIFICATION SYMBOL	MOISTURE	WEATHERING	STRENGTH	CLASSIFICATION	LINEAR STRONGTH (kPa)	COMPRESSIVE STRENGTH (kPa)	EFFECT SPACING (mm)	SOIL DESCRIPTION: Soil type, water content, plasticity or particle size, color. FSC-DESCRIPTION Substratum: Rock type particles size, colour, major constituents. Diagnosis: Type, adhesion, thickness, fragments (mm).
			HAND AUGER			0.0 - 13.0	0.0 - 42.7	MS								Clayey SILT, dark brown, stiff, moist, moderate plasticity, with some nodules
					● 81/17kPa	0.5 - 12.5	0.5 - 41.2	CH								Silty CLAY, dark brown with some red brown, stiff, moist, high plasticity
					● 21657kPa	1.0 - 12.0	1.0 - 39.4	H								Some orange brown
					● 15671kPa	1.5 - 11.5	1.5 - 37.8	VS								Silty CLAY, minor organics, brown with some orange brown, very stiff, moist, high plasticity [Reworked Volcanics?]
					● 13751kPa	2.0 - 11.0	2.0 - 36.1									CLAY, with some silt, orange brown, very stiff, moist, high plasticity
						2.5 - 10.5	2.5 - 34.5									As above, with some coral sand and fine gravel
						3.0 - 10.0	3.0 - 32.8									END OF BOREHOLE AT 3.8m.
						3.5 - 9.5	3.5 - 31.2									Hard to auger. No water.

T-1 DATA/REV/DATE/CDT/AM Log Scale 1:20

Appendix D: Site B - Investigation Logs and Geotechnical Laboratory Testing

- Hand auger borehole logs
- Scala Penetrometer results
- Geotechnical Laboratory Testing



TONKIN & TAYLOR LTD
BOREHOLE LOG

BOREHOLE No: HA12B
Hole Location: Site B (Vaini, refer site plan).
SHEET 1 OF 1

PROJECT: Micro-Grid System in Tonga		LOCATION: Tongatapu, Tonga		JOB No: 750932													
CC-ORDINATES: 268585.4 mN 1687719.63 mE		DRILL TYPE: 50mm Hand Auger		HOLE STARTED: 28/9/12													
R.L. 12.50 m		DRILL METHOD: Hand Auger		HOLE FINISHED: 28/9/12													
DATUM: TGD2005		DRILL FLUID: Nil		LOGGED BY: CWM													
GEOLOGICAL		ENGINEERING DESCRIPTION		CHECKED: SRS													
GEOLOGICAL UNIT, GENERIC NAME, ORIGIN, MATERIAL COMPOSITION	FLUID LOSS	WATER	CORE RECOVERY (%)	METHOD	CASING	TESTS	SAMPLES	R.L. (m)	DEPTH (m)	CLASSIFICATION SYMBOL	MOISTURE / WEATHERING	STRENGTH/DENSITY	CLASSIFICATION	SHEAR STRENGTH	COMPRESSIVE STRENGTH	DETECT SPACING (mm)	SOIL DESCRIPTION (soil type, major components, plasticity w/ particle size, color, ROCK DESCRIPTION, Silt/clay: Rock type, particle size, colour, major components, Diatoms: Type, percentage, thickness, roughness, fill)
TOPSOIL						71/17kPa		-12.5	0.5	ML, M, ST		VS					SILT, with some clay and minor line sand, dark brown, stiff, moist, low plasticity, many rootlets
VOLCANIC TUFF						118/25kPa		-12.0	1.0	ME							Clayey SILT, orange brown with some black, very stiff, moist, moderate plasticity
						189/51kPa		-11.5	1.5								
						178/42kPa		-11.0	2.0								
						159/25kPa		-10.5	2.5	CH, M-AW, N							CLAY, with some silt, orange brown, stiff, moist to wet, high plasticity
								-10.0	3.0								Minor limestone gravel
								-9.5	3.5								
CORAL LIMESTONE								-9.0	4								END OF BOREHOLE AT 3.6m. Fired to auger (scales hit rock at 2.45m, 100mm from hand auger, filled void/cavity?)

Log Scale 1:20

SC1.xlsx




TONKIN & TAYLOR
SCALA PENETROMETER LOG

Job No: 750932
Project: Micro-Grid System in Tonga
Location: Site B
R.L: 12.91m

Date: 27/09/2012
Operated by: CWM
Logged by: CWM
Checked by: ADP

Test No. SC1B
Sheet 1 of 1



Test Method Used: NZS 4402:1988 Test 6.5.2 Dynamic Cone Penetrometer

CLIENT: Vaini Engineering
TITLE: Scala Penetrometer Test
REFERENCE No: 750932

September 2012






TONKIN & TAYLOR

SCALA PENETROMETER LOG

Job No: 750932
 Project: Micro-Grid System in Tonga
 Location: Site B
 RL: 13.23m

Date: 27/09/2012
 Operated by: CWM
 Logged by: CWM
 Checked by: ADP

Test No. SC2B
 Sheet 1 of 1



Test Method Used: NZS 4402:1988 Test 6.5.2 Dynamic Cone Penetrometer

CLIENT: Vastigo Engineering
 TITLE: Scala Penetrometer Test
 REFERENCE No: 750932

September 2012

11




TONKIN & TAYLOR

SCALA PENETROMETER LOG

Job No: 750932
 Project: Micro-Grid System in Tonga
 Location: Site B
 RL: 13.23m

Date: 27/09/2012
 Operated by: CWM
 Logged by: CWM
 Checked by: ADP

Test No. SC3B
 Sheet 1 of 1



Test Method Used: NZS 4402:1988 Test 6.5.2 Dynamic Cone Penetrometer

CLIENT: Vastigo Engineering
 TITLE: Scala Penetrometer Test
 REFERENCE No: 750932

September 2012

11




TONKIN & TAYLOR

SCALA PENETROMETER LOG

Job No: 750932
 Project: Micro-Grid System in Tonga
 Location: Site B
 RL: 12.92m

Date: 27/09/2012
 Operated by: CWM
 Logged by: CWM
 Checked by: ADP

Test No. SC4B
 Sheet 1 of 1



Test Method Used: NZS 4402:1988 Test 6.5.2 Dynamic Cone Penetrometer

CLIENT: Yeshiva Engineering
 TITLE: Scala Penetrometer Test
 REFERENCE No. 750932

September 2012

(1)




TONKIN & TAYLOR

SCALA PENETROMETER LOG

Job No: 750932
 Project: Micro-Grid System in Tonga
 Location: Site B
 RL: 13.00m

Date: 27/09/2012
 Operated by: CWM
 Logged by: CWM
 Checked by: ADP

Test No. SC5B
 Sheet 1 of 1



Test Method Used: NZS 4402:1988 Test 6.5.2 Dynamic Cone Penetrometer

CLIENT: Yeshiva Engineering
 TITLE: Scala Penetrometer Test
 REFERENCE No. 750932

September 2012


(1)

SCALA PENETROMETER LOG

Job No: 750932
 Project: Tonga Solar
 Location: Site B
 RL: 13.07m

Date: 27/09/2012
 Operated by: CWM
 Logged by: CWM
 Checked by: ADP

Test No. SC6B
 Sheet 1 of 1




Test Method Used: NZS 4402:1988 Test 6.5.2 Dynamic Cone Penetrometer

SCALA PENETROMETER LOG

Job No: 750932
 Project: Micro-Grid System in Tonga
 Location: Site B
 RL: 13.14m

Date: 27/09/2012
 Operated by: CWM
 Logged by: CWM
 Checked by: ADP

Test No. SC7B
 Sheet 1 of 1



Test Method Used: NZS 4402:1988 Test 6.5.2 Dynamic Cone Penetrometer




TONKIN & TAYLOR

SCALA PENETROMETER LOG

Job No: 750932
 Project: Micro-Grid System in Tonga
 Location: Site B
 RL: 13.07m

Date: 27/09/2012
 Operated by: CWM
 Logged by: CWM
 Checked by: ADP

Test No. SC8B
 Sheet 1 of 1



Test Method Used: NZS 4402:1988 Test 6.5.2 Dynamic Cone Penetrometer
 CLIENT: Vashyo Engineering
 TITLE: Scala Penetrometer Test
 REFERENCE No: 750932
 September 2012




TONKIN & TAYLOR

SCALA PENETROMETER LOG

Job No: 750932
 Project: Micro-Grid System in Tonga
 Location: Site B
 RL: 13.15m

Date: 27/09/2012
 Operated by: CWM
 Logged by: CWM
 Checked by: ADP

Test No. SC9B
 Sheet 1 of 1



Test Method Used: NZS 4402:1988 Test 6.5.2 Dynamic Cone Penetrometer
 CLIENT: Vashyo Engineering
 TITLE: Scala Penetrometer Test
 REFERENCE No: 750932
 September 2012

SC11.xlsx




TONKIN & TAYLOR

SCALA PENETROMETER LOG

Job No: 750932
 Date: 27/09/2012
 Project: Micro-Grid System in Tonga
 Location: Site B
 RL: 13.28m

Test No. SC11B
 Sheet 1 of 1
 Operated by: CWM
 Logged by: CWM
 Checked by: ADP



Test Method Used: NZS 4402:1988 Test 6.5.2 Dynamic Cone Penetrometer

CLIENT: Yasabya Engineering
 TITLE: Scala Penetrometer Test
 REFERENCE No. 750932

September 2012

11

SC10.xlsx




TONKIN & TAYLOR

SCALA PENETROMETER LOG

Job No: 750932
 Date: 27/09/2012
 Project: Micro-Grid System in Tonga
 Location: Site B
 RL: 12.87m

Test No. SC10B
 Sheet 1 of 1
 Operated by: CWM
 Logged by: CWM
 Checked by: ADP



Test Method Used: NZS 4402:1988 Test 6.5.2 Dynamic Cone Penetrometer

CLIENT: Yasabya Engineering
 TITLE: Scala Penetrometer Test
 REFERENCE No. 750932

September 2012

11

SC12.xlsx


TOKIN & TAYLOR

SCALA PENETROMETER LOG

Job No: 750932
 Project: Micro-Grid System in Tonga
 Location: Site B
 RL: 12.92m

Date: 27/09/2012
 Operated by: CWM
 Logged by: CWM
 Checked by: ADP

Test No. **SC12B**
 Sheet 1 of 1



Test Method Used: NZS 4402:1988 Test 6.5.2 Dynamic Cone Penetrometer

CLIENT: Yachyo Engineering
 TITLE: Scala Penetrometer Test
 REFERENCE No. 750932

September 2012

23 Morgan Street, Newmarket
 Auckland 1023, New Zealand
 P: +64 9 550 3510
 W: www.geotechnics.co.nz

geotechnics

Your Job No.: 750932
 Our Job No.: 615931.000

Page of

Site: Vaini, Tongatapu, Tonga - Site B
 Test Method Used: NZS 4402:1988 Test 2.1 Determination of the water content

WATER CONTENT TEST RESULTS

Table 1: Water Content

HA No.:	1	3
Depth (m)	1.1	0.6
Water Content (%)	71.4	81.5

Tested by: ST
 Date: 10/10/12
 Checked by: ASTC
 Date: 10/10/12

23 Moxgan Street, Newmarket
Auckland 1023, New Zealand
P: +64 9 356 3510
W: www.geotechnics.co.nz

Form No. 14
First Issue: January 2004
The PROVISION OF SERVICES BY THE ENGINEER

Page of

Your Job No.: 750932
Our Job No.: 615931.000
Depth: 1.1 (m)

Site: Vaini, Tongatapu, Tonga - Site B
HA No.: 1
Sample No.: ---
Test Method Used: NZS 4402:1986 Test 2.8.4 Hydrometer

PARTICLE SIZE ANALYSIS

Sieve (mm)	Total % Passing	Sieve (mm)	Total % Passing	Equivalent Particle Diameter D (mm)	% of Particles Finer than D
2.00	100			0.0408	89
0.600	99			0.0291	86
0.212	98			0.0209	82
0.063	93			0.0150	77
				0.0111	73
				0.0080	68
				0.0057	63
				0.0041	58
				0.0029	54
				0.0012	44

Sample history: As received.
Description: silty CLAY with minor sand, stiff, dark red with dark brown, mottled orange, high plasticity.
Solid Density (Measured): 3.00 t/m³

Remarks: A sub sample was split from the original sample for hydrometer analysis. This sample was soaked with a dispersing agent (~3 hours), then the mechanical shaker was used, until the material was brought into suspension, before proceeding with the test.
Suspension pH 8.0
The classification of sand-silt-clay components are described on the basis of particle size analysis.
Sample description is not IANZ endorsed.

Entered by: ST

Date: 10/10/12

Checked by: ASFC

Date: 10/10/12

23 Moxgan Street, Newmarket
Auckland 1023, New Zealand
P: +64 9 356 3510
W: www.geotechnics.co.nz

Form No. 14
First Issue: January 2004
The PROVISION OF SERVICES BY THE ENGINEER

Page of

Your Job No.: 750932
Our Job No.: 615931.000

Site: Vaini, Tongatapu, Tonga - Site B
HA No.: 1
Sample No.: ---
Test Method Used: NZS 4402:1986 Test 2.7.2 Determination of Solid Density of Soil Particles - Vacuum Method

SOLID DENSITY TEST RESULTS

HA No.:	*Single Specimen tested	*Single Specimen tested
1	1.1	3
Depth (m)	3.00	0.6
Solid Density (t/m ³)	2.84	



Remarks: Solid density was performed on whole material.
*As per the standard, two specimens required to perform a solid density, but due to insufficient sample mass obtained, it was performed on a single specimen as directed by the engineer. Therefore the test results are not IANZ endorsed.


Tested by: ST

Date: 10/10/12

Checked by: ASFC

Date: 10/10/12

 <p>23 Mairangi Street, Newmarket Auckland 1023, New Zealand P: +64 9 356 3510 W: www.geotechnics.co.nz</p>	<p>Form No.: PB Form Date: January 2009 File: P:\M1901\2009\labing\manual\A_3-8-10.doc</p>	<p>Page of</p> <p>Your Job No.: 750932 Our Job No.: 615931.000 Depth: 0.6 (m)</p>																																																																		
<p>Plate No.: Site : HA No.: Test Method Used : NZS 4402:1986 Test 2.8.4 Hydrometer</p>	<p>Valinj, Tongatapu, Tonga - Site B 3 Sample No.: ---</p>	<p>Appendix E: Scala Penetrometer / SPT 'N' Value Conversion Chart</p>																																																																		
<p>PARTICLE SIZE ANALYSIS</p>																																																																				
																																																																				
		<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Sieve (mm)</th> <th>Total % Passing</th> <th>Sieve (mm)</th> <th>Total % Passing</th> <th>Equivalent Particle Diameter D (mm)</th> <th>% of Particles Finer than D</th> </tr> </thead> <tbody> <tr> <td>2.00</td> <td>100</td> <td></td> <td></td> <td>0.0431</td> <td>82</td> </tr> <tr> <td>0.600</td> <td>97</td> <td></td> <td></td> <td>0.0309</td> <td>77</td> </tr> <tr> <td>0.212</td> <td>93</td> <td></td> <td></td> <td>0.0222</td> <td>72</td> </tr> <tr> <td>0.063</td> <td>85</td> <td></td> <td></td> <td>0.0159</td> <td>67</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td>0.0118</td> <td>62</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td>0.0084</td> <td>57</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td>0.0050</td> <td>52</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td>0.0043</td> <td>47</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td>0.0031</td> <td>42</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td>0.0013</td> <td>33</td> </tr> </tbody> </table>	Sieve (mm)	Total % Passing	Sieve (mm)	Total % Passing	Equivalent Particle Diameter D (mm)	% of Particles Finer than D	2.00	100			0.0431	82	0.600	97			0.0309	77	0.212	93			0.0222	72	0.063	85			0.0159	67					0.0118	62					0.0084	57					0.0050	52					0.0043	47					0.0031	42					0.0013	33
Sieve (mm)	Total % Passing	Sieve (mm)	Total % Passing	Equivalent Particle Diameter D (mm)	% of Particles Finer than D																																																															
2.00	100			0.0431	82																																																															
0.600	97			0.0309	77																																																															
0.212	93			0.0222	72																																																															
0.063	85			0.0159	67																																																															
				0.0118	62																																																															
				0.0084	57																																																															
				0.0050	52																																																															
				0.0043	47																																																															
				0.0031	42																																																															
				0.0013	33																																																															
<p>Sample history : As received.</p> <p>Description: clayey SILT with some sand, stiff, dark red with dark brown, mottled orange, high plasticity.</p> <p>Solid Density (Measured) : 2.64 t/m³</p> <p>Remarks : A sub sample was split from the original sample for hydrometer analysis. This sample was soaked with a dispersing agent (~3 hours), then the mechanical shaker was used, until the material was brought into suspension, before proceeding with the test.</p> <p style="text-align: right;">Suspension pH 8.0</p> <p>The classification of sand-silt-clay components are described on the basis of particle size analysis. Sample description is not IANZ endorsed.</p>																																																																				
<p>Entered by : ST</p>	<p>Date : 10/10/12</p>	<p>Checked by : ASEC</p> <p>Date : 10/10/12</p>																																																																		



A-9 Data Analysis for Wind Turbine Generation

Report of data Analysis for wind conditions in the Kingdom of Tonga

December 2012

West JEC, INC.

CONTENTS

1.	Preconditions	3
1.1.	Existing wind condition data	3
1.2.	Observation site of the existing data and candidate site for wind turbine	3
1.3.	A wind turbine model	4
1.4.	The objective of the evaluation in the report	6
2.	Mean wind speed	7
2.1.	Monthly average wind speed	7
2.2.	Hourly average wind speed	8
3.	Frequency distribution of wind direction	9
3.1.	Annual and monthly frequency distribution of wind direction	9
3.2.	Hourly frequency distribution of wind direction	11
4.	Frequency distribution of wind direction for each wind force scale, and correlation between mean wind speed and frequency distribution of wind direction	12
5.	Wind profile.....	13
6.	Turbulence intensity	15
7.	Maximum instantaneous wind speed.....	17
8.	Wind speed distribution.....	18
9.	Density of wind energy	20
10.	Availability (generation available time ratio).....	22
11.	Wind energy production and capacity factor.....	23
11.1.	Wind energy production	23
11.2.	Capacity factor.....	25
12.	Conclusion	26
12.1.	Wind conditions.....	26
12.2.	Wind energy	27
12.3.	Capacity factor and generation available time ratio	27
12.4.	Comprehensive evaluation	27

This is a report summarized a feasibility evaluation for introduction of wind power by organizing and analyzing based on existing data of wind condition and determining the energy characteristics in mind the wind turbine scale that can be introduced in the Kingdom of Tonga.

1. Preconditions

1.1. Existing wind condition data

The specification of the existing wind condition data is shown in Table 1-1.

Table 1-1 Specification of the existing wind condition data and the observation site

Observation site of the existing data	Lapaha site (near Ha'malo Beach on the eastern coast of Tnogatapu Island) Latitude of 21°11' 22" degrees south, Longitude of 175° 05' 35" degrees east, Altitude of 28 m
Observation period of wind condition data	from July 2010 to October 2011
Applicable period for analysis of wind condition data	form 1st August 2010 to 31st July 2011
Implementation agency	MLECCNR
Specification of measuring instruments	6 anemometers 30 m above the ground, installed sensors at 22.5 and 202.5 degrees to magnetic north. 40 m above the ground, installed sensors at 22.5 and 202.5 degrees to magnetic north. 50 m above the ground, installed sensors at 22.5 and 202.5 degrees to magnetic north.
	2 wind vanes 37 m above the ground, installed sensor at 22.5 degrees to magnetic north 48 m above the ground, installed sensor at 22.5 degrees to magnetic north

1.2. Observation site of the existing data and candidate site for wind turbine

As noted above, the existing wind condition data has been observed by MLECCNR, the other place determined as candidate site for wind turbine is going to be developed.

Candidate site for wind turbine is approximately 6.5 km away from the observation site of the existing data in the straight-line distance. (Figure 1-1)

However, on the grounds that both sites are about the same with respect to topography and altitude conditions, this evaluation can be assumed to adapt to the candidate site for wind turbine.

The information of candidate site for wind turbine is shown in Table 1-2.

Also, the wind condition data is expected to be observed in the candidate site for wind turbine.

Table 1-2 The candidate site for wind turbine

Candidate site for wind turbine	Niutoua site (near Finehika Beach on the north eastern coast of Tongatapu Island) Latitude of 21° 09' 23" degrees south, Longitude 175° 02' 24" degrees east, Altitude of 26 m
Planning agency	TPL




Figure 1-1 The observation site and the candidate site

1.3. A wind turbine model

Considering the current situation of Tonga as an isolated island, the introduction of a medium-sized wind turbine is realistic in terms of construction.

A typical specification and a figure for 300 kW class wind turbine are shown in Table 1-3 and Figure 1-2.

Since a hub height is approximately 40 m in general, the wind condition data with a height of 40 m are used for analysis.

Table 1-3 Typical specification of 300 kW class wind turbine

Rating capacity	300 kW
Type	Horizontal axis
System	Upwind turbine
Rotor diameter	33 m
Hub height	41.5 m (approx. 40 m)
Rated wind speed	11.5 m/s
Rated rotating speed	40.5 rpm
Cut-in wind speed	3.0 m/s
Cut-out wind speed	25 m/s (average per 10 minutes)
Optimum tip speed ratio	7.5
Survival wind speed	70 m/s
Design life	20 years




Figure 1-2 Typical figure of 300 kW wind turbine

Target of installed capacity for wind turbine is 500 kW in Tonga.

Therefore, it is assumed that two units of wind turbine the rated power of which is 250 kW are introduced (total installed capacity is 500 kW).

Here, it is assumed that 300 kW class wind turbine is adopted as rated power of 250 kW.

The assumed component of wind turbine is shown in Table 1-4.

Table 1-4 Assumed components of wind turbine

Installed capacity	Components
500 kW	250 kW (rated power) x 2 units

1.4. The objective of the evaluation in the report

Environmental impact assessment in accordance with the development of wind power has not been carried out, this project is not in the situation which immediately steps to the implementation phase.

Therefore, potential evaluation including expected energy production is carried out only in this report.

The items analyzed in this report are shown in Table 1-5.

Table 1-5 Analysis items

Attribution	Analysis items	Object
Wind conditions characteristics	Mean wind speed	To determine whether the development of wind power should be carried out.
	Frequency distribution of wind direction	To determine annual prevailing wind direction
	Hourly frequency distribution of wind direction	To determine hourly fluctuation characteristics of wind direction
	Frequency distribution of wind direction for each wind force scale, and correlation between wind speed and wind direction	To determine correlation between the wind speed and the wind direction
	Wind profile	To determine the wind shear for each wind direction
	Turbulence intensity	To determine the magnitude of the turbulence
	Maximum instantaneous wind speed	To determine the maximum instantaneous wind speed
	Wind speed distribution	To determine the wind speed distribution
Energy characteristics	Density of wind energy	To determine whether the development of wind power should be carried out.
	Availability	
	Annual energy production, Capacity factor	

2. Mean wind speed

2.1. Monthly average wind speed

Monthly average wind speed with a height of 40 m is shown in Table 2-1 and Figure 2-1. The data in March to April and July are 5.1 ~ 5.5 m/s, other months are more than 6.0 m/s in general. In particular the data in September to December are greater than or equal to 7.0 m/s. The annual average wind speed is 6.2 m/s.

Table 2-1 Monthly average wind speed and annual average by ground height

Ground height	2011							2010					Ave.
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
30 m	5.0	4.9	4.4	4.4	5.2	5.3	4.8	5.5	6.1	6.3	6.4	6.1	5.4
40 m	5.8	5.7	5.1	5.2	6.0	6.2	5.5	6.2	6.9	7.1	7.2	7.0	6.2
50 m	6.2	6.1	5.4	5.5	6.4	6.6	5.9	6.6	7.3	7.4	7.6	7.4	6.5




Figure 2-1 Monthly average wind speed by ground height

2.2. Hourly average wind speed

Diurnal variation of hourly average wind speed with a height of 40 m per year is small (5.8 to 6.4 m/s), tended to be somewhat weaker at midnight to morning than during the day as shown in Table 2-2 and Figure 2-2.

With respect to the hourly variation of each month, the data in January indicates a similar tendency as the data in a year. In contrast, wind speed in August tends to be slightly stronger in early morning.

Table 2-2 Hourly average wind speed and standard deviation [ground height: 40 m]

year/month	item	Hour																								Ave.
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	
Jan. 2011	WS	5.7	5.5	5.5	5.4	5.6	5.6	5.7	5.4	5.4	5.5	5.9	6.1	6.3	6.3	6.2	6.1	5.9	5.9	5.7	5.7	6.0	6.3	6.4	6.0	5.8
	SD	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.9	1.0	1.1	1.0	1.0	1.1	1.1	1.0	1.0	0.9	0.8	0.8	0.9	0.9	0.9	0.9
Feb. 2011	WS	5.6	5.4	5.1	5.0	5.1	5.2	5.3	5.4	5.6	5.7	6.0	6.1	6.1	6.0	5.8	5.8	6.0	5.9	5.9	5.8	5.8	5.7	5.7	5.5	5.7
	SD	0.7	0.7	0.7	0.6	0.6	0.6	0.7	0.7	0.9	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	0.9	0.8	0.8	0.7	0.7	0.7	0.7	0.8
Mar. 2011	WS	4.9	4.9	4.8	4.7	4.8	4.8	4.7	5.0	5.1	5.4	5.5	5.6	5.8	5.6	5.5	5.3	5.0	5.0	5.0	5.0	5.2	5.0	5.1	5.0	5.1
	SD	0.7	0.7	0.7	0.6	0.7	0.7	0.7	0.7	0.9	1.0	1.0	1.0	1.0	1.0	1.0	1.0	0.9	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.8
Apr. 2011	WS	4.8	4.9	4.8	4.7	4.8	4.8	5.0	5.2	5.2	5.5	5.6	6.0	6.0	5.8	5.5	5.5	5.6	5.1	5.0	4.9	5.0	4.9	4.8	4.7	5.2
	SD	0.6	0.7	0.6	0.6	0.6	0.6	0.6	0.7	0.8	0.9	0.9	1.0	1.0	1.0	0.9	0.9	0.8	0.7	0.7	0.6	0.6	0.6	0.6	0.6	0.8
May. 2011	WS	6.2	6.0	5.9	6.0	6.0	6.1	6.2	6.0	5.9	5.9	6.0	6.0	6.1	5.8	5.9	5.7	5.7	5.8	6.0	6.1	6.3	6.3	6.1	5.8	6.0
	SD	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.7	0.8	0.8	0.8	0.8	0.8
Jun. 2011	WS	6.4	6.2	5.8	5.6	5.8	5.9	5.9	5.9	5.9	6.1	6.2	6.2	6.2	6.0	6.1	6.3	6.5	6.5	6.4	6.5	6.4	6.4	6.6	6.8	6.2
	SD	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.8
Jul. 2011	WS	5.0	5.2	5.2	5.3	5.3	5.5	5.4	5.3	5.4	5.4	5.7	5.6	5.5	5.7	5.8	6.1	5.8	5.8	5.7	5.7	5.6	5.6	5.4	5.2	5.5
	SD	0.7	0.7	0.6	0.7	0.7	0.7	0.7	0.7	0.8	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.8
Aug. 2010	WS	6.6	6.5	6.3	6.3	6.4	6.3	6.1	5.8	5.8	5.7	5.7	6.0	6.3	6.0	6.4	6.4	6.6	6.4	6.5	6.5	6.4	6.1	6.2	6.2	6.2
	SD	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.8
Sep. 2010	WS	6.6	6.7	6.5	6.4	6.5	6.2	6.4	6.6	6.7	6.7	6.9	7.1	7.1	7.1	7.0	6.9	7.1	7.0	7.2	7.3	7.4	7.4	7.3	7.1	6.9
	SD	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.9	0.9	0.8
Oct. 2010	WS	7.1	6.9	6.7	7.1	7.1	7.0	7.1	7.2	7.2	7.1	7.2	7.2	7.1	7.2	7.1	6.9	7.0	6.9	7.1	7.1	7.1	7.2	7.2	7.0	7.1
	SD	0.8	0.7	0.8	0.8	0.8	0.7	0.8	0.8	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8
Nov. 2010	WS	7.0	6.7	6.7	6.8	6.9	7.1	6.9	7.3	7.4	7.5	7.4	7.5	7.5	7.5	7.5	7.4	7.5	7.2	7.1	7.2	7.1	7.1	7.0	7.1	7.2
	SD	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.9	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.9
Dec. 2010	WS	6.9	6.8	6.6	6.6	6.4	6.8	6.7	6.7	6.9	7.3	7.3	7.1	7.1	7.0	7.0	7.0	7.0	7.1	7.3	7.4	7.3	7.2	7.0	7.0	7.0
	SD	0.8	0.8	0.8	0.8	0.7	0.7	0.8	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.8
Ave.	WS	6.1	6.0	5.8	5.8	5.9	5.9	5.9	6.0	6.0	6.2	6.3	6.4	6.4	6.4	6.3	6.3	6.3	6.2	6.2	6.3	6.3	6.3	6.3	6.1	6.2
	SD	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.8	0.9	0.9	0.9	1.0	1.0	1.0	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8

WP: Wind speed, SD: Standard deviation




Figure 2-2 Hourly average wind speed

3. Frequency distribution of wind direction

3.1. Annual and monthly frequency distribution of wind direction

Frequency distribution of wind direction with a height of 40 m is shown in Table 3-1, Figure 3-1a and 3-1b.

The observation point is located in the trade wind belt, a prevailing wind (approximately 53% per year) blow from east (east to southeast) throughout the year. As regarding other wind directions, the north-northeast to northeast wind (approximately 10-14%) is superior to annual average in winter and spring season (January to May), and the east-southeast to southeast east wind (approximately 15-28%) is superior to annual average in summer and autumn season (June to November).

Angular difference between the magnetic north and the arm mounted wind vane was 22.5 (east side) degrees. Assumed that the raw data of wind direction have not been corrected for angular difference, the raw data of all was added 22.5 degrees before evaluations.

The magnetic declination in Tonga is 13.0 (east side) degrees. Assumed that the raw data of wind direction have already been corrected for the magnetic declination, the raw data of all have not made the correction before evaluation.

Table 3-1 Monthly and annual frequency distribution of wind direction
[ground height: 40 m]

month/year	Calm	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Quantity of data
Jan. 2011	0.0	10.9	13.8	12.0	14.4	18.1	19.1	5.1	0.4	1.2	0.3	0.1	0.0	0.4	0.1	0.5	3.5	744
Feb. 2011	0.0	6.5	3.1	11.0	10.9	11.0	20.4	8.0	3.9	1.9	0.0	0.6	1.5	4.2	5.8	5.7	5.5	672
Mar. 2011	0.0	5.1	14.4	10.3	8.5	11.7	18.0	11.7	4.3	1.9	1.1	0.9	0.3	0.0	1.1	3.9	6.9	744
Apr. 2011	0.0	5.3	4.9	14.0	8.8	9.4	11.3	15.8	4.9	2.1	1.8	0.8	1.8	1.4	2.1	7.5	8.2	720
May. 2011	0.0	1.3	2.0	11.7	12.4	21.2	14.5	21.2	3.6	1.5	1.5	0.4	0.8	0.8	3.2	1.9	1.9	744
Jun. 2011	0.0	1.9	4.2	6.0	13.1	17.9	21.1	14.9	11.4	5.7	3.1	0.6	0.1	0.0	0.0	0.0	0.1	720
Jul. 2011	0.0	3.2	2.7	7.0	4.6	5.8	15.5	16.3	9.8	4.8	4.2	2.6	4.2	5.4	5.1	5.6	3.4	744
Aug. 2010	0.0	0.9	2.0	7.1	9.8	19.1	21.0	20.3	10.8	2.6	1.3	0.7	0.7	0.8	1.1	0.9	0.9	744
Sep. 2010	0.0	0.6	1.1	1.0	9.2	17.6	34.4	17.9	8.9	4.2	3.1	0.8	0.1	0.4	0.3	0.4	0.0	720
Oct. 2010	0.0	1.6	2.7	1.3	3.9	9.3	21.4	28.1	15.2	9.0	0.9	0.5	0.7	0.9	1.5	1.7	1.2	744
Nov. 2010	0.0	5.1	3.9	2.9	3.8	5.6	15.3	35.0	12.8	9.3	0.6	0.3	0.4	0.3	1.3	0.4	3.2	720
Dec. 2010	0.0	3.9	1.2	1.5	3.4	26.9	44.1	11.3	1.1	0.9	0.0	0.8	0.4	0.8	0.5	1.3	1.9	744
Ave.	0.0	3.9	4.7	7.1	8.5	14.5	21.3	17.2	7.2	3.8	1.5	0.8	0.9	1.3	1.8	2.5	3.0	8760




Figure 3-1a Annual wind rose

Note) The trade winds (also called trades) are the prevailing pattern of easterly surface winds

found in the tropics, within the lower portion of the Earth's atmosphere, in the lower section of the troposphere near the Earth's equator.




Figure 3-1b Monthly wind rose

3.2. Hourly frequency distribution of wind direction

On hourly frequency distribution of wind direction per year with a height of 40 m, the wind directions of east to southeast prevail throughout the day. In particular, the wind directions of east-northeast and northeast appear continually from afternoon to evening (at 12:00 am to 19:00 pm). In addition, the wind direction of southeast is reduced and east-southeast and east are increased from morning to night (at 10:00 am to 18:00 pm).

Table3-2 Hourly frequency distribution of wind direction in year [ground height: 40 m]

Hour	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	CALM	sum
1	0.2	0.2	0.3	0.4	0.6	0.9	0.7	0.3	0.1	0.1	0.0	0.0	0.1	0.1	0.0	0.1	0.0	4.2
2	0.2	0.2	0.4	0.4	0.6	0.8	0.8	0.3	0.1	0.1	0.0	0.0	0.1	0.1	0.1	0.1	0.0	4.2
3	0.2	0.2	0.5	0.3	0.6	0.7	0.8	0.3	0.1	0.1	0.0	0.0	0.0	0.1	0.1	0.1	0.0	4.2
4	0.2	0.2	0.4	0.3	0.5	0.7	0.8	0.3	0.1	0.1	0.1	0.0	0.1	0.1	0.1	0.1	0.0	4.2
5	0.2	0.2	0.4	0.4	0.5	0.8	0.8	0.3	0.1	0.1	0.0	0.1	0.0	0.1	0.1	0.1	0.0	4.2
6	0.2	0.2	0.4	0.4	0.4	0.8	0.8	0.3	0.1	0.1	0.0	0.1	0.1	0.1	0.1	0.1	0.0	4.2
7	0.2	0.2	0.4	0.4	0.5	0.7	0.9	0.3	0.2	0.0	0.0	0.1	0.0	0.1	0.1	0.1	0.0	4.2
8	0.2	0.3	0.3	0.4	0.6	0.8	0.7	0.3	0.1	0.0	0.1	0.0	0.1	0.1	0.1	0.1	0.0	4.2
9	0.2	0.2	0.2	0.5	0.5	0.8	0.7	0.3	0.1	0.0	0.1	0.0	0.0	0.1	0.1	0.1	0.0	4.2
10	0.2	0.2	0.2	0.5	0.6	0.8	0.7	0.4	0.2	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.0	4.2
11	0.1	0.2	0.2	0.4	0.8	0.9	0.6	0.4	0.1	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.0	4.2
12	0.1	0.3	0.2	0.4	0.7	1.0	0.7	0.3	0.1	0.0	0.0	0.0	0.1	0.0	0.2	0.1	0.0	4.2
13	0.1	0.3	0.1	0.4	0.7	1.1	0.5	0.4	0.1	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.0	4.2
14	0.1	0.2	0.2	0.3	0.7	1.1	0.6	0.4	0.2	0.0	0.0	0.0	0.1	0.1	0.1	0.2	0.0	4.2
15	0.1	0.2	0.2	0.3	0.7	1.0	0.6	0.3	0.2	0.0	0.0	0.0	0.1	0.1	0.2	0.1	0.0	4.2
16	0.2	0.2	0.2	0.3	0.6	1.1	0.6	0.3	0.3	0.0	0.1	0.0	0.0	0.0	0.1	0.1	0.0	4.2
17	0.1	0.2	0.2	0.3	0.6	1.1	0.6	0.3	0.3	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.0	4.2
18	0.1	0.1	0.2	0.4	0.5	1.1	0.6	0.3	0.2	0.1	0.0	0.0	0.1	0.1	0.1	0.1	0.0	4.2
19	0.2	0.1	0.3	0.3	0.6	1.0	0.7	0.3	0.2	0.1	0.0	0.1	0.1	0.1	0.1	0.1	0.0	4.2
20	0.1	0.2	0.4	0.2	0.7	0.9	0.7	0.3	0.2	0.1	0.0	0.0	0.1	0.1	0.1	0.1	0.0	4.2
21	0.1	0.1	0.4	0.3	0.7	0.8	0.8	0.3	0.1	0.1	0.1	0.0	0.1	0.1	0.1	0.1	0.0	4.2
22	0.2	0.2	0.3	0.3	0.7	0.8	0.8	0.3	0.1	0.1	0.1	0.0	0.0	0.1	0.1	0.1	0.0	4.2
23	0.1	0.2	0.3	0.4	0.6	0.8	0.9	0.2	0.1	0.1	0.1	0.0	0.0	0.1	0.1	0.1	0.0	4.2
24	0.2	0.2	0.4	0.3	0.7	0.9	0.7	0.2	0.1	0.1	0.0	0.0	0.0	0.1	0.1	0.1	0.0	4.2
Ave.	3.9	4.7	7.1	8.5	14.5	21.3	17.2	7.2	3.8	1.5	0.8	0.9	1.3	1.8	2.5	3.0	0.0	100.0




Figure 3-2 Hourly frequency direction of wind direction in year [ground height: 40 m]

4. Frequency distribution of wind direction for each wind force scale, and correlation between mean wind speed and frequency distribution of wind direction

The wind direction of east-southeast is dominant with appearance ratio of 21.3%, the appearance of wind direction of east to southeast centered on the east-southeast is occupied 53% of the total. It should be noted that the frequency distribution of wind direction correlate significantly with mean wind speed.

Table 4-1 Frequency distribution of wind direction for each wind force scale, and correlation between mean wind speed and appearance ratio [ground height: 40 m]

Wind speed	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW
0<V<1	0.1	0.1	0.1	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
1≤V<2	0.3	0.2	0.2	0.2	0.1	0.1	0.3	0.3	0.3	0.2	0.2	0.2	0.3	0.2	0.2	0.2
2≤V<3	0.5	0.5	0.7	0.6	0.4	0.5	0.6	0.5	0.4	0.3	0.1	0.1	0.2	0.4	0.3	0.3
3≤V<4	1.0	1.1	2.8	1.5	1.4	1.0	1.0	0.7	0.3	0.4	0.3	0.3	0.3	0.6	0.5	0.6
4≤V<5	0.7	1.1	1.7	1.3	2.2	1.8	1.7	0.9	0.5	0.3	0.1	0.2	0.2	0.4	0.5	0.8
5≤V<6	0.5	0.6	0.5	1.5	2.5	2.2	1.8	1.3	0.6	0.1		0.1	0.1	0.1	0.5	0.5
6≤V<7	0.4	0.3	0.5	1.3	2.1	2.1	2.2	1.1	0.6	0.1			0.0	0.1	0.2	0.3
7≤V<8	0.3	0.3	0.4	0.9	1.9	2.6	2.0	0.9	0.3	0.0	0.0		0.1	0.0	0.0	0.2
8≤V<9	0.2	0.1	0.2	0.5	1.3	3.1	2.0	0.5	0.2	0.0		0.0		0.0	0.0	0.1
9≤V<10	0.0	0.3	0.0	0.3	0.8	2.6	1.6	0.4	0.1	0.0					0.0	0.0
10≤V<11		0.1		0.2	0.7	2.2	1.5	0.4	0.0							
11≤V<12			0.0	0.1	0.5	1.8	1.4	0.2	0.0							
12≤V<13			0.0	0.0	0.1	0.8	0.6	0.0	0.0							
13≤V<14				0.0	0.2	0.2	0.3	0.0	0.0							
14≤V<15				0.0	0.1	0.1	0.1	0.0	0.1							
Mean wind speed (m/s)	4.4	4.7	4.3	5.6	6.5	7.9	7.4	6.1	5.4	3.6	2.8	3.2	3.2	3.4	4.1	4.5
Appearance ratio (%)	3.9	4.7	7.1	8.5	14.5	21.3	17.2	7.2	3.8	1.5	0.8	0.9	1.3	1.8	2.5	3.0




Figure 4-1 Correlation between mean wind speed and frequency distribution of wind direction

5. Wind profile

In general, the wind speed increases with increasing altitude. It is said that the power law is applicable to the wind speed from near the ground up to height of 300 m. Therefore to clarify the wind profile, the power index is calculated.

Power law is defined by the following equation.

$$\frac{U}{U_1} = \left(\frac{z}{z_1} \right)^{1/n}$$

U : The wind speed at ground height of z m/s

U_1 : The wind speed at ground height of z_1 m/s

$1/n$: Power index

Power index, which varies depending on the atmospheric stability and roughness condition of the ground surface, the power index is shown in the table below in the case of the neutral atmospheric stability.

The value of the power index n of the power law

Ground condition	"n" value
Flat ground (grassland, coast)	7~10
Rural area	4~6
Urban area	2~4

Calculation result of power index ("n" value) is shown in Table 5-1 using the data for height of 40 m and 50m.

The "n" value is 3.5 in all directional average, indicates as same as the ground condition of urban area.

By direction, "n" value in east-southeast is 5.2, equivalent to the ground condition of rural area. Other direction's "n" values are 4.0 or less, it is assumed that wind profile is reflected by around timber (palm tree).

Table 5-1 Power index of wind direction

Wind direction	Mean wind speed (m/s)		Power index (n)	Appearance frequency
	40 m	50 m		40 m
N	4.4	4.8	2.3	332
NNE	4.7	4.7	—	360
NE	4.4	4.6	2.9	485
ENE	5.1	5.6	2.4	743
E	6.4	6.9	3.2	1461
ESE	7.8	8.2	5.2	1899
SE	7.4	7.8	3.9	1505
SSE	6.1	6.5	3.5	635
S	5.4	5.9	2.9	330
SSW	3.6	3.6	—	130
SW	2.8	2.9	5.0	67
WSW	3.2	3.4	2.7	82
W	3.3	3.6	2.4	104
WNW	3.2	3.5	1.9	160
NW	4.1	4.5	2.0	210
NNW	4.6	5.1	2.1	257
All directions	6.2	6.5	3.5	8760

Note) “-“ means a negative value or a value greater than or equal to 10.




Figure 5-1 Correlation between frequency distribution of wind direction and power index

6. Turbulence intensity

Turbulence intensity with a height of 40 m is 0.15 in all directional average, which is equivalent to the type of the plain field with reference to the following table named "Correlation between terrain types and disturbance intensity". In addition, the turbulence intensity at around wind speed of 15 m/s is 0.11, which fully satisfy the evaluation criteria of 0.18 or less.

Correlation between terrain types and turbulence intensity

Terrain types	Turbulence intensity
Sea, lake	0.10
Plain field	0.15
Hilly terrain	0.20
Low mountain terrain	0.25
High mountain terrain	0.30

Table 6-1 Turbulence intensity of wind direction for each wind force scale (ground height: 40m)

wind speed (m/s)	Wind direction																Sum
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
0 < V < 1	0.47	0.49	0.44	0.48	0.45	0.46	0.47	0.42	0.50	0.45	0.47	0.53	0.42	0.41	0.43	0.41	0.45
1 ≤ V < 2	0.29	0.29	0.27	0.30	0.27	0.28	0.31	0.28	0.28	0.24	0.32	0.25	0.25	0.23	0.25	0.26	0.27
2 ≤ V < 3	0.19	0.19	0.18	0.19	0.18	0.19	0.19	0.20	0.19	0.15	0.18	0.19	0.19	0.18	0.18	0.18	0.19
3 ≤ V < 4	0.15	0.16	0.14	0.16	0.17	0.15	0.15	0.15	0.17	0.15	0.18	0.18	0.17	0.13	0.16	0.15	0.16
4 ≤ V < 5	0.18	0.18	0.16	0.17	0.16	0.14	0.13	0.14	0.18	0.17	0.16	0.17	0.18	0.14	0.18	0.16	0.16
5 ≤ V < 6	0.21	0.20	0.19	0.17	0.15	0.12	0.12	0.13	0.17	0.18	0.22	0.21	0.20	0.18	0.19	0.20	0.15
6 ≤ V < 7	0.20	0.20	0.19	0.16	0.14	0.11	0.12	0.12	0.15	0.19	0.21	0.21	0.22	0.17	0.19	0.20	0.14
7 ≤ V < 8	0.20	0.20	0.19	0.15	0.14	0.11	0.11	0.12	0.15	0.19	0.23	0.32	0.19	0.19	0.19	0.20	0.13
8 ≤ V < 9	0.21	0.20	0.18	0.16	0.13	0.10	0.11	0.11	0.15	0.19	0.17	0.23	0.19	0.19	0.19	0.20	0.12
9 ≤ V < 10	0.21	0.20	0.19	0.15	0.13	0.10	0.10	0.11	0.14	0.20		0.21	0.22	0.15	0.18	0.19	0.12
10 ≤ V < 11	0.18	0.19	0.20	0.15	0.13	0.10	0.10	0.11	0.14	0.19	0.21		0.28		0.20	0.20	0.11
11 ≤ V < 12		0.19	0.18	0.15	0.13	0.10	0.10	0.10	0.14	0.51					0.17		0.11
12 ≤ V < 13			0.19	0.14	0.13	0.09	0.10	0.11	0.15						0.18		0.10
13 ≤ V < 14			0.19	0.14	0.13	0.09	0.09	0.09	0.15	0.15							0.10
14 ≤ V < 15	0.21		0.19	0.14	0.12	0.10	0.09	0.11	0.14								0.11
15 ≤ V < 16			0.17	0.14	0.12	0.11	0.09	0.10	0.13								0.12
16 ≤ V < 17			0.18	0.14	0.08	0.09	0.11	0.08	0.10								0.11
17 ≤ V < 18			0.17	0.15	0.12												0.15
18 ≤ V < 19				0.16		0.11	0.09										0.12
19 ≤ V < 20				0.15		0.08											0.13
20 ≤ V < 21				0.15	0.13	0.10	0.12										0.13
21 ≤ V < 22				0.15	0.13	0.08											0.13
22 ≤ V < 23				0.14	0.13	0.11											0.12
23 ≤ V < 24					0.12	0.12											0.12
24 ≤ V < 25																	
Sum	0.20	0.19	0.17	0.17	0.15	0.12	0.12	0.14	0.18	0.18	0.22	0.21	0.20	0.17	0.19	0.18	0.15




Figure 6-1 Correlation between turbulence intensity and 10 minutes average wind speed [in all wind directions, ground height: 40 m]




Figure 6-2 Correlation between turbulence intensity and 10 minutes average wind speed [each wind directions, ground height: 40 m]

7. Maximum instantaneous wind speed

Maximum instantaneous wind speed during the observation period is 32.9 m/s (1:00 am, January 25th, 2011).

In general, Survival wind speed for wind turbine of class 300kW is designed to 70 m/s, instantaneous wind speed exceeds survival wind speed is not observed in same period.

Table 7-1 Maximum wind speed and maximum instantaneous wind speed
[ground height : 40 m]

(unit: m/s)

Monty	2011							2010					Muximum value
	Jan.	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Max. wind speed	23.9	13.2	14.1	11.3	17.1	21.9	15.5	14.6	15.6	15.1	13.4	13.9	23.9
Max. instantaneous wind speed	32.9	18.9	22.3	15.5	21.2	28.7	20.8	22.7	19.3	18.9	18.1	21.2	32.9

Maximum instantaneous wind speed: AM1:00 25th January

8. Wind speed distribution

On distribution ratio for each wind force, the distribution ratio of class not less than 4 m/s but less than 5 m/s is most commonly (14.2%), the distribution ratio of more than 6 m/s is occupied approximately 48% of the total.

Incidentally, the distribution ratio of more than 12 m/s and less than 25 m/s which is generated rated output of 250 kW is 3 % of the total.

It is noted that wind speed distribution can be approximated by the Weibull distribution. Also in this evaluation, the Weibull parameters which are scale parameter represented by “c” and shape parameter represented by “k” are calculated by the method of least squares.

The Weibull function is defined as following equation.

Consequently, wind speed distribution is shown in Table 8-1, the scale parameter of the Weibull function is $c = 7.18$, the shape parameter of the Weibull function is $k = 2.21$.

$$f(V) = \frac{k}{c} \left(\frac{V}{c} \right)^{k-1} \cdot \exp \left\{ - \left(\frac{V}{c} \right)^k \right\}$$

Where

$f(V)$: appearance ratio of wind speed of “V” (%)

c : the scale parameter of the Weibull function

k : the shape parameter of the Weibull function

Table 8-1 Monthly and annual wind speed distribution [ground height: 40 m]

Wind speed (m/s)	2011							2010					In a year
	Jan.	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
0<V<1	0.7	0.6	3.6	2.1	1.5	0.4	4.8	0.7	0.7	1.5	0.3	0.9	1.5
1≤V<2	3.8	1.6	3.2	2.4	6.0	1.7	7.9	1.5	1.7	2.7	2.5	4.2	3.3
2≤V<3	8.7	4.0	7.3	4.7	8.9	7.4	10.5	5.9	4.6	5.9	3.5	6.6	6.5
3≤V<4	17.9	15.3	17.6	21.8	14.5	14.0	12.9	20.8	8.9	7.7	6.1	6.2	13.6
4≤V<5	12.1	18.8	24.2	18.1	11.0	18.2	13.4	15.5	11.5	15.2	6.4	7.1	14.3
5≤V<6	11.4	19.0	14.2	15.0	10.1	17.2	9.9	10.9	17.2	13.0	10.4	7.8	13.0
6≤V<7	10.9	13.8	9.0	16.4	9.8	12.9	8.1	8.2	12.1	9.5	15.3	9.7	11.3
7≤V<8	12.6	11.9	7.9	9.9	9.0	7.2	7.3	7.7	12.5	5.6	13.3	16.5	10.1
8≤V<9	10.8	7.7	4.2	6.7	10.8	4.7	9.0	6.2	6.0	4.7	15.1	14.1	8.3
9≤V<10	5.1	4.0	4.7	2.9	6.7	3.6	6.2	5.9	3.9	6.5	13.1	10.8	6.1
10≤V<11	1.9	1.6	2.4	0.1	6.3	1.8	5.1	6.2	7.9	8.7	8.8	9.8	5.1
11≤V<12	1.5	1.3	1.5		4.2	3.1	3.0	6.9	7.4	9.7	4.0	5.5	4.0
12≤V<13	0.4	0.1	0.1		0.8	1.5	0.8	3.2	4.4	5.4	1.3	0.8	1.6
13≤V<14	1.1				0.3	2.1	0.8	0.4	1.0	3.6			0.8
14≤V<15	0.4					2.8	0.3	0.1	0.3	0.3			0.3
15≤V<16	0.3				0.1	1.0							0.1
16≤V<17						0.1							
17≤V<18													
18≤V<19	0.1												
19≤V<20	0.1					0.1							
20≤V<21						0.1							
21≤V<22													
22≤V<23	0.3												
23≤V<24													
24≤V<25													
Sum	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Table 8-2 Monthly and annual Weibull parameter

Parameter	2011							2010					In a year
	Jan.	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
k	2.01	3.14	2.46	3.05	2.34	2.32	1.89	2.77	2.85	2.30	2.81	2.65	2.21
c	7.10	6.57	5.92	5.83	6.49	7.65	6.13	7.08	7.56	7.95	8.01	7.27	7.17

(unit: %)




Figure 8-1 Annual wind speed distribution




Figure 8-2 Annual cumulative wind speed distribution

9. Density of wind energy

Density of wind energy is calculated Annual average spot the of (air field) and by using standard atmospheric conditions (temperature: 15°C, atmospheric pressure: 1013 hPa, vapor pressure: 17.05 hPa) and annual average of local atmospheric conditions (temperature: 24.2°C, atmospheric pressure: 1012.7 hPa, vapor pressure: 29.8 hPa) in order to evaluate the amount of potential for wind development.

The density of wind energy is calculated by the following equation.

$$P_0 = \sum (0.5 \cdot \rho \cdot V^3) / n$$

P_0 : annual density of wind energy (w/m²)
 ρ : air density (kg/m³)
 V : hourly average wind speed (m/s)
 n : number of hours in the applicable period

The energy density with height of 40 m is 244 W/m² at the standard atmospheric conditions and 236 W/m² at local atmospheric conditions which is approximately 3% less than the value at standard atmospheric conditions.

By direction, the energy density of east-northeast is the largest (390 W/m²: standard atmospheric conditions, 405 W/m²: local atmospheric conditions), and east is second largest (360 W m²: standard atmospheric conditions, 347 W/m²: local atmospheric conditions).

As well as the energy density, the energy acquisition ratio of east-southeast is the largest (35.4%), and southeast is second largest (25.3%).

In addition, energy acquisition ratio in just three directions (northeast to east) is occupied approximately 76% of the total. (with regard to energy acquisition ratio, there is no significant distinction between the ratio under standard atmospheric conditions and local atmospheric conditions)

Table 9-1 Density of wind energy and energy acquisition ratio

Wind direction	Density of wind energy (W/m ²)		Energy acquisition ratio (%)	
	SAC	LAC	SAC	LAC
N	83	80	1.3	1.3
NNE	110	106	2.1	2.1
NE	75	73	2.2	2.2
ENE	177	171	6.2	6.2
E	259	250	15.4	15.4
ESE	405	390	35.4	35.4
SE	360	347	25.3	25.3
SSE	216	208	6.4	6.4
S	190	183	2.9	2.9
SSW	49	48	0.3	0.3
SW	25	24	0.1	0.1
WSW	37	35	0.1	0.1
W	40	39	0.2	0.2
WNW	38	37	0.3	0.3
NW	67	65	0.7	0.7
NNW	84	81	1.0	1.0
All directions	244	235	100.0	100.0

SAC: Standard atmospheric conditions

LAC: Local atmospheric conditions




Figure 9-1 Density of wind energy and energy acquisition ratio (standard atmospheric conditions)




Figure 9-2 Density of wind energy and energy acquisition ratio (local atmospheric conditions)

10. Availability (generation available time ratio)

The availability of the wind turbine is calculated by using the data of wind condition with height of 40 m. As a result of the calculation is shown in Table 10-1 and Figure 10-1.

The availability of the wind turbine is 88.7% in the year.

Looking at monthly availability, the highest is 93.8% in February, meanwhile the lowest is 76.7% in July.

The term “Availability” here, means the ratio of the amount of time that the operable wind speed is obtained to all calendar time during the same period.

Table 10-1 Generation available time ratio
(unit: %)

year/month	Wind turbine 250 kW
Jan. 2011	86.8
Feb. 2011	93.8
Mar. 2011	85.9
Apr. 2011	90.8
May. 2011	83.6
Jun. 2011	90.6
Jul. 2011	76.7
Aug. 2010	91.9
Sep. 2010	93.1
Oct. 2010	89.9
Nov. 2010	93.8
Dec. 2010	88.3
In a year	88.7




Figure 10-1 Generation available time ratio

11. Wind energy production and capacity factor

11.1. Wind energy production

The wind energy production is calculated by accumulating the hourly value corresponding to the performance curve a wind turbine of 250 kW based on hourly average wind speed with height of 40 m.

The performance curve of 300 kW class wind turbine to calculate wind energy production is used to limit to 250 kW rated output.

As a result, the wind energy production per year is estimated to 565 MWh. The largest monthly wind energy production is approximately 69 MWh in October, and the lowest is approximately 24 MWh in April.

In addition, since wind energy density at local atmospheric conditions is approximately 3% less than the wind energy density at standard atmospheric conditions, the wind energy production is assumed to decline by approximately 3% compared with the results calculated by the standard atmospheric conditions.

Table 11-1 Monthly production of wind energy

風車№	Item	2010					2011							Sum
		Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	
トンガ	Energy production (kWh)	51,165	59,148	68,864	65,160	66,916	40,248	29,648	27,435	24,022	47,995	42,576	41,658	564,835
	Mean wind speed (m/s)	6.2	6.9	7.1	7.2	7.0	5.8	5.7	5.1	5.2	6.0	6.2	5.5	6.2
	Generation available time ratio (%)	91.9	93.1	89.9	93.8	88.3	86.8	93.8	85.9	90.8	83.6	90.6	76.7	88.7
	Capacity factor (%)	27.5	32.9	37.0	36.2	36.0	21.6	17.6	14.8	13.3	25.8	23.7	22.4	25.8




Figure 11-1 Monthly production of wind energy

Table 11-2 Wind energy production by wind direction

Item	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Sum
Energy production (kWh)	7,096	11,866	10,161	32,547	85,456	204,471	147,584	37,892	15,193	1,263	215	484	906	989	3,274	5,437	564,835




Figure 11-2 Wind energy production by wind direction

Wind speed (m/s)	Output (kW)
	250 kW
0.0	-
1.0	-
2.0	-
3.0	0.0
4.0	1.8
5.0	11.2
6.0	35.0
7.0	66.7
8.0	103.9
9.0	143.9
10.0	184.0
11.0	221.7
12.0	250.0
13.0	250.0
14.0	250.0
15.0	250.0
16.0	250.0
17.0	250.0
18.0	250.0
19.0	250.0
20.0	250.0
21.0	250.0
22.0	250.0
23.0	250.0
24.0	250.0
25.0	250.0
Cut-in wind speed (m/s)	3.0
Rated wind speed (m/s)	11.5
Cut-out wind speed (m/s)	25.0

Note: Standard power curve at air density of 1.225kg/m³




Figure 11-3 Performance curve of a 250 kW wind turbine

11.2. Capacity factor

The capacity factor is calculated based on the wind energy production at standard atmospheric conditions is shown in Table 11-3 and Figure 11-4. The annual capacity factor is 25.8%, the highest monthly capacity factor is 37.0% in October and the lowest is 13.3% in April.

In addition, when local atmospheric conditions is considered, the capacity factor is assumed to decline by about 3% compared with the results calculated by the standard atmospheric conditions.

Table 11-3 Monthly utilization of wind turbine equipment

(unit: %)

year/month	wind turbine 250 kW
Jan. 2011	21.6
Feb. 2011	17.6
Mar. 2011	14.8
Apr. 2011	13.3
May. 2011	25.8
Jun. 2011	23.7
Jul. 2011	22.4
Aug. 2010	27.5
Sep. 2010	32.9
Oct. 2010	37.0
Nov. 2010	36.2
Dec. 2010	36.0
In a year	25.8




Figure 11-4 Monthly capacity factor

12. Conclusion

12.1. Wind conditions

- Annual average wind speed (40m height above ground) is calculated to be 6.2m/s.
Monthly average wind speed has tendency to be the highest (7.2 m/s) in October to November and to be somewhat lower (5.1 to 5.5 m/s) in March to April and July.
- With regard to wind distribution, three wind directions which are east (14.5%), east-southeast (21.3%) and southeast (17.2%) are dominant.
Therefore, the wind axis is considered to be a line from east-southeast to west-northwest (58.6%).
- The power index ("n" value) in all directions is $n=3.5$ equivalent of urban area.
And the power index in prevailing wind direction (east-southeast) is $n=45$ to 5.0 equivalent of rural area.
- Turbulence intensity is 0.15 in omni-directional average, which is equivalent to the type of the plain field. In addition, the turbulence intensity at around wind speed of 15 m/s is 0.11, which fully satisfy the evaluation criteria of 0.18 or less.
- Maximum instantaneous wind speed during the observation period is 32.9 m/s (1:00 am January 25th, 2011).
In general, Survival wind speed for wind turbine of class 300kW is designed to 70 m/s, there is little possibility of appearance over survival wind speed in the region.
- With regard to distribution ratio for each wind force, the distribution ratio of class more than 4 m/s and less than 5 m/s is most commonly (14.2%).
Incidentally, the distribution ratio of more than 12 m/s and less than 25 m/s which can be generated rated output of 250 kW is 3 % of the total.
- The scale parameter of the Weibull function is $c = 7.18$, and the shape parameter of the Weibull function is $k = 2.21$.

12.2. Wind energy

The energy density with height of 40 m is 244 W/m² at the standard atmospheric conditions and 235 W/m² at local atmospheric conditions which is approximately 3% less than the value at standard atmospheric conditions.

Energy density required for the development of wind power is equal to or greater than 240 W/m² (30 m height above ground), the above results slightly below the criteria.

However, in these days the criterion of mean wind speed for wind power in Japan is more than 6 m/s at hub height of wind turbine.

Because the annual average wind speed is 6.2 m/s at 40m height above ground, the value can be expected towards the development of wind power.

12.3. Capacity factor and generation available time ratio

The capacity factor of the wind turbine is 25.7% and the availability is 88.7%.

Those values are fully satisfied the criteria (capacity factor should be 20% or more, availability should be 45% or more).

12.4. Comprehensive evaluation

According to the analysis of wind conditions, wind speed condition such as mean wind speed and density of wind energy generally meet the criteria. Furthermore, capacity factor of the wind turbine and availability are also fully satisfied the criteria, it is deemed to be feasible to develop wind power generation at the site.

The results of the analysis of the wind profile, since the “n” value indicate urban area, examination of wind turbine layout should be consider the effects of ground roughness (such as felling of trees around)

In the case of the arrangement of the wind turbine plurality, it is necessary to be separated by 3D (D: rotor diameter) or more in the direction perpendicular to the wind axis (east-northeast)

The results of the analysis of wind conditions are shown in Table 12-1.

The amount of wind energy production by the assumed components of wind turbine is estimated as follows.

Components	Amount of wind energy production	Conditions
Installed capacity:500kW (250kW x 2 units)	1,130 MWh/year	Standard atmospheric conditions
	1,096 MWh/year (approx. 1.1 GWh/year)	Local atmospheric conditions

The wind energy production noted above is gross output.

To assume net output, it is necessary to consider the loss as shown below. The total loss is roughly estimated to be about 20% of the gross output.

Therefore, net output is able to be estimated at 80% of gross output.

Type of loss	Contents
Outage	Scheduled maintenance
Mechanical loss	Loss on speed-up gear, loss on lag of wind direction following, etc.
Electrical loss	Transformer loss, Transmission loss to the point of interconnection, etc.

Table 12-1 Analysis result for wind condition

Analysis item		Result of analysis	Judgment	Remarks
Mean wind speed	Annual average	6.2 m/s	Good (Criteria #1)	
	Maximum	7.2 m/s		November
	Minimum	5.1 m/s		March
Wind direction	Prevailing wind direction	ESE 21.3%		
	Wind axis	ESE - WNW (E-W) (SE-NW) 58.6%	Basically good (Criteria #2)	Wind axis means 6 wind directions (the prevailing wind direction and the both sides, and their opposing wind directions)
Correlation between wind direction and wind speed		Roughly fit		
Maximum instantaneous wind speed		32.9 m/s	Good (Criteria #3)	25th January 2011 AM 1:00
Turbulence intensity	360-degree	0.15	Good (Criteria #4)	
	In wind speed of 15m/s	0.11		
Wind profile (power index: n)		3.5	Poor (Criteria #5)	5.2 (at prevailing wind direction): Basically good
Weibull function	Shape parameter (k)	7.17		
	Scale parameter (C)	2.21		
Density of wind energy (in all directions)		244 W/m ² (235 W/m ²)	Basically good (Criteria #6)	The value as calculated under local atmospheric conditions is shown in parentheses
Availability (Generation available time ratio)		88.7%	Good (Criteria #7)	
Annual energy production		565 MWh		In case of 250 kW wind turbine
Capacity factor		25.8%	Good (Criteria #8)	

Criteria #1: Annual average should be 6m/s or more

Criteria #2: Annual frequency distribution of wind direction on wind axis should be 60% or more

Criteria #3: Maximum instantaneous wind speed should be 70 m/s (typical survival wind speed) or less

Criteria #4: Turbulence intensity should be 1.8 (in around wind speed of 15 m/s) or less

Criteria #5: high power index of wind profile, and low wind shear

Criteria #6: Density of wind energy should be 240 W/m² or more

Criteria #7: Annual availability (generation available time ratio) should be 45% or more

Criteria #8: Capacity factor should be 20% or more

Note) The above criteria are given by the following manuals and guidelines which has been established by NEDO (New Energy and Industrial Technology Development Organization, an independent government agency in Japan).


- Evaluation manual for wind conditions (Dec. 1997, digest version)
- Evaluation manual for high-altitude wind conditions (Feb. 2006)
- Introduction guidebook for wind power generation (Feb. 2008 the revised ninth version)

A-10 Outline Design Drawings

Drawing List

図面リスト

Dwg. No.	Title
E-01	Power System in Tongatapu Island トンガタプ島の電力系統
E-02	Control System of Generation Facilities 発電設備システムの制御システム
E-03	Single Line Diagram of the Equipment at Vaini Project Site バイニ計画地側の対象設備の単線結線図
E-04	Single Line Diagram of the Equipment at Popua Power Station ポプア発電所側の対象設備の単線結線図
E-05	Layout of the Equipment at Vaini Project Site バイニ計画地側の対象設備の機材配置
E-06	Layout of the Equipment at Popua Power Station ポプア発電所側の対象設備の機材配置
E-07	Layout of PV Arrays at Vaini Project Site バイニ計画地における PV アレイ配置
E-08	Control System of Number of CAT Diesel Engine Generators in Operation CAT 製ディーゼル発電機の運転台数制御システム




— EXISTING EQUIPMENT

— PROCURED AND INSTALLED BY THE JAPANESE SIDE


— PROCURED BY THE JAPANESE SIDE AND INSTALLED BY THE TONGAN SIDE

— PROCURED AND INSTALLED BY THE TONGAN SIDE

Popua Power Station ← → Vaini Project Site




A-10-3



E-03



Single Line Diagram of the Equipment at Vaini Project Site
バイニ計画地側の対象設備の単線結線図




* DC Power Supply Panel shall be installed for energy use.


Single Line Diagram of the Equipment at Popua Power Station
 ポプア発電所側の対象設備の単線結線図

E-05
Layout of the Equipment at Vaini Project Site
バイニ計画地側の対象設備の機材配置



E-06
Layout of the Equipment at Popua Power Station
ポプア発電所側の対象設備の機材配置





UNIT:m

E-07
Layout of PV Arrays at Vaini Project Site
バイニ計画地におけるPVアレイ配置



