

I. WWTP 容量計算書

表 I.1 C1 処理場 容量計算書 (1/16)

1 BASIC CONDITIONS

1-1 Basic Items

- (1) Name : C1 WWTP
- (2) Land Area : Approximately xxxx ha
- (3) Ground Level (Elevation) : + 4.50 m
- (4) Inlet Pipe Invert Level : - 6.80 m
- (5) Pipe Diameter : 1,500 mm
- (6) Land Use : —
- (7) Collection System : ~~Combined System~~ **Separate System**
- (8) Treatment Process : Conventional Activated Sludge Process
- (9) Effluent Point : Yangon River
- (10) Water Level at the Effluent Point :
 High water level = 3.70 m
 Low water level = — m
- (11) Target Year : 2020 (F/S Stage)
 2040 (M/P Stage)

1-2 Service Area and Design Population

- (1) Service Area : 499 ha
- (2) Design Population

Item	Year 2020	Year 2040
Design Population person	-	178,000

表 I.1 C1 処理場 容量計算書 (2/16)

1-3 Design Sewage Flow

(Year 2020)

Item	m ³ /day	m ³ /hr	m ³ /min	m ³ /sec
Maximum Daily Flow		0.0	0.00	0.000
Maximum Hourly Flow	0	0.0	0.00	0.000

(Year 2040)

Item	m ³ /day	m ³ /hr	m ³ /min	m ³ /sec
Maximum Daily Flow	70,200	2,925.0	48.75	0.813
Maximum Hourly Flow	102,900	4,287.5	71.46	1.191

1-4 Design Sewage Quality

Item	BOD	SS	T-N	Coli-group	Oil&Greese
	(mg/l)	(mg/l)	(mg/l)	(MPN/cm ³)	(mg/l)
Influent	200	180	-	-	-
Effluent	20	30	-	3,000	5

1-5 Process Flow Diagram




表 I.1 C1 処理場 容量計算書 (3/16)

1.6 Design Criteria

ITEMS	UNIT	Formula or Value	Application
1 Grit Chamber (For Maximum Hourly Flow)			
(1) Hydraulic Load	m ³ /m ² /day	1,800	1,800
(2) Average Velocity	m/sec	0.3	0.3
2 Primary Sedimentation Tank (For Maximum Daily Flow)			
(1) Hydraulic Load	m ³ /m ² /day	35.0-70.0	50
(2) Settling Time (Ref.)	hour	1.5	1.5
(3) Water Depth	m	2.5-4.0	3.5
(4) Weir Loading	m ³ /m/day	250	250
3 Aeration Tank (For Maximum Daily Flow)			
(1) Hydraulic Retention Time (HRT)	hour	6 - 8	6.0
(2) MLSS Concentration	mg/l	1,500 -2,000	2,000
(3) BOD-SS Load (Reference only)	kg/kg/day	0.2 - 0.4	-
4 Final Sedimentation Tank (For Maximum Daily Flow)			
(1) Hydraulic Load	m ³ /m ² /day	20.0-30.0	25
(2) Settling Time (Ref.)	hour	3.0-4.0	-
(3) Water Depth	m	2.5-4.0	3.5
(4) Weir Loading	m ³ /m/day	150	150
5 Disinfection Tank (For Maximum Daily Flow)			
(1) Retention (Chlorination) Time	min	15	15
6 Gravity Thickener (For Maximum Daily Flow)			
(1) Solids Loading	kg/m ² /day	60-90	75
(2) Water Depth	m		4.0

表 I.1 C1 処理場 容量計算書 (9/16)

Continuing Aeration Tank
(2) Proposed

Item	Sign	Unit	Calculation	F/S	M/P				
Type	-	-	Multi-tank Complete mixing Type						
Design Sewage Flow	Q1	m ³ /day			24,800				
(Maximum Daily Flow)	Q2	m ³ /hr			1,033.3				
Hydraulic Retention Time	HRT	hr			6.0				
Basin Number	BN	basin			2				
Required Volume per basin	RV	m ³ /basin	Q2×RT/BN		3,100				
Width	W	m	1~2H		12.0				
Water Depth	H	m	4.0m~6.0m		5.5				
Length	L1	m	RV/(W×H)		47.0				
	<i>Therefore</i> L2	m			48.2				
Dimension									
(Width)	W	m			12.0				
(Depth)	H	m			5.5				
(Length)	L	m			48.2				
(Basin Number)	N	basin			2				
(Check)									
Hydraulic Retention Time	HRT	hour	W×H×L×N/Q2		6.2				
BOD-SS load	BSS _L	kgBOD/kgSS/d	(Q1×BOD _{in})/(W×H×L×N×Xa)		0.23				
BOD _{in} : Inflow BOD Concentration			120 mg/L	(Removal Rate in PST : 40%)					
Xa : MLSS Concentration			2,000 mg/L						
Aerobic Sludge Retention Time	ASRT	day	HRT/24×Xa / (a×S-BOD _{in} + b×SS _{in} - c×HRT/24×Xa) =		4.888				
S-BOD _{in} : Inflow S-BOD Concentration			80 mg/L	(S-BOD[Solved BOD]=BOD _{in} ×0.6)					
SS _{in} : Inflow SS Concentration			90 mg/L	(Removal Rate in PST : 50%)					
a : Sludge converting ratio of solved BOD			0.5 mgMLSS/mgBOD	(0.4~0.6)					
b : Sludge converting ratio of SS			0.95 mgMLSS/mgSS	(0.9~1.0)					
c : Sludge reduction ratio caused by endogenous respiration			0.04 (1/day)	(0.03~0.05)					
Effluent Quality (C-BOD)	EQ	mg/L	10.42×A-SRT ^(-0.519) (15~20°C)		4.573				
Water Temperature			20 °C						
Effluent Water Quality (C=BOD Maximum)			EQ×3		14				
					-OK-				
			1 : 1.5 : 1.5 : 2.25						
Partition of Aeration Tank			<table border="1" style="display: inline-table; border-collapse: collapse;"> <tr> <td>No.1</td> <td>No.2</td> <td>No.3</td> <td>No.4</td> </tr> </table>	No.1	No.2	No.3	No.4		
No.1	No.2	No.3	No.4						
Total Length of Tank	TL	m			48.2				
No.1 Tank Length	L1	m	TL×1/(1+1.5+1.5+2.25)		7.7				
No.2 Tank Length	L2	m	TL×1.5/(1+1.5+1.5+2.25)		11.6				
No.3 Tank Length	L3	m	TL×1.5/(1+1.5+1.5+2.25)		11.6				
No.4 Tank Length	L4	m	TL×2.25/(1+1.5+1.5+2.25)		17.4				
			Total		48.3				

7)

表 I.1 C1 処理場 容量計算書 (13/16)

2-6 Disinfection Channel

(1) Proposed

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Chlorination		
Design Sewage Flow	Q1	m ³ /day			70,200
(Maximum Daily Flow)	Q2	m ³ /min			48.75
Retention(Chlorination) Time	RT	min			15.0
Required Volume	RV	m ³	Q2×RT		731
Width of channel	W	m			2.5
Depth of channel	H	m			2.0
Pass Number	PN	pass			6
Length of channel	L1	m/pass	RV/(W×H×PN)		24.4
<i>Therefore</i>	L2	m/pass			24.5
Dimension (Width)	W	m			2.5
(Depth)	H	m			2.0
(Length)	L	m/pass			24.5
(Pass Number)	N	pass			6
(Check)					
Retention(Chlorination) Time	RT	min	(W×H×L×PN)/Q2		15.1

表 I.1 C1 処理場 容量計算書 (14/16)

2-7 Sludge Thickening Tank

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Gravity Thickener (Radial Flow Circular Type)		
Generated Sludge Solids	GS	t-DS/day	Refer to Mass Balance Cal.		12.32
Generated Sludge Volume	GSV	m ³ /day	Refer to Mass Balance Cal.		1,503
Solid Matter Load	SML	kg/m ² /day			75
Required Surface Area	SA	m ²	$(GS \times 10^3) / SML$		164.3
Water Depth	H	m			4.1
Basin Number	BN	basin			2
Required Tank Diameter	TD1	m	$(SA \times 4 / (3.14 \times BN))^{0.5}$		10.23
Therefore	TD2	m			10.5
Dimension (Diameter)	D	m/basin			10.5
(Depth)	H	m			4.1
(Basin Number)	BN	basin			2
(Check)					
Solid Matter Load	SML	kg/m ² /day	$GS \times 10^3 / (3.14 \times D^2 / 4) \times BN$		71.2
Sludge Thickened Time	T	hr	$(3.14 \times D^2 / 4) \times H \times BN \times 24 / GSV$		11.3

2-8 Sludge Dewatering

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Mechanical Dewatering (Screw Press Type)		
Thickened Sludge Solids	TS	t-DS/day	Refer to Material Balance		11.201
Unit Number	UN	Unit			4
Operating Day	OD	day/(week)			5.0
Operating Time	OT	hr/day			10.0
Required Dewatering Capacity	DC	kg/hr/unit	$TS \times 10^3 \times 7 / (OD \times OT \times UN)$		392.0
Solids Loading	Q ₁₀₀	kg-ds/hr/φ100			3.0
Screnn Diameter	SD1	mm	$100 \times (DC / Q_{100})^{(1/2.2)}$		916.0
Therefore	SD2	mm			800
Dimension (unit)	UN	Unit			4
(Screen Diameter)	SD	mm			800
(Check)					
Dewatering Capacity	DC	kg/hr/unit	$(SD / 100)^{2.2} \times Q_{100}$		291.0
Operating Time	OT	hour/day	$TS \times 10^3 / (DC \times (UN - 1)) \times (7 / OT)$		13.5

表 I.1 C1 処理場 容量計算書 (15/16)

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Mechanical Dewatering)

Table-1 Input Data

1. Calculation Manner	1: Premise that the quality of supernatants are same level removed with inlet sewage 2: Premise that the entire supernatants are removed at treatment process																					
2. Selection of Treatment Efficiency	1: Total Removal Ratio 2: Outlet Water Quality (input 1 or 2)																					
In case of 1: input data	90 (%)																					
In case of 2: input data	30 (mg/l)																					
3. Excess Sludge Generation	1: Consideration of Solid Matter Only 2: Consideration of Converting of Solved BOD (input 1 or 2)																					
In case of 1: input data (Sludge generation)	100																					
In case of 2: input data	<table border="1"> <tr> <td>a</td> <td>-----</td> <td>T2=Q2*S2=(a*S_{BOD}+b*S1-c*θ*XA)*Q1*10⁶**Excess sludge generation formula</td> </tr> <tr> <td>b</td> <td>-----</td> <td>a: Converting ratio of solved BOD(mg/MLSS mgBOD)</td> </tr> <tr> <td>c</td> <td>-----</td> <td>b: Converting ratio of SS(mg/MLSS mgSS)</td> </tr> <tr> <td>SBOD</td> <td>-----</td> <td>c: Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)</td> </tr> <tr> <td>XA</td> <td>-----</td> <td>S_{BOD}: Solved BOD quality at inlet to reactor</td> </tr> <tr> <td>θ</td> <td>-----</td> <td>XA: MLSS concentration(mg/l)</td> </tr> <tr> <td></td> <td>-----</td> <td>θ: Hydraulic retention time(day)</td> </tr> </table>	a	-----	T2=Q2*S2=(a*S _{BOD} +b*S1-c*θ*XA)*Q1*10 ⁶ **Excess sludge generation formula	b	-----	a: Converting ratio of solved BOD(mg/MLSS mgBOD)	c	-----	b: Converting ratio of SS(mg/MLSS mgSS)	SBOD	-----	c: Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)	XA	-----	S _{BOD} : Solved BOD quality at inlet to reactor	θ	-----	XA: MLSS concentration(mg/l)		-----	θ: Hydraulic retention time(day)
a	-----	T2=Q2*S2=(a*S _{BOD} +b*S1-c*θ*XA)*Q1*10 ⁶ **Excess sludge generation formula																				
b	-----	a: Converting ratio of solved BOD(mg/MLSS mgBOD)																				
c	-----	b: Converting ratio of SS(mg/MLSS mgSS)																				
SBOD	-----	c: Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)																				
XA	-----	S _{BOD} : Solved BOD quality at inlet to reactor																				
θ	-----	XA: MLSS concentration(mg/l)																				
	-----	θ: Hydraulic retention time(day)																				


Table 2 Basic Conditions

Water Flow and Quality		Sludge Moisture and Recovery Ratio		Chemical Conditions for Dewatering	
*Inlet flow: Q(m ³ /D)	70200	*Primary sludge moisture ratio: W1(%)	98.5	*Removal ratio in primary tank: A2(%)	50.0
*Inlet quality: S0(mg/l)	180	*Excess sludge moisture ratio: W2(%)	99.5	*Recovery ratio in sludge thickener: A3(%)	90.0
*Total removal ratio: A1(%)	-	*Thickened sludge moisture ratio: W3(%)	98.0	*Recovery ratio in dewatering: A4(%)	95.0
*Effluent quality: S1(mg/l)	30.0	*Dewatered sludge moisture ratio: W4(%)	80.0		
*Sludge generation ratio per removal: S1(%)	100.0				

Table-3 Material Balance Calculation

	0	1	2	3	4	5	6	7	8	9	10	11	12	S-1
Q(m ³ /day)	70200	71205	481	71224	1022	70202	554	948	55	610	52	557	1505	70147
T(t*DS/day)	12636	14428	7214	7214	5108	2106	11090	1232	0.111	11201	10.641	0.560	1.792	1995
S(mg/l)	180	301	15000	101	5000	30	20000	1300	2000	18364	200000	1006	1191	30
X(θ*TV*100)	100	114.2	27.1	27.1	40.4	16.7	87.8	9.8	0.9	88.6	84.2	4.4	14.2	15.8

Figure-1 Material Balance Model



Calculation Formula					
*Q0=Input Data	*Q3=Q1-Q2	*Q6=T4*100/(100-W3)	*Q9=Q6-Q8	*Q12=Q7-Q11	*Q5=Q5-Q8
*T0=Q0*S0*10 ⁶ (-6)	*T3=T1/(100-A2)*100	*T6=(T2-T4)*A3/100	*T9=T6-T8	*T12=T7-T11	*T5=1=T5-T8
*S0=Input Data	*S3=T3*10 ⁶ /Q3	*S6=10 ⁶ *Q6/(100-W3)*100	*S9=T9*10 ⁶ /Q9	*S11=T11*10 ⁶ /Q11	*S5=1=S5
*Q1=Q0-Q13	*Q4=(Q3*S3-T3*10 ⁶)/(S1-S4)*T4/(T3-T5)	*Q7=(Q2-Q4)-Q6	*Q10=T10*100/(100-W4)		
*T1=T0-T13	*T4=((T1-T5)*S1/100)-T2	*T7=(T2-T4)-T6	*T10=T9*A4/100		
*S1=T1*10 ⁶ /Q1	*S4=10 ⁶ *Q4/(100-W2)*100	*S7=T7*10 ⁶ /Q7	*S10=10 ⁶ *Q10/(100-W4)*100		
*Q2=T2*100/(100-W1)	*Q5=(T3*10 ⁶ -Q3*S4)/(S1-S4)	*Q8=T6*A5/A6	*Q11=Q9-Q10		
*T2=T1-T3	*T5=Q5*S1*10 ⁶	*T8=Q8*S8*10 ⁶	*T11=T9-T10		
*S2=10 ⁶ *Q2/(100-W1)*100	*S5=S1	*S8=10 ⁶ *A6	*S11=T11*10 ⁶ /Q11		

表 I.1 C1 処理場 容量計算書 (16/16)

Material Balance Sheet




表 I.2 C2+E1 処理場 容量計算書 (1/11)

1 BASIC CONDITIONS

1-1 Basic Items

- (1) Name : C2+E1 WWTP
- (2) Land Area : Approximately xxxx ha
- (3) Ground Level (Elevation) : + 4.00 m (Plan)
- (4) Inlet Pipe Invert Level : - 15.82 m
- (5) Pipe Diameter : 3,200 mm
- (6) Land Use : —
- (7) Collection System : ~~Combined System~~ **Separate System**
- (8) Treatment Process : Conventional Activated Sludge Process
- (9) Effluent Point : Ngamoeyeik Creek
- (10) Water Level at the Effluent Point :
 High water level = 3.70 m
 Low water level = — m
- (11) Target Year : 2020 (F/S Stage)
 2040 (M/P Stage)

1-2 Service Area and Design Population

- (1) Service Area : 11,286 ha
- (2) Design Population

Item	Year 2020	Year 2040
Design Population person	-	1,902,000

表 I.2 C2+E1 処理場 容量計算書 (2/11)

1-3 Design Sewage Flow

(Year 2020)

Item	m ³ /day	m ³ /hr	m ³ /min	m ³ /sec
Maximum Daily Flow		0.0	0.00	0.000
Maximum Hourly Flow	0	0.0	0.00	0.000

(Year 2040)

Item	m ³ /day	m ³ /hr	m ³ /min	m ³ /sec
Maximum Daily Flow	744,000	31,000.0	516.67	8.611
Maximum Hourly Flow	1,116,000	46,500.0	775.00	12.917

1-4 Design Sewage Quality

Item	BOD	SS	T-N	Coli-group	Oil&Grease
	(mg/l)	(mg/l)	(mg/l)	(MPN/cm ³)	(mg/l)
Influent	200	180	-	-	-
Effluent	20	30	-	3,000	5

1-5 Process Flow Diagram




表 I.2 C2+E1 処理場 容量計算書 (3/11)

1.6 Design Criteria

ITEMS	UNIT	Formula or Value	Application
1 Grit Chamber (For Maximum Hourly Flow)			
(1) Hydraulic Load	m ³ /m ² /day	1,800	1,800
(2) Average Velocity	m/sec	0.3	0.3
2 Primary Sedimentation Tank (For Maximum Daily Flow)			
(1) Hydraulic Load	m ³ /m ² /day	35.0-70.0	50
(2) Settling Time (Ref.)	hour	1.5	1.5
(3) Water Depth	m	2.5-4.0	3.5
(4) Weir Loading	m ³ /m/day	250	250
3 Aeration Tank (For Maximum Daily Flow)			
(1) Hydraulic Retention Time (HRT)	hour	6 - 8	6.0
(2) MLSS Concentration	mg/l	1,500 -2,000	2,000
(3) BOD-SS Load (Reference only)	kg/kg/day	0.2 - 0.4	-
4 Final Sedimentation Tank (For Maximum Daily Flow)			
(1) Hydraulic Load	m ³ /m ² /day	20.0-30.0	25
(2) Settling Time (Ref.)	hour	3.0-4.0	-
(3) Water Depth	m	2.5-4.0	3.5
(4) Weir Loading	m ³ /m/day	150	150
5 Disinfection Tank (For Maximum Daily Flow)			
(1) Retention (Chlorination) Time	min	15	15
6 Gravity Thickener (For Maximum Daily Flow)			
(1) Solids Loading	kg/m ² /day	60-90	75
(2) Water Depth	m		4.0

表 I.2 C2+E1 処理場 容量計算書 (4/11)

2 CAPACITY CALCULATION

2-1 Grit Chamber

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Parallel Flow Type		
Design Sewage Flow	Q1	m ³ /day			1,116,000
(Maximum Hourly Flow)	Q2	m ³ /sec			12.917
Water Surface Load	WSL	m ³ /m ² /day			1,800
Required Surface Area	RSA	m ²	Q1/WSL		620.00
Basin Number	BN	basin			16
Average Velocity	AV	m/sec			0.3
Depth	H	m			1
Width	W1	m	Q2/(AV×H×BN)		2.69
<i>Therefore</i>	W2	m			3.0
Length	L1	m	RSA/(W2×BN)		12.92
<i>Therefore</i>	L2	m			13.0
Dimension (Width)	W	m			3.0
(Length)	L	m	L2		13.0
(Depth)	H	m	H		1.0
(Basin Number)	N	basin			16
(Check)					
Water Surface Load		m ³ /m ² /day	Q1/(W×L×N)		1,788
Average Velocity		m/sec	Q2/(W×H×N)		0.269

2-2 Lift Pump Station

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Vertical shaft Volute type mixed flow pump		
Design Sewage Flow	Q1	m ³ /min	Peak Flow/4Nos		193.75
Pump Unit -1 Number	UN1	unit			2
Discharge per Unit	DU1	m ³ /min	1/10×Q1		19.38
Pump Diameter(V=1.5~3.0m/s)	D1	mm	146×(DU1/1.5~3.0) ^{0.5}		371 ~ 525
<i>Therefore</i>	D1	mm			450
Pump Unit -2 Number	UN2	unit			2
Discharge per Unit	DU2	m ³ /min	2/10×Q1		38.75
Pump Diameter(V=1.5~3.0m/s)	D2	mm	146×(DU2/1.5~3.0) ^{0.5}		525 ~ 742
<i>Therefore</i>	D2	mm			600
Pump Unit -3 Number	UN3	unit	including 1 stand-by		2
Discharge per Unit	DU3	m ³ /min	4/10×Q1		77.50
Pump Diameter(V=1.5~3.0m/s)	D3	mm	146×(DU3/1.5~3.0) ^{0.5}		742 #####
<i>Therefore</i>	D3	mm			900

表 I.2 C2+E1 処理場 容量計算書 (6/11)

2-4 Aeration Tank

Item	Sign	Unit	Calculation	F/S	M/P				
Type	-	-	Multi-tank Complete mixing Type						
Design Sewage Flow	Q1	m ³ /day			744,000				
(Maximum Daily Flow)	Q2	m ³ /hr			31,000.0				
Hydraulic Retention Time	HRT	hr			6.0				
Basin Number	BN	basin			32				
Required Volume per basin	RV	m ³ /basin	Q2×RT/BN		5,813				
Width	W	m	1~2H		10.5				
Water Depth	H	m	Deep Aeration Tank		10.0				
Length	L1	m	RV/(W×H)		55.4				
	<i>Therefore</i> L2	m			56.0				
Dimension (Width)	W	m			10.5				
(Depth)	H	m			10.0				
(Length)	L	m			56.0				
(Basin Number)	N	basin			32				
(Check)									
Hydraulic Retention Time	HRT	hour	W×H×L×N/Q2		6.1				
BOD-SS load	BSS _L	kgBOD/kgSS/d	(Q1×BOD _{in})/(W×H×L×N×Xa)		0.24				
BOD _{in} : Inflow BOD Concentration			120 mg/L (Removal Rate in PST : 40%)						
Xa : MLSS Concentration			2,000 mg/L						
Aerobic Sludge Retention Time	ASRT	day	HRT/24×Xa / (a×S-BOD _{in} + b×SS _{in} - c×HRT/24×Xa) =		4.805				
S-BOD _{in} : Inflow S-BOD Concentration			80 mg/L (S-BOD[Solved BOD]=BOD _{in} ×0.6)						
SS _{in} : Inflow SS Concentration			90 mg/L (Removal Rate in PST : 50%)						
a : Sludge converting ratio of solved BOD			0.5 mgMLSS/mgBOD (0.4~0.6)						
b : Sludge converting ratio of SS			0.95 mgMLSS/mgSS (0.9~1.0)						
c : Sludge reduction ratio caused by endogenous respiration			0.04 (1/day)(0.03~0.05)						
Effluent Quality (C-BOD)	EQ	mg/L	10.42×A-SRT ^(-0.519) (15~20°C)		4.614				
Water Temperature			20 °C						
Effluent Water Quality (C=BOD Maximum)			EQ×3	20mg/l >	14				
					-OK-				
			1 : 1.5 : 1.5 : 2.25						
Partition of Aeration Tank			<table border="1" style="margin-left: auto; margin-right: auto;"> <tr> <td>No.1</td> <td>No.2</td> <td>No.3</td> <td>No.4</td> </tr> </table>	No.1	No.2	No.3	No.4		
No.1	No.2	No.3	No.4						
Total Length of Tank	TL	m			56.0				
No.1 Tank Length	L1	m	TL×1/(1+1.5+1.5+2.25)		9.0				
No.2 Tank Length	L2	m	TL×1.5/(1+1.5+1.5+2.25)		13.4				
No.3 Tank Length	L3	m	TL×1.5/(1+1.5+1.5+2.25)		13.4				
No.4 Tank Length	L4	m	TL×2.25/(1+1.5+1.5+2.25)		20.2				
			Total		56.0				

表 I.2 C2+E1 処理場 容量計算書 (8/11)

2-6 Disinfection Channel

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Chlorination		
Design Sewage Flow	Q1	m ³ /day			744,000
(Maximum Daily Flow)	Q2	m ³ /min			516.7
Retention(Chlorination) Time	RT	min			15.0
Required Volume	RV	m ³	Q2×RT		7,750
Width of channel	W	m			2.0
Depth of channel	H	m			3.0
Pass Number	PN	pass			32
Length of channel	L1	m/pass	RV/(W×H×PN)		40.4
<i>Therefore</i>	L2	m/pass			41.0
Dimension (Width)	W	m			2.0
(Depth)	H	m			3.0
(Length)	L	m/pass			41.0
(Pass Number)	N	pass			32
(Check)					
Retention(Chlorination) Time	RT	min	(W×H×L×PN)/Q2		15.2

2-7 Sludge Thickening Tank

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Gravity Thickener (Radial Flow Circular Type)		
Generated Sludge Solids	GS	t-DS/day	Refer to Mass Balance Cal.		138.68
Generated Sludge Volume	GSV	m ³ /day	Refer to Mass Balance Cal.		17,464
Solid Matter Load	SML	kg/m ² /day			75
Required Surface Area	SA	m ²	(GS×10 ³)/SML		1849.1
Water Depth	H	m			4.0
Basin Number	BN	basin			16
Required Tank Diameter	TD1	m	(SA×4/(3.14×BN)) ^{0.5}		12.13
<i>Therefore</i>	TD2	m			12.5
Dimension (Diameter)	D	m/basin			12.5
(Depth)	H	m			4.0
(Basin Number)	BN	basin			16
(Check)					
Solid Matter Load	SML	kg/m ² /day	GS×10 ³ /(3.14×D ² /4)×BN		70.7
Sludge Thickened Time	T	hr	(3.14×D ² /4)×H×BN×24/GSV		10.8

表 I.2 C2+E1 処理場 容量計算書 (11/11)




表 I.3 W1 処理場 容量計算書 (1/11)

1 BASIC CONDITIONS

1-1 Basic Items

- (1) Name : **W1 WWTP**
- (2) Land Area : Approximately xxxx ha
- (3) Ground Level (Elevation) : + 4.10 m (Plan)
- (4) Inlet Pipe Invert Level : - 7.60 m
- (5) Pipe Diameter : 2,000 mm
- (6) Land Use : —
- (7) Collection System : ~~Combined System~~ Separate System
- (8) Treatment Process : Conventional Activated Sludge Process
- (9) Effluent Point : Hlaing River
- (10) Water Level at the Effluent Point :
 High water level = 3.70 m
 Low water level = — m
- (11) Target Year : 2020 (F/S Stage)
 2040 (M/P Stage)

1-2 Service Area and Design Population

- (1) Service Area : 1,654 ha
- (2) Design Population

Item		Year 2020	Year 2040
Design Population	person	-	483,300

表 I.3 W1 処理場 容量計算書 (2/11)

1-3 Design Sewage Flow

(Year 2020)

Item	m ³ /day	m ³ /hr	m ³ /min	m ³ /sec
Maximum Daily Flow		0.0	0.00	0.000
Maximum Hourly Flow	0	0.0	0.00	0.000

(Year 2040)

Item	m ³ /day	m ³ /hr	m ³ /min	m ³ /sec
Maximum Daily Flow	184,000	7,666.7	127.78	2.130
Maximum Hourly Flow	276,000	11,500.0	191.67	3.194

1-4 Design Sewage Quality

Item	BOD	SS	T-N	Coli-group	Oil&Grease
	(mg/l)	(mg/l)	(mg/l)	(MPN/cm ³)	(mg/l)
Influent	200	180	-	-	-
Effluent	20	30	-	3,000	5

1-5 Process Flow Diagram




表 I.3 W1 処理場 容量計算書 (3/11)

1.6 Design Criteria

ITEMS	UNIT	Formula or Value	Application
1 Grit Chamber (For Maximum Hourly Flow)			
(1) Hydraulic Load	m ³ /m ² /day	1,800	1,800
(2) Average Velocity	m/sec	0.3	0.3
2 Primary Sedimentation Tank (For Maximum Daily Flow)			
(1) Hydraulic Load	m ³ /m ² /day	35.0-70.0	50
(2) Settling Time (Ref.)	hour	1.5	1.5
(3) Water Depth	m	2.5-4.0	3.5
(4) Weir Loading	m ³ /m/day	250	250
3 Aeration Tank (For Maximum Daily Flow)			
(1) Hydraulic Retention Time (HRT)	hour	6 - 8	6.0
(2) MLSS Concentration	mg/l	1,500 -2,000	2,000
(3) BOD-SS Load (Reference only)	kg/kg/day	0.2 - 0.4	-
4 Final Sedimentation Tank (For Maximum Daily Flow)			
(1) Hydraulic Load	m ³ /m ² /day	20.0-30.0	25
(2) Settling Time (Ref.)	hour	3.0-4.0	-
(3) Water Depth	m	2.5-4.0	3.5
(4) Weir Loading	m ³ /m/day	150	150
5 Disinfection Tank (For Maximum Daily Flow)			
(1) Retention (Chlorination) Time	min	15	15
6 Gravity Thickener (For Maximum Daily Flow)			
(1) Solids Loading	kg/m ² /day	60-90	75
(2) Water Depth	m		4.0

表 I.3 W1 処理場 容量計算書 (4/11)

2 CAPACITY CALCULATION

2-1 Grit Chamber

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Parallel Flow Type		
Design Sewage Flow	Q1	m ³ /day			276,000
(Maximum Hourly Flow)	Q2	m ³ /sec			3.194
Water Surface Load	WSL	m ³ /m ² /day			1,800
Required Surface Area	RSA	m ²	Q1/WSL		153.33
Basin Number	BN	basin			4
Average Velocity	AV	m/sec			0.3
Depth	H	m			1
Width	W1	m	Q2/(AV×H×BN)		2.66
<i>Therefore</i>	W2	m			3.0
Length	L1	m	RSA/(W2×BN)		12.78
<i>Therefore</i>	L2	m			12.5
Dimension (Width)	W	m			3.0
(Length)	L	m	L2		12.5
(Depth)	H	m	H		1.0
(Basin Number)	N	basin			4
(Check)					
Water Surface Load		m ³ /m ² /day	Q1/(W×L×N)		1,840
Average Velocity		m/sec	Q2/(W×H×N)		0.266

2-2 Lift Pump Station

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Vertical shaft Volute type mixed flow pump		
Design Sewage Flow	Q1	m ³ /min	Peak Flow		191.67
Pump Unit -1 Number	UN1	unit			2
Discharge per Unit	DU1	m ³ /min	1/10×Q1		19.17
Pump Diameter(V=1.5~3.0m/s)	D1	mm	146×(DU1/1.5~3.0) ^{0.5}		369 ~522
<i>Therefore</i>	D1	mm			450
Pump Unit -2 Number	UN2	unit			2
Discharge per Unit	DU2	m ³ /min	2/10×Q1		38.33
Pump Diameter(V=1.5~3.0m/s)	D2	mm	146×(DU2/1.5~3.0) ^{0.5}		522 ~738
<i>Therefore</i>	D2	mm			600
Pump Unit -3 Number	UN3	unit	including 1 stand-by		2
Discharge per Unit	DU3	m ³ /min	4/10×Q1		76.67
Pump Diameter(V=1.5~3.0m/s)	D3	mm	146×(DU3/1.5~3.0) ^{0.5}		738 #####
<i>Therefore</i>	D3	mm			800

表 I.3 W1 処理場 容量計算書 (6/11)

2-4 Aeration Tank

Item	Sign	Unit	Calculation	F/S	M/P				
Type	-	-	Multi-tank Complete mixing Type						
Design Sewage Flow	Q1	m ³ /day			184,000				
(Maximum Daily Flow)	Q2	m ³ /hr			7,666.7				
Hydraulic Retention Time	HRT	hr			6.0				
Basin Number	BN	basin			6				
Required Volume per basin	RV	m ³ /basin	Q2×RT/BN		7,667				
Width	W	m	1~2H		10.5				
Water Depth	H	m	Deep Aeration Tank		10.0				
Length	L1	m	RV/(W×H)		73.0				
	Therefore L2	m			73.0				
Dimension (Width)	W	m			10.5				
(Depth)	H	m			10.0				
(Length)	L	m			73.0				
(Basin Number)	N	basin			6				
(Check)									
Hydraulic Retention Time	HRT	hour	W×H×L×N/Q2		6.0				
BOD-SS load	BSS _L	kgBOD/kgSS/d	(Q1×BOD _{in})/(W×H×L×N×Xa)		0.24				
BOD _{in} : Inflow BOD Concentration			120 mg/L	(Removal Rate in PST : 40%)					
Xa : MLSS Concentration			2,000 mg/L						
Aerobic Sludge Retention Time	ASRT	day	HRT/24×Xa / (a×S-BOD _{in} + b×SS _{in} - c×HRT/24×Xa) =		4.738				
S-BOD _{in} : Inflow S-BOD Concentration			80 mg/L	(S-BOD[Solved BOD]=BOD _{in} ×0.6)					
SS _{in} : Inflow SS Concentration			90 mg/L	(Removal Rate in PST : 50%)					
a : Sludge converting ratio of solved BOD			0.5 mgMLSS/mgBOD	(0.4~0.6)					
b : Sludge converting ratio of SS			0.95 mgMLSS/mgSS	(0.9~1.0)					
c : Sludge reduction ratio caused by endogenous respiration			0.04 (1/day)	(0.03~0.05)					
Effluent Quality (C-BOD)	EQ	mg/L	10.42×A-SRT ^(-0.519) (15~20°C)		4.648				
Water Temperature			20 °C						
Effluent Water Quality (C=BOD Maximum)			EQ×3	20mg/l >	14				
					-OK-				
			1 : 1.5 : 1.5 : 2.25						
Partition of Aeration Tank			<table border="1" style="display: inline-table; border-collapse: collapse;"> <tr> <td>No.1</td> <td>No.2</td> <td>No.3</td> <td>No.4</td> </tr> </table>	No.1	No.2	No.3	No.4		
No.1	No.2	No.3	No.4						
Total Length of Tank	TL	m			73.0				
No.1 Tank Length	L1	m	TL×1/(1+1.5+1.5+2.25)		11.7				
No.2 Tank Length	L2	m	TL×1.5/(1+1.5+1.5+2.25)		17.5				
No.3 Tank Length	L3	m	TL×1.5/(1+1.5+1.5+2.25)		17.5				
No.4 Tank Length	L4	m	TL×2.25/(1+1.5+1.5+2.25)		26.3				
			Total		73.0				

表 I.3 W1 処理場 容量計算書 (8/11)

2-6 Disinfection Channel

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Chlorination		
Design Sewage Flow	Q1	m ³ /day			184,000
(Maximum Daily Flow)	Q2	m ³ /min			127.8
Retention(Chlorination) Time	RT	min			15.0
Required Volume	RV	m ³	Q2×RT		1,917
Width of channel	W	m			2.5
Depth of channel	H	m			3.0
Pass Number	PN	pass			4
Length of channel	L1	m/pass	RV/(W×H×PN)		63.9
<i>Therefore</i>	L2	m/pass			64.0
Dimension (Width)	W	m			2.5
(Depth)	H	m			3.0
(Length)	L	m/pass			64.0
(Pass Number)	N	pass			4
(Check)					
Retention(Chlorination) Time	RT	min	(W×H×L×PN)/Q2		15.0

2-7 Sludge Thickening Tank

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Gravity Thickener (Radial Flow Circular Type)		
Generated Sludge Solids	GS	t-DS/day	Refer to Mass Balance Cal.		34.298
Generated Sludge Volume	GSV	m ³ /day	Refer to Mass Balance Cal.		4,319
Solid Matter Load	SML	kg/m ² /day			75
Required Surface Area	SA	m ²	(GS×10 ³)/SML		457.3
Water Depth	H	m			4.0
Basin Number	BN	basin			4
Required Tank Diameter	TD1	m	(SA×4/(3.14×BN)) ^{0.5}		12.07
<i>Therefore</i>	TD2	m			12.0
Dimension (Diameter)	D	m/basin			12.0
(Depth)	H	m			4.0
(Basin Number)	BN	basin			4
(Check)					
Solid Matter Load	SML	kg/m ² /day	GS×10 ³ /(3.14×D ² /4)×BN		75.9
Sludge Thickened Time	T	hr	(3.14×D ² /4)×H×BN×24/GSV		10.1

表 I.3 W1 処理場 容量計算書 (10/11)

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Mechanical Dewatering)

Table-1 Input Data

1. Calculation Manner		1: Premise that the quality of supernatants are same level removed with inlet sewage 2: Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency		1: Total Removal Ratio 2: Outlet Water Quality (input 1 or 2)
In case of 1: input data		90 (%)
In case of 2: input data		(mg/l)
3. Excess Sludge Generation		1: Consideration of Solid Matter Only 2: Consideration of Converting of Solved BOD (input 1 or 2)
In case of 1: input data (Sludge generation)		100 Sludge generation ratio per removal SS (%)
In case of 2: input data	a	$T2 = Q2 \cdot S2 = (a \cdot S_{acc} + b \cdot S1 - c \cdot \theta \cdot XA) \cdot Q1 \cdot 10^{-6}$ (Excess sludge generation formula) a: Converting ratio of solved BOD (mgMLSS/mgBOD) b: Converting ratio of SS (mgMLSS/mgSS) c: Sludge reduction ratio caused by endogenous respiration of activated sludge (1/day) S _{acc} : Solved BOD quality at inlet to reactor XA: MLSS concentration (mg/l) θ: Hydraulic retention time (day)
	b	
	c	
	SBOD	
	XA	
	θ	


Table-2 Basic Conditions

Water Flow and Quality		Sludge Moisture and Recovery Ratio			Chemical Conditions for Dewatering		
*Inlet flow: Q0 (m3/D)	184000	*Primary sludge moisture ratio: W1 (%)	98.3	*Removal ratio in primary tank: A2 (%)	50.0	*Chemical dosage: A5 (%)	1.0
*Inlet quality: S0 (mg/l)	180	*Excess sludge moisture ratio: W2 (%)	99.3	*Recovery ratio in sludge thickener: A3 (%)	90.0	*Chemical dissolve concentration: A6 (%)	0.2
*Total removal ratio: A1 (%)	90.0	*Thickened sludge moisture ratio: W3 (%)	98.0	*Recovery ratio in dewatering: A4 (%)	95.0		
*Effluent quality: S1 (mg/l)	-	*Dewatered sludge moisture ratio: W4 (%)	80.0				
*Sludge generation ratio per removal SS: S1 (%)	100.0						

Table-3 Material Balance Calculation

	0	1	2	3	4	5	6	7	8	9	10	11	12	5-1
Q (m3/day)	184000	188,225	1,270	187,055	3,049	184,006	1,543	2,276	154	1,698	148	1,550	4,325	182,852
T (t·DS/day)	33,120	38,109	19,054	19,054	15,243	3,811	30,868	3,430	0,309	31,177	29,618	1,559	4,989	3,502
S (mg/l)	180	202	15,000	102	5,000	21	20,000	1,236	2,000	18,364	200,000	1,006	1,153	21
X (t·DS/100)	100	113.1	57.5	57.5	48.0	11.5	93.2	10.4	0.9	94.1	89.4	4.7	15.1	10.6

Figure-1 Material Balance Model



Calculation Formula

*Q0=Input Data	*Q3=Q1-Q2	*Q6=Q4*100/(100-W3)	*Q9=Q6-Q8	*Q12=Q7+Q11	*Q5-1=Q5-Q8
*T0=Q0*S0*10 ⁻⁶ (t·D)	*T3=T1*(100-A2)/100	*T6=(T2-T4)*A3/100	*T9=T6-T8	*T12=T7-T11	*T3-1=T3-T8
*S0=Input Data	*S3=T3*10 ⁻⁶ /Q3	*S6=10 ⁻⁶ *(100-W3)/100	*S9=T9*10 ⁻⁶ /Q9	*S11=T11*10 ⁻⁶ /Q11	*S5-1=S5
*Q1=Q0-Q13	*Q4=Q4*100/(100-W2)	*Q7=Q3-Q4-Q6	*Q10=T10*100/(100-W4)		
*T1=T0-T13	*T4=((T1-T5)*S1/100)-T2	*T7=(T2-T4)-T6	*T10=T9*A4/100		
*S1=T1*10 ⁻⁶ /Q1	*S4=10 ⁻⁶ *(100-W2)/100	*S7=T7*10 ⁻⁶ /Q7	*S10=10 ⁻⁶ *(100-W4)/100		
*Q8=T2*100/(100-W1)	*Q5=Q3-Q4*(T3-T5)/T4	*Q8=T6*A5/A6	*Q11=Q9-Q10		
*T2=T1-T3	*T5=T1*(100-A1)/100	*T8=Q8*S8*10 ⁻⁶	*T11=T9-T10		
*S2=10 ⁻⁶ *(100-W1)/100	*S5=T5*10 ⁻⁶ /Q5	*S8=10 ⁻⁶ *A6	*S11=T11*10 ⁻⁶ /Q11		

表 I. 3 W1 処理場 容量計算書 (11/11)

Material Balance Sheet




表 I.4 W2 処理場 容量計算書 (1/11)

1 BASIC CONDITIONS

1-1 Basic Items

- (1) Name : **W2 WWTP**
- (2) Land Area : Approximately xxxx ha
- (3) Ground Level (Elevation) : + 4.50 m (Plan)
- (4) Inlet Pipe Invert Level : - 6.54 m
- (5) Pipe Diameter : 1,800 mm
- (6) Land Use : —
- (7) Collection System : ~~Combined System~~ (**Separate System**)
- (8) Treatment Process : Conventional Activated Sludge Process
- (9) Effluent Point : Hlaing River
- (10) Water Level at the Effluent Point :
 High water level = 3.70 m
 Low water level = — m
- (11) Target Year : 2020 (F/S Stage)
 2040 (M/P Stage)

1-2 Service Area and Design Population

- (1) Service Area : 2,356 ha
- (2) Design Population

Item	Year 2020	Year 2040
Design Population person	-	349,500

表 I.4 W2 処理場 容量計算書 (2/11)

1-3 Design Sewage Flow

(Year 2020)

Item	m ³ /day	m ³ /hr	m ³ /min	m ³ /sec
Maximum Daily Flow		0.0	0.00	0.000
Maximum Hourly Flow	0	0.0	0.00	0.000

(Year 2040)

Item	m ³ /day	m ³ /hr	m ³ /min	m ³ /sec
Maximum Daily Flow	126,000	5,250.0	87.50	1.458
Maximum Hourly Flow	189,000	7,875.0	131.25	2.188

1-4 Design Sewage Quality

Item	BOD	SS	T-N	Coli-group	Oil&Grease
	(mg/l)	(mg/l)	(mg/l)	(MPN/cm ³)	(mg/l)
Influent	200	180	-	-	-
Effluent	20	30	-	3,000	5

1-5 Process Flow Diagram




表 I.4 W2 処理場 容量計算書 (3/11)

1.6 Design Criteria

ITEMS	UNIT	Formula or Value	Application
1 Grit Chamber (For Maximum Hourly Flow)			
(1) Hydraulic Load	m ³ /m ² /day	1,800	1,800
(2) Average Velocity	m/sec	0.3	0.3
2 Primary Sedimentation Tank (For Maximum Daily Flow)			
(1) Hydraulic Load	m ³ /m ² /day	35.0-70.0	50
(2) Settling Time (Ref.)	hour	1.5	1.5
(3) Water Depth	m	2.5-4.0	3.5
(4) Weir Loading	m ³ /m/day	250	250
3 Aeration Tank (For Maximum Daily Flow)			
(1) Hydraulic Retention Time (HRT)	hour	6 - 8	6.0
(2) MLSS Concentration	mg/l	1,500 -2,000	2,000
(3) BOD-SS Load (Reference only)	kg/kg/day	0.2 - 0.4	-
4 Final Sedimentation Tank (For Maximum Daily Flow)			
(1) Hydraulic Load	m ³ /m ² /day	20.0-30.0	25
(2) Settling Time (Ref.)	hour	3.0-4.0	-
(3) Water Depth	m	2.5-4.0	3.5
(4) Weir Loading	m ³ /m/day	150	150
5 Disinfection Tank (For Maximum Daily Flow)			
(1) Retention (Chlorination) Time	min	15	15
6 Gravity Thickener (For Maximum Daily Flow)			
(1) Solids Loading	kg/m ² /day	60-90	75
(2) Water Depth	m		4.0

表 I.4 W2 処理場 容量計算書 (4/11)

2 CAPACITY CALCULATION

2-1 Grit Chamber

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Parallel Flow Type		
Design Sewage Flow	Q1	m ³ /day			189,000
(Maximum Hourly Flow)	Q2	m ³ /sec			2.188
Water Surface Load	WSL	m ³ /m ² /day			1,800
Required Surface Area	RSA	m ²	Q1/WSL		105.00
Basin Number	BN	basin			4
Average Velocity	AV	m/sec			0.3
Depth	H	m			0.8
Width	W1	m	Q2/(AV×H×BN)		2.28
<i>Therefore</i>	W2	m			2.5
Length	L1	m	RSA/(W2×BN)		10.50
<i>Therefore</i>	L2	m			11.0
Dimension (Width)	W	m			2.5
(Depth)	L	m	L2		11.0
(Length)	H	m	H		0.8
(Basin Number)	N	basin			4
(Check)					
Water Surface Load		m ³ /m ² /day	Q1/(W×L×N)		1,718
Average Velocity		m/sec	Q2/(W×H×N)		0.273

2-2 Lift Pump Station

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Vertical shaft Volute type mixed flow pump		
Design Sewage Flow	Q1	m ³ /min	Peak Flow		131.25
Pump Unit -1 Number	UN1	unit			2
Discharge per Unit	DU1	m ³ /min	1/10×Q1/UN1		13.13
Pump Diameter(V=1.5~3.0m/s)	D1	mm	146×(DU1/1.5~3.0) ^{0.5}		305 ~432
<i>Therefore</i>	D1	mm			350
Pump Unit -2 Number	UN2	unit			2
Discharge per Unit	DU2	m ³ /min	2/10×Q1/UN2		26.25
Pump Diameter(V=1.5~3.0m/s)	D2	mm	146×(DU2/1.5~3.0) ^{0.5}		432 ~611
<i>Therefore</i>	D2	mm			500
Pump Unit -3 Number	UN3	unit	including 1 stand-by		2
Discharge per Unit	DU3	m ³ /min	4/10×Q1/UN3		52.50
Pump Diameter(V=1.5~3.0m/s)	D3	mm	146×(DU3/1.5~3.0) ^{0.5}		611 ~864
<i>Therefore</i>	D3	mm			700

表 I.4 W2 処理場 容量計算書 (6/11)

2-4 Aeration Tank

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Multi-tank Complete mixing Type		
Design Sewage Flow	Q1	m ³ /day			126,000
(Maximum Daily Flow)	Q2	m ³ /hr			5,250.0
Hydraulic Retention Time	HRT	hr			6.0
Basin Number	BN	basin			8
Required Volume per basin	RV	m ³ /basin	Q2×RT/BN		3,938
Width	W	m	1~2H		10.5
Water Depth	H	m	4.0m~6.0m		6.0
Length	L1	m	RV/(W×H)		62.5
	<i>Therefore</i>	L2			63.0
Dimension (Width)	W	m			10.5
(Depth)	H	m			6.0
(Length)	L	m			63.0
(Basin Number)	N	basin			8
(Check)					
Hydraulic Retention Time	HRT	hour	W×H×L×N/Q2		6.0
BOD-SS load	BSS _L	kgBOD/kgSS/d	(Q1×BOD _{in})/(W×H×L×N×Xa)		0.24
BOD _{in} : Inflow BOD Concentration			120 mg/L (Removal Rate in PST : 40%)		
Xa : MLSS Concentration			2,000 mg/L		
Aerobic Sludge Retention Time	ASRT	day	HRT/24×Xa / (a×S-BOD _{in} + b×SS _{in} - c×HRT/24×Xa) =		4.785
S-BOD _{in} : Inflow S-BOD Concentration			80 mg/L (S-BOD[Solved BOD]=BOD _{in} ×0.6)		
SS _{in} : Inflow SS Concentration			90 mg/L (Removal Rate in PST : 50%)		
a : Sludge converting ratio of solved BOD			0.5 mgMLSS/mgBOD (0.4~0.6)		
b : Sludge converting ratio of SS			0.95 mgMLSS/mgSS (0.9~1.0)		
c : Sludge reduction ratio caused by endogenous respiration			0.04 (1/day)(0.03~0.05)		
Effluent Quality (C-BOD)	EQ	mg/L	10.42×A-SRT ^(-0.519) (15~20°C)		4.624
Water Temperature			20 °C		
Effluent Water Quality (C=BOD Maximum)			EQ×3	20mg/l >	14
					-OK-
			1 : 1.5 : 1.5 : 2.25		
Partition of Aeration Tank					
			No.1 No.2 No.3 No.4		
Total Length of Tank	TL	m			63.0
No.1 Tank Length	L1	m	TL×1/(1+1.5+1.5+2.25)		10.1
No.2 Tank Length	L2	m	TL×1.5/(1+1.5+1.5+2.25)		15.1
No.3 Tank Length	L3	m	TL×1.5/(1+1.5+1.5+2.25)		15.1
No.4 Tank Length	L4	m	TL×2.25/(1+1.5+1.5+2.25)		22.7
			Total		63.0

表 I.4 W2 処理場 容量計算書 (8/11)

2-6 Disinfection Channel

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Chlorination		
Design Sewage Flow	Q1	m ³ /day			126,000
(Maximum Daily Flow)	Q2	m ³ /min			87.5
Retention(Chlorination) Time	RT	min			15.0
Required Volume	RV	m ³	Q2×RT		1,313
Width of channel	W	m			2.0
Depth of channel	H	m			2.5
Pass Number	PN	pass			8
Length of channel	L1	m/pass	RV/(W×H×PN)		32.8
<i>Therefore</i>	L2	m/pass			33.0
Dimension (Width)	W	m			2.0
(Depth)	H	m			2.5
(Length)	L	m/pass			33.0
(Pass Number)	N	pass			8
(Check)					
Retention(Chlorination) Time	RT	min	(W×H×L×PN)/Q2		15.1

2-7 Sludge Thickening Tank

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Gravity Thickener (Radial Flow Circular Type)		
Generated Sludge Solids	GS	t-DS/day	Refer to Mass Balance Cal.		23.487
Generated Sludge Volume	GSV	m ³ /day	Refer to Mass Balance Cal.		2,958
Solid Matter Load	SML	kg/m ² /day			75
Required Surface Area	SA	m ²	(GS×10 ³)/SML		313.2
Water Depth	H	m			4.0
Basin Number	BN	basin			4
Required Tank Diameter	TD1	m	(SA×4/(3.14×BN)) ^{0.5}		9.99
<i>Therefore</i>	TD2	m			10.0
Dimension (Diameter)	D	m/basin			10.0
(Depth)	H	m			4.0
(Basin Number)	BN	basin			4
(Check)					
Solid Matter Load	SML	kg/m ² /day	GS×10 ³ /(3.14×D ² /4)×BN		74.8
Sludge Thickened Time	T	hr	(3.14×D ² /4)×H×BN×24/GSV		10.2

表 I.4 W2 処理場 容量計算書 (10/11)

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Mechanical Dewatering)

Table-1 Input Data

1. Calculation Manner		1.Premise that the quality of supernatants are same level removed with inlet sewage 2.Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency		1.Total Removal Ratio 2.Outlet Water Quality(input 1or2)
In case of 1: input data	90	(%)
In case of 2: input data		(mg/l)
3. Excess Sludge Generation		1.Consideration of Solid Matter Only 2.Consideration of Converting of Solved BOD (input 1or2)
In case of 1:input data (Sludge generation)	100	Sludge generation ratio per removal SS(%)
		$T2=Q2 \cdot S2=(a \cdot S_{BOD}+b \cdot S1-c \cdot \theta \cdot XA) \cdot Q1/10^6$ (Excess sludge generation formula)
	a	a:Converting ratio of solved BOD(mg/MLSS mgBOD)
	b	b:Converting ratio of SS(mg/MLSS mgSS)
	c	c:Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)
In case of 2:input data	SBOD	S_{BOD} :Solved BOD quality at inlet to reactor
	XA	XA:MLSS concentration(mg/l)
	θ	θ :Hydraulic retention time(day)


Table-2 Basic Conditions

Water Flow and Quality		Sludge Moisture and Recovery Ratio		Chemical Conditions for Dewatering			
*Inlet flow: Q0(m ³ /D)	126000	*Primary sludge moisture ratio: W1(%)	98.5	*Removal ratio in primary tank: A2(%)	50.0	*Chemical dosage: A5(%)	1.0
*Inlet quality: S0(mg/l)	180	*Excess sludge moisture ratio: W2(%)	99.5	*Recoveryratio in sludge thickener: A3(%)	90.0	*Chemical dissolve concentration: A6(%)	0.2
*Total removal ratio: A1(%)	90.0	*Thickened sludge moisture ratio: W3(%)	98.0	*Recoveryratio in dewatering: A4(%)	95.0		
*Effluent quality: S1(mg/l)		*Dewatered sludge moisture ratio: W4(%)	80.0				
*Sludge generation ratio per removal SS: S1(%)	100.0						

Table-3 Material Balance Calculation

	0	1	2	3	4	5	6	7	8	9	10	11	12	5-1
Q(m ³ /day)	126,000	128,962	870	128,092	2,088	126,004	1,057	1,901	106	1,163	101	1,061	2,962	125,899
T(t°DS/day)	22,680	26,096	13,048	13,048	10,438	2,610	21,138	2,349	0,211	21,349	20,282	1,067	3,416	2,398
S(mg/l)	180	202	15,000	102	5,000	21	20,000	1,236	2,000	18,364	200,000	1,006	1,153	21
X(%)	100	115.1	57.5	57.5	46.0	11.5	93.2	10.4	0.9	94.1	89.4	4.7	15.1	10.6

Figure-1 Material Balance Model



Calculation Formula					
*Q0=Input Data	*Q3=Q1-Q2	*Q6=Q4*100/(100-W3)	*Q9=Q6-Q8	*Q12=Q7-Q11	*Q5-1=Q5-Q8
*T0=Q0*S0*10 ⁻⁶ (-6)	*T3=T1*(100-A2)/100	*T6=(T2-T4)*A3/100	*T9=T6-T8	*T12=T7-T11	*T5-1=T5-T8
*S0=Input Data	*S3=T3*10 ⁻⁶ /Q3	*S6=10 ⁻⁶ *Q6/(100-W3)/100	*S9=T9*10 ⁻⁶ /Q9	*S11=T11*10 ⁻⁶ /Q11	*S5-1=S5
*Q1=Q0-Q13	*Q4=Q4*100/(100-W2)	*Q7=(Q2-Q4)-Q6	*Q10=Q10*100/(100-W4)	*T10=Q9*A4/100	
*T1=T0-T13	*T4=(T1-T5)*S1/100-T2	*T7=(T2-T4)-T6	*S10=10 ⁻⁶ *Q10/(100-W4)/100		
*S1=T1*10 ⁻⁶ /Q1	*S4=10 ⁻⁶ *Q4/(100-W2)/100	*S7=T7*10 ⁻⁶ /Q7			
*Q2=T2*100/(100-W1)	*Q5=Q3-Q4*(T3-T5)/T4	*Q8=T6*A5/A6	*Q11=Q9-Q10		
*T2=T1-T3	*T5=T1*(100-A1)/100	*T8=Q8*S8/10 ⁻⁶	*T11=T9-T10		
*S2=10 ⁻⁶ *Q2/(100-W1)/100	*S5=T5*10 ⁻⁶ /Q5	*S8=10 ⁻⁴ *A6	*S11=T11*10 ⁻⁶ /Q11		

表 I. 4 W2 処理場 容量計算書 (11/11)

Material Balance Sheet




表 I.5 E3 処理場 容量計算書 (1/11)

1 BASIC CONDITIONS

1-1 Basic Items

- (1) Name : **E3 WWTP**
- (2) Land Area : Approximately xxxx ha
- (3) Ground Level (Elevation) : + 6.90 m (Plan)
- (4) Inlet Pipe Invert Level : - 10.82 m
- (5) Pipe Diameter : 2,400 mm
- (6) Land Use : —
- (7) Collection System : ~~Combined System~~ **Separate System**
- (8) Treatment Process : Conventional Activated Sludge Process
- (9) Effluent Point : Ngamoeyeik Creek
- (10) Water Level at the Effluent Point :
 High water level = 3.70 m
 Low water level = — m
- (11) Target Year : 2020 (F/S Stage)
 2040 (M/P Stage)

1-2 Service Area and Design Population

- (1) Service Area : 5,418 ha
- (2) Design Population

Item		Year 2020	Year 2040
Design Population	person	-	921,000

表 I.5 E3 処理場 容量計算書 (2/11)

1-3 Design Sewage Flow

(Year 2020)

Item	m ³ /day	m ³ /hr	m ³ /min	m ³ /sec
Maximum Daily Flow		0.0	0.00	0.000
Maximum Hourly Flow	0	0.0	0.00	0.000

(Year 2040)

Item	m ³ /day	m ³ /hr	m ³ /min	m ³ /sec
Maximum Daily Flow	264,000	11,000.0	183.33	3.056
Maximum Hourly Flow	396,000	16,500.0	275.00	4.583

1-4 Design Sewage Quality

Item	BOD	SS	T-N	Coli-group	Oil&Greese
	(mg/l)	(mg/l)	(mg/l)	(MPN/cm ³)	(mg/l)
Influent	200	180	-	-	-
Effluent	20	30	-	3,000	5

1-5 Process Flow Diagram




表 I.5 E3 処理場 容量計算書 (3/11)

1.6 Design Criteria

ITEMS	UNIT	Formula or Value	Application
1 Grit Chamber (For Maximum Hourly Flow)			
(1) Hydraulic Load	m ³ /m ² /day	1,800	1,800
(2) Average Velocity	m/sec	0.3	0.3
2 Primary Sedimentation Tank (For Maximum Daily Flow)			
(1) Hydraulic Load	m ³ /m ² /day	35.0-70.0	50
(2) Settling Time (Ref.)	hour	1.5	1.5
(3) Water Depth	m	2.5-4.0	3.5
(4) Weir Loading	m ³ /m/day	250	250
3 Aeration Tank (For Maximum Daily Flow)			
(1) Hydraulic Retention Time (HRT)	hour	6 - 8	6.0
(2) MLSS Concentration	mg/l	1,500 -2,000	2,000
(3) BOD-SS Load (Reference only)	kg/kg/day	0.2 - 0.4	-
4 Final Sedimentation Tank (For Maximum Daily Flow)			
(1) Hydraulic Load	m ³ /m ² /day	20.0-30.0	25
(2) Settling Time (Ref.)	hour	3.0-4.0	-
(3) Water Depth	m	2.5-4.0	3.5
(4) Weir Loading	m ³ /m/day	150	150
5 Disinfection Tank (For Maximum Daily Flow)			
(1) Retention (Chlorination) Time	min	15	15
6 Gravity Thickener (For Maximum Daily Flow)			
(1) Solids Loading	kg/m ² /day	60-90	75
(2) Water Depth	m		4.0

表 I.5 E3 処理場 容量計算書 (4/11)

2 CAPACITY CALCULATION

2-1 Grit Chamber

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Parallel Flow Type		
Design Sewage Flow	Q1	m ³ /day			396,000
(Maximum Hourly Flow)	Q2	m ³ /sec			4.583
Water Surface Load	WSL	m ³ /m ² /day			1,800
Required Surface Area	RSA	m ²	Q1/WSL		220.00
Basin Number	BN	basin			4
Average Velocity	AV	m/sec			0.3
Depth	H	m			1
Width	W1	m	Q2/(AV×H×BN)		3.82
<i>Therefore</i>	W2	m			4.0
Length	L1	m	RSA/(W2×BN)		13.75
<i>Therefore</i>	L2	m			14.0
Dimension (Width)	W	m			4.0
(Length)	L	m	L2		14.0
(Depth)	H	m	H		1.0
(Basin Number)	N	basin			4
(Check)					
Water Surface Load		m ³ /m ² /day	Q1/(W×L×N)		1,768
Average Velocity		m/sec	Q2/(W×H×N)		0.286

2-2 Lift Pump Station

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Vertical shaft Volute type mixed flow pump		
Design Sewage Flow	Q1	m ³ /min	Peak Flow		275.00
Pump Unit -1 Number	UN1	unit			2
Discharge per Unit	DU1	m ³ /min	1/10×Q1		27.50
Pump Diameter(V=1.5~3.0m/s)	D1	mm	146×(DU1/1.5~3.0) ^{0.5}		442 ~ 625
<i>Therefore</i>	D1	mm			500
Pump Unit -2 Number	UN2	unit			2
Discharge per Unit	DU2	m ³ /min	2/10×Q1		55.00
Pump Diameter(V=1.5~3.0m/s)	D2	mm	146×(DU2/1.5~3.0) ^{0.5}		625 ~ 884
<i>Therefore</i>	D2	mm			700
Pump Unit -3 Number	UN3	unit	including 1 stand-by		2
Discharge per Unit	DU3	m ³ /min	4/10×Q1		110.00
Pump Diameter(V=1.5~3.0m/s)	D3	mm	146×(DU3/1.5~3.0) ^{0.5}		884 #####
<i>Therefore</i>	D3	mm			1000

表 I.5 E3 処理場 容量計算書 (6/11)

2-4 Aeration Tank

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Multi-tank Complete mixing Type		
Design Sewage Flow	Q1	m ³ /day			264,000
(Maximum Daily Flow)	Q2	m ³ /hr			11,000.0
Hydraulic Retention Time	HRT	hr			6.0
Basin Number	BN	basin			8
Required Volume per basin	RV	m ³ /basin	Q2×RT/BN		8,250
Width	W	m	1~2H		10.5
Water Depth	H	m	Deep Aeration Tank		10.0
Length	L1	m	RV/(W×H)		78.6
	<i>Therefore</i>	L2			78.0
Dimension					
(Width)	W	m			10.5
(Depth)	H	m			10.0
(Length)	L	m			78.0
(Basin Number)	N	basin			8
(Check)					
Hydraulic Retention Time	HRT	hour	W×H×L×N/Q2		6.0
BOD-SS load	BSS _L	kgBOD/kgSS/d	(Q1×BOD _{in})/(W×H×L×N×Xa)		0.24
BOD _{in} : Inflow BOD Concentration			120 mg/L	(Removal Rate in PST : 40%)	
Xa : MLSS Concentration			2,000 mg/L		
Aerobic Sludge Retention Time	ASRT	day	HRT/24×Xa / (a×S-BOD _{in} + b×SS _{in} - c×HRT/24×Xa) =		4.698
S-BOD _{in} : Inflow S-BOD Concentration			80 mg/L	(S-BOD[Solved BOD]=BOD _{in} ×0.6)	
SS _{in} : Inflow SS Concentration			90 mg/L	(Removal Rate in PST : 50%)	
a : Sludge converting ratio of solved BOD			0.5 mgMLSS/mgBOD	(0.4~0.6)	
b : Sludge converting ratio of SS			0.95 mgMLSS/mgSS	(0.9~1.0)	
c : Sludge reduction ratio caused by endogenous respiration			0.04 (1/day)	(0.03~0.05)	
Effluent Quality (C-BOD)	EQ	mg/L	10.42×A-SRT ^(-0.519) (15~20°C)		4.668
Water Temperature			20 °C		
Effluent Water Quality (C=BOD Maximum)			EQ×3	20mg/l >	14
					-OK-
			1 : 1.5 : 1.5 : 2.25		
Partition of Aeration Tank					
			No.1 No.2 No.3 No.4		
Total Length of Tank	TL	m			78.0
No.1 Tank Length	L1	m	TL×1/(1+1.5+1.5+2.25)		12.5
No.2 Tank Length	L2	m	TL×1.5/(1+1.5+1.5+2.25)		18.7
No.3 Tank Length	L3	m	TL×1.5/(1+1.5+1.5+2.25)		18.7
No.4 Tank Length	L4	m	TL×2.25/(1+1.5+1.5+2.25)		28.1
			Total		78.0

表 I.5 E3 処理場 容量計算書 (8/11)

2-6 Disinfection Channel

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Chlorination		
Design Sewage Flow	Q1	m ³ /day			264,000
(Maximum Daily Flow)	Q2	m ³ /min			183.3
Retention(Chlorination) Time	RT	min			15.0
Required Volume	RV	m ³	Q2×RT		2,750
Width of channel	W	m			3.0
Depth of channel	H	m			3.0
Pass Number	PN	pass			8
Length of channel	L1	m/pass	RV/(W×H×PN)		38.2
<i>Therefore</i>	L2	m/pass			38.5
Dimension (Width)	W	m			3.0
(Depth)	H	m			3.0
(Length)	L	m/pass			38.5
(Pass Number)	N	pass			8
(Check)					
Retention(Chlorination) Time	RT	min	(W×H×L×PN)/Q2		15.1

2-7 Sludge Thickening Tank

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Gravity Thickener (Radial Flow Circular Type)		
Generated Sludge Solids	GS	t-DS/day	Refer to Mass Balance Cal.		49.21
Generated Sludge Volume	GSV	m ³ /day	Refer to Mass Balance Cal.		6,197
Solid Matter Load	SML	kg/m ² /day			75
Required Surface Area	SA	m ²	(GS×10 ³)/SML		656.1
Water Depth	H	m			4.0
Basin Number	BN	basin			4
Required Tank Diameter	TD1	m	(SA×4/(3.14×BN)) ^{0.5}		14.46
<i>Therefore</i>	TD2	m			15.0
Dimension (Diameter)	D	m/basin			15.0
(Depth)	H	m			4.0
(Basin Number)	BN	basin			4
(Check)					
Solid Matter Load	SML	kg/m ² /day	GS×10 ³ /(3.14×D ² /4)×BN		69.7
Sludge Thickened Time	T	hr	(3.14×D ² /4)×H×BN×24/GSV		10.9

表 I.5 E3 処理場 容量計算書 (10/11)

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Mechanical Dewatering)

Table-1 Input Data

1. Calculation Manner		1: Premise that the quality of supernatants are same level removed with inlet sewage 2: Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency		1: Total Removal Ratio 2: Outlet Water Quality(input 1or2)
In case of 1: input data		(%)
In case of 2: input data		(mg/l)
3. Excess Sludge Generation		1: Consideration of Solid Matter Only 2: Consideration of Converting of Solved BOD (input 1or2)
In case of 1: input data (Sludge generation)		100 Sludge generation ratio per removal SS(%)
In case of 2: input data	a	$T2=Q2 \cdot S2=(a \cdot S_{acc} + b \cdot S1 \cdot c \cdot \theta \cdot XA) \cdot Q1 / 10^6$ (Excess sludge generation formula)
	b	a: Converting ratio of solved BOD(mg/MLSS mgBOD)
	c	b: Converting ratio of SS(mg/MLSS mgSS)
	SBOD	c: Sludge reduction ratio caused by endogenous respiration of activated sludge(1/day)
	XA	Sacc: Solved BOD quality at inlet to reactor
θ	XA: MLSS concentration(mg/l) θ: Hydraulic retention time(day)	


Table-2 Basic Conditions

Water Flow and Quality		Sludge Moisture and Recovery Ratio		Chemical Conditions for Dewatering	
*Inlet flow: Q0(m ³ D)	264000	*Primary sludge moisture ratio: W1(%)	93.3	*Removal ratio in primary tank: A2(%)	50.0
*Inlet quality: S0(mg/l)	180	*Excess sludge moisture ratio: W2(%)	99.3	*Recovery ratio in sludge thickener: A3(%)	90.0
*Total removal ratio: A1(%)	90.0	*Thickened sludge moisture ratio: W3(%)	98.0	*Recovery ratio in dewatering: A4(%)	95.0
*Effluent quality: S6(mg/l)		*Dewatered sludge moisture ratio: W4(%)	80.0		
*Sludge generation ratio per removal SS: S1(%)	100.0				

Table-3 Material Balance Calculation

	0	1	2	3	4	5	6	7	8	9	10	11	12	
Q(m ³ day)	264,000	270,206	1,823	268,383	4,374	264,009	2,214	3,882	221	2,426	212	2,222	6,206	263,788
T(t·DS/D)	47,520	54,678	27,339	27,339	21,871	5,468	44,289	4,921	0,443	44,732	42,495	2,237	7,158	5,025
S(mg/l)	180	202	15,000	102	5,000	21	20,000	1,236	7,000	18,364	200,000	1,006	1,153	21
X(1/10 ⁶)	100	115.1	57.5	57.5	46.0	11.5	93.2	10.4	0.9	94.1	89.4	4.7	15.1	10.6

Figure-1 Material Balance Model



Calculation Formula					
*Q0=Input Data	*Q3=Q1-Q2	*Q6=T4*100/(100-W3)	*Q9=Q6-Q8	*Q12=Q7+Q11	*Q5-1=Q5-Q8
*T0=Q0*S0*10 ⁻⁶ (γ-g)	*T3=T1*(100-A2)/100	*T6=(T2-T4)*A3/100	*T9=T6+T8	*T12=T7+T11	*T5-1=T5-T8
*S0=Input Data	*S3=T3*10 ⁻⁶ /Q3	*S6=10 ⁻⁶ *Q6/(100-W3)/100	*S9=T9*10 ⁻⁶ /Q9	*S11=T11*10 ⁻⁶ /Q11	*S5-1=S5
*Q1=Q0-Q13	*Q4=T4*100/(100-W2)	*Q7=(Q2-Q4)-Q6	*Q10=T10*100/(100-W4)		
*T1=T0-T13	*T4=(T1-T5)*S1/100)-T2	*T7=(T2-T4)-T5	*T10=T9+A4/100		
*S1=T1*10 ⁻⁶ /Q1	*S4=10 ⁻⁶ *Q4/(100-W2)/100	*S7=T7*10 ⁻⁶ /Q7	*S10=10 ⁻⁶ *Q10/(100-W4)/100		
*Q2=T2*100/(100-W1)	*Q5=Q3-Q4*(T1-T5)/T4	*Q8=T6*A5/A6	*Q11=Q9-Q10		
*T2=T1-T3	*T5=T1*(100-A1)/100	*T8=Q8*S3/10 ⁻⁶	*T11=T9-T10		
*S2=10 ⁻⁶ *Q2/(100-W1)/100	*S5=T5*10 ⁻⁶ /Q5	*S8=10 ⁻⁶ *A6	*S11=T11*10 ⁻⁶ /Q11		

表 I.5 E3 処理場 容量計算書 (11/11)

Material Balance Sheet




表 I.6 N1 処理場 容量計算書 (1/11)

1 BASIC CONDITIONS

1-1 Basic Items

- (1) Name : **N1 WWTP**
- (2) Land Area : Approximately xxxx ha
- (3) Ground Level (Elevation) : + 4.00 m (Plan)
- (4) Inlet Pipe Invert Level : - 5.82 m
- (5) Pipe Diameter : 1,650 mm
- (6) Land Use : —
- (7) Collection System : ~~Combined System~~ **Separate System**
- (8) Treatment Process : Conventional Activated Sludge Process
- (9) Effluent Point : Hlaing River
- (10) Water Level at the Effluent Point :
 High water level = 3.70 m
 Low water level = — m
- (11) Target Year : 2020 (F/S Stage)
 2040 (M/P Stage)

1-2 Service Area and Design Population

- (1) Service Area : 3,163 ha
- (2) Design Population

Item		Year 2020	Year 2040
Design Population	person	-	377,200

表 I.6 N1 処理場 容量計算書 (2/11)

1-3 Design Sewage Flow

(Year 2020)

Item	m ³ /day	m ³ /hr	m ³ /min	m ³ /sec
Maximum Daily Flow		0.0	0.00	0.000
Maximum Hourly Flow	0	0.0	0.00	0.000

(Year 2040)

Item	m ³ /day	m ³ /hr	m ³ /min	m ³ /sec
Maximum Daily Flow	140,000	5,833.3	97.22	1.620
Maximum Hourly Flow	210,000	8,750.0	145.83	2.431

1-4 Design Sewage Quality

Item	BOD	SS	T-N	Coli-group	Oil&Grease
	(mg/l)	(mg/l)	(mg/l)	(MPN/cm ³)	(mg/l)
Influent	200	180	-	-	-
Effluent	20	30	-	3,000	5

1-5 Process Flow Diagram




表 I.6 N1 処理場 容量計算書 (3/11)

1.6 Design Criteria

ITEMS	UNIT	Formula or Value	Application
1 Grit Chamber (For Maximum Hourly Flow)			
(1) Hydraulic Load	m ³ /m ² /day	1,800	1,800
(2) Average Velocity	m/sec	0.3	0.3
2 Primary Sedimentation Tank (For Maximum Daily Flow)			
(1) Hydraulic Load	m ³ /m ² /day	35.0-70.0	50
(2) Settling Time (Ref.)	hour	1.5	1.5
(3) Water Depth	m	2.5-4.0	3.5
(4) Weir Loading	m ³ /m/day	250	250
3 Aeration Tank (For Maximum Daily Flow)			
(1) Hydraulic Retention Time (HRT)	hour	6 - 8	6.0
(2) MLSS Concentration	mg/l	1,500 -2,000	2,000
(3) BOD-SS Load (Reference only)	kg/kg/day	0.2 - 0.4	-
4 Final Sedimentation Tank (For Maximum Daily Flow)			
(1) Hydraulic Load	m ³ /m ² /day	20.0-30.0	25
(2) Settling Time (Ref.)	hour	3.0-4.0	-
(3) Water Depth	m	2.5-4.0	3.5
(4) Weir Loading	m ³ /m/day	150	150
5 Disinfection Tank (For Maximum Daily Flow)			
(1) Retention (Chlorination) Time	min	15	15
6 Gravity Thickener (For Maximum Daily Flow)			
(1) Solids Loading	kg/m ² /day	60-90	75
(2) Water Depth	m		4.0

表 I.6 N1 処理場 容量計算書 (4/11)

2 CAPACITY CALCULATION

2-1 Grit Chamber

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Parallel Flow Type		
Design Sewage Flow	Q1	m ³ /day			210,000
(Maximum Hourly Flow)	Q2	m ³ /sec			2.431
Water Surface Load	WSL	m ³ /m ² /day			1,800
Required Surface Area	RSA	m ²	Q1/WSL		116.67
Basin Number	BN	basin			4
Average Velocity	AV	m/sec			0.3
Depth	H	m			1
Width	W1	m	Q2/(AV×H×BN)		2.03
<i>Therefore</i>	W2	m			2.5
Length	L1	m	RSA/(W2×BN)		11.67
<i>Therefore</i>	L2	m			12.0
Dimension (Width)	W	m			2.5
(Depth)	L	m	L2		12.0
(Length)	H	m	H		1.0
(Basin Number)	N	basin			4
(Check)					
Water Surface Load		m ³ /m ² /day	Q1/(W×L×N)		1,750
Average Velocity		m/sec	Q2/(W×H×N)		0.243

2-2 Lift Pump Station

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Vertical shaft Volute type mixed flow pump		
Design Sewage Flow	Q1	m ³ /min	Peak Flow		145.83
Pump Unit -1 Number	UN1	unit			2
Discharge per Unit	DU1	m ³ /min	1/10×Q1/UN1		14.58
Pump Diameter(V=1.5~3.0m/s)	D1	mm	146×(DU1/1.5~3.0) ^{0.5}		322 ~455
<i>Therefore</i>	D1	mm			400
Pump Unit -2 Number	UN2	unit			2
Discharge per Unit	DU2	m ³ /min	2/10×Q1/UN2		29.17
Pump Diameter(V=1.5~3.0m/s)	D2	mm	146×(DU2/1.5~3.0) ^{0.5}		455 ~644
<i>Therefore</i>	D2	mm			500
Pump Unit -3 Number	UN3	unit	including 1 stand-by		2
Discharge per Unit	DU3	m ³ /min	4/10×Q1/UN3		58.33
Pump Diameter(V=1.5~3.0m/s)	D3	mm	146×(DU3/1.5~3.0) ^{0.5}		644 ~910
<i>Therefore</i>	D3	mm			700

表 I.6 N1 処理場 容量計算書 (6/11)

2-4 Aeration Tank

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Multi-tank Complete mixing Type		
Design Sewage Flow	Q1	m ³ /day			140,000
(Maximum Daily Flow)	Q2	m ³ /hr			5,833.3
Hydraulic Retention Time	HRT	hr			6.0
Basin Number	BN	basin			8
Required Volume per basin	RV	m ³ /basin	Q2×RT/BN		4,375
Width	W	m	1~2H		10.5
Water Depth	H	m	4.0m~6.0m		6.0
Length	L1	m	RV/(W×H)		69.4
	<i>Therefore</i> L2	m			70.0
Dimension					
(Width)	W	m			10.5
(Depth)	H	m			6.0
(Length)	L	m			70.0
(Basin Number)	N	basin			8
(Check)					
Hydraulic Retention Time	HRT	hour	W×H×L×N/Q2		6.0
BOD-SS load	BSS _L	kgBOD/kgSS/d	(Q1×BOD _{in})/(W×H×L×N×Xa)		0.24
BOD _{in} : Inflow BOD Concentration			120 mg/L (Removal Rate in PST : 40%)		
Xa : MLSS Concentration			2,000 mg/L		
Aerobic Sludge Retention Time	ASRT	day	HRT/24×Xa / (a×S-BOD _{in} + b×SS _{in} - c×HRT/24×Xa) =		4.785
S-BOD _{in} : Inflow S-BOD Concentration			80 mg/L (S-BOD[Solved BOD]=BOD _{in} ×0.6)		
SS _{in} : Inflow SS Concentration			90 mg/L (Removal Rate in PST : 50%)		
a : Sludge converting ratio of solved BOD			0.5 mgMLSS/mgBOD (0.4~0.6)		
b : Sludge converting ratio of SS			0.95 mgMLSS/mgSS (0.9~1.0)		
c : Sludge reduction ratio caused by endogenous respiration			0.04 (1/day)(0.03~0.05)		
Effluent Quality (C-BOD)	EQ	mg/L	10.42×A-SRT ^(-0.519) (15~20°C)		4.624
Water Temperature			20 °C		
Effluent Water Quality (C=BOD Maximum)			EQ×3	20mg/l >	14
					-OK-
			1 : 1.5 : 1.5 : 2.25		
Partition of Aeration Tank					
			No.1 No.2 No.3 No.4		
Total Length of Tank	TL	m			70.0
No.1 Tank Length	L1	m	TL×1/(1+1.5+1.5+2.25)		11.2
No.2 Tank Length	L2	m	TL×1.5/(1+1.5+1.5+2.25)		16.8
No.3 Tank Length	L3	m	TL×1.5/(1+1.5+1.5+2.25)		16.8
No.4 Tank Length	L4	m	TL×2.25/(1+1.5+1.5+2.25)		25.2
			Total		70.0

表 I.6 N1 処理場 容量計算書 (8/11)

2-6 Disinfection Channel

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Chlorination		
Design Sewage Flow	Q1	m ³ /day			140,000
(Maximum Daily Flow)	Q2	m ³ /min			97.2
Retention(Chlorination) Time	RT	min			15.0
Required Volume	RV	m ³	Q2×RT		1,458
Width of channel	W	m			2.0
Depth of channel	H	m			2.5
Pass Number	PN	pass			8
Length of channel	L1	m/pass	RV/(W×H×PN)		36.5
<i>Therefore</i>	L2	m/pass			37.0
Dimension (Width)	W	m			2.0
(Depth)	H	m			2.5
(Length)	L	m/pass			37.0
(Pass Number)	N	pass			8
(Check)					
Retention(Chlorination) Time	RT	min	(W×H×L×PN)/Q2		15.2

2-7 Sludge Thickening Tank

Item	Sign	Unit	Calculation	F/S	M/P
Type	-	-	Gravity Thickener (Radial Flow Circular Type)		
Generated Sludge Solids	GS	t-DS/day	Refer to Mass Balance Cal.		26.096
Generated Sludge Volume	GSV	m ³ /day	Refer to Mass Balance Cal.		3,286
Solid Matter Load	SML	kg/m ² /day			75
Required Surface Area	SA	m ²	(GS×10 ³)/SML		347.9
Water Depth	H	m			4.0
Basin Number	BN	basin			4
Required Tank Diameter	TD1	m	(SA×4/(3.14×BN)) ^{0.5}		10.53
<i>Therefore</i>	TD2	m			10.5
Dimension (Diameter)	D	m/basin			10.5
(Depth)	H	m			4.0
(Basin Number)	BN	basin			4
(Check)					
Solid Matter Load	SML	kg/m ² /day	GS×10 ³ /(3.14×D ² /4)×BN		75.4
Sludge Thickened Time	T	hr	(3.14×D ² /4)×H×BN×24/GSV		10.1

表 I.6 N1 処理場 容量計算書 (10/11)

Material Balance Calculation (Primary and Secondary Sedimentation Tank + Thickening Tank + Mechanical Dewatering)

Table-1 Input Data

1. Calculation Manner		1: Premise that the quality of supernatants are same level removed with inlet sewage 2: Premise that the entire supernatants are removed at treatment process
2. Selection of Treatment Efficiency		1: Total Removal Ratio 2: Outlet Water Quality (input 1 or 2)
In case of 1: input data		90 (%)
In case of 2: input data		(mg/l)
3. Excess Sludge Generation		1: Consideration of Solid Matter Only 2: Consideration of Converting of Solved BOD (input 1 or 2)
In case of 1: input data (Sludge generation)		100
In case of 2: input data	a	Sludge generation ratio per removal SS (%)
	b	$T2=Q2 \cdot S2=(a \cdot S_{BOD} + b \cdot S1 - c \cdot \theta \cdot XA) \cdot Q1 / 10 \cdot 6 \cdot \theta$ (Excess sludge generation formula)
	c	a: Converting ratio of solved BOD (mg/MLSS mgBOD)
	SBOD	b: Converting ratio of SS (mg/MLSS mgSS)
	XA	c: Sludge reduction ratio caused by endogenous respiration of activated sludge (1/day)
		S _{BOD} : Solved BOD quality at inlet to reactor
		XA: MLSS concentration (mg/l)
		θ: Hydraulic retention time (day)


Table-2 Basic Conditions

Water Flow and Quality		Sludge Moisture and Recovery Ratio		Chemical Conditions for Dewatering	
*Inlet flow: Q0 (m3/D)	140000	*Primary sludge moisture ratio: W1 (%)	99.5	*Removal ratio in primary tank: A2 (%)	50.0
*Inlet quality: S0 (mg/l)	180	*Excess sludge moisture ratio: W2 (%)	99.5	*Recovery ratio in sludge thickener: A3 (%)	90.0
*Total removal ratio: A1 (%)	90.0	*Thickened sludge moisture ratio: W3 (%)	98.0	*Recovery ratio in dewatering: A4 (%)	95.0
*Effluent quality: S1 (mg/l)	1	*Dewatered sludge moisture ratio: W4 (%)	80.0		
*Sludge generation ratio per removal SS: S1 (%)	100.0				
				*Chemical dosage: A5 (%)	1.0
				*Chemical dissolve concentration: A6 (%)	0.2

Table-3 Material Balance Calculation

	0	1	2	3	4	5	6	7	8	9	10	11	12	5-1
Q (m3/day)	140,000	143,291	967	142,324	2,320	140,005	1,174	2,112	117	1,292	113	1,179	3,291	139,887
T (t·DS/day)	25,200	28,996	14,498	14,498	11,598	2,900	23,487	2,610	0,235	23,721	22,535	1,186	3,796	2,665
S (mg/l)	180	202	15,000	102	5,000	21	20,000	1,736	2,000	18,364	200,000	1,006	1,153	21
X (g/100g)	100	115.1	57.5	57.5	46.0	11.5	92.2	10.4	0.9	94.1	89.4	4.7	15.1	10.6

Figure-1 Material Balance Model



Calculation Formula					
*Q0=Input Data	*Q3=Q1-Q2	*Q6=T4*100/(100-W3)	*Q9=Q6-Q8	*Q12=Q7-Q11	*Q5-1=Q5-Q8
*T0=Q0*S0*10^-6	*T3=T1*(100-A2)/100	*T6=(T2-T4)*A3/100	*T9=T6-T8	*T12=T7-T11	*T5-1=T5-T8
*S0=Input Data	*S3=T3*10^-6/Q3	*S6=10^-6*(100-W3)/100	*S9=T9*10^-6/Q9	*S11=T11*10^-6/Q11	*S5-1=S5
*Q1=Q0-Q13	*Q4=T4*100/(100-W2)	*Q7=Q3-Q4-Q6	*Q10=T10*100/(100-W4)		
*T1=T0-T13	*T4=((T1-T5)*S1/100)-T2	*T7=(T2-T4)-T6	*T10=T9*A4/100		
*S1=T1*10^-6/Q1	*S4=10^-6*(100-W2)/100	*S7=T7*10^-6/Q7	*S10=10^-6*(100-W4)/100		
*Q2=T2*100/(100-W1)	*Q5=Q3-Q4-T3-T5-T4	*Q8=T8*A5/A6	*Q11=Q9-Q10		
*T2=T1-T3	*T5=T1*(100-A1)/100	*T9=Q8*S8*10^-6	*T11=T9-T10		
S2=10^-6(100-W1)/100	*S5=T5*10^-6/Q5	*S8=10^-4*A6	*S11=T11*10^-6/Q11		

表 I.6 N1 処理場 容量計算書 (11/11)

Material Balance Sheet

